


325
9/10/44

POSTED
1944

PWAC-429
EXPERIMENTAL RESULTS OF FORCED
CONVECTION BOILING POTASSIUM HEAT
TRANSFER AND PRESSURE DROP TESTS

AEC RESEARCH AND DEVELOPMENT REPORT



P R A T T & W H I T N E Y A I R C R A F T
D I V I S I O N O F U N I T E D A I R C R A F T C O R P O R A T I O N

C A N E L

M I D D L E T O W N C O N N E C T I C U T

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

TID-4500 (31st Ed.) CATEGORY UC-80
REACTOR TECHNOLOGY

PWAC-429
EXPERIMENTAL RESULTS OF FORCED
CONVECTION BOILING POTASSIUM HEAT
TRANSFER AND PRESSURE DROP TESTS

AEC RESEARCH AND DEVELOPMENT REPORT

CONTRACT
AT(30-1)-2789



Issued
July 16, 1964

Printed in U.S.A. Price ~~\$2.00~~. Available from the Office of
Technical Services, Department of Commerce,
Washington 25, D.C.

P R A T T & W H I T N E Y A I R C R A F T
D I V I S I O N O F U N I T E D A I R C R A F T C O R P O R A T I O N

C A N E L

M I D D L E T O W N C O N N E C T I C U T

TABLE OF CONTENTS

| | <u>Page No.</u> |
|---|-----------------|
| Table of Figures ----- | 3 |
| I. Abstract ----- | 7 |
| II. Introduction and Summary ----- | 9 |
| III. Experimental Equipment ----- | 19 |
| A. Pump ----- | 19 |
| B. Throttle Valves ----- | 19 |
| C. Radiant Preheater ----- | 19 |
| D. Preboiler ----- | 19 |
| E. Test Boiler ----- | 19 |
| F. Superheater ----- | 30 |
| G. Condenser ----- | 30 |
| H. Miscellaneous ----- | 30 |
| 1. Auxiliary Valves ----- | 30 |
| 2. Calibration Tanks ----- | 30 |
| IV. Instrumentation ----- | 31 |
| A. Electromagnetic Flowmeter ----- | 31 |
| B. Differential Pressure Measurements ----- | 31 |
| C. Pressure Measurements ----- | 31 |
| D. Electric Power Measurements ----- | 31 |
| E. Liquid Level Measurements ----- | 31 |
| F. Thermocouples ----- | 34 |
| V. Experimental Procedure ----- | 35 |
| A. Boiler Heat Loss Calibration ----- | 35 |
| B. Condensing Coefficients ----- | 35 |
| C. Pressure Gage Zero Shift Calibration ----- | 35 |
| D. Preboiler Shell to Tube ΔT ----- | 36 |

| | <u>Page No.</u> |
|---|-----------------|
| VI. Experimental Results ----- | 38 |
| A. Test Boiler Heat Transfer and Pressure Drop Data ----- | 38 |
| B. Preboiler Heat Transfer and Pressure Drop Data ----- | 38 |
| C. Two-Phase Stability Experience ----- | 48 |
| 1. Preheater ----- | 48 |
| 2. Preboiler ----- | 48 |
| 3. Condenser ----- | 48 |
| 4. Miscellaneous System Stability Tests ----- | 52 |
| VII. Chemistry and Metallurgy ----- | 54 |
| A. Gas System ----- | 54 |
| B. Loop Bake Out ----- | 54 |
| C. Liquid Metal History ----- | 54 |
| 1. Potassium ----- | 54 |
| 2. Sodium ----- | 54 |
| D. Test Termination ----- | 54 |
| VIII. Analog Studies ----- | 62 |
| IX. Conclusions and Recommendations ----- | 63 |
| A. Heat Transfer ----- | 63 |
| B. Pressure Drop ----- | 63 |
| C. Stability ----- | 63 |
| D. General ----- | 63 |
| X. References ----- | 64 |
| Appendix A - Equation Representation of Data ----- | 67 |
| Appendix B - Sample Calculations for BKHT-1 ----- | 71 |
| Appendix C - Boiling Heat Transfer Correlation ----- | 79 |

TABLE OF FIGURES

| <u>Figure No.</u> | <u>Title</u> | <u>Page No.</u> |
|-------------------|--|-----------------|
| 1 | Condenser Section ----- | 8 |
| 2 | Range of Experimental Parameters ----- | 10 |
| 3 | Forced Convection Local Boiling Heat Transfer Coefficients for Potassium Inside a Serpentine Tube ----- | 11 |
| 4 | Comparison of Experimental Forced Convection Local Boiling Pressure Coefficient with the Martinelli-Lockhart Pressure Drop Correlation ----- | 12 |
| 5 | Serpentine Tube Boiler Mock-Up ----- | 13 |
| 6 | Description of Experimental Technique ----- | 14 |
| 7 | Test Boiler During Assembly ----- | 15 |
| 8 | Post-Test Photo of Test Boiler ----- | 16 |
| 9 | Haynes-25 Boiling Potassium Heat Transfer Loop ----- | 17 |
| 10 | Control Panel ----- | 18 |
| 11 | Simplified Schematic of Haynes-25 Boiling Potassium Heat Transfer Rig ----- | 20 |
| 12 | Forced Convection Alkali Metal Vaporization-Condensation Heat Transfer Rig ----- | 21 |
| 13 | Loop Schematic ----- | 23 |
| 14 | Helium System Schematic ----- | 24 |
| 15 | Component Specifications ----- | 25 |
| 16 | Pump Performance and System Pressure Drop ----- | 28 |
| 17 | Typical Serpentine Tube ----- | 29 |
| 18 | Electromagnetic Flowmeter Calibration ----- | 32 |
| 19 | Pretest Pressure Gage Calibration ----- | 33 |
| 20 | Experimental Relationship of Potassium and Sodium Vapor Pressure ----- | 37 |
| 21 | Experimental Data ----- | 39 |
| 22 | Forced Convection Local Boiling Heat Transfer Coefficients ----- | 45 |

| <u>Figure No.</u> | <u>Title</u> | <u>Page No.</u> |
|-------------------|---|-----------------|
| 23 | Band of Experimental Error ----- | 46 |
| 24 | Overall Heat Transfer Coefficient, U, for the Potassium Preboiler in the P&WA Boiling Potassium Heat Transfer Test ----- | 47 |
| 25 | Explanation of Preboiler Instability ----- | 49 |
| 26 | Typical Stable Flow Rate Oscillograph Record ----- | 50 |
| 27 | Typical Oscillograph Record of Flow Instabilities ----- | 51 |
| 28 | Potassium Loop Gas Purity Data ----- | 55 |
| 29 | Preboiler Effluent Gas Purity Measurement ----- | 56 |
| 30 | Test Boiler Gas Purity Measurement ----- | 57 |
| 31 | Superheating Boiler Effluent Gas Purity Measurement ----- | 58 |
| 32 | Potassium Analysis ----- | 59 |
| 33 | Test Boiler X-ray, Post-Test ----- | 61 |
| 34 | Nucleate Boiling Correlation ----- | 82 |
| 35 | Full Range Boiling Correlation ----- | 83 |
| 36 | Comparison of Experimental Data with the Full Range Boiling Correlation ----- | 84 |

EXPERIMENTAL RESULTS OF FORCED CONVECTION BOILING
POTASSIUM HEAT TRANSFER AND PRESSURE DROP TESTS



Prepared By: E. Bernstein
J. P. Petrek
G. J. Rose
J. J. Horan

Approved By: D. G. Randall
D. G. Randall

H. E. Means
H. E. Means

R. W. Kelly
R. W. Kelly

UNCLASSIFIED

CLASSIFICATION

H. E. Means

AUTHORIZED CLASSIFIER

July 9, 1964


DATE

I. ABSTRACT

Experimental forced-convection boiling potassium heat transfer and pressure drop data were obtained at 1725F in a horizontal zero gravity boiler tube. System stability tests were conducted and the results compared with an electric analog of the system. A distinct condensing interface was observed in the condenser. This is illustrated in Fig. 1.

CONDENSER SECTION

NOTE: DISTINCT CONDENSING INTERFACE CAN BE OBSERVED



II. INTRODUCTION AND SUMMARY

Pratt & Whitney Aircraft-CANEL recently finished a series of forced-convection high temperature (1725F) boiling potassium heat transfer tests in a zero gravity serpentine boiler tube. The test-obtained data provides the boiler designer with a significant start in the design of a once-through alkali metal boiler for space applications. A promising full range boiling correlation is described in the Appendix.

The resistance to heat transfer in wet and dry vapor was defined to 100 percent vapor quality in a 0.186 inch diameter boiler tube, made of Haynes-25 alloy. Superheated vapor (to 74F) was obtained. Two-phase pressure drop data was simultaneously obtained and compared with theoretical correlations. The range of experimental parameters investigated are tabulated in Fig. 2.

The heat transfer data shown in Fig. 3 demonstrates the tremendous change in heat transfer rates between low and high quality potassium vapor. The dry vapor region virtually sizes the boiler. The pressure drop data, plotted in Fig. 4, shows the influence of vapor quality on pressure drop. The experimental pressure drop is compared with the Martinelli-Lockhart two-phase pressure drop correlation. The correlation is bounded (+ 20 percent) by the experimental data. The boiler pressure drop has a strong influence on the size of the boiler, since the integrated driving force (ΔT) is significantly influenced by the pressure drop in the tube.

The localized nature of this data, as opposed to over-all data, allows the designer to use it over a wide range of pressures, temperatures, flow rates, heating fluids, heating methods and power conditions. The boiler designer utilizes this localized data by analytically traversing the length of the boiler tube, adjusting the resistance to heat transfer and fluid flow as the quality increases and recalculating the driving force (ΔT) for incremental lengths. These incremental lengths are integrated to obtain the required boiler tube length. Also, the system designer is now better able to select optimum temperature and flow levels. A typical result of this data is exemplified by the boiler mockup in Fig. 5.

In this experiment, a two-phase mixture was generated in a preboiler and vaporized an additional incremental amount in the test boiler. Heat was transferred to the test section by condensing potassium vapor on the shell side of the tube. Differential pressure measurement between the condensing potassium on the outside of the tube and the boiling potassium on the inside of the tube was converted to temperature differential by the application of the slope of the vapor pressure curve for potassium. The condensing resistance is near zero. The wall resistance was calculated using the Fourier heat conduction equation. Elimination of these resistances from the measured over-all resistance provided an accurate determination of the tube-side boiling heat transfer coefficient. A schematic description of the experimental technique is shown in Fig. 6. Photographs of the test boiler and experimental facility are shown in Figs. 7, 8, 9, and 10.

This experimental technique, employed by W. K. Woods at Massachusetts Institute of Technology in 1940, proved quite successful. It can be used to obtain local data for shell-side boiling, as in nuclear reactors, or tube side boiling, as employed in tube and shell heat exchangers. Some outstanding advantages of this experimental technique are:


1. Constant wall temperature data which is immediately applicable in the designer's equations.
2. The heat flux is precisely known and controlled, from which a heat transfer coefficient is calculated.
3. Simplicity and reliability of both the heaters and the instrumentation is of a high order.
4. Data is reproducible and highly accurate.
5. There is flexibility in selection of tube geometry or material.

RANGE OF EXPERIMENTAL PARAMETERS


| | |
|--|---------------|
| Potassium Flow Rate, lb/hr | 17-25 |
| Vapor Quality, % | 0-100 |
| Boiling ΔT , F | 2-170 |
| Boiling Temperature, F | 1625-1725 |
| Heat Flux in Test Boiler, Btu/hr ft ² | 17,000-52,000 |
| Max. Heat Flux in Pre-Boiler | 64,000 |
| Boiling Pressure, psia | 42-62 |
| Max. Vapor Velocity, ft/sec | 330 |
| Test Duration, hr | 3625 |
| Boiling Hours | 980 |

FIG 3


FORCED CONVECTION LOCAL BOILING HEAT TRANSFER COEFFICIENTS FOR POTASSIUM INSIDE A SERPENTINE TUBE




COMPARISON OF EXPERIMENTAL FORCED CONVECTION LOCAL BOILING PRESSURE COEFFICIENT WITH MARTINELLI-LOCKHART PRESSURE DROP CORRELATION



SERPENTINE TUBE BOILER MOCK-UP




DESCRIPTION OF EXPERIMENTAL TECHNIQUE




DRY VAPOR = WET VAPOR + 5% QUALITY INCREASE


TEST BOILER DURING ASSEMBLY



POST-TEST PHOTO OF TEST BOILER




HAYNES-25 BOILING POTASSIUM HEAT TRANSFER LOOP



P W A C - 4 2 9
F I G 9

E - 1 0 9 8 9

CONTROL PANEL



III. EXPERIMENTAL EQUIPMENT

The Haynes-25 alloy heat transfer rig was designed and fabricated at Pratt & Whitney Aircraft-CANEL from a conceptual design originated at Pratt & Whitney Aircraft-East Hartford. A detailed report, CNLM-4358, entitled "Engineering Report on the Design of the Pratt & Whitney Aircraft Forced Convection Alkali Metal Vaporization-Condensation Heat Transfer Rig" which describes this apparatus, was issued, January 18, 1963. A simplified schematic is shown in Fig. 11, with a pictorial sketch of the liquid metal loop in Fig. 12. A complete schematic of the liquid metal system is included in Fig. 13. The helium cover gas schematic is shown in Fig. 14. Detailed component specifications are tabulated in Fig. 15.

A. Pump (MSA Style I)

The pump is a low-flow, alternating-current, electromagnetic type, developing high shut-off head which was useful in loop stability evaluations. The pump performance curves are shown in Fig. 16.

B. Throttle Valves (Hoke 442, Modification 1)

The manually-operated throttle valves were especially designed for high temperature liquid metal service. The spring return was replaced by a positive manual return. The throttling characteristics were good; however, two of these valves were used in series to permit fine control at low flow rates and high pressure drops.

C. Radiant Preheater

The preheater raised the temperature of the liquid potassium from 800F to 1500F. Heat was radiated from "Hevi-Duty" clamshell heaters to a concentric 3/8-inch tube. The exit temperature was measured and manually controlled with a variable transformer.

D. Preboiler (P&WA Drawing No. 1033896)

The preboiler heated the flow to saturation temperature and vaporized the fluid to any desired quality. The fluid was heated and vaporized by condensing sodium on the outside of the tube. The sodium vapor was generated by Haynes-25 clad tubular heaters immersed in a pool of sodium below the tube.

Non-condensibles were removed by boiling the sodium and venting the vapor and gases until the pool was at the proper level. Experience in other experiments (Ref. 22) has shown that this technique removes all non-condensibles satisfactorily.

The tubular immersion heaters consisted of straight lengths of Kanthal A-1 resistance wire with nickel leads, insulated with MgO, and sheathed in 3/16-inch OD Haynes-25. The measured power factor of these heaters is unity which therefore simplified the task of measuring the power input to the boiling fluid. Heater power was manually controlled with a variable transformer.

Heat leakage was blocked by guard heaters. A pretest calibration established the power requirement of these heaters for zero heat loss (or gain) at any temperature level.

The preboiler tube is described in P&WA Drawing No. 1033897 and was identical, except for length, to the tube in the test boiler (Fig. 17).


E. Test Boiler (P&WA Drawing No. 1033898)

The test boiler accepted wet vapor from the preboiler and vaporized it to a slightly higher quality. Since the quality change is small, local heat transfer and pressure drop data is obtained.


The heating technique and heat leakage control was identical in all aspects to that described in Section III-D. The condensing fluid was potassium. The serpentine tube test section is described in P&WA Drawing No. 1033899 and pictured in Fig. 17.

Pertinent test boiler instrumentation included two differential pressure gages by which the pressure drop in the tube and the differential vapor pressure between the tube and shell were measured.

SIMPLIFIED SCHEMATIC OF HAYNES-25 BOILING POTASSIUM HEAT TRANSFER RIG



FORCED CONVECTION ALKALI METAL VAPORIZATION-CONDENSATION HEAT TRANSFER RIG



FORCED CONVECTION ALKALI METAL VAPORIZATION-CONDENSATION
HEAT TRANSFER RIG

(CONTINUED)

- A. VOLUMETRIC FLOW CALIBRATOR
- B. E. M. PUMP
- C. BYPASS VALVE
- D. THROTTLE VALVE
- E. THERMAL FLOW METER
- F. RADIANT PREHEATER (LOW FLOW)
- G. I²R PREHEATER LUGS (HIGH FLOW)
- H. BOILERS (3)
- I. Na CONDENSER
- J. Na FILL-DRAIN POT
- K. POTASSIUM FILL-DRAIN POT
- L. CONSTANT HEAT FLUX CONDENSER
- M. NAT'L CONVECTION CONDENSER
- N. E. M. FLOW METER
- O. VAPOR TRAPS
- P. PRESSURE TRANSMITTERS
- a. INSULATION
- b. CLAMSHELL HEATER
- c. HEAT DISTRIBUTOR
- d. INSULATION
- e. THERMOCOUPLE
- f. PRESSURE SHELL
- g. TEST SPECIMEN
- h. BOILING POTASSIUM
- i. SODIUM LIQUID, SODIUM VAPOR
- j. IMMERSION HEATER
- k. BAFFLE
- l. POTASSIUM LIQUID
- m. COOLANT AIR

LOOP SCHEMATIC

LEGEND

- | | | | |
|---|---------------------|---|-----------------|
| A | E.M. PUMP | H | VAPOR TRAPS |
| B | PREBOILER | I | CRYOGENIC TRAPS |
| C | TEST BOILER | J | CONTROL PANEL |
| D | SUPERHEAT BOILER | K | EXPANSION TANK |
| E | CONDENSER | L | He BOTTLES |
| F | CALIBRATION TANKS | M | CALORIMETER |
| G | FILL AND DUMP TANKS | N | FLOW METER |





FIG 14

HELIUM SYSTEM SCHEMATIC

LEGEND

- | | | | |
|---|---------------------|---|-----------------|
| A | E.M. PUMP | H | VAPOR TRAPS |
| B | PREBOILER | I | CRYOGENIC TRAPS |
| C | TEST BOILER | J | CONTROL PANEL |
| D | SUPERHEAT BOILER | K | EXPANSION TANK |
| E | CONDENSER | L | He BOTTLES |
| F | CALIBRATION TANKS | M | CALORIMETER |
| G | FILL AND DUMP TANKS | N | FLOW METER |



- * NEEDLE VALVE
- ⊞ REGULATOR —(NON BLEEDING)
- PRESSURE GAGE

COMPONENT SPECIFICATIONS

(P&WA LOOP DRAWING NO. 1033925; RIG DRAWING CLR 10404)

1. Pump (P&WA Drawing No. 1033448)

| | |
|-----------------------------------|--------------------------------------|
| Type | Electromagnetic Conduction Pump (AC) |
| Manufacturer | Mine Safety Appliances Co. |
| Duct dimensions, in. | 1/4 OD x 0.032 w |
| Design flow (280 volts), gpm | 1.5 |
| Design head rise (280 volts), psi | 131 |
| Shut-off head (280 volts), psi | 130 |
| Duct material | Type 316 stainless steel |

2. Preboiler (P&WA Drawing No. 1033896)

| | |
|--|-----------------|
| Shell OD, in. | 3.5 |
| Shell ID, in. | 3.0 |
| Tube OD, in. | 0.250 |
| Tube ID, in. | 0.186 |
| Type of boiler tube | Serpentine |
| Developed length of tube within shell, in. | 65.5 |
| Over-all length of tube within shell, in. | 57 |
| Design pressure (shell), psig | 80 |
| Design temperature (shell), F | 1800 |
| Design power (2-SKN 17109 heaters), Kw | 9 |
| Design time, hr | 1000 |
| Material | Haynes-25 alloy |
| Slope, degrees | 0.5 (upward) |

3. Test Boiler (P&WA Drawing No. 1033898)

| | |
|--|------------|
| Shell OD, in. | 3.5 |
| Shell ID, in. | 3.0 |
| Tube OD, in. | 0.250 |
| Tube ID, in. | 0.186 |
| Type of boiler tube | Serpentine |
| Developed length of tube within shell, in. | 10.35 |
| Over-all length of tube within shell, in. | 9 |

COMPONENT SPECIFICATIONS

(P&WA LOOP DRAWING NO. 1033925; RIG DRAWING CLR 10404)
(CONTINUED)

| | |
|---|-----------------------------|
| Design pressure (shell), psig | 80 |
| Design temperature (shell), F | 1800 |
| Design power (1-SKN 17110 heater), Kw | 1-3 |
| Design time, hr | 1000 |
| Material | Haynes-25 alloy |
| Slope, degrees | 0.5 (upward) |
| 4. <u>Superheat Boiler</u> (P&WA Drawing No. 1033900) | |
| Shell OD, in. | 3.5 |
| Shell ID, in. | 3.0 |
| Tube OD, in. | 0.250 |
| Tube ID, in. | 0.186 |
| Type of boiler tube | Serpentine |
| Developed length of tube within shell, in. | 41.4 |
| Over-all length of tube within shell, in. | 36 |
| Design pressure (shell), psig | 80 |
| Design temperature (shell), F | 1800 |
| Design power (2-SKN 17111 heaters), Kw | 5.5 |
| Design time, hr | 1000 |
| Material | Haynes-25 alloy |
| Slope, degrees | 0.5 (upward) |
| 5. <u>Vapor Traps</u> (P&WA Drawing No. 1033150) | |
| Type | Condensing |
| Diameter, in. | 1.5 |
| Length, in. | 8 |
| Loop side temperature, F | 400 |
| Gas side temperature, F | 70 |
| Internals | Wire mesh |
| 6. <u>Cryogenic Trap</u> (P&WA Drawing No. CC-103701) | |
| Cryogenic liquid | Liquid nitrogen |
| Filter material | Activated charcoal (CS1947) |

COMPONENT SPECIFICATIONS

(P&WA LOOP DRAWING NO. 1033925; RIG DRAWING CLR 10404)
(CONTINUED)

7. Valves

| | |
|----------------------|--------------------------|
| Hoke Part No. | THY 442 |
| Type | Needle |
| Orifice size, in. | 5/32 |
| Plug tip material | Stellite 6 |
| Body material | Type 316 stainless steel |
| Seal | Bellows |
| Bellows material | Type 347 stainless steel |
| Pipe connection, in. | 1/4 OD x 0.065 wall |
| Flow coefficient, Cv | 0.33 |
| P&WA part number | 1033461 |
| Hoke Part No. | HY 473 Mod 20 |
| Type | Needle |
| Orifice size, in. | 5/16 |
| Plug tip material | Stellite 6 |
| Body material | Type 316 stainless steel |
| Seal | Bellows |
| Bellows material | Type 347 stainless steel |
| Pipe connection, in. | 3/8 OD x 0.065 wall |
| Flow coefficient, Cv | 1.0 |
| P&WA part number | 1033418 |

8. Condenser (P&WA Drawing Nos. 1033452 and 1033460)

| | |
|----------------------|-----------------------|
| Type | Finned tube |
| Tube dimensions, in. | 0.250 OD x 0.032 wall |
| Tube material | Haynes-25 alloy |
| Fin dimensions, in. | 0.50 x 0.010 thk |
| Fin material | Haynes-25 alloy |
| Braze material | Coast Metal 52 |
| Fins thick | 30 |
| Length, ft | 14 |
| Slope, degrees | 2 (upward) |


9. Potassium Loop Fill and Drain Put (P&WA Drawing No. 1033254)

| | |
|-----------------------|-------------------------|
| LM filler porosity | 5-micron |
| LM getter material | Titanium sponge CS-1941 |
| Design temperature, F | 1600 |


FIG 16

PUMP PERFORMANCE AND SYSTEM PRESSURE DROP

(MSA STYLE 0.5-150 ELECTROMAGNETIC PUMP)



TYPICAL SERPENTINE TUBE



The differential pressure was converted to differential temperature using the slope of the potassium vapor pressure curve at the test temperature. A differential pressure of 1.0 psi represents 4.3F at 1700F. The differential temperature obtained by this technique is considered quite accurate, since the error in the ΔP measurement is estimated at no more than 2 percent of full-scale reading, or 0.18 psi.

This technique of heating with condensing metal vapors was chosen for the following reasons:

1. Uniform wall temperature data is achieved. This type of data is directly amenable to design computations.
2. Accurate temperature differences are obtained by pressure differential measurements.
3. Simple instrumentation requirements.
4. The heat flux is precisely known and controlled.

F. Superheater (P&WA Drawing No. 1033900)

The superheater was included as a calorimetric device from which the heat balance could be checked.

This component was identical in all aspects to the preboiler except for tube length. The condensing fluid was sodium.

Unfortunately, the two thermocouples designated to measure the exact amount of superheat at the exit of this boiler failed during preheating, eliminating its usefulness as a calorimeter.

G. Condenser (P&WA Drawings No. 1033452 and 1033460)

The condenser consisted of a single finned tube (30 fins/inch) in a near horizontal attitude (2 degrees upward). The first six feet of tubing was designed for forced convection cooling. An additional eight feet of finned tubing was included for natural convection cooling. Natural convection was adequate for all tests.

H. Miscellaneous

1. Auxiliary Valves (Hoke THY-442, Modification 1, and Hoke HY-473, Modification 20).

These manually-operated liquid metal throttle valves were especially designed for high temperature liquid metal service. The spring return was replaced by a positive return. They were all-welded, bellows-sealed needle valves.

2. Calibration Tanks (P&WA Drawing No. 1033256)

These devices, which were connected to the loop at the pump inlet, had several functions:

- a. They served as expansion tanks during single-phase preheating.
- b. They served as an accumulator (absorb pressure and mass fluctuations) during two-phase flow operation.
- c. They served as a flowmeter calibration device. The flowmeter was volumetrically calibrated by flowing from one tank into the other through the loop. The change in liquid level was measured and the time recorded. "J" probes were used in measuring the liquid level change and a stop watch was used to measure time (Ref. Section IV-A).

IV. INSTRUMENTATION

A. Electromagnetic Flowmeter (Fig. 18)

A 2266.2-gauss permanent magnet was placed around the tube downstream from the condenser. The voltage (0.15 - 0.20 mv) generated by the flowing potassium liquid was measured. The flow rate was calculated as follows:

$$\frac{Q}{E} = \frac{\beta d_i}{3.188} \times 10^4 \times \frac{1}{R}$$

$$\frac{1}{R} = \frac{1 + (d_i/d_o)^2}{2(d_i/d_o)} + \frac{P_f}{P_w} \frac{1 - (d_i/d_o)^2}{2(d_i/d_o)}$$

d_i = inside diameter, inches

d_o = outside diameter, inches

P_f = resistivity of fluid, ohms/cm

P_w = resistivity of tube wall, ohms/cm

β = magnetic field, gauss

Q = volumetric flow rate, gallons/minute

E = electrical output, millivolts

The calculated flow rate was lower than the calibrated flow rate (Fig. 18) by approximately 10 percent. The calibration was reproducible within 1 percent. The calibrated rate was used in all calculations.

B. Differential Pressure Measurements

Differential pressure measurements were obtained by Taylor Model 225TN114 differential pressure transmitters. An accuracy of 2 percent of scale reading was assured by pretest calibrations. The vendor-quoted speed of response (63.2 percent time) was one second.

C. Pressure Measurements

Liquid metal pressures were measured by Taylor Model 225TN5114 pressure transmitters. These transmitters were checked periodically with a precision Heiss gage which was used to measure the accumulator pressure. An accuracy of 2 percent of scale reading seems reasonable based on pretest calibration (Fig. 19) and instrument checks made during the test. The vendor-quoted speed of response (63.2 percent time) was one second.

D. Electric Power Measurements

Electric power into the immersion heaters was measured by Weston Type 904-1902004 multi-range voltmeters, and Weston Type 904-2903001, 904-2903004 multi-range ammeters. An instrument accuracy of 1/2 percent of full scale was verified by pretest calibration. Since the capacitance and inductance of the immersion heaters was shown to be insignificant, the power was taken as the product of volts and amperes.


E. Liquid Level Measurements (Ref. 21)

Liquid level measurements were taken at several places, primarily to establish proper operating levels and to obtain a volume-time calibration for the flowmeter.

Two "J" probes were installed in all tanks, although only one probe was electrically connected at any time. Twenty-two probes were used in the test rig. All probes functioned well during the duration

ELECTROMAGNETIC FLOWMETER CALIBRATION

MAGNET NO.: P&WA-38
GAUSS: 2266.3
TUBE MATERIAL: HAYNES-25
TUBE OUTSIDE DIAMETER: 0.250"
TUBE INSIDE DIAMETER: 0.186"
LIQUID: POTASSIUM



PRETEST PRESSURE GAGE CALIBRATION

| Standard (psig) | <u>Pressure Gages</u> | | | | | | |
|-----------------|-----------------------|-------|------|-------|-------|------|-------|
| | 5.0 | 10.0 | 15.0 | 20.0 | 30.0 | 40.0 | 50.0 |
| PI-1 | 5.0 | 10.0 | 15.0 | 20.0 | 30.1 | 40.1 | 50.1 |
| PI-2 | 5.0 | 10.2 | 15.2 | 20.25 | 30.6 | 40.7 | 50.9 |
| PI-3 | 5.0 | 10.1 | 15.0 | 20.0 | 29.9 | 39.8 | 49.6 |
| PI-4 | 5.0 | 10.15 | 15.0 | 20.0 | 30.05 | 40.0 | 49.5 |
| PI-5 | 5.0 | 10.2 | 15.2 | 20.3 | 30.4 | 40.5 | 50.25 |
| PI-6 | 5.0 | 10.0 | 14.9 | 19.95 | 30.1 | 40 | 49.7 |
| PI-7* | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PI-8* | 0 | 0 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 |
| PI-9* | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PI-10* | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PI-11 | 5 | 10.1 | 15.0 | 20 | 30 | 40 | 49.8 |
| PI-21* | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

*Differential pressure gages at 0 psi

of the test. The "J" probes are described in P&WA Drawing No. L-101522. The levels in all except the accumulator tanks were indicated by millivolt indicators. The levels in these tanks were recorded on an oscillograph.

F. Thermocouples (P&WA Drawings No's. 1029530, 1029286, 1027164, Ref. 20).

Boiler thermocouples were Chromel/Alumel couples sheathed in 1/8-inch OD stainless steel.

Loop thermocouples were Chromel/Alumel wires tacked onto external surfaces with a condenser discharge welded, and spaced with MgO insulators.

The location of all pressure, preheater, temperature, and flow-sensing points is shown in Fig. 13.

V. EXPERIMENTAL PROCEDURES

Typically, the power into the first boiler (preboiler) was adjusted to obtain the required vapor quality at a set flow rate and pressure. The power in the second test boiler was set to obtain a desired heat flux. The test boiler was sized to minimize the quality change. The third boiler was set at a nominally low power, since a heat balance check from the superheated state was not possible because of failure of the exit thermocouples. When steady state conditions were obtained, data was recorded. Steady state operation was defined as that state when the flow, loop pressure, and differential pressure between the boiling liquid and condensing vapor was constant for more than 20 minutes.

Initially, the loop was brought to two-phase operation by lowering the pressure in the accumulator. During the life of the experiment (3625 total hours), two-phase data was taken during the day shift and the loop was operated in single-phase during the night shifts. Subsequent to the initial start, the loop converted from two-phase to single-phase operation by throttling the valve at the condenser exit and turning off the immersion heaters. Two-phase operation was initiated by reversing this procedure.

Heat loss calibrations were conducted initially and repeated periodically. The condensing resistance at the test section OD was found to be negligible.

A. Boiler Heat Loss Calibration

Zero heat leakage was maintained by external clamshell heaters placed around the boilers. The required heater power for zero heat loss was determined by recording the powerstat setting necessary to maintain a given boiler temperature with zero potassium flow and no immersion heat generation. These settings were maintained during the test to correspond to the test temperature. All heat generated by the immersion heaters was then presumed to go into the boiling process. This heat input was used, by means of a heat balance across the preboiler, to determine the vapor quality entering the test boiler; it was used in the test boiler to determine the average quality and the heat transfer coefficient.

B. Condensing Coefficients

The engineering literature indicates good agreement between Nusselt's Theory (Ref. 17) and liquid metal condensing data at low condensing rates (Reynolds Moduli). The condensing rates on the outside of the tube were quite low, and negligible condensing Δt 's were anticipated. Any error in the calculated condensing coefficient was assumed to be small. This was demonstrated in preliminary tests in the nucleate boiling regime. In this regime, the boiling coefficient is very high. If the condensing resistance were significant, a high over-all Δt would result. However, for a heat flux of approximately 20,000 Btu/hr ft² in the test section, the overall Δt was only 5F. Assuming no boiling resistance, this represents a maximum condensing Δt of 2F. A two-degree absolute error represents a small error in the boiling coefficient in the region of most interest (high quality, low h).

The Nusselt correlation (Ref. 17) indicates a 0.1F condensing Δt at a heat flux of 20,000 Btu/hr ft². This correlation was used in all calculations.

C. Pressure Gage Zero Shift Calibration

The over-all tube-to-shell temperature difference in the test boiler was obtained by measuring the tube-to-shell saturation pressure difference and converting the pressure difference to temperature difference using the slope of the potassium vapor pressure curve. In order to measure the tube-to-shell pressure difference as accurately as possible, it was necessary to devise a calibration technique by which the zero position of the differential pressure transmitter could be easily checked.

The calibration was performed by holding the preboiler at such temperature to only preheat the potassium to saturation conditions. Boiling was accomplished in the test boiler at some nominal heat input and flow rate. Heat loss in the test boiler was held constant at zero by proper adjustment of the guard heaters (Section V-A). The power to the test boiler immersion heater was then cut off, and the residual heat was removed through condensation on the test section until a zero temperature difference was attained between the shell vapor and tube inlet vapor. Since the same fluid was used in the shell and in the tube, the pressure differential approached zero. This was noted on the shell-to-

tube pressure differential gage as it approached a constant reading when the zero temperature difference was achieved. This reading was subtracted from the gage reading obtained during a typical test run. One-half of the tube side pressure drop across the test boiler tube was added to the shell and tube inlet differential pressure reading, and the result was considered to be the actual pressure differential between shell and tube. This ΔP was converted into temperature difference using the slope of the potassium vapor pressure curve.


D. Preboiler Shell-to-Tube ΔT

The preboiler shell side sodium vapor pressure gage reading was calibrated against the potassium tube-side vapor pressure reading at various temperature levels to obtain a relative vapor pressure relationship. This calibration was used in reducing the data of the preboiler to determine over-all shell-to-tube ΔT .

The calibration was performed at a zero-heat-loss condition, with no potassium flow. A constant sodium pressure controlled by the immersion heater was maintained on the shell side of the boiler. The potassium pressure was then decreased until a volume change was noted in the calibration expansion tank "J" probe. Readings of the potassium and sodium pressures were simultaneously recorded during this inventory change. The process was repeated by pressurizing the potassium until a drop in the "J" probe level reading was noted. It was found that the volume change occurred at a potassium pressure reproducible within 0.2 psi, whether raising or lowering the pressure. Various pressure levels were similarly calibrated and the results are shown in Fig. 20. Fig. 20 is not corrected for sodium and potassium head effects and is, therefore, directly applicable to the gage readings.

FIG 20

EXPERIMENTAL RELATIONSHIP OF POTASSIUM AND SODIUM VAPOR PRESSURE



VI. EXPERIMENTAL RESULTS

A. Test Boiler Heat Transfer and Pressure Drop Data

Heat transfer and pressure drop data was obtained within the range of experimental parameters indicated in Fig. 2. The data is included in tabular form in Fig. 21 and in graphic form in Figs. 3, 4, and 22. The data was represented by the equations in Appendix A, which were used in a computer program to design the boiler shown in Fig. 5. The heat transfer data indicates the following: 1) nucleate boiling extends to about 85 percent vapor quality for this tube (Fig. 3); 2) the effect of pressure and flow is small within the ranges tested; 3) the effect of heat flux is most noticeable in the nucleate boiling regime (Fig 22); 4) the data in the film-bound regime agrees with water data in a similar tube (Fig 22); 5) the data in the nucleate boiling regime departs from water data in a similar tube (Fig. 22).

The pressure drop data shows good agreement with the Martinelli-Lockhart two-phase pressure drop correlation (Fig. 4). When the straight tube correlation is multiplied by the ratio of single-phase friction factors at the vapor Reynolds Number for straight tubes and serpentine tubes (Ref. 22) the data bounds the correlation by ± 20 percent. The pressure drop for this serpentine tube is 24 percent greater than a straight tube.

An error analysis indicates the following:

Error Analysis

| | <u>High Quality Regime</u> | <u>Low Quality Regime</u> |
|---------------------------|--------------------------------|-------------------------------|
| Heat Transfer Coefficient | $\pm 5\%$ | $\pm 25\%$ |
| Quality | $\pm 5\%$ | $\pm 10\%$ |
| Pressure Drop | $\pm 5\%$ | $\pm 10\%$ |

The difference is experimental error between the high quality and the low quality regimes is primarily a result of the magnitude of the pressure differentials and heat input. Fig. 23 depicts a bank of experimental uncertainty which includes the above errors, as applied to the "h versus x" plots.

B. Preboiler Heat Transfer and Pressure Drop Data

The over-all data for this boiler is included in Figs. 21 and 24.

The over-all heat transfer data indicates a slight decrease for qualities greater than 85% vapor quality. This is consistent with the performance in the test boiler. A calculated U for the preboiler using local data from the test boiler agrees with the experimental U within 10 percent.

Observations of the shell side pressure during boiling initiation indicated that approximately 50F to 70F liquid superheat was required to initiate boiling. This was indicated by the following sequence of events:

1. Power into the preboiler was turned on with single-phase liquid flowing in the tube. A small (~ 1 psi) tube pressure drop was indicated.
2. The pressure in the shell rose and continued to rise a significant amount. The tube pressure drop was still small.
3. The tube side pressure drop rose a significant amount (5 psi) and the shell side pressure dropped. The increase in tube side pressure drop indicated initiation of boiling.

FIG 21

EXPERIMENTAL DATA

| Date | Run No. | Condenser-Discharge Static Pressure (psia) | Preboiler Tube-Side Pressure Drop (psi) | Test Boiler Tube-Side Pressure Drop (psi) | Mass Flow Rate (lb/hr) | Preboiler Boiling Heat Flux (Btu/hr-ft ²) | Test Boiler Boiling Heat Flux (Btu/hr-ft ²) | Preboiler Subcool ΔT, (F) | Preboiler Heat Into Preheat (Btu/hr) | Preboiler Heat Into Boiling (Btu/hr) |
|---------|---------|--|---|---|------------------------|---|---|---------------------------|--------------------------------------|--------------------------------------|
| 7/2/63 | 1 | 49.55 | 4.053 | 1.55 | 18.9 | 53,600 | 4,230 | 248.0 | 885 | 13,500 |
| | 2 | 48.84 | 3.817 | 1.464 | 16.4 | 48,900 | 4,230 | 194.7 | 606 | 12,500 |
| | 3 | 45.92 | 4.47 | 1.73 | 17.4 | 54,500 | 17,180 | 159.3 | 529 | 14,170 |
| | 4 | 48.11 | 3.98 | 1.63 | 17.4 | 50,700 | 17,560 | 127.8 | 427 | 13,173 |
| | 5 | 47.81 | 3.91 | 1.578 | 16.9 | 50,700 | 17,560 | 119.7 | 390 | 13,210 |
| | 6 | 48.21 | 3.93 | 1.60 | 17.3 | 50,700 | 17,560 | 119.2 | 397 | 13,200 |
| | 7 | 48.20 | 3.93 | 1.61 | 17.0 | 50,700 | 17,560 | 114.2 | 374 | 13,225 |
| | 8 | 48.19 | 3.95 | 1.588 | 16.5 | 51,800 | 17,560 | 222.2 | 693 | 13,157 |
| | 9 | 48.20 | 4.0 | 1.616 | 17.9 | 52,700 | 17,400 | 216.0 | 732 | 13,388 |
| | 10 | 48.86 | 4.043 | 1.68 | 18.15 | 53,100 | 17,180 | 213.0 | 732 | 13,388 |
| | 11 | 48.76 | 4.13 | 1.708 | 18.03 | 52,900 | 17,180 | 228.0 | 779 | 13,381 |
| 7/3/63 | 12 | 48.56 | 4.218 | 1.68 | 17.65 | 59,300 | 17,110 | 237.5 | 791 | 15,100 |
| | 13 | 48.36 | 3.87 | 1.61 | 17.65 | 51,000 | 17,110 | 222.5 | 744 | 12,906 |
| | 14 | 48.16 | 3.835 | 1.578 | 17.4 | 51,000 | 17,110 | 221.5 | 730 | 12,920 |
| | 15 | 48.46 | 3.80 | 1.58 | 15.9 | 51,000 | 16,570 | 225.0 | 679 | 12,971 |
| | 16 | 48.56 | 3.91 | 1.58 | 17.0 | 52,700 | 16,570 | 230.7 | 743 | 13,350 |
| | 17 | 48.66 | 3.945 | 1.57 | 16.9 | 52,400 | 16,570 | 228.0 | 729 | 13,320 |
| | 18 | 48.65 | 3.98 | 1.58 | 17.14 | 53,000 | 16,570 | 225.2 | 731 | 13,470 |
| | 19 | 48.84 | 4.11 | 1.64 | 17.32 | 50,200 | 16,570 | 225.1 | 738 | 12,610 |
| | 20 | 48.74 | 4.00 | 1.61 | 17.4 | 53,700 | 16,570 | 225.3 | 741 | 13,660 |
| | 21 | 53.34 | 3.62 | 1.55 | 17.27 | 51,800 | 18,000 | 200.0 | 657 | 13,220 |
| | 22 | 53.36 | 3.60 | 1.52 | 17.0 | 51,800 | 18,000 | 198.3 | 641 | 13,240 |
| | 23 | 53.36 | 3.60 | 1.53 | 17.14 | 51,800 | 18,000 | 198.3 | 647 | 13,233 |
| | 24 | 55.27 | 3.59 | 1.45 | 16.76 | 50,200 | 16,950 | 216.8 | 690 | 12,760 |
| 7/8/63 | 25 | 56.01 | 0.19 | 0.0469 | 17.26 | 4,488 | 17,087 | 278.2 | 899 | 305 |
| | 26 | 56.61 | 0.19 | 0.0505 | 16.63 | 4,488 | 17,337 | 251.2 | 785 | 419 |
| | 27 | 57.01 | 0.19 | 0.0505 | 16.63 | 2,507 | 17,337 | 246.8 | 772 | 0 |
| | 28 | 55.41 | 0.19 | 0 | 14.49 | 2,976 | 0 | 240.3 | 656 | 143 |
| 7/9/63 | 29 | 51.25 | 3.49 | 1.66 | 15.88 | 45,242 | 11,099 | 188.8 | 571 | 11,569 |
| | 30 | 51.05 | 3.48 | 1.62 | 19.15 | 45,678 | 17,007 | 170.0 | 622 | 11,634 |
| | 31 | 49.65 | 3.82 | 1.90 | 20.4 | 47,827 | 16,926 | 160.0 | 626 | 12,207 |
| | 32 | 53.91 | 0.19 | 0.029 | 17.77 | 2,840 | 677 | 239 | 798 | 0 |
| | 33 | 52.81 | 0.19 | 0 | 15.75 | 2,840 | 677 | 268 | 790 | 0 |
| | 34 | 53.71 | 0.19 | 0 | 16.38 | 2,840 | 677 | 270 | 828 | 0 |
| | 35 | 54.31 | 0.19 | 0 | 17.01 | 2,840 | 677 | 255 | 814 | 0 |
| | 36 | 55.11 | 0.19 | 0 | 17.01 | 2,840 | 677 | 259 | 826 | 0 |
| | 37 | 53.81 | 0.19 | 0 | 17.51 | 2,840 | 677 | 257 | 844 | 0 |
| | 38 | 53.71 | 0.19 | 0 | 17.64 | 2,840 | 677 | 252 | 834 | 0 |
| | 39 | 54.36 | 0.19 | 0 | 16.76 | 2,840 | 677 | 255 | 803 | 0 |
| | 40 | 54.36 | 0.19 | 0 | 16.76 | 2,840 | 6,770 | 255 | 803 | 0 |
| | 41 | 53.31 | 0.19 | 0 | 15.75 | 2,840 | 6,770 | 250 | 740 | 22 |
| 7/11/63 | 42 | 52.17 | 0.244 | 0 | 23.94 | 1,990 | 0 | 313 | 1395 | 0 |
| | 43 | 49.88 | 4.20 | 1.89 | 20.16 | 54,537 | 17,087 | 172 | 663 | 13,970 |
| | 44 | 49.78 | 4.14 | 1.90 | 19.53 | 54,319 | 17,087 | 173 | 646 | 13,929 |
| | 45 | 49.88 | 4.32 | 1.92 | 19.78 | 56,763 | 21,448 | 174 | 658 | 14,572 |
| | 46 | 50.08 | 4.25 | 1.85 | 19.78 | 56,540 | 17,256 | 168 | 636 | 14,535 |
| | 47 | 48.56 | 4.03 | 1.805 | 19.03 | 50,791 | 15,596 | 163 | 594 | 13,034 |
| | 48 | 49.76 | 4.02 | 1.77 | 18.77 | 51,001 | 15,596 | 161 | 578 | 13,106 |
| 7/12/63 | 49 | 54.29 | 0.19 | 0.032 | 17.64 | 1,408.1 | 17,764 | 184 | 615 | 0 |
| | 50 | 54.49 | 0.19 | 0.087 | 18.02 | 1,631.3 | 34,336 | 175 | 598 | 0 |
| | 51 | 55.39 | 0.19 | 0.022 | 18.27 | 1,755.4 | 17,426 | 148 | 515 | 0 |
| | 52 | 55.79 | 0.19 | 0.020 | 18.52 | 1,688.6 | 17,176 | 141 | 498 | 0 |
| | 53 | 52.19 | 3.55 | 1.393 | 16.63 | 48,781 | 8,350 | 174 | 552 | 0 |
| 7/17/63 | 54 | 55.77 | 0.19 | 0.0469 | 17.65 | 2,360 | 27,800 | 168 | 562 | 0 |
| | 55 | 57.35 | 0.19 | 0.0325 | 17.0 | 1,435 | 27,600 | 180 | 581 | 0 |
| | 56 | 56.05 | 0.19 | 0.0227 | 17.0 | 1,855 | 27,600 | 176 | 569 | 0 |
| 7/18/63 | 57 | 53.84 | 1.092 | 0.874 | 17.65 | 22,400 | 28,000 | 153 | 515 | 5,495 |
| | 58 | 54.72 | 3.29 | 1.60 | 17.75 | 45,300 | 28,300 | 243 | 816 | 11,334 |
| | 59 | 55.32 | 3.22 | 1.56 | 17.75 | 47,200 | 28,400 | 246 | 826 | 11,824 |
| | 60 | 55.32 | 3.37 | 1.61 | 17.40 | 49,000 | 28,400 | 252 | 828 | 12,302 |
| | 61 | 55.12 | 3.37 | 1.59 | 17.40 | 49,100 | 28,500 | 257 | 843 | 12,307 |
| | 62 | 54.91 | 3.44 | 1.64 | 17.0 | 49,400 | 28,500 | 253 | 812 | 12,438 |
| | 63 | 54.71 | 3.37 | 1.59 | 17.0 | 49,300 | 28,500 | 253 | 812 | 12,388 |
| | 64 | 55.51 | 3.04 | 1.46 | 16.65 | 46,300 | 28,400 | 249 | 783 | 11,647 |
| | 65 | 56.21 | 3.00 | 1.40 | 16.65 | 46,100 | 28,500 | 251 | 790 | 11,560 |
| 7/23/63 | 66 | 57.17 | 0.948 | 0.787 | 16.75 | 23,000 | 28,800 | 225 | 712 | 5,468 |
| | 67 | 57.27 | 0.966 | 0.733 | 16.90 | 23,100 | 16,900 | 224 | 716 | 5,488 |
| 7/22/63 | 68 | 56.02 | 0.19 | 0.141 | 17.65 | 1,755 | 39,400 | 196 | 656 | 0 |
| | 69 | 56.52 | 0.19 | 0.123 | 17.40 | 1,532 | 39,100 | 203 | 670 | 0 |
| 7/23/63 | 70 | 56.77 | 1.02 | 0.884 | 16.75 | 22,950 | 39,100 | 225 | 714 | 5,436 |
| | 71 | 56.97 | 0.984 | 0.845 | 17.00 | 23,000 | 39,100 | 225 | 724 | 5,456 |
| | 72 | 56.17 | 2.236 | 1.155 | 16.75 | 29,100 | 38,400 | 221 | 702 | 7,098 |
| | 73 | 54.39 | 3.071 | 1.61 | 17.40 | 46,600 | 38,600 | 238 | 784 | 11,716 |
| | 74 | 54.72 | 3.251 | 1.668 | 17.75 | 47,900 | 38,700 | 249 | 835 | 12,015 |
| | 75 | 54.25 | 3.281 | 1.66 | 17.40 | 49,250 | 38,700 | 251 | 825 | 12,375 |
| 7/24/63 | 76 | 55.18 | 1.265 | 1.097 | 18.25 | 27,400 | 39,800 | 228 | 787 | 6,553 |
| | 77 | 56.18 | 0.948 | 0.938 | 17.00 | 28,200 | 39,800 | 207 | 666 | 6,894 |
| | 78 | 56.58 | 3.251 | 1.075 | 17.00 | 25,900 | 39,800 | 237 | 762 | 6,178 |
| | 79 | 55.97 | 2.751 | 1.25 | 17.25 | 32,150 | 39,800 | 232 | 758 | 7,862 |
| | 80 | 55.97 | 3.251 | 1.54 | 17.25 | 45,400 | 41,000 | 231 | 755 | 11,445 |

(See last page of this figure for footnotes)

FIG 21

EXPEREMENTAL DATA

CONTINUED

| Run No. | Preboiler Exit Quality | Preboiler Average Tube to Shell ΔT (F) | Preboiler Over-all Heat Trans. Coefficient (Btu/hr-ft ² F) | Test Boiler Tube to Shell ΔT(e) (F) | Test Boiler Boiling ΔT(e) (F) | Test Boiler Local Heat Trans. Coeff. (e) (Btu/hr-ft ² F) | Test Boiler Boiling ΔT(f) (F) | Test Boiler Local Heat Trans. Coeff. (f) (Btu/hr-ft ² F) | Test Boiler Average Quality | Average Tube-Side Pressure in Test Boiler, psia |
|---------|------------------------|--|---|-------------------------------------|-------------------------------|---|-------------------------------|---|-----------------------------|---|
| 1 | 87.8 | 38.6 | 1389 | 23.0 | 22.3 | 189.7 | 22.6 | 187.2 | 90.8 | 58.43 |
| 2 | 93.3 | 42.7 | 1145 | 54.5 | 53.8 | 78.6 | c | -- | 94.0 | 57.06 |
| 3 | 99.8 | 46.4 | 1175 | 61.5 | 59.0 | 291.2 | c | -- | 100.4 | 55.76 |
| 4 | 92.8 | 32.4 | 1565 | 39.5 | 36.9 | 475.9 | 30.55 | 574.8 | 95.3 | 57.31 |
| 5 | 95.9 | 34.8 | 1457 | 60.0 | 57.4 | 305.9 | c | -- | 98.6 | 56.62 |
| 6 | 93.7 | 33 | 1536 | 66.0 | 63.4 | 277.0 | c | -- | 96.35 | 57.23 |
| 7 | 95.5 | 33.8 | 1500 | 70.5 | 67.9 | 258.6 | c | -- | 98.2 | 57.22 |
| 8 | 97.9 | 44.1 | 1175 | 78.0 | 75.4 | 232.9 | c | -- | 100.67 | 56.98 |
| 9 | 91.7 | 51.1 | 1031 | 79.5 | 76.95 | 226.1 | c | -- | 94.12 | 56.88 |
| 10 | 90.5 | 40 | 1328 | 78.0 | 75.5 | 227.5 | 25.40 | 676.4 | 93.0 | 57.81 |
| 11 | 91.1 | 33 | 1603 | 23.0 | 20.5 | 838.0 | c | -- | 93.57 | 58.28 |
| 12 | 104.8 | 38 | 1561 | b | -- | -- | b | -- | 100+ | 58.13 |
| 13 | 89.8 | 32.5 | 1569 | 53.0 | 50.5 | 338.8 | c | -- | 92.3 | 57.37 |
| 14 | 91.2 | 33.5 | 1522 | 39.0 | 36.5 | 468.8 | c | -- | 93.76 | 57.16 |
| 15 | 100.0 | 31.5 | 1619 | 42.5 | 40.05 | 413.7 | c | -- | 102.7 | 57.31 |
| 16 | 96.5 | 35.7 | 1476 | 56.5 | 54.05 | 306.6 | c | -- | 99.0 | 57.38 |
| 17 | 97.0 | 39.1 | 1340 | 36.5 | 34.05 | 486.6 | c | -- | 99.5 | 57.38 |
| 18 | 96.4 | 39.1 | 1355 | 61.0 | 58.55 | 283.0 | c | -- | 98.9 | 57.41 |
| 19 | 89.6 | 48.2 | 1041 | 65.5 | 63.05 | 262.8 | c | -- | 92.1 | 57.92 |
| 20 | 96.4 | 20 | 2685 | 43.5 | 41.05 | 403.7 | c | -- | 98.9 | 57.88 |
| 21 | 94.3 | 33.2 | 1560 | 30.8 | 28.15 | 636.0 | 32.04 | 561.8 | 97.0 | 61.92 |
| 22 | 95.9 | 28.4 | 1824 | 39.8 | 37.15 | 484.5 | c | -- | 98.65 | 61.82 |
| 23 | 95.1 | 28.7 | 1805 | 43.3 | 40.65 | 442.8 | c | -- | 97.83 | 61.82 |
| 24 | 93.7 | 27.2 | 1846 | g | -- | -- | 6.23 | 2,721 | 96.35 | 63.18 |
| 25 | 2.16 | 15.8 | a | g | -- | -- | 3.31 | 5,162 | 4.725 | 56.57 |
| 26 | 3.08 | 21.6 | a | g | -- | -- | 3.27 | 5,302 | 5.78 | 56.74 |
| 27 | 0 | 18.2 | a | g | -- | -- | 3.27 | 5,302 | 2.70 | 57.56 |
| 28 | 1.21 | 11.9 | a | g | -- | -- | -- | -- | -- | 58.77 |
| 29 | 89.72 | 21.2 | 2134 | g | -- | -- | 3.00 | 3,700 | 91.54 | 61.47 |
| 30 | 74.82 | 22.7 | 2012 | g | -- | -- | 3.49 | 4,873 | 77.135 | 61.53 |
| 31 | 73.79 | 24.2 | 1976 | g | -- | -- | 3.97 | 4,263 | 79.955 | 63.45 |
| 32 | 0 | a | -- | -- | -- | -- | 2.42 | 280 | 0.0985 | 54.66 |
| 33 | 0 | a | -- | -- | -- | -- | 2.63 | 257 | 0.1115 | 53.98 |
| 34 | 0 | a | -- | -- | -- | -- | 2.27 | 298 | 0.107 | 54.87 |
| 35 | 0 | a | -- | -- | -- | -- | 2.16 | 313 | 0.103 | 55.99 |
| 36 | 0 | a | -- | -- | -- | -- | 0.27 | 2,489 | 0.1035 | 56.71 |
| 37 | 0 | a | -- | -- | -- | -- | 2.43 | 278 | 0.100 | 56.31 |
| 38 | 0 | a | -- | -- | -- | -- | 2.43 | 278 | 0.0995 | 56.25 |
| 39 | 0 | a | -- | -- | -- | -- | 1.77 | 382 | 0.1045 | 57.57 |
| 40 | 0 | a | -- | -- | -- | -- | 1.47 | 4,612 | 1.045 | 57.56 |
| 41 | 0.171 | a | -- | -- | -- | -- | 1.47 | 4,612 | 1.286 | 57.29 |
| 42 | 0 | a | -- | -- | -- | -- | -- | -- | -- | 53.45 |
| 43 | 85.34 | 27 | 2020 | g | -- | -- | 3.79 | 4,304 | 87.55 | 61.88 |
| 44 | 87.84 | 27 | 2012 | 60.0 | 57.4 | 298 | 4.14 | 5,181 | 90.12 | 61.68 |
| 45 | 90.73 | 26 | 2183 | -- | -- | -- | 36.32 | 475.1 | 93.56 | 61.79 |
| 46 | 90.50 | 27 | 2094 | 60.0 | 57.4 | 301 | c | -- | 92.78 | 61.59 |
| 47 | 84.35 | 21 | 2419 | 63.0 | 60.64 | 257.2 | 3.81 | 4,093 | 86.49 | 59.85 |
| 48 | 85.99 | 26 | 1962 | 59.0 | 56.64 | 275.4 | 4.21 | 3,705 | 88.16 | 60.83 |
| 49 | 0 | a | -- | 28.5 | 25.82 | 688.0 | c | -- | 2.605 | 55.63 |
| 50 | 0 | a | -- | 36.5 | 31.42 | 1,093 | c | -- | 49.38 | 56.23 |
| 51 | 0 | a | -- | 39.0 | 36.37 | 479.1 | 3.86 | 4,515 | 2.47 | 56.46 |
| 52 | 0 | a | -- | 36.0 | 33.41 | 514.1 | 3.58 | 4,798 | 2.405 | 56.83 |
| 53 | 0 | a | -- | 61.0 | 59.69 | 139.9 | c | -- | 1.31 | 60.31 |
| 54 | 0 | a | -- | -- | -- | -- | 1.85 | 15,000 | 4.08 | 57.62 |
| 55 | 0 | a | -- | -- | -- | -- | 1.87 | 14,800 | 4.23 | 59.03 |
| 56 | 0 | a | -- | -- | -- | -- | 1.56 | 17,700 | 4.23 | 58.13 |
| 57 | 38.1 | 46 | 487 | -- | -- | -- | 0.88 | 31,800 | 42.23 | 58.30 |
| 58 | 78.6 | 24 | 1888 | -- | -- | -- | 1.21 | 23,400 | 82.76 | 63.13 |
| 59 | 81.9 | 24 | 1967 | -- | -- | -- | 1.72 | 16,500 | 86.08 | 63.44 |
| 60 | 87.0 | 27 | 1815 | -- | -- | -- | 2.73 | 10,400 | 91.26 | 63.86 |
| 61 | 87.0 | 26 | 1888 | -- | -- | -- | 18.77 | 1,520 | 91.28 | 63.46 |
| 62 | 90.3 | 30 | 1647 | -- | -- | -- | 34.77 | 821 | 94.68 | 63.31 |
| 63 | 89.5 | 34 | 1450 | -- | -- | -- | 34.67 | 823 | 93.87 | 63.08 |
| 64 | 86.1 | 30 | 1543 | -- | -- | -- | 17.08 | 1,665 | 90.55 | 62.53 |
| 65 | 85.9 | 27 | 1707 | -- | -- | -- | 35.27 | 807 | 90.37 | 63.02 |
| 66 | 40.1 | 30 | 766.7 | -- | -- | -- | 0.84 | 34,300 | 44.74 | 61.24 |
| 67 | 39.9 | 31 | 745.2 | -- | -- | -- | 0.70 | 24,150 | 42.51 | 60.94 |
| 68 | 0 | a | -- | -- | -- | -- | 2.59 | 15,200 | 5.8 | 61.50 |
| 69 | 0 | a | -- | -- | -- | -- | 1.90 | 20,600 | 5.85 | 61.79 |
| 70 | 39.9 | 31 | 740.3 | -- | -- | -- | 0.93 | 42,100 | 46.0 | 61.12 |
| 71 | 39.4 | 30 | 766.7 | -- | -- | -- | 0.85 | 46,000 | 45.88 | 61.14 |
| 72 | 52.1 | 32 | 909.4 | -- | -- | -- | 1.53 | 25,100 | 58.08 | 61.21 |
| 73 | 83 | 30 | 1553 | -- | -- | -- | 12.80 | 3,010 | 88.78 | 62.71 |
| 74 | 83.5 | 26 | 1842 | -- | -- | -- | 3.47 | 11,150 | 89.18 | 63.75 |
| 75 | 87.6 | 26 | 1894 | -- | -- | -- | 60.5 | 635 | 93.4 | 62.95 |
| 76 | 44.3 | 35 | 782.9 | -- | -- | -- | 1.17 | 34,000 | 49.98 | 61.61 |
| 77 | 49.7 | 58 | 486.2 | -- | -- | -- | 1.91 | 20,850 | 53.9 | 61.81 |
| 78 | 44.4 | 8 | 3238 | -- | -- | -- | 1.43 | 27,800 | 50.5 | 62.68 |
| 79 | 56.1 | 13 | 2473 | -- | -- | -- | 1.53 | 26,000 | 58.15 | 62.96 |
| 80 | 81.8 | 25 | 1816 | -- | -- | -- | 6.75 | 6,070 | 88.0 | 64.09 |

(See last page of this figure for footnotes)

FIG 21

EXPERIMENTAL DATA

CONTINUED

| Date | Run No. | Condenser-Discharge Static Pressure (psia) | Preboiler Tube-Side Pressure Drop (psi) | Test Boiler Tube-Side Pressure Drop (psi) | Mass Flow Rate (lb/hr) | Preboiler Boiling Heat Flux (Btu/hr-ft ²) | Test Boiler Boiling Heat Flux (Btu/hr-ft ²) | Preboiler Subcool ΔT, (F) | Preboiler Heat Into Prehear (Btu/hr) | Preboiler Heat Into Boiling (Btu/hr) |
|----------|---------|--|---|---|------------------------|---|---|---------------------------|--------------------------------------|--------------------------------------|
| 7/26/63 | 81 | 54.72 | 3.285 | 1.625 | 17.14 | 27,200 | 52,600 | 220 | 716 | 11,083 |
| | 82 | 54.42 | 3.267 | 1.79 | 17.26 | 33,600 | 52,700 | 226 | 740 | 11,672 |
| 7/29/63 | 83 | 56.99 | 0.19 | 0.130 | 17.39 | 6,550 | 51,300 | 203 | 669 | 1,084 |
| | 84 | 57.98 | 0.19 | 0.1083 | 17.51 | 1,755 | 51,800 | 202 | 671 | 0 |
| 7/31/63 | 85 | 58.18 | 0.19 | 0.00721 | 17.64 | 2,050 | 16,750 | 219 | 730 | 0 |
| | 86 | 56.37 | 0.19 | 0.0433 | 17.77 | 2,025 | 28,000 | 208 | 699 | 0 |
| | 87 | 57.37 | 0.19 | 0.0758 | 17.01 | 2,025 | 39,800 | 213 | 685 | 0 |
| | 88 | 58.06 | 0.19 | 0.1083 | 16.76 | 1,725 | 51,500 | 218 | 691 | 0 |
| 8/2/63 | 89 | 53.87 | 3.51 | 1.75 | 17.51 | 50,371 | 43,443 | 251 | 830 | 12,674 |
| 8/5/63 | 90 | 55.78 | 3.31 | 1.49 | 17.26 | 43,070 | 33,207 | 191 | 630 | 10,916 |
| | 91 | 53.58 | 3.98 | 1.68 | 17.26 | 43,070 | 33,207 | 204 | 669 | 10,877 |
| | 92 | 57.17 | 3.44 | 1.35 | 17.64 | 40,882 | 31,676 | 236 | 789 | 10,171 |
| 8/6/63 | 93 | 57.04 | 3.26 | 1.23 | 16.63 | 50,371 | 4,103 | 233 | 735 | 12,769 |
| | 94 | 52.65 | 4.11 | 1.65 | 18.27 | 54,696 | 4,103 | 241 | 834 | 13,829 |
| | 95 | 51.46 | 4.23 | 1.61 | 17.89 | 57,316 | 6,964 | 252 | 851 | 14,514 |
| 8/7/63 | 96 | 59.87 | 3.04 | 1.20 | 17.01 | 46,517 | 4,272 | 246 | 792 | 11,678 |
| | 97 | 52.26 | 2.97 | 1.32 | 17.64 | 38,465 | 4,272 | 217 | 725 | 9,587 |
| 8/8/63 | 98 | 42.84 | 2.93 | 1.47 | 17.67 | 43,070 | 16,604 | 235 | 785 | 10,761 |
| | 99 | 53.93 | 2.90 | 1.29 | 17.26 | 42,396 | 12,090 | 234 | 764 | 10,602 |
| | 100 | 55.0 | 2.83 | 1.34 | 17.01 | 42,396 | 24,019 | 239 | 769 | 10,597 |
| | 101 | 55.0 | 2.86 | 1.39 | 16.63 | 42,396 | 32,240 | 240 | 755 | 10,611 |
| 8/9/63 | 102 | 51.29 | 3.62 | 2.31 | 25.83 | 46,377 | 31,998 | 296 | 1441 | 10,992 |
| | 103 | 54.47 | 3.22 | 1.93 | 25.2 | 42,266 | 23,777 | 222 | 1068 | 10,260 |
| | 104 | 55.05 | 3.55 | 1.97 | 25.2 | 42,266 | 16,537 | 230 | 1104 | 10,224 |
| 8/10/63 | 105 | 51.69 | 4.12 | 1.88 | 20.79 | 50,676 | 11,284 | 203 | 803.9 | 12,781 |
| | 106 | 51.51 | 4.12 | 1.92 | 20.79 | 50,676 | 16,587 | 203 | 803.9 | 12,781 |
| | 107 | 51.61 | 4.14 | 1.98 | 20.79 | 50,676 | 23,938 | 195 | 774 | 12,811 |
| 8/11/63 | 108 | 52.45 | 3.87 | 1.98 | 20.79 | 50,676 | 32,562 | 235 | 928 | 12,657 |
| | 109 | 52.35 | 4.88 | 2.07 | 20.16 | 59,199 | 32,699 | 227 | 869 | 15,001 |
| 8/12/63 | 110 | 4.53 | 3.26 | 1.88 | 24.57 | 42,116 | 16,587 | 246 | 1145 | 10,146 |
| | 111 | 56.13 | 3.51 | 1.98 | 24.57 | 45,092 | 16,990 | 257 | 1197 | 10,891 |
| | 112 | 53.93 | 3.22 | 1.85 | 24.57 | 38,783 | 16,741 | 246 | 1145 | 9,252 |
| | 113 | 53.53 | 2.97 | 1.70 | 24.82 | 35,591 | 16,741 | 240 | 1129 | 8,412 |
| | 114 | 52.73 | 2.79 | 1.57 | 24.28 | 32,411 | 16,741 | 235 | 1081 | 7,607 |
| 8/13/63 | 115 | 51.41 | 2.48 | 1.44 | 24.57 | 32,690 | 1,752 | 212 | 988 | 7,783 |
| | 116 | 51.21 | 2.59 | 1.48 | 24.57 | 32,818 | 1,699 | 202 | 943 | 7,862 |
| | 117 | 57.38 | 2.0 | 1.12 | 25.20 | 26,076 | 16,749 | 209 | 998 | 5,999 |
| 8/14/63 | 118 | 52.24 | 3.62 | 2.04 | 24.82 | 45,169 | 6,587 | 235 | 1106 | 11,013 |
| | 119 | 51.84 | 3.98 | 2.21 | 24.82 | 48,272 | 16,749 | 227 | 1070 | 11,882 |
| | 120 | 51.67 | 4.16 | 2.31 | 24.82 | 48,272 | 16,749 | 216 | 1021 | 11,931 |
| | 121 | 52.99 | 5.44 | 2.35 | 25.20 | 51,567 | 16,749 | 235 | 893 | 12,943 |
| | 122 | 51.10 | 4.70 | 2.47 | 25.20 | 54,696 | 16,749 | 240 | 912 | 13,764 |
| | 123 | 51.72 | 4.80 | 2.49 | 25.20 | 57,863 | 16,749 | 246 | 934 | 14,592 |
| 8/15/63 | 124 | 52.53 | 3.15 | 1.58 | 20.79 | 42,396 | 16,749 | 195 | 774 | 10,601 |
| | 125 | 52.33 | 3.38 | 1.66 | 20.79 | 45,309 | 16,749 | 223 | 879 | 11,278 |
| | 126 | 52.43 | 3.66 | 1.64 | 20.79 | 48,272 | 16,749 | 209 | 826 | 12,126 |
| | 127 | 53.83 | 3.98 | 1.76 | 20.79 | 51,402 | 16,749 | 227 | 896 | 12,896 |
| | 128 | 22.2 | 4.20 | 1.80 | 20.79 | 54,849 | 16,749 | 215 | 850 | 13,867 |
| 8/16/63 | 129 | 17.0 | 3.26 | 1.60 | 20.79 | 42,256 | 4,070 | 188 | 745 | 10,593 |
| | 130 | 18.6 | 3.55 | 1.64 | 20.79 | 45,169 | 4,070 | 187 | 741 | 11,378 |
| | 131 | 20.9 | 3.96 | 1.76 | 21.04 | 48,272 | 4,070 | 199 | 798 | 12,154 |
| 8/20/63 | 132 | 16.2 | 3.11 | 1.52 | 19.53 | 42,256 | 17,168 | 212 | 786 | 10,552 |
| | 133 | 16.0 | 3.08 | 1.48 | 19.53 | 42,256 | 17,168 | 218 | 808 | 10,530 |
| 8/29/63 | 134 | 0 | 0.19 | 0.022 | 25.2 | 2,099 | 17,278 | 209 | 996 | 0 |
| | 135 | 0 | 0.19 | 0.054 | 25.2 | 2,671 | 28,720 | 239 | 1135 | 0 |
| | 136 | 0 | 0.19 | 0.087 | 24.7 | 2,636 | 28,720 | 191 | 895 | 0 |
| | 137 | 0 | 0.19 | 0 | 24.57 | 2,636 | 15,927 | 188 | 876 | 0 |
| | 138 | 0 | 0.19 | 0 | 24.07 | 2,636 | 20,875 | 199 | 908 | 0 |
| 8/30/63 | 139 | 26.8 | 5.03 | 2.21 | 21.8 | 63,473 | 17,845 | 255 | 1053 | 15,978 |
| | 140 | 26.4 | 4.96 | 2.34 | 21.8 | 63,740 | 29,355 | 241 | 997 | 16,105 |
| | 141 | 26.4 | 4.96 | 2.35 | 21.8 | 63,473 | 29,459 | 243 | 1005 | 16,026 |
| 9/19/63 | 142 | 54.46 | 4.36 | 1.74 | 18.65 | 59,034 | 24,502 | 252 | 889 | 14,951 |
| 10/8/63 | 143 | 52.84 | 4.16 | 1.69 | 18.5 | 51,096 | 17,087 | 244 | 855 | 12,855 |
| | 144 | 53.35 | 3.98 | 1.56 | 17.1 | 53,946 | 17,087 | 248 | 802 | 13,672 |
| | 145 | 53.77 | 4.11 | 1.44 | 17.0 | 57,698 | 17,087 | 247 | 794 | 14,687 |
| | 146 | 53.18 | 3.80 | 1.36 | 17.0 | 50,066 | 17,087 | 238 | 765 | 12,668 |
| 10/29/63 | 147 | 54.89 | 1.60 | 0.942 | 17.39 | 28,162 | 38,688 | 232 | 762 | 6,794 |
| | 148 | 54.89 | 1.58 | 0.928 | 17.39 | 28,162 | 38,688 | 227 | 746 | 6,810 |
| | 149 | 54.59 | 1.63 | 0.928 | 17.39 | 28,162 | 38,688 | 221 | 727 | 6,829 |
| | 150 | 54.48 | 1.72 | 0.935 | 17.39 | 27,984 | 38,688 | 221 | 727 | 6,782 |
| | 151 | 55.88 | 1.90 | 0.892 | 17.51 | 28,938 | 29,999 | 272 | 896 | 6,869 |
| | 152 | 55.88 | 1.98 | 0.899 | 17.51 | 28,938 | 29,999 | 257 | 849 | 6,916 |
| | 153 | 55.68 | 2.16 | 0.910 | 17.51 | 29,938 | 29,999 | 248 | 819 | 6,946 |

(See last page of this figure for footnotes)

FIG 21

EXPEREMENTAL DATA

CONTINUED

| Run No. | Preboiler Exit Quality | Preboiler Average Tube to Shell ΔT (F) | Preboiler Over-all Heat Trans. Coefficient (Btu/hr-ft ² F) | Test Boiler Tube to Shell ΔT(e) (F) | Test Boiler Boiling ΔT(e) (F) | Test Boiler Local Heat Trans. Coeff. (e) (Btu/hr-ft ² F) | Test Boiler Boiling ΔT(f) (F) | Test Boiler Local Heat Trans. Coeff. (f) (Btu/hr-ft ² F) | Test Boiler Average Quality | Average Tube-Side Pressure in Test Boiler, psia |
|---------|------------------------|--|---|-------------------------------------|-------------------------------|---|-------------------------------|---|-----------------------------|---|
| 81 | 79.6 | 25 | 1088 | -- | -- | -- | 6.23 | 8,443 | 87.6 | 63.20 |
| 82 | 83.3 | 26 | 1292 | -- | -- | -- | 30.0 | 1,757 | 91.2 | 63.37 |
| 83 | 7.46 | 8 | 818.8 | -- | -- | -- | 2.68 | 19,142 | 15.29 | 61.72 |
| 84 | 0 | a | -- | -- | -- | -- | 2.52 | 20,556 | 7.7 | 62.69 |
| 85 | 0 | a | -- | -- | -- | -- | 0.96 | 17,448 | 2.47 | 60.08 |
| 86 | 0 | a | -- | -- | -- | -- | 1.83 | 15,301 | 4.09 | 58.68 |
| 87 | 0 | a | -- | -- | -- | -- | 1.69 | 23,550 | 6.08 | 59.84 |
| 88 | 0 | a | -- | -- | -- | -- | 1.88 | 27,394 | 7.98 | 60.87 |
| 89 | 89.14 | 24 | 2099 | 37.0 | 30.6 | 1,420 | c | -- | 95.59 | 63.12 |
| 90 | 77.89 | 20 | 2154 | d | -- | -- | c | -- | 82.89 | 64.22 |
| 91 | 77.61 | 25 | 1723 | 55.0 | 50.1 | 663 | c | -- | 82.61 | 62.19 |
| 92 | 71.0 | 20 | 2044 | d | -- | -- | d | -- | 75.65 | 64.49 |
| 93 | 94.68 | 22 | 2290 | d | -- | -- | d | -- | 95.32 | 64.52 |
| 94 | 93.22 | 24 | 2279 | d | -- | -- | d | -- | 93.8 | 63.62 |
| 95 | 99.91 | 29 | 1976 | 15.0 | 13.89 | 501 | c | -- | 100.92 | 61.51 |
| 96 | 84.76 | 23 | 2022 | d | -- | -- | d | -- | 85.42 | 66.38 |
| 97 | 66.77 | 25 | 1539 | 1.0 | 70.28 | 15,257 | c | -- | 67.4 | 59.51 |
| 98 | 74.91 | 22 | 1958 | 63.0 | 60.49 | 274 | c | -- | 77.35 | 61.20 |
| 99 | 75.56 | 23 | 1843 | d | -- | -- | d | -- | 77.38 | 61.22 |
| 100 | 76.72 | 23 | 1843 | d | -- | -- | d | -- | 80.4 | 62.33 |
| 101 | 78.58 | 24 | 1767 | 6.0 | 1.23 | 26,211 | c | -- | 83.63 | 62.57 |
| 102 | 52.6 | 21 | 2208 | d | -- | -- | c | -- | 55.74 | 67.61 |
| 103 | 50.33 | 19 | 2225 | d | -- | -- | d | -- | 52.8 | 68.32 |
| 104 | 50.15 | 18 | 2348 | d | -- | -- | d | -- | 51.87 | 68.82 |
| 105 | 75.9 | 25 | 2027 | d | -- | -- | d | -- | 77.32 | 64.11 |
| 106 | 75.9 | 25 | 2027 | d | -- | -- | d | -- | 77.99 | 64.11 |
| 107 | 76.07 | 24 | 2112 | d | -- | -- | d | -- | 79.09 | 64.35 |
| 108 | 75.16 | 22 | 2303 | d | -- | -- | d | -- | 79.25 | 64.77 |
| 109 | 91.98 | 22 | 2691 | 18.0 | 13.26 | 2,465 | c | -- | 96.22 | 65.42 |
| 110 | 50.98 | 21 | 2006 | d | -- | -- | d | -- | 52.74 | 66.03 |
| 111 | 54.79 | 19 | 2373 | d | -- | -- | d | -- | 56.6 | 68.71 |
| 112 | 46.72 | 20 | 1939 | d | -- | -- | d | -- | 48.51 | 66.14 |
| 113 | 41.8 | 20 | 1780 | d | -- | -- | d | -- | 43.56 | 64.58 |
| 114 | 35.58 | 21 | 1543 | d | -- | -- | d | -- | 40.37 | 63.11 |
| 115 | 39.92 | 21 | 1557 | 3.0 | 0.41 | 41,834 | c | -- | 40.74 | 60.62 |
| 116 | 39.31 | 21 | 1563 | d | -- | -- | c | -- | 41.11 | 60.77 |
| 117 | 29.24 | 22 | 1185 | 3.0 | 0.47 | 35,636 | c | -- | 30.97 | 58.67 |
| 118 | 54.78 | 21 | 2151 | d | -- | -- | d | -- | 56.52 | 65.40 |
| 119 | 59.10 | 21 | 2299 | d | -- | -- | d | -- | 60.86 | 66.20 |
| 120 | 59.42 | 21 | 2299 | d | -- | -- | d | -- | 61.18 | 66.98 |
| 121 | 63.55 | 11 | 4688 | d | -- | -- | d | -- | 65.30 | 68.52 |
| 122 | 67.60 | 24 | 2279 | 3.0 | 0.47 | 35,636 | c | -- | 69.34 | 67.90 |
| 123 | 71.66 | 25 | 2315 | 4.0 | 1.47 | 11,394 | c | -- | 73.40 | 68.76 |
| 124 | 62.80 | 24 | 1767 | 4.0 | 1.47 | 11,394 | c | -- | 64.90 | 62.22 |
| 125 | 66.81 | 23 | 1970 | d | -- | -- | d | -- | 68.91 | 62.63 |
| 126 | 71.92 | 24 | 2011 | g | -- | -- | 2.33 | 7,188 | 74.02 | 63.33 |
| 127 | 76.58 | 25 | 2056 | -- | -- | -- | 4.55 | 3,681 | 78.68 | 65.35 |
| 128 | 82.35 | 25 | 2194 | -- | -- | -- | 4.64 | 3,610 | 84.45 | 65.38 |
| 129 | 62.75 | 22 | 1921 | d | -- | -- | d | -- | 63.26 | 61.48 |
| 130 | 67.40 | 23 | 1964 | d | -- | -- | d | -- | 67.91 | 62.26 |
| 131 | 71.32 | 24 | 2011 | d | -- | -- | d | -- | 71.82 | 64.61 |
| 132 | 66.54 | 24 | 1761 | 3.0 | 0.41 | 41,873 | d | -- | 68.83 | 62.75 |
| 133 | 66.40 | 24 | 1761 | 4.0 | 1.41 | 12,176 | d | -- | 68.69 | 61.69 |
| 134 | 0 | a | -- | g | -- | -- | 5.06 | 3,409 | 1.78 | 58.82 |
| 135 | 0 | a | -- | g | -- | -- | 6.55 | 4,385 | 2.96 | 58.94 |
| 136 | 0 | a | -- | g | -- | -- | 6.67 | 4,306 | 3.02 | 59.65 |
| 137 | 0 | a | -- | -- | -- | -- | 3.55 | 4,486 | 1.68 | 59.15 |
| 138 | 0 | a | -- | -- | -- | -- | 3.17 | 6,585 | 2.25 | 58.40 |
| 139 | 90.60 | 24 | 2645 | g | -- | -- | 5.16 | 3,458 | 92.74 | 65.88 |
| 140 | 91.21 | 26 | 2452 | 8.0 | 3.64 | 8,065 | 5.86 | 5,009 | 94.73 | 64.89 |
| 141 | 90.76 | 26 | 2441 | g | -- | -- | 6.09 | 4,837 | 94.29 | 65.55 |
| 142 | 98.85 | 33 | 1789 | 36.0 | 32.35 | 757.4 | 33.96 | 721.50 | 102.28 | 63.60 |
| 143 | 85.7 | 29 | 1762 | g | -- | -- | 1.09 | 15,676 | 88.11 | 63.26 |
| 144 | 98.6 | 28 | 1927 | 7 | 4.422 | 3,864 | 4.77 | 3,582 | 101.21 | 63.17 |
| 145 | 106.5 | 30 | 1923 | b | -- | -- | b | -- | 100+ | 63.01 |
| 146 | 91.8 | 39 | 1284 | 61 | 58.42 | 292.5 | c | -- | 94.42 | 61.13 |
| 147 | 48.0 | 23 | 1224 | g | -- | -- | 1.55 | 24,960 | 53.79 | 61.10 |
| 148 | 48.11 | 23 | 1224 | g | -- | -- | 1.46 | 26,499 | 53.90 | 61.02 |
| 149 | 48.24 | 23 | 1224 | 7 | 1.29 | 29,991 | 1.59 | 24,332 | 54.03 | 60.77 |
| 150 | 47.91 | 23 | 1217 | g | -- | -- | 1.59 | 24,332 | 53.70 | 60.69 |
| 151 | 48.25 | 22 | 1315 | g | -- | -- | 1.16 | 25,861 | 52.71 | 61.92 |
| 152 | 48.58 | 22 | 1315 | g | -- | -- | 1.20 | 24,999 | 53.04 | 61.87 |
| 153 | 48.79 | 21 | 1378 | g | -- | -- | 1.12 | 26,785 | 53.25 | 61.82 |

(See last page of this figure for footnotes)

FIG 21
EXPERIMENTAL DATA
 CONTINUED

| Date | Run No. | Condenser-Discharge Static Pressure (psia) | Preboiler Tube-Side Pressure Drop (psi) | Test Boiler Tube-Side Pressure Drop (psi) | Mass Flow Rate (lb/hr) | Preboiler Boiling Heat Flux (Btu/hr-ft ²) | Test Boiler Boiling Heat Flux (Btu/hr-ft ²) | Preboiler Subcool ΔT, (F) | Preboiler Heat Into Preheat (Btu/hr) | Preboiler Heat Into Boiling (Btu/hr) |
|----------|---------|--|---|---|------------------------|---|---|---------------------------|--------------------------------------|--------------------------------------|
| 10/31/63 | 154 | 56.78 | 1.94 | 0.773 | 16.00 | 30,566 | 10,051 | 259 | 782 | 7,419 |
| | 155 | 56.58 | 1.85 | 0.751 | 15.88 | 30,566 | 10,051 | 252 | 755 | 7,446 |
| | 156 | 56.58 | 1.76 | 0.740 | 15.88 | 30,566 | 10,051 | 241 | 723 | 7,478 |
| | 157 | 56.48 | 1.65 | 0.740 | 15.75 | 30,566 | 10,041 | 241 | 717 | 7,484 |
| | 158 | 57.04 | 1.62 | 0.953 | 17.14 | 27,412 | 48,891 | 249 | 806 | 6,549 |
| | 159 | 57.14 | 1.60 | 0.946 | 17.01 | 27,412 | 49,891 | 254 | 815 | 6,540 |
| | 160 | 57.14 | 1.60 | 0.946 | 17.01 | 27,412 | 49,891 | 254 | 815 | 6,540 |
| | 161 | 57.14 | 1.59 | 0.946 | 17.01 | 27,412 | 49,891 | 254 | 815 | 6,540 |
| | 162 | 56.94 | 1.56 | 0.986 | 17.01 | 26,598 | 59,837 | 249 | 800 | 6,337 |
| | 163 | 56.94 | 1.56 | 0.986 | 17.01 | 26,598 | 59,837 | 259 | 831 | 6,306 |
| | 164 | 56.94 | 1.56 | 0.989 | 17.01 | 26,598 | 59,837 | 259 | 831 | 6,306 |
| | 165 | 56.94 | 1.56 | 0.986 | 17.01 | 26,598 | 59,837 | 259 | 831 | 6,306 |
| | 166 | 57.14 | 2.01 | 0.935 | 16.63 | 26,598 | 59,837 | 260 | 816 | 6,321 |
| 11/1/63 | 167 | 57.34 | 1.81 | 0.960 | 17.01 | 26,598 | 59,837 | 271 | 871 | 6,266 |
| | 168 | 55.98 | 2.12 | 1.040 | 17.39 | 25,796 | 69,985 | 273 | 895 | 6,027 |
| | 169 | 55.68 | 2.01 | 1.047 | 17.39 | 25,796 | 69,985 | 267 | 877 | 6,045 |
| | 170 | 54.74 | 1.67 | 1.047 | 17.39 | 25,796 | 69,985 | 262 | 861 | 6,061 |
| | 171 | 54.64 | 1.78 | 1.047 | 17.39 | 25,796 | 69,985 | 262 | 861 | 6,061 |
| | 172 | 54.54 | 1.87 | 1.040 | 17.39 | 25,796 | 69,985 | 261 | 857 | 6,065 |
| | 173 | 54.54 | 1.87 | 1.032 | 17.26 | 25,796 | 69,985 | 261 | 851 | 6,078 |
| | 174 | 1415 | 1.89 | 2.152 | 16.38 | 51,249 | 20,198 | 184 | 567 | 13,194 |
| | 175 | 1430 | 2.00 | 2.058 | 15.75 | 51,249 | 18,087 | 183 | 542 | 13,209 |
| | 176 | 1445 | 1.87 | 2.014 | 15.50 | 51,264 | 18,264 | 175 | 511 | 13,240 |
| 11/2/63 | 177 | 39.84 | 4.20 | 2.0 | 17.25 | 50,000 | 16,900 | 182 | 591 | 12,829 |
| | 178 | 39.5 | 4.99 | 1.82 | 17.0 | 49,900 | 16,900 | 181 | 584 | 12,786 |
| | 179 | 40.78 | 4.65 | 1.78 | 17.0 | 49,900 | 16,900 | 182 | 586 | 12,784 |
| | 180 | 40.78 | 5.06 | 1.81 | 17.0 | 49,900 | 16,900 | 185 | 596 | 12,774 |
| 11/3/63 | 181 | 39.69 | 4.99 | 1.87 | 17.4 | 49,800 | 7,770 | 179 | 591 | 12,759 |
| | 182 | 39.35 | 4.70 | 1.795 | 16.6 | 49,900 | 7,770 | 158 | 499 | 12,881 |
| 11/4/63 | 183 | 39.77 | 4.67 | 1.805 | 17.3 | 55,294 | 7,955 | 188 | 617 | 14,219 |
| | 184 | 40.5 | 4.90 | 1.834 | 17.6 | 55,459 | 8,181 | 177 | 591 | 14,290 |
| 11/5/63 | 185 | 42.2 | 5.1 | 1.829 | 17.6 | 50,944 | 9,245 | 169 | 565 | 13,104 |
| | 186 | 42.2 | 5.14 | 1.823 | 17.6 | 50,944 | 9,245 | 169 | 565 | 13,104 |
| | 187 | 42.79 | 5.5 | 1.955 | 18.6 | 54,378 | 10,962 | 192 | 678 | 13,912 |
| | 188 | 39.78 | 5.69 | 2.2 | 19.5 | 54,543 | 17,087 | 174 | 645 | 13,990 |
| | 189 | 39.78 | 5.8 | 2.2 | 19.5 | 54,543 | 17,087 | 175 | 649 | 13,986 |
| 11/9/63 | 190 | 35.02 | 5.21 | 1.92 | 16.9 | 50,371 | 17,337 | 197 | 629 | 12,886 |
| | 191 | 35.02 | 5.14 | 1.93 | 16.9 | 50,391 | 17,337 | 197 | 629 | 12,886 |
| | 192 | 37.23 | 5.06 | 1.96 | 17.6 | 50,371 | 17,337 | 197 | 656 | 12,859 |
| | 193 | 36.93 | 5.08 | 1.98 | 17.6 | 50,371 | 17,337 | 196 | 652 | 12,863 |
| | 194 | 36.83 | 5.01 | 1.95 | 17.5 | 54,543 | 13,331 | 200 | 661 | 13,974 |
| 11/10/63 | 195 | 36.76 | 4.56 | 1.75 | 16.0 | 47,064 | 17,337 | 165 | 500 | 12,128 |
| | 196 | 36.86 | 4.52 | 1.75 | 16.0 | 47,064 | 17,337 | 165 | 500 | 12,128 |
| | 197 | 33.04 | 4.94 | 1.95 | 16.4 | 42,256 | 17,337 | 164 | 509 | 10,829 |
| 11/11/63 | 198 | 35.27 | 5.14 | 1.99 | 17.3 | 46,568 | 17,337 | 196 | 640 | 11,855 |
| | 199 | 35.16 | 5.24 | 2.01 | 17.5 | 46,568 | 17,337 | 201 | 664 | 11,831 |
| 11/17/63 | 200 | 36.29 | 1.11 | 0.81 | 17.01 | 21,039 | 17,676 | 142 | 457 | 5,188 |
| 11/20/63 | 201 | 41.0 | 4.05 | 7.29 | 18.52 | 43,731 | 17,087 | 142 | 498 | 11,236 |
| | 202 | 40.38 | 4.00 | 7.08 | 18.52 | 43,731 | 17,087 | 142 | 498 | 11,236 |
| | 203 | 40.25 | 3.98 | 7.04 | 18.52 | 43,731 | 17,087 | 144 | 505 | 11,229 |
| | 204 | 40.0 | 3.94 | 6.80 | 18.52 | 43,731 | 17,087 | 148 | 519 | 11,215 |
| 11/21/63 | 205 | 36.59 | 4.74 | 1.84 | 16.76 | 41,594 | 17,514 | 176 | 559 | 10,601 |
| 11/22/63 | 206 | 38.57 | 6.69 | 1.88 | 17.26 | 55,459 | 17,514 | 211 | 688 | 14,193 |
| | 207 | 37.67 | 3.51 | 1.62 | 17.26 | 42,396 | 17,514 | 184 | 601 | 10,774 |
| | 208 | 37.97 | 3.51 | 1.61 | 17.26 | 42,396 | 17,514 | 185 | 604 | 10,771 |
| | 209 | 37.27 | 3.66 | 1.65 | 17.26 | 42,396 | 17,514 | 185 | 604 | 10,771 |
| | 210 | 37.17 | 3.98 | 1.63 | 17.26 | 42,256 | 17,514 | 185 | 604 | 10,734 |
| | 211 | 35.06 | 4.97 | 1.81 | 17.64 | 46,924 | 17,514 | 181 | 605 | 11,985 |
| | 212 | 34.96 | 5.01 | 1.81 | 17.64 | 46,924 | 17,684 | 180 | 601 | 11,989 |
| 11/24/63 | 213 | 36.66 | 3.22 | 1.55 | 17.14 | 39,368 | 17,514 | 174 | 564 | 9,999 |
| | 214 | 36.46 | 3.17 | 1.56 | 17.14 | 39,368 | 17,514 | 173 | 561 | 10,002 |
| 11/28/63 | 215 | 52.82 | 2.12 | * | 20.16 | 31,177 | * | 314 | 1183.8 | 7,181 |
| | 216 | 53.82 | 2.90 | * | 16.63 | 41,836 | * | 284 | 887.9 | 10,337 |
| | 217 | 53.80 | 3.08 | * | 16.76 | 45,493 | * | 286 | 901.2 | 11,305 |
| | 218 | 53.10 | 3.33 | * | 16.38 | 49,913 | * | 287 | 883.8 | 12,508 |
| | 219 | 52.19 | 3.31 | * | 16.51 | 49,761 | * | 278 | 863.3 | 12,489 |
| 11/29/63 | 220 | 52.34 | 2.90 | * | 16.38 | 41,836 | * | 248 | 766.1 | 10,459 |
| | 221 | 52.29 | 3.11 | * | 16.38 | 45,639 | * | 252 | 778.5 | 11,468 |
| | 222 | 52.35 | 3.31 | * | 16.13 | 49,913 | * | 254 | 772.7 | 12,619 |
| | 223 | 51.95 | 3.10 | * | 16.00 | 49,346 | * | 256 | 771.7 | 12,468 |
| 11/30/63 | 224 | 51.45 | 3.71 | * | 17.51 | 54,219 | * | 269 | 887.4 | 13,661 |
| | 225 | 51.43 | 3.87 | * | 17.39 | 54,596 | * | 260 | 852.7 | 13,796 |
| | 226 | 50.99 | 3.53 | * | 16.51 | 49,455 | * | 250 | 778.5 | 12,492 |
| 12/1/63 | 227 | 52.11 | 3.29 | * | 16.38 | 49,608 | * | 256 | 790.4 | 12,521 |
| | 228 | 52.51 | 3.51 | * | 17.64 | 49,913 | * | 254 | 845.9 | 12,546 |
| | 229 | 52.26 | 3.33 | * | 17.01 | 49,043 | * | 265 | 849.2 | 12,310 |
| 12/2/63 | 230 | 51.23 | 3.37 | * | 16.63 | 49,332 | * | 254 | 796.7 | 12,440 |
| 12/3/63 | 231 | 24.94 | 5.45 | * | 17.01 | 49,760 | * | 285 | 902 | 12,450 |
| 12/4/63 | 232 | 25.73 | 6.65 | * | 17.39 | 54,973 | * | 352 | 1133 | 13,617 |
| | 233 | 25.63 | 6.33 | * | 17.39 | 54,596 | * | 351 | 1129.2 | 13,520 |
| | 234 | 51.78 | 3.38 | * | 17.01 | 49,608 | * | 258 | 827.7 | 12,482 |
| 12/5/63 | 235 | 51.60 | 3.38 | * | 17.64 | 49,913 | * | 249 | 829.3 | 12,563 |

(See last page of this figure for footnotes)

FIG 21
EXPEREMENTAL DATA
CONTINUED

| Run No. | Preboiler Exit Quality | Preboiler Average Tube to Shell ΔT (F) | Preboiler Over-all Heat Trans. Coefficient (Btu/hr-ft ² F) | Test Boiler Tube to Shell ΔT(e) (F) | Test Boiler Boiling ΔT(e) (F) | Test Boiler Local Heat Trans. Coeff. (e) (Btu/hr-ft ² F) | Test Boiler Boiling ΔT(f) (F) | Test Boiler Local Heat Trans. Coeff. (f) (Btu/hr-ft ² F) | Test Boiler Average Quality | Average Tube-Side Pressure in Test Boiler, psia |
|---------|------------------------|--|---|-------------------------------------|-------------------------------|---|-------------------------------|---|-----------------------------|---|
| 154 | 57.03 | 18 | 1698 | -- | -- | -- | 1.50 | 6,701 | 58.67 | 62.35 |
| 155 | 57.68 | 19 | 1609 | -- | -- | -- | 1.41 | 7,128 | 59.33 | 62.06 |
| 156 | 57.92 | 17 | 1798 | -- | -- | -- | 1.38 | 7,283 | 59.57 | 61.96 |
| 157 | 58.45 | 17 | 1798 | -- | -- | -- | 1.38 | 7,283 | 60.11 | 61.85 |
| 158 | 47.05 | 16 | 1713 | -- | -- | -- | 0.45 | 110,869 | 54.64 | 63.66 |
| 159 | 47.35 | 15 | 1827 | -- | -- | -- | 0.45 | 110,869 | 55.00 | 63.71 |
| 160 | 47.35 | 15 | 1827 | -- | -- | -- | 0.41 | 121,685 | 55.00 | 63.72 |
| 161 | 47.35 | 15 | 1827 | -- | -- | -- | 0.67 | 74,464 | 55.00 | 63.71 |
| 162 | 45.88 | 15 | 1773 | -- | -- | -- | 0.65 | 92,057 | 55.05 | 63.74 |
| 163 | 45.66 | 15 | 1773 | -- | -- | -- | 0.79 | 75,743 | 54.83 | 63.75 |
| 164 | 45.66 | 15 | 1773 | -- | -- | -- | 0.83 | 72,093 | 54.83 | 63.77 |
| 165 | 45.66 | 15 | 1773 | -- | -- | -- | 0.83 | 72,093 | 54.83 | 63.77 |
| 166 | 46.81 | 13 | 2046 | -- | -- | -- | 0.74 | 80,861 | 56.19 | 63.57 |
| 167 | 45.37 | 14 | 1900 | -- | -- | -- | 2.22 | 26,954 | 54.54 | 64.08 |
| 168 | 42.68 | 17 | 1517 | -- | -- | -- | 3.22 | 21,080 | 53.18 | 63.08 |
| 169 | 42.81 | 16 | 1612 | -- | -- | -- | 3.14 | 22,288 | 53.31 | 62.71 |
| 170 | 42.87 | 15 | 1720 | -- | -- | -- | 2.05 | 34,139 | 53.35 | 61.85 |
| 171 | 42.87 | 14 | 1843 | -- | -- | -- | 2.01 | 34,818 | 53.35 | 61.76 |
| 172 | 42.90 | 15 | 1720 | -- | -- | -- | 2.05 | 34,139 | 53.38 | 61.63 |
| 173 | 43.27 | 15 | 1720 | -- | -- | -- | 2.01 | 34,818 | 53.83 | 61.62 |
| 174 | 97.80 | 58 | 883.6 | 169 | 165.97 | 121.70 | c | -- | 100.97 | 43.03 |
| 175 | 101.91 | 54 | 949.1 | b | -- | -- | c | -- | 100+ | 42.84 |
| 176 | 103.66 | 59 | 868.6 | b | -- | -- | c | -- | 100+ | 42.54 |
| 177 | 91.2 | 87 | 574.7 | 99 | 96.45 | 175.5 | c | -- | 93.75 | 52.42 |
| 178 | 92.2 | 88 | 567.0 | 103 | 100.45 | 168.5 | c | -- | 94.79 | 51.40 |
| 179 | 92.1 | 84 | 594.0 | 102 | 99.45 | 170 | c | -- | 94.69 | 52.15 |
| 180 | 92.0 | 71 | 702.8 | 100 | 97.45 | 173.5 | c | -- | 94.59 | 52.19 |
| 181 | 89.8 | 72 | 691.7 | 69 | 67.77 | 115 | c | -- | 90.96 | 52.04 |
| 182 | 95.0 | 86 | 580.2 | 78 | 76.77 | 101.5 | c | -- | 96.22 | 51.06 |
| 183 | 100.7 | 67 | 825.3 | 82 | 80.75 | 98.5 | c | -- | 101.90 | 52.24 |
| 184 | 99.5 | 81 | 684.7 | 65 | 63.71 | 128.4 | c | -- | 100.71 | 51.69 |
| 185 | 91.2 | 80 | 636.8 | 81 | 79.56 | 116.2 | c | -- | 92.56 | 53.11 |
| 186 | 91.2 | 71 | 717.5 | 88 | 86.56 | 106.8 | c | -- | 92.56 | 53.09 |
| 187 | 91.8 | 61 | 891.4 | 78 | 76.31 | 143.7 | c | -- | 93.33 | 55.40 |
| 188 | 87.9 | 67 | 814.1 | 106 | 103.42 | 165.2 | c | -- | 90.18 | 53.37 |
| 189 | 87.9 | 61 | 894.1 | 111 | 108.42 | 157.6 | c | -- | 90.18 | 53.42 |
| 190 | 93.2 | 62 | 812.4 | 100 | 97.39 | 178.0 | c | -- | 95.85 | 48.20 |
| 191 | 93.2 | 55 | 915.8 | 111 | 108.39 | 160.0 | c | -- | 95.85 | 48.30 |
| 192 | 89.4 | 59 | 853.7 | 103 | 100.39 | 172.7 | c | -- | 91.95 | 50.40 |
| 193 | 89.5 | 51 | 987.7 | 111 | 108.39 | 160.0 | c | -- | 92.05 | 50.26 |
| 194 | 97.7 | 47 | 1160 | 117 | 114.97 | 116.0 | c | -- | 99.68 | 50.16 |
| 195 | 92.55 | 53 | 880 | 78 | 75.39 | 230.0 | c | -- | 95.35 | 47.60 |
| 196 | 92.55 | 49 | 960.5 | 88 | 85.39 | 203.0 | c | -- | 95.35 | 47.65 |
| 197 | 80.52 | 46 | 918.6 | 99 | 96.39 | 179.9 | c | -- | 83.25 | 45.92 |
| 198 | 83.67 | 51 | 913.1 | 54 | 51.39 | 337.4 | c | -- | 86.26 | 48.15 |
| 199 | 82.65 | 46 | 1012.3 | g | -- | -- | 12.87 | 1,347 | 85.22 | 48.94 |
| 200 | 37.06 | 72 | 292.2 | 4 | 1.34 | 13,191 | c | -- | 39.74 | 45.99 |
| 201 | 73.81 | 65 | 672.8 | d | -- | -- | d | -- | 76.19 | 52.38 |
| 202 | 73.81 | 66 | 662.6 | d | -- | -- | d | -- | 76.19 | 51.82 |
| 203 | 73.76 | 65 | 672.8 | d | -- | -- | d | -- | 76.14 | 51.69 |
| 204 | 73.67 | 65 | 672.8 | d | -- | -- | d | -- | 76.05 | 51.43 |
| 205 | 77.23 | 53 | 784.8 | 63 | 60.36 | 290.2 | 28.40 | 616.7 | 79.93 | 48.57 |
| 206 | 100+ | 30 | 1848.6 | b | -- | -- | c | -- | 100+ | 50.79 |
| 207 | 76.22 | 21 | 2018.9 | d | -- | -- | d | -- | 78.85 | 49.56 |
| 208 | 76.20 | 21 | 2018.9 | d | -- | -- | d | -- | 78.83 | 49.74 |
| 209 | 76.20 | 21 | 2018.9 | d | -- | -- | d | -- | 78.83 | 49.45 |
| 210 | 75.93 | 21 | 2012.2 | d | -- | -- | d | -- | 78.56 | 49.30 |
| 211 | 83.06 | 17 | 2760.2 | -- | -- | -- | 0.39 | 44,908 | 85.63 | 49.29 |
| 212 | 83.08 | 18 | 2606.9 | -- | -- | -- | 0.37 | 47,795 | 85.68 | 49.21 |
| 213 | 71.14 | 20 | 1968.4 | d | -- | -- | d | -- | 80.29 | 47.75 |
| 214 | 71.16 | 22 | 1789.5 | d | -- | -- | d | -- | 80.31 | 47.67 |
| 215 | 43.76 | 17 | 1834 | * | * | * | * | * | * | * |
| 216 | 76.55 | 22 | 1902 | * | * | * | * | * | * | * |
| 217 | 83.07 | 24 | 1896 | * | * | * | * | * | * | * |
| 218 | 94.04 | 26 | 1920 | * | * | * | * | * | * | * |
| 219 | 93.04 | 27 | 1843 | * | * | * | * | * | * | * |
| 220 | 78.54 | 27 | 1549 | * | * | * | * | * | * | * |
| 221 | 86.12 | 27 | 1690 | * | * | * | * | * | * | * |
| 222 | 96.23 | 33 | 1513 | * | * | * | * | * | * | * |
| 223 | 95.73 | 41 | 1204 | * | * | * | * | * | * | * |
| 224 | 96.08 | 33 | 1643 | * | * | * | * | * | * | * |
| 225 | 97.70 | 32 | 1706 | * | * | * | * | * | * | * |
| 226 | 93.06 | 31 | 1595 | * | * | * | * | * | * | * |
| 227 | 94.02 | 31 | 1600 | * | * | * | * | * | * | * |
| 228 | 87.59 | 25 | 1997 | * | * | * | * | * | * | * |
| 229 | 89.02 | 28 | 1752 | * | * | * | * | * | * | * |
| 230 | 92.01 | 26 | 1897 | * | * | * | * | * | * | * |
| 231 | 89.15 | 51 | 975.7 | * | * | * | * | * | * | * |
| 232 | 95.49 | 79 | 695.9 | * | * | * | * | * | * | * |
| 233 | 94.70 | 59 | 925.4 | * | * | * | * | * | * | * |
| 234 | 90.38 | 26 | 1908 | * | * | * | * | * | * | * |
| 235 | 87.71 | 27 | 1849 | * | * | * | * | * | * | * |

*Boiler No. 2 isolated from the system

a - Single phase flow in preboiler - exit quality <5%

b - Superheat - quality >100%

c - Tube to shell pressure differential indicated over scale.

Calculations based on absolute pressure readings.

d - Tube to shell pressure differential gage (PI-21) not operating during these runs - NaK line frozen. Temperature differential (tube to shell) was not sufficient (<5F) to permit usage of the absolute pressures.


e - From absolute pressure measurement

f - From differential pressure measurement


g - Differential pressure gage was used because of small pressure differences

FIG 22


FORCED CONVECTION LOCAL BOILING HEAT TRANSFER COEFFICIENTS



BAND OF EXPERIMENTAL ERROR



OVER-ALL HEAT TRANSFER COEFFICIENT, U, FOR THE POTASSIUM PREBOILER
 IN THE P&WA BOILING POTASSIUM HEAT TRANSFER TEST



C. Two-Phase Stability Experience

1. Preheater

The achievement of loop stability was a continuing problem despite the high pressure drop in the liquid portion of the loop. Much of the instability appeared to originate in the preheater as a result of subcooled nucleate boiling. This boiling phenomenon is a result of a temperature gradient in the boundary layer which can result in local temperature higher than saturation. A bubble is formed at the wall, swept into the core or cooler portion of the stream, and consequently collapsed.

This phenomenon was indicated by a preheater surface thermocouple which cycled 50 to 100F. The average wall temperature was about 100F above saturation while the fluid temperature at the exit of the preheater was below saturation. Post-test examination of the preheater also indicated heavier than average oxidation rate. The flow momentarily increased, then decreased below normal and oscillated rapidly when the measured temperature dropped suddenly from a maximum. The preheater inlet pressure oscillated. In time, the flow rate went back to normal, the pressure oscillation stopped, and the preheater surface temperature started to rise again. The cycle repeated itself. This phenomenon was indicative of a bubble being formed at the wall, resulting in liquid being momentarily displaced by the bubble and causing a sudden rise in the indicated flow rate. The bubble or bubbles being formed then caused a general lowering of flow rate by restricting the flow area. The bubble collapsed suddenly when it was swept into the cold portion of the stream, causing additional pressure and flow fluctuations. The cyclic nature of the process stemmed from the thermal inertia of the tube, and the superheat required to initiate boiling.

This form of instability was reduced to a minimum by operating the preheater at the lower heat flux. The preheater outlet temperature could not be reduced without limit, however, as similar pressure and flow oscillations were observed at low preheater outlet temperatures. This indicates subcooled nucleate boiling within the preboiler. Stable operation was observed when the preheater outlet temperature was about 200F below the saturation temperature.

2. Preboiler


A unique form of instability was observed in the preboiler. The boiler would stop boiling periodically, as evidenced by a decrease in the boiling pressure drop and a rise in the shell side pressure. The interface was pictured to move down to the preboiler outlet. This phenomenon could be predicted by observing the preheater inlet pressure. The boiling pressure drop would decrease shortly after this pressure started to oscillate. Boiling was restored by allowing the driving Δt to increase (i.e., increase in shell side temperature). When the shell side pressure reached the maximum allowable pressure and the boiler still would not function, power was cut off and the pressure allowed to drop. In time, the boiler would start to boil again, the heat being supplied from the thermal inertia of the boiler. Power was gradually increased when the preboiler started to function normally. This could also be predicted by a decrease in preheater inlet pressure oscillations.

It is believed that system pressure disturbances had the effect of increasing the temperature required to boil the potassium due to boiling initiation (superheat) requirements. As a consequence of the pressure oscillation, vapor generation increased in the first boiler diminished shell temperature, the boiler pressure drop decreased, and the flow increased. The increase in flow rate reduced the amount of subcooled nucleate boiling. When the pressure oscillation ceased, the preboiler began to operate effectively, and boiling began. A graphical description of this preboiler instability is shown in Fig. 25. Typical oscillations are shown in Figs. 26 and 27.

3. Condenser

The condensing interface could be clearly observed. A uniform tube temperature in the vapor region was followed by a sudden temperature gradient to about 850F. This is shown in Fig. 1. Intermittently, this apparent interface moved a foot downstream. When the interface reached the end of its travel, the temperature level of the entire visible region would drop uniformly by approximately 200F. System pressures and flow would oscillate. In time, the interface would reappear from the upstream section of the condenser and gradually move to its original position. This random cycle took 45 seconds to one minute. Flow stratification with bridging of

EXPLANATION OF PREBOILER INSTABILITY



(BUBBLE COLLAPSE AND REBOIL IS NOT A NECESSARY CONDITION FOR CONTINUED PERIODIC OSCILLATION)

TYPICAL STABLE FLOW RATE OSCILLOGRAPH RECORD






FIG 27

TYPICAL OSCILLOGRAPH RECORD OF FLOW INSTABILITIES



the liquid stream is offered as a possible explanation, since the condenser was sloped two degrees upward. This instability was observed in both hard and soft systems.

4. Miscellaneous System Stability Tests

Several tests were conducted to obtain better insight into the design and operation of two-phase systems. These tests are described below.

- a. Effect of liquid pressure drop at the preheater inlet at constant flow, pressure, and degree of subcooling:

Stability improved as the pressure drop was varied from a negligible value to 60 psi. Above 10 psi, however, no significant improvement was observed. At very little pressure drop, the system was highly unstable. Ten psi was comparable to the boiling pressure drop.

- b. Effect of pressure drop at the condenser exit:

A valve downstream of the condenser and near the EM flowmeter was throttled to improve stability. A small pressure drop (3 to 5 psi, which corresponded roughly to the condenser pressure drop) resulted in a marked improvement. Above 10 psi, no apparent improvement was observed.

- c. Effect of non-condensibles:

Non-condensibles in the potassium circuit seemed to have a definite effect on the loop stability.

At one point in the operation, about 100 hours of continuous boiling time were accumulated with only short periods of stable operation. It was decided to pump the potassium through the calibration tanks to eliminate non-condensibles which were assumed to originate from the helium cover gas during normal operation. After one hour of this mode of operation, stability was obtained.

- d. Effect of subcooling:

The amount of subcooling was varied from 100 to 300F at constant flow and pressure.

About 200F subcooling seemed to produce the best compromise. Below this, subcooled nucleate boiling was apparent in the preheater. Above this, subcooled nucleate boiling in the boiler inlet caused instability.

- e. Effect of pressure level:

The boiling pressure was varied from 42 psia to 62 psia at constant flow and subcooling.

Stability was improved at the higher boiling pressures, but due to the small pressure range covered, no quantitative statements can be made.

- f. Effect of system hardness:

The system was operated with a variable loop inventory (soft) and with a fixed inventory (hard) by valving an expansion tank in or out of the system.

The hard system was more stable; however, the system was more difficult to control since:

- 1) No bellows-type accumulator was incorporated into the system. Therefore, the loop inventory could not be varied except by opening a valve which required that the pressure in the expansion tank be preset at the proper level for the inventory required.

- 2) The heat rejection system utilized natural convection. Any drift in the net enthalpy of the system resulted in a drift of the loop pressure. Lack of fine control of the cooling air flow rate resulted in no improvement when forced convection cooling was used instead of natural convection cooling.

The hard system did not prevent the preboiler instability described in Section VI-C-2. Flow recordings made during stable and unstable operation of both soft and hard systems are shown in Figs. 26 and 27, respectively.

g. Effect of condensing length:

The location of the condensing interface was varied. Forced air convection, natural convection, and insulation were all applied to change the location of the interface. No change in the loop stability was noted.

h. Effect of accumulator location:

An alternate accumulator was connected at the preheater inlet to investigate the effect on stability when loop pressure was controlled at this location rather than at the pump inlet.

This mode of operation was quickly discarded. Loop stability was not achieved, and preheater failure by overheating was a real possibility in the event of a prolonged reversal or stoppage of flow.

VII. CHEMISTRY AND METALLURGY

A. Gas System

Helium was chosen as the cover gas, as it is easily purified by cryogenic means. The small quantities of gas needed involved no great expense. The helium was purified (i.e., O_2 and H_2O were removed) by passing it through activated charcoal filters at liquid air temperatures. This method of purification reduced the oxygen content from about 10 ppm in Grade A helium to less than 1 ppm. The water content was reduced from 20 ppm to less than 1 ppm. The all-welded gas system is shown in Fig. 14.

B. Loop Bake-Out

Absorbed gases were removed by heating all liquid metal bearing components to 350F to 400F. Prior to bake-out, the loop was purged with purified helium and evacuated. The loop was then back-filled with helium, and bake-out was started. Water and oxygen content of helium bled from the system were measured. Two parts per million each of O_2 and H_2O was considered satisfactory. A Beckman Moisture Analyzer was used to measure water content and a Lockwood McLorie Oxygen Analyzer was used to measure oxygen content. The decrease in O_2 and H_2O content with time is shown in Figs. 28, 29, 30, and 31 for the loop and all boilers.

C. Liquid Metal History

1. Potassium

The potassium used in this test was purchased from Mine Safety Appliances Co. Sodium-free potassium was specified. The incoming potassium was analyzed, purified, analyzed again, charged into the loop fill and drain tanks, and purified once again. The purification cycle consisted of hot trapping at 1400F for 24 hours with titanium sponge. The purified potassium was vacuum charged at 400F into the system through a 5-micron sintered metal filter. Once charged, the system was heated to 1000F and potassium circulated for two hours, then dumped hot. The potassium was repurified and refiltered before refilling the loop for test operation. The potassium analysis prior to charging the loop is tabulated in Fig. 32.

2. Sodium


The sodium used in this test was purchased from duPont. The purity analysis prior to final filtering indicated 10-31 ppm O_2 . The liquid was charged into the loop through a 5 micron filter at 400F.

D. Test Termination


In the interest of obtaining the maximum amount of two-phase operating experience and experimental data, it was decided to continue operation beyond the system design life of 1000 hours.

After approximately 3170 hours at operating temperatures (1800F), including 825 boiling hours, a liquid metal leak occurred at the test boiler drain line junction. This was evidenced by a drop in shell cavity pressure, and by liquid metal smoke. In order to continue obtaining data on the pre-boiler and superheat boiler, it was decided to isolate the test boiler from the remainder of the system. The failure region was manually cleaned and decontaminated to remove metallic oxides and residual liquid metal. The test boiler drain line was then capped and the shell cavity maintained under an inert gas blanket for the remainder of the test program.

POTASSIUM LOOP GAS PURITY DATA



PREBOILER EFFLUENT GAS PURITY MEASUREMENT



TEST BOILER GAS PURITY MEASUREMENT

O₂ ANALYZER: LOCKWOOD MCLORIE
H₂O ANALYZER: BECKMAN
BOILER TEMPERATURES: 350F-400F
INSTRUMENT FLOW RATE: 100 ML/MIN

HISTORY:

BOILER WAS BAKED OUT 2 HOURS, PURGED WITH PURIFIED GAS FOR ONE HOUR AND BACKFILLED TO 18 PSIG PRIOR TO ZERO TIME.


INSTRUMENT HOOK-UP.

PURIFIED GAS SUPPLY

TEST BOILER

INSTRUMENT

X
BYPASS FLOW





SUPERHEATING BOILER EFFLUENT GAS PURITY MEASUREMENT

O₂ ANALYZER: LOCKWOOD MCLORIE
H₂O ANALYZER: BECKMAN
TEMPERATURE: 350F-400F

HISTORY:

BOILER WAS BAKED OUT 2 HOURS, PURGED WITH PURIFIED GAS FOR ONE HOUR AND BACKFILLED TO 18 PSIG PRIOR TO ZERO TIME

INSTRUMENT HOOK-UP



POTASSIUM ANALYSIS

| Job No. | <u>MSA Quoted Analysis (ppm)</u> | <u>Incoming Analysis (ppm)</u> | <u>*Post Purification Analysis (ppm)</u> |
|----------------|--|--|--|
| | | N-164 | N-244 |
| O ₂ | -- | 20-24 | 14-24 |
| Na | Present | 100 | -- |
| Ca | 1 | less than 50 | less than 50 |
| Mg | 5 | 10 to 100 | 10 |
| Fe | 1 | less than 100 | 8 |
| Ni | 2 | less than 100 | less than 1 |
| Cr | 3 | less than 100 | 2 |

*Subsequent to this analysis, the potassium was purified, filtered, repurified and refiltered

At 3580 hours, an immersion heater in the preboiler gave an indication of being grounded. A hole had developed in the heater cladding exposing the heater element to liquid metal. The heater was isolated from the electrical system and the test continued, using the one remaining immersion heater in the preboiler.


After 3625 hours (980 boiling hours) a leak in the superheat-boiler drain line, similar to the test-boiler failure, caused a termination of the test program. Initial analyses indicate a stress-rupture type of failure due to weakening of the Haynes-25 material, at the drain-line junction.

Complete post-test evaluations, now in progress, of the failure regions and corrosion studies of the entire system will be presented in reports TIM-825 and CNLM-5660.

Fig. 33 is a post-test X-ray of the test boiler, which gives no indication of failure in the boiler tube or the heater.

TEST BOILER X-RAY, POST-TEST

TOP VIEW



VIII. ANALOG STUDIES
(Reference 23)

A simplified electrical mock-up of the test loop was devised and constructed to establish the feasibility of using the analog computer as a tool in the design and operation of two-phase forced-convection systems. Actual performance of the test loop was compared with performance predicted by the analog. Areas of agreement between the experimental loop and the electrical analog were:

1. Subcooled nucleate boiling was simulated in the analog by superimposing a random noise (dirty diode) signal on the preheater inlet pressure. The noise signal caused pressure and flow perturbations. These perturbations were large at low qualities and small at high qualities. The positive slope of the heat transfer versus quality curve at low qualities caused a positive feedback loop, thus magnifying flow oscillations. The negative slope curve at high qualities caused a negative feedback system.

Loop experience agreed with the analog as the magnitude of observed flow perturbations was less in the high quality regime than in the low quality regime.
2. Greater stability was predicted for high exit qualities. This agreed with the over-all operating experience.
3. It was predicted that throttling was needed at the preheater inlet to obtain stability. This was also confirmed in the experiment (Section VI-C-4).
4. The direction of pressure and flow changes as a result of a change in preheater power was predicted and demonstrated for both fixed-inventory and variable-inventory systems. This is shown below:

| | <u>Variable Inventory</u> <u>Soft System</u> | <u>Fixed Inventory</u> <u>Hard System</u> |
|-------------------------|---|--|
| Power change | + | + |
| Boiler Exit Pressure | + | + |
| Condenser Exit Pressure | - | + |
| Condenser ΔP | + | + |
| Flow | - | - |

In a hard system, a power change caused more significant changes in the system pressure level than in a soft system.

IX. CONCLUSIONS AND RECOMMENDATIONS

A. Heat Transfer

1. The performance of this tube did not start to deteriorate until about 85 percent vapor quality (Fig. 3). A straight tube indicates a performance drop at 60 percent quality (Ref. 22).
2. To properly size liquid metal boilers, it is necessary to obtain data using liquid metals. Water or other fluids can be used to indicate trends, (Fig. 22).
3. This experimental technique is excellent for obtaining local data, being versatile, reliable, and accurate.
4. The heat transfer data obtained in this experiment represents a significant start. Additional work is necessary and should be done at higher ΔT driving forces, and above average tube sizes and geometries.

B. Pressure Drop

1. The measured pressure drop bounds the calculated pressure drop (Martinelli-Lockhart correlation) by ± 20 percent (Fig. 4).
2. The pressure drop for the serpentine tube is 24 percent greater than for a straight round tube.
3. The pressure drop in a boiler significantly affects the size of a boiler since the integrated driving force (ΔT) is appreciably influenced by the reduction in saturated temperature.

C. Stability

1. Subcooled nucleate boiling appeared to create most of the instability experienced in this loop. Flashing orifices in the boiler are considered as the best method of solution. The choking effects expected in some types of orifices indicate potassium orifice tests are necessary.
2. Presence of noncondensable gas seemed to have an adverse effect on loop stability.
3. The condensing instabilities observed in the forced convection near horizontal (2 degrees upward) condenser indicates additional effort is needed to investigate the remedy for this problem.
4. The loop was most stable at high vapor qualities.
5. A fixed-inventory system was slightly more stable than a variable inventory system, but pressure control was more sensitive.
6. Stability of two-phase potassium systems cannot logically be studied with water or other common fluids because of liquid superheat requirements. These are functions of the amount of noncondensibles present, system purity, and the fluid properties of surface tension and thermal conductivity.

D. General


1. 50F to 70F of liquid superheat was necessary to initiate boiling.
2. Analog techniques promise to be a valuable tool in the understanding and operation of two-phase systems and in defining stable regimes. The operation of a Rankine Cycle in space by computer techniques requires that a conscientious effort be made to develop this valuable tool.

X. REFERENCES

1. Wright, Roger Maurice, "Downflow Forced-Convection Boiling of Water in Uniformly Heated Tubes", (Ph.D Thesis), UCRL 9744, August 21, 1961.
2. Polomik, E. E., Levy, S. and Sawochka, S. G., "Heat Transfer Coefficients with Annular Flow During 'Once-Through' Boiling of Water to 100% Quality at 800, 1100, and 1400 psi", GEAP 3703.
3. Kardys, C. F., "Boiling Inside Tubes to High Quality, " Pratt & Whitney Aircraft, (Preliminary Issue).
4. Liquid Metal Heat Transfer Programs, AiResearch Manufacturing Company. Presented by James J. Killackey at the Brookhaven Heat Transfer Conference in April 1962.
5. Noyes, R. C., "An Experimental Study of Sodium Pool Boiling Heat Transfer", NAA-SR-6769.
6. Sani, R. L., "Downflow Boiling and Nonboiling Heat Transfer in a Uniformly Heated Tube", UCRL 9023.
7. Nuclear Engineering, Edited by C. F. Bonilla, 1957, McGraw-Hill Book Co.
8. Heat Transmission, William H. McAdams, 1954, McGraw-Hill Book Co.
9. WADD Technical Report 61-96, Properties of Inorganic Energy Conversion and Heat Transfer Fluids for Space Applications.
10. Huber, D. A. and Hoehne, J. C., "Pool Boiling Investigation of Benzene, Diphenyl, and Benzene-Diphenal Mixtures under Pressure", NAA-SR-6681.
11. Griffith, P. and Wallis, J. D., "The Role of Surface Conditions in Nucleate Boiling", AICHE Preprint 106 presented at the Third National Heat Transfer Conference ASME-AICHE, Aug. 9 - 12, 1959.
12. Harrison, W. B. and Levine, Z., "Wetting Effects on Boiling Heat Transfer", AICHE Paper 57-HT-29.
13. Mumm, J., "Heat Transfer to Boiling Water Forced Through a Uniformly Heated Tube", ANL-5276.
14. Alman, M., Norris, R. H. and Staub, F. W., "Local and Average Heat Transfer and Pressure Drop for Refrigerants Evaporating in Horizontal Tubes", Trans. Am. Soc. Mech. Engrs. Ser. C, J. Heat Transfer 82, 189 (1960).
15. Hoffman, H. W. and Krakoviak, A. J., "Forced Convection Saturated Boiling of Potassium at Near Atmospheric Pressure", ORNL Report.
16. E. Bernstein, "Engineering Report on the Design of the Pratt & Whitney Aircraft Forced Convection Alkali Metal Vaporization-Condensation Heat Transfer Rig", CNLM-4358, January 18, 1963.
17. M. Jacobs and J. Hawkins, "Elements of Heat Transfer and Insulation, John Wiley & Sons, April, 1954.
18. J. Petrek, "Operating Instructions for the Forced Convection Alkali Metal Vaporization-Condensation Heat Transfer Rig", CNLM-5047, May 22, 1963.
19. Alkali Metals Boiling and Condensing Investigations, NASA Contract NAS-3-2528, NAS-5681, General Electric.
20. S. Fanciullo, "Thermocouple Development, Lithium Cooled Reactor Experiment", PWAC-422, March, 1964.

21. S. Fanciullo, "Development of Liquid Metal Level Probes", PWAC-423, April, 1964.
22. E. Bernstein, J. Petrek, J. Meregian, "Evaluation and Performance of Once-Through Zero Gravity Boiler Tubes with Two-Phase Water", PWAC-428, April, 1964.
23. Personal Communication with L. Beltracchi of P&WA.
24. Personal Communication R. Fritz, J. Horan, and D. Sadowsky of P&WA.
25. Correlation of Boiling Potassium Heat Transfer Data, TIM-832, Pratt & Whitney Aircraft, CANEL, June 16, 1964, D. Sadowsky.

APPENDIX A



EQUATION REPRESENTATION OF DATA

All the boiling heat transfer and pressure drop data obtained from the test boiler is best represented by the following equations:

Heat Transfer (x = fractional vapor quality, h_b = heat transfer coefficient, Btu/hr ft² F)

For $0 \leq x \leq 0.2$

$$h_b = 40,000 x + 7000$$

For $0.2 \leq x \leq 0.4$

$$h_b = 10^4 \sqrt{\frac{x-0.055}{0.0645}}$$

For $0.40 \leq x \leq 0.75$

$$h_b = 25,420 - 1.187 \times 10^5 (x - 0.54)^2$$

For $0.75 \leq x \leq 0.80$

$$h_b = 75,700 - 74,000 x_n$$

For $0.80 \leq x \leq 0.85$

$$h_b = 115,700 - 124,000 x_n$$

For $0.85 \leq x \leq 0.90$

$$h_b = 125,900 - 136,000 x_n$$

For $0.90 \leq x \leq 0.92$

$$h_b = 79,500 - 84,500 x_n$$

For $0.92 \leq x \leq 1.0$

$$h_b = 275 \times 10^3 (1 - x_b)^2 + h_v$$

Where h_v is calculated from Nusselt type forced convection equation using vapor properties.

Pressure Drop (ΔP in psi, flow = 17 lb/hr, ID = 0.186 inch, serpentine tube length = 14.98", equivalent straight length between pressure taps).

For $0.0 \leq x \leq 0.50$

$$\Delta P = 1.96 x + 0.02$$

For $0.50 \leq x \leq 1.0$

$$\Delta P = 1.4 x + 0.30$$

APPENDIX B



NOMENCLATURE FOR BKHT-1 SAMPLE CALCULATIONS

| | | |
|----------------|---|--|
| A | = | Heat transfer area, ft ² |
| C _p | = | Specific heat, Btu/lb F |
| C | = | Nusselt equation constant, 0.725 |
| D | = | Outer diameter of tube on which condensing occurs, ft. |
| g | = | Gravitational constant, 418 (10 ⁶) ft/hr ² |
| h | = | Local boiling heat transfer coefficient, Btu/hr ft ² F |
| I | = | Immersion heater current, amps |
| K | = | Thermal conductivity, Btu-in/ft ² hr F |
| L | = | Length, ft |
| P | = | Pressure, psia |
| ΔP | = | Pressure differential, psi |
| q | = | Heat flux, Btu/hr ft ² |
| Q | = | Heat flow, Btu/hr |
| U | = | Over-all boiling heat transfer coefficient, Btu/hr ft ² F |
| r | = | Radius, ft. |
| t | = | Temperature, F |
| T | = | Temperature, F |
| ΔT | = | Temperature difference, F |
| V | = | Immersion heater voltage, volts |
| W _f | = | Mass flow, lb/hr |
| W | = | Immersion heater power, watts |
| X | = | Average vapor quality by weight |
| ΔX | = | Quality Change |

Greek Symbols

| | | |
|---|---|-------------------------------------|
| λ | = | Latent heat of vaporization, Btu/lb |
| ρ | = | Density, lb/ft ³ |
| μ | = | Viscosity, lb/ft hr |

Subscripts

| | | |
|---|---|------------------|
| a | = | Atmospheric |
| B | = | Boiling |
| c | = | Condensing |
| h | = | Head effects |
| H | = | Haynes-25 alloy |
| i | = | Inside |
| o | = | Outside |
| L | = | Liquid metal |
| P | = | Preboiler |
| S | = | Superheat boiler |
| T | = | Test boiler |
| W | = | Wall |

| | | |
|-----|---|--|
| C/D | = | Condenser discharge |
| C/F | = | Condensing film |
| PI | = | Preboiler inlet |
| PS | = | Preboiler shell |
| PT | = | Preboiler tube |
| TS | = | Test boiler shell |
| TS | = | Tube to shell (when used with ΔP) |
| TT | = | Test boiler tube |

Conversion Constants

| | | |
|---|---|--|
| a | = | 0.0903 psi/scale division (100% scale = 250" H ₂ O) |
| b | = | 0.1805 psi/scale division (100% scale = 500" H ₂ O) |
| c | = | 0.0361 psi/scale division (100% scale = 100" H ₂ O) |
| d | = | 3.413 Btu/hr watt |
| e | = | 0.23 psi/F (slope of "K" vapor pressure curve) |

Pressure Locations

| | | |
|-----|---|--|
| P3 | - | Condenser discharge pressure |
| P4 | - | Preboiler cavity shell pressure |
| P4K | - | Preboiler shell pressure converted to "K" Pressure |
| P5 | - | Test boiler cavity shell pressure |
| P7 | - | Preboiler tube side pressure drop |
| P8 | - | Test boiler tube side pressure drop |
| P9 | - | Superheat boiler tube side pressure drop |
| P10 | - | Condenser pressure drop |
| P21 | - | Test boiler shell to tube pressure differential |

SAMPLE CALCULATIONS FOR BKHT-1

Sample Calculations for BKHT-1 using Run No. 19. Physical properties were obtained from Ref. 9.

I. "K" loop flow.

From flowmeter calibration curve (Fig. 14) at 0.1375 mv.

$$W_f = 17.32 \text{ lb/hr}$$

II. The system pressure distribution can be determined from gage readings corrected for atmospheric and head effects.

A. Condenser discharge pressure (psia)

$$P_{C/D} = P_3 + P_a + P_{h3}$$

$$P_{C/D} = 48.84 \text{ psia}$$

B. Condenser pressure drop (psi)

$$\Delta P_C = (P_{10} - P_{h10})_a$$

$$\Delta P_C = 2.94 \text{ psi}$$

C. Boiler tube-side pressure drop (psi)

1. Preboiler

$$\Delta P_P = (P_7 \times b) + P_{h7}$$

$$\Delta P_P = 4.11 \text{ psi}$$

2. Test Boiler

$$\Delta P_T = (P_8 \times C)$$

$$\Delta P_T = 1.64 \text{ psi}$$

3. Superheat Boiler

$$\Delta P_S = (P_9 \times b)$$

$$\Delta P_S = 5.31 \text{ psi}$$

D. Preboiler inlet pressure (psia)

$$P_{PI} = P_{C/D} + \Delta P_C + \Delta P_S + \Delta P_T + \Delta P_P$$

$$P_{PI} = 62.85 \text{ psia}$$

E. Boiler shell-side pressure (psia)

1. Preboiler

From the Experimental Relation of Potassium and Sodium Vapor Pressures (Fig. 25) and $(P_4)_{Na} = 15.4 \text{ psig}$

$$P_{4K} = 57.0 \text{ psig}$$

$$P_{PS} = P_{4K} + P_a + P_{h4}$$

$$P_{PS} = 71.72 \text{ psia}$$

2. Test Boiler

$$P_{TS} = P_5 + p_a + P_{h5}$$

$$P_{TS} = 73.12 \text{ psia}$$

F. Boiler average tube-side pressure(psia)

1. Test Boiler

$$P_{TT} = P_{C/D} + \Delta P_C + \Delta P_S + \frac{\Delta P_T}{2}$$

$$P_{TT} = 57.92 \text{ psia}$$

G. Test boiler, shell-to-tube pressure differential

$$\Delta P_{TS} = P_{TS} - P_{TT}$$

$$\Delta P_{TS} = 15.2 \text{ psi}$$

III. The boiler heat fluxes can be determined from power measurements on immersion heaters.

A. Preboiler

$$W_P = V_P I_P$$

$$W_P = 3940 \text{ watts}$$

$$q_P = \frac{W_P \times d}{A_P}$$

$$q_P = 50,200 \text{ Btu/hr ft}^2$$

B. Test Boiler

$$W_T = 205.7 \text{ watts}$$

$$q_T = \frac{W_T \times d}{A_T}$$

$$q_T = 16,570 \text{ Btu/hr ft}^2$$

IV. Preboiler Over-all Coefficient

A. Preboiler heat to preheat liquid to saturation temperature

$$Q_P = W_f C_P (T_b - T_1)$$

$$Q_P = 738 \text{ Btu/hr}$$

B. Preboiler heat to vaporizing liquid

$$Q_B = Q_T - Q_P$$

$$Q_B = 12,610 \text{ Btu/hr}$$

C. Preboiler exit quality

$$X_P = \frac{Q_B}{W_f \lambda}$$

$$X_P = 0.896$$

D. Preboiler over-all heat transfer coefficient

$$U_P = \frac{Q_P}{T_{PS} - T_{PT}}$$

$$U_P = 1041 \text{ Btu/hr ft}^2 \text{ F}$$

V. Test Boiler local heat transfer coefficient

A. Quality change in test boiler

$$\Delta X_T = \frac{Q_T}{W_f} \qquad X_T = X_{PT} \frac{\Delta X_T}{2}$$

$$\Delta X_T = 0.0496 \qquad X_T = 0.921$$

B. Local heat transfer coefficient

1. Temperature difference from shell to tube can be corrected for wall temperature drop (ΔT_W) and condensing film temperature drop ($\Delta T_{C/F}$).

a. Wall Temperature Drop

Equation for heat conduction through a homogeneous cylinder wall is

$$Q = \frac{2\pi L K_H (t_i - t_o)}{1_N r_o/r_i} = q_T A_T$$

$$\frac{2\pi L K_H \Delta T_W}{1_N r_o/r_i} = 2\pi L r_i q_T$$

$$\Delta T_W = \frac{r_i 1_N r_o/r_i}{K} q_T$$

for

$$\Delta T_W = 1.45 \times 10^{-4} q_T^2$$

$$q_T = 16,570 \text{ Btu/hr ft}^2$$

$$\Delta T_W = 2.4 \text{ }^\circ\text{F}$$

b. Condensing Film Temperature Drop

Nusselt's theory of film condensation on a horizontal tube (Ref. 17) and Newton's law of cooling ($Q = hA\Delta t$) can be applied to obtain an approximation.

$$\frac{hD}{K} = C \left(\frac{g\rho^2 \lambda D^3}{K_L M \Delta T_{C/F}} \right)^{1/4}$$

$$h = \frac{Q/A}{\Delta T_{C/F}}$$

Using these equations, a condensing film temperature drop of 1.0F at a heat flux of 20,000 Btu/ft² hr was determined. This correlation is applicable to condensing metal vapors at 102 Reynolds Moduli which occur in this case.

2. For high tube-to-shell temperature differences, the shell cavity and average tube temperatures can be obtained from potassium vapor pressure at their recorded pressures.

$$\begin{aligned}
 T_{TS} &= 1769 \text{ at } P_{TS} = 73.12 \text{ psia} \\
 T_{TT} &= 1704\text{F at } P_{TT} = 57.92 \text{ psia} \\
 \Delta T_B &= T_{TS} - T_{TT} - \Delta T_W - \Delta T_{C/F} \\
 \Delta T_B &= 62.5\text{F} \\
 h_T &= \frac{q_T}{\Delta T_B} \\
 h_T &= 265 \text{ Btu/hr ft}^2\text{F}
 \end{aligned}$$

3. For low tube-to-shell temperature differences, a shell-to-tube differential pressure measurement* can be used to determine this small differential. For Run No. 1-16,

$$\begin{aligned}
 \Delta T_B &= \frac{(P_{21} \times a) + \Delta P_T / 2}{e} - T_W - \Delta T_{C/F} \\
 \Delta T_B &= 32\text{F} \\
 h_T &= \frac{q_T}{\Delta T_B} \\
 h_T &= 563 \text{ Btu/hr ft}^2\text{F}
 \end{aligned}$$

*For greater accuracy, the differential pressure scale was set at 0 - 250" H₂O. Therefore, this calculation can be made for temperature differences less than 40F.

APPENDIX C
(Reference 24)



BOILING HEAT TRANSFER CORRELATION


In order to generalize the many types of data from many sources, a continuing attempt to correlate available information has produced some promising results.

Available data was plotted and cross plotted until a significant parameter was established. The results of this effort are shown in Fig. 34. This work was then extended to 100 percent vapor quality when all the data from this test was obtained. This empiricism is described in Fig. 35. A comparison with actual data is shown in Fig. 36.

If this work continues to look promising, a report will be circulated describing the correlation in more detail.

NUCLEATE BOILING CORRELATION

THIS CORRELATION IS FOR NUCLEATE BOILING ENTERING
AT BOILING POINT AND "0" QUALITY, AND LEAVING AT
"X" QUALITY



82

P W A C - 429
FIG 34

FULL RANGE BOILING CORRELATION

$$h_{\text{local}} = h_L(1-x) + h_g x + h_{\text{TPF}}(x)(1-x)^{(1)}$$

where:

$$h_L = h_1 + (\text{Chen}) \Delta T_{\text{film}}, \quad \frac{h_1 D}{K_1} = 5.0$$

(Chen)⁽²⁾ is a coefficient of bubble contribution dependent on physical properties for potassium

| T °R | (Chen) |
|------|--------|
| 1660 | 270 |
| 1860 | 450 |
| 2060 | 690 |
| 2260 | 980 |

$$h_g = c_1 c_2 h_2, \quad \frac{h_2 D}{K_g} = 0.023 N_{\text{Reg}}^{0.8} N_{\text{Prg}}^{0.4}$$

$c_1 \doteq 1$, roughness and/or curvature contribution

$c_2 \doteq 3$, upstream condition contribution⁽³⁾

$$h_{\text{TPF}} = c_3 N_{\text{Re}_{\text{TPF}}}^{\frac{1}{2}} \left(\frac{T}{\Delta T_{\text{film}}} \right)^{1/2}$$

$c_3 =$ dimensional constant 14.0 Btu/hr-ft²-F

$$N_{\text{Re}_{\text{TPF}}} = \frac{\text{inertia forces}}{\text{viscous forces}} = \frac{\left[\frac{G}{\rho_L} \left\{ 1 + x \left[\left(\frac{\rho_L}{\rho_g} \right)^{2/3} - 1 \right] \right\} \right]^2 \frac{1}{R_o} + g}{\frac{\mu_L G}{D^2 \rho_L^2} \left\{ 1 + x \left[\left(\frac{\rho_L}{\rho_g} \right)^{2/3} - 1 \right] \right\}} \quad \text{from}$$

$$\frac{V_g}{V_L} \doteq \left(\frac{\rho_L}{\rho_g} \right)^{1/3}$$

(1) Major groupings shown in Fig. 34.

(2) Chen, J. C. ASME Preprint 63-HT-34. Also Brookhaven National Lab Report BNL 7319.

(3) This increase in gas coefficient is believed to be caused by shear between liquid droplets and vapor. No correlating description of this surviving turbulence contribution is available.

FIG 36

COMPARISON OF EXPERIMENTAL DATA WITH FULL RANGE BOILING CORRELATION

