



NYO-7875

NYO-7875

MASTER

# TECHNICAL MEMORANDUM



## PROJECT MATTERHORN

Contract AT(30-1) - 1238 with the  
US Atomic Energy Commission

PRINCETON UNIVERSITY

PRINCETON, NEW JERSEY

835-001

### NOTICE

This document contains information of a preliminary nature and was prepared primarily for internal use at Project Matterhorn, Princeton University. It is subject to revision or correction and therefore does not represent a final report.

The information is not to be abstracted or otherwise given public dissemination without approval. For information regarding such approval, contact E. Aubin.

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

Project Matterhorn  
Princeton University  
Princeton, N.J.

Test of Granville-Phillips Type C Ultra-High

Vacuum Valve

Herbert Sauer

Tech Memo No. 33

Retyped: May, 1960

~~NYO 6378~~  
7875

AEC RESEARCH AND DEVELOPMENT REPORT

This work was supported under Contract AT(30-1)-1238 with the Atomic Energy Commission. Reproduction, translation, publication, use and disposal in whole or in part, by or for the United States Government is permitted.

## Test of Granville-Phillips Type C Ultra-High Vacuum Valve

Tests were made of one Granville-Phillips UHV valve to determine its characteristics, and in particular, the feasibility of baking the valve closed at high temperatures ( $400^{\circ}\text{C}$ ) to enable a copper foil vapor trap to be baked while isolated from its system by means of one of these valves. A photograph and sketch of the valve will be found at the end of this report.

The valve was installed on a typical Alpert-type UHV system, and the system was given two ten-hour  $400^{\circ}\text{C}$  bake-outs. The pressure achieved in the system was  $5 \times 10^{-10}$  mm. Hg.

### I. Conductance vs. Torque

The method used in determining the conductance was to pump the system, close the valve, and observe the rate of rise of pressure in a closed volume when the arm of the valve was exposed to dried air at atmospheric pressure. After baking the system with the valve held open with a bake-out clamp, the valve was closed to the desired torque and a rate of rise determined. Then the system was rebaked in preparation for a determination at the new closing torque. It should be noted that all bakes mentioned in this report were performed at  $400^{\circ}\text{C}$  for 10 hours. The open-valve bake-outs did not appear to affect noticeably the operation of the valve in that successive determinations of the conductance at the same closing torque were consistent.

The values found for various closing torques between 200 in. lbs. and 400 in. lbs. are tabulated below:

TABLE I

Closing torque (in. lbs.)	Conductance (l/sec)
200	$4.1 \times 10^{-10}$
250	$1.1 \times 10^{-10}$
300	$5.5 \times 10^{-11}$
350	$2.5 \times 10^{-11}$
400	$1.0 \times 10^{-11}$

These values correspond reasonably with the results obtained on a valve of similar construction reported by D.G. Bills and F.G. Allen of Harvard University. (Fig. 1)



## II. Feasibility of Closed-Valve Bake-outs.

The valve was baked once, closed to a torque of 200 in. lbs. using the normal drive mechanism. On opening, some degree of sticking was noted but apparently the valve was not damaged in that a redetermination of the conductance at a closing torque of 300 in. lbs. yielded a value of :

$$C = 5.8 \times 10^{-11} \quad \text{l/sec}$$

which agrees very well with the previously obtained value in Table I.

At this point, the system was modified in that the valve was used to isolate the UHV system from an untrapped auxiliary mechanical pump operating at a pressure of 2-microns. It was felt that the mechanical pump would effectively simulate a source of oil and contaminants that might be expected from baking a saturated copper foil trap.



The valve was then re-closed to 200 in. lbs. and baked with the UHV system. Upon completion of the bake, it was backed off just a bit to determine the degree of sticking and immediately reclosed to 300 in. lbs. The pressure attained by the UHV system was found to be  $5 \times 10^{-10}$  mm. Hg.

This procedure was followed for a total of five bake-outs. In all cases the terminal pressure of the UHV system was approximately  $5 \times 10^{-10}$  mm. Hg. From this alone, a maximum value of conductance of the valve could be set at  $1 \times 10^{-9}$  l/sec. This value would probably be adequate for purpose of trap isolation.

It should be noted that some erratic action of the drive mechanism occurred after the second bake due to the deterioration of the screw threads and ball-bearings at temperatures for which they were not designed to operate. (ie.  $400^{\circ}\text{C}$ ) This may have caused some discrepancy in the thrust applied to the valve at the prescribed closing torque, but it is felt that errors from this source are not excessive.

### III. Re-determined Conductance Values


At the completion of the five closed bake-outs, the conductance of the valve was again determined as in the first part. The results are tabulated below:

TABLE II

Closing torque (in. lbs.)	Conductance (l/sec)
200	$5 \times 10^{-10}$
250	$3.5 \times 10^{-10}$
300	$2.0 \times 10^{-10}$
* 350	$5.0 \times 10^{-11}$
400	$1.5 \times 10^{-11}$




\* Note: The first determination at 350 in. lbs. yielded a value of C of  $3 \times 10^{-13}$  1/sec. Three subsequent determinations yielded the value tabulated. It is not certain whether this extremely low value was true or merely the result of faulty data.

These values of conductance, while deviating from the original run, seem to indicate that certainly this valve did not seriously suffer from the high temperature bake-outs and could be considered still reliable.



4-DRIVER MOUNTING  
SCREW 1/4 - 20 x 1 1/2  
2 9/16 DBC

3-VALVE MOUNTING  
SCREW 10 - 32 x 1/2  
1 3/4 DBC




TOLERANCE  $\pm 1/64$ " UNLESS SPECIFIED

GRANVILLE - PHILLIPS CO  
CAMBRIDGE, MASSACHUSETTS

TYPE C ULTRA-HIGH VACUUM VALVE

MATERIAL	DRAWING NO. C-12
SCALE 1:1	SUPERSEDES NO.
DRAWN BY	CHECKED BY
	SUPERSEDED BY NO.



835 009



Do NOT PHOTOSTAT

**LEGAL NOTICE**

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission to the extent that such employee or contractor prepares, handles or distributes, or provides access to, any information pursuant to his employment or contract with the Commission.