

MASTER

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

DUQUESNE LIGHT COMPANY

SHIPPINGPORT ATOMIC POWER STATION

TEST RESULTSDLCS 3070102
T-641100-B**PRIMARY PLANT SELF-ACTUATED RELIEF VALVE OPERATION**

CORE I SEED 2

Section 1 of 2 Sections

First Issue, March 13, 1961

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

TEST RESULTS
DLCS 3070102
T-641100-B
PRIMARY PLANT SELF-ACTUATED RELIEF VALVE OPERATION
CORE I SEED 2

Purpose

To insure the reliable operation of the self-actuated pressurizer steam relief valve (06-H15-10).

Conclusion

The self-actuated pressurizer steam relief valve (06-H15-10) was tested to operate within the prescribed setting of 2300 + 50 psig. The valve popped at 2265 psig and reseated at 2190 psig, with a time lapse of 12.9 seconds between popping and reseating. Leak rates before and after popping of the valve were 0.70 gallons/hour and 1.35 gallons/hour, respectively. The valve performed reliably in that it popped within the prescribed setting and then reseated with no valve chatter or flutter being observed.

Description of Test Equipment and Test Procedure

The reactor plant was maintained at 500 F and 1800 psig with the reactor shutdown and three reactor coolant pumps (1A, 1B, 1C) on fast speed. The leakage of the pressurizer self-actuated steam relief valve (06-H15-10) was measured and recorded utilizing the leak collection vessel. Next, the pressurizer steam relief valve was tested by raising System pressure with the pressurizer to 2260 psig and lifting the valve open by use of the hand lifting level. The valve was held open for approximately five seconds and then released to close sharply. This operation was performed to blow out crud and other foreign matter to reduce the probability of any crud becoming lodged between the relief valve seating surfaces. System pressure was then raised with the pressurizer to actuate the valve and the performance was observed and data recorded. In order to actuate only this valve other relief valves were gagged to prevent them from popping. After the relief valve set pressure was determined, a leak rate of the valve was performed at System pressure and temperature of 1800 psig and 500 F, respectively.

Results

The pressurizer steam relief valve (06-H15-10) was tested on June 14, 15, and 18. This was the only valve that was tested for this performance of DLCS 3070102. On June 14 and 18, before and after the valve was popped, leak rate tests were performed. The leak rates were 0.70 gallons/hr and 1.35 gallons/hr., respectively. The leak rate increased by approximately a factor of two after the valve was popped. All water initially in the piping downstream of the relief valve was allowed to drain before commencing the leak rate measurements. It was also noted that the leak rate was constant over the one hour period. The leak rates are tabulated in Table I.

TEST RESULTS DLCS 3070102

T-641100-B

PRIMARY PLANT SELF-ACTUATED RELIEF VALVE OPERATION

The steam relief valve (06-H15-10) was popped at 1960 hours of June 15, 1960 at a pressure of 2265 psig and reseated at 2190 psig. This popping pressure was within the prescribed setting of 2300 ± 50 psig. Valve temperatures and plant parameters were taken before and after the valve was popped. The valve had a blow-down of 3.3% as compared to 4.0% blow-down on the previous performance of this test. The data recorded during the popping of the pressurizer steam relief valve is presented in Tables II and III. The valve performed reliably in that it lifted and reseated with no valve chattering or flutter being observed.

It was noted that steam was leaking out of the relief valve at the plug which covers the set screw. Steam was also observed leaking out of the other pressurizer self-actuated relief valve (06-H15-1) at the setscrew. The leak was noted when the pressurizer pressure was increased from 1900 psig to approximately 2300 psig. New copper gaskets were installed on the plugs of both valves (06-H15-1 and 06-H15-10) on June 23, 1960.

The Norwood Indicator for the pressurizer temperature was off scale at a pressure of 2260 psig. Using saturation pressure tables (Table 2) in Keynan and Keyes, Thermodynamic Properties of Steam, the pressurizer temperature was found to be 653 F.

DUQUESNE LIGHT COMPANY
POWER STATIONS DEPARTMENT
SHIPPINGPORT ATOMIC POWER STATION

PRIMARY PLANT SELF-ACTUATED RELIEF
VALVE OPERATION
DLCS 3070102 (T-641100-E)

TABLE I
Pressurizer Relief Valve (06-H15-10)

Date	Leak Rate	Leak Rate	
	Duration of Test	Inches of water	Leak rate (gal/hr)
6-14-60	45 Minutes	2. 1/8	0.698
6-18-60	1 Hour	5. 1/2	1.353

TABLE II
Pressurizer Relief Valve (06-H15-10)

Date of Test	6-15-60
Time When Valve Popped	1434
Pressure When Valve Popped	2265 psig
Pressure When Valve Reseated	2190 psig
Reset Time	12.9 sec.

TABLE III

	Before Valve Popped	After Valve Popped
Average Temp. (F)	500	500.2
Reactor Press. (psig)	2260	2200
Pressurizer Temp. (F)	*653	*650
Pressurizer Level (in)	168	165
Valve Temperatures (F)		
Body (at Lower Adjusting Ring)		
Set Screw	210	270
Bonnet (at Tell-Tale Nipple)	140	149
Inlet Nipple (at Test Ring)	520	600+
Outlet Nipple (at Test Ring)	225	260

* Pressurizer Temp. Indicator was off-scale - The pressurizer temperatures before and after were calculated by assuming saturation temperatures at pressurizer pressures of 2260 and 2200 psig, respectively.

TEST RESULTS DLCS 3070102

T-641100-B

PRIMARY PLANT SELF-ACTUATED RELIEF VALVE OPERATION

Results Prepared By

Jay F. Henricksen, Jr. P.E.

Results Reviewed By

Robert J. Lawrence

Approved (Duquesne Light Company)

George O. Santel

Date

3-13-61