

P  
MASTER

JUL 5 1960

DUQUESNE LIGHT COMPANY

SHIPPINGPORT ATOMIC POWER STATION

TEST RESULTS

DLCS 2310302  
T-612394

PERIODIC RADIATION SURVEY

CORE I, SEED 1

Section 3 of 3 Sections

First Issue, June 17, 1960

868 001

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

## TEST RESULTS

DLCS 2310302  
T-612394

### PERIODIC RADIATION SURVEY

CORE I, SEED 1

#### Purpose

To determine the radiation level inside the concrete enclosures but outside the Reactor Plant Containers after shutdown following plant operation. This information was necessary to determine possible build up of contamination in these areas during the life of the plant.

#### Conclusions

Radiation levels in the 1AC, 1BD Boiler Chamber enclosures and in the Reactor Chamber enclosure were on the average at a higher radiation level than the previous performance of this test. The highest reading obtained was 7.5 mr/hr and the lowest reading was .03 mr/hr with a mean radiation level of 3.76 mr/hr as compared to a 1.37 mr/hr mean radiation level for the previous performance of this test.

#### Description of Test Equipment and Test Procedure

With the reactor plant shut down, portable survey meters were used to measure the radiation levels inside the concrete enclosure around the Reactor Plant Containers.


#### Results


DLCS 2310302, Periodic Radiation Survey, was performed October 7, 1959. Location of the survey points are shown in Figures 3, 4 and 5 and their radiation levels are listed in Tables I, II and III. Calibration data for the portable survey meters are listed in Table IV. The power history is shown in Figure 1.

There are a total of six points below the average radiation level by a factor of three and one point above the average radiation level by a factor of three. These points are indicated by an asterisk (\*) on Tables I, II and III. Figure 2 is a decay curve of the radiation level at point 1 in the reactor chamber enclosure. Point 1 was monitored every half hour for three hours and every hour for the next five hours. The decay indicates that the level is due to an isotope or a composite of isotopes with an approximate 76 hour half life. These radiation readings were taken at chest level which is approximately four feet above floor level.

DUQUESNE LIGHT COMPANY  
POWER STATIONS DEPARTMENT  
SHIPPINGPORT ATOMIC POWER STATION

PERIODIC RADIATION SURVEY  
DLCS 2310302  
T-612394





DUQUESNE LIGHT COMPANY  
POWER STATIONS DEPARTMENT  
SHIPPINGPORT ATOMIC POWER STATION

PERIODIC RADIATION SURVEY  
DLCS 2310302  
T-612394

FIGURE 3




TABLE I.

METER - THYAC NO. 947

Point	Time	mr/hr
1	1003	.03
2	1003	.03
3	1004	.04
4	1004	.03
5	1004	.03
6	1005	.09
7	1005	.65 *
8	1006	.065
9	1006	.03
10	1006	.07

Floor and air lock platform 0.03 mr/hr

\* Above average radiation level by a factor of three (3).

FIGURE 4




TABLE II

Meter Jordon No. 733  
1AC Boiler Container  
Enclosure

Point	Time	mr/hr
11	0920	4.0
12	0919	5.25
13	0919	3.25
14	0918	0.50 *
15	0918	3.25
16	0925	5.0
17	0924	7.5
18	0924	5.0
19	0923	0.5 *
20	0923	3.0
21	0922	6.0
22	0922	3.2
23	0921	3.0
24	0921	0.5 *
25	0920	2.5

Meter Thyac No. 974  
1BD Boiler Container  
Enclosure

Point	Time	mr/hr
11	0930	0.7 *
12	----	0.7 *
13	----	3.0
14	----	3.0
15	----	4.0
16	----	1.0
17	----	1.5
18	----	0.7 *
19	----	0.8
20	----	1.0
21	----	1.3
22	----	1.0
23	----	1.7
24	----	1.7
25	----	1.0


Floor and Air Lock Platform 0.03 mr/hr

\* Below average radiation level by a factor of 3

DUQUESNE LIGHT COMPANY  
POWER STATIONS DEPARTMENT  
SHIPPINGPORT ATOMIC POWER STATION

PERIODIC RADIATION SURVEY  
BLCS 2310302  
T-612394

FIGURE 5



1  
N

TABLE III

METER THYAC NO. 947

REACTOR HOT SPOT MONITORED  
FOR DECAY POINT 1  
METER THYAC NO. 947

Point	Time	Mr/hr	Time	Mr/hr
1	0940	2.50	0940	2.50
2	----	1.75	1010	2.25
3	----	1.75	1040	1.60
4	----	1.75	1110	1.60
5	----	1.75	1140	1.50
6	----	1.75	1210	1.50
7	----	1.75	1240	1.50
8	----	1.75	1340	1.50
9	----	1.75	1440	1.50
10	----	1.75	1540	1.40
11	----	1.75	1640	1.40
12	----	1.75	1740	1.45
13	----	1.75		
14	----	1.75		
15	----	1.75		
16	----	1.75		

Changed  
Meter  
Scale

DUQUESNE LIGHT COMPANY  
POWER STATIONS DEPARTMENT  
SHIPPINGPORT ATOMIC POWER STATION

PERIODIC RADIATION SURVEY  
DLCS 2310302  
T-612394

TABLE IV  
Calibration Data, Radiation Detectors

Thyac No. 974

1.1 Millicurie Co<sup>60</sup>  
Distance  
(Inches)

12.00  
37.75  
119.25

Calibrated - October 3, 1959  
Actual Calculated  
mr/hr mr/hr  
Reading Reading

15.0	15.0
1.5	1.5
0.15	0.15

Jordon No. 733

38 Millicurie Co<sup>60</sup>  
Distance  
(Inches)

6.80  
8.33  
11.78

Calibrated - October 5, 1959  
Actual Calculated  
Reading Reading  
r/hr r/hr  
mr/hr mr/hr

1.5	1.5
1.0	1.0
0.5	0.5
500	500
250	250
100	100
60	50
10	10

TEST RESULTS DLCS 2310302

T-612394

PERIODIC RADIATION SURVEY; (cont'd)

Results Prepared By

Warren Duff

Results Reviewed By

R W Noble

Approved (Duquesne Light Company)

G.O. Santel

Date

6-17-60