

ORNL-5070
UC-80 — General Reactor
Technology

Contract No. W-7405-eng-26

ENERGY DIVISION

NOISE RADIATION FROM NATURAL-DRAFT COOLING TOWERS
FOR NUCLEAR POWER PLANTS

T. G. Carley

Consultant, University of Tennessee

This study was performed for the Nuclear Regulatory Commission in connection with the development of their Nuclear Energy Center Site Survey report to Congress.

OCTOBER 1975

—NOTICE—
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION

This document is
PUBLICLY RELEASABLE
Larry E. Williams
Authorizing Official
Date: 01/18/2007

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

CONTENTS

	<u>Page</u>
ABSTRACT	v
INTRODUCTION	1
BACKGROUND	1
NOISE PREDICTION METHODOLOGY	3
Acoustic Power of Natural-Draft Cooling Towers	3
Sound Pressure Level at a Point	4
Spectrum Shape of Noise Radiated by Natural-Draft Cooling Towers	5
Attenuation of Radiated Sound due to Atmospheric Absorption	6
Attenuation of Radiated Sound due to Screening	6
Attenuation of Radiated Sound due to Gradients of Wind and Temperature	7
Attenuation of Radiated Sound due to Vegetation	8
APPLICATION OF NOISE PREDICTION METHODOLOGY TO THE KENTUCKY LAKE NEC SURROGATE SITE	9
Results for a Typical Four-Reactor Site	10
Results for Kentucky Lake NEC Surrogate Site	10
REFERENCES	14
APPENDIX	15

ABSTRACT

A procedure for computing the noise levels in the vicinity of natural-draft cooling towers is presented. The noise levels are computed in overall and octave band levels with A-weighting and with no weighting. Attenuation of the noise by wave spreading, atmospheric absorption, barrier screening, vegetation, and wind and temperature gradients are included. The procedure is applied to a nuclear power plant served by four cooling towers and to a nuclear energy center with forty cooling towers.

NOISE RADIATION FROM NATURAL-DRAFT COOLING TOWERS

FOR NUCLEAR POWER PLANTS

T. G. Carley

INTRODUCTION

Cooling towers, both forced- and natural-draft, generate and radiate noise when in operation. As the tower size and thermal capacity are increased, the accompanying noise radiation increases. As the generated noise is radiated away from the cooling tower, the resulting sound pressure levels at locations in the vicinity of the power plant will be affected by various features of the landscape and prevailing weather conditions. In addition, the presence of other cooling towers or structures will modify the noise pattern. This paper presents a procedure for calculating the sound pressure levels in terms of both octave band levels and overall levels that can be expected at specified points in the vicinity of a nuclear power station that is served by natural-draft cooling towers. Minor adjustments to the procedure would make it applicable to forced-draft tower installations.

BACKGROUND

In 1971, Ellis¹ published a paper in which he developed a method for predicting the level of noise generated by natural-draft cooling towers and the radiation to points in the surrounding area. The acoustic power of the cooling towers was calculated from an empirical equation that he developed. Ellis's calculations included attenuation due to wave spreading, atmospheric absorption, and screening effects of other

cooling towers. The characteristic octave band frequency spectrum shape was obtained from octave band data taken from a number of cooling towers.

In an earlier paper by Dyer and Miller,² the acoustic power of mechanical-draft cooling towers was found to correlate very well with the rated fan power. In addition, they found the characteristic spectrum was highest at low frequencies and that it decreased monotonically with increasing frequency. Spectrum measurements made by Ellis indicate a much different character for natural-draft towers, being lowest near the 250-Hz octave band and rising with increasing frequency to a maximum near the 4000-Hz octave band.

Ellis applied his prediction method to a 2000-MW power station served by eight natural-draft cooling towers, two of which were not in service. The predicted overall A-weighted* sound pressure levels were consistently within 2% of measured levels. In each case, he assumed complete acoustical screening of a tower if the line of sight between the receiver and source was obstructed by intervening towers.

In September 1975, Capano and Bradley³ published the results of a series of noise level measurements near large natural-draft cooling towers. They concluded that Ellis's method, when applied to towers appreciably larger than the sizes upon which his method was based, consistently overestimates the noise levels by approximately 5 dB, indicating that the acoustic power of natural-draft cooling towers is not a linear function of thermal capacity over a large range of tower sizes. They indicate that an improved procedure for computing the acoustic power of a tower is in progress.

*A sound filtering system having a characteristic that roughly matches the frequency response of the human ear for sound levels up to 55 dB. (Frequently used at higher levels.)

NOISE PREDICTION METHODOLOGY

The methodology described in this paper is based on Ellis's method. The empirical estimate of the acoustic power developed by him is used in addition to the octave band frequency spectrum shape recommended in his paper. Additional attenuation mechanisms of wind, temperature gradients, local vegetation, and terrain have been incorporated into the methodology.

Acoustic Power of Natural-Draft Cooling Towers

The equation given by Ellis for computing the acoustic power of a natural-draft cooling tower is

$$W_{ac} = Mh \left[A \left(\frac{T}{h} \right)^n + B \left(\frac{D}{h} \right)^m \right] , \quad (1)$$

in which

W_{ac} = acoustic power (watts),

M = mass flow rate of cooling water (kg/sec),

h = distance water falls from culvert to pond (m),

T = depth of packing below the ring beam (m),

D = height from pond to the base of the packing (m),

A , B , m , n = empirical constants.

Ellis attempted, unsuccessfully, to correlate the acoustic power of each cooling tower to the hydraulic power dissipated, which led to the development of the empirical equation given above.

Sound Pressure Level at a Point

The acoustic intensity at a point is the acoustic power transmitted per unit area. The mean square acoustic pressure at a point is proportional to the intensity and inversely proportional to the acoustic impedance of the medium. For a plane wave,

$$\frac{P_{rms}^2}{Z_0} = I = W_{ac}/A \text{ (watt/m}^2\text{)} , \quad (2)$$

in which

P_{rms}^2 = mean square acoustic pressure (N/m^2),

Z_0 = characteristic impedance (mks rayls),

I = acoustic intensity ($watt/m^2$),

W_{ac} = total radiated acoustic power (watts),

A = area normal to wave front through which W_{ac} is transmitted (m^2).

For a concentrated source radiating a total acoustic power of W_{ac} , the mean square acoustic pressure at a point r meters away is

$$P_{rms}^2 = \frac{W_{ac} Z_0}{2\pi r^2} \text{ (N/m}^2\text{)}^2 . \quad (3)$$

This equation assumes that the radiated acoustic energy is contained in a uniformly spreading hemispherical wave. For a cooling tower, if the open height between the pond and the ring is h , then the mean square acoustic pressure at the pond rim will be

$$(P_{rms}^2)_{\text{rim}} = \frac{W_{ac} Z_0}{2\pi R h} \text{ (N/m}^2\text{)}^2 , \quad (4)$$

in which R is the base radius of the cooling tower.

The sound pressure level is defined as

$$SPL = 10 \log \left(\frac{P_{rms}}{P_{ref}} \right)^2, \quad (5)$$

in which $P_{ref} = 2 \cdot 10^{-5} \text{ N/m}^2$.

At a distance a from the rim of the pond, the mean square acoustic pressure will be given by

$$(P_{rms})^2 = \frac{W_{ac} \cdot Z_0}{\pi^2 (a^2 + 2aR)} \tan^{-1} \sqrt{\frac{a + 2R}{a}}. \quad (6)$$

This equation, again, assumes uniform hemispherical wave spreading. The corresponding sound pressure level can then be calculated relative to the reference acoustic pressure.

Spectrum Shape of Noise Radiated by Natural-Draft Cooling Towers

Ellis made a series of sound pressure level measurements near natural-draft cooling towers and established the characteristics of the frequency spectrum of the radiated noise. The octave band levels are given relative to the overall A-weighted sound pressure level. Because the spectrum is dominated by high frequencies (>1000 Hz), the overall level calculated is considered to be the A-weighted sound pressure level.

The values that, when subtracted from the A-weighted overall level, give the octave band levels are given by Ellis¹ as:

<u>Octave band center frequency</u>	<u>Level difference relative to A-weighted level</u>
125	19.4
250	19.8
500	13.0
1000	7.8
2000	6.3
4000	4.3
8000	7.2

Attenuation of Radiated Sound due to Atmospheric Absorption

As the sound radiated by the cooling tower travels through the air, acoustic energy is extracted by viscous effects, heat transfer, and molecular absorption. Molecular absorption, which is the predominant mechanism, is strongly dependent on the ambient temperature and relative humidity of the air. In 1964,⁴ the results of a number of studies were reported for determining the dependence of this atmospheric absorption of sound energy on temperature and relative humidity. These data are given in terms of attenuation in decibels per 1000 ft of wave travel for each 1/3 octave and 1/1 octave frequency band. The attenuation in each octave band is subtracted from the corresponding spectral value of the radiated sound pressure level at the receiving point.

Attenuation of Radiated Sound due to Screening

The attenuation attributable to barriers is based on wave diffraction theory and depends upon the Fresnel number, which is calculated from the wave length of the sound and the straight line distance and shortest propagation distance between source and receiver. Also, a thin rigid barrier is assumed to be obstructing the sound propagation. Experimental

data show substantial departure from this theory for screening by buildings. The data show at least a 10-dB reduction in sound pressure level for complete line-of-sight screening by intervening buildings.

When the noise is being generated by an installation with more than one tower, many receiving points will be screened by one tower from another. If the noise level at the receiving point is reduced by 10 dB for the screened tower, the level due to both towers (assuming equal acoustic power for each tower) will be less than half a decibel higher than the level at that point due to the unshielded tower alone. Consequently, when visual line of sight between a receiving point and a tower occurs, the contribution of that tower to the noise level at that receiving point is taken to be negligible. Correspondingly, the computer code requires the screening data for each receiving point and each cooling tower.

Attenuation of Radiated Sound due to Gradients of Wind and Temperature

The variation of mean temperature and horizontal wind speed with height above the ground causes refraction of propagating sound waves. This is because these gradients cause the mean speed of sound to vary with height. The sound can be refracted upward away from the ground and cause an acoustical shadow zone when there is a strong negative temperature gradient or at points upwind from the source. The effect of a wind gradient is usually the more important of the two and will override the temperature gradient effect resulting in no shadow zone down wind. Wiener and Keast⁵ have developed equations with which the

location of the shadow zone, if one exists, can be approximated and with which the excess attenuation can be calculated at any distance from the source. The data required for the computer code input are the wind and temperature gradients prevailing in the vicinity of the power plant.

Attenuation of Radiated Sound due to Vegetation

The excess attenuation of a propagating sound wave due to vegetation is considered in two parts: first, the attenuation due to shrubbery and thick grass and, second, the attenuation due to thick stands of trees. Analytical approximations of the corresponding attenuations are given in Beranek.⁶ These equations give the excess attenuation for these two cases as a function of distance from the source and the frequency of the sound wave. For broad band noise, the equations are applied to the sound pressure levels in each octave band using the octave band center frequency in the appropriate attenuation equation.

Each of the appropriate attenuations are made for each boundary point and cooling tower to obtain the octave band sound pressure levels at the boundary point at which the total noise level is being calculated. The total attenuated octave band and overall sound pressure level due to all towers is calculated at each boundary point by superimposing the level at that point calculated for each tower.

If the attenuation is such that a negative sound pressure level results (i.e., a sound pressure less than the reference sound pressure), a value of 0 dB is given, which means the sound level attributable to the cooling towers is inaudible.

APPLICATION OF NOISE PREDICTION METHODOLOGY TO THE KENTUCKY LAKE
NEC SURROGATE SITE

The noise prediction methodology was coded in FORTRAN IV for numerical computation on the IBM System 360 Model 91 at the Oak Ridge National Laboratory and was used to compute the predicted noise levels at various points at the Kentucky Lake Nuclear Energy Center Surrogate Site. First, the levels were computed at points around an arbitrarily chosen boundary of one of the four-reactor groups as though it were operating as a single dispersed reactor installation. The methodology was then used to predict the noise levels at a series of points in the NEC Surrogate Site with ten of the four-reactor units, making a total of 40 cooling towers. The points chosen were along a line, one end of which was near the center of the site, extending over 11 miles to the north.

In both cases, the elevations of the cooling tower bases and the points at which the noise levels were computed were assumed to be identical. Ecological surveys indicated that the site is covered with heavy stands of deciduous trees. Consequently, noise levels were computed to include both possible cases: when the trees are in full foliage and when they are bare. In the absence of data concerning wind and temperature variations, the gradients of both were assumed to be negligible.

Acoustical screening was assumed whenever the line of sight between a particular cooling tower and computation point was obstructed by another cooling tower or by an adjacent building. The values of the various parameters used to calculate the acoustic power of each of the cooling towers are given below:

Cooling tower base radius, m	61
Distance from water culvert to pond, m	11.8
Packing depth below ring beam, m	0
Pond to packing height, m	8.96
Pond to ring beam height, m	8.96
Elevation of tower base, m	152
Cooling water flow rate, kg/sec	57,500

The corresponding acoustic power of each cooling tower using these data was computed to be 7.06 W. This acoustic power corresponds to an A-weighted sound pressure level of 93.2 dB(A) at the rim of each tower.

Results for a Typical Four-Reactor Site

The noise levels were computed at twenty points along the arbitrarily chosen boundary of the typical four-reactor site. The site chosen was the four-unit group farthest north and west at the Kentucky Lake NEC Surrogate Site, as designated in Fig. 1. The noise levels computed at these points are given in Table 1 for both cases — when the trees are in full foliage and when they are bare.

As can be seen from Table 1, the noise levels vary from a minimum of 51 dB(A) at point number 12 to a maximum of 64 dB(A) at point number 18.

Results for Kentucky Lake NEC Surrogate Site

The noise levels were computed at twenty points along a line starting near the center of the Kentucky Lake Surrogate Site and extending due north 11.4 miles. The points along the line are 3/5 of a mile apart and are shown in Fig. 1. The computed noise levels are given in Table 2 for the cases of full tree foliage and bare trees.




Fig. 1. Kentucky Lake NEC Surrogate Site.

Table 1. Computed sound pressure levels around
a typical four-reactor site

Boundary point number	Sound pressure level ^a [dB(A)]	
	Trees in full foliage	Trees bare
1	59	59
2	60	60
3	58	58
4	60	60
5	59	59
6	57	57
7	56	56
8	54	54
9	53	53
10	59	59
11	57	58
12	0	51
13	52	58
14	5	59
15	58	58
16	57	57
17	63	63
18	64	64
19	62	62
20	61	61

^aRe: 2×10^{-5} N/m².

Table 2. Computed sound pressure levels for
Kentucky Lake NEC Surrogate Site

Noise computation point number	Sound pressure level ^a [dB(A)]	
	Trees in full foliage	Trees bare
1	8	66
2	7	64
3	0	61
4	0	60
5	0	57
6	0	59
7	0	61
8	6	61
9	5	61
10	0	58
11	0	56
12	0	54
13	0	52
14	0	51
15	0	50
16	0	49
17	0	49
18	0	49
19	0	48
20	0	47

^aRe: 2×10^{-5} N/m².

The levels vary along this line from a minimum of 47 dB(A) at point 20 to a maximum of 66 dB(A) at point 1. The attenuation effect of a thick stand of trees over appreciable distances is evident in that the levels at sixteen of the measurement points are inaudible and very nearly so at the remaining points.

REFERENCES

1. R. M. Ellis, *J. Sound Vib.* 14: 171-182 (1971).
2. I. Dyer and L. N. Miller, *Noise Control*, pp. 180-183 (May 1959).
3. G. A. Capano and W. E. Bradley, *Radiation of Noise from Large Natural Draft and Mechanical Draft Cooling Towers*, ASME Paper 74-WA/HT-55, 1975.
4. Society of Automotive Engineers, *Standard Values of Atmospheric Absorption as a Function of Temperature and Humidity for Use in Evaluating Aircraft Flyover Noise*, A.R.P. 866, New York, 1964.
5. F. M. Wiener and D. N. Keast, *J. Acoust. Soc. Am.* 31: 724-733 (1959).
6. U. Kurze and L. L. Beranek, Chapter 6 in *Noise and Vibration Control*, L. L. Beranek, ed., McGraw-Hill, 1971.

Table 2. Computed sound pressure levels for
Kentucky Lake NEC Surrogate Site

Noise computation point number	Sound pressure level ^a [dB(A)]	
	Trees in full foliage	Trees bare
1	8	66
2	7	64
3	0	61
4	0	60
5	0	57
6	0	59
7	0	61
8	6	61
9	5	61
10	0	58
11	0	56
12	0	54
13	0	52
14	0	51
15	0	50
16	0	49
17	0	49
18	0	49
19	0	48
20	0	47

^aRe: 2×10^{-5} N/m².

The levels vary along this line from a minimum of 47 dB(A) at point 20 to a maximum of 66 dB(A) at point 1. The attenuation effect of a thick stand of trees over appreciable distances is evident in that the levels at sixteen of the measurement points are inaudible and very nearly so at the remaining points.

REFERENCES

1. R. M. Ellis, *J. Sound Vib.* 14: 171-182 (1971).
2. I. Dyer and L. N. Miller, *Noise Control*, pp. 180-183 (May 1959).
3. G. A. Capano and W. E. Bradley, *Radiation of Noise from Large Natural Draft and Mechanical Draft Cooling Towers*, ASME Paper 74-WA/HT-55, 1975.
4. Society of Automotive Engineers, *Standard Values of Atmospheric Absorption as a Function of Temperature and Humidity for Use in Evaluating Aircraft Flyover Noise*, A.R.P. 866, New York, 1964.
5. F. M. Wiener and D. N. Keast, *J. Acoust. Soc. Am.* 31: 724-733 (1959).
6. U. Kurze and L. L. Beranek, Chapter 6 in *Noise and Vibration Control*, L. L. Beranek, ed., McGraw-Hill, 1971.

APPENDIX

INPUT DATA FORMATCARD 1 FORMAT (7I5, 2 F10. 3)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-5	M	Number of grid points in X-direction
6-10	N	Number of grid points in Y-direction
11-15	NBP	Number of site boundary points
16-20	NOT	Number of cooling towers
21-25	NOP	Number of points at which noise levels are to be computed
26-30	IWIND	0 - No wind or temperature effects 1 - Wind and temperature effects considered
31-35	IBOUN	0 - Coordinates of all boundary points not input 1 - Coordinates of all boundary points input
36-45	GS	Grid size in meters
46-55	AI	Acoustic impedance of air

CARD 2 FORMAT (I 3) (SKIP IF IBOUN = 0)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-3	NUM	Number of boundary point in ROW

CARD 3 FORMAT (20I3) (SKIP IF IBOUN = 0)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-NUM	IVECT	X-coordinates of boundary points in row

(CARDS 2 AND 3 ARE REPEATED N TIMES)

CARD 4 FORMAT (20I4)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-80	ICX, ICY	X and Y grid coordinates of cooling towers

(REPEATED IF MORE THAN 10 COOLING TOWERS)

CARD 5 FORMAT (20I4)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-30	IBX, IBY	X and Y are grid coordinates of points at which noise levels are to be computed

(REPEATED IF MORE THAN 10 POINTS)

CARD 6 FORMAT (10F8.2)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-80	BDYEL	Base elevation of cooling towers

(REPEATED IF MORE THAN 10 TOWERS)

CARD 7 FORMAT (I4)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-4	NOSP (I)	Number of computation points which are screened from cooling tower I

CARD 8 FORMAT (10I5)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-50	NVECT (I, J)	Grid coordinates of points J screened from cooling tower I

CARD 9 FORMAT (F5.1, 7F5.2)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-5	TEMP	Ambient temperature - °Celsius
6-40	ATMOS	Octave band atmospheric absorption values - dB/100 meter

CARD 10 FORMAT (7F6.2)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-42	ARIM	Octave band spectrum shape values to be subtracted from A-weighted level at cooling tower rim

CARD 11 FORMAT (6F10.2, E15.3)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-10	R	Cooling tower base radius (m)
11-20	H	Cooling tower hydraulic height (m)
21-30	T	Depth of packing below ring beam (m)
31-40	D	Distance from pond to packing (m)
41-50	HP	Open height at tower base (m)
51-60	BEL	Elevation of tower base (m)
61-75	RM	Water mass flow rate (kg/sec)

(REPEAT NOT TIMES)

CARD 12 FORMAT (3F10.4)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-10	VANE	Wind direction relative to X-axis (rad.)
11-20	BETA	Wind speed gradient (m/sec/m)
21-30	GAMMA	Temperature gradient (°C/m)

CARD 13 FORMAT (20I4)

<u>COLUMNS</u>	<u>VARIABLE NAME</u>	<u>MEANING</u>
1-80	IVEG (I, J)	Code for vegetation attenuation 0 - No vegetation attenuation 1 - Shrubbery and grass - no forest 2 - Forest - no shrubbery or grass

(NOT X NOP VALUES)

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

COMPILER OPTIONS - NAME= MAIN,OPT=02,LINECNT=60,SIZE=0000K,
 SOURCE,ABCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREF

```
*****  

* PROGRAM COOLNOISE *  

* PROGRAM AUTHOR *  

* T.G.CARLEY *  

*****
```

```
THIS PROGRAM COMPUTES THE OCTAVE BAND AND  

OVERALL NOISE LEVELS AT SPECIFIED POINTS  

IN THE VICINITY OF A GROUP OF POWER PLANTS  

WHICH ARE SERVED BY NATURAL DRAFT COOLING  

TOWERS.
```

```
ISN 0002      DIMENSION POW(4J),IB(72,120),BOUNBD(20,7),BOUNDA(20,7),  

>ICX(40),ICY(40),IBX(20),IBY(20),ARIM(7),ATMOS(7),R(40),H(40),  

>T(40),D(40),HP(40),BL(40),RM(40),W(40),BAND(7),BDYBND(7),  

>RIMUW(7),RIMBND(7),BDYUW(7),SLVL(7),NPISCR(40,20),PR(7),  

>ARAY1(7),ARAY2(7)  

ISN 0003      DIMENSION IVECT(120),BDYEL(20),NVECT(40,20),NOSP(40),IVEG(40,20)  

ISN 0004      EQUIVALENCE (POD(1),W(1))  

ISN 0005      PI=3.14159  

ISN 0006      READ(5,1000) N,N,NBP,NOT,NOP,IWIND,IBOUND,GS,AI  

ISN 0007      1000 FORMAT ?7I5,2E10.3)  

ISN 0008      C      IF(IBOUND.EQ.0) GO TO 6  

ISN 0009      C      I=1  

1 READ(5,1001) NU1  

  READ(5,1002) (IVECT(K),K=1,NUM)  

  I2=1  

  J=1  

2 IF(J.LT.IVECT(I2)) GO TO 3  

  IB(I,J) = 1  

  I2=I2+1  

  GO TO 15  

3 IB(I,J)=0  

15 J=J+1  

  IF(J.GT.N) GO TO 4  

  GO TO 2  

4 I=I+1  

  IF(I.GT.N) GO TO 6  

  GO TO 1  

6 CONTINUE  

1001 FORMAT (I3)  

1002 FORMAT (20I3)  

  READ(5,1020) (ICX(I),ICY(I),I=1,NOT)  

1020 FORMAT (20I4)  

  READ(5,1030) (IBX(I),IBY(I),I=1,NOP)  

1030 FORMAT (20I4)
```

```

ISN 0036      READ(5,1015) (BDFYL(K),K=1,NOP)
ISN 0037      1015 FORMAT(10F8.2)
C
ISN 0038      DO 7 I=1,NOT
ISN 0039      READ(5,1028) NOSP(I)
ISN 0040      IF((NOSP(I)).EQ.0) GO TO 7
ISN 0042      JN=NOSP(I)
ISN 0043      READ(5,1029) (NVECT(I,J),J=1,JN)
ISN 0044      7 CONTINUE
ISN 0045      1028 FORMAT(1I4)
ISN 0046      1029 FORMAT(10I5)
ISN 0047      READ(5,1045) TEAP,(ATMOS(I),I=1,7)
ISN 0048      1045 FORMAT(1F5.1,7F5.2)
ISN 0049      READ(5,1040) (ARIM(I),I=1,7)
ISN 0050      1040 FORMAT(7F6.2)
ISN 0051      DO 10 I=1,NOT
ISN 0052      10 READ(5,1025) R(I),H(I),T(I),D(I),HP(I),BL(I),RM(I)
ISN 0053      1025 FORMAT(6F10.2,E15.3)
ISN 0054      READ(5,1190) VAVE,BETA,GAMMA
ISN 0055      1190 FORMAT(3F10.4)
C *****READ SCREENING DATA VALUES OF IVEG *****
ISN 0056      READ(5,1030) (IVEG(I,J),J=1,NOP),I=1,NOT)
ISN 0057      WRITE(6,6000)
ISN 0058      WRITE(6,6010) (I(I),H(I),T(I),D(I),HP(I),BL(I),RM(I),I=1,NOT)
ISN 0059      6000 FORMAT('1',50X,'COOLING TOWER DATA',//6X,'COOLING TOWER',4X,'HYDRA
>ULIC',3X,'PACKING DEPTH',5X,'POND TO',6X,'POND TO RING',6X,'BASE',
>7X,'COOLING WATER',1X,'6X,'BASE RADIUS',6X,'HEIGHT',5X,'BELOW RIN
>G BEAM',1X,'PACKING HEIGHT',2X,'BEAM HEIGHT',5X,'ELEVATION',6X,'FL
>OW RATE',1X,'7X,'(METERS)',7X,'(METERS)',7X,'(METERS)',8X,'(METER
>S)',6X,'(METERS)',7X,'(METERS)',8X,'(KG/SEC')
ISN 0060      6010 FORMAT('0',1X,7E15.3)
ISN 0061      CALL POWER(R,H,E,D,RM,POW,NOT)
ISN 0062      WRITE(6,6045) NOT
ISN 0063      6045 FORMAT('0',2X,///40X,'THE ACOUSTIC POWER OF THE COOLING TOWERS IN
> WATTS',/55X,I4,' COOLING TOWERS')
ISN 0064      WRITE(6,6050) (POW(I),I=1,NOT)
ISN 0065      6050 FORMAT(10E10.3)
ISN 0066      WRITE(6,6055)
ISN 0067      6055 FORMAT('0',2X,///53X,'NEC SITE DATA')
ISN 0068      WRITE(6,1070) M,N,NBP,NOT,NOP,GS,AI
ISN 0069      1070 FORMAT(5X,'NUMBER OF GRID POINTS IN THE X AND Y DIRECTIONS',//5X,'X
> = ',I5,2X,'Y = ',I5,/,5X,'NUMBER OF POINTS DEFINING SITE BOUNDARY
> - ',I5,/,5X,'NUMBER OF COOLING TOWERS - ',I5,/,5X,'NUMBER OF POIN
> TS AT WHICH NOISE LEVELS ARE TO BE CALCULATED - ',I5,/,5X,'GRID SI
> ZE - ',E10.3,'METERS PER GRID UNIT',//5X,'ACOUSTIC IMPEDANCE OF TH
> E AMBIENT AIR - ',E10.3,2X,' MKS-RAYLS',//)
ISN 0070      WRITE(6,1100)
ISN 0071      1100 FORMAT(5X,'GRID LOCATIONS OF THE COOLING TOWERS',//10X,'X',11X,'Y')
ISN 0072      WRITE(6,1110) (ICK(I),ICV(I),I=1,NOT)
ISN 0073      1110 FORMAT((9X,I4,84,I4))
ISN 0074      WRITE(6,1120)
ISN 0075      1120 FORMAT(5X,'GRID LOCATIONS ON THE BOUNDARY AT WHICH NOISE LEVELS AR
> E TO BE CALCULATED'/10X,'X',11X,'Y')
ISN 0076      WRITE(6,1130) (IBX(I),IBY(I),I=1,NOP)
ISN 0077      1130 FORMAT((9X,I4,84,I4))
ISN 0078      WRITE(6,1140)
ISN 0079      1140 FORMAT(5X,'OCTAVE BAND ATTENUATIONS THAT GIVE SPECTRUM SHAPE RELAT
> IVP TO THE OVERALL A-WEIGHTED LEVEL AT THE COOLING TOWER RIM',//12X

```

```

>,'OCTAVE BAND CENTER FREQUENCY ',/6X,'125',5X,'250',5X,'500',6X,
>1000',4X,'2000',4X,'4000',4X,'800.0')
      WRITE(6,1150) (ARIM(I),I=1,7)
1150 FORMAT(5X,F6.2,6(2X,F6.2))
      WRITE(6,1160) TAMP
1160 FORMAT('0',/5X,'TEMPERATURE = ',F5.1,' DEGREES CELSIUS',///)
      WRITE(6,1162)
1162 FORMAT('0','***** OCTAVE BAND ATMOSPHERIC ABSORPTION ATTENUATION C
>EFFICIENTS *****')
      WRITE(6,1170) (ATMOS(I),I=1,7)
1170 FORMAT(5X,'ATTENUATION COEFFICIENTS - DB PER 100 METERS',/12X,'OC
>TAKE BAND CENTERED FREQUENCIES',/6X,'125',5X,'250',5X,'500',6X,'1000
>',4X,'2000',4X,'4000',4X,'8000',/5X,F6.2,6(2X,F6.2))
      WRITE(6,1191) VANE,BETA,GAMMA
1191 FORMAT(5X,'WIND DIRECTION RELATIVE TO THE X AXIS=',F10.4,'RADIAN'
>,'/5X,'THE WIND SPEED GRADIENT=',F10.4,'METERS PER SECOND PER MET
>ER',/5X,'THE TEMPERATURE GRADIENT=',F10.4,'DEGREES CELSIUS PER MET
>ER')
C ** INITIALIZE ACCUMULATED BAND LEVELS **
      DO 8 I=1,NOP
      DO 8 J=1,7
      BOUNBD(I,J) = 0.
8 BOUNDA(I,J) = 0.
C ***** BOUNDARY POINT CALCULATIONS*****
      DO 35 I=1,NOT
      DO 35 J=1,NOP
35 NPTSCR(I,J)=1
      DO 37 I=1,NOT
      IF(NOSP(I).EQ.0) GO TO 37
      LIM=NOSP(I)
      DO 36 J=1,LIM
      JT=NVECT(I,J)
36 NPTSCR(I,J,T)=0
37 CONTINUE
C
      I=1
      20 WRITE(6,1220) I,IBX(I),IBY(I)
1220 FORMAT('1',10X,'BOUNDARY POINT NUMBER',I4,2X,'LOCATED AT GRID LOCA
>TION X = ',I4,24,'AND Y = ',I4,///)
      30 RLBPX = (IBX(I)-1)*GS
      RLBPY = (IBY(I)-1)*GS
C
      40 IT=1
C ***** EXCESS ATTENUATION FOR SCREENING *****
      41 CONTINUE
      IF(NPTSCR(IT,I).NE.0) GO TO 50
      IT=IT+1
      IF(IT.GT.NOT) GJ TO 140
      GO TO 41
C
      50 PSQR = (W(IT)*AI)/(2.*PI*R(IT)*HP(IT))
      C1=4.3-10
      RIMA = 10.* ALOG10(PSQR/C1)
      RLCTX = (ICX(IT)-1)*GS
      RLCTY = (ICY(IT)-1)*GS
      DELTX = RLBPX - RLCTX
      DELTY = RLBPY - RLCTY
      DELTZ = BDYEL(I) - BEL(IT)

```

```

ISN 0126 DISTH=SQRT(DELTA**2+DELTY**2) - R(IT)
ISN 0127 DIST=SQRT(DISTH**2+DELTZ**2)
ISN 0128 IF(DELTX.EQ.0.) GO TO 52
ISN 0130 ANG = ATAN(DELTA/DELTX)
ISN 0131 GO TO 54
ISN 0132 S2 ANG=PI/2.
ISN 0133 54 CONTINUE
ISN 0134 ACTN = ATAN(SQRT((DIST+2.*R(IT))/DIST))
ISN 0135 PSQB = (W(IT)*AL/((PI**2)*(DIST**2+2.*DIST*R(IT))))*ACTN
ISN 0136 60 BOUNA = 10.*AL0310*PSQB/C1)

C ISN 0137 CALL A0CT(RIMBND,ARIM,RIMA)
C ISN 0138 CALL A0CT(BDYBND,ARIM,BOUNA)
C ISN 0139 DO 70 I1=1,7
ISN 0140 RIMUW(I1)=RIMBND(I1)
ISN 0141 CALL AWEIGHT(RIMUW,1.0)

C ISN 0142 DO 80 I1=1,7
ISN 0143 80 BDYUW(I1)=BDYBNJ(I1)
ISN 0144 CALL AWEIGHT(BDYUW,1.0)

C C ***** WRITE UNATTENUATED LEVELS *****
ISN 0145 WRITE(6,1230) I1,ICK(IT),ICY(IT)
ISN 0146 1230 FORMAT(2X,'>>> COOLING TOWER NO. ',I2,' LOCATED AT GRID LOCATION
> X = ',I4,2X,'Add Y = ',I4,///)
ISN 0147 WRITE(6,1240)
ISN 0148 1240 FORMAT(5X,'OVERALL AND OCTAVE BAND NOISE LEVELS - RE:2.E-05 NEWTON
>S PER METER**2---ATTENUATION DUE ONLY TO WAVE SPREADING')
ISN 0149 WRITE(6,1242)
ISN 0150 1242 FORMAT('0',5X,'***** OCTAVE BAND AND OVERALL SOUND PRESSURE LEVEL
>AT THE COOLING TOWER RIM *****',//)
ISN 0151 WRITE(6,1250) RIMA,(RIMBND(I1),I1=1,7)
ISN 0152 1250 FORMAT(5X,'A-WEIGHTED OVERALL LEVEL =',F6.2,/,5X,'A-WEIGHTED OCTAV
>E BAND LEVELS',/,12X,'OCTAVE BAND CENTER FREQUENCY-HZ',/,6X,'125',5
>X,'250',5X,'500',6X,'1000',4X,'2000',4X,'4000',4X,'8000',/,5X,F6.2
>,6(2X,F6.2))
ISN 0153 WRITE(6,1252)
ISN 0154 1252 FORMAT('0',5X,'***** UNATTENUATED OCTAVE BAND AND OVERALL SOUND PR
>ESSURE LEVEL AT THE BOUNDARY POINT *****',//)
ISN 0155 WRITE(6,1260) BOUNA,(BDYBND(I1),I1=1,7)
ISN 0156 1260 FORMAT(5X,'UNWEIGHTED OVERALL LEVEL =',F6.2,/,5X,'UNWEIGHTED OCTAV
>E BAND LEVELS',/,12X,'OCTAVE BAND CENTER FREQUENCY-HZ',/,6X,'125',5
>X,'250',5X,'500',6X,'1000',4X,'2000',4X,'4000',4X,'8000',/,5X,F6.2
>,6(2X,F6.2))

C ***** EXCESS ATTENUATION FOR ATMOSPHERIC ABSORPTION *****
ISN 0157 DO 90 I1=1,7
ISN 0158 90 SLVL(I1)=BDYUW(I1)
ISN 0159 CALL ASORB(ATMOS,SLVL,DIST)

C ***** EXCESS ATTENUATION DUE TO WIND *****
ISN 0160 IF(IWIND.EQ.0.) GO TO 100
ISN 0161 CALL WIND(DIST,TEMP,ANG,BDYBND,VANE,BETA,GAMMA)
ISN 0162 100 CONTINUE
C ***** EXCESS ATTENUATION FOR GRASS AND SHRUBBERY *****
ISN 0163 IV=IVEG(IT,I)

```

```

ISN 0165      CALL VEG(BDYBND,DIST,IV)
ISN 0166      WRITE(6,1270)
ISN 0167      1270 FORMAT('0',5X,'***** ATTENUATED OCTAVE BAND LEVELS AT THE BOUNDARY
> POINT *****',//)
ISN 0168      WRITE(6,2050) (BDYBND(J),J=1,7)
ISN 0169      2050 FORMAT('5X,'UNWEIGHTED LEVELS WITH EXCESS ATTENUATION',/5X,F6.1,6(2
>X,F6.1))

C
ISN 0170      DO 120 J=1,7
ISN 0171      RK1=(BOUNBD(I,J))/10.
ISN 0172      IF(ABS(RK1).GT.20.) RK1=-20.
ISN 0174      RK2=10.**(RK1)
ISN 0175      RK3=(BDYBND(J))/10.
ISN 0176      IF(ABS(RK3).GT.20.) RK3=-20.
ISN 0178      RK4=10.**(RK3)
ISN 0179      SUM1=RK2+RK4
ISN 0180      120 BOUNBD(I,J)=10.* ALOG10(SUM1)

C
ISN 0181      CALL AWEIGHT(BDYBND,-1.)
C
ISN 0182      DO 130 J=1,7
ISN 0183      RK5=(BOUNDA(I,J))/10.
ISN 0184      IF(ABS(RK5).GT.20.) RK5=-20.
ISN 0186      RK6=10.**(RK5)
ISN 0187      RK7=(BDYBND(J))/10.
ISN 0188      IF(ABS(RK7).GT.20.) RK7=-20.
ISN 0190      RK8=10.**(RK7)
ISN 0191      SUM2=RK6+RK8
ISN 0192      130 BOUNDA(I,J)=10.* ALOG10(SUM2)

C
ISN 0193      WRITE(6,2060) (BDYBND(J),J=1,7)
ISN 0194      2060 FORMAT('5X,'A-WEIGHTED LEVELS WITH EXCESS ATTENUATION',/5X,F6.1,6(2
>X,F6.1),//)
C ** INCREMENT 'IT' FOR NEXT COOLING TOWER **
ISN 0195      IT = IT+1
ISN 0196      IF(IT.GT.NOT) GJ TO 140
ISN 0198      GO TO 41
ISN 0199      140 CONTINUE
C ** WRITE TOTAL ATTENUATED LEVELS FOR BOUNDARY POINT **
ISN 0200      WRITE(6,2070) I
ISN 0201      2070 FORMAT(23X,'TOTAL OCTAVE BAND LEVELS WITH EXCESS ATTENUATION FOR B
>OUNDARY POINT-',I4,//45X,'OCTAVE BAND CENTER FREQUENCY-HZ',//45X,'1
>25',5X,'250',5X,'500',6X,'1000',4X,'2000',4X,'4000',4X,'8000')
ISN 0202      WRITE(6,2080) (BOUNBD(I,J),J=1,7)
ISN 0203      2080 FORMAT(25X,'UNWEIGHTED',9X,F6.2,6(2X,F6.2))
ISN 0204      WRITE(6,2090) (BOUNDA(I,J),J=1,7)
ISN 0205      2090 FORMAT(25X,'A-WEIGHTED',9X,F6.2,6(2X,F6.2))

C
ISN 0206      DO 145 J=1,7
ISN 0207      ARAY1(J)=BOUNBD(I,J)
ISN 0208      145 ARAY2(J)=BCUNDA(I,J)
ISN 0209      CALL OVER(ARAY1,AWOA)
ISN 0210      WRITE(6,2100) AWOA
ISN 0211      2100 FORMAT('0',45X,'UNWEIGHTED OVERALL LEVEL = ',F10.2,' DB - RE 2*10*
>*(-5) NEWTONS PER SQUARE METER',//)
ISN 0212      CALL OVER(ARAY2,AWOA)
ISN 0213      WRITE(6,2110) AWOA
ISN 0214      2110 FORMAT(46X,'A-WEIGHTED OVERALL LEVEL = ',F10.2,' DB - RE 2*10**(-5)

```

```

      >) NEWTONS PER SQUARE METER')
C
C ** INCREMENT 'I' FOR NEXT BOUNDARY POINT **
ISN 0215      I=I+1
ISN 0216      IF(I.GT.NOP) GO TO 150
ISN 0218      GO TO 20
ISN 0219      150 CONTINUE
ISN 0220      WRITE (6,2120)
ISN 0221      2120 FORMAT (5X,'***** LE BRUIT EST FINIS *****')
C
ISN 0222      STOP
ISN 0223      END

```

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

```

COMPILER OPTIONS - NAME= 4AIN,OPT=02,LINECNT=60,SIZE=0000K,
                   SOURCE,4BCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREP
C
C
ISN 0002      SUBROUTINE AOCT(BAND,ARIM,ALEVEL)
ISN 0003      DIMENSION BAND(7),ARIM(7)
ISN 0004      DO 10 I=1,7
ISN 0005      10 BAND(I)=ALEVEL-ARIM(I)
ISN 0006      RETURN
ISN 0007      END

```

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

```

COMPILER OPTIONS - NAME= 4AIN,OPT=02,LINECNT=60,SIZE=0000K,
                   SOURCE,4BCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREP
C
C
ISN 0002      SUBROUTINE ASORD(ATMOS,SLVL,DIST)
C ***** SUBROUTINE TO ATTENUATE OCTAVE
C      BAND LEVELS FOR ATMOSPHERIC ABSORPTION *****
ISN 0003      DIMENSION ATMOS(7),SLVL(7)
ISN 0004      DO 10 I1=1,7
ISN 0005      10 SLVL(I1) = SLVL(I1) - (ATMOS(I1))*(DIST/100.)
ISN 0006      RETURN
ISN 0007      END

```

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

COMPILER OPTIONS - NAME= MAIN,OPT=02,LINECNT=60,SIZE=0000K,
 SOURCE,BCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREF

```

C
C
ISN 0002      SUBROUTINE AWEIGHT(BNDWGT,A)
ISN 0003      C ***** TO A-WEIGHT A=-1 *** TO UNWEIGHT A=+1 ****
ISN 0004      DIMENSION BNDWGT(7)
ISN 0005      BNDWGT(1)=BNDWGT(1) + (16.1*A)
ISN 0006      BNDWGT(2)=BNDWGT(2) + (8.6*A)
ISN 0007      BNDWGT(3)=BNDWGT(3) + (3.2*A)
ISN 0008      BNDWGT(5)=BNDWGT(5) - (1.2*A)
ISN 0009      BNDWGT(6)=BNDWGT(6) - (1.0*A)
ISN 0010      BNDWGT(7)=BNDWGT(7) + (1.1*A)
ISN 0011      RETURN
ISN 0012      END

```

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

COMPILER OPTIONS - NAME= MAIN,OPT=02,LINECNT=60,SIZE=0000K,
 SOURCE,BCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREF

```

C
C
ISN 0002      SUBROUTINE OVER(BNDL,OVRAL)
ISN 0003      DIMENSION BNDL(7)
ISN 0004      SUM=0.
ISN 0005      DO 10 J=1,7
ISN 0006      IF(BNDL(J).LE.0.) GO TO 5
ISN 0008      8 PSQ=10.**((BNDL(J))/10.)
ISN 0009      GO TO 10
ISN 0010      5 PSQ=4.2-10
ISN 0011      10 SUM=SUM+PSQ
ISN 0012      IF(SUM.GT.1.1) GO TO 15
ISN 0014      OVRAL=0.
ISN 0015      GO TO 20
ISN 0016      15 OVRAL=10.* ALOG10(SUM)
ISN 0017      20 RETURN
ISN 0018      END

```

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

COMPILER OPTIONS - NAME= MAIN,OPT=02,LINECNT=60,SIZE=0000K,
 SOURCE,BCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREF

```

C
C
ISN 0002      SUBROUTINE POWER(R,H,T,D,RM,POW,NOT)
ISN 0003      DIMENSION R(40),H(40),T(40),D(40),RM(40),POW(40)
ISN 0004      A=0.95E-5
ISN 0005      B=1.8E-5
ISN 0006      DO 10 IT=1,NOT
ISN 0007      10 POW(IT)=RM(IT)*D(IT)*(A*((T(IT)/H(IT))**2.)*B*((D(IT)/H(IT))**2.))
ISN 0008      RETURN
ISN 0009      END

```

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

COMPILER OPTIONS - NAME= SAIN,OPT=02,LINECNT=60,SIZE=0000K,
 SOURCE,BCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREF

```

C
C
  ISN 0002      SUBROUTINE VEG(BDYBND,DIST,IV)
  ISN 0003      DIMENSION BDYBND(7),PR(7)
  ISN 0004      IF(IV.EQ.0) GO TO 50
  ISN 0006      IF(IV.EQ.2) GO TO 20
  ISN 0008      DO 10 I=1,7
  ISN 0009      PR(I)=125.
  ISN 0010      IF(I.EQ.1) GO TO 10
  ISN 0012      PR(I)=125.*{2.***{I-1}}
  ISN 0013      10 BDYBND(I)=BDYBND(I)-{.18*ALOG10(PR(I))-.31}*DIST
  ISN 0014      GO TO 50
  ISN 0015      20 DO 30 I=1,7
  ISN 0016      PR(I)=125.
  ISN 0017      IF(I.EQ.1) GO TO 30
  ISN 0019      PR(I)=125.*{2.***{I-1}}
  ISN 0020      30 BDYBND(I)=BDYBND(I)-0.01*{(PR(I))**0.3333}*DIST
  ISN 0021      50 RETURN
  ISN 0022      END

```

LEVEL 21.6 (DEC 72)

OS/360 FORTRAN H

COMPILER OPTIONS - NAME= SAIN,OPT=02,LINECNT=60,SIZE=0000K,
 SOURCE,BCDIC,NOLIST,NOECK,LOAD,MAP,NOEDIT,NOID,NOXREF

```

C
C
  ISN 0002      SUBROUTINE WIND(DIST,TEMP,ANG,BDYBND,VANE,BETA,GAMMA)
  ISN 0003      DIMENSION PR(7),BDYBND(7)
  ISN 0004      IF(GAMMA.EQ.0..AND.BETA.EQ.0.) GO TO 50
  ISN 0006      ATEM = TEMP + 273.2
  ISN 0007      SPEED = 20.05*SQR(ATEM)
  ISN 0008      PHICR=ARCCOS((SPEED/(2.*ATEM))*(GAMMA/BETA))
  ISN 0009      COP1 = 3.22
  ISN 0010      PHI = ANG-VANE
  ISN 0011      IF(ABS(PHI)-PHI>B) 25,30,30
  ISN 0012      25 ALPHA=(SPEED*GAMMA)/{2.*ATEM}
  ISN 0013      DENOM=(BETA*COS(PHI))-ALPHA
  ISN 0014      IF(ABS(ALPHA)-B>TA) 10,5,5
  ISN 0015      5 IF(ALPHA.GT.0.) GO TO 30
  ISN 0017      10 XSHDW = {SQR(2.*SPEED)/(DENOM)}*COP1
  ISN 0018      RAT = DIST/XSHDW
  ISN 0019      ATT=27.
  ISN 0020      IF(RAT.GE.3) GO TO 28
  ISN 0022      ATT=9.*{RAT-1.}
  ISN 0023      28 DO 29 I=1,7
  ISN 0024      29 BDYBND(I)=BDYBND(I)-ATT
  ISN 0025      GO TO 50
  ISN 0026      30 DO 46 I=1,7
  ISN 0027      PR(I)=125.
  ISN 0028      IF(I.EQ.1) GO TO 40
  ISN 0030      PR(I)=125.*{2.***{I-1}}
  ISN 0031      40 PTR=PR(I)*DIST
  ISN 0032      IF(PTR.LT.1.21985) GO TO 46
  ISN 0034      45 BDYBND(I)=BDYBND(I)-10.*{ALOG(PTR)-5.086}
  ISN 0035      46 CONTINUE
  ISN 0036      50 RETURN
  ISN 0037      END

```

ORNL-5070
UC-80 — General Reactor
Technology

INTERNAL DISTRIBUTION

- | | |
|---------------------|-----------------------------------|
| 1. S. I. Auerbach | 32. R. L. Lyons |
| 2. J. A. Auxier | 33. R. J. Olsen |
| 3-12. C. C. Burwell | 34. H. Postma |
| 13-22. T. G. Carley | 35. H. P. Raaen |
| 23. R. S. Carlsmith | 36. M. W. Rosenthal |
| 24. F. L. Culler | 37-42. T. H. Row |
| 25. G. G. Fee | 43-45. O. Sisman |
| 26. A. P. Fraas | 46. I. Spiewak |
| 27. W. Fulkerson | 47-50. Central Research Library |
| 28. D. D. Gray | 51. Document Reference Section |
| 29. R. F. Hibbs | 52-54. Laboratory Records |
| 30. H. W. Hoffman | 55. Laboratory Records, ORNL R.C. |
| 31. S. I. Kaplan | 56. ORNL Patent Office |

EXTERNAL DISTRIBUTION

- | |
|--|
| 57. R. E. Balzhiser, Director, Fossil Fuel and Advanced Systems Division, Electric Power Research Institute, P.O. Box 10412, Palo Alto, CA 94304 |
| 58. J. D. Buffington, Argonne National Laboratory, 9700 South Cass Avenue, Bldg. 11-A, Argonne, IL 60439 |
| 59. S. D. Freeman, 7211 Pyle Road, Bethesda, MD 20034 |
| 60. H. Landsberg, Director, Division of Energy and Resource Commodities, Resources for the Future, 1755 Massachusetts Avenue, N.W., Washington, D.C. 20036 |
| 61. Louise Markel, Information Officer, Oak Ridge Associated Universities, Institute for Energy Analysis, Oak Ridge, TN 37830 |
| 62. P. M. Meier, Brookhaven National Laboratory, Bldg. 475, Upton, NY 11973 |
| 63. L. D. Taylor, Professor of Economics, University of Arizona, Tucson, AZ 85721 |
| 64. J. B. Vetrano, Battelle Northwest, Richland, WA 99352 |
| 65-84. Office of Special Studies Branch, Nuclear Regulatory Commission, Washington, D.C. 20555 |
| 85. Research and Technical Support Division, ORO, Oak Ridge, TN 37830 |
| 86-207. Given distribution as shown in TID-4500 under General Reactor Technology category (25 copies — NTIS) |