

**Grand Junction Projects Office
Remedial Action Project**

Building 2 Public Dose Evaluation

May 1996

MASTER



**U.S. Department of Energy
Grand Junction Projects Office**

Approved for public release; distribution is unlimited.

Work Performed Under DOE Contract No. DE-AC04-86ID12584 for the U.S. Department of Energy

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CM

Grand Junction Projects Office Remedial Action Project

Building 2 Public Dose Evaluation

Final Report

Robert Morris, CHP

May 1996

Prepared for
U.S. Department of Energy
Albuquerque Operations Office
Grand Junction Projects Office

Prepared by
Rust Geotech
Grand Junction, Colorado

Work Performed Under DOE Contract No. DE-AC04-86ID12584

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

**Portions of this document may be illegible
in electronic image products. Images are
produced from the best available original
document.**

Table of Contents

	Page
Executive Summary	1
1.0 Introduction	3
2.0 Characterization Data	4
2.1 External Gamma Exposure Rate Measurements	4
2.2 Radon Measurements	5
2.3 Contamination Measurements	6
2.3.1 Scanning Measurements	6
2.3.2 Direct Contamination Measurements of Accessible Areas	7
2.3.3 Smear Contamination Measurements of Accessible Areas	9
2.3.4 Direct Contamination Measurements of Inaccessible Areas Using Core Samples	9
2.3.5 Smear Contamination Measurements of Inaccessible Areas Using Core Samples	11
2.4 Pipe Explorer™ Measurements	11
3.0 Dose Assessment	15
3.1 Dose During Normal Occupancy	15
3.2 Dose During Demolition	16
3.3 Disposal of Demolition Debris	16
4.0 Conclusions	17
5.0 References	18
6.0 Appendices	19

Tables and Figures within Text

Table 1.	Summary of Pressurized Ion Chamber Data	5
Table 2.	Summary of Average Contamination Levels for Each Survey Unit	8
Table 3.	Average Total Contamination for each Survey Unit and Material Type Having Elevated Contamination Levels	10
Figure 1.	Pipe Explorer Data Summary Graph	13

Contents (continued)

Appendix 1- Data Tables and Figures

Table A1-1. Exposure Rate Measurements Using Pressurized Ion Chamber

Table A1-2. Scan Measurements of Building 2

Table A1-3. Direct Measurements and Smears of Building 2

Table A1-4. Potentially Elevated Building 2 Smears

Table A1-5. Wall and Floor Core Measurements of Building 2

Table A1-6. Wall Core Measurements Sorted by Material Type

Figure A1-1. PIC and RDC Measurement Locations in Building 12

Figure A1-2. PIC and RDC Measurement Locations in Building 2

Figure A1-3. Scan Measurement Locations in Building 2

Figure A1-4. Direct Measurements/Smears Locations in Building 2

Figure A1-5. Core Locations Floors and Walls in Building 2

Appendix 2 - Results of the Landauer Radon Track Etch Measurements

**Appendix 3 - DQOs, Use Scenarios, and Affected Area Designation
of GJPORAP Building 2 Characterization**

Appendix 4 - Radiological Survey and Sampling Plan for Building 2

Appendix 5 - Input parameters for RESRAD-BUILD

Appendix 6 - RESRAD-BUILD Output

Executive Summary

Building 2 on the U.S. Department of Energy (DOE) Grand Junction Projects Office (GJPO) site, is part of the GJPO Remedial Action Program (GJPORAP). This report describes measurements and modeling efforts to evaluate the radiation dose to members of the public who might someday occupy or tear down Building 2. Releasing the building for unrestricted use instead of demolishing it now could save a large amount of money because the site telecommunications system would not be disabled and replaced.


Building 2 was built in 1944 as a Manhattan Project building. The north portion was used as a shower and change facility for uranium workers, the south portion was a warehouse. Many originally exposed surfaces are no longer accessible for contamination surveys because expensive telecommunications equipment has been mounted on panels covering the walls and floors.

Release criteria were proposed in a data quality objectives (DQO) process conducted in cooperation with the Independent Verification Contractor (Oak Ridge National Laboratory). The building may be released for unrestricted use if the predicted dose (excluding radon) to a member of the public occupying the building is less than 15 mrem in a typical year, and less than 30 mrem in the year when demolition occurs. The radon exclusion is consistent with proposed EPA guidance. However, the radon concentration in Building 2 must not exceed 4 pCi/L, which is the action level recommended to the public by the EPA.

In an extensive effort, data were collected to characterize exposure rate, contamination levels, radon concentration, and contaminants in subsurface drain lines. When direct measurements of the dose component were not possible, RESRAD-BUILD, a predictive model sponsored by DOE, was used to assess the dose potential.

Summing all sources, the predicted Total Effective Dose Equivalent (TEDE) from normal occupancy of Building 2 is 2 mrem/year, and radon is insignificant. For demolition the predicted dose is 0.1 mrem and radon is insignificant.

Building 2 is suitable for unrestricted use by the public. Measurement and model predictions show the dose to the public from future use of Building 2 is much less than the legal limit of 100 mrem/year and well below the release criteria proposed in the DQO process. An ALARA analysis should be performed using the predicted dose and potential cost savings. A decision of disposition of the building would follow.



1.0 Introduction

Building 2 on the U.S. Department of Energy (DOE) Grand Junction Projects Office (GJPO) site, which is operated by Rust Geotech, is part of the GJPO Remedial Action Program. This report describes measurements and modeling efforts to evaluate the radiation dose to members of the public who might someday occupy or tear down Building 2. The assessment of future doses to those occupying or demolishing Building 2 is based on assumptions about future uses of the building, measured data when available, and predictive modeling when necessary. Future use of the building is likely to be as an office facility. The DOE sponsored program, RESRAD-BUILD, Version 1.5 (Reference 1) was chosen for the modeling tool.

Releasing the building for unrestricted use instead of demolishing it now could save a substantial amount of money compared with the baseline cost estimate because the site telecommunications system, housed in Building 2, would not be disabled and replaced. The information developed in this analysis may be used as part of an as low as reasonably achievable (ALARA) cost/benefit determination regarding disposition of Building 2.

Building 2 was built in 1944 as a Manhattan Project building. The north portion was used as a shower and change facility for workers involved in uranium milling operations, the south portion was a warehouse. Many originally exposed surfaces, which may be contaminated with uranium and its byproducts, are no longer accessible for contamination surveys because expensive telecommunications equipment has been mounted on panels covering the walls and floors of the north end of the building.

This dose evaluation includes measurements of gamma exposure rate, radon concentration, radioactive contamination in subsurface drain lines, contamination on accessible surfaces, and an evaluation of contamination on originally exposed but now inaccessible surfaces using statistically selected core samples. Data were evaluated using the dose prediction model RESRAD-BUILD (Reference 1). The results are compared with values proposed in a data quality objectives (DQO) process in cooperation with the Independent Verification Contractor (Oak Ridge National Laboratory). The Independent Verification Contractor has responsibility for assuring that the cleanup criteria established for the GJPO Remedial Action Program have been met. The DQO is included as Appendix 3; the executive summary of the DQO follows:

This document defines the Data Quality Objectives (DQO) and future use assumptions necessary for predicting the public dose associated with future use of Building 2 as part of the DOE Grand Junction Projects Office Remedial Action Program (GJPORAP). A formal definition of the "affected areas," which is needed for design of the sampling plan, is also included.

The DQO states that the building may be released for unrestricted use if the predicted dose (excluding radon) to a member of the public occupying the building is less than 15 mrem in a typical year, and less than 30 mrem in the year when demolition occurs. The required confidence level for sampling is set at 95%. In keeping with proposed EPA guidance (FR Vol. 59, No. 246, p. 66415) the dose criteria do not include the

contribution from indoor radon, either from naturally occurring radium-bearing soils or fill material situated beneath or near the building. However the radon concentration in Building 2 must not exceed 4 pCi/L, which is the level recommended to the public by the EPA and Centers for Disease Control in "A Citizen's Guide to Radon" (EPA 402-K92-001).

Future use of Building 2 is expected to be the same as its current use: an office facility occupied for eight hours per day, five days per week. Some day the building will be demolished. Exposure to potentially radioactive dust on surfaces that are currently inaccessible may occur, creating larger doses compared with normal occupancy. Demolition is assumed to take 80 hours to complete. No beneficial use of the building debris is expected; all will go to a sanitary landfill.

The "affected area" of Building 2 is the exposed surfaces (including drain lines) that existed during the era of its use as a locker and shower facility for uranium workers. Subsequent construction on the building, which includes interior walls, wood paneling, and floor coverings installed over a leveling slab are designated "unaffected."

2.0 Characterization Data

A sampling plan, included as Appendix 4, was prepared to provide instructions to the personnel collecting characterization information. The sampling plan was derived from the DQO report. Samples and measurements were made following approved procedures from the Rust Geotech Environmental Procedures Catalog (Reference 2) and the Rust Geotech Field Assessments Procedures Manual. (Reference 3). Personnel assigned to do the measurements and collect samples were qualified according to Environmental Procedures Catalog procedure GN-4P, "Standard Procedure for Personnel Qualifications."

2.1 External Gamma Exposure Rate Measurements

A Reuter-Stokes Pressurized Ion Chamber with a NIST-traceable calibration was used to measure the gamma exposure rate. Building 2 was divided into two survey units: North and South. Data were also collected in the log cabin portion of Building 12 as a reference survey unit. Measurement locations are shown in Appendix 1 as Figures A1-1 and A1-2.

Significant comments were considered during the DQO process regarding the selection of Building 12 as a reference area. It is true that materials and construction of Building 12 are different from Building 2, and that Building 12 has a basement. These differences could result in lower or higher radon concentration or exposure rates, and could bias the outcome of the dose assessment. The log cabin portion of Building 12 was chosen as the reference unit because it predates radioactive material use on the site and is likely to conservatively represent the background exposure rate and radon concentration in Building 2. Lacking a clearly unaffected reference structure of similar design and age, Building 12 was chosen because there was little doubt it was unaffected.

Table A1-1 in Appendix 1 shows the exposure rate data measured one meter above the floor for each survey unit. The mean and standard deviation of these data are summarized below in Table 1.

Table 1. Summary of Pressurized Ion Chamber Data

Survey Unit	Mean, $\mu\text{R/hr}$	Standard Deviation
Building 12 Log Cabin	10.94	0.618
Building 2 North	11.99	0.189
Building 2 South	11.77	0.368
Building 2 North/South Pooled	11.87	0.314

These data were tested for statistical differences using the nonparametric Wilcoxon Rank Sum (WRS) and Quantile tests. The null hypothesis, that there is no difference in the exposure rates between the pooled Building 2 survey units and the reference unit, was rejected in WRS test and accepted in the Quantile test. A parametric 't' test found significant difference between the two means. (See Reference 4 for documentation.)

By considering the exposure rate data for the Building 2 north and south survey units as one (called pooling) and subtracting the background from Building 12, the estimate of the increase in exposure rate above background is $0.926 \pm 1.39 \mu\text{R/hour}$. The uncertainty term represents the 95% confidence interval around the difference. Pooling the data from the north and south survey units is reasonable since it is likely that future building occupants will have access to both areas.

The data obtained with the pressurized ion chamber is consistent with historical data collected by the Rust Geotech occupational dosimetry area TLD program (Reference 4).

After these measurements were made, evidence of soil contamination below the west foundation of Building 2 was discovered during the excavation of an adjacent structure. Though readily detectable the material does not appear to extend more than $\frac{1}{2}$ meter past the edge of the foundation and is lower in concentration than the site cleanup standard. The material discovered was consistent with uranium contamination from prior site activities. This material did not noticeably affect exposure rate in the structure. However, the present plan is to remove the material during other remedial actions near Building 2.

2.2 Radon Measurements

Landaaur Track Etch radon detectors, type DRN, were used to measure radon-222 concentration. Building 2 was divided into two survey units: North and South. One sample was also collected in the log cabin portion of Building 12. Sampling locations are shown in Figures A1-1 and A1-2

in Appendix 1. The samples were collected from January 3 through February 2, 1996. It is generally accepted that in the middle latitudes, where buildings are heated in winter, radon sampling during January will conservatively estimate the annualized average concentration.

Data presented in Appendix 2 show the radon concentration was less than the detection limit, which was 1 pCi/L, for all measurements. This concentration is much less than the 4 pCi/L EPA guideline value.

Data from a 1989-1990 nationwide study of radon in DOE buildings (Reference 5) confirms these measurements. In an exposure from 11/13/89 to 2/13/89 the concentration in Building 2 was 1.4 pCi/L and in Building 12 was 3.0 pCi/L. Since then significant remedial actions have occurred on the GJPO site that have removed nearby radon sources.

2.3 Contamination Measurements

Measurements of total and removable contamination were made in both accessible and inaccessible areas. Although uranium and its byproducts also emit alpha radiation, the proportions of alpha to beta radiation are roughly one to one. Only beta measurements were collected for this characterization because, under field conditions, beta radiation is much more detectable and the contamination guidelines for alpha and beta contamination apply separately. The data are useful to show compliance with traditional contamination guidelines (Reference 6) and to model the dose that would result from future use of the building.

Scanning measurements are made to estimate contamination levels and find elevated areas of contamination called "hot spots." Direct measurements were made to quantitate the contamination levels at hot spots and other randomly selected areas. This should result in a conservatively biased estimate of the average activity per unit area. When scanning was not feasible due to surface coverings on originally exposed surfaces, core samples were taken at random locations selected according to the method in the sampling plan. Core sampling should produce an unbiased estimate of the contamination levels on inaccessible surfaces.

2.3.1 Scanning Measurements

A summary of the scanning measurements made with hand-held contamination survey meters is included in Appendix 1 as Table A1-2. Figure A1-3, also in Appendix 1, shows the locations graphically. NE Electra survey meters with DP6a scintillation probes were operated in the rate meter mode to obtain the data. NIST-traceable chlorine-36 sources were used to calibrate the survey meters. The scanning data were used to identify areas for more detailed evaluation and to decide if small accessible areas exceeded the "hot spot" criteria of three times average guideline value. Locations where elevated count rates were found or suspected were evaluated with direct measurements as discussed below.

Scanning measurements revealed only three areas where contamination greater than the average limit was found. No hot spot greater than three times the average guideline value in any 100-cm² area was found.

2.3.2 Direct Contamination Measurements of Accessible Areas

Locations identified in the scanning survey as contaminated or potentially contaminated were quantitatively evaluated for total beta contamination with the same model survey meters used for scanning, operated instead in the scaler mode. Other locations, which were randomly selected according to the sampling plan were also measured. Measurement locations are shown in Figure A1-4 in Appendix 1. To make these measurements, the meter was held at a fixed height ($\frac{1}{2}$ inch) over the same location for a fixed time (one minute). At each of these locations a smear test, discussed below, was also taken.

The results of these measurements are shown in Table A1-3 which is in Appendix 1. Only three locations were contaminated more than the average guideline value. None were more than the hot spot criteria. These three areas correlate exactly with the elevated areas identified in the scanning surveys. One location, D90, an old room radiator that is not in service, is contaminated to the level of 10,330 dpm/100 cm². Current plans call for this item to be removed during maintenance. Future building occupants are unlikely to encounter this source.

Table 2 on the next page summarizes the average contamination levels found in each sampling unit.

Table 2. Summary of Average Contamination Levels for Each Survey Unit ①

Survey Unit	Accessible or Inaccessible	Total Contamination, dpm/100 cm ²	Standard Deviation, dpm/100 cm ²
New Walls	accessible	-110	167
North - Old Walls ②	accessible	1484	2313
Floor	accessible	413	946
North Floor (cores)③	inaccessible	1023	1129
South Floor (cores) ④	inaccessible	679	743
North - East Wall (cores)	inaccessible	1659	6706
North - North Wall (cores)	inaccessible	4000	8609
North - West Wall (cores)	inaccessible	1897	5254
South - East Wall (cores)	inaccessible	786	5526
South - West Wall (cores)	inaccessible	2499	5962

① No removable contamination greater than guideline values was found in any sampling unit. Using field screening techniques the highest 34 smears were reevaluated with a desktop scaler counter. The mean of these measurements was 4.7 dpm/100 cm² with a standard deviation of 43. For dose modeling purposes the one sigma upper limit, 39 dpm/100 cm², from this conservatively biased sample of smears will be used as the removable contamination level for each sampling unit when such a value is required.

② When location D90 is removed from consideration (plans call for removal of the contaminated radiator) the mean is 1150 dpm/100 cm² and the standard deviation is 1643.

③ Data in the table represent the average over all concrete surfaces, including the new slab. When only the surface of the original slab (side "C" in the location code) is considered, the mean is 2352 dpm/100 cm² and the standard deviation is 1198.

④ Data in the table represent the average over all concrete surfaces, including the new slab. When only the surface of the original slab (side "C" in the location code) is considered, the mean is 1460 dpm/100 cm² and the standard deviation is 681.

2.3.3 Smear Contamination Measurements of Accessible Areas

At the same location where direct contamination measurements were made, removable contamination smears were taken. The smears were semi-quantitatively evaluated in the field using the hand probe in the scaler mode to decide if a better, more quantitative measurement was required. The results of these field measurements are in Table A1-3 in Appendix 1. The maximum value estimated in this semi-quantitative analysis was 912 dpm/100 cm².

No field measurements of smears showed removable contamination greater than the guideline value of 1000 dpm/100 cm². Thirty-four smears were identified as potentially elevated above background. These smears were quantitatively evaluated using the Ludlum Model 2929 desktop scaler/counter. Table A1-4 in Appendix 1 shows these data. The highest value found in quantitative analysis was 75 dpm/100 cm².

To avoid introducing more error than necessary, the field estimates of removable contamination were discarded and replaced with the one sigma upper confidence interval from the quantitative measurements of the thirty-four highest smears. This provides a conservative estimate of the removable contamination. The mean and standard deviation of the potentially elevated smears was -4.7 ± 43 dpm/100 cm². The value of the one sigma upper confidence interval was 39 dpm/100 cm².

2.3.4 Direct Contamination Measurements of Inaccessible Areas Using Core Samples

Core samples were taken to discover the average contamination level on originally exposed surfaces that are now covered. Core sample locations are shown in Figure A1-5 in Appendix 1. Table A1-5 in Appendix 1 shows the data from direct contamination measurements made in these cores. Figure A1-5 in Appendix 1 shows the locations of core samples.

The following information is useful for decoding the location codes in the table. At each location the top or facing surface of the material was measured after removal and identified as surface "A." The back of the material -- which typically was paneling, sheetrock, plywood, or a concrete slab -- was identified as surface "B." Often multiple layers of material were encountered and then the front of the second material was labeled surface "C." A typical example is Location C21 where sheetrock covered Celotex. The team leader's notes (Reference 4) indicates that facing side of both surfaces were painted.

Table A1-5 includes data taken from both floors (locations C1 through C13) and walls (C14 through C58). Inspection of the wall sample data reveals that the contamination levels do not vary as much with spacial location on the sampling grid as they do by Material Type. Therefore, analysis was done to discover the average contaminant level associated with each material. Table A1-6 in Appendix 1 shows the wall core data sorted by Material Type. Table 3, below, summarizes the mean and standard deviation of the activity per 100 cm² for each Material Type.

Table 3. Average Total Contamination for each Survey Unit and Material Type Having Elevated Contamination Levels

Material Type ①	Survey Unit	Mean, dpm/100 cm²	Standard Deviation
Concrete	North-N	26,676	5,036
" "	North-E	13,114	14,828
Insulation	South-W	19,643	2,825
" "	South-E	9,586	9,618
Wood	North-N	12,146	5,828
" "	North-E	4,050	12,951
" "	North-W	9,075	9,309
" "	South-W	10,641	4,005
" "	South-E	1,735	3,172

① For Material Types with elevated contamination levels only those survey units having data are shown. For Material Types not shown, the average total contamination level in each survey unit was less than 500 dpm/100 cm².

The concrete Material Type forms the lower half of the north and east walls of the telecommunications room. The interior face of this concrete appears to be contaminated. Although it is possible that the concrete aggregate is naturally radioactive and is the cause of the elevated readings, it is more likely that this is residual activity from the facility's original use as a shower and change room for uranium workers.

The wood Material Type was found to have elevated contamination in five different survey units. This was often associated with structural wood and was almost uniformly distributed throughout the exterior walls. The contaminant level for wood averaged over all affected survey units is approximately 8000 dpm/100 cm² with standard deviation of about 8500.

The insulation Material Type was significantly elevated inside external walls on the south end of the building.

The core samples from the concrete floor slabs revealed relatively uniform contamination levels over the two survey units. The mean value of the pooled data was 1906 dpm/100 cm² with a standard deviation of 1039.

2.3.5 Smear Contamination Measurements of Inaccessible Areas Using Core Samples


No removable contamination greater than the guideline value was found in any core sample. The smears exhibiting the largest values were reevaluated using a tabletop smear counter. These reevaluated results are discussed in Section 2.3.3 above. For dose modeling purposes the value of 39 dpm/100 cm² will be used.

2.4 Pipe Explorer™ Measurements

Science and Engineering Associates, Inc. (SEA) was contracted to do radiological and video characterization survey of the two identified drain pipes running below Building 2. A report of the SEA operations at the Grand Junction Projects Office (Reference 7) provides information on this and other work performed. SEA used its Pipe Explorer™ system to tow a small video camera and a beta detector through the pipes to collect information. The Pipe Explorer™ process involves inverting (turning inside out) a tubular impermeable membrane under air pressure. The membrane can tow a sensor through pipe constrictions, around 90 degree bends, and vertically up and down. Because the sensor is transported inside the disposable membrane, it is protected from contamination.

Calibration of the beta detector was established using a NIST-traceable strontium-90 source in a geometry matched to the 4-inch iron drain pipe.

Two abandoned drain pipes were to be imaged and measured for beta contamination. Line number 1 drained the bathrooms on the northwest side of Building 2. Line number 2 drained the water from the sinks and showers used by uranium workers in the northeast side of Building 2. The video image and operators log for line number 1 indicates the layout of the pipe and features such as connecting lines. Figure 1, below, is a graph of the data collected in line number 1 and shows that the contamination level in the pipe is significantly below release limits and below the minimum detectable activity for this system of 2,700 dpm/100 cm². The Pipe Explorer™ could not be used and was unable to obtain data in line number 2 because it was blocked by sediments. The most important effect of the contamination that may be in line number 2 is probably external exposure. This effect was measured as part of the overall exposure rate in the North Survey Unit.



Pipe Explorer Data Summary Graph
 Grand Junction Projects Office
 Building No. 2, Pipe Run ID, No. 1
 4-Inch Iron Pipe
 Data taken 2/20/96





Figure 1



3.0 Dose Assessment

The assessment of future doses to people occupying or demolishing Building 2 is based on measured data, and assumptions about future uses of the building. The assumptions about future use of the building were documented in the DQOs and summarized in Section 1. The process of modeling future dose involves converting assumptions into equations and including the measured data as parameters in those equations. Usually the equations have been published as computer codes and reference documents. The approach taken in this dose assessment is to use the equations and some default parameters used in RESRAD-BUILD, Version 1.5 (Reference 1). For external exposure and radon concentration, measured data makes those calculations done by RESRAD-BUILD irrelevant.

RESRAD-BUILD is a new member of a family of programs issued by DOE. These programs have been peer reviewed and gained wide acceptance. Before doing this work the capability of RESRAD-BUILD to assess future doses from Building 2 was evaluated and found adequate (Reference 8).

3.1 Dose During Normal Occupancy

The attributable dose during normal occupancy of the building will be the result of:

- external gamma exposure greater than background,
- radon concentrations greater than 4 pCi/L,
- inhalation of residual airborne contaminants, and
- ingestion of residual contaminants.

Measured external exposure rate data were used instead of the modeled exposure rate. Assumptions used in the calculation were that a member of the public occupies the building eight hours each day, five days a week, fifty weeks a year for a total of 2,000 hours each year. In Section 2.1 it was established that the best estimate of exposure rate above background is 0.926 μ R per hour. The convention that 1 R equals 1 rem was used. Multiplying the exposure rate, conversion convention, and exposed hour per year results in a dose of 1.85 mrem/year above background. The 95% confidence interval around this estimate is -0.928 to +4.63 mrem/year.

The contribution of radon to the risk of residual radioactivity is best represented by comparison to the national guidelines established by the U. S. EPA for radon in homes. The EPA has set a guideline for action at 4 pCi/L without regard for the source. This was established in the DQO as the decision criteria. The data presented in Section 2.2 show that the concentration of radon is approximately 1 pCi/L or less and therefore radon is not a concern in Building 2.

Contamination in buried pipes is not a concern because the pipe that was measured had contamination levels lower than the release limits. The other pipe is not accessible and any contribution to dose is accounted for in the external exposure measurements.

The input parameters used to run RESRAD-BUILD are detailed in Appendix 5. Data in Section 2.3 of this report was the basis for the input parameters. The report of results is in Appendix 6. The maximum annual inhalation dose predicted by RESRAD-BUILD over the next 30 years is 0.1 mrem. The maximum annual ingestion dose predicted by RESRAD-BUILD over the next 30 years is 0.0005 mrem.

Summing all sources, the predicted Total Effective Dose Equivalent (TEDE) from normal occupancy of Building 2 is 1.95 mrem/year, and the radon concentration is insignificant.

Considering the uncertainty in measurements and assumptions, it is appropriate to state that the dose from normal occupancy is approximately 2 mrem/year TEDE.

3.2 Dose During Demolition

Dose during demolition will be the sum of the same components considered during normal occupancy, but the accessibility of the residual radioactivity and work patterns will be significantly different. The assumptions and input parameters used as input are detailed in Appendix 3. Important differences are in the fraction of the radioactivity that is removable, the dust resuspension rate, the breathing rate and dust ingestion rate of workers, the duration of exposure and outdoor ventilation conditions. The report of the calculated results is in Appendix 4.

Assumptions used in the calculation were that demolition occurs during 10 eight-hour days, for a total of 80 hours. The net effect of shielding configuration changes on the external exposure dose rate should be insignificant, so the same rate is assumed. The predicted external dose during demolition is 0.074 mrem with a 95% confidence interval spanning from -0.037 to +0.185 mrem.

As in the normal occupancy scenario, radon is of no concern.

Any contamination that may be in buried drainage pipes will be largely contained by those pipes during demolition and disposal. This source term is unlikely to significantly alter the calculated inhalation dose.

Inhalation dose due to demolition predicted by RESRAD-BUILD is 0.69 mrem. Ingestion dose predicted by RESRAD-BUILD is 0.002 mrem.

Summing all sources, the predicted Total Effective Dose Equivalent (TEDE) due to demolition of Building 2 is 0.77 mrem, and the radon concentration is insignificant.

Considering the uncertainty in measurements and assumptions, it is appropriate to state that the dose from normal occupancy approximately is 1 mrem TEDE.

3.3 Disposal of Demolition Debris

The demolition debris from Building 2 will be essentially like other debris from the region. No beneficial use of disposal debris is anticipated, and it is likely that all will be incorporated into the

subsurface structure of a sanitary landfill. The process of demolition will cause the radioactive contaminants to be averaged into the mass of debris, resulting in extremely low concentrations. The concentration of radioactivity in the debris is likely to be far below EPA disposal criteria for uranium mill tailings. The disposal criteria, specified in 40 CFR 192, is that activity should not exceed 15 pCi/g in soil structures 15-cm or more below the surface.

4.0 Conclusions

Measurement and model predictions have shown the dose to the public from future use of Building 2 is much less than the legal limit of 100 mrem/year and well below the release criteria proposed in the DQO process. Building 2 is suitable for unrestricted use by the public.


Disposal of demolition debris in a sanitary landfill is acceptable. Disposal will pose no hazard because the radioactivity concentration will be much less than the EPA disposal criteria for uranium mill tailings.

An ALARA analysis should be performed using the predicted dose and potential cost savings. The cost savings estimates should be developed by the GJPORAP. A decision of disposition of the building based on this information would follow.

5.0 References

1. Argonne National Laboratory, *RESRAD-BUILD [Version 1.5]: A Computer Model for Analyzing the Radiological Doses Resulting from the Remediation and Occupancy of Buildings Contaminated with Radioactive Material*, ANL/EAD/LD-3, 1994.
2. Rust Geotech, *Environmental Procedures Catalog*, Manual 116.
3. Rust Geotech, *Field Assessments Procedures Manual*.
4. Supporting documentation filed in the DOE Grand Junction Projects Office, GJPORAP Building 2 Project Records, April 1996.
5. *Results of the U.S. Department of Energy Indoor Radon Study*, Volume 2. CNG/GJ-TP-1. UNC Geotech, DOE Grand Junction Projects Office, Grand Junction, Colorado, 1990.
6. DOE Order 5400.5, *Radiation Protection of the Public and the Environment*, Figure IV-1, Surface Contamination Guidelines. See the entry for "U-natural."
7. Science & Engineering Associates, Inc., *Results of the Radiological and Video Surveys of Drain Lines at the DOE Grand Junction Projects Office with the Pipe Explorer™ System*, Albuquerque, New Mexico, March 8, 1996.
8. *Evaluation of RESRAD-BUILD for application to Building 2*. February, 1996. Filed in the same volume as Reference 4.

6.0 Appendices



Appendix 1

Data Tables and Figures

Table A1-1. Exposure Rate Measurements Made Using Pressurized Ion Chamber

Building 2					Building 12		
North Survey Unit		South Survey Unit			Reference Survey Unit		
Loc	Exp Rate $\mu\text{R/hr}$	Loc	Exp Rate $\mu\text{R/hr}$	Duplicate $\mu\text{R/hr}$	Loc	Exp Rate $\mu\text{R/hr}$	Duplicate $\mu\text{R/hr}$
R11	11.9	R1	10.9		R1	9.9	
R12	12.1	R2	11.6		R2	11.2	
R13	12.3	R3	11.8		R3	11.0	
R14	11.8	R4	11.8		R4	10.9	
R15	12.1	R5	12.0	12.2	R5	13.1	
R16	11.8	R6	11.9		R6	10.8	11.4
R17	11.8	R7	12.3		R7	11.4	
R18	12.1	R8	12.0		R8	10.8	
		R9	11.8		R9	11.3	
		R10	11.6		R10	10.8	
					R11	10.5	
					R12	10.3	
					R13	10.5	
					R14	10.5	
					R15	10.5	
					R16	11.1	
					R17	11.3	
					R18	11.3	
					R19	10.8	
					R20	10.9	
					R21	11.3	
					R22	10.5	
Mean	11.99		11.77			10.94	
Std Dev	0.189		0.368			0.618	

Table A1-2
SCAN MEASUREMENTS
BUILDING 2

			Inst. Reading dpm/100 cm ²		Bkg dpm/100 cm ²	Net dpm/100 cm ²		
Survey Unit	Location ID	Material Type	High	Low		High	Low	Exceeds Limit?
FLOOR	F01-N	Vinyl	2205	1638	1261	944	377	no
FLOOR	F01-S	Carpet	2630	1438	1700	930	-262	no
FLOOR	F02-N	Vinyl	2500	1600	1504	996	96	no
FLOOR	F02-S	Carpet	2548	1438	1700	848	-262	no
FLOOR	F03-N	Vinyl	2403	1875	1261	1142	614	no
FLOOR	F03-S	Carpet	2250	1478	1700	550	-222	no
FLOOR	F04-N	Vinyl	2240	1378	1504	736	-126	no
FLOOR	F04-S	Carpet	3107	2204	1265	1842	939	no
FLOOR	F05-N	Vinyl	2556	1895	1261	1295	634	no
FLOOR	F05-S	Carpet	2540	1632	1700	840	-68	no
FLOOR	F06-S	Carpet	2633	1488	1690	943	-202	no
FLOOR	F07-S	Carpet	2957	1677	1690	1267	-13	no
FLOOR	F08-S	Carpet	2909	1867	1746	1163	121	no
FLOOR	F09-S	Carpet	2510	1867	1265	1245	602	no
FLOOR	F10-S	Carpet	2559	1516	1746	813	-230	no
FLOOR	F11-S	Carpet	2500	1506	1746	754	-240	no
FLOOR	F12-S	Carpet	2459	1597	1746	713	-149	no
FLOOR	F13-S	Carpet	2506	1834	1746	760	88	no
FLOOR	F14-S	Vinyl	2484	1614	1690	794	-76	no
FLOOR	F15-S	Vinyl	2239	1400	1690	549	-290	no
FLOOR	F16-S	Vinyl	2368	1548	1690	678	-142	no
FLOOR	F17-S	Vinyl	2016	1547	1746	270	-199	no
FLOOR	F18-S	Vinyl	2510	1488	1690	820	-202	no
FLOOR	F19-S	Concrete	7680	1963	1333	6347	630	maybe
NEW WALLS	W01-N	Sheetrock	2104	963	1298	806	-335	no
NEW WALLS	W01-S	Paneling	1475	922	1292	183	-370	no
NEW WALLS	W02-N	Paneling	1438	1003	1483	-45	-480	no
NEW WALLS	W02-S	Paneling	1602	933	1216	386	-283	no
NEW WALLS	W03-N	Plywood	1846	960	1298	548	-338	no
NEW WALLS	W03-S	Cork Board	1219	911	1292	-73	-381	no
NEW WALLS	W04-N	plywood	2264	1095	1298	966	-203	no
NEW WALLS	W04-S	Paneling	2000	1125	1292	708	-167	no
NEW WALLS	W05-S	Paneling	1612	1010	1216	396	-206	no
NEW WALLS	W06-S	Paneling	1600	1017	1216	384	-199	no
NEW WALLS	W07-S	Paneling	1719	1109	1292	427	-183	no
NEW WALLS	W08-S	Paneling	1807	1117	1216	591	-99	no
NEW WALLS	W09-S	Paneling	1646	1110	1292	354	-182	no
NEW WALLS	W10-S	Paneling	1929	1124	1216	713	-92	no

Table A1-2
SCAN MEASUREMENTS
BUILDING 2

			Inst. Reading dpm/100 cm ²		Bkg dpm/100 cm ²	Net dpm/100 cm ²		
Survey Unit	Location ID	Material Type	High	Low		High	Low	Exceeds Limit?
NEW WALLS	W11-N	Sheetrock	1641	1125	1325	316	-200	no
NEW WALLS	W11-S	Sheetrock	1536	1080	1229	307	-149	no
NEW WALLS	W12-N	Sheetrock	1715	1103	1325	390	-222	no
NEW WALLS	W12-S	Sheetrock	1531	1016	1229	302	-213	no
NEW WALLS	W13-S	Sheetrock	1856	1094	1088	768	6	no
NEW WALLS	W14-S	Sheetrock	1569	891	1305	264	-414	no
NEW WALLS	W15-S	Sheetrock	1641	1188	1305	336	-117	no
NEW WALLS	W16-S	Sheetrock	1516	1141	1229	287	-88	no
NEW WALLS	W17-S	Sheetrock	1656	1359	1305	351	54	no
NEW WALLS	W18-S	Sheetrock	1609	1109	1305	304	-196	no
NEW WALLS	W19-S	Sheetrock	1651	1151	1471	180	-320	no
NEW WALLS	W20-S	Sheetrock	1672	1156	1471	201	-315	no
NEW WALLS	W21-S	Sheetrock	1719	1331	1305	414	26	no
NEW WALLS	W22-S	Sheetrock	1531	1113	1305	226	-192	no
NEW WALLS	W23-S	Sheetrock	1934	984	1229	705	-245	no
NEW WALLS	W24-S	Sheetrock	1563	938	1229	334	-291	no
NEW WALLS	W25-S	Paneling	1922	1078	1117	805	-39	no
NEW WALLS	W26-S	Sheetrock	1271	949	1117	154	-168	no
NEW WALLS	W27-S	Paneling	1797	1229	1338	459	-109	no
NEW WALLS	W28-S	Paneling	1431	979	1338	93	-359	no
NEW WALLS	W29-S	Sheetrock	1641	1031	1471	170	-440	no
NEW WALLS	W30-S	Paneling	1749	1171	1338	411	-167	no
NEW WALLS	W31-S	Paneling	1542	1041	1117	425	-76	no
OLD WALLS	W05-N	Concrete	3147	1797	1858	1289	-61	no
OLD WALLS	W06-N	Concrete	3610	2109	1858	1752	251	no
OLD WALLS	W07-N	Concrete	4516	1799	1570	2946	229	no
OLD WALLS	W07-N	Radiator	10300	2600	1570	8730	1030	maybe
OLD WALLS	W08-N	Concrete	3046	1605	1570	1476	35	no
OLD WALLS	W09-N	Concrete	2418	1830	1570	848	260	no
OLD WALLS	W10-N	Concrete	4408	1692	1596	2812	96	no
OLD WALLS	W32-S	Concrete	11800	1800	1690	10110	110	maybe
OLD WALLS	W33-S	Concrete	2797	1844	1446	1351	398	no
OLD WALLS	W34-S	Concrete	2942	1990	1746	1196	244	no
OLD WALLS	W35-S	Concrete	2790	1450	1540	1250	-90	no

Notes:

1) All measurements collected with NE Electra/DP6a Scintillation Probe calibrated for CI-36

Table A1-3
DIRECT MEASUREMENTS & SMEARS
BUILDING 2

		Direct Measurements (dpm/100 cm ²)				Smear Measurements (dpm/100 cm ²)			
Location		Inst.		Mean for Survey		Mean for Survey		Mean for Survey	
Survey Unit	Material Type	Reading	Bkg	Net	Exceeds Limit?	Reading	Bkg	Net	Exceeds Limit?
FLOOR	D001	CARPET	2074	2016	58	no	2094	2016	78
FLOOR	D002	CARPET	2110	2016	94	no	2106	2016	90
FLOOR	D003	VINYL	2267	1804	463	no	2196	1804	392
FLOOR	D004	VINYL	2274	2078	196	no	1913	2078	160
FLOOR	D005	CARPET	2102	2016	86	no	1820	2016	-196
FLOOR	D006	CARPET	2027	1998	29	no	2008	1998	10
FLOOR	D007	CARPET	2245	2016	229	no	2057	2016	41
FLOOR	D008	CARPET	2204	2016	188	no	1959	2016	-57
FLOOR	D009	VINYL	2309	2016	293	no	1902	2016	-114
FLOOR	D010	CARPET	2163	1998	165	no	1902	1998	96
FLOOR	D011	CARPET	2126	2016	110	no	1902	2016	-114
FLOOR	D012	VINYL	1928	2078	150	no	2029	2078	-49
FLOOR	D013	CARPET	2320	2016	304	no	1980	2016	-36
FLOOR	D014	CARPET	2367	1998	369	no	1984	1998	-14
FLOOR	D015	VINYL	1825	1804	21	no	1808	1804	4
FLOOR	D016	CARPET	2180	2016	164	no	1931	2016	-85
FLOOR	D017	VINYL	1788	1804	-16	no	2075	1804	271
FLOOR	D018	CARPET	1963	2016	-53	no	1835	2016	-181
FLOOR	D019	VINYL	1881	1804	77	no	1875	1804	71
FLOOR	D020	CARPET	2138	1788	350	no	1600	1788	-188
FLOOR	D021	VINYL	1776	2078	-302	no	2049	2078	-29
FLOOR	D022	CARPET	1833	1788	45	no	1754	1788	-34
FLOOR	D023	CARPET	1963	2016	-53	no	1861	2016	-155
FLOOR	D024	CARPET	2151	2016	135	no	1967	2016	-49
FLOOR	D025	CARPET	2236	2016	220	no	1608	2016	-408
FLOOR	D026	VINYL	2026	2078	-52	no	1976	2078	-102
FLOOR	D027	CARPET	2129	1788	341	no	1663	1788	-125
FLOOR	D028	CARPET	2042	1788	254	no	1688	1788	-100
FLOOR	D029	CARPET	2123	1998	125	no	1843	1998	-155

Table A1-3
DIRECT MEASUREMENTS & SMEARS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location		Inst.	Mean for Survey				Std Dev	Mean for Survey				Std Dev							
Survey Unit	ID		Material Type	Reading	Bkg	Net		Exceeds Limit?	Unit	Unit	Unit		Unit	Unit					
FLOOR	D030	CARPET	2023	2016	7	no	1918	2016	98	no									
FLOOR	D097	CONCRETE	6760	1333	5427	yes	1583	1638	-55	no									
FLOOR	D098	CARPET	3315	1265	2050	no	1490	1265	225	no									
FLOOR	D099	CARPET	2416	1910	506	no	2135	1910	225	no									
FLOOR	D100	CARPET	3067	1871	1196	no	1963	1871	92	no									
FLOOR	D101	CARPET	2123	1265	858	no	1596	1265	331	no									
FLOOR	D102	CARPET	2029	1261	768	no	1710	1261	449	no									
FLOOR	D103	CARPET	2057	1261	796	no	413	946	1261	376	no	1	187						
NEW WALLS	D031-0	PLYWOOD	1642	1529	113	no	2029	1529	500	no									
NEW WALLS	D031-1	PLYWOOD	1317	1529	-212	no	1918	1529	389	no									
NEW WALLS	D031-2	PLYWOOD	1338	1529	-191	no	1875	1529	346	no									
NEW WALLS	D032-2	SHEET ROCK	1400	1722	-322	no	2176	1722	454	no									
NEW WALLS	D033-0	SHEET ROCK	1747	1722	25	no	1922	1722	200	no									
NEW WALLS	D033-1	SHEET ROCK	1171	1722	-551	no	1633	1722	-89	no									
NEW WALLS	D033-2	SHEET ROCK	1180	1722	-542	no	1641	1722	-81	no									
NEW WALLS	D034-0	PLYWOOD	1592	1533	59	no	1879	1533	346	no									
NEW WALLS	D034-1	PLYWOOD	1524	1533	9	no	1883	1533	50	no									
NEW WALLS	D034-2	PLYWOOD	1363	1533	-170	no	1571	1533	38	no									
NEW WALLS	D035-0	PLYWOOD	1646	1530	116	no	1871	1530	441	no									
NEW WALLS	D035-1	PLYWOOD	1325	1530	-205	no	1891	1530	361	no									
NEW WALLS	D035-2	PLYWOOD	1238	1530	-292	no	2038	1530	508	no									
NEW WALLS	D036-0	VINYL	1902	2078	-176	no	2094	2078	16	no									
NEW WALLS	D036-1	PLYWOOD	1518	1347	171	no	2200	1347	853	no									
NEW WALLS	D036-2	PLYWOOD	1441	1347	94	no	2102	1347	755	no									
NEW WALLS	D037-0	VINYL	1743	1882	-139	no	1747	1882	135	no									
NEW WALLS	D037-1	PLYWOOD	1310	1347	-37	no	1710	1347	363	no									
NEW WALLS	D037-2	PLYWOOD	1130	1347	-217	no	1771	1347	424	no									
NEW WALLS	D038-0	SHEETROCK	1688	1479	209	no	1663	1479	184	no									
NEW WALLS	D038-1	SHEETROCK	1254	1479	-225	no	1725	1479	246	no									

Table A1-3
DIRECT MEASUREMENTS & SMEARS
BUILDING 2

		Direct Measurements (dpm/100 cm ²)				Smear Measurements (dpm/100 cm ²)			
Location		Inst		Mean for Survey		Mean for Survey		Std Dev for Survey	
Survey Unit	Material Type	Reading	Bkg	Net	Exceeds Limit?	Reading	Bkg	Net	Exceeds Limit?
Unit									
NEW WALLS D038-2	SHEETROCK	1238	1479	-241	no	1700	1479	221	no
NEW WALLS D039-0	PANELING	1625	1437	188	no	2135	1437	698	no
NEW WALLS D039-1	PANELING	1367	1437	-70	no	2061	1437	624	no
NEW WALLS D039-2	PANELING	1278	1437	159	no	1931	1437	494	no
NEW WALLS D040-2	SHEETROCK	1242	1500	-258	no	1692	1500	192	no
NEW WALLS D041	SHEETROCK	1385	1384	49	no	1678	1706	28	no
NEW WALLS D042	PANELING	1171	1450	-279	no	1679	1638	41	no
NEW WALLS D043	VINYL	1796	2041	245	no	1865	1706	41	no
NEW WALLS D044	SHEETROCK	1355	1384	-29	no	1649	1706	-57	no
NEW WALLS D045	PANELING	1204	1450	-246	no	1792	1638	154	no
NEW WALLS D046	SHEETROCK	1376	1384	-8	no	1596	1706	-110	no
NEW WALLS D047	SHEETROCK	1318	1384	-66	no	1780	1706	74	no
NEW WALLS D048	SHEETROCK	1171	1384	-213	no	1494	1706	-212	no
NEW WALLS D049	SHEETROCK	1347	1384	-37	no	1592	1706	114	no
NEW WALLS D050	SHEETROCK	1392	1384	8	no	1739	1706	33	no
NEW WALLS D051	PANELING	1458	1450	8	no	1629	1638	109	no
NEW WALLS D052	SHEETROCK	1343	1384	-41	no	1531	1706	-175	no
NEW WALLS D053	PANELING	1129	1450	-321	no	1483	1638	155	no
NEW WALLS D054	SHEETROCK	1404	1384	20	no	1612	1706	-94	no
NEW WALLS D055	SHEETROCK	1445	1384	61	no	1665	1706	41	no
NEW WALLS D056	SHEETROCK	1302	1384	-82	no	1637	1706	-69	no
NEW WALLS D057	PANELING	1163	1450	-287	no	1546	1638	92	no
NEW WALLS D058	SHEETROCK	1347	1384	-37	no	1680	1706	-26	no
NEW WALLS D059	SHEETROCK	1265	1384	119	no	1563	1706	143	no
NEW WALLS D060	SHEETROCK	1442	1450	-8	no	1567	1638	-71	no
NEW WALLS D061	SHEETROCK	1302	1384	-82	no	1559	1706	147	no
NEW WALLS D062	SHEETROCK	1388	1450	-62	no	1688	1638	50	no
NEW WALLS D063	PANELING	1388	1450	62	no	1571	1638	67	no
NEW WALLS D064	SHEETROCK	1279	1450	-171	no	1479	1638	-159	no

Table A1-3
DIRECT MEASUREMENTS & SMEARS
BUILDING 2

		Direct Measurements (dpm/100 cm ²)				Smear Measurements (dpm/100 cm ²)			
		Inst		Mean for Survey		Mean for Survey		Mean for Survey	
Survey Unit	Location	Material Type	Reading Bkg	Net	Exceeds Limit?	Reading Bkg	Net	Exceeds Limit?	Unit
	ID								Unit
NEW WALLS D065	SHEETROCK		1292	1450	no	1596	1638	no	
NEW WALLS D066	SHEETROCK		1579	1450	no	1583	1638	no	
NEW WALLS D067	PANELING		1083	1450	no	1563	1638	no	
NEW WALLS D068	SHEETROCK		1490	1384	no	1494	1706	no	
NEW WALLS D069	SHEETROCK		1215	1450	no	1458	1638	no	
NEW WALLS D070	PANELING		1171	1450	no	1450	1638	no	105
OLD WALLS D032-0	VINYL		2012	2078	no	2400	2078	no	
OLD WALLS D032-1	CONCRETE		2294	1665	no	2282	1665	no	
OLD WALLS D040-0	CONCRETE		2054	1500	no	1846	1500	no	
OLD WALLS D040-1	CONCRETE		2021	1500	no	1667	1500	no	
OLD WALLS D071	CONCRETE		10700	1690	yes	779	806	no	
OLD WALLS D072	CONCRETE		2583	1446	no	967	806	no	
OLD WALLS D073	CONCRETE		2453	1746	no	645	806	no	
OLD WALLS D074	CONCRETE		2790	1540	no	860	806	no	
OLD WALLS D075	CONCRETE		3467	1963	no	2254	1963	no	
OLD WALLS D076	CONCRETE		2396	1796	no	2142	1796	no	
OLD WALLS D077	CONCRETE		2104	1796	no	2221	1796	no	
OLD WALLS D078	CONCRETE		1733	1796	no	2271	1796	no	
OLD WALLS D079	CONCRETE		2208	1796	no	2367	1796	no	
OLD WALLS D080	CONCRETE		2383	1621	no	2400	1621	no	
OLD WALLS D081	CONCRETE		2517	1621	no	2325	1621	no	
OLD WALLS D082	CONCRETE		2508	1621	no	2533	1621	no	
OLD WALLS D083	CONCRETE		2925	1621	no	2421	1621	no	
OLD WALLS D084	CONCRETE		3647	1788	no	1525	1788	no	
OLD WALLS D085	CONCRETE		2008	1490	no	2338	1490	no	
OLD WALLS D086	CONCRETE		3779	1490	no	2046	1490	no	
OLD WALLS D087	CONCRETE		2750	1490	no	2379	1490	no	
OLD WALLS D088	CONCRETE		2271	1490	no	2213	1490	no	
OLD WALLS D089	CONCRETE		5049	1600	no	2310	1600	no	

Table A1-3
DIRECT MEASUREMENTS & SMEARS
BUILDING 2

		Direct Measurements (dpm/100 cm ²)				Smear Measurements (dpm/100 cm ²)			
Survey Unit	Location ID	Material Type	Inst	Reading Bkg	Net	Exceeds Limit?	Mean for Survey		Std Dev
							Unit	Unit	
OLD WALLS D090	METAL		12400	2070	10330	yes	2210	2070	140
OLD WALLS D091	CONCRETE		3229	2008	1221	no	2078	2008	70
OLD WALLS D092	CONCRETE		2054	1692	362	no	2042	1692	350
OLD WALLS D093	CONCRETE		1975	1692	283	no	2067	1692	375
OLD WALLS D094	CONCRETE		1796	1692	104	no	1892	1692	200
OLD WALLS D095	CONCRETE		2538	1692	846	no	2046	1692	354
OLD WALLS D096	CONCRETE		1979	1692	287	no	2142	1488	654
OLD WALLS D104	CONCRETE		3629	1580	2049	no	1484	2313	398

Notes: 1) All readings were collected with NE Electra/DP6A Scintillation probe calibrated for CI-36. The smears were wiped over an area of approximately 100 cm².

Table A1-4						
Potentially Elevated Building 2 Smears						
Ludlum Model 2929 Scaler						
Survey Unit	Sample ID	Instrument Reading, counts	Bkg, counts	Net dpm	Beta Cal Factor	Exceeds Limit?
NORTH-E	C034-B	52	59	-32.7	4.67	no
NORTH-E	D036-1	59	56	13.7	4.57	no
NORTH-E	D036-2	53	56	-13.7	4.57	no
NORTH-E	C037-A	51	59	-37.4	4.67	no
NORTH-E	D039-0	63	56	32.0	4.57	no
NORTH-W	D080	56	56	0.0	4.57	no
NORTH-W	D081	70	56	64.0	4.57	no
NORTH-W	D082	58	56	9.1	4.57	no
NORTH-W	D083	67	56	50.3	4.57	no
NORTH-W	D085	70	56	64.0	4.57	no
NORTH-W	D087	55	56	-4.6	4.57	no
NORTH-W	D088	54	56	-9.1	4.57	no
NORTH-W	C014-B	55	59	-18.7	4.67	no
NORTH-W	C015-B	60	59	4.7	4.67	no
NORTH-W	C016-A	49	59	-46.7	4.67	no
NORTH-W	C016-B	45	59	-65.4	4.67	no
NORTH-N	C023-A	35	59	-112.1	4.67	no
NORTH-N	C025	44	59	-70.1	4.67	no
NORTH-N	C026-B	55	59	-18.7	4.67	no
NORTH-N	C029-E	54	59	-23.4	4.67	no
NORTH-N	C029-F	49	59	-46.7	4.67	no
NORTH-N	C031	50	59	-42.0	4.67	no
SOUTH-E	C052-C	53	59	-28.0	4.67	no
SOUTH-E	C052-D	61	59	9.3	4.67	no
SOUTH-E	C053-B	65	59	28.0	4.67	no
SOUTH-E	C054-B	66	59	32.7	4.67	no
SOUTH-E	C054-D	50	59	-42.0	4.67	no
SOUTH-E	C055-A	71	59	56.0	4.67	no
SOUTH-W	C045-B	75	59	74.7	4.67	no
SOUTH-W	C045-C	65	59	28.0	4.67	no
SOUTH-W	C046-C	52	59	-32.7	4.67	no
SOUTH-W	C046-D	66	59	32.7	4.67	no
SOUTH-W	C049-A	65	59	28.0	4.67	no
SOUTH-F	C010-B	50	59	-42.0	4.67	no
		Mean		-4.67		
		Std Dev		43.29		
		1 sigma UCL		38.628436		

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)				
Survey Unit	Location ID	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey Unit	Std Dev for Survey Unit	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey Unit	Std Dev for Survey Unit
NORTH-E	C32	CONCRETE	91134	78518	12616	yes					NA	NA		
NORTH-E	C32-A	PLYWOOD	1021	833	188	no				833	806	27	no	
NORTH-E	C32-B	PLYWOOD	698	833	-135	no				914	806	108	no	
NORTH-E	C32-C	SHEETROCK	833	833	0	no				816	806	10	no	
NORTH-E	C32-D	SHEETROCK	779	833	-54	no				591	806	-215	no	
NORTH-E	C33	WOOD	73821	78518	-4897	no					NA	NA		
NORTH-E	C33-A	PLYWOOD	779	833	-54	no				672	806	-134	no	
NORTH-E	C33-B	PLYWOOD	725	833	-108	no				618	806	188	no	
NORTH-E	C33-C	SHEETROCK	698	833	-135	no				698	806	-108	no	
NORTH-E	C33-D	SHEETROCK	833	833	0	no				403	806	-403	no	
NORTH-E	C34	CONCRETE	111801	78518	33283	yes					NA	NA		
NORTH-E	C34-A	PLYWOOD	1209	833	376	no				672	806	-134	no	
NORTH-E	C34-B	PLYWOOD	860	833	27	no				1048	806	242	no	
NORTH-E	C34-C	SHEETROCK	598	833	-135	no				752	806	54	no	
NORTH-E	C34-D	SHEETROCK	806	833	-27	no				967	806	161	no	
NORTH-E	C35	WOOD	64491	78518	-14027	no				672	806	-134	no	
NORTH-E	C35-A	PANELING	806	833	-27	no				994	806	188	no	
NORTH-E	C35-B	PANELING	779	833	-54	no				673	806	-133	no	
NORTH-E	C35-C	CELOTEX	1209	833	376	no				698	806	-108	no	
NORTH-E	C35-D	CELOTEX	994	833	161	no				698	806	-108	no	
NORTH-E	C36	CONCRETE	87233	78518	8715	yes				860	806	54	no	
NORTH-E	C36-A	PANELING	725	833	-108	no				569	806	-237	no	
NORTH-E	C36-B	PANELING	725	833	-108	no				994	806	188	no	
NORTH-E	C37	CONCRETE	76360	78518	-2158	no				672	806	-134	no	
NORTH-E	C37-A	PANELING	779	833	-54	no				1021	806	215	no	
NORTH-E	C37-B	PANELING	940	833	107	no				833	806	27	no	
NORTH-E	C38	WOOD	66898	54199	12699	yes					NA	NA		
NORTH-E	C38-A	PANELING	729	833	-104	no				833	806	27	no	
NORTH-E	C38-B	PANELING	806	833	-27	no				457	806	-349	no	
NORTH-E	C38-C	CELOTEX	1048	833	216	no				887	806	81	no	
NORTH-E	C38-D	CELOTEX	967	833	134	no				887	806	81	no	
NORTH-E	C39	WOOD	64242	54199	10043	yes					NA	NA		

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location		Inst.		Mean for				Exceeds		Mean for		Inst.		Exceeds				Mean for	
Survey Unit	ID	Material Type	Reading	Bkg	Net	Limit?	Survey Unit	Unit	Std Dev for	Survey Unit	Unit	Reading	Bkg	Net	Limit?	Survey Unit	Unit	Std Dev for	
NORTH-E	C39-A	PANELING	914	833	81	no						376	806	-430	no				
NORTH-E	C39-B	PANELING	564	833	-269	no						779	806	-27	no				
NORTH-E	C39-C	PLYWOOD	1774	833	941	no						833	806	27	no				
NORTH-E	C39-D	PLYWOOD	779	833	-54	no						967	806	161	no				
NORTH-E	C39-E	CELOTEX	1075	833	242	no						967	806	161	no				
NORTH-E	C39-F	CELOTEX	752	833	-81	no						860	806	54	no				
NORTH-E	C40	WOOD	70633	54199	16434	yes						779	806	-27	no				
NORTH-E	C40-A	PANELING	1048	833	215	no						779	806	-27	no				
NORTH-E	C40-B	PANELING	994	833	161	no						645	806	-161	no				
NORTH-E	C40-C	PLYWOOD	1182	833	349	no						779	806	-27	no				
NORTH-E	C40-D	PLYWOOD	1075	833	242	no						994	806	188	no				
NORTH-E	C40-E	CELOTEX	698	833	-135	no						967	806	161	no				
NORTH-E	C40-F	CELOTEX	645	833	-188	no	1659		6706			672	806	-134	no	-25	158		
NORTH-F	C01-A	CONCRETE	1370	914	456	no						779	994	-215	no				
NORTH-F	C01-B	CONCRETE	1102	887	215	no						725	994	-269	no				
NORTH-F	C01-C	CONCRETE	1209	887	322	no						1048	994	54	no				
NORTH-F	C02-A	CONCRETE	1612	1102	510	no						725	994	-269	no				
NORTH-F	C03-A	CONCRETE	1561	1319	242	no						591	994	-403	no				
NORTH-F	C03-B	CONCRETE	1317	887	430	no						994	994	0	NA				
NORTH-F	C03-C	CONCRETE	2870	887	1983	no						698	994	-296	no				
NORTH-F	C04-A	CONCRETE	1209	967	242	no						725	994	-269	no				
NORTH-F	C04-B	CONCRETE	1344	887	457	no						914	994	-80	no				
NORTH-F	C04-C	CONCRETE	4380	887	3493	no						806	994	-188	no				
NORTH-F	C05-A	CONCRETE	1397	1021	376	no						818	994	-176	no				
NORTH-F	C05-B	CONCRETE	1397	887	510	no						833	994	-161	no				
NORTH-F	C05-C	CONCRETE	4510	887	3628	no						672	994	-322	no				
NORTH-F	C06-A	CONCRETE	1451	861	590	no						698	994	-296	no				
NORTH-F	C06-B	CONCRETE	1048	887	161	no						860	994	-134	no				
NORTH-F	C06-C	CONCRETE	3190	887	2303	no						994	994	0	NA				
NORTH-F	C13-A	CONCRETE	1397	833	564	no						967	940	-27	no				
NORTH-F	C13-B	CONCRETE	1397	833	564	no						1021	940	81	no				
NORTH-F	C13-C	CONCRETE	3220	833	2387	no	1023		1128			779	940	-161	no			159	

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location		Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey		Std Dev for Survey Unit	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey		Std Dev for Survey Unit				
Survey Unit	Material Type					Unit	Unit						Unit	Unit					
NORTH-N	C23	CONCRETE	84494	58432	26062	yes			940	806	134	no							
NORTH-N	C23-A	PLYWOOD	833	833	0	no			1048	806	242	no							
NORTH-N	C23-B	PLYWOOD	860	833	27	no			672	806	-134	no							
NORTH-N	C23-C	SHEETROCK	779	833	-54	no			994	806	188	no							
NORTH-N	C23-D	SHEETROCK	967	833	134	no			860	806	54	no							
NORTH-N	C24	SHEETROCK	58847	58432	415	no			697	806	-109	no							
NORTH-N	C24-A	PLYWOOD	1075	833	242	no			698	806	-108	no							
NORTH-N	C24-B	PLYWOOD	833	833	0	no			806	806	0	NA							
NORTH-N	C25	CONCRETE	81921	58432	23489	yes			1021	806	215	no							
NORTH-N	C25-A	PLYWOOD	862	833	29	no			645	806	-161	no							
NORTH-N	C25-B	PLYWOOD	806	833	-27	no			698	806	-108	no							
NORTH-N	C25-C	SHEETROCK	672	833	-161	no			672	806	-134	no							
NORTH-N	C25-D	SHEETROCK	833	833	0	no			833	806	27	no							
NORTH-N	C26	CONCRETE	86652	58432	28220	yes			698	806	-108	no							
NORTH-N	C26-A	PLYWOOD	887	833	54	no			645	806	-161	no							
NORTH-N	C26-B	PLYWOOD	833	833	0	no			1075	806	269	no							
NORTH-N	C27	WOOD	77107	58432	18675	yes			698	806	-108	no							
NORTH-N	C27-A	PLYWOOD	833	833	0	no			833	806	27	no							
NORTH-N	C27-B	PLYWOOD	591	833	-242	no			994	806	188	no							
NORTH-N	C28	CONCRETE	92794	58432		no			591	806	215	no							
NORTH-N	C28-A	PLYWOOD	1075	833	242	no			537	806	-269	no							
NORTH-N	C28-B	PLYWOOD	860	833	27	no			860	806	54	no							
NORTH-N	C29	WOOD	65902	58432	7470	yes					NA	NA							
NORTH-N	C29-A	PLYWOOD	591	833	-242	no			725	806	81	no							
NORTH-N	C29-B	PLYWOOD	1021	833	188	no			698	806	-108	no							
NORTH-N	C29-C	PLYWOOD	806	833	-27	no			672	806	-134	no							
NORTH-N	C29-D	PLYWOOD	967	833	134	no			725	806	-81	no							
NORTH-N	C29-E	PLYWOOD	1344	1075	269	no			1021	806	215	no							
NORTH-N	C29-F	PLYWOOD	779	1075	-296	no			1048	806	242	no							
NORTH-N	C30	WOOD	68724	58432	10292	yes			860	806	54	no							
NORTH-N	C30-A	PLYWOOD	779	833	-54	no			887	806	81	no							
NORTH-N	C30-B	PLYWOOD	806	833	-27	no			698	806	-108	no							

Page 3 of 9

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location			Inst.	Mean for				Inst.	Mean for										
Survey Unit	ID	Material		Type	Reading	Bkg	Net		Exceeds Limit?	Survey Unit	Unit	Survey	Unit						
NORTH-N	C31	CONCRETE		79680	58432	21248	yes	Reading	Bkg	Net	Exceeds Limit?	Survey Unit	Unit	Survey	Unit				
NORTH-N	C31-A	PLYWOOD		806	833	-27	no	1129	806	323	no	698	806	-108	no				
NORTH-N	C31-B	PLYWOOD		779	833	-54	no	833	806	27	no	833	806	27	no				
NORTH-W	C14	WOOD		65072	58847	6225	yes	672	806	-134	no	672	806	-134	no				
NORTH-W	C14-A	PLYWOOD		1586	833	753	no	914	887	27	no	914	887	27	no				
NORTH-W	C14-B	PLYWOOD		1559	833	726	no	1129	887	242	no	1129	887	242	no				
NORTH-W	C14-C	CELOTEX		887	833	54	no	967	887	80	no	967	887	80	no				
NORTH-W	C14-D	CELOTEX		887	833	64	no	967	887	80	no	967	887	80	no				
NORTH-W	C15	WOOD		88893	58847	30046	yes	967	806	161	no	967	806	161	no				
NORTH-W	C15-A	SHEETROCK		914	833	81	no	887	887	0	NA	887	887	0	NA				
NORTH-W	C15-B	SHEETROCK		1129	833	296	no	1129	887	242	no	1129	887	242	no				
NORTH-W	C15-C	MASONITE		915	833	82	no	914	887	27	no	914	887	27	no				
NORTH-W	C15-D	MASONITE		1102	833	269	no	1021	887	134	no	1021	887	134	no				
NORTH-W	C15-E	CELOTEX		2160	833	1317	no	779	887	-108	no	779	887	-108	no				
NORTH-W	C15-F	CELOTEX		1451	833	618	no	779	887	-108	no	779	887	-108	no				
NORTH-W	C16	WOOD		64076	58847	5229	yes		NA	NA	NA		NA	NA	NA				
NORTH-W	C16-A	SHEETROCK		1290	833	457	no	1155	887	268	no	1155	887	268	no				
NORTH-W	C16-B	SHEETROCK		1344	833	511	no	1182	887	295	no	1182	887	295	no				
NORTH-W	C16-C	CELOTEX		1102	833	269	no	1021	887	134	no	1021	887	134	no				
NORTH-W	C16-D	CELOTEX		914	833	81	no	725	887	162	no	725	887	162	no				
NORTH-W	C17	WOOD		68060	65321	2739	no		NA	NA	NA		NA	NA	NA				
NORTH-W	C17-A	PLYWOOD		860	833	27	no	806	806	0	NA	806	806	0	NA				
NORTH-W	C17-B	PLYWOOD		779	833	-54	no	940	806	134	no	940	806	134	no				
NORTH-W	C17-C	SHEETROCK		1270	833	437	no	833	806	27	no	833	806	27	no				
NORTH-W	C17-D	SHEETROCK		1102	833	269	no	725	806	-81	no	725	806	-81	no				
NORTH-W	C17-E	CELOTEX		967	833	134	no	806	806	0	NA	806	806	0	NA				
NORTH-W	C17-F	CELOTEX		779	833	-54	no	860	806	54	no	860	806	54	no				
NORTH-W	C18	WOOD		83415	65321	18094	yes		NA	NA	NA		NA	NA	NA				
NORTH-W	C18-A	SHEETROCK		698	833	-135	no	752	887	-135	no	752	887	-135	no				
NORTH-W	C18-B	SHEETROCK		914	833	81	no	806	887	81	no	806	887	81	no				
NORTH-W	C18-C	CELOTEX		1048	833	215	no	672	887	-215	no	672	887	-215	no				
NORTH-W	C18-D	CELOTEX		806	833	27	no	887	887	0	NA	887	887	0	NA				

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)																																																																																																																																																																																																																																																																																																																																																																																																																																																									
Location		Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey		Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey		Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Survey	Std Dev for Survey	Inst. Reading	Bkg	Net	

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

		Direct Measurements (dpm/100 cm ²)						Smear Measurements (dpm/100 cm ²)					
Location		Inst. Reading	Material Type	Bkg.	Net	Exceeds Limit?	Mean for Survey Unit	Inst. Reading	Bkg.	Net	Exceeds Limit?	Mean for Survey Unit	Std Dev for Survey Unit
Survey Unit	ID												
SOUTH-E	C52-D	1075	SHEETROCK	1129	-54	no		1371	779	592	no		
SOUTH-E	C53	62167	INSULATION	63080	-913	no				NA	NA		
SOUTH-E	C53-A	1048	PANELING	1129	-81	no		725	779	-54	no		
SOUTH-E	C53-B	940	PANELING	1129	-189	no		1129	779	350	no		
SOUTH-E	C53-C	1048	SHEETROCK	1129	-81	no		725	779	-54	no		
SOUTH-E	C53-D	887	SHEETROCK	1129	-242	no		806	779	27	no		
SOUTH-E	C54	76194	INSULATION	64989	11205	yes				NA	NA		
SOUTH-E	C54-A	1048	PANELING	1129	-81	no		967	779	188	no		
SOUTH-E	C54-B	994	PANELING	1129	-135	no		1129	779	350	no		
SOUTH-E	C54-C	940	SHEETROCK	1129	-189	no		806	779	27	no		
SOUTH-E	C54-D	1075	SHEETROCK	1129	-54	no		1021	779	242	no		
SOUTH-E	C55	67645	INSULATION	64989	2656	no				NA	NA		
SOUTH-E	C55-A	1371	PANELING	1129	242	no		1102	779	323	no		
SOUTH-E	C55-B	1048	PANELING	1129	-81	no		940	779	161	no		
SOUTH-E	C55-C	914	SHEETROCK	1129	-215	no		887	779	108	no		
SOUTH-E	C55-D	1075	SHEETROCK	1129	54	no		584	779	-215	no		
SOUTH-E	C56	42662	MASONITE	59096	-16434	no				NA	NA		
SOUTH-E	C56-A	860	PANELING	1129	-269	no		887	779	108	no		
SOUTH-E	C56-B	940	PANELING	1129	-189	no		806	779	27	no		
SOUTH-E	C57	64491	WOOD	59096	5395	yes				NA	NA		
SOUTH-E	C57-A	779	PANELING	1129	-350	no		591	779	-188	no		
SOUTH-E	C57-B	914	PANELING	1129	-215	no		752	779	27	no		
SOUTH-E	C57-C	860	SHEETROCK	1129	-269	no		833	779	54	no		
SOUTH-E	C57-D	1075	SHEETROCK	1129	-54	no		887	779	108	no		
SOUTH-E	C57-E	1155	WOOD	1129	26	no		833	779	54	no		
SOUTH-E	C57-F	914	WOOD	1129	215	no		645	779	134	no		
SOUTH-E	C58	51543	CELOTEX	59096	-7553	no				NA	NA		
SOUTH-E	C58-A	967	PANELING	1129	-162	no		860	779	81	no		
SOUTH-E	C58-B	1182	PANELING	1129	53	no		967	779	188	no		
SOUTH-E	C58-C	1397	CELOTEX	1129	268	no		645	779	134	no		
SOUTH-E	C58-D	967	CELOTEX	1129	-162	no		967	779	188	no		
SOUTH-E	C58-E	1021	CONCRETE	967	54	no		967	1021	135	no		

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location		Inst.	Material Type	Reading	Bkg.	Net	Exceeds Limit?	Mean for Survey		Inst.	Reading	Bkg.	Net	Exceeds Limit?	Mean for Survey		Std. Dev for Survey	Unit	Survey Unit
Survey Unit	ID							Unit	Unit										
SOUTH-F	C07-B	CONCRETE	1048	967	81	no				940	1102	-162	no						
SOUTH-F	C07-C	CONCRETE	1720	967	753	no				914	1102	-188	no						
SOUTH-F	C08-A	CONCRETE	1451	1424	27	no				833	940	-107	no						
SOUTH-F	C08-B	CONCRETE	1102	1424	-322	no				967	940	27	no						
SOUTH-F	C08-C	CONCRETE	2520	1424	1096	no				806	940	-134	no						
SOUTH-F	C09-A	CONCRETE	1048	1075	-27	no				994	940	54	no						
SOUTH-F	C09-B	CONCRETE	1155	1075	80	no				833	940	-107	no						
SOUTH-F	C09-C	CONCRETE	2090	1075	1015	no				860	940	-80	no						
SOUTH-F	C10-A	CONCRETE	1639	860	779	no				1048	940	108	no						
SOUTH-F	C10-B	CONCRETE	1182	860	322	no				1424	940	484	no						
SOUTH-F	C10-C	CONCRETE	2410	860	1550	no				940	940	0	NA						
SOUTH-F	C11-A	CONCRETE	1397	1021	376	no				860	940	-80	no						
SOUTH-F	C11-B	CONCRETE	1424	1021	403	no				940	940	0	NA						
SOUTH-F	C11-C	CONCRETE	2710	1021	1689	no				779	940	161	no						
SOUTH-F	C12-A	CONCRETE	1397	645	752	no				806	940	-134	no						
SOUTH-F	C12-B	CONCRETE	1586	645	941	no				698	940	-242	no						
SOUTH-F	C12-C	CONCRETE	3300	645	2655	no				591	940	-349	no						176
SOUTH-W	C41	CELOTEX	75198	68973	6225	yes						NA	NA						
SOUTH-W	C41-A	PANELING	725	833	-108	no				779	806	-27	no						
SOUTH-W	C41-B	PANELING	994	833	161	no				887	806	81	no						
SOUTH-W	C41-C	CELOTEX	1290	833	457	no				591	806	-215	no						
SOUTH-W	C41-D	CELOTEX	806	833	-27	no				833	806	27	no						
SOUTH-W	C42	WOOD	74368	68973	5395	yes						NA	NA						
SOUTH-W	C42-A	SHEETROCK	672	833	161	no				645	806	161	no						
SOUTH-W	C42-B	SHEETROCK	1048	833	215	no				457	806	-349	no						
SOUTH-W	C43	WOOD	70467	67768	12699	yes						NA	NA						
SOUTH-W	C43-A	PANELING	1102	1129	-27	no				914	779	135	no						
SOUTH-W	C43-B	PANELING	806	1129	-323	no				887	779	108	no						
SOUTH-W	C43-C	PLYWOOD	806	1129	-323	no				672	779	-107	no						
SOUTH-W	C43-D	PLYWOOD	915	1129	-214	no				994	779	215	no						
SOUTH-W	C43-E	CELOTEX	1290	1129	161	no				887	779	108	no						
SOUTH-W	C43-F	CELOTEX	1102	1129	-27	no				645	779	-134	no						

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)							
Location			Inst.		Mean for			Mean for			Inst.		Mean for				
Survey Unit	ID	Material Type	Reading	Bkg	Net	Exceeds Limit?	Survey Unit	Unit	Survey Unit	Unit	Reading	Bkg	Net	Exceeds Limit?	Survey Unit	Unit	Survey Unit
SOUTH-W	C44	WOOD	73704	63080	10624	yes							NA	NA			
SOUTH-W	C44-A	PANELING	698	1129	-431	no					752	779	-27	no			
SOUTH-W	C44-B	PNAELING	725	1129	-404	no					994	779	215	no			
SOUTH-W	C44-C	SHEETROCK	1075	1129	-54	no					753	779	-26	no			
SOUTH-W	C44-D	SHEETROCK	860	1129	-269	no					591	779	-188	no			
SOUTH-W	C45	WOOD	67645	59096	8549	yes							NA	NA			
SOUTH-W	C45-A	PANELING	618	1129	-511	no					940	779	161	no			
SOUTH-W	C45-B	PANELING	672	1129	-457	no					1021	779	242	no			
SOUTH-W	C45-C	SHEETROCK	1209	1129	80	no					1104	779	325	no			
SOUTH-W	C45-D	SHEETROCK	940	1129	-189	no					752	779	-27	no			
SOUTH-W	C46	INSULATION	78435	55610	22825	yes							NA	NA			
SOUTH-W	C46-A	PANELING	914	1129	-215	no					887	779	108	no			
SOUTH-W	C46-B	PANELING	807	1129	-322	no					940	779	161	no			
SOUTH-W	C46-C	CELOTEX	887	1129	-242	no					1021	779	242	no			
SOUTH-W	C46-D	CELOTEX	887	1129	-242	no					1182	779	403	no			
SOUTH-W	C47	INSULATION	74285	55610	18675	yes							NA	NA			
SOUTH-W	C47-A	PANELING	914	1129	-215	no					914	779	135	no			
SOUTH-W	C47-B	PANELING	779	1129	-350	no					887	779	108	no			
SOUTH-W	C47-C	CELOTEX	752	1129	-377	no					967	779	188	no			
SOUTH-W	C47-D	CELOTEX	672	1129	-457	no					860	779	81	no			
SOUTH-W	C48	INSULATION	72625	55195	17430	yes							NA	NA			
SOUTH-W	C48-A	PLYWOOD	994	1129	-135	no					806	779	-27	no			
SOUTH-W	C48-B	PLYWOOD	887	1129	-242	no					860	779	81	no			
SOUTH-W	C48-C	CELOTEX	1075	1129	-54	no					510	779	-269	no			
SOUTH-W	C48-D	CELOTEX	994	1129	-135	no					860	779	81	no			
SOUTH-W	C49	WOOD	71712	55776	15936	yes							NA	NA			
SOUTH-W	C49-A	PANELING	967	1129	-162	no					1182	779	403	no			
SOUTH-W	C49-B	PANELING	1075	1129	-54	no					967	779	188	no			
SOUTH-W	C49-C	SHEETROCK	1155	1129	26	no					967	779	188	no			
SOUTH-W	C49-D	SHEETROCK	860	1129	-269	no					779	779	0	NA		55	159

Table A1-5
WALL AND FLOOR CORE MEASUREMENTS
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Survey Unit ID	Location	Material Type	Inst.	Reading	Bkg	Net	Exceeds Limit?	Mean for		Inst.	Reading	Bkg	Net	Exceeds Limit?	Mean for				
								Survey	Unit						Survey	Unit			

- Notes:
- 1) Direct readings at locations C14 thru C58 were collected in the core hole with an E-600 with PG-2 low energy gamma detector calibrated for Cl-36. An area correction factor of 8.3 was used to convert the readings from dpm to dpm/100 cm² based on the detector area of 12 cm². The MDA for this instrument is approximately 8600 dpm/100 cm²
 - 2) All other readings were collected with an E-600 with SHP-330 detector calibrated to Cl-36. The instrument was configured to read directly in dpm/100 cm², using the detector efficiency and area correction factor determined during calibration. The MDA for this instrument is approximately 800 dpm/100 cm²
 - 3) All smears were wiped over an area of approximately 20 to 40 cm². The smears were counted with an E-600 with SHP-330. No area correction factor (other than the probe area) was used for these measurements.
 - 4) All reading were for 60 seconds.

Table A1-6
WALL CORE MEASUREMENTS SORTED BY MATERIAL TYPE
BUILDING 2

		Direct Measurements (dpm/100 cm ²)				Smear Measurements (dpm/100 cm ²)			
Survey Unit	Location ID	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Material Type	Std Dev for Material Type	
SOUTH-W	C41	CELOTEX	75198	68973	6225	yes			
SOUTH-W	C41-C	CELOTEX	1290	833	457	no			
SOUTH-W	C41-D	CELOTEX	806	833	-27	no			
SOUTH-W	C43-E	CELOTEX	1290	1129	161	no			
SOUTH-W	C43-F	CELOTEX	1102	1129	-27	no			
SOUTH-W	C46-C	CELOTEX	887	1129	-242	no			
SOUTH-W	C46-D	CELOTEX	887	1129	-242	no			
SOUTH-W	C47-C	CELOTEX	752	1129	377	no			
SOUTH-W	C47-D	CELOTEX	672	1129	-457	no			
SOUTH-W	C48-C	CELOTEX	1075	1129	54	no			
SOUTH-W	C48-D	CELOTEX	994	1129	-135	no			
SOUTH-E	C50-C	CELOTEX	833	1129	296	no			
SOUTH-E	C50-D	CELOTEX	1182	1129	53	no			
SOUTH-E	C58	CELOTEX	51543	59096	-7553	no			
SOUTH-E	C58-C	CELOTEX	1397	1129	268	no			
SOUTH-E	C58-D	CELOTEX	967	1129	-162	no			
NORTH-W	C14-C	CELOTEX	887	833	54	no			
NORTH-W	C14-D	CELOTEX	887	833	54	no			
NORTH-W	C15-E	CELOTEX	2150	833	1317	no			
NORTH-W	C15-F	CELOTEX	1451	833	618	no			
NORTH-W	C16-C	CELOTEX	1102	833	269	no			
NORTH-W	C16-D	CELOTEX	914	833	81	no			
NORTH-W	C17-E	CELOTEX	967	833	134	no			
NORTH-W	C17-F	CELOTEX	779	833	54	no			
NORTH-W	C18-C	CELOTEX	1048	833	215	no			
NORTH-W	C18-D	CELOTEX	806	833	-27	no			
NORTH-W	C19-C	CELOTEX	940	833	107	no			
NORTH-W	C19-D	CELOTEX	1048	833	215	no			
NORTH-W	C21-C	CELOTEX	860	833	27	no			
NORTH-W	C21-D	CELOTEX	924	833	161	no			

Table A1-6
WALL CORE MEASUREMENTS SORTED BY MATERIAL TYPE
BUILDING 2

		Direct Measurements (dpm/100 cm ²)				Smear Measurements (dpm/100 cm ²)			
Survey Unit	Location ID	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for		Std Dev
							Material Type	Material Type	
NORTH-W	C22-C	CELOTEX	1048	833	215	no	806	806	0 NA
NORTH-W	C22-D	CELOTEX	914	833	81	no	806	806	0 NA
NORTH-E	C35-C	CELOTEX	1209	833	376	no	698	806	-108 no
NORTH-E	C35-D	CELOTEX	994	833	161	no	698	806	108 no
NORTH-E	C38-C	CELOTEX	1048	833	215	no	887	806	81 no
NORTH-E	C38-D	CELOTEX	967	833	134	no	887	806	81 no
NORTH-E	C39-E	CELOTEX	1075	833	242	no	967	806	161 no
NORTH-E	C39-F	CELOTEX	752	833	81	no	860	806	54 no
NORTH-E	C40-E	CELOTEX	698	833	-135	no	967	806	161 no
NORTH-E	C40-F	CELOTEX	645	833	-188	no	44.6	1596.4	4.1 144.5
NORTH-N	C23	CONCRETE	84494	58432	26062	yes	940	806	134 no
NORTH-N	C25	CONCRETE	81921	58432	23489	yes	1021	806	215 no
NORTH-N	C26	CONCRETE	86652	58432	28220	yes	698	806	-108 no
NORTH-N	C28	CONCRETE	82794	58432	34362	yes	591	806	215 no
NORTH-N	C31	CONCRETE	79680	58432	21248	yes	1129	806	323 no
NORTH-E	C32	CONCRETE	91134	78518	12616	yes		NA	NA
NORTH-E	C34	CONCRETE	111801	78518	33283	yes		NA	NA
NORTH-E	C36	CONCRETE	87233	78518	8715	yes	860	806	54 no
NORTH-E	C37	CONCRETE	76360	78518	-2158	no	20648.6	12092.4	672 806 -134 no 29.9 172.9
SOUTH-W	C46	INSULATION	78435	55610	22825	yes		NA	NA
SOUTH-W	C47	INSULATION	74285	55610	18675	yes		NA	NA
SOUTH-W	C48	INSULATION	72625	55195	17430	yes		NA	NA
SOUTH-E	C50	INSULATION	82668	55776	26892	yes		NA	NA
SOUTH-E	C51	INSULATION	72625	63080	9545	yes		NA	NA
SOUTH-E	C52	INSULATION	71214	63080	8134	yes		NA	NA
SOUTH-E	C53	INSULATION	62167	63080	-913	no		NA	NA
SOUTH-E	C54	INSULATION	76194	64989	11205	yes		NA	NA
SOUTH-E	C55	INSULATION	67645	64989	2666	no	12938.8	9224.4	NA NA 8.0
SOUTH-E	C56	MASONITE	42662	59096	-16434	no		NA	NA
NORTH-W	C15-C	MASONITE	915	833	82	no	914	887	127 no

Table A1-6
WALL CORE MEASUREMENTS SORTED BY MATERIAL TYPE
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location		Survey Unit	ID	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Material Type		Std Dev	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Mean for Material Type		Std Dev
									Material Type	Material Type							Material Type	Material Type	
NORTH-W	C15-D	MASONITE			1102	833	269	no	-5361.0	9590.0			1021	887	134	no	53.7		70.9
SOUTH-W	C41-A	PANELING			725	833	-108	no					779	806	27	no			
SOUTH-W	C41-B	PANELING			994	833	161	no					887	806	81	no			
SOUTH-W	C43-A	PANELING			1102	1129	-27	no					914	779	135	no			
SOUTH-W	C43-B	PANELING			806	1129	-323	no					887	779	108	no			
SOUTH-W	C44-A	PANELING			698	1129	-431	no					752	779	27	no			
SOUTH-W	C45-A	PANELING			618	1129	-511	no					940	779	161	no			
SOUTH-W	C45-B	PANELING			672	1129	-457	no					1021	779	242	no			
SOUTH-W	C46-A	PANELING			914	1129	-215	no					887	779	108	no			
SOUTH-W	C46-B	PANELING			807	1129	-322	no					940	779	161	no			
SOUTH-W	C47-A	PANELING			914	1129	-215	no					914	779	135	no			
SOUTH-W	C47-B	PANELING			779	1129	-350	no					887	779	108	no			
SOUTH-W	C49-A	PANELING			967	1129	-162	no					1182	779	403	no			
SOUTH-W	C49-B	PANELING			1075	1129	-54	no					967	779	188	no			
SOUTH-E	C50-A	PANELING			1021	1129	-108	no					779	779	0	NA			
SOUTH-E	C50-B	PANELING			1209	1129	-80	no					725	779	54	no			
SOUTH-E	C51-A	PANELING			1129	1129	0	no					752	779	-27	no			
SOUTH-E	C51-B	PANELING			1036	1129	-93	no					940	779	161	no			
SOUTH-E	C52-A	PANELING			672	1129	-457	no					940	779	161	no			
SOUTH-E	C52-B	PANELING			914	1129	-215	no					860	779	81	no			
SOUTH-E	C53-A	PANELING			1048	1129	-81	no					725	779	-54	no			
SOUTH-E	C53-B	PANELING			940	1129	-189	no					1129	779	350	no			
SOUTH-E	C54-A	PANELING			1048	1129	-81	no					967	779	188	no			
SOUTH-E	C54-B	PANELING			984	1129	-135	no					1129	779	350	no			
SOUTH-E	C55-A	PANELING			1371	1129	242	no					1102	779	323	no			
SOUTH-E	C55-B	PANELING			1048	1129	-81	no					940	779	161	no			
SOUTH-E	C56-A	PANELING			860	1129	-269	no					887	779	108	no			
SOUTH-E	C56-B	PANELING			940	1129	-189	no					806	779	27	no			
SOUTH-E	C57-A	PANELING			779	1129	-350	no					591	779	-188	no			
SOUTH-E	C57-B	PANELING			914	1129	-215	no					752	779	27	no			

Table A1-6

page 4 of 8

Table A1-6
WALL CORE MEASUREMENTS SORTED BY MATERIAL TYPE
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location			Mean for				Std Dev			Mean for			Std Dev						
Survey Unit	ID	Material	Type	Inst.	Reading	Bkg	Net	Limit?	Exceeds	Material	Type	Inst.	Reading	Bkg	Net	Limit?	Exceeds	Material	Type
NORTH-N	C26-B	PLYWOOD		833	833	833	0	no					1075	806	269	no			
NORTH-N	C27-A	PLYWOOD		833	833	833	0	no					833	806	27	no			
NORTH-N	C27-B	PLYWOOD		591	833	833	-242	no					994	806	188	no			
NORTH-N	C28-A	PLYWOOD		1075	833	833	242	no					537	806	269	no			
NORTH-N	C28-B	PLYWOOD		860	833	833	27	no					860	806	54	no			
NORTH-N	C29-A	PLYWOOD		591	833	833	-242	no					725	806	-81	no			
NORTH-N	C29-B	PLYWOOD		1021	833	833	188	no					698	806	-108	no			
NORTH-N	C29-C	PLYWOOD		806	833	833	-27	no					672	806	134	no			
NORTH-N	C29-D	PLYWOOD		967	833	833	134	no					725	806	-81	no			
NORTH-N	C29-E	PLYWOOD		1344	1075	1075	269	no					1021	806	215	no			
NORTH-N	C29-F	PLYWOOD		779	1075	1075	-296	no					1048	806	242	no			
NORTH-N	C30-A	PLYWOOD		779	833	833	-54	no					887	806	81	no			
NORTH-N	C30-B	PLYWOOD		806	833	833	-27	no					698	806	-108	no			
NORTH-N	C31-A	PLYWOOD		806	833	833	-27	no					898	806	108	no			
NORTH-N	C31-B	PLYWOOD		779	833	833	-54	no					833	806	27	no			
NORTH-E	C32-A	PLYWOOD		1021	833	833	188	no					833	806	27	no			
NORTH-E	C32-B	PLYWOOD		698	833	833	-135	no					914	806	108	no			
NORTH-E	C33-A	PLYWOOD		779	833	833	-54	no					672	806	134	no			
NORTH-E	C33-B	PLYWOOD		725	833	833	-108	no					618	806	-188	no			
NORTH-E	C34-A	PLYWOOD		1209	833	833	376	no					672	806	134	no			
NORTH-E	C34-B	PLYWOOD		860	833	833	27	no					1048	806	242	no			
NORTH-E	C39-C	PLYWOOD		1774	833	833	941	no					833	806	27	no			
NORTH-E	C39-D	PLYWOOD		779	833	833	-54	no					967	806	161	no			
NORTH-E	C40-C	PLYWOOD		1182	833	833	349	no					719	806	27	no			
NORTH-E	C40-D	PLYWOOD		1075	833	833	242	no					994	806	188	no			
SOUTH-W	C42-A	SHEETROCK		672	833	833	-161	no					645	806	-161	no			
SOUTH-W	C42-B	SHEETROCK		1048	833	833	215	no					457	806	-349	no			
SOUTH-W	C44-C	SHEETROCK		1075	1129	1129	-54	no					753	779	-26	no			
SOUTH-W	C44-D	SHEETROCK		860	1129	1129	-269	no					591	779	-188	no			
SOUTH-W	C45-C	SHEETROCK		1209	1129	1129	80	no					1104	779	325	no			

page 3 of 8

Table A1-6

WALL CORE MEASUREMENTS SORTED BY MATERIAL TYPE

BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)									
Location		Inst.	Material Type	Reading	Bkg	Net	Exceeds Limit?	Mean for		Inst.	Material Type	Reading	Bkg	Net	Exceeds Limit?	Mean for		Material Type	Std Dev
Survey Unit	ID							Material	Type		Material	Type				Material	Type		
SOUTH-W	C45-D		SHEETROCK	940	1129	-189	no					752	779	-27	no				
SOUTH-W	C49-C		SHEETROCK	1155	1129	26	no					967	779	188	no				
SOUTH-W	C49-D		SHEETROCK	860	1129	-269	no					779	779	0	NA				
SOUTH-E	C51-C		SHEETROCK	1048	1129	-81	no					752	779	-27	no				
SOUTH-E	C51-D		SHEETROCK	1236	1129	107	no					833	779	54	no				
SOUTH-E	C52-C		SHEETROCK	1344	1129	215	no					1048	779	269	no				
SOUTH-E	C52-D		SHEETROCK	1075	1129	-54	no					1371	779	592	no				
SOUTH-E	C53-C		SHEETROCK	1048	1129	-81	no					725	779	-54	no				
SOUTH-E	C53-D		SHEETROCK	887	1129	-242	no					806	779	27	no				
SOUTH-E	C54-C		SHEETROCK	940	1129	-189	no					806	779	27	no				
SOUTH-E	C54-D		SHEETROCK	1075	1129	-54	no					1021	779	242	no				
SOUTH-E	C55-C		SHEETROCK	914	1129	-215	no					887	779	108	no				
SOUTH-E	C55-D		SHEETROCK	1075	1129	-54	no					564	779	-215	no				
SOUTH-E	C57-C		SHEETROCK	860	1129	-269	no					833	779	54	no				
SOUTH-E	C57-D		SHEETROCK	1075	1129	-54	no					887	779	108	no				
NORTH-W	C15-A		SHEETROCK	914	833	81	no					887	887	0	NA				
NORTH-W	C15-B		SHEETROCK	1129	833	296	no					1129	887	242	no				
NORTH-W	C16-A		SHEETROCK	1290	833	467	no					1155	887	268	no				
NORTH-W	C16-B		SHEETROCK	1344	833	511	no					1182	887	295	no				
NORTH-W	C17-C		SHEETROCK	1270	833	437	no					833	806	27	no				
NORTH-W	C17-D		SHEETROCK	1102	833	269	no					725	806	-81	no				
NORTH-W	C18-A		SHEETROCK	698	833	-135	no					752	887	-135	no				
NORTH-W	C18-B		SHEETROCK	914	833	81	no					806	887	-81	no				
NORTH-W	C19-A		SHEETROCK	779	833	-54	no					914	806	108	no				
NORTH-W	C19-B		SHEETROCK	752	833	-81	no					645	806	-161	no				
NORTH-W	C20-A		SHEETROCK	812	833	-21	no					483	806	323	no				
NORTH-W	C20-B		SHEETROCK	940	833	107	no					940	806	134	no				
NORTH-W	C21-A		SHEETROCK	914	833	81	no					887	806	87	no				
NORTH-W	C21-B		SHEETROCK	725	833	-108	no					940	806	134	no				
NORTH-W	C22-A		SHEETROCK	1048	833	215	no					806	806	0	NA				

Table A1-6
WALL CORE MEASUREMENTS SORTED BY MATERIAL TYPE
BUILDING 2

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)											
Location			Inst.			Mean for				Std Dev			Exceeds			Mean for			Std Dev		
Survey Unit	ID	Material Type	Reading	Bkg	Net	Limit?	Material Type	Material Type	Material Type	Material Type	Inst.	Reading	Bkg	Net	Limit?	Material Type	Material Type	Material Type	Material Type		
NORTH-W	C22-B	SHEETROCK	914	833	81	no						698	806	-108	no						
NORTH-N	C23-C	SHEETROCK	779	833	54	no						994	806	188	no						
NORTH-N	C23-D	SHEETROCK	967	833	134	no						860	806	54	no						
NORTH-N	C24	SHEETROCK	58847	58432	415	no						697	806	-109	no						
NORTH-N	C25-C	SHEETROCK	672	833	-161	no						672	806	-134	no						
NORTH-N	C25-D	SHEETROCK	833	833	0	no						833	806	27	no						
NORTH-E	C32-C	SHEETROCK	833	833	0	no						816	806	10	no						
NORTH-E	C32-D	SHEETROCK	779	833	54	no						591	806	215	no						
NORTH-E	C33-C	SHEETROCK	698	833	-135	no						698	806	-108	no						
NORTH-E	C33-D	SHEETROCK	833	833	0	no						403	806	403	no						
NORTH-E	C34-C	SHEETROCK	698	833	-135	no						752	806	-54	no						
NORTH-E	C34-D	SHEETROCK	806	833	27	no	12.9	195.3				967	806	161	no	16.3	188.7				
SOUTH-W	C42	WOOD	74368	68973	5395	yes								NA	NA						
SOUTH-W	C43	WOOD	70467	57768	12699	yes								NA	NA						
SOUTH-W	C44	WOOD	73704	63080	10624	yes								NA	NA						
SOUTH-W	C45	WOOD	67645	59096	8549	yes								NA	NA						
SOUTH-W	C49	WOOD	71712	55776	15936	yes								NA	NA						
SOUTH-E	C57	WOOD	64491	59096	5395	yes								NA	NA						
SOUTH-E	C57-E	WOOD	1155	1129	26	no						833	779	54	no						
SOUTH-E	C57-F	WOOD	914	1129	215	no						645	779	-134	no						
NORTH-W	C14	WOOD	65072	58847	6225	yes						672	806	-134	no						
NORTH-W	C15	WOOD	88893	58847	30046	yes						967	806	161	no						
NORTH-W	C16	WOOD	64076	58847	5229	yes								NA	NA						
NORTH-W	C17	WOOD	68060	65321	2739	no								NA	NA						
NORTH-W	C18	WOOD	83415	65321	18094	yes								NA	NA						
NORTH-W	C19	WOOD	74285	65321	8964	yes						940	806	-134	no						
NORTH-W	C20	WOOD	65902	65321	581	no						645	806	-161	no						
NORTH-W	C21	WOOD	71214	65321	5893	yes								NA	NA						
NORTH-W	C22	WOOD	69222	65321	3901	no						779	806	-27	no						
NORTH-W	C27	WOOD	77107	58432	18675	yes						698	806	108	no						

**Table A1-6
REQUIREMENTS
BUILDING 2**

Direct Measurements (dpm/100 cm ²)										Smear Measurements (dpm/100 cm ²)						
Location		Mean for				Mean for				Std Dev		Mean for		Std Dev		
Survey Unit ID	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Material Type	Inst. Reading	Bkg	Net	Exceeds Limit?	Material Type
NORTH-N C29	WOOD	65902	58432	7470	yes											
NORTH-N C30	WOOD	68724	58432	10292	yes			860	806	54	no					
NORTH-E C33	WOOD	73621	78518	-4897	no											
NORTH-E C35	WOOD	64491	78518	-14027	no			672	806	134	no					
NORTH-E C38	WOOD	66898	54199	12699	yes											
NORTH-E C39	WOOD	64242	54199	10043	yes											
NORTH-E C40	WOOD	70633	54199	16434	yes	7870.8	8680.7	779	806	-27	no				-12.9	76.0

Notes:

- 1) Direct readings at locations C14 thru C58 were collected in the core hole with an E-600 with PG-2 low energy gamma detector calibrated for CI-36. An area correction factor of 8.3 was used to convert the readings from dpm to dpm/100 cm² based on the detector area of 12 cm². The MDA for this instrument is approximately 8600 dpm/100 cm²
- 2) All other readings were collected with an E-600 with SHP-330 detector calibrated to CI-36. The instrument was configured to read directly in dpm/100 cm², using the detector efficiency and area correction factor determined during calibration. The MDA for this instrument is approximately 800 dpm/100 cm²
- 3) All smears were wiped over an area of approximately 20 to 40 cm². The smears were counted with an E-600 with SHP-330. No area correction factor (other than the probe area) was used for these measurements.
- 4) All reading were for 60 seconds.

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and the role of the accounting department in ensuring the integrity of the financial statements. It also highlights the need for regular audits and the importance of transparency in financial reporting.


2. The second part of the document focuses on the implementation of internal controls to prevent fraud and ensure the accuracy of financial data. It outlines the key components of a robust internal control system, including segregation of duties, authorization procedures, and regular monitoring and evaluation.

3. The third part of the document addresses the challenges faced by organizations in managing their financial resources effectively. It discusses the importance of budgeting, forecasting, and cost management, and provides practical advice on how to overcome common financial management challenges.

4. The fourth part of the document explores the role of technology in modern accounting and finance. It discusses the benefits of using accounting software and the importance of staying up-to-date with the latest technological advancements in the field.


5. The fifth part of the document discusses the importance of ethical considerations in financial reporting and the role of the accounting profession in promoting ethical behavior. It highlights the need for transparency, honesty, and integrity in all financial transactions and the importance of adhering to professional standards and regulations.

6. The sixth part of the document provides a summary of the key points discussed in the document and offers recommendations for organizations looking to improve their financial management practices. It emphasizes the importance of a proactive approach to financial management and the need for continuous improvement and learning.




FLOOR PLAN


LEGEND:


PRESSURIZED ION CHAMBER (PIC) MEASUREMENT LOCATION
 MEASUREMENT LOCATION NUMBER
 MEASUREMENT LOCATION


RADON DECAY PRODUCT CONCENTRATION (RDC) MEASUREMENT LOCATION



PROJECT OFFICE GRAND JUNCTION PROJECTS OFFICE GRAND JUNCTION, CO		U.S. DEPARTMENT OF ENERGY GRAND JUNCTION PROJECTS OFFICE, COLORADO	
PROJECT NO. 		COMPLETION REPORTS GJPORAP	
		BUILDING 12 - FIGURE A1-1 PIC and RDC Measurement Location	
PROJECT NO. FAS-031-0002-00-000		SHEET 1 OF 5	
DRAWING NO. 10000700.DWG			



LEGEND:



ROOM NUMBER AND ELEVATION LABEL



PRESSURIZED ION CHAMBER (PIC) MEASUREMENT LOCATION
MEASUREMENT LOCATION NUMBER
MEASUREMENT LOCATION



RADON DECAY PRODUCT CONCENTRATION (RDC) MEASUREMENT LOCATION

PROJECT LOCATION
GRAND JUNCTION
PROJECTS OFFICE
GRAND JUNCTION, CO

REVISIONS
DATE
BY
APPROVED
DATE
BY
RUST Rust Geotech
10000600.DWG

U.S. DEPARTMENT OF ENERGY
GRAND JUNCTION PROJECTS OFFICE, COLORADO




GJPORAP




BUILDING 2 - FIGURE A1-2
PIC and RDC MEASUREMENT
LOCATIONS

PROJECT NO. FAS-031-0002-00-000
DRAWING NO. 10000600.DWG




2


5





RUST Rust Geotech
A W&A Technologies Company





LEGEND:

1 ROOM NUMBER AND ELEVATION LABEL

C33 CORE SAMPLE LOCATION
CORE LOCATION NUMBER
CORE LOCATION

PROJECT LOCATION GRAND JUNCTION PROJECTS OFFICE GRAND JUNCTION, CO		U.S. DEPARTMENT OF ENERGY GRAND JUNCTION PROJECTS OFFICE, COLORADO	
IDENTIFICATION / VERIFICATION DATE TEST YEAR TESTED ELEVATION LOCATION COMMENTS		GJPORAP BUILDING 2 - FIGURE A1-5 CORE LOCATIONS FLOORS AND WALLS	
PROJECT NO. FAS-031-0002-00-000 DRAWING NO. 10000600.DWG		SHEET 5 OF 5	

RUST Rust Geotech
A TRC Technology Company

Appendix 2

Results of the Landauer Radon Track Etch Measurements

RUST GEOTECH INC.

MEMO TO: R. Morris
FROM: C. Miracle *cm*
DATE: February 13, 1996
SUBJECT: *D. Miracle*
RBC results for GJPO Building 46 (copy center)

The Landauer Track-etch cup results for the copy center room and the telecommunications room both measured at less than .0050 Working Levels. The readings are "less than indicated value" due to the low number of tracks on the film. Therefore, the measurements have determined that there is no significant radon within the structure. The third background measurement taken in the "log cabin" portion of building 12 is also less than .0050 Working Levels.

If you have any further questions regarding the measurements taken, please contact me at 6291.

/cm

ALPHA-TRACK MEASUREMENT SUMMARY SHEET

Location Number: /	Address: GJPO
Other information: Telecommunications Room	
Start Date: 11/3/96	End Date: 2/2/96
Number of Days:	Batch Number: 40

$$\frac{\text{Exposure (pCi/L/days)}}{\text{Number of Days}} = \text{Radon Concentration (pCi/L)}$$

$$\frac{\text{Radon Concentration}}{200} = \text{RDC (Working Level)}$$

Detector Number	Tracks per mm ²	Exposure (pCi/L/days)	Radon Concentration (pCi/L)	RDC (working level)
3892176	0.4	30.0	< 1.00	< 0.0050
3892289	0.0	30.0	< 1.00	< 0.0050
3892274	0.2	30.0	< 1.00	< 0.0050
Average				< 0.0050

CRITERIA USED FOR PLACEMENT					
Placement	Pickup		Placement	Pickup	
N/A		Basement	✓		Detector facing room
N/A		Area of interior removal	✓		At least 18 inches from floor
✓		Lowest habitable level	✓		Serial numbers match pouch
N/A		Highest interior gamma exposure	✓		Detectors away from doors, vents, heat, window or sunlight
✓		Least ventilated area			Detectors are not damaged at pickup
		Other			

Explanation of deviation from placement criteria:

Technician: CM	Verified: CM
----------------	--------------

ALPHA-TRACK MEASUREMENT SUMMARY SHEET

Location Number: <u>3</u>	Address: <u>GSPC</u>
Other information: <u>Copy Center</u>	
Start Date: <u>11/3/96</u>	End Date: <u>2/2/96</u>
Number of Days: <u>212/96</u>	Batch Number: <u>40</u>

$$\frac{\text{Exposure (pCi/L/days)}}{\text{Number of Days}} = \text{Radon Concentration (pCi/L)}$$

$$\frac{\text{Radon Concentration}}{200} = \text{RDC (Working Level)}$$

Detector Number	Tracks per mm ²	Exposure (pCi/L/days)	Radon Concentration (pCi/L)	RDC (working level)
3892268	0.6	30.0	< 1.00	< .0050
3892280	0.0	30.0	< 1.00	< .0050
3892159	0.1	30.0	< 1.00	< .0050
Average				< .0050

CRITERIA USED FOR PLACEMENT					
Placement	Pickup		Placement	Pickup	
N/A		Basement	✓		Detector facing room
N/A		Area of interior removal	✓		At least 18 inches from floor
✓		Lowest habitable level	✓		Serial numbers match pouch
N/A		Highest interior gamma exposure	✓		Detectors away from doors, vents, heat, window or sunlight
✓		Least ventilated area			Detectors are not damaged at pickup
		Other			

Explanation of deviation from placement criteria:

Technician: <u>Am</u>	Verified: <u>Am</u>
-----------------------	---------------------

ALPHA-TRACK MEASUREMENT SUMMARY SHEET

Location Number: 2	Address: GJPO
Other information: Log Cabin - Background	
Start Date: 1/3/96	End Date: 2/2/96
Number of Days: 2/2/96	Batch Number: 40

$$\frac{\text{Exposure (pCi/L/days)}}{\text{Number of Days}} = \text{Radon Concentration (pCi/L)}$$

$$\frac{\text{Radon Concentration}}{200} = \text{RDC (Working Level)}$$

Detector Number	Tracks per mm ²	Exposure (pCi/L/days)	Radon Concentration (pCi/L)	RDC (working level)
3851473	0.0	30.0	< 1.00	< .0050
3892206	0.0	30.0	< 1.00	< .0050
3892264	0.0	30.0	< 1.00	< .0050
Average				< .0050

CRITERIA USED FOR PLACEMENT					
Placement	Pickup		Placement	Pickup	
N/A		Basement	✓		Detector facing room
N/A		Area of interior removal	✓		At least 18 inches from floor
✓		Lowest habitable level	✓		Serial numbers match pouch
N/A		Highest interior gamma exposure	✓		Detectors away from doors, vents, heat, window or sunlight
✓		Least ventilated area			Detectors are not damaged at pickup
		Other			

Explanation of deviation from placement criteria:

Technician: C.M.	Verified: C.M.
------------------	----------------

SEND REPORT & 5 1/4" DISKETTE
TO NAME & ADDRESS ON SHIPPING
DOCUMENT.

Radon Monitoring Report


LANDAUER

Landauer, Inc. 2 Science Road Glenview, Illinois 60425-1586
Telephone: (708) 755-7911 Facsimile: (708) 755-7016

Acci. No. 0400051


Detector Number	Detector Type	Starting Date	Ending Date	Field Data / Comments	Exposure pCi/d-days	Avg. Radon Conc. pCi/l	GROSS COUNT	NET COUNT	AVG NET TRACKS/ MM SQ.	LOT NO.
3851473	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	36	0	0.0	N1111
3892159	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	41	2	0.1	R1196
3892176	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	46	7	0.4	R1196
3892206	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	27	0	0.0	R1196
3892264	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	35	0	0.0	R1196
3892268	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	49	10	0.6	R1196
3892274	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	42	3	0.2	R1196
3892280	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	38	0	0.0	R1196
3892289	DRN	03-JAN-96	02-FEB-96	* - LESS THAN INDICATED VALUE	* 30.0	* 1.0	38	0	0.0	R1196

Q.C. Release MAB	Process No. A18147	Report Date 08-FEB-96	Date Received 05-FEB-96
---------------------	-----------------------	--------------------------	----------------------------



Appendix 3

DQOs, Use Scenarios, and Affected Area Designation of GJPORAP Building 2 Characterization




**DQOs, Use Scenarios, and Affected Area Designation for
GJPORAP Building 2 Characterization**

Rev 1.
April 30, 1996

Rust Geotech, Inc.

Prepared by Robert Morris and David Thorne



number the equations

Executive Summary

This document defines the Data Quality Objectives (DQO) and future use assumptions necessary for predicting the public dose associated with future use of Building 2 as part of the DOE Grand Junction Projects Office Remedial Action Program (GJPORAP). A formal definition of the "affected areas," which is needed for design of the sampling plan, is also included.

The DQO states that the building may be released for unrestricted use if the predicted dose (excluding radon) to a member of the public occupying the building is less than 15 mrem in a typical year, and less than 30 mrem in the year when demolition occurs. The required confidence level needed for sampling to establish the future dose is set at the 95% level. In keeping with proposed EPA guidance (FR Vol. 59, No. 246, p. 66415) the dose criteria do not include the contribution from indoor radon, either from naturally occurring radium-bearing soils or fill material situated beneath or near the building. However the radon concentration in Building 2 must not exceed the level recommended to the public by the EPA and Centers for Disease Control in "A Citizen's Guide to Radon" (EPA 402-K92-001), which is 4 pCi/L.

Future use of Building 2 is expected to be the same as its current use: an office facility occupied for eight hours per day, five days per week. Some day the building will be demolished. Exposure to potentially radioactive dust on surfaces that are currently inaccessible may occur, along with larger doses compared with normal occupancy. Demolition is assumed to take 80 hours to complete. No beneficial use of the building debris is expected; all will go to a sanitary landfill.

The "affected area" of Building 2 is the exposed surfaces (including drain lines) that existed during the era of its use as a locker and shower facility for uranium workers. Subsequent construction on the building, which includes interior walls, wood paneling, and floor coverings installed over a leveling slab are unaffected.

DQOs, Use Scenarios, and Affected Area Designation for GJPORAP Building 2 Characterization

This document defines the Data Quality Objectives (DQO) and future use assumptions necessary for predicting the public dose associated with future use of Building 2 as part of the DOE Grand Junction Projects Office Remedial Action Program (GJPORAP). A formal definition of the "affected areas," which is needed for design of the sampling plan, is also included.

Part I. DATA QUALITY OBJECTIVES

The Data Quality Objectives (DQO) process (EPA 1995) includes seven steps to define the data needed for decision-making. In a separate document (Morris 1996) the DQOs for Pipe Explorer operations in Building 2 were specified.

DQO Step 1: State the Problem

Data is needed to define the contaminant level of alpha, and beta/gamma emitting radionuclides, associated with prior operations in Building 2. We assume that "yellowcake" (nominally U_3O_8) is the primary radiological contaminant, although uranium mill tailings may also be involved. The dose rate and radon concentrations also need to be evaluated to find out the dose impact of the existing environment in Building 2.

The contaminant level data will be used in a model to predict the radiation dose likely to occur if the contaminants are left in place. Measurements will include dose rate, radon concentration, and surface contamination on accessible and inaccessible surfaces.

The data and resulting dose model will be incorporated into a report to be issued by the GJPORAP program at the end of February 1996. Therefore, the data report should be submitted to the project health physicist by February 15, 1996.

DQO Step 2: Identify the Decision

Building 2 may be released from radiological control for unrestricted use if the following criteria are met:

Criteria 1: The best estimate of annual Total Effective Dose Equivalent (TEDE) above background (not including dose from naturally-occurring or DOE-enhanced radon and short-lived progeny) to a member of the public under the most likely use scenario for a typical year may not exceed 15 mrem/year above background.

Criteria 2: The best estimate of the annual TEDE above background (not including dose from naturally-occurring or DOE-enhanced radon and short-lived progeny) to a member of the public during a full year that includes building demolition may not exceed 30 mrem/year above background.

Criteria 3: The concentration of radon in the building should be less than the EPA guide value of 4 pCi/L.¹

Criteria 4: For surface contamination on currently accessible surfaces²:

Removable beta contamination should be reduced to levels consistent with those in NRC RegGuide 1.86³.

Total beta contamination should be reduced to levels that are ALARA. The process used to establish the ALARA level will be documented in the closeout report for the building for those normally

¹ In keeping with proposed EPA guidance (FR Vol. 59, No. 246, p. 66415) the dose criteria do not include the contribution from indoor radon, either from naturally occurring radium-bearing soils or fill material situated beneath or near the building. However the radon concentration in Building 2 must not exceed the level recommended to the public by the EPA and Centers for Disease Control in "A Citizen's Guide to Radon" (EPA 402-K92-001), which is 4 pCi/L.

²Surface contamination will be assessed by measuring high energy beta and gamma ray emissions. It is recognized that the radionuclides found in yellowcake and uranium mill tailings also emit alpha radiation, however in most cases the proportions of alpha emissions to beta emissions is near unity and the alpha and beta limits are to be applied separately. Since beta emissions are more readily detected than alpha emissions, measurement of only the beta signal is assumed to be sufficient to characterize the hazard.

³The surface contamination guidelines for uranium in NRC RegGuide 1.86 are the same as those published by DOE in all current regulatory documents.

and currently accessible surfaces exceeding the applicable value in NRC RegGuide 1.86.

In a year of normal occupancy the contaminant levels on inaccessible surfaces and within drainage pipes will not contribute appreciably to dose. In the year of demolition, a short duration exposure to the inaccessible contaminants will occur. The contribution to dose from this pathway will be modeled.

Other areas of Building 2 are of potential interest in future dose scenarios, but we assume that remedial action will be taken to correct these conditions before release. For example, undocumented spot checks of the soil next to the building foundation suggests uranium mill tailings contamination may need to be removed. Prior surveys have shown surface contamination in attic insulation and on wooden structural members. This insulation may need to be removed, and wood may need to be decontaminated. Surveys confirming the adequacy of this cleanup should be performed before release of the building.

DQO Step 3: Identify Inputs

Inputs include the following:

Assumptions for RESRAD-BUILD (ANL/EAD/LD-3), or a similar dosimetry model.

Dose conversion factors and specific activity factors for yellowcake and uranium mill tailings obtained from Rust technical basis documents for internal dosimetry

Future use assumptions for the building. The assumptions for future use of Building 2 are in Part II of this document.

Data from the survey and reference units listed in Table 1.

Laboratory analysis of a high-activity sample to confirm the assumptions regarding radionuclides associated with Building 2.

Background levels of the quantities of concern are normally subtracted from the gross level in the survey. In most cases the background is established by measuring the same phenomenon in a reference area. However, sometimes long-term estimates of the

background may be better, for example area TLD data may provide a better estimate when averaged over a quarter or year. When it is judged that long-term average estimates of background are more reliable, these may be used instead of or in addition to the point measurement of background in the reference area. Since radon levels will be compared with a gross screening level recommended by the EPA, no background subtraction will be used.

Surface contamination background levels are generally assumed to be near zero. However, contamination survey meters are affected by ambient beta and gamma ray background and consequently instrument background will be subtracted.

Besides the external dose rate data set obtained with the PIC measurements, an equivalent data set has been historically measured at GJPO as part of the area TLD program. This data set may be used to supplement or confirm the PIC measurements.

Similarly, a 1989 nationwide survey of radon concentration in DOE buildings may have included Building 2. If so, that information may be used to supplement the data collected in this characterization effort.

Calibration of the beta survey instruments will be done using NIST-traceable Chlorine-36 sources, according to a written procedure. Chlorine-36 is chosen because it has an intermediate beta energy that will conservatively approximate the energy of the beta emissions from the suspected radionuclides.

DQO Step 4: Define the Boundaries

Affected Area Designation

By defining what portions of a facility have been affected by prior operations, the sampling intensity for an area can be established. Here the affected area is influenced both by location and by date of construction. The originally exposed surfaces on the north end of the building are affected. The originally exposed surfaces in the adjacent area to the south are affected by proximity. However, the building has been remodeled several times since that original use. New walls, and wall or floor coverings are not expected to be affected by the original operations, consequently these will be designated as unaffected.

Survey Units

The areas of the building will be divided into survey units. The survey units will be broadly classified as dose rate survey units, radon survey units, and contamination survey units. A summary of the survey units is provided in Table 1.

Dose rate survey units

Building 2 will be divided into two logical dose rate survey units: 1) the telecommunications center to the north and; 2) the copy center and surrounding offices. A reference building will also be used statistically to compare the dose rate survey data. Building 12, "Log Cabin" will be used for this purpose and will be the reference survey unit for dose rate surveys.

Radon survey units

Only two logical survey units exist in Building 2: the telecommunications center and the balance of the building. These are logically separate because they are separately ventilated, and ventilation is strongly associated with radon decay product concentration. Other possible survey units, such as the attic are discounted because they are not routinely occupied and any elevated radon concentration would be more easily shown by elevated surface contamination levels in the attic. Building 12, "Log Cabin" will serve as the reference building for radon measurements since it is considered unaffected and is built on original soils.

Surface contamination survey units

Building 2 will be divided into two areas: 1) the telecommunications center (i.e., historical mill worker change room; and 2) the southern area of the building (i.e., copy center and offices). Each area will contain several survey units for surface activity surveys. In addition, the survey units are different for accessible (i.e., new walls and accessible old walls) and inaccessible surfaces (i.e., old covered walls).

Accessible surfaces - the telecommunications center will consist of two units: 1) all new walls are one survey unit; and 2) the old walls are the other survey unit. The southern portion of Building 2 has two survey units consisting of all new walls as one unit and old walls as the other unit.

Inaccessible surfaces - the telecommunications center will consist of four units: 1) the north wall; 2) the east wall; 3) the west wall; and 4) the floor. The southern portion of Building 2 has three survey units: 1) the floor; 2) the east wall and half of the south wall; and 3) the west wall and half of the south wall.

Table 1. Sampling Units for Building 2 and Reference Area

Measurement Type	Total Sampling Units	Building 12 "Log Cabin"	Building 2 (South End)	Building 2 (North End)
PIC	3	all one unit	all one unit	all one unit
Radon	3	all one unit	all one unit	all one unit
Accessible Surfaces	4	none	old walls one unit	old walls one unit
			new walls one unit	new walls one unit
Inaccessible Surfaces	7	none	floor one unit	floor one unit
			walls two units	walls three units

DQO Step 5: Develop a Decision Rule

The dose rate measurements from the reference building will be compared with the Building 2 data using the Wilcoxon Rank Sum (WRS) test and the Quantile test. Both are nonparametric statistical tests (NUREG-1505).

For the WRS test, the total number of required samples from the reference area and survey units combined is (NUREG -1505):

$$N = \frac{(Z_{1-\alpha/2} + Z_{1-\beta})^2}{12c(1-c)(P_r - 0.5)^2} \quad (1)$$

where:

- α = specified Type I error rate
- β = specified Type II error rate
- $Z_{1-\alpha/2}$ = 100(1 - $\alpha/2$) percentile of the standard normal distribution function
- $Z_{1-\beta}$ = 100(1 - β) percentile of the standard normal distribution function
- c = proportion of samples to be collected in the reference area

The proportion, c , of measurements to be taken from the reference area is determined from:

$$c = \frac{v^2 h^{1/2}}{v^2 h^{1/2} + 1} \quad (2)$$

where:

- h = number of survey units being compared with the given reference area
- v = $\sigma_{\text{reference}}/\sigma_{\text{survey}}$, the ratio of the standard deviation of the measurements in the reference area to the standard deviation of the measurements in the survey units.

The value of v must be estimated from previous samples or expert opinion. Lacking any information to the contrary, assuming that $v = 1$ is reasonable (NUREG-1505).

Once N is calculated, then $m = c*N$ samples will be taken from the reference area, and $n = (1 - c)*N$ samples will be taken from each survey unit being compared with it.

For the WRS test, the specification of the criteria is based on the amount of the shift, Δ , toward higher values in the survey unit that is important to detect compared with the reference distribution. The criterion for dose rate surveys using pressurized ionization chambers is based on detecting a dose 15 mrem above background. The value of Δ was chosen as 15 mrem above background.

If σ is the standard deviation of the measurements in the reference area, then Δ/σ , expresses this shift as the number of standard deviations toward higher values that would

be considered "large" for the distribution of measurements in the survey unit. The shift Δ is a fixed value depending on the criteria of interest. However, the ease or difficulty of detecting this shift statistically depends on the variability in the data, expressed by σ . Therefore, the statistical hypothesis must depend not solely on the absolute shift Δ , but on the relative shift Δ/σ , which expresses the shift relative to the variability in the measurements at a given site.

Some estimate for σ is needed, based on prior sampling or other information. Radiation control technicians who were interviewed about the dose rate at GJPO generally agree that the exposure rate ranges from 10 to 14 $\mu\text{R/hr}$. This provides an estimate of $\sigma = 9$ mrem/year.⁴

P_r is the specified probability required to detect that a random measurement from the survey unit be larger than a random measurement from the reference area. P_r is greater than 0.5 whenever $\Delta/\sigma > 0$.

P_r is determined using the specified shift Δ/σ that must be detected with power $1 - \beta$. Values of P_r computed for a normal distribution are determined as follows:

$$P_r = \frac{1}{\sqrt{2\pi}} \int_{-\infty}^{\frac{\Delta}{\sqrt{2}\sigma}} e^{-x^2/2} dx = \Phi\left(\frac{\Delta}{\sqrt{2}\sigma}\right) \quad (3)$$

The normal distribution is used here only to enable the conversion of the values of Δ/σ to values of P_r to calculate the appropriate sample size and error rates. The normal distribution is not used actually to conduct the test.

For an α and β error rate of 0.05 and the comparison of the reference area to two survey units (i.e., north and south ends of Building 2), the required number of samples was determined to be 38. The data is given in Table 2.

⁴ This is an overestimate of sigma that was discovered to be in error after the sampling plan had already been issue. In fact sigma is closer to 1 mrem/yr. Rather than change this value and the associated calculations, we will simply acknowledge the error and note that the result was excess measurement of the gamma exposure rate. No adverse affect on the data set occurred.

Table 2.

Determination of the Number of Pressurized Ionization Chamber Measurements for Building 2 and Reference Area					
		1- /2	1-		
0.5	0.5	1.96	1.645	0.59	
D/s				N + 20%	
15	15.00	1.0000	0.7600	66	79
15	14.12	1.0625	0.7740	60	72
15	13.33	1.1250	0.7870	54	65
15	12.63	1.1875	0.7990	50	60
15	12.00	1.2500	0.8120	46	55
15	11.43	1.3125	0.8230	43	51
15	10.91	1.3750	0.8350	40	48
15	10.43	1.4375	0.8450	38	45
15	10.00	1.5000	0.8560	35	42
15	9.60	1.5625	0.8650	34	40
15	9.23	1.6250	0.8750	32	38
15	8.89	1.6875	0.8840	30	36
15	8.57	1.7500	0.8920	29	35
15	8.28	1.8125	0.9000	28	34
15	8.00	1.8750	0.9080	27	32
15	7.74	1.9375	0.9150	26	31
15	7.50	2.0000	0.9210	25	30

When applying statistical tests, it should be understood that the use of these hypotheses will occasionally allow some survey unit measurements to be larger than some reference area measurements without rejecting the null hypotheses. The central issue addressed by these statistical tests, is whether the site measurements are sufficiently larger to be considered significantly (statistically) different from reference area measurements. Therefore, to apply these tests, what is meant by "larger" must be defined. This is one purpose of constructing the desired power curve as a function of residual radioactivity as shown in the next section.

The WRS test is able to detect uniform failure of the building of interest from meeting the desired decision error level. It is not able to detect hot-spots of contamination. The Quantile test described NUREG-1505 will also be used to analyze this data set for non-uniform contamination. However, the main objective of this study is to evaluate the potential dose to normal occupants and a future demolition of the building. Therefore the

mean activity and dose is the primary objective of this study, not the detection of hot-spots.

The dose rate data will be used to assess the dose from the external exposure pathway. The external dose will be added to the dose from additional pathways evaluated using the RESRAD-BUILD model.

The radon data will be compared with the reference building and to long-term community averages, but the dose from radon will not be included in the total dose to the building occupants. Instead the radon concentration will be evaluated against the EPA screening guideline value.

Contamination levels on accessible and inaccessible surfaces will be used for input into the RESRAD-BUILD model for the determination of the potential dose to building occupants and demolition crews. In addition, the contamination levels on accessible surfaces will be compared with present DOE standards for release.

The survey procedure for scans, direct measurements, and smears on accessible surfaces was taken from NUREG/CR-5849. A square grid of 1 m by 1 m will be established in Building 2. Scanning of accessible surfaces to identify locations of residual and near-surface activity will be done according to the following schedule:

Affected area surfaces - 100% of floors and walls

Unaffected area surfaces - 10% of floors and walls

Direct measurements of surface activity will be done at systematically and randomly selected locations and at locations of elevated direct radiation, identified by surface scans. At least 30 measurement locations for each survey unit must be selected on the grid points by a random process. If the location contains items that prevent the measurement, then the nearest accessible location should be measured and the location noted on the standard survey forms. An integrated count will be obtained at each randomly selected grid point.

A smear for removable contamination will be obtained at each location of a direct surface activity measurement. These smears should encompass an area of 100 cm². Smears will be placed into envelopes or other individual containers, to prevent cross-contamination while awaiting analysis.

Inaccessible surfaces will require the use of core samples to estimate the mean and variance of the total beta contamination level. The number of required samples was determined and subsequently optimized based on the cost of sampling and the importance of the result, using the following equation (ASTM 1982):

$$N = \frac{\sigma^2 z^2}{E^2} \quad (4)$$

where:

- N = number of required samples in a sampling unit.
- z = a value corresponding to a confidence level (in this case the 95% CL) for the normal distribution. $z = 1.96$ in this case.
- σ = preliminary estimate of the standard deviation of the contamination level in a sampling unit, in dpm/100 cm².
- E = the acceptable error in a sampling unit, in dpm/100 cm².

The assumed parameters and results are shown in Table 3. The value of sigma was selected after examining survey data from accessible surfaces. E was chosen after estimating an order-of-magnitude effect on the dose due to various contamination levels. The result is a rough estimate of the number of required samples.

Table 3. Parameters used to estimate the required number of samples in each sampling unit.

Sampling units(s)	σ	E	N
North walls	15,000	10,000	9
North floor	15,000	12,000	6
South walls	15,000	10,000	9
South floor	15,000	12,000	6

A total of 24 cores will be taken in the southern end of Building 2. Eighteen cores will be taken on the walls, i.e., 9 cores on each wall sampling unit. Six core samples will be obtained from the floor sampling unit.

A total of 34 cores will be taken in the northern end of Building 2. Twenty-six cores will be taken on the walls, i.e., 9 cores on each wall sampling unit. Six cores will be taken from the floor sampling unit. It may not be possible to randomly select the sampling locations on the walls or floors in the northern end because the telecommunications equipment, which cannot be moved, blocks access. In that case an attempt will be made to obtain representative sampling to extent it is feasible. Any significant departure from representative sampling will be discussed in the final report.

The original wall surface and floor surface will be separated from the cores and direct measurements (i.e., integrated counts) will be taken for gross beta measurements. In addition, a smear for removable contamination will also be obtained for each core.

The main decision rule for the occupants of the building will be based upon a TEDE of 15 mrem above background. The dose to building occupants will be determined from the survey data by using the RESRAD-BUILD model.

The decision rule for demolition crews of the building will be based upon a TEDE of 30 mrem above background. The dose to demolition crews will be determined from the survey data by using the RESRAD-BUILD model.

DQO Step 6: Specify Limits on Decision Errors

Limits on the decision error rates are developed to establish appropriate goals for limiting uncertainty in the data. This is done by establishing the goals for the Type I error rate and the Type II error rate.

Discomfort curves were developed for each survey and sampling measurement to be taken in Building 2. These curves provide the acceptable error levels and the area of no discomfort for each measurement type and final dose values. Discomfort curves are easy to understand graphical descriptions of the confidence the decision maker needs as a product of the analysis. Each discomfort curve, which is a continuous function, is transformed into a step function curve, called the acceptable decision error curve. This curve matches the discrete confidence levels traditionally used in statistical evaluations.

From this statistical power curve, that can be tested using as a null hypothesis is derived. Power curves are used to define the number of samples needed confidently to estimate a particular quantity, such as dose rate. The discomfort, acceptable decision error, and power curves for the each quantity to be measured are grouped; see Figures 1.a through 4.c. The discomfort curves represent the value judgements of the authors, based on informed consideration of current regulation and practice, and newly proposed regulations.

DQO Step 7: Optimize the Design

Occasionally the predetermined location for a measurement will not be accessible due to obstructions. Then a field variance will be noted and the data will be collected from the nearest accessible point. Variances deemed to be important to the estimate of dose will be discussed in the final report.

Because core sampling is an expensive process, effort was made to optimize the sampling plan for inaccessible areas. The effect of various contamination levels on dose during the demolition scenario was estimated using omphaloskepsis and order-of-magnitude calculations. After the effect on dose was estimated, the value for E, the acceptable error was increased. By maximizing E, the required number of samples is minimized.

Part II. FUTURE USE OF BUILDING 2

Future use of a building is difficult to predict with accuracy. However, we believe that assuming that this 50-year-old World War II-era wooden structure has a useful life of 30 years or less is reasonable. Future use is likely to be continued as an office and telecommunications structure, or perhaps as classroom, but not as a residential structure. This likely use limits occupancy by any individual to 240 days per year, eight hours per day. HVAC is not expected to be substantially different from current practice. Adjacent land use is unlikely to be agricultural because of the soil type and depth near the structure.

Inevitably the building will be demolished at some future date that poses a risk to the constructions workers involved and potentially to workers operating the landfill where debris and rubble will be disposed. Demolition, which will result in elevated airborne dust concentration, is assumed to occur during a two week period. Only new equipment, unaffected by prior operations, is expected to be salvaged. Building materials, such as

copper wiring, drain pipe, wood, and concrete rubble, are assumed to go to a sanitary landfill and not put to any future beneficial use.

References

ASTM 1982. ASTM E122-72, "Standard Recommended Practice for Choice of Sample Size to Estimate the Average Quality of a Lot or Process." 1982. Annual Book of ASTM Standards.

EPA 1995. Guidance for Planning for Data Collection in Support of Environmental Decision Making Using the Data Quality Objective Process. Interim final. EPA QA/G-4. 1995.

Morris 1996. Data Quality Objectives for the GJPORAP Building 2 Pipe Explorer™ Operation. Robert Morris. Rust Geotech, Inc. 1996.

NUREG/CR-5849. Manual for Conducting Radiological Surveys in Support of License Termination. Draft Report for Comment. NUREG/CR-5849/ORAU-92/C57. J. D. Berger. U. S. Nuclear Regulatory Commission. 1992.

NUREG 1505. A Nonparametric Statistical Methodology for the Design and Analysis of Final Status Decommissioning Surveys. Draft Report for Comment. U. S. Nuclear Regulatory Commission. August 1995.

ANL/EAD/LD-3. RESRAD-BUILD: A Computer Model for Analyzing the Radiological Doses Resulting from the Remediation and Occupancy of Buildings Contaminated with Radioactive Material. Environmental Assessment Division, Argonne National Laboratory. November 1994.

Figure 1.a

DECISION MAKER'S "DISCOMFORT CURVE"




Figure 1.b

ACCEPTABLE DECISION ERRORS




Figure 1.c

CHART OF DESIRED POWER FOR SETTING DECISION ERROR RATE TARGETS




Figure 2.a

DECISION MAKER'S "DISCOMFORT CURVE"




Figure 2.b

ACCEPTABLE DECISION ERRORS




Figure 2.c

ACCEPTABLE DECISION ERRORS




Figure 3.a

DECISION MAKER'S "DISCOMFORT CURVE"




Figure 3.b

ACCEPTABLE DECISION ERRORS




Figure 3.c

CHART OF DESIRED POWER FOR SETTING DECISION ERROR RATE TARGETS




Figure 4.a

DECISION MAKER'S "DISCOMFORT CURVE"




Figure 4.b

ACCEPTABLE DECISION ERRORS




Figure 4.c

CHART OF DESIRED POWER FOR SETTING DECISION ERROR RATE TARGETS




Figure 5.a

DECISION MAKER'S "DISCOMFORT CURVE"




Figure 5.b

ACCEPTABLE DECISION ERRORS





Figure 5.c

CHART OF DESIRED POWER FOR SETTING DECISION ERROR RATE TARGETS



Appendix 4

Radiological Survey and Sampling Plan for Building 2 at the DOE Grand Junction Projects Office

Radiological Survey and Sampling Plan for Building 2
at the DOE Grand Junction Projects Office

January 19, 1996

Rust Geotech, Inc.

Prepared by Robert Morris

Robert Morris 1/19/96

1.0 Introduction

Building 2 is located at the Department of Energy's (DOE) Grand Junction Projects Office (GJPO) in Grand Junction, Colorado. Currently, Building 2 contains the copy and reproduction equipment in the south end of the building and the telecommunications center at the north end of the building. Historically, the south end of Building 2 was used as a warehouse. The north end of the building was a change room facility containing lockers and showers for uranium-refinery and mill workers. The north end of building 2 is suspected of containing non-uniform contamination related to the change room activities of the mill workers and thus probably contains U-238 and its decay products. The south end of the building is not suspected of being significantly contaminated and most likely contains uniform contamination in small quantities related to surrounding activities at the mill.

Building 2 has been identified for demolition under the Grand Junction Projects Office Remedial Action Program (GJPORAP). However, due to the large cost of such activities related to the telecommunications equipment, a study is being done to predict the radiation dose to the public if the building is released for unrestricted use. The radiation dose will relate to contamination level in the building. This radiological survey and sampling plan were developed to guide the survey and sample collection activities related to Building 2 in support of the development of this variance.

A report (Rust, 1996) describing the data quality objectives for this study has been prepared. It should be consulted for clarification of any questions that may arise in carrying out this sampling plan.

2.0 Sampling Units

Two buildings were chosen for this sampling plan. The "Log Cabin" of Building 12 was chosen as the reference area, which is the unaffected area for comparison with the affected area (i.e., Building 2). Building 2 was divided into two areas, 1) the southern area containing the copy center and 2) the northern area containing the communications equipment. The southern area is considered affected with uniform contamination, while the northern area is considered affected with non-uniform contamination.

Various sampling units were identified depending on the type of measurement being taken. These sampling units and their descriptions are given in Table 1. Sampling units will be 100 ft² for non-uniform contamination and 1000 ft² for uniform contamination areas.

3.0 Potential Contaminants

Based on knowledge of site operations and results from GJPO radiological surveys, the principal contaminants associated with GJPO buildings are uranium isotopes and their associated daughter products including Ra-226 and Th-230. These radionuclides are present in uranium mill-tailings and tailings contaminated soil and concrete. Uranium may also be present as yellowcake, primarily as surface contamination.

Table 1. Sampling Units for Building 2 and Reference Area

Measurement Type	Total Sampling Units	Building 12 "Log Cabin"	Building 2 (South End)	Building 2 (North End)
PIC	3	all one unit	all one unit	all one unit
Radon	3	all one unit	all one unit	all one unit
Accessible Surfaces	4	none	old walls one unit	old walls one unit
			new walls one unit	new walls one unit
Inaccessible Surfaces	7	none	floor one unit	floor one unit
			walls two units	walls three units

The sampling units for Inaccessible wall surfaces in the south end of Building 2 consist of the 1) the west and half of the south wall as one unit, and 2) the east and half of the south wall as the other unit. The north end of Building 2 has three wall sampling units for inaccessible surfaces, where each wall, north, east, and west are each individual units.

4.0 Pressurized Ionization Chamber Measurements

A total of thirty-eight Pressurized Ionization Chamber (PIC) measurements will be taken in the Building 938 and in Building 12 (i.e., Log Cabin). Standard RUST survey procedures will be followed for these surveys. Twenty-two PIC measurements will be taken in Building 12 (i.e.,

Log Cabin) to find the average dose in the reference building. Sixteen PIC measurements will be taken in Building 2, eight measurements in the northern portion of the building (i.e., telecommunications center), and eight measurements in the southern portion of the building (i.e., copy center). All PIC measurements will be taken one meter off the floor and one meter from all walls at evenly spaced square grid locations. Occasionally, the grid point may be obscured by office equipment, in these cases the PIC measurement will be taken at the nearest accessible point to the selected grid point. All measurement locations and measurement values will be noted on standard survey forms. PIC measurements will follow applicable procedures contained in the RUST Geotech Field Assessments Procedures Manual, Chapter 11.

5.0 Radon Measurements

One radon measurement will be taken in each sampling unit. One each in Building 12 (i.e., Log Cabin), the southern portion of Building 2 (i.e., copy center), and in the northern portion of Building 2 (i.e., telecommunications center). These measurements will be taken with track etch FA Chip 10 detectors emplaced during winter time for a minimum of one month. Radon measurements will follow applicable procedures contained in the RUST Geotech Field Assessments Procedures Manual, Chapter 10.

6.0 Beta Measurements on Accessible Surfaces

Beta survey measurements for surface activity will consist of a combination of surface scans, direct measurements, and measurements of removable activity. Instrument background, established in a nearby unaffected area, should be subtracted from the measurements. Only Building 2 will be involved in these measurements, no reference measurements in Building 12 are needed. All survey measurements for surface activity will follow applicable procedures contained in the RUST Geotech Field Assessments Procedures Manual, Chapter 22. A square grid will be established at one meter intervals for Building 2.

Scanning of accessible surfaces to identify locations of residual and near-surface activity will be done according to the methods defined in NUREG 5849 (Berger 1992). In summary that method includes the following:

Affected area surfaces - 100% of floor and walls;

Unaffected area surfaces - 10% of floor and walls up to 2 meters above the floor

Scanning speeds will be no greater than one detector width per second. All scanning results will be noted on standard field record forms.

Direct measurements of surface activity will be taken in Building 2. Surface activity measurements will be performed at systematically and randomly selected locations and at locations of elevated direct radiation, identified by surface scans. At least 30 measurement locations for each survey unit must be selected on the grid points by a random process. If the location contains items that prevent the measurement, then the nearest accessible location should be measured and the location noted on the standard survey form. One minute integrated counts will be obtained at each location randomly selected grid point.

A smear for removable contamination will be obtained at each location of a direct surface activity measurement. These smears should encompass an area of 100 cm². Smears will be placed into envelopes or other individual containers, to prevent cross-contamination while awaiting analysis.

Survey instruments should be calibrated with NIST-traceable beta sources that approximate the energy of beta emissions associated with uranium and associated radionuclides expected to occur in Building 2. Chlorine-36 beta sources will provide acceptable approximations of the expected energy.

7.0 Sampling of Inaccessible Surfaces

Inaccessible surfaces will be sampled in Building 2 using the applicable procedure in the RUST Geotech Field Assessments Procedures Manual, Chapter 13. Inaccessible surfaces will require the use of coring machines, therefore, a Radiation Work Permit will be required from Health and Safety to ensure worker protection and identification of any potential release of contamination. Using the square grid system established at one meter intervals for Building 2, cores will be taken at accessible grid points chosen, to the extent feasible, to represent the entire sampling unit. The sampling locations will be noted on the standard survey forms.

It may not be feasible to select the sampling locations on the northern sampling units in a truly random manner because access may be blocked by the sensitive telecommunications equipment. Sampling locations should be selected based on the sampler's judgement. Field notes should describe why sampling locations were selected if they deviate significantly from a random pattern or if contiguous areas larger 4 m² could not be accessed.

Before sampling in the northern portion of Building 2, the telecommunications equipment should be protected from airborne dust. This may be done by covering equipment with plastic sheeting and using a high efficiency vacuum cleaner to capture the air near the wall coring operations. Any covering or interference with the telecommunication equipment should be verbally approved by the telecommunication supervisor before installation to prevent damaging this sensitive and expensive equipment. Vibrations near the telecommunication equipment should be minimized.

A total of 24 cores will be taken in the southern end of Building 2. Nine cores will be taken on each wall sampling unit in the southern end of Building 2. The sampling units for Inaccessible wall surfaces in the south end of Building 2 consist of the 1) the west and half of the south wall as one unit, and 2) the east and half of the south wall as the other unit. Six core samples will be obtained from the floor sampling unit.

A total of 34 cores will be taken in the northern end of Building 2. Twenty-six cores will be taken on the walls, i.e., 9 cores on each wall sampling unit. The north end of Building 2 has three wall sampling units for inaccessible surfaces, where each wall, north, east, and west are each individual units. Six cores will be taken from the floor sampling unit.

The original wall surface and floor surfaces will be separated from the cores and direct measurement (i.e., integrated one minute counts) will be made. In addition, a smear for removable contamination will also be obtained for each core.


8.0 Data and Records Management

Data and records will be managed according to Rust policies and procedures and the GJPORAP Records Management Plan. Original copies of the base maps and field record forms for Building 2 and 12 (i.e., Log Cabin) will be retained by the organizations that collect the data until all surveys and sampling for the buildings are completed. Within 30 days of completing the surveys, the organizations that collected the data will forward copies of the documents to the project manager. The project manager will then forward the final report along with copies of the base maps and field record forms to the Rust Records Management Section for storage in the appropriate folio. All field and technical data will be archived by RUST or its successors in the GJPO records storage vaults until DOE authorizes disposal.

9.0 References

Berger, J.D. 1992. *Manual for Conducting Radiological Surveys in Support of License Termination*. NUREG/CR-5849, ORAU-92/C57, Draft Report for Comment, Environmental Survey and Site Assessment Program, Energy/Environmental Systems Division, Oak Ridge Associated Universities, Oak Ridge, TN, 37831-0117.

Rust, 1996. "DQOs, Use Scenarios, and Affected Area Designation for GJPORAP Building 2 Characterization." Robert Morris and David Thorne, Rust Geotech, Inc. 1996.



Appendix 5

Input parameters for RESRAD-BUILD

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes that proper record-keeping is essential for transparency and accountability, particularly in financial matters. The text outlines various methods for organizing and storing data, including digital databases and physical filing systems.

2. The second section focuses on the role of technology in modern record management. It highlights how cloud storage and data analytics tools can enhance the efficiency and security of record-keeping processes. The author notes that while technology offers significant benefits, it also introduces new challenges, such as data privacy and system vulnerabilities, which must be carefully managed.

3. The third part of the document addresses the legal and regulatory requirements governing record retention. It provides a detailed overview of the various laws and standards that organizations must adhere to, depending on their industry and geographical location. The text stresses the importance of staying up-to-date with these regulations to avoid potential legal consequences.

4. The final section discusses the importance of training and education for staff involved in record management. It argues that even the most advanced systems and regulations are only as good as the people who use them. Therefore, ongoing training and education are crucial for ensuring that all personnel understand their responsibilities and can effectively manage records.

RESRAD-BUILD INPUT DATA

Input parameters for normal occupancy case

Occupancy characteristics

Total time spent of site:	240 days	50 weeks/year, 5 days/week, 8 hr/day
Fraction of time in B2:	0.3	where 1 = 24 hours/day
Times set for evaluation:	1,10,20,30	years

Building characteristics

Number of rooms 2

Room 1, North End of Building 2

Height 2.4 m

Area 50.5 m² Nominally 5.8 x 8.7 m

Air exchange rate 1/hr

Outdoor inflow 50 m³/hr

Room 2, South End of Building 2

Height 2.4 m

Area 138 m² Nominally 5.8 x 23.8 m

Air exchange rate 1/hr

Outdoor inflow 50 m³/hr

Total air exchange rate

N21 (net inflow 1-2) 10/hr

Deposition velocity 0.01 m/s default

Resuspension rate 5.00e-7 /s default

Number of receptors 2

Receptor 1

position 3,3,1 approximate room center

room number 1 north end

time fraction 0.27 ratio of size of room 1 to room 2

inhalation rate 18 m³/d default

ingestion rate 0.0001 m²/d default

Receptor 2

position 20,2,1 approximate room center

room no. 2 South end

Time fraction 0.73 ratio of room sizes

Inhalation rate 18 m³/d default

Ingestion rate 0.0001 m²/d default


Number of sources 6

See details regarding sources and shielding below

In all cases the activity is assumed to be refined uranium in naturally occurring activity ratios of 47.33% ²³⁸U, 2.2% ²³⁵U, and 50.47% ²³⁴U. To obtain the input information for each radionuclide,

the total activity listed below in pCi/m² is multiplied by the factor for each isotope. All sources described here are area sources, coded as type 2. The figure on the next page shows the location of the sources. The source removal time is 30 years (10,950 days).

BUILDING 2 - RESRAD-BUILD MODEL SOURCES



1* Indicates source number and grid center

Source 1. Contamination on concrete in the east wall of Room 1 (telecommunications room) is on the original concrete which is now covered by plywood, sheetrock or paneling. The contamination averaged 13,114 dpm/100 cm² with a standard deviation of 14,828. This is the same as 596,100 pCi/m² with a SD of 674,000. Radioactivity for input to the model is split according to the natural activity ratios described above and results in the following: ²³⁴U: 301,000 pCi/m², ²³⁵U: 13,100 pCi/m², ²³⁸U: 282,000 pCi/m². Concrete was encountered up to about 1 m height along the whole wall. No concrete was found above 1 m. This is consistent with visible structures remaining from the shower and toilet facilities.

To construct a model input the center point and area of the idealized source needs to be defined. Choose the center point as the center of the wall ½ meter above grade. Using the south east corner at floor level as the origin, this point is nominally 28.2/0/0.5. The area is the length of the wall, 8.7 m, times the 1 m concrete height for an area of 8.7 m². The source direction is the vector perpendicular to the face of the source and is coincident with x,y, or z vectors with respect to the origin. In this case the source direction is the same as y, which is coded as 2. The source has an area geometry which is coded as 2.

The source is described as an area source covered by sheetrock or paneling. The survey team leader notes indicate two of the points were covered by 2.0 cm of plywood over 1.5 cm of sheetrock. The other two sampled locations were covered by 0.5 cm of paneling which is similar to masonite or plywood. For purposes of this model we assume the source is covered with one layer of wood, 1 cm thick. Since wood is not a choice in the shielding materials, the best match to effective Z among the choices is water which is coded as 2. The density of wood is nominally 0.5 g/cm³. The air release fraction of the material that is eroded is assumed to be 0.1. The remainder contaminates skin, clothing, and other items and is removed from the site. The removable fraction is assumed to approach zero since it is beneath wall coverings. A value of 0.001 is selected.

Source 2. This is similar to Source 1 except it is in the north wall which is 5.8 m wide with a center point of 32.5/3/0.5. The area of the source is 5.8 m². The direction of the source is the same as x, which is coded as 1. The contamination averaged 26,676 dpm/100 cm² with a standard deviation of 5,036. This is the same as 1,212,545 pCi/m² with a SD of 228,909. Radioactivity for input to the model is split according to the natural activity ratios described above and results in the following: ²³⁴U: 612,000 pCi/m², ²³⁵U: 26,700 pCi/m², ²³⁸U: 574,000 pCi/m².

In two of the five locations the concrete is covered by 2 cm of plywood over 1 cm of sheetrock. In the other locations the covering is 2 cm of plywood. For modeling we assume the system is a volume source of two layers with the top layer being 2 cm of wood. Since wood is not a choice in the shielding materials, the best match to effective Z among the choices is water which is coded as 2. The density of wood is nominally 0.5 g/cm³. The air release fraction of the material that is eroded is assumed to be 0.1. The remainder contaminates skin, clothing, and other items and is removed from the site. The removable fraction is assumed to approach zero since it is

beneath wall coverings. A value of 0.001 is selected.

Source 3. This source is the insulation present in south wall which extends into the southern ends of the east and west walls. For simplicity the model will show this source only in the south wall and compensate for the other affected areas by doubling the average contamination level for this material type. The south wall is 2.4 m high and 5.8 m long for an area of 13.9 m². The source direction is x, which is coded as 1. The center point is 0/3/1. The mean contamination level for the insulation was 12,939 dpm/100 cm² with a standard deviation of 9,224. This is the same as 588,100 pCi/m² with a SD of 419,000. Doubling the activity to account for the simplification in source geometry, the activity to be used in the model is 1,176,000 pCi/m². Radioactivity for input to the model is split according to the natural activity ratios described above and results in the following: ²³⁴U: 594,000 pCi/m², ²³⁵U: 25,900 pCi/m², ²³⁸U: 557,000 pCi/m². For modeling purposes we assume the activity to be in a plane below 0.5 cm of paneling over 1 cm of sheetrock, giving the same effect as 1.5 cm of sheetrock. Since sheetrock is not a choice in the shielding materials, the best match to effective Z among the choices is probably concrete, which is coded as 1. The density of is assumed to be 0.5 g/cm³. The air release fraction of the material that is eroded is assumed to be 0.1. The remainder contaminates skin, clothing, and other items and is removed from the site. The removable fraction is assumed to approach zero since it is beneath wall coverings. A value of 0.001 is selected.

Source 4. This source is the structural wood found in almost all exterior walls. The average activity on all of the wood found in all of the survey units was 7871 dpm/100 cm² with a standard deviation of 8681. This is the same as 357,000 pCi/m² with a SD of 395,000. Radioactivity for input to the model is split according to the natural activity ratios described above and results in the following: ²³⁴U: 180,000 pCi/m², ²³⁵U: 7,900 pCi/m², ²³⁸U: 169,000 pCi/m². Assume the contaminated wood is studs that occur uniformly through all exterior walls and cover 1 1/2 out of every 16 linear inches of wall (in other words, 9.4%). The walls are 2.4 m high and the linear dimension of all the exterior sums to approximately 77 m. Then the affected area for the whole structure is 17 m². Since this source is assumed to be symmetrically distributed, and the receptors are assumed to be in the center of each room, the source can be approximated by putting it all in one of the long walls, say the west walls with a center point of 20/5.8/1. The source direction is y or 2. Assume the wood is covered by 2 cm of sheetrock. Since sheetrock is not a choice in the shielding materials, the best match to effective Z among the choices is probably concrete which is coded as 1. The density of is assumed to be 0.5 g/cm³. The air release fraction of the material that is eroded is assumed to be 0.1. The remainder contaminates skin, clothing, and other items and is removed from the site. The removable fraction is assumed to approach zero since it is beneath wall coverings. A value of 0.001 is selected.

Source 5. This source is the direct contamination measured on the surface of the North - Old Walls Survey Unit, which is the northwest wall of the telecommunications room. The mean contamination level is 1484 dpm/100 cm² with a standard deviation of 2313. This is the same as 67,500 pCi/m² with a SD of 105,000. Radioactivity for input to the model is split according to

the natural activity ratios described above and results in the following: ^{234}U : 34,000 pCi/m², ^{235}U : 1,500 pCi/m², ^{238}U : 32,000 pCi/m². The center point is 28/5.8/1.2. The affected area is 20.8 m². The source direction is y or 2. The air release fraction is assumed to be 0.1 due to particle size and agglomeration. Assume the removable fraction is 0.5. Assume that the material is under a layer of paint with a thickness of 0.01 cm and a density of 2 g/cm³. The shielding characteristics of paint are assumed to be simulated by concrete of the same thickness.

Source 6. This source is the inaccessible contamination measured between the concrete slabs for the north and south rooms. To simplify the model and because there is not much difference between the means of the survey units, the data from the survey units will be averaged together. The mean contamination level is 1906 dpm/100 cm² with a standard deviation of 1039. This is the same as 86,600 pCi/m² with a SD of 47,200. Radioactivity for input to the model is split according to the natural activity ratios described above and results in the following: ^{234}U : 44,000 pCi/m², ^{235}U : 1,900 pCi/m², ^{238}U : 41,000 pCi/m². The center point is 16/3/0. The affected area is the whole floor or 189 m². The source direction is z or 3. The source is assumed to exist under a 10 cm concrete slab. The air release fraction of the material that is eroded is assumed to be 0.1. The remainder contaminates skin, clothing, and other items and is removed from the site. The removable fraction is assumed to approach zero since it is beneath floor coverings. A value of 0.001 is selected.

The south west wall cores indicate that this might be modeled as a source. However inspection of the data shows that the elevated activity is associated with insulation and wood which have already been modeled as sources 3 and 4.

Levels of surface contamination in all other survey units are less than 1000 dpm/100 cm² which is 1/5 of the guideline value and deemed insignificant for this dose assessment.

Input parameters for demolition case

Unless otherwise specified the input parameters are the same as the normal occupancy case

Occupancy characteristics

Total time spent of site:	10 days	2 weeks, 5 days/wk , 8 hr/day
Fraction of time in B2:	0.3	where 1 = 24 hours/day
Times set for evaluation:	0	years

Building characteristics


Number of rooms	1	a bubble of air over the downed bldg
Room 1, North End of Building 2		
Height	3 m	
Area	200	Nominally
Total air exchange rate	15 air chgs/hr	Light breeze
Deposition velocity	0.01 m/s	default
Resuspension rate	1.00e-5 /s	lots of airborne debris
Number of receptors	1	

Receptor 1		
position	15,3,1	approximate room center
Number of source	6	

See details regarding sources and shielding below


The source terms remain the same except that the release fractions are modified to account for the destruction actions occurring and the associated aerosol generation rate.

In each case where the air release fraction is 0.1 it is changed to 0.2. The removable fraction is increased to 0.01. The time for source removal is 11 days so that all it is exposed during the demolition.



Appendix 6

RESRAD-BUILD Output



DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Phonics

```

=====
=====
ëëë                                     ëëë
ëëë      RESRAD-BUILD Table of Contents  ëëë
ëëë                                     ëëë
=====
=====

```

Input Parameters.....	0-1
For Each Time (I) :.....	
Time Specific Parameters.....	I-1
Receptor-Source Dose Summary.....	I-2
Dose by Pathway Detail.....	I-3
Dose by Nuclide Detail.....	I-4
Full Summary.....	F-1

File : DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT

```

=====
RESRAD-BUILD Input Parameters
=====

```

Number of Sources : 6
 Number of Receptors: 2
 Total Time : 2.400000E+02 days
 Fraction Inside : 3.000000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	FracTime	Inhalation [m3/day]	Ingestion(Dust) [m2/hr]
1	1	3.000	3.000	1.000	0.270	1.80E+01	1.00E-04
2	2	20.000	3.000	1.000	0.730	1.80E+01	1.00E-04

Receptor-Source Relationship

Receptor	Source 1		Source 2		Source 3		Source 4		Source 5	
	Density [g/cm3]	Thickness [cm]	Density [g/cm3]	Thickness [cm]	Density [g/cm3]	Thickness [cm]	Density [g/cm3]	Thickness [cm]	Density [g/cm3]	Thickness [cm]
1	5.000E-01	1.000E+00	5.000E-01	2.000E+00	5.000E-01	1.500E+00	5.000E-01	2.000E+00	2.000E+00	1.000E-02
2	5.000E-01	1.000E+00	5.000E-01	2.000E+00	5.000E-01	1.500E+00	5.000E-01	2.000E+00	2.000E+00	1.000E-02

Receptor	Source 6	
	Density [g/cm3]	Thickness [cm]
1	2.500E+00	1.000E+01
2	2.500E+00	1.000E+01

: DOE GJPO Bldg 2 Occupancy

file : B2OCC.DAT

Building Information

Building Air Exchange Rate: 1.00E+00 1/hr

Height[m]	Air Exchanges [m3/hr]	
Area [m2]		

	*	*
	*	*
	*	<=Q02: 5.00E+01
H2: 2.400	* Room 2	* Q20 : 6.00E+01
	* LAMBDA: 1.00E+00	*
Area 138.000	*	*
	* /\ N12: 1.00E+01	
	** *****	Q21 : 2.71E+02
	** *****	Q12 : 2.81E+02
	*	*
	*	*
	*	<=Q01: 4.02E+02
H1: 2.400	* Room 1	* Q10 : 3.92E+02
	* LAMBDA: 5.56E+00	*
Area 50.500	*	*
	*	*

Deposition velocity: 1.00E-02 [m/s] Resuspension Rate: 5.00E-07 [1/s]

Time : DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT

***** Source Information *****

Source: 1

Location:: Room : 1 x: 28.20 y: 0.00 z: 0.50[m]
 Geometry:: Type: Area Area:8.70E+00 [m2] Direction: y
 Pathway ::
 Direct Ingestion Rate: 0.000E+00 [1/hr]
 Fraction released to air: 1.000E-01
 Removable fraction: 1.000E-03
 Time to Remove: 1.095E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration	Dose Conversion Factors					
	Ingestion	Inhalation	External (Surface)	External (Volume)	External (Volume)	Submersion
[pCi/m2]	[mrem/pCi]	[mrem/pCi]	[mrem/yr/ (pCi/m2)]	[mrem/yr/ (pCi/m3)]	[mrem/yr/ (pCi/m3)]	[mrem/yr/ (pCi/m3)]
U-238	2.820E+05	2.500E-04	1.200E-01	3.530E-06	9.510E-08	1.600E-04
U-235	1.310E+04	2.500E-04	1.200E-01	1.950E-05	4.740E-07	9.030E-04
U-234	3.010E+05	2.600E-04	1.300E-01	8.750E-08	2.520E-10	8.930E-07
PA-231	0.000E+00	1.100E-02	1.300E+00	4.760E-06	1.190E-07	2.010E-04
TH-230	0.000E+00	5.300E-04	3.200E-01	8.780E-08	7.570E-10	2.040E-06
AC-227	0.000E+00	1.500E-02	6.700E+00	4.530E-05	1.260E-06	2.160E-03
RA-226	0.000E+00	1.100E-03	7.900E-03	1.940E-04	7.000E-06	1.040E-02
PB-210	0.000E+00	6.700E-03	2.100E-02	4.140E-07	3.820E-09	1.430E-05
CO-60	1.000E+00	2.600E-05	1.500E-04	2.750E-04	1.020E-05	1.470E-02

U-238	5.740E+05	2.500E-04	1.200E-01	3.530E-06	9.510E-08	1.600E-04
U-235	2.670E+04	2.500E-04	1.200E-01	1.950E-05	4.740E-07	9.030E-04
J-234	6.120E+05	2.600E-04	1.300E-01	8.750E-08	2.520E-10	8.930E-07
PA-231	0.000E+00	1.100E-02	1.300E+00	4.760E-06	1.190E-07	2.010E-04
TH-230	0.000E+00	5.300E-04	3.200E-01	8.780E-08	7.570E-10	2.040E-06
AC-227	0.000E+00	1.500E-02	6.700E+00	4.530E-05	1.260E-06	2.160E-03
RA-226	0.000E+00	1.100E-03	7.900E-03	1.940E-04	7.000E-06	1.040E-02
PB-210	0.000E+00	6.700E-03	2.100E-02	4.140E-07	3.820E-09	1.430E-05

File : B20CC.DAT

Source: 3

```

Location:: Room : 2 x: 0.00 y: 3.00 z: 1.00[m]
Geometry:: Type: Area Area:1.39E+01 [m2] Direction: x
Pathway ::
    Direct Ingestion Rate: 0.000E+00 [1/hr]
    Fraction released to air: 1.000E-01
    Removable fraction: 1.000E-03
    Time to Remove: 1.095E+04 [day]

```

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factors

[illegible]

Ingestion	Inhalation	External (Surface)	External (Volume)	Submersion
-----------	------------	-----------------------	----------------------	------------

[pCi/m2] [mrem/pCi] [mrem/pCi] [mrem/yr/ (pCi/m2)] [mrem/yr/ (pCi/m3)] [mrem/yr/ (pCi/m3)]

U-238	5.570E+05	2.500E-04	1.200E-01	3.530E-06	9.510E-08	1.600E-04
-235	2.590E+04	2.500E-04	1.200E-01	1.950E-05	4.740E-07	9.030E-04
-234	5.940E+05	2.600E-04	1.300E-01	8.750E-08	2.520E-10	8.930E-07
PA-231	0.000E+00	1.100E-02	1.300E+00	4.760E-06	1.190E-07	2.010E-04
TH-230	0.000E+00	5.300E-04	3.200E-01	8.780E-08	7.570E-10	2.040E-06
AC-227	0.000E+00	1.500E-02	6.700E+00	4.530E-05	1.260E-06	2.160E-03
RA-226	0.000E+00	1.100E-03	7.900E-03	1.940E-04	7.000E-06	1.040E-02
PB-210	0.000E+00	6.700E-03	2.100E-02	4.140E-07	3.820E-09	1.430E-05

File : B20CC.DAT

Source: 4

Location:: Room : 2 x: 20.00 y: 5.80 z: 1.00 [m]

Geometry:: Type: Area Area:1.70E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factors

[illegible][illegible]

[pci/m2] [mrem/pci] [mrem/pci] [mrem/yr/
(pci/m2)] [mrem/yr/
(pci/m3)] [mrem/yr/
(pci/m3)]

U-238	1.690E+05	2.500E-04	1.200E-01	3.530E-06	9.510E-08	1.600E-04
U-235	7.900E+03	2.500E-04	1.200E-01	1.950E-05	4.740E-07	9.030E-04
U-234	1.800E+05	2.600E-04	1.300E-01	8.750E-08	2.520E-10	8.930E-07
PA-231	0.000E+00	1.100E-02	1.300E+00	4.760E-06	1.190E-07	2.010E-04
TH-230	0.000E+00	5.300E-04	3.200E-01	8.780E-08	7.570E-10	2.040E-06
AC-227	0.000E+00	1.500E-02	6.700E+00	4.530E-05	1.260E-06	2.160E-03
RA-226	0.000E+00	1.100E-03	7.900E-03	1.940E-04	7.000E-06	1.040E-02
PB-210	0.000E+00	6.700E-03	2.100E-02	4.140E-07	3.820E-09	1.430E-05

Title : DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT

Source: 5

Location:: Room : 1 x: 28.00 y: 5.80 z: 1.20[m]
 Geometry:: Type: Area Area:2.08E+01 [m2] Direction: y
 Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]
 Fraction released to air: 1.000E-01
 Removable fraction: 5.000E-01
 Time to Remove: 1.095E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factors

aa

	Ingestion	Inhalation	External (Surface)	External (Volume)	Submersion
[pCi/m2]	[mrem/pCi]	[mrem/pCi]	[mrem/yr/ (pCi/m2)]	[mrem/yr/ (pCi/m3)]	[mrem/yr/ (pCi/m3)]

U-238	3.200E+04	2.500E-04	1.200E-01	3.530E-06	9.510E-08	1.600E-04
-235	1.500E+03	2.500E-04	1.200E-01	1.950E-05	4.740E-07	9.030E-04
-234	3.400E+04	2.600E-04	1.300E-01	8.750E-08	2.520E-10	8.930E-07
PA-231	0.000E+00	1.100E-02	1.300E+00	4.760E-06	1.190E-07	2.010E-04
TH-230	0.000E+00	5.300E-04	3.200E-01	8.780E-08	7.570E-10	2.040E-06
AC-227	0.000E+00	1.500E-02	6.700E+00	4.530E-05	1.260E-06	2.160E-03
RA-226	0.000E+00	1.100E-03	7.900E-03	1.940E-04	7.000E-06	1.040E-02
PB-210	0.000E+00	6.700E-03	2.100E-02	4.140E-07	3.820E-09	1.430E-05

Radon Release Fraction: 0.000E+00

U-238	4.100E+04	2.500E-04	1.200E-01	3.530E-06	9.510E-08	1.600E-04
-235	1.900E+03	2.500E-04	1.200E-01	1.950E-05	4.740E-07	9.030E-04
-234	4.400E+04	2.600E-04	1.300E-01	8.750E-08	2.520E-10	8.930E-07
PA-231	0.000E+00	1.100E-02	1.300E+00	4.760E-06	1.190E-07	2.010E-04
TH-230	0.000E+00	5.300E-04	3.200E-01	8.780E-08	7.570E-10	2.040E-06
AC-227	0.000E+00	1.500E-02	6.700E+00	4.530E-05	1.260E-06	2.160E-03
RA-226	0.000E+00	1.100E-03	7.900E-03	1.940E-04	7.000E-06	1.040E-02
PB-210	0.000E+00	6.700E-03	2.100E-02	4.140E-07	3.820E-09	1.430E-05

T : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 1.00000 years

```

=====
Assessment for Time: 1
Time =1.00E+00 yr
=====

```

Source Information

Source: 1

Location:: Room : 1 x: 28.20 y: 0.00 z: 0.50 [m]
Geometry:: Type: Area Area:8.70E+00 [m2] Direction: y
Pathway ::
Direct Ingestion Rate: 0.000E+00 [1/hr]
Fraction released to air: 1.000E-01
Removable fraction: 1.000E-03
Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	2.820E+05
	U-235	1.310E+04
	U-234	3.010E+05
	PA-231	2.770E-01
	TH-230	2.711E+00
	AC-227	4.379E-03
	RA-226	5.875E-04
	PB-210	6.043E-06
	CO-60	8.767E-01

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 1.00000 years

Source: 2

Location:: Room : 1 x: 32.50 y: 3.00 z: 0.50 [m]

Geometry:: Type: Area Area:5.80E+00 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	5.740E+05
	U-235	2.670E+04
	U-234	6.120E+05
	PA-231	5.645E-01
	TH-230	5.512E+00
	AC-227	8.926E-03
	RA-226	1.194E-03
	PB-210	1.229E-05

Source: 3

Location:: Room : 2 x: 0.00 y: 3.00 z: 1.00 [m]

Geometry:: Type: Area Area:1.39E+01 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	5.570E+05
	U-235	2.590E+04
	U-234	5.940E+05
	PA-231	5.476E-01
	TH-230	5.350E+00
	AC-227	8.658E-03
	RA-226	1.159E-03
	PB-210	1.193E-05

T : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 1.00000 years

Source: 4

Location:: Room : 2 x: 20.00 y: 5.80 z: 1.00 [m]
 Geometry:: Type: Area Area:1.70E+01 [m2] Direction: y
 Pathway ::
 Direct Ingestion Rate: 0.000E+00 [1/hr]
 Fraction released to air: 1.000E-01
 Removable fraction: 1.000E-03
 Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	1.690E+05
	U-235	7.900E+03
	U-234	1.800E+05
	PA-231	1.670E-01
	TH-230	1.621E+00
	AC-227	2.641E-03
	RA-226	3.513E-04
	PB-210	3.614E-06

Source: 5

Location:: Room : 1 x: 28.00 y: 5.80 z: 1.20 [m]
 Geometry:: Type: Area Area:2.08E+01 [m2] Direction: y
 Pathway ::
 Direct Ingestion Rate: 0.000E+00 [1/hr]
 Fraction released to air: 1.000E-01
 Removable fraction: 5.000E-01
 Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	3.147E+04
	U-235	1.475E+03
	U-234	3.343E+04
	PA-231	3.119E-02
	TH-230	3.011E-01
	AC-227	4.931E-04
	RA-226	6.525E-05
	PB-210	6.713E-07

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 1.00000 years

Source: 6

Location:: Room : 2 x: 16.00 y: 3.00 z: 0.00 [m]

Geometry:: Type: Area Area:1.89E+02 [m2] Direction: z

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	4.100E+04
	U-235	1.900E+03
	U-234	4.400E+04
	PA-231	4.017E-02
	TH-230	3.963E-01
	AC-227	6.352E-04
	RA-226	8.588E-05
	PB-210	8.834E-07

T : DOE GJPO Bldg 2 Occupancy

file : B2OCC.DAT

Evaluation Time: 1.00000 years

```

=====
=====
eee
eee      RESRAD-BUILD Dose Tables      eee
eee
=====
=====
    
```

Receptor Point-Source Doses

=====

[mrem]

	Source 1	Source 2	Source 3	Source 4	Source 5	Source 6	Total
Receptor 1	2.3E-04	2.9E-04	6.0E-03	2.6E-04	2.7E-02	5.2E-04	3.4E-02
Receptor 2	1.2E-03	1.0E-03	3.7E-03	7.0E-03	6.1E-02	3.8E-03	7.8E-02
Total	1.4E-03	1.3E-03	9.7E-03	7.2E-03	8.8E-02	4.3E-03	1.1E-01

: DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 1.00000 years

Pathway Detail of Doses

eeeeeeeeeeeeeeeeeeeeeeeeeeee

[mrem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	3.28E-05	3.60E-09	2.28E-11	1.95E-04	2.23E-20	1.06E-06
2	7.56E-04	1.09E-08	5.23E-11	4.47E-04	1.19E-19	2.43E-06
Total	7.89E-04	1.45E-08	7.51E-11	6.42E-04	1.41E-19	3.49E-06

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	2.34E-05	4.88E-09	3.09E-11	2.64E-04	3.03E-20	1.44E-06
2	4.15E-04	1.48E-08	7.10E-11	6.06E-04	1.61E-19	3.30E-06
Total	4.38E-04	1.97E-08	1.02E-10	8.71E-04	1.91E-19	4.73E-06

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	5.47E-03	9.30E-09	5.89E-11	5.03E-04	1.34E-19	2.74E-06
2	3.53E-04	8.24E-08	3.95E-10	3.38E-03	8.06E-19	1.84E-05
Total	5.82E-03	9.17E-08	4.54E-10	3.88E-03	9.40E-19	2.11E-05

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	7.40E-05	3.45E-09	2.19E-11	1.87E-04	4.96E-20	1.01E-06
2	5.71E-03	3.06E-08	1.47E-10	1.25E-03	2.99E-19	6.81E-06
Total	5.78E-03	3.41E-08	1.69E-10	1.44E-03	3.48E-19	7.83E-06

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	9.61E-06	4.89E-07	3.10E-09	2.64E-02	3.01E-18	1.43E-04
2	2.36E-04	1.48E-06	7.11E-09	6.05E-02	1.61E-17	3.29E-04
Total	2.46E-04	1.97E-06	1.02E-08	8.69E-02	1.91E-17	4.73E-04

Source: 6

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.64E-05	9.30E-09	5.89E-11	5.05E-04	1.35E-19	2.75E-06
2	3.89E-04	8.24E-08	3.95E-10	3.39E-03	8.12E-19	1.84E-05
	4.05E-04	9.17E-08	4.54E-10	3.90E-03	9.47E-19	2.12E-05

9.76E-02

5.31E-04

PCN 4/29/96

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 1.00000 years

Nuclide Detail of Doses

[mrem]

Source: 1

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	1.14E-04	7.87E-04	9.01E-04
U-234	2.75E-10	6.70E-10	9.45E-10
TH-230	3.03E-15	7.13E-15	1.02E-14
RA-226	2.11E-18	4.83E-17	5.04E-17
PB-210	1.22E-22	5.25E-22	6.47E-22
U-235			
U-235	1.09E-05	1.66E-04	1.77E-04
PA-231	9.96E-10	3.00E-09	3.99E-09
AC-227	8.05E-11	2.86E-10	3.66E-10
U-234			
U-234	1.04E-04	2.53E-04	3.56E-04
TH-230	2.28E-09	5.37E-09	7.66E-09
RA-226	2.70E-12	6.18E-11	6.45E-11
10	6.67E-16	2.88E-15	3.55E-15
CO-60			
CO-60	5.57E-09	1.28E-07	1.34E-07

Source: 2

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	1.39E-04	6.02E-04	7.41E-04
U-234	3.70E-10	8.59E-10	1.23E-09
TH-230	4.10E-15	9.47E-15	1.36E-14
RA-226	1.81E-18	2.93E-17	3.11E-17
PB-210	1.54E-22	4.55E-22	6.09E-22
U-235			
U-235	1.03E-05	9.88E-05	1.09E-04
PA-231	1.33E-09	3.42E-09	4.75E-09
AC-227	1.06E-10	2.96E-10	4.02E-10
U-234			
U-234	1.39E-04	3.23E-04	4.63E-04
TH-230	3.09E-09	7.14E-09	1.02E-08
RA-226	2.31E-12	3.75E-11	3.98E-11
PB-210	8.45E-16	2.49E-15	3.34E-15

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 1.00000 years

Source: 3

Nuclide	Receptor 1	Receptor 2	Total
238			
U-238	4.51E-03	1.82E-03	6.33E-03
U-234	7.87E-10	4.73E-09	5.52E-09
Th-230	8.61E-15	5.24E-14	6.11E-14
Pa-226	3.79E-16	2.63E-17	4.05E-16
Pb-210	1.87E-21	1.94E-21	3.81E-21
235			
U-235	1.17E-03	1.45E-04	1.32E-03
Pa-231	8.02E-09	1.71E-08	2.51E-08
Ac-227	1.10E-09	1.34E-09	2.43E-09
234			
U-234	2.96E-04	1.78E-03	2.08E-03
Th-230	6.49E-09	3.95E-08	4.60E-08
Pa-226	4.84E-10	3.36E-11	5.17E-10
Pb-210	1.02E-14	1.06E-14	2.09E-14

Source: 4

Nuclide	Receptor 1	Receptor 2	Total
238			
U-238	1.43E-04	5.04E-03	5.18E-03
U-234	2.62E-10	1.82E-09	2.09E-09
Th-230	2.91E-15	2.02E-14	2.32E-14
Pa-226	5.21E-18	4.01E-16	4.06E-16
Pb-210	1.22E-22	2.24E-21	2.37E-21
235			
U-235	1.97E-05	1.24E-03	1.26E-03
Pa-231	1.00E-09	1.20E-08	1.30E-08
Ac-227	8.30E-11	1.43E-09	1.52E-09
234			
U-234	9.87E-05	6.86E-04	7.85E-04
Th-230	2.19E-09	1.52E-08	1.74E-08
Pa-226	6.65E-12	5.12E-10	5.19E-10
Pb-210	6.68E-16	1.23E-14	1.29E-14

T : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 1.00000 years

Source: 5

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	1.21E-02	2.79E-02	3.99E-02
U-234	3.70E-08	8.49E-08	1.22E-07
TH-230	4.10E-13	9.40E-13	1.35E-12
RA-226	2.38E-18	1.86E-17	2.09E-17
PB-210	1.48E-20	3.32E-20	4.80E-20
U-235			
U-235	5.67E-04	1.35E-03	1.91E-03
PA-231	1.32E-07	3.03E-07	4.34E-07
AC-227	1.03E-08	2.30E-08	3.33E-08
U-234			
U-234	1.39E-02	3.19E-02	4.57E-02
TH-230	3.07E-07	7.06E-07	1.01E-06
RA-226	3.03E-12	2.36E-11	2.67E-11
PB-210	8.10E-14	1.81E-13	2.62E-13

Source: 6

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	2.45E-04	1.91E-03	2.16E-03
U-234	7.05E-10	4.73E-09	5.44E-09
TH-230	7.81E-15	5.24E-14	6.03E-14
RA-226	2.62E-18	6.16E-17	6.42E-17
PB-210	2.75E-22	1.86E-21	2.13E-21
U-235			
U-235	1.15E-05	9.26E-05	1.04E-04
PA-231	2.49E-09	1.69E-08	1.94E-08
AC-227	1.90E-10	1.31E-09	1.50E-09
U-234			
U-234	2.67E-04	1.79E-03	2.06E-03
TH-230	5.92E-09	3.98E-08	4.57E-08
RA-226	3.37E-12	7.92E-11	8.25E-11
PB-210	1.52E-15	1.02E-14	1.17E-14

: DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 10.0000 years

```

=====
=====
eee      Assessment for Time: 2      eee
eee      Time =1.00E+01 yr          eee
=====
=====
    
```

===== Source Information =====

Source: 1

Location:: Room : 1 x: 28.20 y: 0.00 z: 0.50 [m]
 Geometry:: Type: Area Area:8.70E+00 [m2] Direction: y
 Pathway ::
 Direct Ingestion Rate: 0.000E+00 [1/hr]
 Fraction released to air: 1.000E-01
 Removable fraction: 1.000E-03
 Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	2.819E+05
	U-235	1.310E+04
	U-234	3.009E+05
	PA-231	2.769E+00
	TH-230	2.710E+01
	AC-227	3.989E-01
	RA-226	5.865E-02
	PB-210	5.637E-03
	CO-60	2.681E-01

T : DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 10.0000 years

Source: 2

Location:: Room : 1 x: 32.50 y: 3.00 z: 0.50 [m]
Geometry:: Type: Area Area:5.80E+00 [m2] Direction: x
Pathway ::
Direct Ingestion Rate: 0.000E+00 [1/hr]
Fraction released to air: 1.000E-01
Removable fraction: 1.000E-03
Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	5.738E+05
	U-235	2.669E+04
	U-234	6.118E+05
	PA-231	5.643E+00
	TH-230	5.510E+01
	AC-227	8.129E-01
	RA-226	1.193E-01
	PB-210	1.146E-02

Source: 3

Location:: Room : 2 x: 0.00 y: 3.00 z: 1.00 [m]
Geometry:: Type: Area Area:1.39E+01 [m2] Direction: x
Pathway ::
Direct Ingestion Rate: 0.000E+00 [1/hr]
Fraction released to air: 1.000E-01
Removable fraction: 1.000E-03
Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	5.568E+05
	U-235	2.589E+04
	U-234	5.938E+05
	PA-231	5.474E+00
	TH-230	5.348E+01
	AC-227	7.886E-01
	RA-226	1.157E-01
	PB-210	1.112E-02

: DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 10.0000 years

Source: 4

Location:: Room : 2 x: 20.00 y: 5.80 z: 1.00 [m]

Geometry:: Type: Area Area:1.70E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	1.689E+05
	U-235	7.897E+03
	U-234	1.799E+05
	PA-231	1.670E+00
	TH-230	1.621E+01
	AC-227	2.405E-01
	RA-226	3.507E-02
	PB-210	3.371E-03

Source: 5

Location:: Room : 1 x: 28.00 y: 5.80 z: 1.20 [m]

Geometry:: Type: Area Area:2.08E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 5.000E-01

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	2.666E+04
	U-235	1.250E+03
	U-234	2.833E+04
	PA-231	2.642E-01
	TH-230	2.551E+00
	AC-227	3.807E-02
	RA-226	5.522E-03
	PB-210	5.308E-04

: DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 10.0000 years

Source: 6

Location:: Room : 2 x: 16.00 y: 3.00 z: 0.00 [m]

Geometry:: Type: Area Area:1.89E+02 [m2] Direction: z

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	4.099E+04
	U-235	1.899E+03
	U-234	4.399E+04
	PA-231	4.016E-01
	TH-230	3.962E+00
	AC-227	5.785E-02
	RA-226	8.574E-03
	PB-210	8.241E-04

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 10.0000 years

```

=====
=====
eee                                     eee
eee      RESRAD-BUILD Dose Tables      eee
eee                                     eee
=====
=====
    
```

Receptor Point-Source Doses

=====

[mrem]

	Source	Source	Source	Source	Source	Source	Total
	1	2	3	4	5	6	
Receptor 1	2.3E-04	2.9E-04	6.0E-03	2.6E-04	2.7E-02	5.2E-04	3.4E-02
Receptor 2	1.2E-03	1.0E-03	3.7E-03	7.0E-03	6.1E-02	3.8E-03	7.8E-02
Total	1.4E-03	1.3E-03	9.7E-03	7.2E-03	8.8E-02	4.3E-03	1.1E-01

File : B20CC.DAT

Evaluation Time: 10.0000 years

Pathway Detail of Doses

=====

[mrem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	3.28E-05	3.60E-09	2.28E-11	1.95E-04	2.23E-18	1.06E-06
2	7.56E-04	1.09E-08	5.23E-11	4.47E-04	1.19E-17	2.43E-06
Total	7.89E-04	1.45E-08	7.51E-11	6.42E-04	1.41E-17	3.49E-06

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	2.34E-05	4.88E-09	3.09E-11	2.64E-04	3.02E-18	1.44E-06
2	4.15E-04	1.48E-08	7.10E-11	6.06E-04	1.61E-17	3.30E-06
Total	4.38E-04	1.97E-08	1.02E-10	8.71E-04	1.91E-17	4.74E-06

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	5.47E-03	9.30E-09	5.89E-11	5.03E-04	1.34E-17	2.74E-06
2	3.52E-04	8.24E-08	3.95E-10	3.38E-03	8.05E-17	1.84E-05
Total	5.82E-03	9.17E-08	4.54E-10	3.88E-03	9.38E-17	2.11E-05

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	7.40E-05	3.45E-09	2.19E-11	1.87E-04	4.95E-18	1.02E-06
2	5.71E-03	3.06E-08	1.47E-10	1.25E-03	2.98E-17	6.82E-06
Total	5.78E-03	3.41E-08	1.69E-10	1.44E-03	3.48E-17	7.83E-06

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.15E-06	4.89E-07	3.10E-09	2.64E-02	3.01E-16	1.43E-04
2	2.00E-04	1.48E-06	7.11E-09	6.05E-02	1.60E-15	3.29E-04
Total	2.08E-04	1.97E-06	1.02E-08	8.69E-02	1.90E-15	4.73E-04

Source: 6

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.64E-05	9.30E-09	5.89E-11	5.05E-04	1.34E-17	2.75E-06
2	3.89E-04	8.24E-08	3.95E-10	3.39E-03	8.11E-17	1.85E-05
	4.05E-04	9.17E-08	4.54E-10	3.90E-03	9.45E-17	2.12E-05

9.76 E-02

5.31 E-02

Ru 4/29/96

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 10.0000 years

Nuclide Detail of Doses

=====

[mrem]

Source: 1

Nuclide	Receptor 1	Receptor 2	Total
88			
-238	1.14E-04	7.86E-04	9.01E-04
-234	2.75E-09	6.70E-09	9.45E-09
H-230	3.03E-13	7.12E-13	1.02E-12
A-226	2.38E-15	5.46E-14	5.69E-14
B-210	4.18E-18	1.81E-17	2.23E-17
85			
-235	1.09E-05	1.66E-04	1.77E-04
A-231	9.96E-09	3.00E-08	3.99E-08
C-227	7.33E-09	2.60E-08	3.34E-08
84			
-234	1.04E-04	2.53E-04	3.56E-04
H-230	2.28E-08	5.37E-08	7.66E-08
A-226	2.69E-10	6.17E-09	6.44E-09
10	6.22E-13	2.69E-12	3.31E-12
D-60	1.70E-09	3.93E-08	4.10E-08

Source: 2

Nuclide	Receptor 1	Receptor 2	Total
88			
-238	1.39E-04	6.02E-04	7.41E-04
-234	3.70E-09	8.59E-09	1.23E-08
H-230	4.10E-13	9.47E-13	1.36E-12
A-226	2.04E-15	3.31E-14	3.52E-14
B-210	5.31E-18	1.57E-17	2.10E-17
85			
-235	1.03E-05	9.88E-05	1.09E-04
A-231	1.33E-08	3.42E-08	4.75E-08
C-227	9.68E-09	2.69E-08	3.66E-08
84			
-234	1.39E-04	3.23E-04	4.63E-04
H-230	3.09E-08	7.13E-08	1.02E-07
A-226	2.30E-10	3.74E-09	3.97E-09
B-210	7.88E-13	2.33E-12	3.11E-12

T : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 10.0000 years

Source: 3

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	4.51E-03	1.82E-03	6.33E-03
U-234	7.87E-09	4.73E-08	5.52E-08
TH-230	8.61E-13	5.24E-12	6.10E-12
RA-226	4.27E-13	2.96E-14	4.57E-13
PB-210	6.43E-17	6.69E-17	1.31E-16
U-235			
U-235	1.17E-03	1.45E-04	1.32E-03
PA-231	8.01E-08	1.71E-07	2.51E-07
AC-227	1.00E-07	1.22E-07	2.22E-07
U-234			
U-234	2.96E-04	1.78E-03	2.08E-03
TH-230	6.49E-08	3.95E-07	4.60E-07
RA-226	4.83E-08	3.35E-09	5.16E-08
PB-210	9.55E-12	9.93E-12	1.95E-11

Source: 4

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	1.43E-04	5.04E-03	5.18E-03
U-234	2.62E-09	1.82E-08	2.09E-08
TH-230	2.91E-13	2.02E-12	2.32E-12
RA-226	5.88E-15	4.53E-13	4.59E-13
PB-210	4.20E-18	7.73E-17	8.15E-17
U-235			
U-235	1.97E-05	1.24E-03	1.26E-03
PA-231	1.00E-08	1.20E-07	1.30E-07
AC-227	7.56E-09	1.31E-07	1.38E-07
U-234			
U-234	9.87E-05	6.86E-04	7.85E-04
TH-230	2.19E-08	1.52E-07	1.74E-07
RA-226	6.64E-10	5.11E-08	5.18E-08
PB-210	6.23E-13	1.15E-11	1.21E-11

: DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 10.0000 years

rce: 5

Nuclide	Receptor 1	Receptor 2	Total
88			
-238	1.21E-02	2.78E-02	3.99E-02
-234	3.70E-07	8.49E-07	1.22E-06
H-230	4.10E-11	9.40E-11	1.35E-10
A-226	2.59E-15	1.85E-14	2.11E-14
B-210	5.11E-16	1.14E-15	1.65E-15
85			
-235	5.67E-04	1.34E-03	1.91E-03
A-231	1.32E-06	3.02E-06	4.34E-06
C-227	9.40E-07	2.10E-06	3.04E-06
84			
-234	1.39E-02	3.19E-02	4.57E-02
H-230	3.07E-06	7.06E-06	1.01E-05
A-226	2.91E-10	2.08E-09	2.37E-09
B-210	7.55E-11	1.69E-10	2.44E-10

rce: 6

Nuclide	Receptor 1	Receptor 2	Total
88			
-238	2.45E-04	1.91E-03	2.16E-03
-234	7.05E-09	4.73E-08	5.44E-08
H-230	7.81E-13	5.24E-12	6.02E-12
A-226	2.96E-15	6.95E-14	7.25E-14
B-210	9.46E-18	6.39E-17	7.33E-17
85			
-235	1.15E-05	9.26E-05	1.04E-04
A-231	2.49E-08	1.69E-07	1.94E-07
C-227	1.73E-08	1.19E-07	1.37E-07
84			
-234	2.67E-04	1.79E-03	2.06E-03
H-230	5.92E-08	3.98E-07	4.57E-07
A-226	3.36E-10	7.90E-09	8.24E-09
B-210	1.41E-12	9.54E-12	1.10E-11

T : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 20.0000 years

```

#####
#####
ëëë Assessment for Time: 3 ëëë
ëëë Time =2.00E+01 yr ëëë
#####
#####

```

Source Information

Source: 1

Location:: Room : 1 x: 28.20 y: 0.00 z: 0.50 [m]

Geometry:: Type: Area Area:8.70E+00 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	2.818E+05
	U-235	1.309E+04
	U-234	3.008E+05
	PA-231	5.535E+00
	TH-230	5.418E+01
	AC-227	1.445E+00
	RA-226	2.342E-01
	PB-210	4.188E-02
	CO-60	7.189E-02

: DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 20.0000 years

Source: 2

Location:: Room : 1 x: 32.50 y: 3.00 z: 0.50 [m]

Geometry:: Type: Area Area:5.80E+00 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration
		[pCi/m2]

	U-238	5.736E+05
--	-------	-----------

	U-235	2.668E+04
--	-------	-----------

	U-234	6.116E+05
--	-------	-----------

	PA-231	1.128E+01
--	--------	-----------

	TH-230	1.102E+02
--	--------	-----------

	AC-227	2.946E+00
--	--------	-----------

	RA-226	4.761E-01
--	--------	-----------

	PB-210	8.515E-02
--	--------	-----------

Source: 3

Location:: Room : 2 x: 0.00 y: 3.00 z: 1.00 [m]

Geometry:: Type: Area Area:1.39E+01 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration
		[pCi/m2]

	U-238	5.566E+05
--	-------	-----------

	U-235	2.588E+04
--	-------	-----------

	U-234	5.936E+05
--	-------	-----------

	PA-231	1.094E+01
--	--------	-----------

	TH-230	1.069E+02
--	--------	-----------

	AC-227	2.858E+00
--	--------	-----------

	RA-226	4.621E-01
--	--------	-----------

	PB-210	8.265E-02
--	--------	-----------

Target: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT

Evaluation Time: 20.0000 years

Source: 4

Location:: Room : 2 x: 20.00 y: 5.80 z: 1.00 [m]

Geometry:: Type: Area Area:1.70E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	1.689E+05
	U-235	7.895E+03
	U-234	1.799E+05
	PA-231	3.338E+00
	TH-230	3.240E+01
	AC-227	8.717E-01
	RA-226	1.400E-01
	PB-210	2.505E-02

Source: 5

Location:: Room : 1 x: 28.00 y: 5.80 z: 1.20 [m]

Geometry:: Type: Area Area:2.08E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 5.000E-01

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	2.133E+04
	U-235	9.997E+02
	U-234	2.266E+04
	PA-231	4.227E-01
	TH-230	4.081E+00
	AC-227	1.104E-01
	RA-226	1.764E-02
	PB-210	3.155E-03

DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 20.0000 years

Source: 6

Location:: Room : 2 x: 16.00 y: 3.00 z: 0.00 [m]

Geometry:: Type: Area Area:1.89E+02 [m2] Direction: z

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	4.097E+04
	U-235	1.899E+03
	U-234	4.397E+04
	PA-231	8.028E-01
	TH-230	7.920E+00
	AC-227	2.096E-01
	RA-226	3.423E-02
	PB-210	6.122E-03

TITLE : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 20.0000 years

```

=====
RESRAD-BUILD Dose Tables
=====

```

Receptor Point-Source Doses

=====

[mrem]

	Source 1	Source 2	Source 3	Source 4	Source 5	Source 6	Total
Receptor 1	2.3E-04	2.9E-04	6.0E-03	2.6E-04	2.7E-02	5.2E-04	3.4E-02
Receptor 2	1.2E-03	1.0E-03	3.8E-03	7.0E-03	6.1E-02	3.8E-03	7.8E-02
Total	1.4E-03	1.3E-03	9.7E-03	7.2E-03	8.8E-02	4.3E-03	1.1E-01

DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT

Evaluation Time: 20.0000 years

Pathway Detail of Doses

=====

[mrem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	3.28E-05	3.60E-09	2.28E-11	1.95E-04	8.90E-18	1.06E-06
2	7.56E-04	1.09E-08	5.23E-11	4.47E-04	4.74E-17	2.43E-06
total	7.88E-04	1.45E-08	7.51E-11	6.42E-04	5.63E-17	3.49E-06

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	2.34E-05	4.88E-09	3.09E-11	2.64E-04	1.21E-17	1.44E-06
2	4.14E-04	1.48E-08	7.10E-11	6.07E-04	6.43E-17	3.30E-06
total	4.38E-04	1.97E-08	1.02E-10	8.71E-04	7.63E-17	4.74E-06

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	5.47E-03	9.30E-09	5.89E-11	5.03E-04	5.33E-17	2.74E-06
2	3.52E-04	8.24E-08	3.95E-10	3.38E-03	3.21E-16	1.84E-05
total	5.82E-03	9.17E-08	4.54E-10	3.88E-03	3.75E-16	2.11E-05

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	7.39E-05	3.45E-09	2.19E-11	1.87E-04	1.98E-17	1.02E-06
2	5.71E-03	3.06E-08	1.47E-10	1.25E-03	1.19E-16	6.82E-06
total	5.78E-03	3.41E-08	1.69E-10	1.44E-03	1.39E-16	7.84E-06

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	6.52E-06	4.89E-07	3.10E-09	2.64E-02	1.20E-15	1.43E-04
2	1.60E-04	1.48E-06	7.11E-09	6.05E-02	6.40E-15	3.29E-04
total	1.67E-04	1.97E-06	1.02E-08	8.69E-02	7.61E-15	4.73E-04

Source: 6

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.64E-05	9.30E-09	5.89E-11	5.05E-04	5.37E-17	2.75E-06
2	3.89E-04	8.25E-08	3.96E-10	3.39E-03	3.24E-16	1.85E-05
total	4.05E-04	9.18E-08	4.54E-10	3.90E-03	3.78E-16	2.12E-05

9.76E-02

5.31E-04

Ln 4/29/96

T : DOE GJPO Bldg 2 Occupancy

file : B20CC.DAT Evaluation Time: 20.0000 years

Nuclide Detail of Doses

eeeeeeeeeeeeeeeeeeeeeeeeeeee

[mrem]

Source: 1

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	1.14E-04	7.86E-04	9.00E-04
U-234	5.49E-09	1.34E-08	1.89E-08
TH-230	1.21E-12	2.85E-12	4.06E-12
RA-226	1.90E-14	4.36E-13	4.55E-13
PB-210	6.31E-17	2.73E-16	3.36E-16
U-235			
U-235	1.09E-05	1.66E-04	1.77E-04
PA-231	1.99E-08	5.99E-08	7.98E-08
AC-227	2.66E-08	9.43E-08	1.21E-07
U-234			
U-234	1.04E-04	2.53E-04	3.56E-04
TH-230	4.57E-08	1.07E-07	1.53E-07
RA-226	1.08E-09	2.46E-08	2.57E-08
10	4.62E-12	2.00E-11	2.46E-11
CO-60	4.57E-10	1.05E-08	1.10E-08

Source: 2

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	1.39E-04	6.02E-04	7.41E-04
U-234	7.40E-09	1.72E-08	2.46E-08
TH-230	1.64E-12	3.79E-12	5.43E-12
RA-226	1.63E-14	2.65E-13	2.81E-13
PB-210	8.01E-17	2.36E-16	3.16E-16
U-235			
U-235	1.03E-05	9.87E-05	1.09E-04
PA-231	2.66E-08	6.84E-08	9.50E-08
AC-227	3.51E-08	9.77E-08	1.33E-07
U-234			
U-234	1.39E-04	3.23E-04	4.63E-04
TH-230	6.18E-08	1.43E-07	2.04E-07
RA-226	9.19E-10	1.49E-08	1.59E-08
PB-210	5.86E-12	1.73E-11	2.31E-11

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT

Evaluation Time: 20.0000 years

Source: 3

Nuclide	Receptor 1	Receptor 2	Total
88			
-238	4.51E-03	1.82E-03	6.33E-03
-234	1.57E-08	9.47E-08	1.10E-07
H-230	3.44E-12	2.10E-11	2.44E-11
A-226	3.41E-12	2.37E-13	3.65E-12
B-210	9.70E-16	1.01E-15	1.98E-15
85			
-235	1.17E-03	1.45E-04	1.32E-03
A-231	1.60E-07	3.41E-07	5.01E-07
C-227	3.62E-07	4.41E-07	8.04E-07
84			
-234	2.96E-04	1.78E-03	2.08E-03
H-230	1.30E-07	7.90E-07	9.20E-07
A-226	1.93E-07	1.34E-08	2.06E-07
B-210	7.09E-11	7.38E-11	1.45E-10

Source: 4

Nuclide	Receptor 1	Receptor 2	Total
88			
-238	1.43E-04	5.04E-03	5.18E-03
-234	5.25E-09	3.65E-08	4.17E-08
H-230	1.16E-12	8.10E-12	9.26E-12
A-226	4.70E-14	3.62E-12	3.67E-12
B-210	6.34E-17	1.16E-15	1.23E-15
85			
-235	1.97E-05	1.24E-03	1.26E-03
A-231	2.01E-08	2.40E-07	2.60E-07
C-227	2.74E-08	4.73E-07	5.01E-07
84			
-234	9.87E-05	6.86E-04	7.85E-04
H-230	4.37E-08	3.05E-07	3.48E-07
A-226	2.65E-09	2.04E-07	2.07E-07
B-210	4.63E-12	8.51E-11	8.97E-11

File : DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 20.0000 years

Source: 5

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	1.21E-02	2.78E-02	3.99E-02
U-234	7.40E-07	1.70E-06	2.44E-06
TH-230	1.64E-10	3.76E-10	5.40E-10
RA-226	1.98E-14	1.26E-13	1.45E-13
PB-210	7.70E-15	1.72E-14	2.49E-14
U-235			
U-235	5.67E-04	1.33E-03	1.90E-03
PA-231	2.63E-06	6.05E-06	8.68E-06
AC-227	3.41E-06	7.60E-06	1.10E-05
U-234			
U-234	1.39E-02	3.19E-02	4.57E-02
TH-230	6.15E-06	1.41E-05	2.03E-05
RA-226	1.11E-09	7.07E-09	8.18E-09
PB-210	5.61E-10	1.25E-09	1.82E-09

Source: 6

Nuclide	Receptor 1	Receptor 2	Total
U-238			
U-238	2.45E-04	1.91E-03	2.16E-03
U-234	1.41E-08	9.47E-08	1.09E-07
TH-230	3.12E-12	2.10E-11	2.41E-11
RA-226	2.36E-14	5.55E-13	5.79E-13
PB-210	1.43E-16	9.63E-16	1.11E-15
U-235			
U-235	1.15E-05	9.26E-05	1.04E-04
PA-231	4.98E-08	3.37E-07	3.87E-07
AC-227	6.28E-08	4.33E-07	4.96E-07
U-234			
U-234	2.67E-04	1.79E-03	2.06E-03
TH-230	1.18E-07	7.95E-07	9.14E-07
RA-226	1.34E-09	3.16E-08	3.29E-08
PB-210	1.05E-11	7.09E-11	8.14E-11

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 30.0000 years

```

=====
Assessment for Time: 4
Time =3.00E+01 yr
=====

```

```

===== Source Information =====

```

Source: 1

Location:: Room : 1 x: 28.20 y: 0.00 z: 0.50 [m]

Geometry:: Type: Area Area:8.70E+00 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	2.817E+05
	U-235	1.309E+04
	U-234	3.007E+05
	PA-231	8.299E+00
	TH-230	8.124E+01
	AC-227	2.962E+00
	RA-226	5.260E-01
	PB-210	1.317E-01
	CO-60	1.927E-02

File : B2OCC.DAT

Evaluation Time: 30.0000 years

Source: 2

Location:: Room : 1 x: 32.50 y: 3.00 z: 0.50 [m]

Geometry:: Type: Area Area:5.80E+00 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	5.734E+05
	U-235	2.667E+04
	U-234	6.114E+05
	PA-231	1.691E+01
	TH-230	1.652E+02
	AC-227	6.037E+00
	RA-226	1.069E+00
	PB-210	2.678E-01

Source: 3

Location:: Room : 2 x: 0.00 y: 3.00 z: 1.00 [m]

Geometry:: Type: Area Area:1.39E+01 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	5.564E+05
	U-235	2.587E+04
	U-234	5.934E+05
	PA-231	1.641E+01
	TH-230	1.603E+02
	AC-227	5.856E+00
	RA-226	1.038E+00
	PB-210	2.599E-01

File : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT Evaluation Time: 30.0000 years

Source: 4

Location:: Room : 2 x: 20.00 y: 5.80 z: 1.00 [m]

Geometry:: Type: Area Area:1.70E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	1.688E+05
	U-235	7.892E+03
	U-234	1.798E+05
	PA-231	5.005E+00
	TH-230	4.858E+01
	AC-227	1.786E+00
	RA-226	3.145E-01
	PB-210	7.875E-02

Source: 5

Location:: Room : 1 x: 28.00 y: 5.80 z: 1.20 [m]

Geometry:: Type: Area Area:2.08E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 5.000E-01

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	1.600E+04
	U-235	7.500E+02
	U-234	1.700E+04
	PA-231	4.756E-01
	TH-230	4.593E+00
	AC-227	1.697E-01
	RA-226	2.973E-02
	PB-210	7.445E-03

Title : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 30.0000 years

Source: 6

Location:: Room : 2 x: 16.00 y: 3.00 z: 0.00 [m]

Geometry:: Type: Area Area:1.89E+02 [m2] Direction: z

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 1.000E-01

Removable fraction: 1.000E-03

Time to Remove: 1.095E+04 [day]

Contamination::	Nuclide	Concentration [pCi/m2]
	U-238	4.096E+04
	U-235	1.898E+03
	U-234	4.396E+04
	PA-231	1.204E+00
	TH-230	1.188E+01
	AC-227	4.296E-01
	RA-226	7.688E-02
	PB-210	1.925E-02

: DOE GJPO Bldg 2 Occupancy

File : B2OCC.DAT

Evaluation Time: 30.0000 years

```

=====
=====
eee                                     eee
eee      RESRAD-BUILD Dose Tables      eee
eee                                     eee
=====
=====
    
```

Receptor Point-Source Doses

=====

[mrem]

	Source	Source	Source	Source	Source	Source	Total
	1	2	3	4	5	6	
Receptor 1	3.3E-05	2.3E-05	5.5E-03	7.4E-05	4.9E-06	1.6E-05	5.6E-03
Receptor 2	7.6E-04	4.1E-04	3.5E-04	5.7E-03	1.2E-04	3.9E-04	7.7E-03
Total	7.9E-04	4.4E-04	5.8E-03	5.8E-03	1.2E-04	4.1E-04	1.3E-02

File : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 30.0000 years

Pathway Detail of Doses

~~~~~

[mrem]

Source: 1

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 3.28E-05 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| 2        | 7.55E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| Total    | 7.88E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |

Source: 2

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 2.34E-05 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| 2        | 4.14E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| Total    | 4.38E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |

Source: 3

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 5.47E-03 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| 2        | 3.52E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| Total    | 5.82E-03 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |

Source: 4

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 7.39E-05 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| 2        | 5.70E-03 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| Total    | 5.78E-03 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |

Source: 5

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 4.89E-06 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| 2        | 1.20E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| Total    | 1.25E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |

Source: 6

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 1.64E-05 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| 2        | 3.89E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |
| Total    | 4.05E-04 | 0.00E+00   | 0.00E+00  | 0.00E+00   | 0.00E+00 | 0.00E+00  |

0

0

4/27/96

: DOE GJPD Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 30.0000 years

# Nuclide Detail of Doses

\*\*\*\*\*

[mrem]

ce: 1

| Nuclide | Receptor<br>1 | Receptor<br>2 | Total    |
|---------|---------------|---------------|----------|
| 8       |               |               |          |
| 238     | 2.53E-05      | 5.82E-04      | 6.07E-04 |
| 234     | 5.77E-11      | 1.33E-09      | 1.39E-09 |
| -230    | 7.57E-15      | 1.74E-13      | 1.82E-13 |
| -226    | 6.37E-14      | 1.47E-12      | 1.53E-12 |
| -210    | 3.03E-17      | 6.98E-16      | 7.29E-16 |
| 5       |               |               |          |
| 235     | 6.80E-06      | 1.57E-04      | 1.63E-04 |
| -231    | 1.02E-09      | 2.36E-08      | 2.46E-08 |
| -227    | 3.46E-09      | 7.97E-08      | 8.31E-08 |
| 4       |               |               |          |
| 234     | 7.25E-07      | 1.67E-05      | 1.74E-05 |
| -230    | 1.90E-10      | 4.38E-09      | 4.57E-09 |
| -226    | 2.40E-09      | 5.53E-08      | 5.77E-08 |
| 10      | 1.46E-12      | 3.36E-11      | 3.51E-11 |
| -60     | 1.23E-10      | 2.82E-09      | 2.95E-09 |

ce: 2

| Nuclide | Receptor<br>1 | Receptor<br>2 | Total    |
|---------|---------------|---------------|----------|
| 8       |               |               |          |
| 238     | 1.86E-05      | 3.25E-04      | 3.43E-04 |
| 234     | 8.30E-12      | 2.85E-10      | 2.93E-10 |
| -230    | 2.71E-15      | 5.92E-14      | 6.19E-14 |
| -226    | 5.43E-14      | 8.91E-13      | 9.45E-13 |
| -210    | 1.47E-17      | 3.09E-16      | 3.23E-16 |
| 5       |               |               |          |
| 235     | 4.69E-06      | 8.58E-05      | 9.05E-05 |
| -231    | 7.01E-10      | 1.26E-08      | 1.33E-08 |
| -227    | 2.60E-09      | 4.57E-08      | 4.83E-08 |
| 4       |               |               |          |
| 234     | 1.04E-07      | 3.58E-06      | 3.68E-06 |
| -230    | 6.80E-11      | 1.49E-09      | 1.56E-09 |
| -226    | 2.04E-09      | 3.35E-08      | 3.56E-08 |
| -210    | 7.06E-13      | 1.48E-11      | 1.56E-11 |

Title : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

Evaluation Time: 30.0000 years

Source: 3

| Nuclide | Receptor<br>1 | Receptor<br>2 | Total    |
|---------|---------------|---------------|----------|
| U-238   |               |               |          |
| U-238   | 4.28E-03      | 2.78E-04      | 4.55E-03 |
| U-234   | 2.47E-09      | 1.15E-10      | 2.58E-09 |
| TH-230  | 7.30E-13      | 4.20E-14      | 7.72E-13 |
| RA-226  | 1.15E-11      | 7.91E-13      | 1.23E-11 |
| PB-210  | 3.95E-15      | 2.21E-16      | 4.18E-15 |
| U-235   |               |               |          |
| U-235   | 1.16E-03      | 7.28E-05      | 1.23E-03 |
| PA-231  | 1.66E-07      | 1.06E-08      | 1.76E-07 |
| AC-227  | 6.15E-07      | 3.97E-08      | 6.54E-07 |
| U-234   |               |               |          |
| U-234   | 3.10E-05      | 1.45E-06      | 3.24E-05 |
| TH-230  | 1.83E-08      | 1.05E-09      | 1.94E-08 |
| RA-226  | 4.33E-07      | 2.98E-08      | 4.63E-07 |
| PB-210  | 1.90E-10      | 1.06E-11      | 2.01E-10 |

Source: 4

| Nuclide | Receptor<br>1 | Receptor<br>2 | Total    |
|---------|---------------|---------------|----------|
| U-238   |               |               |          |
| U-238   | 5.78E-05      | 4.46E-03      | 4.52E-03 |
| U-234   | 2.68E-11      | 2.07E-09      | 2.09E-09 |
| TH-230  | 9.38E-15      | 7.24E-13      | 7.34E-13 |
| RA-226  | 1.58E-13      | 1.22E-11      | 1.23E-11 |
| PB-210  | 5.00E-17      | 3.86E-15      | 3.91E-15 |
| U-235   |               |               |          |
| U-235   | 1.57E-05      | 1.21E-03      | 1.23E-03 |
| PA-231  | 2.24E-09      | 1.73E-07      | 1.75E-07 |
| AC-227  | 8.39E-09      | 6.48E-07      | 6.56E-07 |
| U-234   |               |               |          |
| U-234   | 3.36E-07      | 2.59E-05      | 2.62E-05 |
| TH-230  | 2.35E-10      | 1.82E-08      | 1.84E-08 |
| RA-226  | 5.94E-09      | 4.58E-07      | 4.64E-07 |
| PB-210  | 2.41E-12      | 1.86E-10      | 1.88E-10 |

~ : DOE GJPD Bldg 2 Occupancy

File : B2OCC.DAT Evaluation Time: 30.0000 years

ce: 5

| nuclide | Receptor<br>1 | Receptor<br>2 | Total    |
|---------|---------------|---------------|----------|
| 8       |               |               |          |
| 238     | 3.73E-06      | 9.17E-05      | 9.54E-05 |
| 234     | 1.13E-11      | 2.76E-10      | 2.88E-10 |
| -230    | 1.37E-15      | 3.36E-14      | 3.50E-14 |
| -226    | 9.09E-15      | 2.23E-13      | 2.32E-13 |
| -210    | 5.01E-18      | 1.23E-16      | 1.28E-16 |
| 5       |               |               |          |
| 235     | 1.02E-06      | 2.50E-05      | 2.60E-05 |
| -231    | 1.55E-10      | 3.82E-09      | 3.97E-09 |
| -227    | 5.07E-10      | 1.25E-08      | 1.30E-08 |
| 4       |               |               |          |
| 234     | 1.41E-07      | 3.46E-06      | 3.60E-06 |
| -230    | 3.42E-11      | 8.40E-10      | 8.75E-10 |
| -226    | 3.41E-10      | 8.37E-09      | 8.71E-09 |
| -210    | 2.40E-13      | 5.90E-12      | 6.14E-12 |

ce: 6

| nuclide | Receptor<br>1 | Receptor<br>2 | Total    |
|---------|---------------|---------------|----------|
| 8       |               |               |          |
| 238     | 1.55E-05      | 3.67E-04      | 3.83E-04 |
| 234     | 3.23E-13      | 7.66E-12      | 7.98E-12 |
| -230    | 1.93E-16      | 4.58E-15      | 4.77E-15 |
| -226    | 7.86E-14      | 1.86E-12      | 1.94E-12 |
| -210    | 8.50E-20      | 2.02E-18      | 2.10E-18 |
| 5       |               |               |          |
| 235     | 8.86E-07      | 2.10E-05      | 2.19E-05 |
| -231    | 2.53E-10      | 5.99E-09      | 6.24E-09 |
| -227    | 1.05E-09      | 2.49E-08      | 2.60E-08 |
| 4       |               |               |          |
| 234     | 4.08E-09      | 9.67E-08      | 1.01E-07 |
| -230    | 4.88E-12      | 1.16E-10      | 1.21E-10 |
| -226    | 2.98E-09      | 7.06E-08      | 7.36E-08 |
| -210    | 4.11E-15      | 9.76E-14      | 1.02E-13 |

File : DOE GJPO Bldg 2 Occupancy

File : B20CC.DAT

```

=====
=====
    RESRAD-BUILD Dose (Time) Tables
=====
=====
=====
    
```

# Receptor Doses By Time

=====

[mrem]

|   | 1.00E+00 | 1.00E+01 | 2.00E+01 | 3.00E+01 |
|---|----------|----------|----------|----------|
| 1 | 3.38E-02 | 3.38E-02 | 3.38E-02 | 5.62E-03 |
| 2 | 7.78E-02 | 7.78E-02 | 7.78E-02 | 7.74E-03 |

# Receptor Doses Per Year

=====

[mrem/yr]

|   | 1.00E+00 | 1.00E+01 | 2.00E+01 | 3.00E+01 |
|---|----------|----------|----------|----------|
| 1 | 5.14E-02 | 5.14E-02 | 5.14E-02 | 8.55E-03 |
| 2 | 1.18E-01 | 1.18E-01 | 1.18E-01 | 1.18E-02 |

See page 15 for maximum  
inhalation and ingestion doses.

External dose and radon dose  
are disregarded because they  
were measured.

Thomas 4/28/96

DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

*Chow*

```

=====
=====
eee                                     eee
eee      RESRAD-BUILD Table of Contents  eee
eee                                     eee
=====
=====

```

|                                   |     |
|-----------------------------------|-----|
| Input Parameters.....             | 0-1 |
| For Each Time (I) :.....          |     |
| Time Specific Parameters.....     | I-1 |
| Receptor-Source Dose Summary..... | I-2 |
| Dose by Pathway Detail.....       | I-3 |
| Dose by Nuclide Detail.....       | I-4 |
| Full Summary.....                 | F-1 |

T : DOE GJPO Bldg 2 Demolition

ile : B2DEM.DAT

```

#####
#####
eee                                     eee
eee   RESRAD-BUILD Input Parameters   eee
eee                                     eee
#####
#####
    
```

Number of Sources : 6  
 Number of Receptors: 1  
 Total Time : 1.000000E+01 days  
 Fraction Inside : 3.000000E-01

##### Receptor Information #####

| Receptor | Room | x<br>[m] | y<br>[m] | z<br>[m] | FracTime | Inhalation<br>[m3/day] | Ingestion(Dust)<br>[m2/hr] |
|----------|------|----------|----------|----------|----------|------------------------|----------------------------|
| 1        | 1    | 15.000   | 3.000    | 1.000    | 1.000    | 1.80E+01               | 1.00E-04                   |

##### Receptor-Source Relationship #####

| Receptor | Source 1           |                   | Source 2           |                   | Source 3           |                   | Source 4           |                   | Source 5           |                   |
|----------|--------------------|-------------------|--------------------|-------------------|--------------------|-------------------|--------------------|-------------------|--------------------|-------------------|
|          | Density<br>[g/cm3] | Thickness<br>[cm] | Density<br>[g/cm3] | Thickness<br>[cm] | Density<br>[g/cm3] | Thickness<br>[cm] | Density<br>[g/cm3] | Thickness<br>[cm] | Density<br>[g/cm3] | Thickness<br>[cm] |
| 1        | 5.000E-01          | 1.000E+00         | 5.000E-01          | 2.000E+00         | 5.000E-01          | 1.500E+00         | 5.000E-01          | 2.000E+00         | 2.000E+00          | 1.000E-02         |

| Receptor | Source 6           |                   |
|----------|--------------------|-------------------|
|          | Density<br>[g/cm3] | Thickness<br>[cm] |
| 1        | 2.500E+00          | 1.000E+01         |



: DOE GJPO Bldg 2 Demolition

ile : B2DEM.DAT

Building Information

Building Air Exchange Rate: 1.50E+01 1/hr

| Height[m]    | Air Exchanges [m3/hr] |                  |
|--------------|-----------------------|------------------|
| Area [m2]    |                       |                  |
|              | *****                 |                  |
|              | *                     | *                |
|              | *                     | *                |
|              | *                     | <=Q01: 9.00E+03  |
| H1: 3.000    | * Room 1              | * Q10 : 9.00E+03 |
|              | * LAMBDA: 1.50E+01    | *                |
| Area 200.000 | *                     | *                |
|              | *                     | *                |
|              | *****                 |                  |

Deposition velocity: 1.00E-02 [m/s] Resuspension Rate: 1.00E-06 [1/s]

File : DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

Source Information

Source: 1

Location:: Room : 1 x: 28.20 y: 0.00 z: 0.50[m]

Geometry:: Type: Area Area:8.70E+00 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 2.000E-01

Removable fraction: 1.000E-02

Time to Remove: 1.100E+01 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factors

Ingestion Inhalation External External Submersion

(Surface) (Volume)

[pCi/m2] [mrem/pCi] [mrem/pCi] [mrem/yr/ (pCi/m2)] [mrem/yr/ (pCi/m3)] [mrem/yr/ (pCi/m3)]

|        |           |           |           |           |           |           |
|--------|-----------|-----------|-----------|-----------|-----------|-----------|
| U-238  | 2.820E+05 | 2.500E-04 | 1.200E-01 | 3.530E-06 | 9.510E-08 | 1.600E-04 |
| U-235  | 1.310E+04 | 2.500E-04 | 1.200E-01 | 1.950E-05 | 4.740E-07 | 9.030E-04 |
| U-234  | 3.010E+05 | 2.600E-04 | 1.300E-01 | 8.750E-08 | 2.520E-10 | 8.930E-07 |
| PA-231 | 0.000E+00 | 1.100E-02 | 1.300E+00 | 4.760E-06 | 1.190E-07 | 2.010E-04 |
| TH-230 | 0.000E+00 | 5.300E-04 | 3.200E-01 | 8.780E-08 | 7.570E-10 | 2.040E-06 |
| AC-227 | 0.000E+00 | 1.500E-02 | 6.700E+00 | 4.530E-05 | 1.260E-06 | 2.160E-03 |
| RA-226 | 0.000E+00 | 1.100E-03 | 7.900E-03 | 1.940E-04 | 7.000E-06 | 1.040E-02 |
| PB-210 | 0.000E+00 | 6.700E-03 | 2.100E-02 | 4.140E-07 | 3.820E-09 | 1.430E-05 |
| CO-60  | 1.000E+00 | 2.600E-05 | 1.500E-04 | 2.750E-04 | 1.020E-05 | 1.470E-02 |

Source: 2

Location:: Room : 1 x: 32.50 y: 3.00 z: 0.50[m]  
Geometry:: Type: Area Area:5.80E+00 [m2] Direction: x  
Pathway ::  
Direct Ingestion Rate: 0.000E+00 [1/hr]  
Fraction released to air: 2.000E-01  
Removable fraction: 1.000E-02  
Time to Remove: 1.100E+01 [day]  
Radon Release Fraction: 0.000E+00

Contamination::

| Nuclide Concentration | Dose Conversion Factors |            |                        |                        |                        |           |
|-----------------------|-------------------------|------------|------------------------|------------------------|------------------------|-----------|
|                       | Ingestion               | Inhalation | External               | External               | Submersion             |           |
|                       |                         |            | (Surface)              | (Volume)               |                        |           |
| [pCi/m2]              | [mrem/pCi]              | [mrem/pCi] | [mrem/yr/<br>(pCi/m2)] | [mrem/yr/<br>(pCi/m3)] | [mrem/yr/<br>(pCi/m3)] |           |
| U-238                 | 5.740E+05               | 2.500E-04  | 1.200E-01              | 3.530E-06              | 9.510E-08              | 1.600E-04 |
| U-235                 | 2.670E+04               | 2.500E-04  | 1.200E-01              | 1.950E-05              | 4.740E-07              | 9.030E-04 |
| Th-234                | 6.120E+05               | 2.600E-04  | 1.300E-01              | 8.750E-08              | 2.520E-10              | 8.930E-07 |
| PA-231                | 0.000E+00               | 1.100E-02  | 1.300E+00              | 4.760E-06              | 1.190E-07              | 2.010E-04 |
| TH-230                | 0.000E+00               | 5.300E-04  | 3.200E-01              | 8.780E-08              | 7.570E-10              | 2.040E-06 |
| AC-227                | 0.000E+00               | 1.500E-02  | 6.700E+00              | 4.530E-05              | 1.260E-06              | 2.160E-03 |
| RA-226                | 0.000E+00               | 1.100E-03  | 7.900E-03              | 1.940E-04              | 7.000E-06              | 1.040E-02 |
| PB-210                | 0.000E+00               | 6.700E-03  | 2.100E-02              | 4.140E-07              | 3.820E-09              | 1.430E-05 |

Time : DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

Source: 3

Location:: Room : 1 x: 0.00 y: 3.00 z: 1.00[m]  
 Geometry:: Type: Area Area:1.39E+01 [m2] Direction: x  
 Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]  
 Fraction released to air: 2.000E-01  
 Removable fraction: 1.000E-02  
 Time to Remove: 1.100E+01 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factors

aaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaa

|          | Ingestion  | Inhalation | External<br>(Surface)  | External<br>(Volume)   | Submersion             |
|----------|------------|------------|------------------------|------------------------|------------------------|
| [pCi/m2] | [mrem/pCi] | [mrem/pCi] | [mrem/yr/<br>(pCi/m2)] | [mrem/yr/<br>(pCi/m3)] | [mrem/yr/<br>(pCi/m3)] |

|        |           |           |           |           |           |           |
|--------|-----------|-----------|-----------|-----------|-----------|-----------|
| U-238  | 5.570E+05 | 2.500E-04 | 1.200E-01 | 3.530E-06 | 9.510E-08 | 1.600E-04 |
| -235   | 2.590E+04 | 2.500E-04 | 1.200E-01 | 1.950E-05 | 4.740E-07 | 9.030E-04 |
| -234   | 5.940E+05 | 2.600E-04 | 1.300E-01 | 8.750E-08 | 2.520E-10 | 8.930E-07 |
| PA-231 | 0.000E+00 | 1.100E-02 | 1.300E+00 | 4.760E-06 | 1.190E-07 | 2.010E-04 |
| TH-230 | 0.000E+00 | 5.300E-04 | 3.200E-01 | 8.780E-08 | 7.570E-10 | 2.040E-06 |
| AC-227 | 0.000E+00 | 1.500E-02 | 6.700E+00 | 4.530E-05 | 1.260E-06 | 2.160E-03 |
| RA-226 | 0.000E+00 | 1.100E-03 | 7.900E-03 | 1.940E-04 | 7.000E-06 | 1.040E-02 |
| PB-210 | 0.000E+00 | 6.700E-03 | 2.100E-02 | 4.140E-07 | 3.820E-09 | 1.430E-05 |

: DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

Source: 4

Location:: Room : 1 x: 20.00 y: 5.80 z: 1.00[m]

Geometry:: Type: Area Area:1.70E+01 [m2] Direction: y

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 2.000E-01

Removable fraction: 1.000E-02

Time to Remove: 1.100E+01 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factors

aaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaa

Ingestion Inhalation External External Submersion  
(Surface) (Volume)

[pCi/m2] [mrem/pCi] [mrem/pCi] [mrem/yr/  
(pCi/m2)] [mrem/yr/  
(pCi/m3)] [mrem/yr/  
(pCi/m3)]

|        |           |           |           |           |           |           |
|--------|-----------|-----------|-----------|-----------|-----------|-----------|
| U-238  | 1.690E+05 | 2.500E-04 | 1.200E-01 | 3.530E-06 | 9.510E-08 | 1.600E-04 |
| -235   | 7.900E+03 | 2.500E-04 | 1.200E-01 | 1.950E-05 | 4.740E-07 | 9.030E-04 |
| -234   | 1.800E+05 | 2.600E-04 | 1.300E-01 | 8.750E-08 | 2.520E-10 | 8.930E-07 |
| PA-231 | 0.000E+00 | 1.100E-02 | 1.300E+00 | 4.760E-06 | 1.190E-07 | 2.010E-04 |
| TH-230 | 0.000E+00 | 5.300E-04 | 3.200E-01 | 8.780E-08 | 7.570E-10 | 2.040E-06 |
| AC-227 | 0.000E+00 | 1.500E-02 | 6.700E+00 | 4.530E-05 | 1.260E-06 | 2.160E-03 |
| RA-226 | 0.000E+00 | 1.100E-03 | 7.900E-03 | 1.940E-04 | 7.000E-06 | 1.040E-02 |
| PB-210 | 0.000E+00 | 6.700E-03 | 2.100E-02 | 4.140E-07 | 3.820E-09 | 1.430E-05 |

|        |           |           |           |           |           |           |
|--------|-----------|-----------|-----------|-----------|-----------|-----------|
| U-238  | 3.200E+04 | 2.500E-04 | 1.200E-01 | 3.530E-06 | 9.510E-08 | 1.600E-04 |
| -235   | 1.500E+03 | 2.500E-04 | 1.200E-01 | 1.950E-05 | 4.740E-07 | 9.030E-04 |
| J-234  | 3.400E+04 | 2.600E-04 | 1.300E-01 | 8.750E-08 | 2.520E-10 | 8.930E-07 |
| PA-231 | 0.000E+00 | 1.100E-02 | 1.300E+00 | 4.760E-06 | 1.190E-07 | 2.010E-04 |
| TH-230 | 0.000E+00 | 5.300E-04 | 3.200E-01 | 8.780E-08 | 7.570E-10 | 2.040E-06 |
| AC-227 | 0.000E+00 | 1.500E-02 | 6.700E+00 | 4.530E-05 | 1.260E-06 | 2.160E-03 |
| RA-226 | 0.000E+00 | 1.100E-03 | 7.900E-03 | 1.940E-04 | 7.000E-06 | 1.040E-02 |
| PB-210 | 0.000E+00 | 6.700E-03 | 2.100E-02 | 4.140E-07 | 3.820E-09 | 1.430E-05 |

: DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

Source: 6

Location:: Room : 1 x: 16.00 y: 3.00 z: 0.00[m]

Geometry:: Type: Area Area:1.89E+02 [m2] Direction: z

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 2.000E-01

Removable fraction: 1.000E-02

Time to Remove: 1.100E+01 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factors

aaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaa

|          | Ingestion  | Inhalation | External<br>(Surface)  | External<br>(Volume)   | Submersion             |
|----------|------------|------------|------------------------|------------------------|------------------------|
| [pCi/m2] | [mrem/pCi] | [mrem/pCi] | [mrem/yr/<br>(pCi/m2)] | [mrem/yr/<br>(pCi/m3)] | [mrem/yr/<br>(pCi/m3)] |

|        |           |           |           |           |           |           |
|--------|-----------|-----------|-----------|-----------|-----------|-----------|
| U-238  | 4.100E+04 | 2.500E-04 | 1.200E-01 | 3.530E-06 | 9.510E-08 | 1.600E-04 |
| -235   | 1.900E+03 | 2.500E-04 | 1.200E-01 | 1.950E-05 | 4.740E-07 | 9.030E-04 |
| J-234  | 4.400E+04 | 2.600E-04 | 1.300E-01 | 8.750E-08 | 2.520E-10 | 8.930E-07 |
| PA-231 | 0.000E+00 | 1.100E-02 | 1.300E+00 | 4.760E-06 | 1.190E-07 | 2.010E-04 |
| TH-230 | 0.000E+00 | 5.300E-04 | 3.200E-01 | 8.780E-08 | 7.570E-10 | 2.040E-06 |
| AC-227 | 0.000E+00 | 1.500E-02 | 6.700E+00 | 4.530E-05 | 1.260E-06 | 2.160E-03 |
| RA-226 | 0.000E+00 | 1.100E-03 | 7.900E-03 | 1.940E-04 | 7.000E-06 | 1.040E-02 |
| PB-210 | 0.000E+00 | 6.700E-03 | 2.100E-02 | 4.140E-07 | 3.820E-09 | 1.430E-05 |

T : DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT Evaluation Time: 0.000000 years

#####  
#####  
eee Assessment for Time: 1 eee  
eee Time =0.00E+00 yr eee  
#####  
#####

##### Source Information #####

Source: 1

Location:: Room : 1 x: 28.20 y: 0.00 z: 0.50 [m]  
Geometry:: Type: Area Area:8.70E+00 [m2] Direction: y  
Pathway ::  
Direct Ingestion Rate: 0.000E+00 [1/hr]  
Fraction released to air: 2.000E-01  
Removable fraction: 1.000E-02  
Time to Remove: 1.100E+01 [day]

| Contamination:: | Nuclide | Concentration<br>[pCi/m2] |
|-----------------|---------|---------------------------|
|                 | U-238   | 2.820E+05                 |
|                 | U-235   | 1.310E+04                 |
|                 | U-234   | 3.010E+05                 |
|                 | PA-231  | 0.000E+00                 |
|                 | TH-230  | 0.000E+00                 |
|                 | AC-227  | 0.000E+00                 |
|                 | RA-226  | 0.000E+00                 |
|                 | PB-210  | 0.000E+00                 |
|                 | CO-60   | 1.000E+00                 |



: DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT Evaluation Time: 0.000000 years

ce: 2

Location:: Room : 1 x: 32.50 y: 3.00 z: 0.50 [m]

Geometry:: Type: Area Area:5.80E+00 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 2.000E-01

Removable fraction: 1.000E-02

Time to Remove: 1.100E+01 [day]

Contamination:: Nuclide Concentration

[pCi/m2]

U-238 5.740E+05

U-235 2.670E+04

U-234 6.120E+05

PA-231 0.000E+00

TH-230 0.000E+00

AC-227 0.000E+00

RA-226 0.000E+00

PB-210 0.000E+00

ce: 3

Location:: Room : 1 x: 0.00 y: 3.00 z: 1.00 [m]

Geometry:: Type: Area Area:1.39E+01 [m2] Direction: x

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 2.000E-01

Removable fraction: 1.000E-02

Time to Remove: 1.100E+01 [day]

Contamination:: Nuclide Concentration

[pCi/m2]

U-238 5.570E+05

U-235 2.590E+04

U-234 5.940E+05

PA-231 0.000E+00

TH-230 0.000E+00

AC-227 0.000E+00

RA-226 0.000E+00

PB-210 0.000E+00

T : DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT Evaluation Time: 0.000000 years

Source: 4

Location:: Room : 1 x: 20.00 y: 5.80 z: 1.00 [m]  
Geometry:: Type: Area Area:1.70E+01 [m2] Direction: y  
Pathway ::  
Direct Ingestion Rate: 0.000E+00 [1/hr]  
Fraction released to air: 2.000E-01  
Removable fraction: 1.000E-02  
Time to Remove: 1.100E+01 [day]

| Contamination:: | Nuclide | Concentration<br>[pCi/m2] |
|-----------------|---------|---------------------------|
|                 | U-238   | 1.690E+05                 |
|                 | U-235   | 7.900E+03                 |
|                 | U-234   | 1.800E+05                 |
|                 | PA-231  | 0.000E+00                 |
|                 | TH-230  | 0.000E+00                 |
|                 | AC-227  | 0.000E+00                 |
|                 | RA-226  | 0.000E+00                 |
|                 | PB-210  | 0.000E+00                 |

Source: 5

Location:: Room : 1 x: 28.00 y: 5.80 z: 1.20 [m]  
Geometry:: Type: Area Area:2.08E+01 [m2] Direction: y  
Pathway ::  
Direct Ingestion Rate: 0.000E+00 [1/hr]  
Fraction released to air: 2.000E-01  
Removable fraction: 5.000E-01  
Time to Remove: 1.100E+01 [day]

| Contamination:: | Nuclide | Concentration<br>[pCi/m2] |
|-----------------|---------|---------------------------|
|                 | U-238   | 3.200E+04                 |
|                 | U-235   | 1.500E+03                 |
|                 | U-234   | 3.400E+04                 |
|                 | PA-231  | 0.000E+00                 |
|                 | TH-230  | 0.000E+00                 |
|                 | AC-227  | 0.000E+00                 |
|                 | RA-226  | 0.000E+00                 |
|                 | PB-210  | 0.000E+00                 |

: DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT Evaluation Time: 0.000000 years

ce: 6

Location:: Room : 1 x: 16.00 y: 3.00 z: 0.00 [m]

Geometry:: Type: Area Area:1.89E+02 [m2] Direction: z

Pathway ::

Direct Ingestion Rate: 0.000E+00 [1/hr]

Fraction released to air: 2.000E-01

Removable fraction: 1.000E-02

Time to Remove: 1.100E+01 [day]

| Contamination:: | Nuclide | Concentration<br>[pCi/m2] |
|-----------------|---------|---------------------------|
|                 | U-238   | 4.100E+04                 |
|                 | U-235   | 1.900E+03                 |
|                 | U-234   | 4.400E+04                 |
|                 | PA-231  | 0.000E+00                 |
|                 | TH-230  | 0.000E+00                 |
|                 | AC-227  | 0.000E+00                 |
|                 | RA-226  | 0.000E+00                 |
|                 | PB-210  | 0.000E+00                 |

T : DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

Evaluation Time: 0.000000 years

```

=====
=====
eee                                     eee
eee      RESRAD-BUILD Dose Tables      eee
eee                                     eee
=====
=====
    
```

# Receptor Point-Source Doses

=====

[mrem]

|            | Source  | Source  | Source  | Source  | Source  | Source  | Total   |
|------------|---------|---------|---------|---------|---------|---------|---------|
|            | 1       | 2       | 3       | 4       | 5       | 6       |         |
| Receptor 1 | 3.0E-02 | 4.0E-02 | 9.3E-02 | 3.5E-02 | 4.0E-01 | 9.4E-02 | 6.9E-01 |
| Total      | 3.0E-02 | 4.0E-02 | 9.3E-02 | 3.5E-02 | 4.0E-01 | 9.4E-02 | 6.9E-01 |

```
file : B2DEM.DAT
```

Evaluation Time: 0.000000 years

[mrem]

|          |          |            |           |            |          |           |
|----------|----------|------------|-----------|------------|----------|-----------|
| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
| 1        | 1.79E-05 | 3.91E-07   | 3.45E-09  | 2.95E-02   | 2.20E-29 | 8.02E-05  |
| Total    | 1.79E-05 | 3.91E-07   | 3.45E-09  | 2.95E-02   | 2.20E-29 | 8.02E-05  |

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 1.15E-05 | 5.31E-07   | 4.68E-09  | 4.00E-02   | 2.98E-29 | 1.09E-04  |
| Total    | 1.15E-05 | 5.31E-07   | 4.68E-09  | 4.00E-02   | 2.98E-29 | 1.09E-04  |

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 3.73E-05 | 1.23E-06   | 1.09E-08  | 9.30E-02   | 6.93E-29 | 2.53E-04  |
| Total    | 3.73E-05 | 1.23E-06   | 1.09E-08  | 9.30E-02   | 6.93E-29 | 2.53E-04  |

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 1.07E-04 | 4.58E-07   | 4.04E-09  | 3.45E-02   | 2.57E-29 | 9.38E-05  |
| Total    | 1.07E-04 | 4.58E-07   | 4.04E-09  | 3.45E-02   | 2.57E-29 | 9.38E-05  |

| Receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
|----------|----------|------------|-----------|------------|----------|-----------|
| 1        | 5.46E-06 | 5.31E-06   | 4.69E-08  | 3.99E-01   | 2.97E-28 | 1.09E-03  |
| Total    | 5.46E-06 | 5.31E-06   | 4.69E-08  | 3.99E-01   | 2.97E-28 | 1.09E-03  |

|          |          |            |           |            |          |           |
|----------|----------|------------|-----------|------------|----------|-----------|
| ce: 6    |          |            |           |            |          |           |
| receptor | External | Deposition | Immersion | Inhalation | Radon    | Ingestion |
| 1        | 2.38E-05 | 1.23E-06   | 1.09E-08  | 9.34E-02   | 6.98E-29 | 2.54E-04  |
| total    | 2.38E-05 | 1.23E-06   | 1.09E-08  | 9.34E-02   | 6.98E-29 | 2.54E-04  |

6.89 E-01

1.88 E-03

RH 4/29/96

T : DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

Evaluation Time: 0.000000 years

# Nuclide Detail of Doses

~~~~~

[mrem]

Source: 1

Nuclide Receptor		Total
1		
U-238		
U-238	1.34E-02	1.34E-02
U-235		
U-235	6.27E-04	6.27E-04
U-234		
U-234	1.55E-02	1.55E-02
CO-60		
CO-60	3.61E-09	3.61E-09

Source: 2

Nuclide Receptor		Total
1		
U-238		
U-238	1.82E-02	1.82E-02
U-235		
U-235	8.50E-04	8.50E-04
U-234		
U-234	2.10E-02	2.10E-02

Source: 3

Nuclide Receptor		Total
1		
U-238		
U-238	4.24E-02	4.24E-02
U-235		
U-235	1.98E-03	1.98E-03
U-234		
U-234	4.89E-02	4.89E-02

: DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT Evaluation Time: 0.000000 years

ce: 4

	Receptor	Total
	1	
8		
238	1.58E-02	1.58E-02
5		
235	7.57E-04	7.57E-04
4		
234	1.81E-02	1.81E-02

ce: 5

	Receptor	Total
	1	
8		
238	1.82E-01	1.82E-01
5		
235	8.53E-03	8.53E-03
4		
234	2.10E-01	2.10E-01

ce: 6

	Receptor	Total
	1	
8		
238	4.24E-02	4.24E-02
5		
235	1.97E-03	1.97E-03
4		
234	4.93E-02	4.93E-02

T : DOE GJPO Bldg 2 Demolition

File : B2DEM.DAT

```

=====
RESRAD-BUILD Dose (Time) Tables
=====

```

Receptor Doses By Time

=====

[mrem]

Time [yr]

0.00E+00

1 6.91E-01

Receptor Doses Per Year

=====

[mrem/yr]

Time [yr]

0.00E+00

1 2.53E+01

*This summary includes external dose
which has been measured, not modeled.
Disregard this quantity and see page 15
for inhalation and ingestion doses.*

*R. Morris
4/21/96*