

7

4

This is an informal report intended primarily for internal or limited external distribution. (The opinions and conclusions stated are those of the author and may or may not be those of the laboratory.) This report is not to be given additional external distribution or cited in external documents without the consent of the author or LLL Technical Information Department.

UCID- 16407

This document contains neither recommendations nor conclusions of the Energy Research and Development Administration. It is the property of the Government and is loaned to your agency; it and its contents are not to be distributed outside your agency without the express written consent of the Energy Research and Development Administration.

95000



## LAWRENCE LIVERMORE LABORATORY

*University of California/Livermore, California*

# SEISMIC EFFECTS ON A PROPOSED UNDERGROUND REACTOR FACILITY

BY THE FOLLOWING

F. J. Tokarz

R. C. Murray

February 26, 1973

### NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

RESTRICTED DATA  
DO NOT DISTRIBUTE  
DEFENSE INFORMATION  
CLASSIFIED BY  
THE INFORMATION

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

b7

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

LAWRENCE LIVERMORE LABORATORY - UNIVERSITY OF CALIFORNIA <b>ENGINEERING NOTE</b>		FILE NO. ENN 73-45	PAGE 1
SUBJECT SEISMIC EFFECTS ON A PROPOSED UNDERGROUND REACTOR FACILITY		NAME F.Tokarz/R. Murray	
		DATE February 26, 1973	

### INTRODUCTION

A study was conducted to determine the seismic effects on the containment structure of a proposed underground reactor facility. Simplified and often inadequate building code equivalent static design procedures frequently used for conventional reactor systems are not adequate for partially buried or fully buried reactor systems. A sophisticated dynamic analysis which can consider soil-structure interaction effects resulting from both seismic displacements and forces must be employed. One such approach would be to use the finite element method\*. This note gives the results of using such an approach to consider both the static overburden and dynamic earthquake effects on the containment structure of the proposed underground reactor facility.

The first step in the seismic analysis and evaluation of a reactor facility is the postulation of possible earthquake ground motions at the site. Once the reactor site has been selected an investigation of the seismicity and geology of the area permits estimates of both potential earthquake magnitudes and their potential epicenter locations. These estimates coupled with knowledge of site soil conditions permits estimates of peak ground motions and frequency distributions of ground motion for the site.

Two approaches are usually used to predict the ground accelerations resulting from any given earthquake. One approach uses recorded surface motions from past earthquakes to extrapolate directly motions at some epicentral distance. The other estimates the bedrock motion underlying the site and then uses detailed site properties to compute both surface and subsurface motion above the bedrock level. For this analysis the latter approach is assumed.

Since no specific site is being considered here the prediction of earthquake motions for use in the analysis was quite arbitrary. Similarly the choice of detail site properties required to define the media surrounding the containment structure was quite arbitrary. However, the earthquake motions used here are representative of the magnitude and frequency content of previous recorded earthquake ground motions measured in bedrock. In addition, the material properties used for the geological media are considered to be reasonable estimates.

### ANALYSIS

Figure 1 defines the containment structure and the extent of the surrounding media considered. The containment structure consists of a steel liner surrounded by 5 ft of concrete. The steel liner consists of a 90 ft diameter cylinder closed on top by a spherical dome. The steel liner is 1.8 in. thick. Both the steel liner and the concrete are integral with a 10 ft thick foundation which is located 340 ft below the surface. Extending from the top of the spherical dome to the surface is a 10 ft diameter (1.25 in. thick) steel pipe used for access to the contained area.

\*The finite element method is a technique for determining the displacements, strains and stresses in continuous bodies (structures). The basic concept assumes that the entire structure may be considered as an assemblage of substructures or elements. The structure is divided into a finite number of such elements which are interconnected at nodal points. All of the elements are then assembled and analyzed by the displacement method of structure analysis. The finite element method is readily applicable to treatment of non-homogenous structures with complex shapes and loading. Non-linear effects may be included if desireable.

LAWRENCE LIVERMORE LABORATORY - UNIVERSITY OF CALIFORNIA <b>ENGINEERING NOTE</b>		FILE NO. ENN 73-45	PAGE 2
SUBJECT <b>SEISMIC EFFECTS ON A PROPOSED UNDERGROUND REACTOR FACILITY</b>		NAME F.Tokarz/R. Murray	
		DATE February 26, 1973	

The model extends 500 ft below the surface where bedrock is assumed. The horizontal boundaries are located at 500 ft from the axis of the symmetry. Various different geological media are considered as shown in Figure 1.

Two types of loading are considered - an overburden loading and a horizontal earthquake loading\*. Analyses were conducted separately and then superimposed. As indicated earlier the earthquake loading is applied at the assumed bedrock level. The 1971 San Fernando (Pacoima Dam) acceleration record normalized at 0.2 g maximum acceleration was used.

### RESULTS

All of the calculations were made using the finite element computer programs called DTVIS2 and GHOSH. Both codes can treat axisymmetric structures subjected to dynamic loads. In addition, GHOSH can consider non-axisymmetric loading and DTVIS2 can treat thermal problems if desired. For more information regarding these programs see ENW-72-13 and the DTVIS2 User's Manual.

The results are summarized in Figures 2 through 7. The dynamic analysis considered the lowest five fundamental modes of vibration. Five percent critical viscous damping was used in all modes and all materials. Figure 2 gives the first and second mode shapes (magnified considerably), the first five natural periods, and percent participation factors of the combined containment structure and surrounding media. As indicated by the 68 percent participation factor, the combined containment structure and media is responding primarily in the first mode.

Figure 3 gives some of the results obtained from the static overburden analysis. Given are the deformed shape (magnified 500 times) and stress contours of maximum and minimum principal stresses and maximum shear stress. Such information would prove helpful when determining excavation cuts and the selection of backfill material. By excluding the containment structure, backfill material and sand an analysis could be made to evaluate the stability of excavation slopes.

Figures 4 through 7 give plots of maximum axial and hoop stresses versus depth in the steel liner and concrete for both static overburden loading and earthquake loading.

For the static overburden loading maximum stresses in the steel and concrete are:

	Axial Stress (psi)	Hoop Stress (psi)
Steel pipe	- 30,000	- 5,000
Steel pipe/dome	- 42,000	- 48,000
Steel dome	- 17,000	- 12,000
Steel cylinder	- 22,000	- 11,000
Concrete dome	- 425	- 600
Concrete cylinder	- 600	- 250

\* For this analysis the reactor site is assumed to be sufficiently removed from possible fault rupture (e.g. greater than 1/4 mile as per USAEC 10CFR, Appendix A).

**ENGINEERING NOTE**

ENN 73-45

3

SUBJECT SEISMIC EFFECTS ON A PROPOSED UNDERGROUND REACTOR FACILITY

NAME F. Tokarz/R. Murray

DATE February 26, 1973

The maximum steel stresses resulting from the earthquake loading are as follows:

	Axial Stress (psi)	Hoop Stress (psi)
Steel pipe	± 8,000	± 15,000
Steel pipe/dome	± 43,000	± 32,000
Steel dome	± 7,500	± 8,000
Steel cylinder	± 3,300	± 5,000

In the concrete the maximum axial stress is approximately ± 120 psi with a maximum hoop stress of ± 380 psi near the top of the dome.

#### CONCLUSIONS


As expected the results show that, except in the area of the pipe/dome junction, the static overburden loading produces stresses which are generally much greater than those produced by the earthquake loading. In the pipe/dome area more detail analysis is required to establish more precise values for the stresses. Special design considerations are needed in this area.

FT:RM:sc

Copy to:

W. Arnold, L-123  
 J. Bell, L-1  
 V. Karpenko, L-113  
 E. McCauley, L-90  
 D. Norris, L-90  
 C. Walter, L-113  
 DS File (3)  
 ME Library, L-129  
 A. Blake, L-110  
 H. Chu, L-90  
 E. Hill, L-123  
 R. Martin, L-117  
 B. Bowman, L-90

MODEL



MATERIAL PROPERTIES

MATERIAL	E (ksi)	v	$\gamma$ (lb <sub>s</sub> /ft <sup>3</sup> )
SAND	50	0.40	100
BACKFILL	100	0.33	120
PARENT MEDIA	500	0.33	130
ROCK	1000	0.33	160
CONCRETE	1000	0.17	150
STEEL	30000	0.33	490

EARTHQUAKE RECORD






FIG. 1

1<sup>ST</sup> MODE SHAPE



2<sup>ND</sup> MODE SHAPE




MODE	PERIOD (SEC.)	PARTICIPATION FACTOR (%)
------	------------------	-----------------------------


MODE	PERIOD (SEC.)	PARTICIPATION FACTOR (%)
1	0.67	68.0
2	0.40	7.0
3	0.34	7.0
4	0.30	8.0
5	0.26	10.0

FIG. 2


## STATIC OVERBURDEN RESULTS




DEFORMED SHAPE MAGNIFIED BY 5E+02



MAXIMUM PRINCIPAL STRESS




SHEAR STRESS



MINIMUM PRINCIPAL STRESS

STATIC OVERTBURDEN LOADING  
 STRESSES IN STEEL LINER

ENN 73-45  
 Page 7



STRESS (PSI)

FIG. 1

# STATIC OVERBURDEN LOADING

## CONCRETE STRESSES

○ INNER > AXIAL STRESS  
 ● OUTER > AXIAL STRESS  
 △ INNER > HOOP STRESS  
 ▲ OUTER > HOOP STRESS

ENN 73-45  
Page 8




FIG. 5

# EARTHQUAKE LOADING

STRESSES IN STEEL LINER

ENN 73-45  
Page 9




FIG. 6

# EARTHQUAKE LOADING

## CONCRETE STRESSES

○ INNER > AXIAL STRESS

○ OUTER > HOOP STRESS

△ INNER > AXIAL STRESS

△ OUTER > HOOP STRESS

ENN 73-45  
Page 10




FIG. 7

LAWRENCE LIVERMORE LABORATORY - UNIVERSITY OF CALIFORNIA <b>ENGINEERING NOTE</b>		FILE NO. ENN 73-45	PAGE 11
SUBJECT SEISMIC EFFECTS ON A PROPOSED UNDERGROUND REACTOR		NAME F. Tokarz/R. Murray	
FACILITY		DATE February 26, 1973	

External Distribution

Mr. D. C. Willett  
 Manager, Power Division  
 Acres American Incorporated  
 Consulting Engineers  
 The Liberty Bank Building  
 Main at Court  
 Buffalo, New York 14202

Please see page 3 for Internal distribution.

**NOTICE**

"This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately-owned rights."