

File
↑

APAE
MEMO NO. 34

2

UNCLASSIFIED

SHIELDING OF IRRADIATED APPR-1

FUEL ELEMENTS

Contract No. AT (11-1) - 318

Issued July 6, 1956

Alco Products, Inc.
Post Office Box 414
Schenectady, New York

UNCLASSIFIED

DO NOT
PHOTOSTAT

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

DISTRIBUTION

Cps.

1 - 11 Alco Products, Inc.
Post Office Box 414
Schenectady, New York

1 - H. L. Weinberg
2 - J. L. Meem
3 - J. G. Gallagher
4 - F. B. Fairbanks
5 - A. L. Medin

6 - B. M. Ball
7 - G. W. Knighton
8 - D. C. Morse
9 - 11 - File (3)

12 - 21 Schenectady Operations Office
Post Office Box 1069
Schenectady, New York
Attn: J. D. Anderson

DO NOT
PHOTOSTAT

0

APAE

~~AT~~ MEMO NO. 34

UNCLASSIFIED

APAE-MEMO-34

SHIELDING OF IRRADIATED APPR-1

FUEL ELEMENTS

Contract No. AT (11-1) - 318

Issued July 6, 1956

Authors: R. B. Fairbanks and D. C. Morse

Alco Products, Inc.
Post Office Box 414
Schenectady, New York

UNCLASSIFIED

342-1

SHIELDING OF IRRADIATED APPR-1 FUEL ELEMENTS

The purpose of this analysis is to determine the shielding requirements for irradiated APPR-1 fuel elements both in the fuel element storage pit and in transit to the reprocessing plant. The general method of calculation and the results, for each case, are presented below.

I. Shielding for Storage Pit

Upon leaving the reactor core, used fuel elements are transferred directly to the storage pit, which is filled with water. The shielding variable in this case is the distance below the water surface at which the element is located. Calculations were made for water depths of 6, 9, 12, 15, and 18 feet.

Calculations were for one element of twice the average activity, thus allowing for variations from the average. Source strengths were calculated with the aid of charts in Reference 1. Reactor operation time was taken as infinite; time after shutdown was taken as one day. The numerous gamma groups emitted by fission products were combined into two groups. Group B contained gammas with energies from 1.10 Mev. to 1.65 Mev; the average energy for group B was taken as 1.5 Mev. Group C contained gammas from 1.80 Mev. to 2.90 Mev. in energy; the average energy for Group C was 2.5 Mev. Gammas below 1.10 Mev. in energy contribute a negligible dose, as shown in reference 2.

Gamma fluxes were calculated by using the graphs and formulas presented by Foderaro and Obenshain in Reference 3. The element was assumed to be a line source. Results were checked, and good agreement obtained, with a point source approximation. Build-up effects were included by use of the method presented in Reference 4. The following results were obtained:

<u>a</u>	<u>ϕ_B</u>	<u>ϕ_C</u>
6	4.35×10^5	3.52×10^5
9	1.68×10^3	3.87×10^3
12	7.58	6.12×10
15	3.71×10^{-2}	9.20×10^{-1}
18	2.00×10^{-4}	1.42×10^{-2}

where:

a = height of water above element (feet)

ϕ_B = gamma flux for group B (Mev/cm²-sec)

ϕ_C = gamma flux for group C (Mev/cm²-sec)

Reference 5 gives the following formulas for conversion from flux to dose rate:

$$D_B = \frac{\phi_B}{5.76 \times 10^2} \quad D_C = \frac{\phi_C}{6.36 \times 10^2}$$

.001736 .001572

where:

D_B = dose rate for group B (mr/hour)

D_C = dose rate for group C (mr/hour)

ϕ_B and ϕ_C as defined above.

These formulas yielded the following results:

<u>a</u>	<u>D_B</u>	<u>D_C</u>	<u>D_T</u>
6	7.55×10^2	5.54×10^2	1310.
9	2.92	6.09	9.01
12	1.31×10^{-2}	9.64×10^{-2}	.109
15	6.44×10^{-5}	1.45×10^{-3}	.00151
18	3.47×10^{-7}	2.24×10^{-5}	.0000227

where: $D_T = D_B + D_C$ = total dose rate (mr/hour)

Other symbols as defined above.

These results are plotted on the graph included below. Note that the results, as presented in both chart and graph, are for a single fuel element of twice the average activity. The distance indicated is from the surface of the water to the nearest point of the active core section.


WATER SHIELDING OF IRRADIATED ELEMENT

DOSE RATE V. WATER SHIELDING

MODEL

DATE

OPERATION TIME = ∞
TIME AFTER SHUTDOWN = 1 DAY



WATER SHIELDING IN FEET

342 5

II. Shielding in Transit

The calculations presented here are simply a check upon the existing design for the fuel element shipping container (layout no. R-9-48-1001). The maximum dose rate was calculated at the surface of the container and at a point one meter from the surface, for both the radial and axial directions. Calculations were for six fuel elements (the capacity of the container), each having 1.5 times the average activity, to allow for variations in activity.

The method of calculation was similar to that employed in the fuel pit calculations above. Source strengths were obtained from Reference 1, using various lengths of operation time and time after shutdown. The gammas were again divided into two energy groups.

Gamma fluxes were determined by use of References 3 and 4. A cylinder approximation was used for the radial direction, and a line source approximation for the axial direction. The formulas for conversion from flux to dose rate were the same as those presented in the previous section.

Dose rates for 1000 hours operation and for infinite operation, both at 100 days after shutdown, were desired. Unfortunately, however, Reference 1 does not give data on infinite operation at 100 days after shutdown. Since data was given for both 1000 hour and infinite operation at 10 days after shutdown, dose rate for the infinite operation at 100 days after shutdown case was calculated by assuming the ratio of dose rate at 10 days after shutdown to that at 100 days after shutdown is a constant, regardless of operation time.

The calculated dose rates are presented in the chart below. They lie within the established ICC limits of 200 mr/hour at the surface and 10 mr/hour one meter from the surface.

Time after shutdown = 100 days

<u>Operation Time</u>	<u>Direction</u>	<u>Dose Rate in mr/hour</u>		
		<u>At Surface</u>	<u>1 m. from surface</u>	
1000 hours	radial	10.2	2.83	.2774
	axial	9.7	4.07	.42
infinite	radial	20.8 ✓	5.77	.277
	axial	19.7	8.27	.42

$$\frac{X}{100 + X} = .42$$

$$= 28.5 "$$

$$.42 = .58 X$$

$$\frac{25.4}{1.27}$$

REFERENCES

1. Moteff, Fission Product Decay Gamma Energy Spectrum, APEX 134.
2. Meem and Fairbanks, Shielding Requirements for the Army Package Power Reactor, APAE No. 3, May, 1956.
3. Foderaro and Obenshain, Fluxes from Regular Geometric Sources, WAPD-TN-508, June 1955.
4. Taylor, Application of Gamma Ray Build-up Data to Shield Design, WAPD-EM-217, January, 1954.
5. Reactor Handbook, volume 1, RH-1, page 946.