

AEC
RESEARCH
and
DEVELOPMENT
REPORT

320
4-19-65

MASTER

BNWL-5

Zy-2

POSTIRRADIATION EVALUATION OF ZIRCALOY-2

PRTR PRESSURE TUBES - PART III

JANUARY 1965

PATENT CLEARANCE OBTAINED. RELEASE TO
THE PUBLIC IS APPROVED. PROCEDURES
ARE ON FILE IN THE RECEIVING SECTION.



RICHLAND, WASHINGTON

PACIFIC NORTHWEST LABORATORY operated by BATTELLE MEMORIAL INSTITUTE

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

BNWL-5
UC-25, Metals, Ceramics,
and Materials
(TID-4500, 37th Ed.)

POSTIRRADIATION EVALUATION OF ZIRCALOY-2
PRTR PRESSURE TUBES - PART III

By

M. C. Fraser
Metallurgy Research
Reactor and Materials Technology

FIRST UNRESTRICTED
DISTRIBUTION MADE

APR 1 '65

January 1965

BATTELLE-NORTHWEST
RICHLAND, WASHINGTON

Work performed under Contract No. AT(45-1)-1830 between the
Atomic Energy Commission and Battelle Memorial Institute

Printed by/for the U. S. Atomic Energy Commission

Printed in USA. Price \$1.00. Available from the Clearinghouse for Federal
Scientific and Technical Information, National Bureau of Standards
U. S. Department of Commerce, Springfield, Virginia

POSTIRRADIATION EVALUATION OF ZIRCALOY-2
PRTR PRESSURE TUBES - PART III

INTRODUCTION

An additional three Zircaloy-2 pressure tubes have been discharged from the Plutonium Recycle Test Reactor (PRTR), and specimens from two of these tubes and from other tubes have been burst tested since the last status report ⁽¹⁾ was written. Also, irradiated and unirradiated specimens of PRTR Zircaloy-2 pressure tubes have been used for room temperature crack propagation tests. The results of vacuum fusion analyses for hydrogen content of specimens taken from all of the discharged PRTR Zircaloy-2 pressure tubes have been received.

The collected data of this and the previous two reports ^(1, 2) are sufficient, technically, to support a new criteria for PRTR Zircaloy-2 pressure tube selection for destructive examination. The new criteria scope will include neutron exposure (as do the present criteria), ⁽³⁾ crack propagation, notch sensitivity, and hydrogen concentration information.

The testing is described and discussed in this report. The objective of the report is to present the technical basis for new criteria of tube selection for destructive examination.

-
- (1) M. C. Fraser. Postirradiation Evaluation of Zircaloy-2 PRTR Pressure Tubes - Part II, HW-83164. September 1964.
 - (2) L. J. Defferding. Postirradiation Evaluation of Zircaloy-2 PRTR Pressure Tubes - Part I, HW-73698 REV. November 1962.
 - (3) R. W. Porter, Chairman. Highlights - Twelfth Meeting - Technological Hazards Council September 11-13, 1963.

SUMMARY

PRTR Surveillance Program work performed and information obtained since the last status report is reported. In addition to more burst test strength and circumferential elongation data, zirconium hydride concentration values from all tubes examined and crack propagation data for irradiated specimens are presented.

The burst test strength data show that strength increases with neutron exposure, and they indicate that this trend will not be substantially changed by doubling the neutron exposure.

The burst test circumferential elongation data show decreasing elongation values with increasing neutron exposure. The curves indicate that a factor of two increase in neutron exposure will produce a small additional ductility decrement.

Zirconium hydride concentration data indicate generally low levels but at flaws high concentrations (300 to 500 ppm maximum) have been found.

Crack propagation data indicate that neutron irradiation of 5×10^{20} nvt has no effect on critical crack lengths. The indicated PRTR operational critical crack length is about 10 in.

The above conclusions are bases of criteria for selection of PRTR Zircaloy-2 pressure tubes for destructive examination.

REPORT

PRTR Tube 6079 was discharged from Channel 1354 on March 3, 1964, having an average exposure of 326.5 MWd which is, because of the types of fuel elements which resided in this tube, 9.47×10^{20} fast ($E > 1$ MeV) nvt. Selection of Tube 6079 to be the twelfth destructively examined was based upon the number of fret marks observed during in-reactor monitoring on the inside surface of the tube, and the tube's exposure. Of the fret marks observed, three had depths of 10 to 15 mils. They had been formed by fretting corrosion at the fuel element supports.

Two 20 in. long pieces of this tube were pressurized to failure at room temperature. The fret marks mentioned above were on these pieces. The hoop strengths at maximum pressures sustained were 108,600 and 124,000 psi. The piece with the lower strength had annealed microstructure and it displayed 12% circumferential elongation and 9 to 18% reduction in wall thickness. The other piece had cold worked microstructure and it displayed 7% circumferential elongation and 3 to 14% reduction in wall thickness.

Vacuum fusion analysis of samples from both burst specimens indicated that the metal in the region of the burst origin had 70 to 80 ppm hydride; whereas, at the ends of the specimens the hydride concentration was 25 to 40 ppm.

The above evidence indicates that the combination of fret marks and hydride concentration determined the burst origins of these two specimens. Their burst strength values indicate that reduction in strength due to fret marks and the hydride was negligible. The circumferential elongation and the reduction in wall thickness values indicate ductility.

Tube 5526 was discharged from Channel 1558 on October 10, 1964, because of the presence of a large unclassified flaw on the inside surface. The flaw was discovered by in-reactor monitoring at 7 ft 11 in. from the flange. The examination of this flaw and its results have been reported. (4)
The findings were:

- The flaw had been formed in the tube prior to its insertion into the PRTR reactor.
- Metallography indicated that hydride concentration in the metal surrounding the flaw was normal—less than 50 ppm.
- The flaw was 0.36 in. long, 0.053 in. wide, and 0.045 in. thick. The thickness was approximately equally distributed above and below the inside surface of the tube.

(4) M. C. Fraser. Examination of Flaws in PRTR Zircaloy-2 Pressure Tubes, HW-84440. October 14, 1964.

- The flaw was football shaped.
- The flaw was partially filled with a white nonmetallic substance which chemical analysis indicated to be zirconium dioxide.

Tube 6084 was discharged from Channel 1253 on August 25, 1964. It had an average exposure of 479.4 MWd (1.4×10^{21} fast ($E > 1$ MeV) nvt). A piece of this tube, taken from the region having received the greatest neutron exposure, was burst tested at room temperature. The piece sustained a maximum pressure of 12,490 psig and the calculated Lamé hoop stress for this pressure was 142,600 psi. The specimens displayed about 6% hoop elongation. Postburst test examination of this specimen is not completed.

Figure 1 shows curves relating burst test hoop strength to fast ($E > 1$ MeV) neutron exposure of irradiated specimens of Zircaloy-2 pressure tubes. The curves show that the total PRTR reactor environment is increasing the burst test hoop strength. The most recently obtained values are shown. They indicate that the trend of strength increase with increased neutron exposure is continuing. The strength data indicate that the hoop strength of burst test specimens has become indistinguishable at exposures of the order of 10^{21} nvt with respect to microstructure.

The burst test hoop elongation curves of Figure 2 show a gradual value decrease with increasing exposure. At room temperature the values for annealed material are indicated to be decreasing more rapidly than the values for cold-worked material. The most recently obtained values are shown. The room temperature values indicate no change in the trend, but the elevated temperature value indicates significant decrease.




FIGURE 1
 Hoop Strength and Fast Neutron Exposure of PRTR Zircaloy-2 Pressure Tubes




FIGURE 2

Hoop Elongation and Fast Neutron Exposure of PRTR Zircaloy-2 Pressure Tubes

A method for measuring crack propagation characteristics of Zircaloy-2 tubes has been developed.⁽⁵⁾ The method involves milling of a slot in the wall of a burst test specimen. The slot dimensions are usually 1/16 in. wide by 80% of the wall thickness deep, and the slot length is dictated by the desired crack length. The crack is produced by pressurizing the burst test specimen to failure of the thin area at the base of the slot. A compressible rubber gasket assembly is then placed inside the burst test specimen and compressed until the crack is sealed. Upon pressurization of the specimen, the crack is caused to propagate. Pressure equalization on either side of the gasket assembly is achieved by a hole through the compressing bolt.

By this method, 11 specimens of PRTR Zircaloy-2 pressure tubes have been tested. Four of these had cold-worked microstructure and seven had annealed microstructure. Three cold-worked specimens had been irradiated to exposures of 4.5, 5.5, and 6×10^{20} nvt. Three annealed specimens had been irradiated also to exposures of about 2×10^{20} nvt. The five unirradiated specimens consisted of four annealed and one cold-worked. The range of crack lengths used for these tests was 0.3 to 3.0 in. All tests were done at room temperature. The results of the tests indicate that the crack propagation characteristics of these tube specimens can be described by:

$$\text{Stress (Crack Length)}^N = \text{Constant}$$

where N has a value between 0.6 and 0.66, and the constant has a value of about 43,500.

Figure 3 is a log-log plot of the data obtained. Mid-wall stress values were calculated assuming the absence of the "slot-crack." Figure 3 also shows some of the data obtained by R. C. Aungst using KER Zircaloy-2 pressure tube specimens.

(5) R. C. Aungst and L. J. Defferding. Crack Propagation Tests on Zircaloy-2 Reactor Pressure Tubing in Both Normal and Hydrided Conditions, HW-80567. April 23, 1964.




FIGURE 3

Crack Propagation Characteristics of PRTR Zircaloy-2 Pressure Tubes

Hydride analyses of specimens taken from burst test specimens have been performed. These data are arranged in Table I. The average value of all analyses listed in Table I, excluding high localized concentrations which are explained in the table foot notes, is 46 ppm, and the concentration range is 4 ppm to 112 ppm. The tubes most recently discharged are indicated by these data to have hydride concentrations comparable to unirradiated tubes.

TABLE I

ZIRCONIUM HYDRIDE CONCENTRATIONS

| <u>Tube</u> | <u>Hydride Concentration, ppm</u> | <u>Sample Location on Tube, Feet From Inlet</u> |
|-------------|---------------------------------------|---|
| 6100 | ZrH ₂ at BW Mark (a, b) | 8 |
| | ZrH ₂ at UFES Mark (b) | 13 |
| | 58 | 12-15 (e) |
| | 24 | 15 |
| | 27 | 17 |
| 6061 | ZrH ₂ at UFES Mark (b) | 13 |
| | 24-122 (c) | 12-15 (e) |
| 5529 | ZrH ₂ at LFES Mark (b) | 5 |
| | 50 | 1 1/2 |
| | 56 | 11 3/4 |
| 5679 | 202 | 3 1/2 |
| | 27 | 5 1/2 |
| | 93 | 6 1/2 |
| | 200-300 by Metallography | 6 1/2 |
| | 78 | 7 3/4 |
| | 74 and 86 | 9 1/2 |
| | 84 | 11 1/2 |
| 112 | 13 1/2 | |

TABLE I (Contd.)

| <u>Tube</u> | <u>Hydride Concentration, ppm</u> | <u>Sample Location on Tube, Feet From Inlet</u> |
|-------------|---------------------------------------|---|
| 5702 | 52 | 8 1/4 |
| | 89 | 10 1/4 |
| | 30-40 (c) | 12 1/4-14 1/2 (e) |
| 5540 | 43 | 6 1/2 |
| | 26 and 39 | 9 |
| | 205 (d) | 10 1/2-13 1/2 (e) |
| 5537 | - | - |
| 0720 | 55 | 3-5 (e) |
| | 6 | 5-7 1/2 (e) |
| | 27 | 7 1/2 |
| | 35 | 9 1/3 |
| | 10-17 (c) | 9 1/3-10 (e) |
| | 40 | 10 |
| | 50-75 by Metallography | 9 1/3-10 (e) |
| | 69 | 11 3/4 |
| | 46 | 11 3/4-14 (e) |
| 5683 | 15 | 3 3/4 |
| | 24 and 34 | 6 1/2-6 3/4 (e) |
| | 38 and 69 | 7-7 1/4 (e) |
| | 25 and 59 | 9 |
| | 38 and 42 | 10 |
| | 15 and 75 | 11 1/2 |
| | 15 and 51 | 13-13 1/4 |
| | 30 | 15 |
| 5682 | 4 | 6 |
| | 23 and 50 | 7 3/4 |
| | 69 | 9 1/3 |
| | 24 and 53 | 11 |
| | 21 | 12 1/2 |

| <u>Tube</u> | <u>Hydride Concentration, ppm</u> | <u>Sample Location on Tube, Feet From Inlet</u> |
|-------------|---------------------------------------|---|
| 6115 | 300-500 by Metallography | 6 |
| | 74 | 8 2/3 |
| | 41 and 45 | 10 1/2 |
| | 38 | 12 1/4 |
| | 41 | 14 |
| | 32 | 15 3/4 |
| 6079 | 38 | 6 |
| | 35 and 50 | 7 3/4 |
| | 38 | 9 1/2 |
| 5526 | 60 | 9 1/2 |
| 6084 | 44 | 7 2/3 |
| | 35 and 61 | 9 1/4 |
| | 33 | 11 |

- (a) ZrH_2 is of the order of 21,000 ppm Hydrogen
- (b) BW Mark - Fuel Element Bundle Wire Fret Mark
 UFES Mark - Fuel Element Upper Support Fret Mark
 LFES Mark - Fuel Element Lower Support Fret Mark
- (c) Several specimens analyses were within this range.
- (d) High value may have been due to metallography mounting substance
- (e) Sample location uncertain but is within indicated limits

There were three instances discussed in Reference (1) of service produced flaws which during burst testing caused strength reductions of 24%, 23%, and 11%. The more recent tubes tested had service flaws of lesser strength reduction influence. The tabulated burst test data are presented in Table II.

TABLE II

BURST TEST DATA

| Tube | Specimen | Microstructure | Test Temperature, F | Fast Neutron Exposure at Burst, nvt | Hoop Strength, psi | Hoop Elongation, % | Remarks |
|------|----------|----------------|---------------------|--|--------------------|--------------------|---|
| 6100 | 1 B | Annealed | 70 | $1.6 - 3.3 \times 10^{16}$ | 86,200 | 9 | No apparent cause for low strength. |
| | 1 C | Annealed | 70 | $1.25 - 1.35 \times 10^{19}$ | 86,700 | 0 | Burst started by 0.002 in. deep crack in 0.002 in deep hydride layer over a fret mark. |
| 6061 | 2 C | Annealed | 70 | $5.2 \times 10^{17} - 1.1 \times 10^{18}$ | 106,200 | 20 | - |
| | 2 D | Annealed | 575 | $4.7 - 5.4 \times 10^{19}$ | 58,200 | Not Measured | - |
| 5529 | 3 2 | Annealed | 70 | $6.8 \times 10^{17} - 1.35 \times 10^{18}$ | 97,000 | 17 | - |
| | 3 3 | Annealed | 70 | $3.6 - 6.3 \times 10^{19}$ | 111,000 | 15 | - |
| 5679 | 4 B | Annealed | 550 | $1.3 - 2.4 \times 10^{18}$ | 47,200 | 35 | - |
| | 4 C | Annealed | 540 | $3.8 - 7 \times 10^{19}$ | 61,200 | 48 | - |
| | 4 F | Cold Worked | 565 | $6.2 \times 10^{19} - 1.2 \times 10^{20}$ | 70,500 | Not Measured | - |
| 5702 | 5 B | Annealed | 70 | $3.3 - 6.2 \times 10^{18}$ | 107,000 | Not Measured | 0.009 - 0.011 in. deep fret marks had no apparent effect on burst. |
| | 5 C | Annealed | 205 | $1.35 - 1.8 \times 10^{20}$ | 111,000 | Not Measured | - |
| | 5 E | Cold Worked | 70 | $2.1 - 2.25 \times 10^{20}$ | 130,000 | 3.3 | Burst started by 0.017 in. deep fret mark. |
| | 5 G | Cold Worked | 555 | $6.8 \times 10^{18} - 1.7 \times 10^{19}$ | 74,000 | Not Measured | - |
| 5540 | 6 B | Annealed | 560 | $1.4 - 2.8 \times 10^{19}$ | 56,900 | Not Measured | Test was stopped before burst. |
| | 6 C | Annealed | 430 | $2.9 - 3.2 \times 10^{20}$ | 78,100 | 15 | "Pinhole" failure. |
| | 6 E | Cold Worked | 70 | $1.3 - 2.2 \times 10^{20}$ | 120,000 | 0 | Burst started at 0.014 in. deep fret mark. |
| | 6 C | Second Test | 70 | $2.9 - 3.2 \times 10^{20}$ | 125,800 | 0 | Elongation of zero probably due to first burst test. |
| | 6 D | Undetermined | 550 | 4.2×10^{20} | 78,400 | 20 | "Pinhole" failure. |
| 0720 | 8 B | Annealed | 207 | 1×10^{16} | 75,000 | Not Measured | - |
| | 8 C | Annealed | 410 | $3.2 - 6.2 \times 10^{17}$ | 58,000 | Not Measured | - |
| | 8 F | Cold Worked | 410 | $1.2 - 1.7 \times 10^{18}$ | 84,500 | Not Measured | - |
| 5683 | 9 B | Annealed | 70 | $3.5 - 6.5 \times 10^{18}$ | 104,800 | 7.5 | - |
| | 9 H | Cold Worked | 70 | $1.6 - 2.6 \times 10^{20}$ | 134,200 | 7 | - |
| 5682 | 10 C | Annealed | 70 | $2.7 - 3.5 \times 10^{20}$ | 129,000 | 15 | - |
| | 10 G | Cold Worked | 70 | $3.2 - 4.1 \times 10^{20}$ | 134,800 | 9 | - |
| 6115 | 11 C | Annealed | 70 | $1.45 - 2.0 \times 10^{20}$ | 97,500* | Less than 0.2% | * Based on average ID and wall; no allowance for stress concentration. Burst started by 0.016 - 0.020 in. deep mark at the onset of uniform plastic strain. |
| 6079 | 12 A | Annealed | 70 | 1.9×10^{19} | 112,800 | 12 | - |
| | 12 E | Cold Worked | 70 | 3.3×10^{20} | 123,700 | 7 | - |
| 6084 | 14 D | Undetermined | 70 | 1.8×10^{21} | 142,650 | 6 | - |

DISCUSSION

Static burst strength data of Figure 1 indicate Zircaloy-2 pressure tube bursting strengths are 140,000 psi at room temperature and 77,500 psi at elevated temperature for exposures between 450 and 500 Mwd ($\sim 10^{21}$ nvt, $E > 1$ MeV). Compared with values from unirradiated material these bursting strengths are 0 to 55% greater at room temperature and are 25% to 50% greater at elevated temperature depending upon microstructure. Furthermore, these data indicate that at this exposure the strength difference between annealed and cold-worked Zircaloy-2 pressure tube material is not significant.

The most recent static burst strength data (specimen 6D burst at 550 F and 78,400 psi had an exposure of 4.2×10^{20} nvt) indicate strength values will show further increases with increasing neutron exposure. If burst strengths do not change abruptly at a critical exposure, the shape of the curves indicates that at twice the neutron exposure the margin of safety from tube failure by overloading will be about seven. The factor of safety now is between six and seven.

The circumferential elongation values plotted in Figure 2 indicate that Zircaloy-2 pressure tube material having exposure values of 450 to 500 MWd will display about 6% circumferential elongation when pressurized to failure at room temperature and at least 20% circumferential elongation when pressurized to failure at elevated temperature. The shape of the room-temperature elongation versus neutron exposure curve suggests a continued gradual loss of circumferential elongation with increasing neutron exposure. At twice the current exposure the indicated elongation is about 3% or more.

The crack propagation data of Figure 3 indicate that fast neutron irradiation of 2×10^{20} to 6×10^{20} nvt has not changed crack propagation characteristics of Zircaloy-2 pressure tube material. They also

indicate the necessary crack length for propagation at PRTR operating pressure and room temperature is about 10 in. Catastrophic PRTR Zircaloy-2 pressure tube failure is therefore indicated to be not probable. The envisioned events in the life of a developing crack in a PRTR tube are:

- The crack grows radially from a source until the tube wall is penetrated.
- The crack length increases.
- Water flows into the gas annulus
- The water pressure drop along the tube changes...
- The water leak is detected by helium moisture analysis or by pressure losses before the crack reaches critical size.

The data of Table I show there were several cases of hydriding at service produced flaws. Some of these flaws were burst test fracture origins. The worst flaw-hydriding combination tested (300 to 500 ppm hydride and theoretical notch factor of 4.5 in specimen 11C of Tube 6115) caused an effective strength reduction of 25%.

The data of Table I indicate that Tube 5679 had an average hydride concentration greater than 50 ppm. The other tubes are indicated to have had average hydride concentrations of less than 50 ppm.

Service produced flaws with theoretical stress concentration factors of two to three and one-half have demonstrated effective stress concentration factors of less than one and one-half. An effective stress concentration factor of about four to six is necessary for a service produced flaw to cause in-service tube failure.

CONCLUSIONS

The data provide a technical basis for selection of PRTR Zircaloy-2 pressure tubes for discharge and examination under the PRTR surveillance program. The technical basis is:

- Burst test hoop strength and elongation data show that tubes having fast neutron exposure of 10^{21} or less have high strength with ductility;

furthermore, the curves indicate that increasing exposure by a factor of two will not substantially change these conditions.

- Crack propagation data for tubes having fast neutron exposure of 5×10^{20} nvt or less show that resistance to crack propagation is unaffected by the neutron exposure, and that the crack length necessary for propagation at PRTR operating pressures is about 10 in.
- Hydride concentration data indicate general levels of hydride concentration are low, but high hydride concentrations have been found at flaws. The worst combined effect of flaw plus hydride produced a strength reduction of 25%.

INTERNAL DISTRIBUTION

Copy Number

| | |
|---------|-----------------------------|
| 1 | F. W. Albaugh |
| 2 | R. C. Aungst |
| 3 | J. A. Ayres |
| 4 | F. E. Bard |
| 5 | A. L. Bement |
| 6 | R. F. Burch |
| 7 | S. H. Bush |
| 8 | J. J. Cadwell |
| 9 | L. J. Defferding |
| 10 | R. L. Dillon |
| 11 | D. R. Doman |
| 12 | J. C. Fox |
| 13 - 20 | M. C. Fraser |
| 21 | B. Griggs |
| 22 | W. J. Gruber |
| 23 | H. Harty |
| 24 | J. H. Hoage |
| 25 | R. G. Hoagland |
| 26 | P. M. Jackson |
| 27 | R. A. Kennedy |
| 28 | D. R. Koberg |
| 29 | W. R. Lewis |
| 30 | K. R. Merckx |
| 31 | P. J. Pankaskie |
| 32 | L. T. Pedersen |
| 33 | W. D. Richmond |
| 34 | D. P. Schively |
| 35 | R. Teats |
| 36 | J. C. Tobin |
| 37 | L. D. Turner |
| 38 | R. G. Wheeler |
| 39 | R. D. Widrig |
| 40 | N. G. Wittenbrock |
| 41 - 45 | Technical Information Files |
| 46 | Technical Publications |

EXTERNAL DISTRIBUTION (SPECIAL)

Number of Copies

1 AEC, Washington
Military Liason Committee
Attn: Capt. D. E. McCoy,
Staff Assistant to the Chairman

4 Atomic Energy of Canada, Ltd.; Toronto
Attn: R. Isles
E. C. W. Perryman
P. A. Ross-Ross
W. R. Thomas

1 Carolina-Nuclear Power Association
Parr, South Carolina
Attn: W. N. Thomas

5 DTIE

3 General Electric Company, Richland
Attn: D. H. Curtiss,
H. R. Kosmata
J. W. Riches

1 Naval Research Laboratory
Attn: L. E. Steele

1 Reaktor A. G.
Wurenlingen/A. G
Switzerland

7 Richland Operations Office
Attn: P. M. Midkiff
J. M. Musser
O. W. Rathbun
J. Sako
M. R. Schneller
R. K. Sharp
Technical Information Library

3 United Kingdom Atomic Energy Authority
Atomic Energy Research Establishment
Harwell, Didcot, Berks, England
Attn: B. Cox

2 United Kingdom Atomic Energy Authority
Reactor Group, Reactor Materials Laboratory
Wigshaw Lane
Culcheth, Lancashire, England
Attn: R. Nichols
B. Watkins

| Ptd. | Standard Distribution | Ptd. | Standard Distribution |
|------|---|------|---|
| 3 | ABERDEEN PROVING GROUND | 1 | BUREAU OF SHIPS (CODE 1500) |
| 2 | AEROJET-GENERAL CORPORATION | 1 | CARBORUNDUM COMPANY |
| 1 | AEROJET-GENERAL NUCLEONICS | 1 | CHICAGO PATENT GROUP |
| 2 | AERONAUTICAL SYSTEMS DIVISION | 1 | COMBUSTION ENGINEERING, INC. |
| 1 | AEROPROJECTS INCORPORATED | 1 | COMBUSTION ENGINEERING, INC. (NRD) |
| | | 1 | DEFENCE RESEARCH MEMBER |
| 1 | AIR FORCE INSTITUTE OF TECHNOLOGY | 1 | *DEL ELECTRONICS CORPORATION |
| | | 1 | DENVER RESEARCH INSTITUTE |
| 1 | AIR FORCE RESEARCH AND TECHNOLOGY DIVISION | 1 | DOW CHEMICAL COMPANY, ROCKY FLATS |
| | | 4 | DU PONT COMPANY, AIKEN |
| 1 | ALLIS-CHALMERS MANUFACTURING COMPANY | 1 | DU PONT COMPANY, WILMINGTON |
| 1 | ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA | 1 | FRANKFORD ARSENAL |
| | | 1 | FRANKLIN INSTITUTE OF PENNSYLVANIA |
| 1 | ALLISON DIVISION-GMC | 1 | FUNDAMENTAL METHODS ASSOCIATION |
| 10 | ARGONNE NATIONAL LABORATORY | 2 | GENERAL ATOMIC DIVISION |
| 1 | ARMY ENGINEER RESEARCH AND DEVELOPMENT LABORATORIES | 2 | GENERAL DYNAMICS/FORT WORTH |
| 1 | ARMY MATERIALS RESEARCH AGENCY | 2 | GENERAL ELECTRIC COMPANY, CINCINNATI |
| 1 | ARMY MISSILE COMMAND | 1 | GENERAL ELECTRIC COMPANY, PLEASANTON |
| 1 | ARMY RESEARCH OFFICE, DURHAM | 6 | GENERAL ELECTRIC COMPANY, RICHLAND |
| 1 | ARMY TANK-AUTOMOTIVE CENTER | 1 | GENERAL ELECTRIC COMPANY, SAN JOSE |
| 1 | ATOMIC ENERGY COMMISSION, BETHESDA | 1 | GENERAL NUCLEAR ENGINEERING CORPORATION |
| 1 | AEC SCIENTIFIC REPRESENTATIVE, BELGIUM | 1 | GOODYEAR ATOMIC CORPORATION |
| 1 | AEC SCIENTIFIC REPRESENTATIVE, FRANCE | 1 | IIT RESEARCH INSTITUTE |
| 1 | AEC SCIENTIFIC REPRESENTATIVE, JAPAN | 1 | INTERNATIONAL BUSINESS MACHINES CORPORATION |
| 3 | ATOMIC ENERGY COMMISSION, WASHINGTON | | |
| 4 | ATOMIC ENERGY OF CANADA LIMITED | 2 | IOWA STATE UNIVERSITY |
| | | 2 | JET PROPULSION LABORATORY |
| 2 | ATOMIC ENERGY OF CANADA LIMITED, WHITESHELL | 1 | JOHNS HOPKINS UNIVERSITY |
| | | 3 | KNOLLS ATOMIC POWER LABORATORY |
| 4 | ATOMICS INTERNATIONAL | 1 | LING TEMCO VOUGHT, INC. |
| 1 | AVCO CORPORATION | 1 | LOCKHEED-GEORGIA COMPANY |
| 4 | BABCOCK AND WILCOX COMPANY | 1 | LOCKHEED MISSILES AND SPACE COMPANY (NASA) |
| 2 | BATTELLE MEMORIAL INSTITUTE | | |
| 2 | BEERS (ROLAND F.), INC. | 3 | LOS ALAMOS SCIENTIFIC LABORATORY |
| 1 | BERYLLIUM CORPORATION | 1 | M & C NUCLEAR, INC. |
| 1 | BLUME (JOHN A.) AND ASSOCIATES | 1 | MALLINCKRODT CHEMICAL WORKS |
| 2 | BROOKHAVEN NATIONAL LABORATORY | 1 | MARE ISLAND NAVAL SHIPYARD |
| 1 | BUREAU OF MINES, ALBANY | 1 | MARITIME ADMINISTRATION |
| 1 | BUREAU OF NAVAL WEAPONS | 1 | MARTIN-MARIETTA CORPORATION |

| Ptd. | Standard Distribution | Ptd. | Standard Distribution |
|------|---|------|--|
| 1 | *MINNESOTA MINING AND MANUFACTURING COMPANY (BRANDT) | 1 | REACTIVE METALS, INC. |
| 1 | MOUND LABORATORY | 1 | REACTIVE METALS, INC., ASHTABULA |
| | | 1 | RENSSELAER POLYTECHNIC INSTITUTE |
| 1 | NASA LEWIS RESEARCH CENTER | 1 | SAN FRANCISCO OPERATIONS OFFICE |
| | | 2 | SANDIA CORPORATION, ALBUQUERQUE |
| 1 | NASA MANNED SPACECRAFT CENTER | 1 | SANDIA CORPORATION, LIVERMORE |
| 2 | NASA SCIENTIFIC AND TECHNICAL INFORMATION FACILITY | 1 | SOUTHWEST RESEARCH INSTITUTE |
| | | 1 | STANFORD UNIVERSITY (SLAC) |
| 2 | NATIONAL BUREAU OF STANDARDS | 1 | SYLVANIA ELECTRIC PRODUCTS, INC. |
| 1 | NATIONAL BUREAU OF STANDARDS (LIBRARY) | 1 | TENNESSEE VALLEY AUTHORITY |
| 2 | NATIONAL LEAD COMPANY OF OHIO | 1 | TRW SPACE TECHNOLOGY LABORATORIES (NASA) |
| 1 | NAVAL POSTGRADUATE SCHOOL | 1 | UNION CARBIDE CORPORATION, CLEVELAND |
| 3 | NAVAL RESEARCH LABORATORY | 2 | UNION CARBIDE CORPORATION (ORGDP) |
| | | 5 | UNION CARBIDE CORPORATION (ORNL) |
| 1 | NRA, INC. | | |
| 1 | NUCLEAR MATERIALS AND EQUIPMENT CORPORATION | 1 | UNION CARBIDE CORPORATION (PADUCAH PLANT) |
| 1 | NUCLEAR METALS, INC. | 2 | UNITED NUCLEAR CORPORATION (NDA) |
| 1 | NUCLEAR UTILITY SERVICES, INC. | 1 | U. S. GEOLOGICAL SURVEY, DENVER |
| 1 | OFFICE OF ASSISTANT GENERAL COUNSEL FOR PATENTS (AEC) | 1 | U. S. GEOLOGICAL SURVEY, MENLO PARK |
| 2 | OFFICE OF NAVAL RESEARCH | 1 | U. S. GEOLOGICAL SURVEY, WASHINGTON |
| 1 | OFFICE OF NAVAL RESEARCH (CODE 422) | 1 | U. S. PATENT OFFICE |
| 1 | OHIO STATE UNIVERSITY | 2 | UNIVERSITY OF CALIFORNIA, BERKELEY |
| 1 | PETROLEUM CONSULTANTS | 2 | UNIVERSITY OF CALIFORNIA, LIVERMORE |
| 4 | PHILLIPS PETROLEUM COMPANY (NRTS) | 1 | UNIVERSITY OF PUERTO RICO |
| 1 | PHYSICS INTERNATIONAL, INC. | 1 | WESTERN RESERVE UNIVERSITY (MAJOR) |
| 1 | PICATINNY ARSENAL | 4 | WESTINGHOUSE BETTIS ATOMIC POWER LABORATORY |
| 1 | POWER REACTOR DEVELOPMENT COMPANY | 1 | WESTINGHOUSE ELECTRIC CORPORATION |
| 3 | PRATT AND WHITNEY AIRCRAFT DIVISION | 1 | WESTINGHOUSE ELECTRIC CORPORATION (NASA) |
| 1 | PURDUE UNIVERSITY | 325 | DIVISION OF TECHNICAL INFORMATION EXTENSION |
| 1 | RADIOPTICS, INC. | | |
| 1 | RAND CORPORATION | 75 | CLEARINGHOUSE FOR FEDERAL SCIENTIFIC AND TECHNICAL INFORMATION |

*New listing or change in old listing.