

MASTER

NUREG/CR-1767
ORNL/NUREG/TM-408

ornl

OAK
RIDGE
NATIONAL
LABORATORY

UNION
CARBIDE

DO NOT MICROFILM
COVER

**Sodium Oxide and Uranium Oxide
Aerosol Experiments: NSPP Tests
106-108 and Tests 204-207,
Data Record Report**

R. E. Adams
T. S. Kress M. L. Tobias

OPERATED BY
UNION CARBIDE CORPORATION
FOR THE UNITED STATES
DEPARTMENT OF ENERGY

Prepared for the U.S. Nuclear Regulatory Commission
Office of Nuclear Regulatory Research
Under Interagency Agreements DOE 40-551-75 and 40-552-75

~~RESTRICTED~~
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Printed in the United States of America. Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road, Springfield, Virginia 22161

Available from
GPO Sales Program
Division of Technical Information and Document Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

NOT MICROFILMED
COVER

NUREG/CR-1767
ORNL/NUREG/TM-408
Dist. Category R7

Contract No W-7405-eng-26

NUREG/CR--1767

Engineering Technology Division TI86 002665

**SODIUM OXIDE AND URANIUM OXIDE AEROSOL
EXPERIMENTS: NSPP TESTS 106-108 AND
TESTS 204-207, DATA RECORD REPORT**

R. E. Adams
T. S. Kress M. I. Tobias

Manuscript Completed — January 30, 1981

Date Published — March 1981

NOTICE This document contains information of a preliminary nature.
It is subject to revision or correction and therefore does not represent a
final report

Prepared for the
U S Nuclear Regulatory Commission
Office of Nuclear Regulatory Research
Under Interagency Agreements DOE 40-551-75 and 40-552-75

NRC FIN No. B0121

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
DEPARTMENT OF ENERGY

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MGW/gsee



CONTENTS

| | Page |
|---|------|
| SUMMARY | v |
| ABSTRACT | 1 |
| 1. INTRODUCTION | 1 |
| 2. NUCLEAR SAFETY PILOT PLANT (NSPP) | 2 |
| 2.1 NSPP System | 2 |
| 2.1.1 Equipment for measurement of aerosol parameters | 2 |
| 2.1.2 Equipment for measurement of system parameters | 4 |
| 2.1.3 Aerosol generating equipment | 4 |
| 2.2 NSPP Test Procedures | 5 |
| 2.2.1 Sodium oxide aerosol tests | 5 |
| 2.2.2 Uranium oxide aerosol tests | 5 |
| 3. DESCRIPTION OF INDIVIDUAL AEROSOL TESTS | 7 |
| 3.1 Sodium Oxide Test 106 | 7 |
| 3.2 Sodium Oxide Test 107 | 7 |
| 3.3 Sodium Oxide Test 108 | 7 |
| 3.4 Uranium Oxide Test 204 | 8 |
| 3.5 Uranium Oxide Test 205 | 8 |
| 3.6 Uranium Oxide Test 206 | 8 |
| 3.7 Uranium Oxide Test 207 | 8 |
| 4. RESULTS FROM INDIVIDUAL AEROSOL TESTS | 9 |
| 4.1 Summary and Data Graphs for Test 106 | 11 |
| 4.2 Summary and Data Graphs for Test 107 | 25 |
| 4.3 Summary and Data Graphs for Test 108 | 39 |
| 4.4 Summary and Data Graphs for Test 204 | 53 |
| 4.5 Summary and Data Graphs for Test 205 | 67 |
| 4.6 Summary and Data Graphs for Test 206 | 81 |
| 4.7 Summary and Data Graphs for Test 207 | 95 |
| REFERENCES | 109 |



SUMMARY

This data record report summarizes results from three sodium oxide aerosol behavior tests and four uranium oxide aerosol behavior tests in the Nuclear Safety Pilot Plant (NSPP) project, which is part of the Aerosol Release and Transport (ART) program at Oak Ridge National Laboratory (ORNL), sponsored by the Nuclear Regulatory Commission-Advanced Reactor Safety Research (NRC-ARSR). The sodium oxide aerosol tests constitute a continuation of a planned series of tests utilizing both sodium spray and sodium pool fires as sources of aerosol. The uranium oxide aerosol tests are also a continuation of a planned series. The uranium oxide aerosol was generated by a new technique using an argon plasma metallizing torch, which produced higher aerosol mass concentrations than heretofore possible with the previous generation technique. These data on sodium oxide and uranium oxide aerosol behaviors will be used along with future NSPP data to provide experimental validation of aerosol behavioral models being developed for NRC-ARSR.

Of the three sodium oxide aerosol tests, two involved sodium spray fires and the other, a sodium pool fire. Aerosol mass concentration in the 40- to 45- $\mu\text{g}/\text{cm}^3$ range was achieved by the spray fires; the small sodium pool fire test, which produced an aerosol concentration of 2.3 $\mu\text{g}/\text{cm}^3$, was intended to supplement previous tests in the 6- to 25- $\mu\text{g}/\text{cm}^3$ concentration range. The four uranium oxide aerosol tests covered an aerosol concentration range from 0.7 to 5.6 $\mu\text{g}/\text{cm}^3$ and supplemented previous tests performed in the 0.04- to 0.20- $\mu\text{g}/\text{cm}^3$ range.

In this data record report, a brief description of each test and its results in the form of tables and graphs is given. Included are data on aerosol mass concentration, aerosol fallout rate, aerosol plateout rate, cumulative mass fallout and plateout, aerosol particle size, vessel atmosphere pressure, vessel atmosphere temperatures, thermal gradients near the vessel wall, and final aerosol distribution within the vessel at the termination of the test.

SODIUM OXIDE AND URANIUM OXIDE AEROSOL EXPERIMENTS: NSPP TESTS 106-108 AND TESTS 204-207, DATA RECORD REPORT

R. E. Adams
T. S. Kress M. L. Tobias

ABSTRACT

This data record report describes three sodium oxide aerosol tests and four uranium oxide aerosol tests conducted in the Nuclear Safety Pilot Plant project at Oak Ridge National Laboratory. The goal of this project is to establish the validity (or level of conservatism) of the aerosol behavioral code, HAARM-3, and follow-on codes under development at the Battelle Columbus Laboratories for the U.S. Nuclear Regulatory Commission. Descriptions of the seven tests with tables and graphs summarizing the results are included.

1. INTRODUCTION

The Nuclear Safety Pilot Plant (NSPP) project is part of the Aerosol Release and Transport (ART) program at Oak Ridge National Laboratory (ORNL), sponsored by the Nuclear Regulatory Commission-Advanced Reactor Safety Research (NRC-ARSR). The NSPP project involves studying the behavior in secondary containment environments of aerosols released under liquid-metal-cooled fast breeder reactor (LMFBR) accident conditions. These accident conditions involve mixtures of aerosols containing (1) both fuel and sodium oxides, (2) relatively high aerosol concentration, (3) temperature and pressure transients due to sodium burning, (4) possible presence of moisture in the secondary containment air atmosphere, and (5) continuous as well as instantaneous sources of aerosol.

The NSPP program presently focuses on establishing the validity (or level of conservatism) of the aerosol behavioral code, HAARM-3, and follow-on codes under development for NRC at Battelle Columbus Laboratories. Special emphasis is placed on the applicability of the codes for describing the behavior of mixtures of aerosols and on the model features related to the effects of vessel size.

The test program provides for single-component aerosol tests using either sodium oxides or uranium oxides to simulate fuel oxide aerosols. These tests will be followed by two-component aerosol tests in which sodium oxides and uranium oxides will be mixed in varying proportions and time sequences to study the interaction of the two individual aerosols as well as the composite behavior of the aerosol mixture. Previous data record reports^{1,2} covered the first five sodium oxide aerosol tests, the first four uranium oxide aerosol tests, and two preliminary mixed uranium oxide-sodium oxide aerosol tests. This report covers three additional sodium oxide tests and four additional uranium oxide tests which utilized a new aerosol generator. Future reports in this series will cover two-component mixed oxide aerosol tests and additional special-purpose single-component aerosol tests.

2. NUCLEAR SAFETY PILOT PLANT (NSPP)

2.1 NSPP System

The NSPP is composed of a test vessel, aerosol generating equipment, analytical sampling and system parameter measuring equipment, and a liquid spray decontaminating system. A schematic representation of the system is given in Fig. 1. The NSPP vessel is a stainless steel cylinder with dished ends having a diameter of 3.05 m (10 ft), a total height of 5.49 m (18 ft), and a volume of 38.3 m³ (1350 ft³). The wall thickness of the vessel is 9.53 mm (0.375 in.), the floor area is 7.7 m² (82.9 ft²), and the internal surface area (including top and floor) is 68.9 m² (741.6 ft²). The design temperature limitation is 150°C, while the design pressure limitation is 0.41 MPa (60 psia).

2.1.1 Equipment for measurement of aerosol parameters

Aerosol mass concentration. Aerosol mass concentrations are obtained with two types of filter samplers. The in-vessel sampler is a self-contained unit with 12 filter tubes, a sequential valve, and a stepping motor; mechanical operation of this sampler is remote from the control room. The other type, the wall aerosol sampler (so-called because the sampler penetrates the vessel wall through a ball valve and flange arrangement), is inserted and retrieved manually. The sampling procedure for either type of sampler requires drawing a measured volume of containment vessel atmosphere through a sampling pack that contains four membrane filters in series. The filter material is Millipore Fluoropore with a 0.5-µm pore size. The quantity of uranium on each filter paper and associated metal parts is determined by a fluorometric technique, the quantity of sodium is determined by atomic absorption spectroscopy.

The locations of the four in-vessel samplers and the three wall aerosol samplers are noted in Table 1.

Table 1. Locations of aerosol mass concentration samplers

| Sampler | Radial direction | Distance from bottom [m (ft)] | Radial distance from centerline |
|---------------|------------------|-------------------------------|---------------------------------|
| In-vessel 151 | East | 4.15 (13.6) | 0.58 m (1.90 ft) |
| In-vessel 152 | Southeast | 4.15 (13.6) | 1.06 m (3.48 ft) |
| In-vessel 153 | East | 2.80 (9.2) | 1.09 m (3.58 ft) |
| In-vessel 154 | Southeast | 1.34 (4.4) | 1.11 m (3.64 ft) |
| Wall 155 | South | 4.15 (13.6) | 0.61 m (2.0 ft) |
| Wall 156 | Southeast | 2.80 (9.2) | 25 mm (1 in.) from wall |
| Wall 157 | Southwest | 2.80 (9.2) | 1.06 m (3.48 ft) |

Aerosol fallout rate. Aerosol fallout rate is determined with an incremental, retrievable coupon sampler. This system also penetrates the vessel wall through a ball valve and flange arrangement. The sampler is located in the southwest quadrant at 51 mm (2 in.) from the vessel wall and is ~0.56 m (1.83 ft) above the low point of the vessel floor.

Aerosol plateout rate. Aerosol plateout rate is determined with an incremental, retrievable coupon sampler, the coupon, which is in the form of a disk, fits flush with the vessel wall. This system penetrates the vessel wall through a ball valve and flange arrangement and is located in the northeast quadrant ~2.92 m (9.6 ft) above the low point of the vessel floor.




Fig. 1. Nuclear Safety Pilot Plant (NSPP) flow sheet.

Total fallout collectors. Total fallout is determined with six shallow dishes, 65 mm diam (2.56 in), placed along a vessel radius near the bottom of the vessel within the northwest quadrant. The dishes are placed ~30 mm (1.2 in) apart, the edge of the first dish is 13 mm (0.5 in) from the wall. The exposed collectors are retrieved with remote tools at the end of sampling operations before liquid spray decontamination of the vessel interior.

Total plateout collectors. Total plateout is determined with three flat disks, 61 mm diam (2.38 in), mounted flat on the vessel wall. One disk is mounted on the east side of the vessel at an elevation of 0.76 m (2.5 ft) from the low point of the vessel bottom. The other two disks are mounted on the west side of the vessel, 0.76 and 2.67 m (2.5 and 8.75 ft), respectively, from the bottom of the vessel. These exposed disks are also retrieved with remote tools along with the total fallout collectors.

Aerosol particle size. Aerodynamic particle size is measured with a cascade impactor (Andersen Mark III Particle Sizing Stack Sampler). This is an eight-stage impactor, operating at a gas flow of $2.36 \times 10^{-4} \text{ m}^3/\text{s}$ (0.5 cfm), and covers the aerodynamic particle diameter range from 0.54 to 13.6 μm . The sampling location is in the southwest quadrant at 0.457 m (1.5 ft) from the vessel wall at ~2.9 m (9.6 ft) from the low point of the vessel floor.

During the uranium oxide aerosol tests, samples are taken at the same location for electron microscopy. The aerosol is deposited onto carbon-coated copper grids using a Model 3100 Electrostatic Aerosol Sampler (Thermo-Systems, Inc.).

2.1.2 Equipment for measurement of system parameters

Temperature of the vessel atmosphere. Twelve thermocouples (Chromel-Alumel) are used for the measurement of the vessel atmospheric temperatures. At each of three elevations in the vessel, there are four thermocouples, with one placed in each quadrant. The elevations are 1.22, 2.74, and 4.27 m (4, 9, and 14 ft). Thermocouple responses are recorded with both strip-chart recorders and a Digitrend data logger.

Wall temperature gradients. Two thermocouple arrays, each having five thermocouples, are mounted near the wall, one at 2.7-m (9-ft) elevation on the east radius and the other at 1.2-m (4-ft) elevation on the north radius. The thermocouples in each array are located at 10, 5, 2.5, and 1.25 mm (0.39, 0.2, 0.1, and 0.05 in) distance from the wall and on the wall surface, a sixth thermocouple is located on the outer surface of the vessel at approximately the same location. Thermocouple responses are recorded with both strip-chart recorders and the Digitrend data logger.

Vessel gas pressure. Vessel gas pressure is measured with a pressure cell. The pneumatic signal is converted to an equivalent electrical signal and recorded on a strip-chart recorder and with the Digitrend data logger.

2.1.3 Aerosol generating equipment

Sodium oxide aerosols. Two methods were used to produce sodium oxide aerosols. First, to simulate an aerosol produced by a sodium spray fire, heated sodium metal at 773 K (500°C) was injected into the test vessel via a single spray nozzle centrally located in the upper region of the vessel. At an elevation of 3.96 m (13 ft) from the low point of the vessel floor, the nozzle and its spray were directed downward. The average sodium droplet diameter, estimated from the manufacturer's literature on water sprays, was approximately 480 μm .

Using the second method, sodium oxide aerosols from a pool fire were produced by injecting heated sodium at 773 K (500°C) into a preheated burn pan [0.5 m² (5.34 ft²)] located near the bottom of the vessel.

Uranium oxide aerosols. In previous tests, the uranium oxide aerosol was generated by consuming a uranium metal electrode in a dc arc.² The aerosol concentration produced was low, 0.2 μg/cm³ or less. For the tests covered in this report, an alternate generation method, developed by another group within the ART program,³ was adapted to the NSPP system. Essentially, the generator is composed of a METCO Model 7M Plasma Flame Spray System and a special water-cooled combustion adapter head through which uranium metal powder and oxygen gas are added to the argon plasma flame. The resulting mix of high temperature, uranium metal vapor, and oxygen combine to produce an aerosol of uranium oxide (U₃O₈). With this generator, aerosol concentrations up to about 6 μg/cm³ have been achieved.

2.2 NSPP Test Procedures

2.2.1 Sodium oxide aerosol tests

Each of the sodium oxide aerosol tests has followed essentially the same procedure. The vessel atmosphere was air at an initial relative humidity of <20%. The sodium inventory, contained in the sodium transfer tank, is heated to about 773 K (500°C) and then transferred to the heated spray nozzle or heated sodium burn pan by argon gas pressure. The resulting sodium oxidation produces the oxide aerosol, and its behavior is monitored for 24 h (Tests 106 and 107) or 48 h (Test 108). The burn pan was allowed to cool to about 473 K (200°C) and then maintained at that temperature for about 10 h to maintain convection currents and to ensure mixing of the aerosol. At the conclusion of the 24-h test period, the vessel is purged with dry filtered compressed air; all gases leaving the vessel are discharged into the off-gas disposal stack by way of a water scrubber. During this step, a gas sample is taken through a filter pack to determine the amount of sodium oxide aerosol contained in these gases. This step is omitted when the test duration is 48 h; the amount of aerosol remaining airborne at 48 h is inconsequential. Next, the top of the vessel is opened and the various samplers within the vessel are removed and photographs are taken of the interior. The top is replaced, and the vessel atmosphere is purged with nitrogen to reduce the oxygen concentration to <4% prior to operation of the water sprays for vessel decontamination. The lowered oxygen concentration ensures against an energetic hydrogen-oxygen recombination in the event any unoxidized sodium metal remains in the burn pan. The water spray decontamination proceeds sequentially from the vessel floor to the sodium burn pan, the vessel walls, and the top head of the vessel. Each batch of decon water and rinse water is weighed and sampled for analysis prior to disposal. From these data, a sodium material balance is obtained.

All of the aerosol sampling devices (filter packs, impactors, coupons) are disassembled, packaged, and submitted to the ORNL analytical laboratory where the sodium content of each sample is determined by atomic absorption spectroscopy.

2.2.2 Uranium oxide aerosol tests

Each of the four uranium oxide aerosol tests has also followed essentially the same procedure. The vessel atmosphere was air at an initial relative humidity of <20%. Uranium oxide aerosol (U₃O₈) is produced with the plasma torch generator, and the behavior of the aerosol within the vessel is

monitored for 48 h. The sodium burn pan, heated to a temperature of approximately 473 K (200° C), is utilized to maintain convection currents within the vessel over the first 10 h of the test to ensure mixing of the aerosol. At the conclusion of the test period, the samplers are removed and photographs are taken as in the sodium oxide tests. The interior surfaces of the vessel are then remotely decontaminated with a heated solution which is a mixture of oxalic acid, hydrogen peroxide, ammonium citrate, ammonium hydroxide, and water. The spray decontamination proceeds sequentially from the vessel floor to the burn pan, the walls, and the top head of the vessel. Each batch of decon solution and rinse water is weighed and sampled for analysis prior to disposal. All of the sampling devices are disassembled, packaged, and submitted for uranium analysis by a fluorometric technique.

3. DESCRIPTION OF INDIVIDUAL AEROSOL TESTS

3.1 Sodium Oxide Test 106

This was the second sodium spray fire test performed in the NSPP. The first test,¹ designated Test 105, utilized a sodium spray system centrally mounted near the bottom of the vessel with spray directed upward. Results from that test were inconclusive. For this test, the single spray nozzle was centrally located in the upper region of the vessel with spray directed downward. Approximately 5 kg (11 lb) of heated sodium was injected into the relatively dry (initial relative humidity <20%) vessel atmosphere over a period of 3 min. The observed pressure rise because of the burning sodium was 0.038 MPa (5.5 psi), a vertical temperature gradient existed for a short period of time with maximum temperatures of 653, 573, and 413 K (380, 300, and 140°C) measured in the upper, middle, and lower regions of the vessel. Approximately 10 min after termination of the sodium spray, the pressure and temperature transients had disappeared. Early aerosol mass samples were not obtained because of a malfunction of the in-vessel sampling system. Posttest examination revealed that electrical control had been lost as a result of the impact of burning sodium on some exposed electrical wiring. The first filter samples were taken with wall aerosol samplers at 17 min after start of sodium injection. The average sodium oxide aerosol mass concentration at that time was found to be $4.2 \mu\text{g}/\text{cm}^3$. By extrapolation to the time of termination of the sodium spray, an estimated maximum concentration of approximately $45 \mu\text{g}/\text{cm}^3$ may be obtained. Sampling operations for aerosol particle diameter and fallout and plateout rates were more successful. Test duration was 25 h.

3.2 Sodium Oxide Test 107

This test was conducted in a manner similar to that for Test 106. The sodium oxide aerosol was produced by injecting 10 kg (22 lb) of heated sodium through the single spray nozzle over a period of 6.5 min. The observed pressure rise was 0.043 MPa (6.3 psi), again a vertical temperature gradient was produced for a short period of time with maximum temperatures of 689, 643, and 480 K (416, 370, and 207°C) measured in the upper, middle, and lower regions of the vessel. Approximately 14 min after termination of the sodium spray, the pressure and temperature gradients had disappeared. The first set of in-vessel filter samples was taken at 2.5 min after spray termination. Again, electrical problems developed in three of the four in-vessel samplers because of the exposure to high temperatures. The operable in-vessel sampler was located 1.34 m (4.4 ft) from the vessel floor. Filter sampling with the wall samplers was successful. Extrapolation of the aerosol concentration sampler data to termination of the sodium spray produced an estimated maximum concentration of $42 \mu\text{g}/\text{cm}^3$. Test duration was 24 h.

3.3 Sodium Oxide Test 108

The purpose of this test was to study the behavior of a low-concentration sodium oxide aerosol under dry atmospheric conditions. This test completed the series of tests on sodium oxide aerosols produced by pool fires. Earlier tests in this series have been reported previously.¹ The aerosol was generated by a sodium pool fire of 0.45 kg (1 lb) of heated sodium metal which persisted for approximately 2 to 2.5 min. The initial vessel atmosphere was air at a relative humidity of <20%, and the initial pressure and temperatures were slightly above ambient because of the preheating of the sodium burn pan and delivery lines. A maximum aerosol concentration of $2.3 \mu\text{g}/\text{cm}^3$ was measured at 10 min after initiation of the pool fire. Test duration was 48 h.

3.4 Uranium Oxide Test 204

This test was the first of a series to study the behavior of a uranium oxide aerosol at concentrations higher than those produced with the dc arc generator. The first attempt to perform Test 204 with the newly installed plasma torch generator failed due to clogging of the very fine uranium metal powder in the powder feed system supplying the plasma torch. Modifications were then made to the powder feed system and a second attempt was made. This second attempt was more successful even though some powder clogging was again encountered. The generator was operated for 20 min although most of the aerosol production occurred in the first 7 min. The first measured aerosol mass concentration at 4 min after termination of generator operation was $0.7 \mu\text{g}/\text{cm}^3$. Test duration was 48 h.

3.5 Uranium Oxide Test 205

For this test, uranium metal powder with a larger particle size was used in an effort to circumvent the powder clogging problems encountered during Test 204. Aerosol generation was terminated after 5 min because of a severe reduction in powder injection rate. An estimated 0.2 kg (0.44 lb) of uranium powder was injected into the combustion chamber during this period. Posttest examination revealed that the powder injection problem was because of uranium oxide plugging of the exits of the capillary powder feed tubes within the generator's combustion chamber. The first measured aerosol concentration at 5.5 min after termination of generation was $2.7 \mu\text{g}/\text{cm}^3$; extrapolation to the time of termination of generation gave an estimated maximum aerosol concentration of approximately $4 \mu\text{g}/\text{cm}^3$. Duration of the test was 48 h.

3.6 Uranium Oxide Test 206

Modifications were made to the capillary powder supply tubes of the generator before conduct of this test. The powder feeder was charged with 1 kg (2.2 lb) of uranium metal powder. All of this material was injected into the plasma torch generator during a 9.3-min period. At 5.3 min after termination of the generation, the aerosol concentration was measured to be $3.8 \mu\text{g}/\text{cm}^3$; extrapolation to time of termination of generation gave an estimated maximum concentration of about $5.6 \mu\text{g}/\text{cm}^3$. Test duration was 48 h.

3.7 Uranium Oxide Test 207

This test differed from the previous tests in that aerosol mass samples were taken during the aerosol generating period to define the early increase in aerosol concentration. The powder feeder was charged with 2 kg (4.4 lb) of uranium metal powder. All of this material was injected into the plasma torch generator during a 26-min period. The aerosol concentration achieved was not as large as was anticipated. Posttest examination revealed that a large quantity of uranium oxide had accumulated in the outlet of the generator. The maximum measured aerosol concentration was $3.2 \mu\text{g}/\text{cm}^3$ at 23 min after start of aerosol generation. Test duration was 48 h.

4. RESULTS FROM INDIVIDUAL AEROSOL TESTS

The results from each test are summarized in tables and graphs in this section. At the beginning of each section, a table is presented listing test parameters, parameters measured, and a summary of test results. Following each of these initial tables are graphs and numbered tables reporting aerosol mass concentrations, fallout and plateout rates, cumulative mass fallout and plateout, aerosol particle size, vessel pressure, vessel atmosphere temperatures, and temperature gradients near the vessel wall as functions of time. Time is measured from the start of aerosol generation. To aid in interpretation of these graphs and tables, the following comments are offered.

Mass concentration. Results for all seven mass concentration filter samplers are presented in one graph for Tests 108 and 204–207. For Tests 106 and 107, only results from operable samplers are presented. Values of mass concentrations for U_3O_8 or Na_2O within the vessel atmosphere are computed under vessel atmospheric conditions existing at the time of the sample. The legend on the graphs lists the elevation and the radial distance from centerline for all samplers. The radial direction of each sampler is given in Table I.

Aerosol fallout and plateout rates; cumulative values for fallout and plateout mass. The data reported in these graphs were obtained from the coupon samplers. An average fallout or plateout rate was computed from the mass of aerosol deposited on the coupon during the exposure period. The sample time is taken as one-half the exposure period added to the time at the start of the sample.

Values for cumulative mass fallout or plateout were computed by multiplying the fallout and plateout rate by the time of exposure of the coupon and the appropriate area within the vessel.

Aerosol particle size. The data presented were derived with an Andersen Mark III Particle Sizing Stack Sampler (cascade impactor). The raw data were processed to the extent necessary to produce the tables included in this report.

Vessel gas pressure. For all the tests, the initial gas pressure was atmospheric (0 psig). During Tests 106–108, the primary pressure rise was produced by burning the sodium. During Tests 204–207, a slight initial pressure rise was produced by heat from the plasma torch generator and the heated burn pan used to maintain convection currents. However, the second pressure rise in Tests 204–207, noted after about 3000 s, is due to the heat from the burn pan. The graphs depict gas pressure as a function of time after start of aerosol generation, except in the case of Test 108, where time starts at 47 s after start of aerosol generation.

Vessel gas temperatures. Three graphs are presented displaying the temperatures within each of the four quadrants at three different elevations. The legend on each graph gives the elevation measured from the vessel midplane and the radial distance from the centerline of the vessel. An elevation of +1.5 m from midplane is 4.27 m (14 ft) from the bottom of the vessel; the elevation at midplane is 2.74 m (9 ft), and the elevation at -1.5 m is 1.22 m (4 ft) from the bottom of the vessel. One thermocouple at the +1.5-m level (TE 4-7) is near the exit from the plasma torch aerosol generator and senses the heat of the plasma flame; consequently during uranium oxide aerosol generation, this thermocouple indicates a temperature higher than others located at this elevation. Also, for Test 108, time begins at 47 s after start of sodium pool fire.

Temperature gradient at vessel wall. Two graphs are presented to illustrate the temperature gradients near the vessel wall on the north radius (-1.5 m from midplane of the vessel) and on the east radius at the centerline. Two thermocouples measure the temperature on both the outside and inside vessel wall; four other thermocouples measure temperatures at varying distances from the inside wall.

Three additional graphs are also presented. Two of these graphs display the temperatures at various distances from the wall at selected values of time from start of aerosol generation. A third graph illustrates the magnitude of the temperature gradient (degrees Celsius per centimeter) at the two thermocouple rake locations as a function of time. For runs 106 and 107, a large negative temperature gradient may be noted at the -1.5-m elevation; this was caused by the impact of burning sodium on the vessel wall near the thermocouple array which produces a wall temperature higher than that of the nearby vessel atmosphere. This value is computed by subtracting the wall temperature from the atmosphere temperature measured by the thermocouple at 0.125 cm and then dividing the result by 0.125 cm .

Posttest results. In this section, the total aerosol mass concentration achieved is listed. This value is either measured at, or extrapolated to the time of termination of aerosol generation. The final aerosol distribution (percent) at the end of the test is calculated from the total mass fallout and plateout as determined by the *total* fallout and plateout samplers; the mass of airborne aerosol is measured by the final filter samplers taken just prior to termination.

4.1 Summary and Data Graphs for Test 106

Aerosol source

Test aerosol used NaCl
 Aerosol generator Spray fire
 Duration of aerosol generation 2 min

Vessel atmosphere prior to aerosol generation

Oxygen level 21%
 Relative humidity < 20%
 Temperature 60°C
 Pressure 1 atmosphere

Duration of test operations 24 hr

Aerosol parameters measured and figure number

Mass concentration of aerosol Fig 2
 Aerosol fallout rate Fig 3
 Aerosol plateau rate Fig 4
 Cumulative mass fallout and plateau Fig 5
 Aerosol particle size Fig 6

System parameters measured and figure number

Vessel atmosphere pressure Fig 6
 Vessel atmosphere temperatures Fig 7
 Thermal gradients at vessel wall Fig 8

Posttest results

Maximum aerosol concentration at vessel top
 Aerosol distribution at end of test
 Still suspended in vessel atmosphere 0.002%
 Plated onto internal surfaces
 Settled onto vessel floor 0.4%

Table 2. Aerosol fallout data for Test 106

| Aerodynamic mass median diameter (µm) | Sample time | | | | | | Total |
|---------------------------------------|-------------|------------|----------|-------------|-----------|-------------|-------|
| | (12.5 min) | (42.5 min) | (85 min) | (127.5 min) | (170 min) | (212.5 min) | |
| 13.7 | 83.7 | 87.4 | 93.0 | 96.7 | 99.9 | 103.2 | 8 |
| 8.5 | 72.7 | 78.5 | 84.1 | 88.5 | 92.8 | 97.1 | 7 |
| 5.8 | 56.4 | 56.1 | 55.2 | 54.3 | 53.4 | 52.5 | 6.7 |
| 4.0 | 38.7 | 39.6 | 40.7 | 41.8 | 42.9 | 44.0 | 4 |
| 2.5 | 21.6 | 20.9 | 20.9 | 20.6 | 20.3 | 19.9 | 2 |
| 1.3 | 5.4 | 5.1 | 4.8 | 4.5 | 4.2 | 3.9 | 1.5 |
| 0.78 | 1.6 | 2.4 | 3.4 | 4.4 | 5.4 | 6.4 | 1.6 |
| 0.53 | 0.8 | 1.3 | 2.3 | 3.3 | 4.3 | 5.3 | 1.2 |

^aPercent of mass associated with 0.5 microns smaller than indicated.




Fig. 2. Aerosol mass concentrations (measured with three samplers) vs time—NSPP Test 106.




Fig. 3. Fallout rate vs time—NSPP Test 106.




Fig. 4. Plateout rate vs time—NSPP Test 106.




Fig. 5. Cumulative fallout and plateout mass vs time—NSPP Test 106.

ORNL-DWG 80-5728 ETD




Fig. 6. In-vessel pressure vs time—NSPP Test 106.




Fig. 7. Temperature measurements at 1.5 m above vessel midplane—NSPP Test 106.

ORNL DWG 80-5730 ETD




Fig. 8. Temperature measurements at vessel midplane—NSPP Test 106.




Fig. 9. Temperature measurements at 1.5 m below vessel midplane—NSPP Test 106.




Fig. 10. Temperature measurements near the vessel wall at vessel midplane—NSPP Test 106.

ORNL-DWG 80-5733 ETD




Fig. 11. Temperature measurements near the vessel wall at 1.5 m below vessel midplane—NSPP Test 106.

ORNL-DWG 80-5734 ETD




Fig. 12. Temperature profile near the vessel wall at mid plane for various times after start of aerosol generation (note that the distance is measured from the inside wall toward the center of the vessel)—NSPP Test 106.

ORNL-DWG 80-5735 ETD




Fig. 13. Temperature profile near the vessel wall at 1.5 m below midplane for various times after start of aerosol generation—NSPP Test 106.




Fig. 14. Temperature gradient at the vessel wall for two elevations—NSPP Test 106.

4.2 Summary and Data Graphs for Test 107

Aerosol source

| | |
|--------------------------------|-------------------|
| Test aerosol used | Na ₂ O |
| Aerosol generator | Spray fire |
| Duration of aerosol generation | 6.5 min |

Vessel atmosphere prior to aerosol generation

| | |
|-------------------|---------|
| Oxygen level | 21% |
| Relative humidity | <20% |
| Temperature | Ambient |
| Pressure | Ambient |

Duration of test operations

24 h

Aerosol parameters measured and figure number

| | |
|--------------------------------------|---------|
| Mass concentration of aerosol | Fig 15 |
| Aerosol fallout rate | Fig 16 |
| Aerosol plateout rate | Fig 17 |
| Cumulative mass fallout and plateout | Fig 18 |
| Aerosol particle size | Table 3 |

System parameters measured and figure number

| | |
|----------------------------------|------------|
| Vessel atmosphere pressure | Fig 19 |
| Vessel atmosphere temperatures | Figs 20–22 |
| Thermal gradients at vessel wall | Figs 23–27 |

Posttest results

| | |
|--|-----------------------|
| Maximum aerosol concentration achieved | 42 µg/cm ³ |
| Aerosol distribution at end of test | |
| Still suspended in vessel atmosphere | 0.001% |
| Plated onto internal surfaces | 36.3% |
| Settled onto vessel floor | 63.7% |

Table 3. Andersen impactor data—Test 107

| Aerodynamic mass median diameter (µm) | Sample No ^a | | | | | | |
|--|------------------------|---------------|---------------|----------------|----------------|----------------|----------------|
| | 1 (12.7 min) | 2 (30 min) | 3 (75 min) | 4 (145 min) | 5 (226 min) | 6 (380 min) | 7 (558 min) |
| 13.7 | 96.9 | 81.9 | 88.6 | 96.8 | 99.3 | 99.4 | 98.8 |
| 8.5 | 91.1 | 69.8 | 80.6 | 92.2 | 96.5 | 98.2 | 97.8 |
| 5.8 | 68.7 | 50.9 | 59.4 | 69.8 | 80.1 | 86.7 | 93.7 |
| 4.0 | 49.7 | 36.2 | 42.6 | 49.0 | 60.4 | 68.8 | 79.6 |
| 2.5 | 26.6 | 21.3 | 24.4 | 26.6 | 35.2 | 41.2 | 44.8 |
| 1.3 | 10.2 | 8.2 | 12.0 | 14.3 | 21.5 | 22.1 | 7.6 |
| 0.78 | 4.2 | 4.2 | 8.2 | 12.0 | 19.0 | 19.1 | 1.5 |
| 0.53 | 3.3 | 3.8 | 7.6 | 11.6 | 18.6 | 16.0 | 0 |

^aPercent of mass associated with diameters smaller than indicated size




Fig. 15. Aerosol mass concentrations vs time—NSPP Test 107.




Fig. 16. Fallout rate vs time—NSPP Test 107.




Fig. 17. Plateout rate vs time—NSPP Test 107.




Fig. 18. Cumulative fallout and plateout mass vs time—NSPP Test 107.

ORNL-DWG 80-5741 ETD




Fig. 19. In-vessel pressure vs time—NSPP Test 107.

ORNL-DWG 80-5742 ETD




Fig. 20. Temperature measurements at 1.5 m above vessel midplane—NSPP Test 107.




Fig. 21. Temperature measurements at vessel midplane—NSPP Test 107.




Fig. 22. Temperature measurements at 1.5 m below vessel midplane—NSPP Test 107.




Fig. 23. Temperature measurements near the vessel wall at vessel midplane—NSPP Test 107.




Fig. 24. Temperature measurements near the vessel wall at 1.5 m below vessel midplane—NSPP Test 107.




Fig. 25. Temperature profile near the vessel wall at midplane for various times after start of aerosol generation (note that the distance is measured from the inside wall toward the center of the vessel)—NSPP Test 107.




Fig. 26. Temperature profile near the vessel wall at 1.5 m below midplane for various times after start of aerosol generation—NSPP Test 107.




Fig. 27. Temperature gradient at the vessel wall for two elevations—NSPP Test 107.

4.3 Summary and Data Graphs for Test 108

Aerosol source

| | |
|--------------------------------|-------------------|
| Test aerosol used | Na ₂ O |
| Aerosol generator | Pool fire |
| Duration of aerosol generation | 2–2.5 min |

Vessel atmosphere prior to aerosol generation

| | |
|-------------------|---------|
| Oxygen level | 21% |
| Relative humidity | <20% |
| Temperature | Ambient |
| Pressure | Ambient |

Duration of test operations

48 h

Aerosol parameters measured and figure number

| | |
|--------------------------------------|---------|
| Mass concentration of aerosol | Fig 28 |
| Aerosol fallout rate | Fig 29 |
| Aerosol plateout rate | Fig 30 |
| Cumulative mass fallout and plateout | Fig 31 |
| Aerosol particle size | Table 4 |

System parameters measured and figure number

| | |
|----------------------------------|------------|
| Vessel atmosphere pressure | Fig 32 |
| Vessel atmosphere temperatures | Figs 33–35 |
| Thermal gradients at vessel wall | Figs 36–40 |

Posttest results

| | |
|--|------------------------|
| Maximum aerosol concentration achieved | 2.3 µg/cm ³ |
| Aerosol distribution at end of test | |
| Still suspended in vessel atmosphere | 0.002% |
| Plated onto internal surfaces | 52.7% |
| Settled onto vessel floor | 47.3% |

Table 4. Andersen impactor data—Test 108

| Aerodynamic mass median diameter (µm) | Sample No ^a | | | | | | |
|--|------------------------|-----------------|----------------|----------------|----------------|----------------|-----------------|
| | 1 (23.5 min) | 2 (56.6 min) | 3 (111 min) | 4 (231 min) | 5 (350 min) | 6 (596 min) | 7 (1445 min) |
| 13.7 | 99.6 | 96.7 | 99.2 | 99.7 | 99.8 | 99.7 | 99.3 |
| 8.5 | 98.4 | 90.5 | 96.1 | 98.8 | 99.6 | 99.5 | 98.9 |
| 5.8 | 88.7 | 76.8 | 73.9 | 84.9 | 93.3 | 98.9 | 98.2 |
| 4.0 | 70.4 | 45.3 | 37.0 | 59.5 | 75.1 | 92.0 | 97.3 |
| 2.5 | 26.6 | 15.3 | 12.9 | 23.5 | 31.2 | 60.8 | 89.1 |
| 1.3 | 4.2 | 4.0 | 2.9 | 2.8 | 5.8 | 25.3 | 29.8 |
| 0.78 | 1.8 | 2.3 | 1.4 | 1.1 | 1.8 | 18.4 | 15.5 |
| 0.53 | 1.6 | 2.1 | 1.2 | 0.9 | 1.5 | 18.1 | 13.7 |

^aPercent of mass associated with diameters smaller than indicated size




Fig. 28. Aerosol mass concentrations vs time—NSPP Test 108.




Fig. 29. Fallout rate vs time—NSPP Test 108.




Fig. 30. Plateout rate vs time—NSPP Test 108.

ORNL-DWG 80-5753 ETD




Fig. 31. Cumulative fallout and plateout mass vs time—NSPP Test 108.

ORNL-DWG 80-5754 ETD




Fig. 32. In-vessel pressure vs time—NSPP Test 108.




Fig. 33. Temperature measurements at 1.5 m above vessel midplane—NSPP Test 108.




Fig. 34. Temperature measurements at vessel midplane—NSPP Test 108.




Fig. 35. Temperature measurements at 1.5 m below vessel midplane—NSPP Test 108.




Fig. 36. Temperature measurements near the vessel wall at vessel midplane—NSPP Test 108.




Fig. 37. Temperature measurements near the vessel wall at 1.5 m below vessel midplane—NSPP Test 108.




Fig. 38. Temperature profile near the vessel wall midplane for various times after start of aerosol generation (note that the distance is measured from the inside wall toward the center of the vessel)—NSPP Test 108.




Fig. 39. Temperature profile near the vessel wall at 1.5 m below midplane for various times after start of aerosol generation—NSPP Test 108.




Fig. 40. Temperature gradient at the vessel wall for two elevations—NSPP Test 108.

4.4 Summary and Data Graphs for Test 204

Aerosol source

| | |
|--------------------------------|-------------------------------|
| Test aerosol used | U ₃ O ₈ |
| Aerosol generator | Plasma torch |
| Duration of aerosol generation | 2–20 min |

Vessel atmosphere prior to aerosol generation

| | |
|-------------------|---------|
| Oxygen level | 21% |
| Relative humidity | <20% |
| Temperature | Ambient |
| Pressure | Ambient |

Duration of test operations

48 h

Aerosol parameters measured and figure number

| | |
|--------------------------------------|---------|
| Mass concentration of aerosol | Fig. 41 |
| Aerosol fallout rate | Fig. 42 |
| Aerosol plateout rate | Fig. 43 |
| Cumulative mass fallout and plateout | Fig. 44 |
| Aerosol particle size | Table 5 |

System parameters measured and figure number

| | |
|----------------------------------|-------------|
| Vessel atmosphere pressure | Fig. 45 |
| Vessel atmosphere temperatures | Figs. 46–48 |
| Thermal gradients at vessel wall | Figs. 49–53 |

Posttest results

| | |
|--|-------------------------------|
| Maximum aerosol concentration achieved | 0.7 $\mu\text{g}/\text{cm}^3$ |
| Aerosol distribution at end of test | |
| Still suspended in vessel atmosphere | 0.003% |
| Plated onto internal surfaces | 60.0% |
| Settled onto vessel floor | 40.0% |

Table 5. Andersen impactor data—Test 204

| Aerodynamic mass median diameter (μm) | Sample No. ^a | | | | | | |
|---|-------------------------|---------------|---------------|----------------|----------------|----------------|-----------------|
| | 1 (27 min) | 2 (47 min) | 3 (87 min) | 4 (177 min) | 5 (347 min) | 6 (586 min) | 7 (1458 min) |
| 13.7 | 99.6 | 99.6 | 99.0 | 98.3 | 97.1 | 99.1 | 99.2 |
| 8.5 | 99.4 | 99.3 | 98.5 | 97.5 | 96.2 | 98.8 | 99.0 |
| 5.8 | 98.7 | 97.6 | 96.8 | 91.6 | 92.7 | 97.9 | 98.6 |
| 4.0 | 97.8 | 91.2 | 89.3 | 74.1 | 74.9 | 92.6 | 97.9 |
| 2.5 | 93.2 | 65.7 | 62.1 | 38.6 | 44.3 | 62.7 | 92.5 |
| 1.3 | 58.3 | 28.9 | 26.0 | 7.9 | 7.2 | 16.9 | 29.7 |
| 0.78 | 18.0 | 7.5 | 4.0 | 0.9 | 1.1 | 2.6 | 5.2 |
| 0.53 | 1.7 | 0.2 | 0.6 | 0.1 | 0.3 | 0.5 | 1.5 |

^aPercent of mass associated with diameters smaller than indicated size.




Fig. 41. Aerosol mass concentrations vs time—NSPP Test 204.




Fig. 42. Fallout rate vs time—NSPP Test 204.




Fig. 43. Plateout rate vs time—NSPP Test 204.

ORNL-DWG 80-5766 ETD




Fig. 44. Cumulative fallout and plateout mass vs time—NSPP Test 204.




Fig. 45. In-vessel pressure vs time—NSPP Test 204.




Fig. 46. Temperature measurements at 1.5 m above vessel midplane—NSPP Test 204.




Fig. 47. Temperature measurements at vessel midplane—NSPP Test 204.

ORNL-DWG 80-5770 ETD




Fig. 48. Temperature measurements at 1.5 m below vessel midplane—NSPP Test 204.

ORNL-DWG 80-5771 ETD




Fig 49 Temperature measurements near the vessel wall at vessel midplane—NSPP Test 204




Fig. 50. Temperature measurements near the vessel wall at 1.5 m below vessel midplane—NSPP Test 204.

ORNL-DWG 80-5773 ETD




Fig. 51. Temperature profile near the vessel wall midplane for various times after start of aerosol generation (note that the distance is measured from the inside wall toward the center of the vessel)—NSPP Test 204.




Fig. 52. Temperature profile near the vessel wall at 1.5 m below midplane for various times after start of aerosol generation—NSPP Test 204.

ORNL-DWG 80-5775 ETD




Fig. 53. Temperature gradient at the vessel wall for two elevations—NSPP Test 204.

4.5 Summary and Data Graphs for Test 205

Aerosol source

| | |
|--------------------------------|-------------------------------|
| Test aerosol used | U ₃ O ₈ |
| Aerosol generator | Plasma torch |
| Duration of aerosol generation | 5 min |

Vessel atmosphere prior to aerosol generation

| | |
|-------------------|---------|
| Oxygen level | 21% |
| Relative humidity | <20% |
| Temperature | Ambient |
| Pressure | Ambient |

Duration of test operations

48 h

Aerosol parameters measured and figure number

| | |
|--------------------------------------|---------|
| Mass concentration of aerosol | Fig 54 |
| Aerosol fallout rate | Fig 55 |
| Aerosol plateout rate | Fig 56 |
| Cumulative mass fallout and plateout | Fig 57 |
| Aerosol particle size | Table 6 |

System parameters measured and figure number

| | |
|----------------------------------|------------|
| Vessel atmosphere pressure | Fig 58 |
| Vessel atmosphere temperatures | Figs 59-61 |
| Thermal gradients at vessel wall | Figs 62-66 |

Posttest results

| | |
|--|-----------------------------|
| Maximum aerosol concentration achieved | 4 $\mu\text{g}/\text{cm}^3$ |
| Aerosol distribution at end of test | |
| Still suspended in vessel atmosphere | <0.02% |
| Plated onto internal surfaces | 56.3% |
| Settled onto vessel floor | 43.7% |

Table 6. Andersen impactor data—Test 205

| Aerodynamic mass median diameter (μm) | Sample No ^a | | | | | | |
|---|------------------------|---------------|---------------|----------------|----------------|----------------|-----------------|
| | 1 (13 min) | 2 (36 min) | 3 (79 min) | 4 (182 min) | 5 (345 min) | 6 (549 min) | 7 (1531 min) |
| 13.7 | 98.8 | 97.1 | 97.9 | 74.2 | 79.0 | 84.3 | 85.7 |
| 8.5 | 97.1 | 93.4 | 95.1 | 57.2 | 69.0 | 76.2 | 77.6 |
| 5.8 | 92.4 | 80.7 | 82.9 | 45.8 | 51.8 | 65.4 | 64.6 |
| 4.0 | 81.8 | 65.1 | 71.2 | 36.1 | 42.2 | 56.4 | 53.6 |
| 2.5 | 60.6 | 43.4 | 48.4 | 25.9 | 31.0 | 43.6 | 39.3 |
| 1.3 | 27.9 | 18.8 | 16.9 | 14.5 | 13.6 | 19.5 | 17.4 |
| 0.78 | 10.2 | 6.2 | 3.1 | 6.5 | 2.7 | 6.6 | 6.2 |
| 0.53 | 2.8 | 0.6 | 0.7 | 0.6 | 1.4 | 1.8 | 1.7 |

^aPercent of mass associated with diameters smaller than indicated size




Fig. 54. Aerosol mass concentrations vs time—NSPP Test 205.




Fig. 55. Fallout rate vs time—NSPP Test 205.




Fig. 56. Plateout rate vs time—NSPP Test 205.




Fig. 57. Cumulative fallout and plateout mass vs time—NSPP Test 205.




Fig. 58. In-vessel pressure vs time—NSPP Test 205.




Fig. 59. Temperature measurements at 1.5 m above vessel midplane—NSPP Test 205.




Fig. 60. Temperature measurements at vessel midplane—NSPP Test 205.

ORNL-DWG 80-5783 ETD




Fig. 61. Temperature measurements at 1.5 m below vessel midplane—NSPP Test 205.

ORNL-DWG 80-5784 ETD




Fig. 62. Temperature measurements near the vessel wall at vessel midplane—NSPP Test 205.

ORNL-DWG 80-5785 ETD




Fig. 63. Temperature measurements near the vessel wall at 1.5 m below vessel midplane—NSPP Test 205.

ORNL-DWG 80-5786 ETD




Fig. 64. Temperature profile near the vessel wall at midplane for various times after start of aerosol generation (note that the distance is measured from the inside wall toward the center of the vessel)—NSPP Test 205.




Fig. 65. Temperature profile near the vessel wall at 1.5 m below midplane for various times after start of aerosol generation—NSPP Test 205.

ORNL-DWG 80-5788 ETD




Fig. 66. Temperature gradient at the vessel wall for two elevations—NSPP Test 205.

4.6 Summary and Data Graphs for Test 206

Aerosol source

| | |
|--------------------------------|-------------------------------|
| Test aerosol used | U ₃ O ₈ |
| Aerosol generator | Plasma torch |
| Duration of aerosol generation | 9.3 min |

Vessel atmosphere prior to aerosol generation

| | |
|-------------------|---------|
| Oxygen level | 21% |
| Relative humidity | <20% |
| Temperature | Ambient |
| Pressure | Ambient |

Duration of test operations

48 h

Aerosol parameters measured and figure number

| | |
|--------------------------------------|---------|
| Mass concentration of aerosol | Fig 67 |
| Aerosol fallout rate | Fig 68 |
| Aerosol plateout rate | Fig 69 |
| Cumulative mass fallout and plateout | Fig 70 |
| Aerosol particle size | Table 7 |

System parameters measured and figure number

| | |
|----------------------------------|------------|
| Vessel atmosphere pressure | Fig 71 |
| Vessel atmosphere temperatures | Figs 72-74 |
| Thermal gradients at vessel wall | Figs 75-79 |

Posttest results

| | |
|--|------------------------|
| Maximum aerosol concentration achieved | 5.6 µg/cm ³ |
| Aerosol distribution at end of test | |
| Still suspended in vessel atmosphere | <0.01% |
| Plated onto internal surfaces | 35% |
| Settled onto vessel floor | 65% |

Table 7. Andersen impactor data—Test 206

| Aerodynamic mass median diameter (µm) | Sample No ^a | | | | | | |
|--|------------------------|-----------------|---------------|----------------|----------------|----------------|------------------------------|
| | 1 (17 min) | 2 (38.5 min) | 3 (81 min) | 4 (190 min) | 5 (345 min) | 6 (504 min) | 7 ^b (1451 min) |
| 13.7 | 94.0 | 95.7 | 96.6 | 98.1 | 99.3 | 98.9 | 78.6 |
| 8.5 | 86.1 | 92.7 | 93.0 | 96.5 | 98.6 | 98.1 | 66.4 |
| 5.8 | 77.4 | 83.5 | 81.3 | 89.5 | 97.0 | 96.0 | 58.3 |
| 4.0 | 66.7 | 66.3 | 64.5 | 74.4 | 86.2 | 88.8 | 49.5 |
| 2.5 | 51.8 | 44.4 | 40.3 | 44.4 | 55.4 | 60.9 | 42.9 |
| 1.3 | 25.6 | 19.4 | 14.0 | 14.7 | 17.9 | 9.7 | 38.3 |
| 0.78 | 7.7 | 3.8 | 3.8 | 1.8 | 1.8 | 3.2 | 34.6 |
| 0.53 | 1.1 | 0.2 | 0.2 | 0.5 | 0.5 | 1.2 | 28.7 |

^aPercent of mass associated with diameters smaller than indicated size

^bTotal U₃O₈ found in impactor was 52 µg, insufficient for accurate sizing




Fig. 67. Aerosol mass concentrations vs time—NSPP Test 206.




Fig. 68. Fallout rate vs time—NSPP Test 206.




Fig. 69. Plateout rate vs time—NSPP Test 206.




Fig. 70. Cumulative fallout and plateout mass vs time—NSPP Test 206.




Fig. 71. In-vessel pressure vs time—NSPP Test 206.




Fig. 72. Temperature measurements at 1.5 m above vessel midplane—NSPP Test 206

ORNL-DWG 80-5795 ETD




Fig. 73. Temperature measurements at vessel midplane—NSPP Test 206.




Fig. 74. Temperature measurements at 1.5 m below vessel midplane—NSPP Test 206.




Fig. 75. Temperature measurements near the vessel wall at vessel midplane—NSPP Test 206.




Fig. 76. Temperature measurements near the vessel wall at 1.5 m below vessel midplane—NSPP Test 206.

ORNL-DWG 80-5799 ETD




Fig. 77. Temperature profile near the vessel wall at midplane for various times after start of aerosol generation (note that the distance is measured from the inside wall toward the center of the vessel)—NSPP Test 205.

ORNL-DWG 80-5800 ETD




Fig. 78. Temperature profile near the vessel wall at 1.5 m below midplane for various times after start of aerosol generation—NSPP Test 206.

ORNL-DWG 80-5801 ETD




Fig. 79. Temperature gradient at the vessel wall for two elevations—NSPP Test 206.

4.7 Summary and Data Graphs for Test 207

Aerosol source

| | |
|--------------------------------|-------------------------------|
| Test aerosol used | U ₃ O ₈ |
| Aerosol generator | Plasma torch |
| Duration of aerosol generation | 26 min |

Vessel atmosphere prior to aerosol generation

| | |
|-------------------|---------|
| Oxygen level | 21% |
| Relative humidity | <20% |
| Temperature | Ambient |
| Pressure | Ambient |

Duration of test operations

48 h

Aerosol parameters measured and figure number

| | |
|--------------------------------------|---------|
| Mass concentration of aerosol | Fig. 80 |
| Aerosol fallout rate | Fig. 81 |
| Aerosol plateout rate | Fig. 82 |
| Cumulative mass fallout and plateout | Fig. 83 |
| Aerosol particle size | Table 8 |

System parameters measured and figure number

| | |
|----------------------------------|-------------|
| Vessel atmosphere pressure | Fig. 84 |
| Vessel atmosphere temperatures | Figs. 85–87 |
| Thermal gradients at vessel wall | Figs. 88–92 |

Posttest results

| | |
|--|-------------------------------|
| Maximum aerosol concentration achieved | 3.3 $\mu\text{g}/\text{cm}^3$ |
| Aerosol distribution at end of test | |
| Still suspended in vessel atmosphere | 0.01% |
| Plated onto internal surfaces | 47.7% |
| Settled onto vessel floor | 52.3% |

Table 8. Andersen impactor data—Test 207

| Aerodynamic mass median diameter (μm) | Sample No. ^a | | | | | | |
|---|-------------------------|-----------------|----------------|----------------|----------------|----------------|-----------------|
| | 1 (25.2 min) | 2 (61.5 min) | 3 (108 min) | 4 (223 min) | 5 (346 min) | 6 (594 min) | 7 (1467 min) |
| 13.7 | 89.1 | 96.5 | 92.1 | 96.2 | 96.4 | 99.0 | 95.1 |
| 8.5 | 81.4 | 91.0 | 86.3 | 91.8 | 93.2 | 97.9 | 93.7 |
| 5.8 | 72.5 | 79.7 | 76.8 | 81.3 | 88.1 | 95.8 | 92.3 |
| 4.0 | 62.1 | 67.9 | 62.4 | 59.3 | 78.0 | 93.0 | 89.2 |
| 2.5 | 50.1 | 48.8 | 38.4 | 38.9 | 59.7 | 80.3 | 83.7 |
| 1.3 | 32.0 | 23.0 | 21.0 | 19.3 | 38.7 | 48.8 | 61.8 |
| 0.78 | 19.0 | 10.2 | 9.2 | 8.5 | 18.7 | 23.2 | 31.3 |
| 0.53 | 11.4 | 4.2 | 2.4 | 2.5 | 6.8 | 8.4 | 7.9 |

^aPercent of mass associated with diameters smaller than indicated size.




Fig. 80. Aerosol mass concentrations vs time—NSPP Test 207.




Fig. 81. Fallout rate vs time—NSPP Test 207.




Fig. 82. Plateout rate vs time—NSPP Test 207.

ORNL-DWG 80-5805 ETD




Fig. 83. Cumulative fallout and plateout mass vs time— NSPP Test 207.




Fig. 84. In-vessel pressure vs time—NSPP Test 207.




Fig. 85. Temperature measurements at 1.5 m above vessel midplane—NSPP Test 207.




Fig. 86. Temperature measurements at vessel midplane—NSPP Test 207.




Fig. 87. Temperature measurements at 1.5 m below vessel midplane—NSPP Test 207.

ORNL-DWG 80-5810 ETD




Fig. 88. Temperature measurements near the vessel wall at vessel midplane—NSPP Test 207.




Fig. 89. Temperature measurements near the vessel wall at 1.5 m below vessel midplane—NSPP Test 207.

ORNL-DWG 80-5812 ETD




Fig. 90. Temperature profile near the vessel wall at midplane for various times after start of aerosol generation (note that the distance is measured from the inside wall toward the center of the vessel)—NSPP Test 207.

ORNL-DWG 80-5813 ETD




Fig. 91. Temperature profile near the vessel wall at 1.5 m below midplane for various times after start of aerosol generation—NSPP Test 207.




Fig. 92. Temperature gradient at the vessel wall for two elevations—NSPP Test 207.

REFERENCES

1. R. E. Adams, T. S. Kress, and L. F. Parsly, Jr., *Sodium Oxide Aerosol Study: NSPP Runs 101-105, Data Record Report*, ORNL/NUREG/TM-179 (April 1978).
2. R. E. Adams, J. T. Han, T. S. Kress, and L. F. Parsly, Jr., *Uranium and Sodium Oxide Aerosol Experiments: NSPP Tests 201-203 and Tests 301-302, Data Record Report*, ORNL/NUREG/TM-343 (November 1979).
3. T. S. Kress and A. L. Wright, *LMFBR Aerosol Release and Transport Program Quarterly Progress Report for July-September 1978*, ORNL/NUREG/TM-276 (January 1979).



NUREG/CR-1767
ORNL/NUREG/TM-408
Dist. Category R7

Internal Distribution

- | | |
|-------------------|--------------------------------------|
| 1-3. R. E. Adams | 16. M. L. Tobias |
| 4. G. F. Flanagan | 17. H. E. Trammell |
| 5. M. H. Fontana | 18. A. L. Wright |
| 6. H. W. Hoffman | 19. ORNL Patent Office |
| 7-11. T. S. Kress | 20. Central Research Library |
| 12. F. R. Mynatt | 21. Document Reference Section |
| 13. G. W. Parker | 22-23. Laboratory Records Department |
| 14. J. L. Rich | 24. Laboratory Records (RC) |
| 15. J. A. Stevens | |

External Distribution

- 25. R. Sherry, Division of Reactor Safety Research, Nuclear Regulatory Commission, Washington, D.C. 20555
- 26. M. Silberberg, Chief, Experimental Fast Reactor Safety Research Branch, Division of Reactor Safety Research, Nuclear Regulatory Commission, Washington, D.C. 20555
- 27-30. Director, Office of Nuclear Regulatory Research, Nuclear Regulatory Commission, Washington, D.C. 20555
- 31. Office of Assistant Manager for Energy Research and Development, DOE, ORO, Oak Ridge, Tenn. 37830
- 32-33. Technical Information Center, DOE, Oak Ridge, Tenn. 37830
- 34-413. Given distribution as shown in category R7 (NTIS-10)