

LOFT TECHNICAL REPORT LTR 1144-38

EG&G REPORT NO. RE-A-78-012

JANUARY 18, 1978

# MASTER

ANALYSIS OF LOFT PRESSURIZER SPRAY AND  
SURGE NOZZLES TO INCLUDE A 450°F STEP TRANSIENT

M. E. NITZEL

**NOTICE**

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.



**EG&G** Idaho, Inc.



IDAHO NATIONAL ENGINEERING LABORATORY

**DEPARTMENT OF ENERGY**

IDAHO OPERATIONS OFFICE UNDER CONTRACT EY-76-C-07-1570

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

## DISCLAIMER

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

# RESEARCH, ENGINEERING AND CONSTRUCTION REPORT ENGINEERING ANALYSIS DIVISION

## ANALYSIS OF LOFT PRESSURIZER SPRAY AND SURGE NOZZLES TO INCLUDE A 450°F STEP TRANSIENT

NOTICE  
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

*M. E. Nitzel*  
\_\_\_\_\_  
AUTHOR  
M. E. Nitzel

CHECKED BY: *E. G. Tisdell*

APPROVED BY: *CA Moore*

THIS DOCUMENT HAS NOT RECEIVED PATENT CLEARANCE AND IS NOT TO BE TRANSMITTED TO THE PUBLIC DOMAIN.

NOTICE **MN ONLY**

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

*fy*

IDAHO NATIONAL ENGINEERING LABORATORY  
LOFT TECHNICAL REPORT  
LOFT PROGRAM

TITLE		REPORT NO.
Analysis of LOFT Pressurizer Spray and Surge Nozzles to Include a 450°F Step Transient		RE-A-78-012
AUTHOR	GWA NO.	
M. E. Nitzel		
PERFORMING ORGANIZATION	DATE	
Applied Mechanics	Published by CDCS 1-25-78	
LOFT APPROVAL 1-24-78 <i>[Signature]</i>	January 18, 1978	

ABSTRACT

This report presents the analysis of the LOFT pressurizer spray and surge nozzles to include a 450°F step thermal transient. Previous analysis performed under subcontract by Basic Technology Incorporated was utilized where applicable. The SAASIII finite element computer program was used to determine stress distributions in the nozzles due to the step transient. Computer results were then incorporated in the necessary additional calculations to ascertain that stress limitations were not exceeded. The results of the analysis described in this report indicate that both the spray and surge nozzles will be within stress allowables prescribed by subsubarticle NB-3220 of the 1974 edition of the ASME Boiler and Pressure Vessel Code when subjected to currently known design, normal operating, upset, emergency, and faulted condition loads.

<u>TABLE OF CONTENTS</u>		<u>Page</u>
ABSTRACT . . . . .		i
1.0 INTRODUCTION . . . . .		1
2.0 ANALYSIS . . . . .		4
2.1 Structural Adequacy Criteria . . . . .		4
2.2 Material Properties and Allowables . . . . .		4
2.3 ASME Code Analysis . . . . .		4
2.3.1 Design Conditions . . . . .		4
2.3.2 Normal and Upset Conditions . . . . .		4
2.3.3 Emergency Conditions . . . . .		9
2.3.4 Faulted Conditions . . . . .		9
3.0 RESULTS . . . . .		9
4.0 CONCLUSIONS . . . . .		11
5.0 REFERENCES . . . . .		11
APPENDIX A - Spary Nozzle Calculations . . . . .		A-1
APPENDIX B - Surge Nozzle Calculations . . . . .		B-1
APPENDIX C - SAAS III Spray Nozzle Output . . . . .		C-1
APPENDIX D - INTENS Program Source Listing . . . . .		D-1
APPENDIX E - Microfiche Listings and Output . . . . .		E-1

#### LIST OF TABLES

TABLE 1 - LOFT Spray and Surge Nozzle Material Properties . . . . .	5
TABLE 2 - Stress Summary . . . . .	10

#### LIST OF FIGURES

FIGURE 1 - LOFT Pressurizer Spray Nozzle . . . . .	2
FIGURE 2 - LOFT Pressurizer Surge Nozzle and Thermal Shield Assembly . . . . .	3
FIGURE 3 - Spray Nozzle Element Plot . . . . .	7
FIGURE 4 - Surge Nozzle Element Plot . . . . .	8

## 1.0 INTRODUCTION

The currently planned low power physics tests will result in an additional thermal transient being applied to the LOFT pressurizer spray and surge nozzles. This report describes the reanalysis of these nozzles to include the effects of this 450°F thermal step transient.

The spray and surge nozzle configurations shown in Aerojet Nuclear Company (ANC) drawing 204240, Revision C,<sup>(1)</sup> were analyzed by Basic Technology Incorporated (BTI)<sup>(2)</sup>. The overall configurations of these nozzles are shown in Figures 1 and 2. The reference 1 drawing shows additional detail.

Section III, Subsection NB<sup>(3)</sup> of the ASME Boiler and Pressure Vessel Code (hereafter referred to as "The Code") was used to define structural adequacy criteria. Design, normal operating, upset, emergency, and faulted conditions were considered in this analysis. As described in Section 2.0, the SAAS III computer program was used to analyze both nozzles for the 450°F step transient. The result of the SAAS III analysis were then combined with the BTI results to calculate new cumulative usage factors. Design conditions were specified to be  $P = 2500$  psi and  $T = 683^{\circ}\text{F}$ ; while operating conditions were  $P = 2250$  psi and  $T = 653^{\circ}\text{F}$ . The spray nozzle is constructed of inconel (SB-167). The surge nozzle piping connection and thermal liner materials are inconel (SB-167), while the remainder of the surge nozzle is constructed of carbon steel (SA-105, GR II). A complete tabulation of the material properties used in this additional analysis is shown in Section 2.2.

It should be noted that the finite element models used in this analysis were developed by D. H. VanHaften of the Thermal Analysis Branch in conjunction with the analysis reported in Reference 5.

The SAAS III computer run of the spray nozzle was completed by




FIGURE 1

LOFT Pressurizer Spray Nozzle




FIGURE 2

LOFT Pressurizer Surge Nozzle and  
Thermal Shield Assembly

Mr. J. W. Muffett. All other original analysis shown in this report was completed by the author.

## 2.0 ANALYSIS

The following subsections describe all phases of the additional analysis performed on the LOFT pressurizer spray and surge nozzles. As previously noted, results from the BTI<sup>(2)</sup> analysis were used in conjunction with the additional analysis.

### 2.1 Structural Adequacy Criteria

Paragraph NB-3221<sup>(3)</sup> defines stress intensity limits for design conditions of Class 1 components. Paragraphs NB-3222, NB-3223, NB-3224, and NB-3225 define stress limits for normal operating, upset, emergency, and faulted conditions respectively. These guidelines were followed throughout the additional spray and surge nozzle analysis shown in this report.

### 2.2 Material Properties and Allowables

All material properties and allowable  $S_M$  values used in the additional analysis of the spray and surge nozzles are shown in Table I.

### 2.3 ASME Code Analysis

#### 2.3.1 Design Conditions

Design conditions for the spray and surge nozzles are  $P = 2500$  psi and  $T = 683^\circ\text{F}$ . Paragraph NB-3221<sup>(3)</sup> was used to define structural adequacy criteria for both items. Any design condition calculations not previously completed in the BTI analysis are shown in Appendices A and B for the spray and surge nozzles, respectively.

#### 2.3.2 Normal Conditions

The majority of the additional analysis necessitated

TABLE I  
LOFT SPRAY AND SURGE NOZZLE MATERIAL PROPERTIES

MATERIAL	PROPERTY	TEMPERATURE ~°F					
		100	200	400	600	650	700
STAINLESS STEEL (SA-182, F316L)	E	28.2	27.7	26.6	25.4	25.1	24.8
	$\alpha$	9.16	9.34	9.59	9.82	9.87	9.93
	S <sub>y</sub>	25.0	21.1	17.2	15.0	14.6	14.3
	S <sub>M</sub>	16.6	16.6	15.5	13.5	13.2	12.8
INCONEL (SB-167)	E	31.5	30.9	30.0	29.2	28.9	28.6
	$\alpha$	7.2	7.4	7.7	7.9	7.95	8.00
	S <sub>y</sub>	25.0	23.0	21.0	19.8	19.7	19.7
	S <sub>M</sub>	16.6	16.6	16.6	16.6	16.6	16.6
CARBON STEEL (A105 GR II)	E	27.8	27.7	27.0	25.7	25.25	24.8
	$\alpha$	6.13	6.38	6.82	7.23	7.33	7.44
	S <sub>y</sub>	36.0	32.8	30.8	26.6	26.1	25.9
	S <sub>M</sub>	23.3	21.9	20.6	17.8	17.4	17.3
AIR (USED TO MODEL GAP BETWEEN SURGE NOZZLE AND THERMAL SHIELD)	E	1.0	1.0	1.0	1.0	1.0	1.0
	$\alpha$	0.0	0.0	0.0	0.0	0.0	0.0
	S <sub>y</sub>	0.0	0.0	0.0	0.0	0.0	0.0
	S <sub>M</sub>	0.0	0.0	0.0	0.0	0.0	0.0

NOTE - UNITS ARE: E ~ 10<sup>6</sup> PSI,  $\alpha$  ~ 10<sup>-6</sup> IN./IN./°F, S<sub>y</sub> ~ KSI, S<sub>M</sub> ~ KSI

by the addition of the 450°F thermal step transient involved fatigue life calculations considering all transient load cases which are likely to occur during normal operating conditions. Paragraph NB-3222<sup>(3)</sup> was used to define stress limits for all normal operating condition stress categories and to define the procedure for cyclic analysis. The SAAS III finite element computer program was used with the results of the thermal analysis reported in Reference 5 to calculate the stress distribution in the spray and surge nozzles due to the 450°F step transient.

Simplified plots of the finite element mesh used for each of the spray and surge nozzles are shown in Figures 3 and 4.

The reader may refer to Appendices A and B (Spray and Surge Nozzle Calculations, respectively) for more detailed information concerning node and element numbering and other pertinent calculations. SAAS III spray nozzle output is shown in Appendix C, while a microfiche copy of the surge nozzle output is included in Appendix E. Results of the SAAS III analysis were used to ascertain that all normal condition stress requirements were satisfied. The computer program INTENS was used to calculate alternating stress intensities for all transient load set combinations as required for the cyclic analysis. Cumulative usage factors were calculated for each nozzle. As previously stated, calculations performed for the spray and surge nozzles, including the INTENS program output, are shown in Appendices A and B respectively. A complete listing of the INTENS computer program is shown in Appendix D. A microfiche copy of SAAS III




Figure 3  
SPRAY NOZZLE  
ELEMENT PLOT




Figure 4

SURGE NOZZLE  
ELEMENT PLOT

may be found in Appendix E.

### 2.3.3 Emergency Conditions

Paragraph NB-3224<sup>(3)</sup> defines stress limits to be used in the analysis of emergency conditions. Safe shutdown earthquake (SSE) loads were the only additional emergency condition loads considered. All calculations necessary for the satisfaction of stress limits in this section are shown in Appendices A and B for the spray and surge nozzles respectively.

### 2.3.4 Faulted Conditions

Paragraph NB-3225<sup>(3)</sup> defines stress limits and allowable procedures to be used in the analysis of faulted conditions. Loss of Coolant Accident (LOCA) plus SSE loads were considered to be faulted condition loads. Since LOCA loads were not reported in Reference 2 for the spray nozzle, Loss of Coolant Experiment (LOCE) loads were assumed to be equivalent to LOCA loads for analysis purposes. Thus, LOCE plus SSE loads were used for faulted conditions on the spray nozzle. Reference 6 is an example of previous piping analysis that has shown this procedure to be acceptable. All faulted condition calculations necessary for the satisfaction of stress limits are shown in Appendices A and B for the spray and surge nozzles respectively.

## 3.0 RESULTS

The results of the analysis described in the preceding pages shows that both the spray and surge nozzles are within allowable stress limits prescribed by the ASME code. Maximum stresses for the various operating conditions are summarized in Table 2. As can be seen from the table, the primary plus secondary stresses were above the allowable

TABLE 2  
STRESS SUMMARY

NOZZLE	CONDITION	STRESS CATEGORY	MAX. STRESS	LIMIT
SPRAY	DESIGN	GENERAL PRIMARY MEMBRANE	5,215	$S_M = 13,200$
SURGE	DESIGN	↓ ↓ ↓	7,268	$S_M = 16,600$
SPRAY	NORMAL & UPSET	PRIMARY + SECONDARY	40,875	$3S_M = 39,600$
SURGE	NORMAL & UPSET	↓ ↓	85,100	$3S_M = 49,800$
SPRAY	EMERGENCY	GENERAL PRIMARY MEMBRANE	1,719	$1.2S_M = 15,340$
SURGE	EMERGENCY	↓ ↓ ↓	6,580	$1.2S_M = 19,920$
SPRAY	FAULTED	↓ ↓ ↓	2,901	$2.4S_M = 31,680$
SURGE	FAULTED	↓ ↓ ↓	8,540	$2.4S_M = 39,840$

NOTE - STRESSES AND LIMITS IN PSI

limits for both nozzles for normal operating and upset conditions. As shown in Appendices A and B, a simplified elastic-plastic analysis was performed to show that both nozzles comply with code requirements. The normal and upset condition cyclic analysis yielded the following results:

<u>Nozzle</u>	<u>Cumulative Usage Factor</u>	<u>Limit</u>
Spray	0.0027	1.0
Surge	0.6095	1.0

#### 4.0 CONCLUSIONS

The LOFT pressurizer spray and surge nozzles have been reanalyzed to include the effects of a 450°F step thermal transient. From the analysis presented above it can be concluded that both the spray and surge nozzles will comply with all requirements as set forth in subarticle NB-3220 of the ASME code.

#### 5.0 REFERENCES

1. Aerojet Nuclear Company, Drawing 204240, Revision C, "Pressurizer Nozzles", April 10, 1972.
2. G. V. Thompson, et.al., "Stress Report on LOFT Pressurizer", Basic Technology Inc., BTI Report 72083, July 31, 1973.
3. American Society of Mechanical Engineers, ASME Boiler and Pressure Vessel Code, Section III, Division 1, "Nuclear Power Plant Components", Subsection NB, 1974 Edition plus Summer 1976 Addenda.
4. J. G. Crose and R. M. Jones, SAAS III, Finite Element Stress Analysis of Axisymmetric and Plane Solids with Different Orthotropic, Temperature Dependent Material Properties in Tension and Compression, The Aerospace Corporation, Aerospace Report No. TR-0059(56816-53)-1, June 22, 1971.
5. D. H. VanHaften, "Steady State and Transient Thermal Analysis of the LOFT Pressurizer Surge and Spray Nozzles," LTR 1144-29, May 2, 1977.

6. J. W. Muffett, "LOFT Pressurizer Pressure Relief Piping System Stress Analysis and Fatigue Life Report," LTR 1144-26, to be published.

APPENDIX A

SPRAY NOZZLE CALCULATIONS

THIS APPENDIX DESCRIBES IN DETAIL THE LOFT PRESSURIZER SPRAY NOZZLE COMPONENT ANALYSIS IN ACCORDANCE WITH SUBARTICLE NB-3200 OF SECTION III OF THE ASME CODE. IT SHOULD BE NOTED THAT ANY REFERENCES CITED IN THIS APPENDIX ARE TAKEN FROM THE MAIN LIST OF REFERENCES IN SECTION 5.0 OF THE BODY OF THE REPORT.

## DESIGN CONDITIONS

DESIGN CONDITION STRESS ALLOWABLES ARE DEFINED BY PARAGRAPH NB-3221 OF THE ASME CODE. SINCE THE MAIN THRUST OF THIS ANALYSIS WAS THE INCLUSION OF THE 450°F STEP TRANSIENT IN THE FATIGUE CALCULATIONS, THE DESIGN CONDITION CALCULATIONS SHOWN IN THE BTI REPORT (REFERENCE 2) WERE ACCEPTED AS ADEQUATE. BTI REPORTED A GENERAL PRIMARY MEMBRANE STRESS VALUE OF 5215 PSI. THE ALLOWABLE STRESS VALUE,  $S_m$ , FOR SA 182, F316L STAINLESS STEEL AT 683°F IS APPROXIMATELY 13040 PSI.

## NORMAL CONDITIONS

NORMAL CONDITION STRESS ALLOWABLES ARE DEFINED BY PARAGRAPH NB-3222 OF THE ASME CODE. NORMAL OPERATING CONDITIONS ANALYZED CONSIST OF THE FOLLOWING MECHANICAL AND THERMAL LOADS:

### MECHANICAL LOADS:

- DEAD WEIGHT
- POWER RELIEF OPERATING
- POWER RELIEF AND SAFETY OPERATING
- STEADY STATE OPERATION (OTP)
- SPRAY OPERATING
- SEISMIC (OBE)
- LOCE

## THERMAL LOADS:

450 °F STEP TRANSIENT  
 LOCE  
 STEP LOAD REJECTION  
 LOSS OF SITE POWER  
 HEAT-UP  
 COOL DOWN

FROM MATERIAL PRESENTED IN THE SPRAY NOZZLE THERMAL ANALYSIS (REFERENCE 5) IT CAN BE SEEN THAT THE MOST SEVERELY STRESSED AREA WILL BE THE CROTCH REGION AT THE INTERSECTION OF THE INNER SLEEVE AND THE OUTER SHELL. THUS, ONLY THIS REGION WILL BE EXAMINED. AS SHOWN IN THE BTI REPORT (REFERENCE 2), FIGURE 4.2.2-3, THIS INCLUDES ELEMENTS 33-36 AND 81 AND 82 OF THE BTI MODEL.

THE LOADS ON THE NOZZLE ARE AS DOCUMENTED IN THE BTI REPORT WITH THE EXCEPTION OF LOCE (MECHANICAL) AND SEISMIC (OBE). THE STRESSES AT THE AREA OF INTEREST HAVE BEEN CALCULATED BY SAASIII FINITE ELEMENT ANALYSIS. THE LOADS FOR THE LOCE AND SEISMIC TRANSIENTS ARE AS CALCULATED FOR THE PIPING CONNECTION AND ARE DOCUMENTED IN REFERENCE 6. THE LOADS, USING THE BTI COORDINATE SYSTEM, ARE AS SHOWN BELOW:

	$F_x$ (LB)	$F_y$ (LB)	$F_z$ (LB)	$M_x$ (IN-LB)	$M_y$ (IN-LB)	$M_z$ (IN-LB)
LOCE (MECH.)	-112	772	84	-244	256	820
SEISMIC (OBE)	-185	467	121	-348	377	1308

THESE LOADS WERE OBTAINED AT A NODE POINT LOCATED 1.75 INCHES AWAY FROM THE AREA OF INTEREST. THUS, THEY MUST BE TRANSLATED. IT WAS ALSO FOUND THAT THE LOADS SHOWN IN FIGURE 4.2.2-1 OF THE BTI REPORT WERE NOT TRANSLATED CORRECTLY TO THE AREA OF INTEREST UNDER CONSIDERATION. THUS, THE FOLLOWING CALCULATIONS SHOW ALL NECESSARY LOAD TRANSLATIONS. THE EQUATIONS USED ARE:

$$M_y = M_y$$

$$F_y = F_y$$

$$M_x = M_x - l F_z$$

$$M_z = M_z - l F_x$$

$$l = 1.75 \quad (\text{LOCE, SEISMIC})$$

$$l = 11.937 \quad (\text{D.W., ETC. FROM BTI})$$

TRANSLATED LOADS ARE:

LOAD	$M_x$ (IN-LB)	$M_y$ (IN-LB)	$M_z$ (UN-LB)	$F_y$ (LB)
LOCE	-391	256	1016	772
SEISMIC	-212	377	1632	467
DEAD WEIGHT	-126	-2677	1209	-217
POWER RELIEF OP.	3572	-2781	4939	-279
P. R. & SAFETY OP.	-5243	6723	-8979	99
STEADY STATE	5232	-2017	7354	-267
SPRAY OPERATING	-410	-948	-315	-12

STRESSES ARE CALCULATED AS FOLLOWS:

$$\sigma_{M_x} = M_x / z_x$$

$$\sigma_{M_z} = M_z / z_z$$

$$\sigma_{F_y} = F_y / A$$

$$\tau_y = M_y / z_y$$

WHERE

$$z_x = z_z = 3.826 \quad (\text{INSIDE}) \quad \text{IN}^3$$

$$z_x = z_z = 1.305 \quad (\text{OUTSIDE}) \quad \text{IN}^3$$

$$z_y = 7.665 \quad (\text{INSIDE}) \quad \text{IN}^3$$

$$z_y = 2.611 \quad (\text{OUTSIDE}) \quad \text{IN}^3$$

$$A = 3.931 \quad \text{IN}^2$$

THIS RESULTS IN THE FOLLOWING STRESSES

TRANSIENT	$\sigma_{M_x}$ (W)	$\sigma_{M_x}$ (OUT)	$\sigma_{M_z}$ (IN)	$\sigma_{M_z}$ (OUT)	$\sigma_{F_y}$ (IN)	$\sigma_{F_y}$ (OUT)
LOCE	± 102	± 300	± 266	± 779	196	196
SEISMIC	± 55	± 162	± 427	± 1251	119	119
DEADWEIGHT	± 33	± 97	± 316	± 926	-55	-55
P. R. OP.	± 934	± 2737	± 1291	± 3785	-71	-71
P. R. & S. OP.	± 1370	± 4018	± 2347	± 6880	25	25
STEADY STATE	± 1367	± 4009	± 1922	± 5635	-68	-68
SPRAY OP.	± 107	± 314	± 82	± 241	-3	-3

NOTE - ALL STRESSES IN PSI.

PIPING STRESS IS FOUND BY:

$$\sigma_b = \sigma_{F_y} + \sqrt{\sigma_{M_x}^2 + \sigma_{M_z}^2}$$

$$\tau_{yh} = M_y / Z_y$$

$$\sigma_T = \sigma_b / 2 + \sqrt{(\sigma_b / 2)^2 + \tau_{yh}^2}$$

TRANSIENT	$\sigma_b$ (PSI)		$\tau_{yh}$ (PSI)		$\sigma_T$ (PSI)	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
LOCE	481	1031	33	98	483	1040
SEISMIC	550	1380	49	144	554	1395
DEADWEIGHT	263	876	-349	-1025	504	1553
P. R. OP.	1522	4600	-363	-1065	1604	4835
P. R. & S. OP.	2743	7992	877	2575	2999	8750
STEADY STATE	2291	6848	-263	-772	2321	6934
SPRAY OP.	132	393	-124	-363	206	609

MAXIMUM THERMAL TRANSIENT LOADS SHOWN ON PAGES 4-526 TO 4-531 (FOR ELEMENTS 33-36, 81, AND 82) WERE LINEARIZED TO REMOVE PEAK EFFECTS. A SIMPLE LEAST SQUARES REGRESSION METHOD WAS USED AND, THUS, CALCULATIONS WILL NOT BE SHOWN.


TO COMPLETE THE PRIMARY PLUS SECONDARY STRESS CALCULATIONS AND OTHER REQUIREMENTS, THE SAAS III FINITE ELEMENT MODEL OF THE SPRAY NOZZLE WAS RUN WITH THE 450°F STEP TRANSIENT THERMAL LOADING. BOUNDARY CONDITIONS USED

CONSISTED OF AXIAL RESTRAINTS ON NODES 356-361. THE COMPLETE FINITE ELEMENT MODEL, INCLUDING THE NODE AND ELEMENT NUMBERING SCHEME, IS SHOWN IN SEVERAL SECTIONS IN FIGURE A1, PAGES A6-A9. THE AREA OF INTEREST IN THIS MODEL INCLUDES ELEMENTS 120-127, 146, 147, 166, AND 167. THE STRESS COMPONENTS THROUGH THIS SECTION ARE PLOTTED AND LINEARIZED AS SHOWN IN FIGURES A2-A5, PAGES A10-A13.

THE PRIMARY PLUS SECONDARY MAXIMUM STRESS MAY NOW BE CALCULATED USING THE FOLLOWING COMPONENTS:

INSIDE

TRANSIENT	LINEARIZED STRESS COMPONENTS (KSI)			
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$T_{xy}$
DEADWEIGHT	0	.263	0	-.349
POWER RELIEF OP.	↓	1.52	↓	-.363
P.R. & SAFETY OP.		2.74		.877
STEADY STATE		2.29		-.260
SPRAY OPERATING		.130		-.120
LOCF - 195 SEC.		-3.93		-6.95
LOCF - 55 SEC.	-3.5	-8.14	.90	-.14
STEP LOAD REJECTION	-4.42	-.12	8.07	.59
LOSS OF SITE POWER	-4.32	-.20	7.79	.57
HEAT-UP (3.33 HR - NO PRES.)	-1.22	6.84	16.51	.52
HEAT-UP (3.358 HR + OP. PRES.)	-4.82	4.05	18.28	.85
COOL DOWN (4.7 HR, NO PRES.)	-2.41	5.74	12.97	.42
COOL DOWN (1.83 HR + OP. PRES.)	-4.92	2.22	14.88	.71
450°F STEP	13.4	6.4	43.3	-2.8



STR 144 38

	313		301		289		277
(287)		(279)		(269)		(259)	(249)
(285)	308	(275)		(265)		(255)	(245)
			276		284		272

FIGURE A1 (CONT'D)

	273		267		255		243		231		219		207		195		183		171		159		147		
(330)		(320)		(314)		(304)		(294)		(284)		(274)		(264)		(254)		(244)		(234)		(224)		(214)	
(330)	368	(325)	362	(310)	350	(300)	338	(290)	326	(280)	314	(270)	302	(260)	290	(250)	278	(240)	266	(230)	254	(210)	242		
	1.382-01		1.535-01		1.609-01		1.843-01		1.996-01		2.150-01		2.303-01		2.457-01		2.610-01		2.764-01		2.917-01		3.071-01		3.224-01

LTR 144 38





FIGURE A1 (CONT'D)

LTR1144 38


FIGURE A1 (CONT'D)



LTR 144 38

A1


FIGURE A2  
LINEARIZED RADIAL STRESS  
LOFT PRESSURIZER SPRAY NOZZLE  
450°F STEP TRANSIENT  
ELEMENTS 120-127, 146, 157, 166, 167



40 1323  
BY THE REGISTERED ENGINEER CO. HIDE IN USA.

STR-44 38

**FIGURE A3**  
**LINEARIZED AXIAL STRESS**  
**LOFT PRESSURIZER SPRAY NOZZLE**  
**450°F STEP TRANSIENT**  
**ELEMENTS 120-127, 146, 147, 166, 167**




46 1323

K&E 10 X 10 TO 1/8 INCH 7 X 10 INCHES KEUFFEL & ESSER CO. MADE IN U.S.A.


LTR1144 38

FIGURE A4  
LINEARIZED TANGENTIAL STRESS  
LOFT PRESSURIZER SPRAY NOZZLE  
450°F STEP TRANSIENT  
ELEMENTS 120-127, 146, 147, 166, 167



LTR1144 38

FIGURE A5  
LINEARIZED SHEAR STRESS  
LOFT PRESSURIZER SPRAY NOZZLE  
450°F STEP TRANSIENT  
ELEMENTS 120-127, 146, 147, 166, 167



46 1323

K $\sigma$  $\Sigma$  10 X 10 TO 3/4 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

OUTSIDE

TRANSIENT	LINEARIZED STRESS COMPONENTS (KSI)			
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\tau_{yz}$
DEAD WEIGHT	0	.876	0	1.02
POWER RELIEF OP.	↓	4.60	↓	1.06
P.R. & SAFETY OP.		7.99		2.58
STEADY STATE		6.85		.77
SPRAY OP.		.39		.36
LOCE - 195 SEC	2.16	4.48	5.34	-1.01
LOCE - 55 SEC.	2.45	4.38	3.89	-.73
STEP LOAD REJECTION	8.49	-1.86	2.54	-.05
LOSS OF SITE POWER	8.22	-1.81	2.48	-1.02
HEAT-UP (3.33 HR, NO PRES.)	10.37	-4.12	-1.05	.34
HEAT-UP (3.358 HR + OP. PRES.)	14.09	-4.64	1.63	.37
COOL DOWN (4.7 HR, NO PRES.)	12.31	-3.84	2.44	.30
COOL DOWN (1.83 HR + OP. PRES.)	12.62	-3.57	2.36	.33
450°F STEP	6.1	-4.2	-22.5	-1.05

FOR THIS SITUATION, THE TRIAXIAL PRINCIPAL STRESS EQUATION CAN BE WRITTEN AS:

$$\sigma^3 - (\sigma_x + \sigma_y + \sigma_z) \sigma^2 + (\sigma_x \sigma_y + \sigma_y \sigma_z + \sigma_x \sigma_z - \tau_{yz}^2) \sigma - (\sigma_x \sigma_y \sigma_z - \sigma_z \tau_{yz}^2) = 0$$

THE SOLUTION OF THIS EQUATION YIELDS THE PRINCIPAL STRESSES. USING THE COMPONENTS OF STRESS LISTED IN THE TWO PREVIOUS TABLES, MAXIMUM PRIMARY PLUS SECONDARY STRESS INTENSITY AT THE INSIDE AND OUTSIDE SURFACES WAS CALCULATED. MAXIMUM PRIMARY PLUS SECONDARY STRESS INTENSITY RANGE AT THE INSIDE SURFACE OCCURS WHEN THE 450°F STEP TRANSIENT AND THE POWER RELIEF AND SAFETY OPERATING TRANSIENT ARE PAIRED. THE MAXIMUM PRIMARY PLUS SECONDARY STRESS INTENSITY RANGE AT THE OUTSIDE SURFACE OCCURS WHEN THE 450°F STEP TRANSIENT AND THE LOCE (195 SEC.) TRANSIENT ARE PAIRED. THE PRINCIPAL STRESSES FOR THESE CASES ARE AS FOLLOWS:

INSIDE

$$\begin{aligned}\sigma_1 &= 3.32 \text{ KSI} \\ \sigma_2 &= -15.1 \text{ KSI} \\ \sigma_3 &= -43.3 \text{ KSI}\end{aligned}$$

OUTSIDE

$$\begin{aligned}\sigma_1 &= 27.8 \text{ KSI} \\ \sigma_2 &= 8.68 \text{ KSI} \\ \sigma_3 &= -3.94 \text{ KSI}\end{aligned}$$

THUS, A MAXIMUM PRIMARY PLUS SECONDARY STRESS INTENSITY OF  $|-43.3 + 2.4| = 40.9$  KSI OCCURS AT THE INSIDE SURFACE. FOR SA182, F316L, STAINLESS STEEL AT  $650^\circ$  ( $T_{OP} = 653^\circ\text{F}$ ), THE  $S_M$  VALUE IS 13.2 KSI. THE PRIMARY PLUS SECONDARY LIMIT IS  $3S_M$ , THUS:

$$3S_M = 3(13.2) = 39.6 \text{ KSI}$$

$$40.9 > 39.6$$

$\therefore$  EXCEED STRESS LIMIT

SINCE THE  $3S_M$  LIMIT IS EXCEEDED, A SIMPLIFIED ELASTIC-PLASTIC ANALYSIS WILL BE PERFORMED IN ACCORDANCE WITH SUBPARAGRAPH NB-3228.3. TO CHECK PRIMARY PLUS SECONDARY MINUS THERMAL BENDING STRESS INTENSITY, FIGURES A2-A5 ARE USED. THE LINEARIZED STRESS COMPONENTS MINUS THERMAL BENDING ARE:

	$\sigma_x$	$\sigma_y$	$\sigma_H$	$T_{yH}$
① 450° STEP	9.80	1.05	10.40	-1.93
② P.R. & SAFETY OP.	0	2.74	0.0	.88
① - ②	9.80	-1.69	10.40	-2.81

SUBSTITUTING THE STRESS COMPONENT RANGES ABOVE INTO THE PREVIOUSLY SHOWN TRIAXIAL STRESS EQUATION YIELDS THE FOLLOWING PRINCIPAL STRESSES UPON SOLUTION:

$$\begin{aligned}\sigma_1 &= -2.35 \\ \sigma_2 &= 9.53 \\ \sigma_3 &= 11.3.\end{aligned}$$

THIS YIELDS A STRESS INTENSITY OF 13.65 KSI. THIS VALUE OF STRESS INTENSITY IS LESS THAN THE 39.6 KSI  $3S_m$  LIMIT; THUS, THE REMAINDER OF THE SIMPLIFIED ELASTIC-PLASTIC ANALYSIS IS COMPLETED AS FOLLOWS:

$$\begin{aligned}m &= 1.7 \\ n &= .3\end{aligned}$$

$$S_n = 40.9 \quad \text{KSI}$$

$$3mS_m = 3(1.7)(13.2) = 63.32 \text{ KSI}$$

$$\begin{aligned}\Rightarrow K_e &= 1.0 + \frac{1-n}{n(m-1)} \left( \frac{S_n}{3S_m} - 1 \right) \\ &= 1.0 + \frac{.7}{.3(1.7)} \left( \frac{40.9}{39.6} - 1 \right) \\ &= 1.0 + 3.33 (1.03 - 1) \\ &= 1.0 + .10\end{aligned}$$


$$\underline{K_e = 1.10}$$

THUS, THE ALTERNATING STRESS INTENSITY FOR THIS PAIR MUST BE MULTIPLIED BY 1.10 WHEN USED IN THE FATIGUE CALCULATIONS. THIS SATISFIES ALL PRIMARY PLUS SECONDARY STRESS REQUIREMENTS.

THE FATIGUE ANALYSIS WAS PERFORMED IN ACCORDANCE WITH SUB PARAGRAPH NB-3222.4. THE PEAK STRESSES USED IN THESE CALCULATIONS WERE AS LISTED IN THE FATIGUE ANALYSIS SHOWN IN THE BTI REPORT WITH THE EXCEPTION OF THE 450°F STEP TRANSIENT. THE PEAK STRESS VALUES FOR THE 450°F STEP TRANSIENT WERE TAKEN FROM FIGURES A2-A5, PAGES A10-A13. THE TRANSIENTS ANALYZED AND THE PEAK STRESSES USED ARE SHOWN IN THE FOLLOWING TABLE.

TRANSIENT	NO. CYCLES	$\sigma_R$ (KSI)	$\sigma_F$ (KSI)	$\sigma_H$ (KSI)	$T_{RZ}$ (KSI)
1. POWER RELIEF OP.	370	0	4.835	0	0
2. P. R. & SAFETY OP.	370	↓	8.750	↓	↓
3. STEADY STATE FLUCTUATION	1500		6.934		
4. SPRAY OP.	10 <sup>6</sup>		0.609		
5. SEISMIC (LOBE)	100		1.395		
6. LOCE (MECHANICAL)	2600	↓	1.040	↓	↓
7. 450° F STEP THERMAL	500	18.0	14.80	69.50	-4.10
8. LOCE (55 SEC.)	260	-2.886	-6.582	1.39	.447
9. LOCE (195 SEC.)	260	-1.191	-6.143	-8.33	.549
10. STEP LOAD REJECTION	360	-2.724	.507	10.295	.450
11. LOSS OF SITE POWER	360	-2.677	.379	9.909	.435
12. HEAT-UP (3.36 HR)	1500	-.891	6.604	19.213	.669
13. HEAT-UP (+PRESSURE)(3.33HR)	1500	-3.036	4.849	22.132	.891
14. HEAT-UP (+PRESSURE)(3.36 HR)	1500	-3.063	4.849	21.861	.875
15. COOL DOWN (+PRESSURE)	1500	-3.064	2.721	17.958	.711
16. COOLDOWN (.83 HR)	1500	-.620	4.965	14.980	.479
17. COOLDOWN (.67 HR)	1500	-.622	5.759	16.361	.540
18. COOLDOWN (.70 HR)	1500	-.598	5.860	16.397	.547
19. LEAK	260	-2.987	-2.742	3.640	.284
20. O. T. P.	106	-2.445	-2.244	2.978	.231

THE APPLIED MECHANICS BRANCH COMPUTER PROGRAM INTENS WAS USED TO CALCULATE ALTERNATING STRESS INTENSITIES FOR ALL POSSIBLE PAIRINGS OF THE TRANSIENTS LISTED ABOVE. THE FINAL TABLE OF OUTPUT FROM THIS PROGRAM LISTS ALTERNATING STRESS INTENSITIES IN DECREASING ORDER SUCH THAT THE APPROPRIATE FATIGUE LIFE CURVE MAY BE USED TO CALCULATE ALLOWABLE NUMBERS OF CYCLES AND THE CUMULATIVE USAGE FACTOR. FIGURE I-9.2 AS SHOWN ON PAGE 159 OF SUBSECTION NA OF THE 1974 EDITION OF THE ASME CODE WAS USED TO DETERMINE ALLOWABLE NUMBERS OF CYCLES. THIS CURVE IS REPRODUCED IN FIGURE A6, PAGE A18. COMPUTER PROGRAM INTENS OUTPUT IS SHOWN ON PAGES A19 - A41. THE CUMULATIVE USAGE FACTOR CALCULATION IS SHOWN ON PAGE A37. IT WILL BE NOTED THAT THE CUMULATIVE USAGE FACTOR IS 0.0027. THIS WILL MEET ALL FATIGUE LIFE REQUIREMENTS.



NOTE:  
 $E = 26.0 \times 10^6$  psi

**FIGURE A6**  
 DESIGN FATIGUE CURVE FOR AUSTENITIC STEELS, NICKEL-CHROMIUM-IRON  
 ALLOY, NICKEL-IRON-CHROMIUM ALLOY AND NICKEL-COPPER ALLOY

LTR1144 38

A18

\* \* PROGRAM - - INTENS - - CALCULATION OF TRANSIENT STRESS INTENSITIES \* \*

NO. OF PROBLEMS OR POINTS TO BE ANALYZED IS 1

LTR 114438

A19

PROBLEM NO. 1  
 NO. OF TRANSIENTS 20  
 STRESS CONCENTRATION FACTOR = 1.000  
 ELASTIC MODULUS RATIO = 0.965

\* \* TRANSIENT STRESS DATA \* \*

\* \* NOTE THAT STRESSES ARE IN KSI \* \*

TRANS	NO. CYCLES	SIGMA X	SIGMA Y	SIGMA Z	TAU XY	TAU XZ	TAU YZ
1	370	0.0	4.835	0.0	0.0	0.0	0.0
2	370	0.0	8.750	0.0	0.0	0.0	0.0
3	1500	0.0	8.934	0.0	0.0	0.0	0.0
4	1000000	0.0	0.609	0.0	0.0	0.0	0.0
5	100	0.0	1.395	0.0	0.0	0.0	0.0
6	2600	0.0	1.040	0.0	0.0	0.0	0.0
7	500	18.000	14.800	69.500	-4.100	0.0	0.0
8	260	-2.836	-6.582	1.390	-0.447	0.0	0.0
9	260	-1.191	-6.143	-8.330	-0.549	0.0	0.0
10	360	-2.724	0.507	10.295	0.450	0.0	0.0
11	360	-2.667	0.379	9.909	0.435	0.0	0.0
12	1500	-0.891	6.604	19.213	0.669	0.0	0.0
13	1500	-3.036	4.849	22.132	0.891	0.0	0.0
14	1500	-3.063	4.849	21.861	0.875	0.0	0.0
15	1500	-3.064	2.721	17.958	0.711	0.0	0.0
16	1500	-0.620	4.965	14.980	0.479	0.0	0.0
17	1500	-0.622	5.759	16.361	0.540	0.0	0.0
18	1500	-0.599	5.860	16.397	0.547	0.0	0.0
19	260	-2.987	-2.742	3.640	0.284	0.0	0.0
20	1000000	-2.445	-2.244	2.978	0.231	0.0	0.0

LTR114438

A20

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN. PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
1 0	0.0	4.835	0.0	0.0	0.0	0.0
2 0	0.0	8.750	0.0	0.0	0.0	0.0
3 0	0.0	6.934	0.0	0.0	0.0	0.0
4 0	0.0	0.609	0.0	0.0	0.0	0.0
5 0	0.0	1.395	0.0	0.0	0.0	0.0
6 0	0.0	1.040	0.0	0.0	0.0	0.0
7 0	18.000	14.800	69.500	-4.100	0.0	0.0
8 0	-2.886	-6.582	1.390	-0.447	0.0	0.0
9 0	-1.191	-6.143	-8.330	-0.549	0.0	0.0
10 0	-2.724	0.507	10.295	0.450	0.0	0.0
11 0	-2.667	0.379	9.909	0.435	0.0	0.0
12 0	-0.891	6.604	19.213	0.669	0.0	0.0
13 0	-3.036	4.849	22.132	0.891	0.0	0.0
14 0	-3.063	4.849	21.861	0.875	0.0	0.0
15 0	-3.064	2.721	17.958	0.711	0.0	0.0
16 0	-0.620	4.965	14.980	0.479	0.0	0.0
17 0	-0.622	5.759	16.361	0.540	0.0	0.0
18 0	-0.598	5.860	16.397	0.547	0.0	0.0
19 0	-2.987	-2.742	3.640	0.284	0.0	0.0
20 0	-2.445	-2.244	2.978	0.231	0.0	0.0
1 2	0.0	-3.915	0.0	0.0	0.0	0.0
1 3	0.0	-2.099	0.0	0.0	0.0	0.0
1 4	0.0	4.226	0.0	0.0	0.0	0.0
1 5	0.0	3.440	0.0	0.0	0.0	0.0
1 6	0.0	3.795	0.0	0.0	0.0	0.0
1 7	-18.000	-9.965	-69.500	4.100	0.0	0.0
1 8	2.886	11.417	-1.390	-0.447	0.0	0.0
1 9	1.191	10.978	8.330	0.549	0.0	0.0
1 10	2.724	4.328	-10.295	-0.450	0.0	0.0
1 11	2.667	4.456	-9.909	-0.435	0.0	0.0
1 12	0.891	-1.769	-19.213	-0.669	0.0	0.0
1 13	3.036	-0.014	-22.132	-0.891	0.0	0.0
1 14	3.063	-0.014	-21.861	-0.875	0.0	0.0
1 15	3.064	2.114	-17.958	-0.711	0.0	0.0
1 16	0.620	-0.130	-14.980	-0.479	0.0	0.0
1 17	0.622	-0.924	-16.361	-0.540	0.0	0.0
1 18	0.598	-1.025	-16.397	-0.547	0.0	0.0
1 19	2.987	7.577	-3.640	-0.284	0.0	0.0
1 20	2.445	7.079	-2.978	-0.231	0.0	0.0
2 3	0.0	1.816	0.0	0.0	0.0	0.0
2 4	0.0	8.141	0.0	0.0	0.0	0.0
2 5	0.0	7.355	0.0	0.0	0.0	0.0
2 6	0.0	7.710	0.0	0.0	0.0	0.0
2 7	-18.000	-6.050	-69.500	4.100	0.0	0.0
2 8	2.886	15.332	-1.390	0.447	0.0	0.0
2 9	1.191	14.893	8.330	0.549	0.0	0.0

ATR1144 38

AZ1

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN.	PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
2	10	2.724	8.243	-10.295	-0.450	0.0	0.0
2	11	2.667	8.371	-9.909	-0.435	0.0	0.0
2	12	0.891	2.146	-19.213	-0.669	0.0	0.0
2	13	3.036	3.901	-22.132	-0.891	0.0	0.0
2	14	3.063	3.901	-21.861	-0.875	0.0	0.0
2	15	3.064	6.029	-17.958	-0.711	0.0	0.0
2	16	0.620	3.785	-14.980	-0.479	0.0	0.0
2	17	0.622	2.991	-16.361	-0.540	0.0	0.0
2	18	0.598	2.890	-16.397	-0.547	0.0	0.0
2	19	2.987	11.492	-3.640	-0.284	0.0	0.0
2	20	2.445	10.994	-2.978	-0.231	0.0	0.0
3	4	0.0	6.325	0.0	0.0	0.0	0.0
3	5	0.0	5.539	0.0	0.0	0.0	0.0
3	6	0.0	5.894	0.0	0.0	0.0	0.0
3	7	-18.000	-7.866	-69.500	4.100	0.0	0.0
3	8	2.886	13.516	-1.390	0.447	0.0	0.0
3	9	1.191	13.077	8.330	0.549	0.0	0.0
3	10	2.724	6.427	-10.295	-0.450	0.0	0.0
3	11	2.667	6.555	-9.909	-0.435	0.0	0.0
3	12	0.891	0.330	-19.213	-0.669	0.0	0.0
3	13	3.036	2.085	-22.132	-0.891	0.0	0.0
3	14	3.063	2.085	-21.861	-0.875	0.0	0.0
3	15	3.064	4.213	-17.958	-0.711	0.0	0.0
3	16	0.620	1.969	-14.980	-0.479	0.0	0.0
3	17	0.622	1.175	-16.361	-0.540	0.0	0.0
3	18	0.598	1.074	-16.397	-0.547	0.0	0.0
3	19	2.987	9.676	-3.640	-0.284	0.0	0.0
3	20	2.445	9.178	-2.978	-0.231	0.0	0.0
4	5	0.0	-0.786	0.0	0.0	0.0	0.0
4	6	0.0	-0.431	0.0	0.0	0.0	0.0
4	7	-18.000	-14.191	-69.500	4.100	0.0	0.0
4	8	2.886	7.191	-1.390	0.447	0.0	0.0
4	9	1.191	6.752	8.330	0.549	0.0	0.0
4	10	2.724	0.102	-10.295	-0.450	0.0	0.0
4	11	2.667	0.230	-9.959	-0.435	0.0	0.0
4	12	0.891	-5.995	-19.213	-0.669	0.0	0.0
4	13	3.036	-4.240	-22.132	-0.891	0.0	0.0
4	14	3.063	-4.240	-21.861	-0.875	0.0	0.0
4	15	3.064	-2.112	-17.958	-0.711	0.0	0.0
4	16	0.620	-4.356	-14.980	-0.479	0.0	0.0
4	17	0.622	-5.150	-16.361	-0.540	0.0	0.0
4	18	0.598	-5.251	-16.397	-0.547	0.0	0.0
4	19	2.987	3.351	-3.640	-0.284	0.0	0.0
4	20	2.445	2.853	-2.978	-0.231	0.0	0.0
5	6	0.0	0.355	0.0	0.0	0.0	0.0
5	7	-18.000	-13.405	-69.500	4.100	0.0	0.0

LTR 1144 38

A22

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY  
CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN. PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
5 8	2.886	7.977	-1.390	0.447	0.0	0.0
5 9	1.191	7.538	8.330	0.549	0.0	0.0
5 10	2.724	0.888	-10.295	-0.450	0.0	0.0
5 11	2.667	1.016	-9.909	-0.435	0.0	0.0
5 12	0.891	-5.209	-19.213	-0.669	0.0	0.0
5 13	3.036	-3.454	-22.132	-0.891	0.0	0.0
5 14	3.063	-3.454	-21.861	-0.875	0.0	0.0
5 15	3.064	-1.326	-17.958	-0.711	0.0	0.0
5 16	0.620	-3.570	-14.980	-0.479	0.0	0.0
5 17	0.622	-4.364	-16.361	-0.540	0.0	0.0
5 18	0.598	-4.465	-16.397	-0.547	0.0	0.0
5 19	2.987	4.137	-3.640	-0.284	0.0	0.0
5 20	2.445	3.639	-2.978	-0.231	0.0	0.0
6 7	-18.000	-13.760	-69.500	4.100	0.0	0.0
6 8	2.886	7.622	-1.390	0.447	0.0	0.0
6 9	1.191	7.183	8.330	0.549	0.0	0.0
6 10	2.724	0.533	-10.295	-0.450	0.0	0.0
6 11	2.667	0.661	-9.909	-0.435	0.0	0.0
6 12	0.891	-5.564	-19.213	-0.669	0.0	0.0
6 13	3.036	-3.809	-22.132	-0.891	0.0	0.0
6 14	3.063	-3.809	-21.861	-0.875	0.0	0.0
6 15	3.064	-1.681	-17.958	-0.711	0.0	0.0
6 16	0.620	-3.925	-14.980	-0.479	0.0	0.0
6 17	0.622	-4.719	-16.361	-0.540	0.0	0.0
6 18	0.598	-4.820	-16.397	-0.547	0.0	0.0
6 19	2.987	3.782	-3.640	-0.284	0.0	0.0
6 20	2.445	3.284	-2.978	-0.231	0.0	0.0
7 8	20.886	21.382	68.110	-3.653	0.0	0.0
7 9	19.191	20.943	77.530	-3.551	0.0	0.0
7 10	20.724	14.293	59.205	-4.550	0.0	0.0
7 11	20.667	14.421	59.591	-4.535	0.0	0.0
7 12	18.891	8.195	50.287	-4.769	0.0	0.0
7 13	21.036	9.951	47.368	-4.991	0.0	0.0
7 14	21.063	9.951	47.639	-4.975	0.0	0.0
7 15	21.064	12.079	51.542	-4.811	0.0	0.0
7 16	18.620	9.835	54.520	-4.579	0.0	0.0
7 17	18.622	9.041	53.139	-4.640	0.0	0.0
7 18	18.598	8.940	53.103	-4.647	0.0	0.0
7 19	20.987	17.542	65.860	-4.384	0.0	0.0
7 20	20.445	17.044	66.522	-4.331	0.0	0.0
8 9	-1.695	-0.439	9.720	0.102	0.0	0.0
8 10	-0.162	-7.089	-8.965	-0.897	0.0	0.0
8 11	-0.219	-6.961	-8.519	-0.882	0.0	0.0
8 12	-1.995	-13.186	-17.823	-1.116	0.0	0.0
3 13	0.150	-11.431	-20.742	-1.333	0.0	0.0
3 14	0.177	-11.431	-20.471	-1.322	0.0	0.0

LTR1144 38

A23

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN.	PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
8	15	0.172	-9.303	-16.563	-1.158	0.0	0.0
8	16	-2.266	-11.547	-13.590	-0.926	0.0	0.0
8	17	-2.264	-12.341	-14.971	-0.587	0.0	0.0
8	18	-2.268	-12.442	-15.007	-0.994	0.0	0.0
8	19	0.101	-3.840	-2.250	-0.731	0.0	0.0
8	20	-0.441	-4.338	-1.588	-0.678	0.0	0.0
9	10	1.533	-6.650	-18.625	-0.999	0.0	0.0
9	11	1.476	-6.522	-18.239	-0.984	0.0	0.0
9	12	-0.300	-12.747	-27.543	-1.218	0.0	0.0
9	13	1.845	-10.992	-30.462	-1.440	0.0	0.0
9	14	1.872	-10.992	-30.191	-1.424	0.0	0.0
9	15	1.873	-8.864	-26.288	-1.260	0.0	0.0
9	16	-0.571	-11.108	-23.310	-1.028	0.0	0.0
9	17	-0.569	-11.902	-24.691	-1.089	0.0	0.0
9	18	-0.593	-12.003	-24.727	-1.095	0.0	0.0
9	19	1.796	-3.401	-11.970	-0.833	0.0	0.0
9	20	1.254	-3.899	-11.308	-0.780	0.0	0.0
10	11	-0.057	0.128	0.386	0.015	0.0	0.0
10	12	-1.833	-6.097	-8.918	-0.219	0.0	0.0
10	13	0.312	-4.342	-11.837	-0.441	0.0	0.0
10	14	0.339	-4.342	-11.566	-0.425	0.0	0.0
10	15	0.340	-2.214	-7.663	-0.261	0.0	0.0
10	16	-2.104	-4.458	-4.685	-0.029	0.0	0.0
10	17	-2.102	-5.252	-6.066	-0.090	0.0	0.0
10	18	-2.126	-5.353	-6.102	-0.097	0.0	0.0
10	19	0.263	3.249	6.655	0.166	0.0	0.0
10	20	-0.279	2.751	7.317	0.219	0.0	0.0
11	12	-1.776	-6.225	-9.304	-0.234	0.0	0.0
11	13	0.369	-4.470	-12.223	-0.456	0.0	0.0
11	14	0.396	-4.470	-11.952	-0.440	0.0	0.0
11	15	0.397	-2.342	-8.049	-0.276	0.0	0.0
11	16	-2.047	-4.586	-5.071	-0.044	0.0	0.0
11	17	-2.045	-5.380	-6.452	-0.105	0.0	0.0
11	18	-2.069	-5.481	-6.438	-0.112	0.0	0.0
11	19	0.320	3.121	6.269	0.151	0.0	0.0
11	20	-0.222	2.623	6.931	0.204	0.0	0.0
12	13	2.145	1.755	-2.919	-0.222	0.0	0.0
12	14	2.172	1.755	-2.648	-0.206	0.0	0.0
12	15	2.173	3.883	1.255	-0.042	0.0	0.0
12	16	-0.271	1.639	4.253	0.190	0.0	0.0
12	17	-0.269	0.845	2.852	0.129	0.0	0.0
12	18	-0.293	0.744	2.816	0.122	0.0	0.0
12	19	2.096	9.346	15.573	0.385	0.0	0.0
12	20	1.554	8.848	16.235	0.438	0.0	0.0
13	14	0.027	0.0	0.271	0.016	0.0	0.0
13	15	0.028	2.128	4.174	0.130	0.0	0.0

LTR114438

A24

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY  
CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN. PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
13 16	-2.416	-0.116	7.152	0.412	0.0	0.0
13 17	-2.414	-0.910	5.771	0.351	0.0	0.0
13 18	-2.433	-1.011	5.735	0.344	0.0	0.0
13 19	-0.049	7.591	18.492	0.807	0.0	0.0
13 20	-0.591	7.093	19.154	0.660	0.0	0.0
14 15	0.001	2.128	3.903	0.164	0.0	0.0
14 16	-2.443	-0.116	6.891	0.396	0.0	0.0
14 17	-2.441	-0.910	5.500	0.335	0.0	0.0
14 18	-2.465	-1.011	5.464	0.328	0.0	0.0
14 19	-0.076	7.591	18.221	0.591	0.0	0.0
14 20	-0.618	7.093	18.883	0.644	0.0	0.0
15 16	-2.444	-2.244	2.978	0.232	0.0	0.0
15 17	-2.442	-3.038	1.597	0.171	0.0	0.0
15 18	-2.466	-3.139	1.561	0.164	0.0	0.0
15 19	-0.077	5.463	14.318	0.427	0.0	0.0
15 20	-0.619	4.965	14.980	0.480	0.0	0.0
16 17	0.002	-0.794	-1.361	-0.061	0.0	0.0
16 18	-0.022	-0.895	-1.417	-0.068	0.0	0.0
16 19	2.367	7.707	11.340	0.195	0.0	0.0
16 20	1.825	7.309	12.002	0.248	0.0	0.0
17 18	-0.024	-0.101	-0.036	-0.007	0.0	0.0
17 19	2.365	8.501	12.721	0.256	0.0	0.0
17 20	1.823	8.003	13.383	0.309	0.0	0.0
18 19	2.389	8.602	12.757	0.263	0.0	0.0
18 20	1.847	8.104	13.419	0.316	0.0	0.0
19 20	-0.542	-0.498	0.662	0.053	0.0	0.0

LTR 11 4 4 38

A25

\* \* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM. AX\*\*3+BX\*\*2+CX+D=0.....

TRAN.	PAIR	A	B	C	D
1	0	1.000	-0.48350 01	0.0	0.0
2	0	1.000	-0.87500 01	0.0	0.0
3	0	1.000	-0.69340 01	0.0	0.0
4	C	1.000	-0.60900 00	0.0	0.0
5	0	1.000	-0.13950 01	0.0	0.0
6	0	1.000	-0.10400 01	0.0	0.0
7	0	1.000	-0.10230 03	0.25290 04	-0.17350 05
8	0	1.000	0.80780 01	0.56350 01	-0.26130 02
9	0	1.000	0.15660 02	0.68110 02	0.58430 02
10	C	1.000	-0.80780 01	-0.24410 02	0.16300 02
11	0	1.000	-0.76210 01	-0.23870 02	0.11890 02
12	0	1.000	-0.24930 02	0.10340 03	0.12170 03
13	0	1.000	-0.23950 02	0.24610 02	0.34340 03
14	C	1.000	-0.23650 02	0.23430 02	0.34140 03
15	0	1.000	-0.17620 02	-0.15000 02	0.15880 03
16	0	1.000	-0.19330 02	0.61780 02	0.49550 02
17	0	1.000	-0.21500 02	0.80170 02	0.63380 02
18	0	1.000	-0.21660 02	0.82480 02	0.62370 02
19	0	1.000	0.20890 01	-0.12740 02	-0.29520 02
20	0	1.000	0.17110 01	-0.85310 01	-0.16180 02
1	2	1.000	0.39150 01	0.0	0.0
1	3	1.000	0.20990 01	0.0	0.0
1	4	1.000	-0.42260 01	0.0	0.0
1	5	1.000	-0.34400 01	0.0	0.0
1	6	1.000	-0.37950 01	0.0	0.0
1	7	1.000	0.97470 02	0.21060 04	0.11300 05
1	8	1.000	-0.12910 02	0.12870 02	0.45520 02
1	9	1.000	-0.20500 02	0.11410 03	-0.10640 03
1	10	1.000	0.32430 01	-0.61010 02	0.11930 03
1	11	1.000	0.27860 01	-0.58890 02	0.11590 03
1	12	1.000	0.20090 02	0.14850 02	-0.38880 02
1	13	1.000	0.19110 02	-0.67720 02	-0.18510 02
1	14	1.000	0.18810 02	-0.67460 02	-0.17670 02
1	15	1.000	0.12780 02	-0.87010 02	0.10720 03
1	16	1.000	0.14490 02	-0.76500 01	-0.46440 01
1	17	1.000	0.16660 02	0.40750 01	-0.14170 02
1	18	1.000	0.16820 02	0.60890 01	-0.14960 02
1	19	1.000	-0.69240 01	-0.15900 02	0.82090 02
1	20	1.000	-0.65460 01	-0.11110 02	0.51360 02
2	3	1.000	-0.18160 01	0.0	0.0
2	4	1.000	-0.81410 01	0.0	0.0
2	5	1.000	-0.73550 01	0.0	0.0
2	6	1.000	-0.77100 01	0.0	0.0
2	7	1.000	0.93550 02	0.17640 04	0.64000 04
2	8	1.000	-0.16830 02	0.18730 02	0.61230 02
2	9	1.000	-0.24410 02	0.15140 03	-0.14520 03

LTR1144 38

A26

\* \* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM AX\*\*3+BX\*\*2+CX+D=C

TRAN. PAIR	A	B	C	D
2 10	1.000	-0.67200 00	-0.90650 02	0.22910 03
2 11	1.000	-0.11290 01	-0.87240 02	0.21930 03
2 12	1.000	0.16190 02	-0.56890 02	0.22140 02
2 13	1.000	0.15200 02	-0.14250 03	0.24450 03
2 14	1.000	0.14930 02	-0.14110 03	0.24450 03
2 15	1.000	0.88650 01	-0.14530 03	0.32270 03
2 16	1.000	0.10580 02	-0.63370 02	0.31720 02
2 17	1.000	0.12750 02	-0.57540 02	0.25670 02
2 18	1.000	0.12910 02	-0.55760 02	0.23430 02
2 19	1.000	-0.10840 02	-0.16460 02	0.12470 03
2 20	1.000	-0.10460 02	-0.13190 02	0.79890 02
3 4	1.000	-0.63250 01	C.C	C.C
3 5	1.000	-0.55390 01	C.C	C.C
3 6	1.000	-0.58940 01	C.C	C.C
3 7	1.000	0.95370 02	0.19220 04	0.86720 04
3 8	1.000	-0.15010 02	0.16010 02	0.53940 02
3 9	1.000	-0.22600 02	0.13410 03	-0.12720 03
3 10	1.000	0.11440 01	-0.76900 02	0.17320 02
3 11	1.000	0.68700 00	-0.74090 02	0.17140 03
3 12	1.000	0.17590 02	-0.23610 02	-0.29500 01
3 13	1.000	0.17010 02	-0.10780 03	0.12250 03
3 14	1.000	0.16710 02	-0.10890 03	0.12290 03
3 15	1.000	0.10660 02	-0.11930 03	0.22270 03
3 16	1.000	0.12390 02	-0.37790 02	0.14850 02
3 17	1.000	0.14560 02	-0.28060 02	0.71870 01
3 18	1.000	0.14730 02	-0.27070 02	0.56250 01
3 19	1.000	-0.90230 01	-0.17270 02	0.10490 03
3 20	1.000	-0.86450 01	-0.12230 02	0.66670 02
4 5	1.000	0.78600 00	0.0	0.0
4 6	1.000	0.43100 00	0.0	0.0
4 7	1.000	0.10170 03	0.24760 04	0.16580 05
4 8	1.000	-0.86870 01	0.65460 01	0.28570 02
4 9	1.000	-0.16270 02	0.73910 02	-0.64480 02
4 10	1.000	0.74690 01	-0.29020 02	0.77570 00
4 11	1.000	0.70120 01	-0.20280 02	0.42030 01
4 12	1.000	0.24320 02	0.92270 02	-0.11120 03
4 13	1.000	0.23340 02	0.12980 02	-0.30250 03
4 14	1.000	0.23040 02	0.11990 02	-0.30060 03
4 15	1.000	0.17010 02	-0.24070 02	-0.12530 03
4 16	1.000	0.18720 02	0.53040 02	-0.43890 02
4 17	1.000	0.20890 02	0.70590 02	-0.57180 02
4 18	1.000	0.21050 02	0.72860 02	-0.56390 02
4 19	1.000	-0.26980 01	-0.13140 02	0.30140 02
4 20	1.000	-0.23200 01	-0.88550 01	0.20610 02
5 6	1.000	-0.35500 00	C.C	C.C
5 7	1.000	0.10090 03	0.24070 04	0.15600 05

TR1144 38

\* \* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM AX\*\*3+BX\*\*2+CX+D=0

TRAN. PAIR	A	B	C	D
5 8	1.000	-0.94730 01	0.77220 01	0.31720 02
5 9	1.000	-0.17060 02	0.81390 02	-0.72270 02
5 10	1.000	0.58830 01	-0.34970 02	0.22820 02
5 11	1.000	0.62260 01	-0.33970 02	0.24980 02
5 12	1.000	0.23530 02	0.77870 02	-0.97770 02
5 13	1.000	0.22550 02	-0.20290 01	-0.24970 03
5 14	1.000	0.22250 02	-0.27980 01	-0.24800 03
5 15	1.000	0.16220 02	-0.35780 02	-0.82040 02
5 16	1.000	0.17930 02	0.41750 02	-0.36590 02
5 17	1.000	0.20100 02	0.58220 02	-0.49180 02
5 18	1.000	0.20260 02	0.60440 02	-0.48690 02
5 19	1.000	-0.34940 01	-0.13650 02	0.44690 02
5 20	1.000	-0.31060 01	-0.92740 01	0.26340 02
6 7	1.000	0.10130 03	0.24380 04	0.16050 05
6 8	1.000	-0.91180 01	0.71910 01	0.30300 02
6 9	1.000	-0.16700 02	0.78010 02	-0.68750 02
6 10	1.000	0.70380 01	-0.32290 02	0.12860 02
6 11	1.000	0.65810 01	-0.31400 02	0.15590 02
6 12	1.000	0.23890 02	0.64380 02	-0.10380 03
6 13	1.000	0.22910 02	0.47500 01	-0.27350 03
6 14	1.000	0.22610 02	0.38760 01	-0.27180 03
6 15	1.000	0.16580 02	-0.30490 02	-0.10160 03
6 16	1.000	0.18290 02	0.46850 02	-0.39890 02
6 17	1.000	0.20460 02	0.63900 02	-0.52790 02
6 18	1.000	0.20620 02	0.66050 02	-0.52170 02
6 19	1.000	-0.31290 01	-0.13420 02	0.40830 02
6 20	1.000	-0.27510 01	-0.90890 01	0.23750 02
7 8	1.000	-0.11040 03	0.33120 04	-0.29510 05
7 9	1.000	-0.11800 03	0.35130 04	-0.30300 05
7 10	1.000	-0.94220 02	0.23490 04	-0.16310 05
7 11	1.000	-0.94680 02	0.23680 04	-0.16530 05
7 12	1.000	-0.77370 02	0.14940 04	-0.66420 04
7 13	1.000	-0.78360 02	0.16520 04	-0.97360 04
7 14	1.000	-0.78650 02	0.16620 04	-0.88060 04
7 15	1.000	-0.84690 02	0.19400 04	-0.11920 05
7 16	1.000	-0.82980 02	0.17140 04	-0.88410 04
7 17	1.000	-0.80200 02	0.16170 04	-0.78030 04
7 18	1.000	-0.80640 02	0.16070 04	-0.76820 04
7 19	1.000	-0.10440 03	0.28860 04	-0.22980 05
7 20	1.000	-0.10400 03	0.28240 04	-0.21930 05
8 9	1.000	-0.75860 01	-0.20010 02	-0.71320 01
8 10	1.000	0.16160 02	0.64910 02	0.30620 01
8 11	1.000	0.15700 02	0.61910 02	0.63800 01
8 12	1.000	0.33000 02	0.29560 03	0.44670 03
8 13	1.000	0.32020 02	0.23050 03	-0.72700 02
8 14	1.000	0.31730 02	0.22660 03	-0.77200 02

LRI 144 38

A28

\* \* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM AX\*\*3+BX\*\*2+CX+D=0

TRAN. PAIR	A	B	C	D
8 15	1.000	0.2569D 02	0.1482D 03	-0.4965D 02
8 16	1.000	0.2740D 02	0.2130D 03	0.3439D 03
8 17	1.000	0.2958D 02	0.2456D 03	0.4037D 03
8 18	1.000	0.2974D 02	0.2485D 03	0.4124D 03
8 19	1.000	0.5989D 01	0.7491D 01	-0.2075D 01
8 20	1.000	0.6367D 01	0.9042D 01	0.2308D 01
9 10	1.000	0.2374D 02	0.8411D 02	-0.2085D 03
9 11	1.000	0.2329D 02	0.8144D 02	-0.1932D 03
9 12	1.000	0.4059D 02	0.3617D 03	0.6447D 02
9 13	1.000	0.3961D 02	0.2563D 03	-0.6809D 03
9 14	1.000	0.3931D 02	0.2527D 03	-0.6825D 03
9 15	1.000	0.3328D 02	0.1656D 03	-0.4782D 03
9 15	1.000	0.3499D 02	0.2775D 03	0.1232D 03
9 17	1.000	0.3716D 02	0.3135D 03	0.1379D 03
9 18	1.000	0.3732D 02	0.3174D 03	0.1463D 03
9 19	1.000	0.1358D 02	0.1241D 02	-0.8142D 02
9 20	1.000	0.1395D 02	0.2441D 02	-0.6217D 02
10 11	1.000	-0.4570D 00	0.1988D 01	0.2903D 02
10 12	1.000	0.1685D 02	0.8185D 02	0.9924D 02
10 13	1.000	0.1587D 02	0.4615D 02	-0.1834D 02
10 14	1.000	0.1557D 02	0.4465D 02	-0.1911D 02
10 15	1.000	0.9537D 01	0.1354D 02	-0.6290D 01
10 16	1.000	0.1125D 02	0.4012D 02	0.4394D 02
10 17	1.000	0.1342D 02	0.5564D 02	0.6692D 02
10 18	1.000	0.1358D 02	0.5701D 02	0.6939D 02
10 19	1.000	-0.1017D 02	0.2420D 02	-0.5503D 01
10 20	1.000	-0.9789D 01	0.1727D 02	0.5967D 01
11 12	1.000	0.1731D 02	0.8544D 02	0.1024D 02
11 13	1.000	0.1632D 02	0.4827D 02	-0.2270D 02
11 14	1.000	0.1603D 02	0.4673D 02	-0.2347D 02
11 15	1.000	0.9994D 01	0.1465D 02	-0.8097D 01
11 16	1.000	0.1170D 02	0.4302D 02	0.4759D 02
11 17	1.000	0.1388D 02	0.5890D 02	0.7091D 02
11 18	1.000	0.1404D 02	0.6031D 02	0.7349D 02
11 19	1.000	-0.9710D 01	0.2255D 02	-0.6118D 01
11 20	1.000	-0.9332D 01	0.1602D 02	0.4324D 01
12 13	1.000	-0.9810D 00	-0.7669D 01	0.1084D 02
12 14	1.000	-0.1279D 01	-0.6629D 01	0.9981D 01
12 15	1.000	-0.7311D 01	0.1604D 02	-0.1059D 02
12 16	1.000	-0.5601D 01	0.5310D 01	0.2033D 01
12 17	1.000	-0.3428D 01	0.1399D 01	0.6957D 00
12 18	1.000	-0.3267D 01	0.1037D 01	0.6558D 00
12 19	1.000	-0.2702D 02	0.1976D 03	-0.3028D 03
12 20	1.000	-0.2654D 02	0.1824D 03	-0.2201D 03
13 14	1.000	-0.2980D 00	0.7061D 02	0.6938D 04
13 15	1.000	-0.6330D 01	0.9026D 01	-0.1155D 00

LTR1144 38

\* \* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM  $AX^3+BX^2+CX+D=0$

TRAN. PAIR	A	B	C	D
13 16	1.000	-0.46200 01	-0.18000 02	-0.79040 00
13 17	1.000	-0.24470 01	-0.17110 02	-0.11970 02
13 18	1.000	-0.22860 01	-0.17430 02	-0.13460 02
13 19	1.000	-0.26030 02	0.13870 03	0.13690 02
13 20	1.000	-0.25660 02	0.11990 03	0.88640 02
14 15	1.000	-0.60320 01	0.82350 01	0.96670-01
14 16	1.000	-0.43220 01	-0.17480 02	-0.27090 00
14 17	1.000	-0.21490 01	-0.16320 02	-0.11600 02
14 18	1.000	-0.19880 01	-0.16610 02	-0.13030 02
14 19	1.000	-0.25740 02	0.13600 03	0.16890 02
14 20	1.000	-0.25360 02	0.11750 03	0.90600 02
15 16	1.000	0.17100 01	-0.85300 01	-0.16170 02
15 17	1.000	0.38830 01	-0.13620 01	-0.11800 02
15 18	1.000	0.40440 01	-0.10360 01	-0.12040 02
15 19	1.000	-0.19700 02	0.76510 02	0.86330 01
15 20	1.000	-0.19330 02	0.61800 02	0.49490 02
16 17	1.000	0.21730 01	0.10880 01	-0.73320-02
16 18	1.000	0.23340 01	0.13140 01	0.21350-01
16 19	1.000	-0.21410 02	0.13240 03	-0.20640 03
16 20	1.000	-0.21040 02	0.12150 03	-0.15720 03
17 18	1.000	0.16100 00	0.68750-02	0.65500-04
17 19	1.000	-0.23590 02	0.15830 03	-0.25490 03
17 20	1.000	-0.23210 02	0.14600 03	-0.19400 03
18 19	1.000	-0.23750 02	0.16070 03	-0.26130 03
18 20	1.000	-0.23370 02	0.14840 03	-0.19950 03
19 20	1.000	0.37800 00	-0.42140 00	-0.17680 00

LIRI 44 38

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NCTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN.	PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
1	0	0.0	4.835	0.0	4.835	2.334
2	0	0.0	8.750	0.0	8.750	4.224
3	0	0.0	6.934	C.C	6.934	3.347
4	0	0.0	0.609	0.000	0.609	0.294
5	0	0.0	1.395	0.0	1.395	0.673
6	0	0.0	1.040	0.0	1.040	0.502
7	0	69.500	20.801	11.999	57.501	27.756
8	0	1.390	-2.833	-6.635	8.025	3.874
9	0	-1.131	-6.203	-8.330	7.199	3.475
10	0	10.295	0.569	-2.786	13.081	6.314
11	0	9.909	0.440	-2.728	12.637	6.100
12	0	19.213	6.663	-0.950	20.163	9.733
13	0	22.132	4.948	-3.135	25.267	12.197
14	0	21.861	4.945	-3.159	25.020	12.077
15	0	17.958	2.807	-3.150	21.108	10.189
16	0	14.980	5.006	-0.661	15.641	7.550
17	0	16.361	5.804	-0.667	17.028	8.220
18	0	16.397	5.906	-0.644	17.041	8.226
19	0	3.640	-2.555	-3.174	6.814	3.289
20	0	2.978	-2.093	-2.596	5.574	2.691
1	2	0.0	0.0	-3.915	3.915	1.890
1	3	0.0	0.0	-2.099	2.099	1.013
1	4	0.0	4.226	0.000	4.226	2.040
1	5	0.0	3.440	0.0	3.440	1.660
1	6	0.0	3.795	0.0	3.795	1.832
1	7	-8.242	-19.723	-69.500	61.258	29.569
1	8	11.440	2.863	-1.390	12.830	6.193
1	9	11.009	8.330	1.160	9.848	4.754
1	10	4.446	2.606	-10.295	14.741	7.115
1	11	4.556	-2.567	-5.909	14.465	6.982
1	12	1.050	-1.928	-19.213	20.263	9.781
1	13	3.277	-0.255	-22.132	25.409	12.265
1	14	3.294	-0.245	-21.861	25.155	12.143
1	15	3.444	1.734	-17.958	21.402	10.331
1	16	0.853	-0.363	-14.980	15.833	7.643
1	17	0.792	-1.094	-16.361	17.153	8.280
1	18	0.765	-1.192	-16.397	17.162	8.284
1	19	7.595	2.969	-3.640	11.235	5.423
1	20	7.090	2.434	-2.978	10.068	4.860
2	3	0.0	1.816	0.0	1.816	0.877
2	4	0.0	8.141	0.000	8.141	3.930
2	5	0.0	7.355	0.000	7.355	3.550
2	6	0.0	7.710	C.C	7.710	3.722
2	7	-4.779	-19.271	-69.500	64.721	31.241
2	8	15.348	2.870	-1.390	16.738	8.079
2	9	14.915	8.330	1.169	13.746	6.635

LFR1144 38

A31

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN.	PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
2	10	8.279	2.688	-10.295	18.574	8.966
2	11	8.404	2.634	-9.909	18.313	8.840
2	12	2.436	0.601	-19.213	21.649	10.450
2	13	4.459	2.478	-22.132	26.591	12.835
2	14	4.452	2.512	-21.861	26.313	12.701
2	15	6.191	2.902	-17.958	24.149	11.657
2	16	3.856	0.549	-14.980	18.836	9.092
2	17	3.108	0.505	-16.361	19.469	9.398
2	18	3.014	0.474	-16.397	19.411	9.370
2	19	11.501	2.978	-3.640	15.141	7.309
2	20	11.000	2.439	-2.978	13.978	6.747
3	4	0.0	6.325	0.000	6.325	3.053
3	5	0.0	5.539	0.000	5.539	2.674
3	6	0.0	5.894	0.000	5.894	2.845
3	7	-6.415	-19.451	-69.500	63.085	30.451
3	8	13.535	2.867	-1.390	14.925	7.204
3	9	13.102	8.330	1.166	11.937	5.762
3	10	6.481	2.670	-10.295	16.776	8.098
3	11	6.603	2.619	-9.909	16.512	7.970
3	12	1.336	-0.115	-19.213	20.549	9.919
3	13	3.570	1.551	-22.132	25.702	12.407
3	14	3.576	1.572	-21.261	25.437	12.279
3	15	4.553	2.724	-17.958	22.511	10.866
3	16	2.122	0.467	-14.980	17.102	8.255
3	17	1.505	0.292	-16.361	17.866	8.624
3	18	1.433	0.239	-16.397	17.830	8.606
3	19	9.688	2.975	-3.640	13.328	6.433
3	20	9.186	2.437	-2.978	12.164	5.872
4	5	0.0	0.0	-0.786	0.786	0.379
4	6	0.0	-0.000	-0.431	0.431	0.208
4	7	-11.575	-20.616	-69.500	57.925	27.961
4	8	7.237	2.840	-1.390	3.627	4.164
4	9	8.330	6.806	1.137	7.193	3.472
4	10	2.799	0.027	-10.295	13.094	6.321
4	11	2.742	0.155	-9.909	12.651	6.107
4	12	0.955	-6.059	-19.213	20.168	9.735
4	13	3.144	-4.348	-22.132	25.276	12.200
4	14	3.166	-4.343	-21.861	25.027	12.081
4	15	3.160	-2.208	-17.958	21.118	10.194
4	16	0.666	-4.402	-14.980	15.646	7.552
4	17	0.672	-5.200	-16.361	17.023	8.222
4	18	0.649	-5.302	-16.397	17.046	8.228
4	19	-3.640	3.506	2.832	7.146	3.450
4	20	-2.978	2.957	2.341	5.935	2.865
5	6	0.0	0.355	0.0	0.355	0.171
5	7	-11.003	-20.402	-69.500	58.497	28.237

LTR 1144 38

A32

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN. PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
5 8	8.016	2.847	-1.390	9.406	4.540
5 9	8.330	7.585	1.144	7.186	3.469
5 10	2.828	0.784	-10.295	13.123	6.335
5 11	2.775	0.908	-9.909	12.684	6.122
5 12	0.964	-5.282	-19.213	20.177	9.739
5 13	3.156	-3.574	-22.132	25.288	12.207
5 14	3.178	-3.569	-21.861	25.039	12.087
5 15	3.176	-1.438	-17.958	21.134	10.202
5 16	0.674	-3.624	-14.980	15.854	7.556
5 17	0.680	-4.422	-16.361	17.041	8.226
5 18	0.656	-4.523	-16.397	17.053	8.232
5 19	4.203	2.921	-3.640	7.843	3.786
5 20	3.682	2.402	-2.978	6.660	3.215
6 7	-11.264	-20.496	-69.500	58.236	28.110
6 8	7.664	2.844	-1.390	9.054	4.370
6 9	8.330	7.233	1.141	7.189	3.470
6 10	2.813	0.444	-10.295	13.108	6.327
6 11	2.757	0.571	-9.909	12.666	6.114
6 12	0.960	-5.633	-19.213	20.173	9.737
6 13	3.150	-3.923	-22.132	25.282	12.204
6 14	3.173	-3.919	-21.861	25.034	12.084
6 15	3.168	-1.785	-17.958	21.126	10.198
6 16	0.670	-3.975	-14.980	15.650	7.554
6 17	0.676	-4.773	-16.361	17.037	8.224
6 18	0.653	-4.875	-16.397	17.050	8.230
6 19	3.873	2.896	-3.640	7.513	3.627
6 20	3.343	2.386	-2.978	6.321	3.051
7 8	68.110	24.795	17.473	50.637	24.443
7 9	77.830	23.724	16.410	61.420	29.648
7 10	59.205	23.080	11.937	47.268	22.816
7 11	59.591	23.050	12.038	47.553	22.954
7 12	50.287	20.709	6.378	43.909	21.195
7 13	47.368	22.952	8.035	39.333	18.986
7 14	47.639	22.965	8.049	39.590	19.110
7 15	51.542	23.154	9.989	41.553	20.058
7 16	54.520	20.573	7.882	46.638	22.512
7 17	53.139	20.501	7.162	45.977	22.193
7 18	53.103	20.471	7.067	46.036	22.221
7 19	65.860	23.975	14.554	51.306	24.765
7 20	66.522	23.397	14.092	52.430	25.308
8 9	9.720	-0.431	-1.703	11.423	5.514
8 10	-0.048	-7.203	-8.905	8.857	4.275
8 11	-0.106	-7.074	-8.519	8.413	4.061
8 12	-1.885	-13.296	-17.823	15.938	7.693
8 13	0.303	-11.584	-20.742	21.045	10.158
8 14	0.326	-11.580	-20.471	20.797	10.039

LTR1144 38

A33

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN.	PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
8	15	0.317	-9.442	-15.568	16.895	8.151
8	16	-2.175	-11.638	-13.590	11.415	5.510
8	17	-2.168	-12.437	-14.971	12.803	6.180
8	18	-2.192	-12.538	-15.007	12.815	6.186
8	19	0.232	-2.250	-3.971	4.203	2.029
8	20	-0.326	-1.588	-4.453	4.126	1.992
9	10	1.653	-6.770	-18.625	20.278	9.788
9	11	1.595	-6.641	-18.239	19.834	9.574
9	12	-0.182	-12.865	-27.543	27.361	13.207
9	13	2.005	-11.152	-30.462	32.467	15.672
9	14	2.028	-11.148	-30.191	32.219	15.552
9	15	2.019	-9.010	-26.288	28.307	13.664
9	16	-0.472	-11.207	-23.310	22.838	11.024
9	17	-0.465	-12.006	-24.691	24.226	11.694
9	18	-0.489	-12.107	-24.727	24.238	11.700
9	19	1.926	-3.531	-11.970	13.896	6.708
9	20	1.369	-4.014	-11.308	12.677	6.119
10	11	0.386	0.129	-0.058	0.444	0.214
10	12	-1.822	-6.108	-8.918	7.096	3.425
10	13	0.353	-4.383	-11.837	12.190	5.684
10	14	0.377	-4.380	-11.566	11.943	5.765
10	15	0.366	-2.240	-7.663	8.029	3.876
10	16	-2.104	-4.458	-4.685	2.581	1.246
10	17	-2.099	-5.255	-6.066	3.967	1.915
10	18	-2.123	-5.356	-6.102	3.979	1.921
10	19	6.655	3.258	0.254	6.401	3.090
10	20	7.317	2.767	-0.295	7.612	3.674
11	12	-1.764	-6.237	-9.304	7.540	3.640
11	13	0.412	-4.513	-12.223	12.635	6.099
11	14	0.435	-4.509	-11.952	12.387	5.979
11	15	0.425	-2.370	-8.049	8.474	4.090
11	16	-2.046	-4.587	-5.071	3.025	1.460
11	17	-2.042	-5.383	-6.452	4.410	2.129
11	18	-2.065	-5.485	-6.488	4.423	2.135
11	19	6.269	3.129	0.312	5.957	2.876
11	20	6.931	2.638	-0.237	7.168	3.460
12	13	2.245	1.655	-2.919	5.164	2.493
12	14	-2.648	2.257	1.670	4.905	2.367
12	15	3.884	2.172	1.255	2.629	1.269
12	16	4.233	1.658	-0.290	4.523	2.183
12	17	2.852	0.860	-0.284	3.136	1.514
12	18	2.816	0.758	-0.307	3.123	1.508
12	19	15.573	9.366	2.076	13.497	6.515
12	20	16.235	8.874	1.528	14.707	7.099
13	14	0.271	0.034	-0.007	0.278	0.134
13	15	4.174	2.143	0.013	4.161	2.009

LTR1144 38

A34

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN.	PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
13	16	7.152	-0.044	-2.488	9.640	4.653
13	17	5.771	-0.832	-2.492	8.263	3.988
13	18	5.735	-0.932	-2.517	8.252	3.983
13	19	18.492	7.639	-0.097	18.589	8.973
13	20	19.154	7.149	-0.647	19.801	9.558
14	15	3.903	2.141	-0.012	3.915	1.890
14	16	6.881	-0.050	-2.509	9.390	4.532
14	17	5.500	-0.840	-2.511	8.011	3.867
14	18	5.464	-0.940	-2.536	8.000	3.861
14	19	18.221	7.636	-0.121	18.342	8.854
14	20	18.883	7.146	-0.671	19.554	9.439
15	16	2.978	-2.091	-2.597	5.575	2.691
15	17	1.597	-2.396	-3.084	4.681	2.259
15	18	1.561	-2.428	-3.177	4.738	2.287
15	19	14.318	5.496	-0.110	14.428	6.964
15	20	14.980	5.006	-0.660	15.640	7.549
16	17	0.007	-0.799	-1.381	1.388	0.670
16	18	-0.017	-0.900	-1.417	1.400	0.676
16	19	11.340	7.714	2.360	8.980	4.335
16	20	12.002	7.220	1.814	10.188	4.918
17	18	-0.101	-0.023	-0.037	0.079	0.038
17	19	12.721	8.512	2.354	10.367	5.004
17	20	13.383	8.018	1.808	11.575	5.587
18	19	12.757	8.613	2.378	10.379	5.010
18	20	13.419	8.120	1.831	11.588	5.593
19	20	0.662	-0.463	-0.577	1.239	0.598

LTR114438

A35

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR	SPECIFIED NO. CYCLES	ALT. S.I.	N	U	TRAN.	CYCLES REMAINING	TRAN	CYCLES REMAINING	TRAN. ELIMINATED
2 7	370	31.241	3x10 <sup>5</sup> 2.4x10 <sup>5</sup>	.0012	2	0	7	130	2
3 7	500	30.451		.0015	3	1000	7	0	7
7 9	260	29.648							
1 7	370	29.569							
5 7	100	28.237							
6 7	500	28.110							
4 7	500	27.961							
7 0	500	27.756							
7 20	500	25.308							
7 19	260	24.765							
7 8	260	24.443							
7 11	360	22.954							
7 10	360	22.816							
7 16	500	22.512							
7 18	500	22.221							
7 17	500	22.193							
7 12	500	21.195							
7 15	500	20.058							
7 14	500	19.110							
7 13	500	18.986							
9 13	260	15.672							
9 14	260	15.552							
9 15	260	13.664							
9 12	260	13.207							
2 13	370	12.835							
2 14	370	12.701							
3 13	1500	12.407							
3 14	1500	12.279							
1 13	370	12.265							
5 13	100	12.207							
6 13	1500	12.204							
4 13	1500	12.200							
13 0	1500	12.197							
1 14	370	12.143							
5 14	100	12.087							
6 14	1500	12.084							
4 14	1500	12.081							
14 0	1500	12.077							
9 18	260	11.700							
9 17	260	11.694							
2 15	370	11.657							
9 16	260	11.024							
3 15	1500	10.866							
2 12	370	10.450							
1 15	370	10.331							
5 15	100	10.202							

$\Sigma U = .0027$

NO FURTHER USAGE BELOW 26.0 KSI

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR SPECIFIED NO. CYCLES ALT. S.I.

6	15	1500	10.198
4	15	1500	10.194
15	0	1500	10.189
8	13	260	10.158
8	14	260	10.039
3	12	1500	9.919
9	10	260	9.798
1	12	370	9.781
5	12	100	9.739
6	12	1500	9.737
4	12	1500	9.735
12	0	1500	9.733
9	11	260	9.574
13	20	1500	9.558
14	20	1500	9.439
2	17	370	9.398
2	18	370	9.370
2	16	370	9.092
13	19	260	8.973
2	10	360	8.966
14	19	260	8.854
2	11	360	8.840
3	17	1500	8.624
3	18	1500	8.606
1	13	370	8.284
1	17	370	8.280
3	16	1500	8.255
5	18	100	8.232
6	18	1500	8.230
4	18	1500	8.228
18	0	1500	8.226
5	17	100	8.226
6	17	1500	8.224
4	17	1500	8.222
17	0	1500	8.220
8	15	260	8.151
3	10	360	8.098
2	8	260	8.079
3	11	360	7.970
8	12	260	7.693
1	16	370	7.643
5	16	100	7.556
6	16	1500	7.554
4	16	1500	7.552
16	0	1500	7.550
15	20	1500	7.549

LTR1144 38

437

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR	SPECIFIED NO. CYCLES	ALT. S.I.
2 19	260	7.309
3 8	260	7.204
1 10	360	7.115
12 20	1500	7.099
1 11	360	6.982
15 19	260	6.964
2 20	370	6.747
9 19	260	6.708
2 9	260	6.635
12 19	260	6.515
3 19	260	6.433
5 10	100	6.335
6 10	360	6.327
4 10	360	6.321
10 0	360	6.314
1 8	260	6.193
8 18	260	6.186
8 17	260	6.180
5 11	100	6.122
9 20	260	6.119
6 11	360	6.114
4 11	360	6.107
11 0	360	6.100
11 13	360	6.099
11 14	360	5.979
10 13	360	5.884
3 20	1500	5.872
10 14	360	5.765
3 9	260	5.762
18 20	1500	5.593
17 20	1500	5.587
8 9	260	5.514
8 16	260	5.510
1 19	260	5.423
18 19	260	5.010
17 19	260	5.004
16 20	1500	4.918
1 20	370	4.860
1 9	260	4.754
13 16	1500	4.653
5 8	100	4.540
14 16	1500	4.532
6 8	260	4.370
16 19	260	4.335
8 10	260	4.275
2 0	370	4.224

LTR 1 4 4 38

A 38

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN.	PAIR	SPECIFIED NO. CYCLES	ALT. S.I.
4	3	260	4.164
11	15	360	4.090
8	11	260	4.061
13	17	1500	3.988
13	18	1500	3.983
2	4	370	3.930
10	15	360	3.876
8	0	260	3.874
14	17	1500	3.867
14	18	1500	3.861
5	19	100	3.786
2	6	370	3.722
10	20	360	3.674
11	12	360	3.640
6	19	260	3.627
2	5	100	3.550
9	0	260	3.475
4	9	260	3.472
6	9	260	3.470
5	9	100	3.469
11	20	360	3.460
4	19	260	3.450
10	12	360	3.425
3	0	1500	3.347
19	0	260	3.289
5	20	100	3.215
10	19	260	3.090
3	4	1500	3.053
6	20	2600	3.051
11	19	260	2.876
4	20	1000000	2.865
3	6	1500	2.845
15	16	1500	2.691
20	0	1000000	2.691
3	5	100	2.674
12	13	1500	2.493
12	14	1500	2.367
1	0	370	2.334
15	18	1500	2.287
15	17	1500	2.259
12	16	1500	2.183
11	18	360	2.135
11	17	360	2.129
1	4	370	2.040
8	19	260	2.029
13	15	1500	2.009

LTR1144 38

A39

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR	SPECIFIED NO. CYCLES	ALT. S.I.
8 20	260	1.992
10 18	360	1.921
10 17	360	1.915
1 2	370	1.890
14 15	1500	1.890
1 6	370	1.832
1 5	100	1.660
12 17	1500	1.514
12 18	1500	1.508
11 16	360	1.460
12 15	1500	1.269
10 16	360	1.246
1 3	370	1.013
2 3	370	0.877
16 18	1500	0.676
5 0	100	0.673
16 17	1500	0.670
19 20	260	0.598
6 0	2600	0.562
4 5	100	0.379
4 0	1000000	0.294
10 11	360	0.214
4 6	2600	0.208
5 6	100	0.171
13 14	1500	0.134
17 18	1500	0.038

LTR 144 38

940

UPSET CONDITIONS

AS EXPRESSED IN PARAGRAPH NB-3223, UPSET CONDITIONS ARE ANALYZED AS NORMAL CONDITIONS.

EMERGENCY CONDITIONS

PARAGRAPH NB-3224 DEFINES STRESS LIMITS FOR EMERGENCY CONDITIONS. SAFE SHUTDOWN EARTHQUAKE (SSE) IS THE EMERGENCY LOAD WHICH MUST BE CONSIDERED. THE SSE LOADS ARE TWICE THE OBE LOADS AS PREVIOUSLY LISTED. THUS, THE NECESSARY LOADS AFTER BEING TRANSLATED TO THE AREA OF INTEREST ARE:

$$\begin{aligned} M_x &= -907.75 \text{ IN-LB} \\ M_y &= 754 \text{ IN-LB} \\ M_z &= 1632 \text{ IN-LB} \\ F_y &= 934 \text{ LB.} \end{aligned}$$

USING THE SAME CALCULATIONS AS PREVIOUSLY SHOWN, THE PIPING STRESS DUE TO SSE IS FOUND AS FOLLOWS:

$$\sigma_{M_x} = M_x / Z_x = 908 / 1.305 = \pm 696 \text{ PSI}$$

$$\sigma_{M_z} = M_z / Z_z = 1632 / 1.305 = \pm 1251 \text{ PSI}$$

$$\sigma_{F_y} = F_y / A = 934 / 3.931 = 238 \text{ PSI}$$

$$\tau = M_y / Z_y = T / S = 754 / 2.611 = 289 \text{ PSI}$$

$$\sigma_b = \sigma_{F_y} + \sqrt{\sigma_{M_x}^2 + \sigma_{M_z}^2}$$

$$= 238 + \sqrt{(696)^2 + (1251)^2}$$

$$= 238 + 1432$$

$$\sigma_b = 1670 \text{ PSI}$$

$$\begin{aligned} \sigma_T &= \sigma_1/2 + \sqrt{(\sigma_1/2)^2 + \tau_1^2} \\ &= 835 + \sqrt{(835)^2 + (289)^2} \\ &= 835 + 884 \\ \sigma_T &= 1719 \text{ PSI} \end{aligned}$$

THE PRIMARY STRESS LIMIT FOR EMERGENCY CONDITIONS IS 1.2 S<sub>M</sub>

$$S_M = 13,200 \text{ PSI @ } 650^\circ \text{F}$$

$$1.2 (13,200) = 15,840$$

$$1719 < 15,840$$

THUS EMERGENCY CONDITION REQUIREMENTS ARE MET.

### FAULTED CONDITIONS

AS LISTED IN APPENDIX F, PAGE 483, OF THE ASME CODE, THE PRIMARY STRESS LIMITS FOR FAULTED CONDITIONS ARE 2.4 S<sub>M</sub> OR 0.7 S<sub>u</sub>, WHICHEVER IS LESS. AS WAS DONE IN THE REFERENCE 6 PIPING REPORT, LOCE AND SSE WILL BE COMBINED TO FORM THE FAULTED CONDITION LOADING. ORDINARILY, LOSS OF COOLANT ACCIDENT (LOCA) + SSE LOADS WOULD BE USED; HOWEVER, LOCA LOADS WERE NOT AVAILABLE SO LOCE + SSE LOADS WERE USED. AT THE AREA OF INTEREST THE LOADS ARE:

SSE:

$$\begin{aligned} M_x &= -908 \text{ IN-LB} \\ M_y &= 754 \text{ " } \\ M_z &= 1032 \text{ " } \\ F_y &= 934 \text{ LB} \end{aligned}$$

LOCE:

$$\begin{aligned} M_x &= -391 \text{ IN-LB} \\ M_y &= 256 \text{ " } \\ M_z &= 1016 \text{ " } \\ F_y &= 772 \text{ LB} \end{aligned}$$

USING CALCULATIONS SIMILAR TO THOSE SHOWN PREVIOUSLY:

$$\sigma_{M_x} = \pm 995 \text{ PSI}$$

$$\sigma_{M_z} = \pm 2029 \text{ PSI}$$

$$\sigma_{F_y} = 434 \text{ PSI}$$

$$\sigma_{M_y} = \pm 774 \text{ PSI}$$

$$\begin{aligned} \sigma_b &= \sigma_{F_y} + \sqrt{\sigma_{M_x}^2 + \sigma_{M_z}^2} \\ &= 434 + \sqrt{(995)^2 + (2029)^2} \end{aligned}$$

$$= 434 + 2260$$

$$\sigma_b = 2694 \text{ PSI}$$

$$\begin{aligned} \sigma_f &= \sigma_b/2 + \sqrt{(\sigma_b/2)^2 + \tau^2} \\ &= 1347 + \sqrt{(1347)^2 + (774)^2} \end{aligned}$$

$$= 1347 + 1554$$

$$\sigma_f = 2901 \text{ PSI}$$

$$2.4 S_m = 2.4(13,200) = 31,680 \text{ PSI @ } 650^\circ\text{F FOR SA 182}$$

$$.7 S_u = .7(57,200) = 40,040 \text{ PSI @ } 650^\circ\text{F}$$

$$2,901 < 31,680$$

THUS, FAULTED CONDITION REQUIREMENTS ARE MET.

APPENDIX B

SURGE NOZZLE CALCULATIONS

THIS APPENDIX DESCRIBES IN DETAIL THE LOFT PRESSURIZER SURGE NOZZLE COMPONENT ANALYSIS IN ACCORDANCE WITH SUBARTICLE NB-5200 OF SECTION III OF THE ASME CODE. IT SHOULD BE NOTED THAT ANY REFERENCES CITED IN THIS APPENDIX ARE TAKEN FROM THE MAIN LIST OF REFERENCES IN SECTION 5.0 OF THE MAIN BODY OF THE REPORT.

## DESIGN CONDITIONS

DESIGN CONDITION STRESS ALLOWABLES ARE DEFINED BY PARAGRAPH NB-3221 OF THE ASME CODE. SINCE THE EMPHASIS OF THIS REPORT IS THE INCLUSION OF THE 450°F STEP TRANSIENT IN THE FATIGUE CALCULATIONS, THE DESIGN CONDITION CALCULATIONS SHOWN IN THE BTI REPORT (REFERENCE 2) WERE REVIEWED AND ACCEPTED AS ADEQUATE. BTI CALCULATED A GENERAL PRIMARY MEMBRANE STRESS VALUE OF 7,268 PSI AT THE PIPING CONNECTION AND 4,767 PSI IN THE NOZZLE SHELL. THE ALLOWABLE STRESS VALUES FOR THESE AREAS ARE 16,600 PSI AND 17,330 PSI, RESPECTIVELY.

## NORMAL CONDITIONS

NORMAL CONDITION STRESS ALLOWABLES ARE DEFINED BY PARAGRAPH NB-3222 OF THE ASME CODE. NORMAL OPERATING CONDITIONS ANALYZED CONSIST OF THE FOLLOWING MECHANICAL AND THERMAL LOADS:

### MECHANICAL LOADS:

DEADWEIGHT  
STEADY STATE OPERATION  
SEISMIC (OBE)  
LOCE (MECH.)

### THERMAL LOADS:

450°F STEP TRANSIENT  
LOCE

STEADY STATE FLUCTUATIONS  
PLANT LOADING  
HEAT - UP  
COOLDOWN  
OPERATING TEMP.


SINCE THE METHOD USED TO CALCULATE PRIMARY PLUS SECONDARY STRESSES FOR THE SPRAY NOZZLE VERIFIED BTI'S CALCULATION METHOD WITHIN REASONABLE LIMITS, THE BTI PROCEDURE WILL BE USED TO CALCULATE PRIMARY PLUS SECONDARY STRESSES FOR THE SURGE NOZZLE. BRIEFLY, THE BTI METHOD CALCULATES STRESS RANGES USING THE PRINCIPAL STRESS DIFFERENCES FOR EACH LOAD CASE. A MORE COMPLETE DESCRIPTION OF THIS PROCEDURE CAN BE SEEN IN THE BTI REPORT (REFERENCE 2).

TO COMPLETE ALL NECESSARY EVALUATION OF THE SURGE NOZZLE, THE SAAS III FINITE ELEMENT MODEL OF THE SURGE NOZZLE AND THERMAL SHIELD WAS RUN WITH THE 450 OF STEP THERMAL TRANSIENT. A PLOT OF THE FINITE ELEMENT MESH SHOWING NODE AND ELEMENT NUMBERING SCHEMES IS SHOWN IN SEVERAL SECTIONS IN FIGURE B1, PAGES, B3-B5. PRESSURE LOADS WERE USED TO CALCULATE AN EQUIVALENT END PRESSURE OF 6704 PSI AT THE PIPING CONNECTION, WHILE PRESSURIZER SHELL STRESSES WERE USED AS BOUNDARY CONDITIONS ALONG THE MODEL BOUNDARY IN THE SHELL. DATA PRESENTED IN REFERENCE 5 WAS USED TO DETERMINE CRITICAL TIME STEPS FOR SEVERAL PROFILES THROUGH THE MODEL. THE SAAS III RUN SHOWED THAT FOR ALL TIME STEPS THE AREAS OF MAXIMUM STRESS WERE THE TWO INCH END OF THE END FITTING (ELEMENTS 67-72, FIG. B1, PAGE B5) AND THE BI-METALLIC WELD CONNECTING THE END FITTING TO THE NOZZLE (ELEMENTS 150-159, FIGURE B1, PAGE B4). THUS, THESE TWO AREAS WILL BE THE SUBJECT OF THE REMAINING DISCUSSION. THE COMPLETE OUTPUT FROM THE SAAS III COMPUTER RUN IS SHOWN IN MICROFICHE FORM IN APPENDIX C. THE FOUR STRESS COMPONENTS RESULTING FROM THE SAAS III ANALYSIS ARE PLOTTED AND LINEARIZED IN FIGURES B2-B5, PAGES B6-B9, FOR PROFILE 1 (ELEMENTS 67-72) AND FIGURES B6-B9, PAGES B10-B13, FOR PROFILE 2 (ELEMENTS 150-159).

FIGURE B1  
SAAS III


ELEMENT PLOT

SURGE NOZZLE 450 DEGREE STEP TRANSIENT



LTR1144 38

FIGURE B1 (CONT'D)




① → NODE #1  
 | → ELEMENT #1

8.100+00  
 7.200+00  
 6.300+00  
 5.400+00  
 4.500+00  
 3.600+00  
 2.700+00  
 1.800+00  
 0.900+00  
 0.000+00  
 -1.485-04  
 S-YIS  
 R-AXIS

LTR1144 38


64

FIGURE B1 (CONT'D)



LTR1144 38


FIGURE B2  
LINEARIZED STRESS  $\sigma_r$   
PROFILE 1  
LOFT PRESSURIZER SURGE NOZZLE



40 1323


1/76 KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE B3  
LINEARIZED STRESS ~  $\sigma_z$   
PROFILE 1  
LOFT PRESSURIZER SURGE NOZZLE




46 1323

K-E 10 X 10 TO 1/4 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.



10 1070  
NEWTON B. ROBERT CO. MADE IN U.S.A.

FIGURE 85  
LINEARIZED STRESS ~  $\tau_{rz}$   
PROFILE I  
LOFT PRESSURIZER SURGE NOZZLE



46 1323

K&E 10 X 10 TO 1/4 INCH 7 X 10 INCHES KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE B6  
LINEARIZED STRESS  $\sim \sigma_R$   
PROFILE 2  
LOFT PRESSURIZER SURGE NOZZLE






FIGURE B7  
LINEARIZED STRESS  $\sim \sigma_z$   
PROFILE 2  
LOFT PRESURIZER SURGE NOZZLE



46 1323

K&E 10 X 10 TO 1/4 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.


FIGURE B8  
LINEARIZED STRESS ~  $\sigma_r$   
PROFILE 2  
LOFT PRESSURIZER SURGE NOZZLE



46 1323

KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE B9  
LINEARIZED STRESS  $\sim T_{rz}$   
PROFILE 2  
LOFT PRESSURIZER SURGE NOZZLE



46 1323

K-E 10 X 10 TO 1/4 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

USING THE LINEARIZED COMPONENTS SHOWN IN THESE FIGURES AND THE TRIAXIAL STRESS EQUATION:

$$\sigma^3 - (\sigma_R + \sigma_z + \sigma_T) \sigma^2 + (\sigma_R \sigma_z + \sigma_z \sigma_T + \sigma_R \sigma_T - \tau_{Rz}^2) \sigma - (\sigma_R \sigma_z \sigma_T - \sigma_T \tau_{Rz}^2) = 0$$

THE PRINCIPAL STRESSES AND STRESS DIFFERENCES SHOWN BELOW ARE FOUND:

PROFILE 1, INSIDE:

$$\sigma_1 = \sigma_{x_{BTI}} = 7.2 \quad \text{KSI}$$

$$\sigma_2 = \sigma_{y_{BTI}} = 89.1 \quad \text{KSI}$$

$$\sigma_3 = \sigma_{h_{BTI}} = 56.0 \quad \text{KSI}$$

NOTE USE OF BTI'S SYSTEM

$$S_{xy} = 7.2 - 89.1 = -81.9 \quad \text{KSI}$$

$$S_{yh} = 89.1 - 56.0 = 33.1 \quad \text{KSI}$$

$$S_{hx} = 56.0 - 7.2 = 48.8 \quad \text{KSI}$$

PROFILE 1, OUTSIDE

$$\sigma_x = -6.6 \quad \text{KSI}$$

$$\sigma_y = -86.2 \quad \text{KSI}$$

$$\sigma_h = -84.0 \quad \text{KSI}$$

$$S_{xy} = -6.6 - (-86.2) = 79.6 \quad \text{KSI}$$

$$S_{yh} = -86.2 - (-84.0) = -2.2 \quad \text{KSI}$$

$$S_{hx} = -84.0 - (-6.6) = -77.4 \quad \text{KSI}$$

PROFILE 2, INSIDE

$$\sigma_x = 11.4 \text{ KSI}$$

$$\sigma_y = 38.2 \text{ KSI}$$

$$\sigma_H = 57.5 \text{ KSI}$$

$$S_{xy} = 11.4 - 38.2 = -26.8 \text{ KSI}$$

$$S_{yH} = 38.2 - 57.5 = -19.3 \text{ KSI}$$

$$S_{HX} = 57.5 - 11.4 = 46.1 \text{ KSI}$$

PROFILE 2, OUTSIDE

$$\sigma_x = 0.7 \text{ KSI}$$

$$\sigma_y = -32.6 \text{ KSI}$$

$$\sigma_H = -37.0 \text{ KSI}$$

$$S_{xy} = .7 - (-32.6) = 33.3 \text{ KSI}$$

$$S_{yH} = -32.6 - (-37.0) = 4.4 \text{ KSI}$$

$$S_{HX} = -37.0 - .7 = -37.7 \text{ KSI}$$

AS STATED IN THE BTI REPORT, MAXIMUM PRIMARY PLUS SECONDARY STRESS RANGES ARE AS FOLLOWS:

PROFILE 1, INSIDE : LOCE (20 SEC.) & S.S.F. (+6)

PROFILE 1, OUTSIDE : LOCE (20) & S.S.F. (36)

PROFILE 2, INSIDE : LOCE (20) & S.S.F. (36)

PROFILE 2, OUTSIDE : LOCE (25) & HOT LEAK

NOW, MUST CHECK TO SEE IF RANGE BETWEEN 450°F STEP TRANSIENT AND ANY OF THE ABOVE IS GREATER THAN MAXIMUMS CALCULATED BY BTI.

PROFILE 1, INSIDE, LOCE & 450°F STEP:

$$\begin{array}{r}
 \text{LOCE} \\
 - 450^\circ \text{STEP}
 \end{array}
 \begin{array}{r}
 S_{xy} = -45.2 \\
 + 81.9 \\
 \hline
 36.7
 \end{array}
 \begin{array}{r}
 S_{yh} = 22.6 \\
 - 33.1 \\
 \hline
 -10.5
 \end{array}
 \begin{array}{r}
 S_{hx} = 22.6 \\
 - 48.8 \\
 \hline
 -26.2
 \end{array}$$

MAX S.I. RANGE = 36.7 KSI

PROFILE 1, INSIDE, S.S.F. (6) & 450°F STEP:

$$\begin{array}{r}
 \text{SSF} \\
 - 450^\circ \text{STEP}
 \end{array}
 \begin{array}{r}
 S_{xy} = -1.7 \\
 + 81.9 \\
 \hline
 80.2
 \end{array}
 \begin{array}{r}
 S_{yh} = -5.7 \\
 - 33.1 \\
 \hline
 -38.8
 \end{array}
 \begin{array}{r}
 S_{hx} = 7.4 \\
 - 48.8 \\
 \hline
 -41.4
 \end{array}$$

MAX. S.I. RANGE = 80.2 KSI

PROFILE 1, OUTSIDE, LOCE & 450°F STEP:

$$\begin{array}{r}
 \text{LOCE} \\
 - 450^\circ \text{STEP}
 \end{array}
 \begin{array}{r}
 S_{xy} = 47.9 \\
 - 79.6 \\
 \hline
 -31.7
 \end{array}
 \begin{array}{r}
 S_{yh} = -6.6 \\
 + 2.2 \\
 \hline
 -4.4
 \end{array}
 \begin{array}{r}
 S_{hx} = -41.3 \\
 + 77.4 \\
 \hline
 36.1
 \end{array}$$

MAX. S.I. RANGE = 36.1

PROFILE 1, OUTSIDE, S.S.F. & 450°F STEP:

$$\begin{array}{r}
 \text{SSF} \\
 - 450^\circ \text{STEP}
 \end{array}
 \begin{array}{r}
 S_{xy} = -5.5 \\
 - 79.6 \\
 \hline
 -85.1
 \end{array}
 \begin{array}{r}
 S_{yh} = -1.7 \\
 + 2.2 \\
 \hline
 0.5
 \end{array}
 \begin{array}{r}
 S_{hx} = 7.2 \\
 + 77.4 \\
 \hline
 84.6
 \end{array}$$

MAX S.I. RANGE = 85.1 KSI

PROFILE 2, INSIDE, LOCE & 450°F STEP:

$$\begin{array}{r}
 \text{LOCE} \\
 - 450^\circ \text{STEP}
 \end{array}
 \begin{array}{r}
 S_{xy} = -28.6 \\
 + 26.8 \\
 \hline
 -1.8
 \end{array}
 \begin{array}{r}
 S_{yh} = 2.2 \\
 + 19.3 \\
 \hline
 21.5
 \end{array}
 \begin{array}{r}
 S_{hx} = 26.4 \\
 - 46.1 \\
 \hline
 -19.7
 \end{array}$$

MAX. S.I. RANGE = 21.5 KSI

PROFILE 2, INSIDE, S.S.F. & 450° STEP:

SSF 450° STEP	$S_{xy} = \frac{0.2}{26.8} = \frac{26.8}{27.0}$	$S_{yh} = \frac{0.9}{19.3} = \frac{19.3}{20.2}$	$S_{hx} = \frac{-1.1}{-46.1} = \frac{-46.1}{-47.2}$
------------------	---	---	---

MAX. S.I. RANGE = 47.2 KSI

PROFILE 2, OUTSIDE, LOCE & 450° STEP

LOCE 450° STEP	$S_{xy} = \frac{22.7}{-33.3} = \frac{-33.3}{10.6}$	$S_{yh} = \frac{7.3}{-4.4} = \frac{-4.4}{2.9}$	$S_{hx} = \frac{-30.0}{37.7} = \frac{37.7}{7.7}$
-------------------	--	--	--

MAX. S.I. RANGE = 10.6 KSI

PROFILE 2, OUTSIDE, HOT LEAK & 450° STEP

H.L. 450° STEP	$S_{xy} = \frac{-4.3}{-33.3} = \frac{-33.3}{-37.6}$	$S_{yh} = \frac{-1.9}{-4.4} = \frac{-4.4}{-6.3}$	$S_{hx} = \frac{6.3}{37.7} = \frac{37.7}{44.0}$
-------------------	---	--	---

MAX S.I. RANGE = 44.0 KSI

MATERIAL FOR BOTH PROFILES IS INCONEL (SB-167),  
THUS:

$$S_M = 16.6 \text{ KSI } @ 650^\circ \text{ F}$$

$$3S_M = 49.8 \text{ KSI}$$

IT CAN BE SEEN IN THE PREVIOUS CALCULATIONS THAT THE  $3S_M$  LIMIT ON PRIMARY PLUS SECONDARY STRESS INTENSITY HAS BEEN EXCEEDED IN TWO AREAS. THUS, A SIMPLIFIED ELASTIC-PLASTIC ANALYSIS PER NB-3228.3 WILL BE PERFORMED FOR THE TWO POINTS.

USING FIGURES B2-B5, THE STRESS COMPONENTS FOR PROFILE 1, EXCLUDING THERMAL BENDING, ARE:

$$\begin{aligned}\sigma_R &= - .35 \text{ KSI} \\ \sigma_B &= 2.50 \text{ KSI} \\ \sigma_H &= -15.50 \text{ KSI} \\ \tau_{RZ} &= -3.83 \text{ KSI}\end{aligned}$$

USING THESE COMPONENTS IN THE TRIAXIAL STRESS EQUATION SHOWN ON PAGE B14 YIELDS THE FOLLOWING PRINCIPAL STRESSES:

$$\begin{aligned}\sigma_1 = \sigma_x &= -3.01 \\ \sigma_2 = \sigma_y &= 5.16 \\ \sigma_3 = \sigma_z &= -15.50\end{aligned}$$

STRESS DIFFERENCES ARE:

$$S_{xy} = -3.01 - 5.16 = -8.17$$

$$S_{yz} = 5.16 - (-15.50) = 20.66$$

$$S_{xz} = -15.50 - (-3.01) = -12.49$$

PROFILE 1, INSIDE, S.S.F. & 450° STEP (MINUS T.B.)

S.S.F.  
- 450° STEP

$$S_{xy} = \begin{array}{r} -1.7 \\ 8.2 \\ \hline 6.5 \end{array}$$

$$S_{yz} = \begin{array}{r} -5.7 \\ -20.7 \\ \hline -26.4 \end{array}$$

$$S_{xz} = \begin{array}{r} 7.4 \\ 12.5 \\ \hline 19.9 \end{array}$$

$$\text{MAX. S.I.} = 26.4 \text{ KSI}$$

PROFILE 1, OUTSIDE, S.S.F. & 450° STEP (MINUS T.B.)

S.S.F.  
- 450° STEP

$$S_{xy} = \begin{array}{r} -5.5 \\ 8.2 \\ \hline 2.7 \end{array}$$

$$S_{yz} = \begin{array}{r} -1.7 \\ -20.7 \\ \hline -22.4 \end{array}$$

$$S_{xz} = \begin{array}{r} 7.2 \\ 12.5 \\ \hline 19.7 \end{array}$$

$$\text{MAX. S.I.} = 22.4 \text{ KSI}$$

SO MAXIMUM RANGE OF PRIMARY + SECONDARY - THERMAL BENDING STRESS INTENSITY IS

$$26.4 \text{ KSI}$$

$$26.4 < 3S_M \text{ (OR } 49.8) \text{ KSI} \quad \text{SO MAY PROCEED}$$

$S_n$  = RANGE OF PRIMARY + SECONDARY STRESS  
 USING MAXIMUM VALUE HAVE:

$$S_n = 85.1 \text{ KSI}$$

FOR INCONEL SB-167:

$$m = 1.7$$

$$n = .3$$

$$3m S_m = 3.0(1.7)(16.6) = 84.7 \text{ KSI}$$

$$S_n > 3m S_m$$

16.

$$85.1 > 84.7$$

THUS:

$$K_e = \frac{1}{n}$$

$$= \frac{1}{.3}$$

$$\underline{\underline{K_e = 3.33}}$$

THUS, MUST MULTIPLY  $S_A$  VALUE FOR STEADY STATE FLUCTUATIONS AND 450°F STEP TRANSIENT PAIRING IN FATIGUE CALCULATIONS BY  $K_e$  IF THIS PAIRING ENTERS INTO CUMULATIVE USAGE CALCULATIONS.

## FATIGUE ANALYSIS

THE FATIGUE ANALYSIS WAS PERFORMED IN ACCORDANCE WITH SUBPARAGRAPH NB-3222.4 OF THE ASME CODE. THE PEAK STRESSES USED IN THESE CALCULATIONS WERE AS LISTED IN THE FATIGUE ANALYSIS SHOWN IN THE BTI REPORT WITH THE EXCEPTION OF THE 450°F STEP TRANSIENT. PEAK STRESS VALUES FOR THE 450°F STEP TRANSIENT WERE TAKEN FROM FIGURES B2 - B9 FOR PROFILES 1 AND 2.

THE TRANSIENT LOADS ANALYZED WERE:

1. OBE
2. LOCE (MECH.)
3. 450°F STEP
4. LOCE (20 SEC.)
5. LOCE (25 SEC.)
6. LOCE (55 SEC.)
7. LOCE (195 SEC.)
8. STEADY STATE FLUCTUATIONS (S.S.F.) (-, 6 SEC)
9. S.S.F. (- 36 SEC.)
10. S.S.F. (+ 6 SEC.)
11. S.S.F. (+ 36 SEC.)
12. PLANT LDG. (4 SEC.)
13. PLANT LDG. (48 SEC.)
14. HEAT-UP (3.3 HR.)
15. HEAT-UP (5.8 HR.)
16. COOL DOWN (1.06 HR.)
17. LEAK TEST
18. HOT LEAK
19. O.T.P.


THE APPLIED MECHANICS BRANCH COMPUTER PROGRAM INTENS WAS USED TO CALCULATE ALTERNATING STRESS INTENSITIES FOR ALL POSSIBLE PAIRINGS OF TRANSIENT LOADS FOR BOTH AREAS OF INTEREST IN THE MODEL. THE FINAL TABLE OF OUTPUT FROM THIS PROGRAM LISTS ALTERNATING STRESS INTENSITIES IN DECREASING ORDER SUCH THAT THE APPROPRIATE FATIGUE LIFE CURVE MAY BE USED TO CALCULATE ALLOWABLE NUMBERS OF CYCLES AND THE CUMULATIVE USAGE FACTOR. FIGURE I-9.2 AS SHOWN ON PAGE 159 OF SUBSECTION NA OF THE 1974 EDITION OF THE ASME CODE WAS USED TO DETERMINE ALLOWABLE NUMBERS OF CYCLES. THIS CURVE IS REPRODUCED IN FIGURE B10, PAGE B22. A COMPLETE FORTRAN LISTING OF THE INTENS PROGRAM IS SHOWN IN APPENDIX D.

THE INTENS COMPUTER RUNS FOR BOTH AREAS OF INTEREST SHOWED THAT MAXIMUM ALTERNATING STRESS INTENSITY OCCURRED IN PROFILE 2 (THE AREA OF THE BI-METALLIC WELD) WHEN A STRESS CONCENTRATION FACTOR OF 2.0, AS ALLOWED BY SUBPARAGRAPH NB-3352.2, WAS USED. THUS, ONLY PROFILE 2 FATIGUE CALCULATIONS ARE INCLUDED IN THIS APPENDIX.

THE INTENS COMPUTER OUTPUT FOR PROFILE 2 IS SHOWN ON PAGES B23-B44. THE CUMULATIVE USAGE CALCULATIONS ARE SHOWN ON PAGES B40 AND B41. AS CAN BE SEEN ON PAGE B41, THE CUMULATIVE USAGE FACTOR WAS 0.6095. THIS VALUE IS UNDER THE USAGE FACTOR LIMIT OF 1.0.

### UPSET CONDITIONS

AS EXPRESSED IN PARAGRAPH NB-3223, UPSET CONDITIONS ARE ANALYZED AS NORMAL CONDITIONS.



NOTE:  
 $E = 26.0 \times 10^6$  psi

### FIGURE B10

DESIGN FATIGUE CURVE FOR AUSTENITIC STEELS, NICKEL-CHROMIUM-IRON ALLOY, NICKEL-IRON-CHROMIUM ALLOY AND NICKEL-COPPER ALLOY

LTR1144 38

024

\* \* PROGRAM -- INTENS -- CALCULATION OF TRANSIENT STRESS INTENSITIES \* \*

NO. OF PROBLEMS OR POINTS TO BE ANALYZED IS 1

LIRL 44 38

823

PROBLEM NO. 1  
 NO. OF TRANSIENTS 19  
 STRESS CONCENTRATION FACTOR = 2.000  
 ELASTIC MODULUS RATIO = 0.900

\* \* TRANSIENT STRESS DATA \* \*

\* \* NOTE THAT STRESSES ARE IN KSI \* \*

TRANS	NO. CYCLES	SIGMA X	SIGMA Y	SIGMA Z	TAU XY	TAU XZ	TAU YZ
1	100	0.0	-0.024	0.0	0.0	0.0	0.0
2	2600	0.0	-0.056	0.0	0.0	0.0	0.0
3	500	11.150	87.000	119.000	2.600	0.0	0.0
4	260	3.308	84.329	93.387	7.106	0.0	0.0
5	260	0.707	54.302	62.665	5.815	0.0	0.0
6	260	1.878	20.018	28.294	1.326	0.0	0.0
7	260	1.582	12.958	18.051	1.106	0.0	0.0
8	1000000	5.583	5.300	5.919	-0.961	0.0	0.0
9	1000000	4.864	7.834	10.901	-0.982	0.0	0.0
10	1000000	5.293	0.075	1.297	-1.102	0.0	0.0
11	1000000	6.011	-2.459	-2.687	-1.081	0.0	0.0
12	11000	5.784	6.347	8.460	-0.730	0.0	0.0
13	11000	4.605	12.154	17.195	-0.798	0.0	0.0
14	1500	-0.467	5.432	7.075	0.539	0.0	0.0
15	1500	3.504	6.469	8.571	-0.984	0.0	0.0
16	1500	2.987	5.914	6.543	0.648	0.0	0.0
17	260	1.740	3.368	6.667	-2.432	0.0	0.0
18	260	5.754	3.300	4.820	-1.474	0.0	0.0
19	1000000	5.438	2.688	3.607	-1.032	0.0	0.0

LRI 44 38

B24

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN.	PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
1	0	0.0	-0.024	0.0	0.0	0.0	0.0
2	0	0.0	-0.056	0.0	0.0	0.0	0.0
3	0	11.150	87.000	119.000	2.600	0.0	0.0
4	0	3.308	84.329	93.387	7.106	0.0	0.0
5	0	0.707	54.302	62.665	5.815	0.0	0.0
6	0	1.878	20.018	28.294	1.326	0.0	0.0
7	0	1.582	12.958	18.051	1.106	0.0	0.0
8	0	5.583	5.300	5.919	-0.961	0.0	0.0
9	0	4.864	7.834	10.901	-0.982	0.0	0.0
10	0	5.293	0.075	1.297	-1.102	0.0	0.0
11	0	6.011	-2.459	-3.687	-1.081	0.0	0.0
12	0	5.784	6.347	8.460	-0.730	0.0	0.0
13	0	4.605	12.154	17.195	-0.798	0.0	0.0
14	0	-0.467	5.432	7.075	0.539	0.0	0.0
15	0	3.504	6.469	8.571	-0.984	0.0	0.0
16	0	2.987	5.914	6.543	0.648	0.0	0.0
17	0	1.740	3.368	6.667	-2.432	0.0	0.0
18	0	5.754	3.300	4.820	-1.474	0.0	0.0
19	0	5.438	2.688	3.607	-1.032	0.0	0.0
1	2	0.0	0.032	0.0	0.0	0.0	0.0
1	3	-11.150	-87.024	-119.000	-2.600	0.0	0.0
1	4	-3.308	-84.353	-93.387	-7.106	0.0	0.0
1	5	-0.707	-54.326	-62.665	-5.815	0.0	0.0
1	6	-1.878	-20.042	-28.294	-1.326	0.0	0.0
1	7	-1.582	-12.982	-18.051	-1.106	0.0	0.0
1	8	-5.583	-5.324	-5.919	0.961	0.0	0.0
1	9	-4.864	-7.858	-10.901	0.982	0.0	0.0
1	10	-5.293	-0.099	-1.297	1.102	0.0	0.0
1	11	-6.011	2.435	3.687	1.081	0.0	0.0
1	12	-5.784	-6.371	-8.460	0.730	0.0	0.0
1	13	-4.605	-12.178	-17.195	0.798	0.0	0.0
1	14	0.467	-5.456	-7.075	-0.539	0.0	0.0
1	15	-3.504	-6.493	-8.571	0.984	0.0	0.0
1	16	-2.987	-5.938	-6.543	-0.648	0.0	0.0
1	17	-1.740	-3.392	-6.667	2.432	0.0	0.0
1	18	-5.754	-3.324	-4.820	1.474	0.0	0.0
1	19	-5.438	-2.712	-3.607	-1.032	0.0	0.0
2	3	-11.150	-87.056	-119.000	-2.600	0.0	0.0
2	4	-3.308	-84.385	-93.387	-7.106	0.0	0.0
2	5	-0.707	-54.358	-62.665	-5.815	0.0	0.0
2	6	-1.878	-20.074	-28.294	-1.326	0.0	0.0
2	7	-1.582	-13.014	-18.051	-1.106	0.0	0.0
2	8	-5.583	-5.356	-5.919	0.961	0.0	0.0
2	9	-4.864	-7.890	-10.901	0.982	0.0	0.0
2	10	-5.293	-0.131	-1.297	1.102	0.0	0.0
2	11	-6.011	2.403	3.687	1.081	0.0	0.0

LRI 144 38

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN.	PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
2	12	-5.784	-6.403	-8.460	0.730	0.0	0.0
2	13	-4.605	-12.210	-17.195	0.798	0.0	0.0
2	14	0.467	-5.488	-7.075	-0.539	0.0	0.0
2	15	-3.504	-6.525	-8.571	0.984	0.0	0.0
2	16	-2.987	-5.970	-6.543	-0.648	0.0	0.0
2	17	-1.740	-3.424	-6.667	2.432	0.0	0.0
2	18	-5.754	-3.356	-4.820	1.474	0.0	0.0
2	19	-5.438	-2.744	-3.607	1.032	0.0	0.0
3	4	7.842	2.671	25.613	-4.506	0.0	0.0
3	5	10.443	32.698	56.335	-3.215	0.0	0.0
3	6	9.272	66.982	90.706	1.274	0.0	0.0
3	7	9.568	74.042	100.949	1.494	0.0	0.0
3	8	5.567	81.700	113.081	3.561	0.0	0.0
3	9	6.286	79.166	108.099	3.582	0.0	0.0
3	10	5.857	86.925	117.703	3.702	0.0	0.0
3	11	5.139	89.459	122.687	3.681	0.0	0.0
3	12	5.366	80.653	110.540	3.330	0.0	0.0
3	13	6.545	74.846	101.805	3.398	0.0	0.0
3	14	11.617	81.568	111.925	2.061	0.0	0.0
3	15	7.646	80.531	110.429	3.584	0.0	0.0
3	16	8.163	81.086	112.457	1.952	0.0	0.0
3	17	9.410	83.632	112.333	5.032	0.0	0.0
3	18	5.396	83.700	114.180	4.074	0.0	0.0
3	19	5.712	84.312	115.393	3.632	0.0	0.0
4	5	2.601	30.027	30.722	1.291	0.0	0.0
4	6	1.430	64.311	65.093	5.780	0.0	0.0
4	7	1.726	71.371	75.336	6.000	0.0	0.0
4	8	-2.275	79.029	87.468	8.067	0.0	0.0
4	9	-1.556	76.495	82.486	8.088	0.0	0.0
4	10	-1.985	84.254	92.090	8.208	0.0	0.0
4	11	-2.703	86.788	97.074	8.187	0.0	0.0
4	12	-2.476	77.982	84.927	7.836	0.0	0.0
4	13	-1.297	72.175	76.192	7.904	0.0	0.0
4	14	3.775	78.897	86.312	6.567	0.0	0.0
4	15	-0.196	77.860	84.816	8.090	0.0	0.0
4	16	0.321	78.415	86.844	6.458	0.0	0.0
4	17	1.568	80.961	86.720	9.538	0.0	0.0
4	18	-2.446	81.029	88.567	8.580	0.0	0.0
4	19	-2.130	81.641	89.780	8.138	0.0	0.0
5	6	-1.171	34.284	34.371	4.489	0.0	0.0
5	7	-0.875	41.344	44.614	4.709	0.0	0.0
5	8	-4.876	49.002	56.746	6.776	0.0	0.0
5	9	-4.157	46.468	51.764	6.797	0.0	0.0
5	10	-4.586	54.227	61.368	6.917	0.0	0.0
5	11	-5.304	56.761	66.352	6.896	0.0	0.0
5	12	-5.077	47.955	54.205	6.545	0.0	0.0

LTR 1144 38

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN. PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
5 13	-3.898	42.148	45.470	6.613	0.0	0.0
5 14	1.174	48.870	55.590	5.276	0.0	0.0
5 15	-2.797	47.833	54.094	6.799	0.0	0.0
5 16	-2.280	48.388	56.122	5.167	0.0	0.0
5 17	-1.033	50.934	55.998	8.247	C.C	0.0
5 18	-5.047	51.002	57.845	7.289	C.C	0.0
5 19	-4.731	51.614	59.058	6.847	0.0	0.0
6 7	0.296	7.060	10.243	0.220	0.0	0.0
6 8	-3.705	14.718	22.375	2.287	0.0	0.0
6 9	-2.986	12.184	17.393	2.308	0.0	0.0
6 10	-3.415	19.943	26.997	2.428	0.0	0.0
6 11	-4.133	22.477	31.981	2.407	0.0	0.0
6 12	-3.906	13.671	19.834	2.056	C.C	0.0
6 13	-2.727	7.864	11.099	2.124	0.0	0.0
6 14	2.345	14.586	21.219	0.787	0.0	0.0
6 15	-1.626	13.549	19.723	2.310	0.0	0.0
6 16	-1.109	14.104	21.751	0.678	0.0	0.0
6 17	0.138	16.650	21.627	3.758	0.0	0.0
6 18	-3.876	16.718	23.474	2.800	C.C	0.0
6 19	-3.560	17.330	24.687	2.358	0.0	0.0
7 8	-4.001	7.658	12.132	2.067	C.C	0.0
7 9	-3.282	5.124	7.150	2.088	C.C	0.0
7 10	-3.711	12.883	16.754	2.208	0.0	0.0
7 11	-4.429	15.417	21.738	2.187	0.0	0.0
7 12	-4.202	6.611	9.591	1.836	0.0	0.0
7 13	-3.023	0.804	0.856	1.904	0.0	0.0
7 14	2.049	7.526	10.976	0.567	0.0	0.0
7 15	-1.922	6.489	9.480	2.090	0.0	0.0
7 16	-1.405	7.044	11.508	0.458	C.C	0.0
7 17	-0.158	9.590	11.384	3.538	0.0	0.0
7 18	-4.172	9.658	13.231	2.580	0.0	0.0
7 19	-3.856	10.270	14.444	2.138	C.C	0.0
8 9	0.719	-2.534	-4.982	0.021	0.0	0.0
8 10	0.290	5.225	4.622	0.141	0.0	0.0
8 11	-0.428	7.759	9.606	0.120	C.C	0.0
8 12	-0.201	-1.047	-2.541	-0.231	C.C	0.0
8 13	0.978	-6.854	-11.276	-0.163	0.0	0.0
8 14	6.050	-0.132	-1.156	-1.500	0.0	0.0
8 15	2.079	-1.169	-2.652	0.023	0.0	0.0
8 16	2.596	-0.614	-0.624	-1.609	0.0	0.0
8 17	3.843	1.932	-0.748	1.471	0.0	0.0
8 18	-0.171	2.000	1.099	0.513	C.C	0.0
8 19	0.145	2.612	2.312	0.071	0.0	0.0
9 10	-0.429	7.759	9.604	0.120	0.0	0.0
9 11	-1.147	10.293	14.588	0.099	C.C	0.0
9 12	-0.920	1.487	2.441	-0.252	0.0	0.0

LTR1144 38

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY  
CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN. PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
9 13	0.259	-4.320	-6.294	-0.184	0.0	0.0
9 14	5.331	2.402	3.826	-1.521	0.0	0.0
9 15	1.360	1.365	2.330	0.002	0.0	0.0
9 16	1.877	1.920	4.358	-1.630	0.0	0.0
9 17	3.124	4.466	4.234	1.450	0.0	0.0
9 18	-0.890	4.534	6.081	0.492	0.0	0.0
9 19	-0.574	5.146	7.294	0.050	0.0	0.0
10 11	-0.718	2.534	4.984	-0.021	0.0	0.0
10 12	-0.491	-6.272	-7.163	-0.372	0.0	0.0
10 13	0.688	-12.079	-15.898	-0.304	0.0	0.0
10 14	5.760	-5.357	-5.778	-1.641	0.0	0.0
10 15	1.789	-6.394	-7.274	-0.118	0.0	0.0
10 16	2.306	-5.839	-5.246	-1.750	0.0	0.0
10 17	3.553	-3.293	-5.370	1.330	0.0	0.0
10 18	-0.461	-3.225	-3.523	0.372	0.0	0.0
10 19	-0.145	-2.613	-2.310	-0.070	0.0	0.0
11 12	0.227	-8.806	-12.147	-0.351	0.0	0.0
11 13	1.406	-14.613	-20.882	-0.283	0.0	0.0
11 14	6.478	-7.891	-10.762	-1.620	0.0	0.0
11 15	2.507	-8.928	-12.258	-0.097	0.0	0.0
11 16	3.024	-8.373	-10.230	-1.729	0.0	0.0
11 17	4.271	-5.827	-10.354	1.351	0.0	0.0
11 18	0.257	-5.759	-8.507	0.393	0.0	0.0
11 19	0.573	-5.147	-7.294	-0.049	0.0	0.0
12 13	1.179	-5.807	-8.735	0.068	0.0	0.0
12 14	6.251	0.915	1.385	-1.269	0.0	0.0
12 15	2.280	-0.122	-0.111	0.254	0.0	0.0
12 16	2.797	0.433	1.917	-1.378	0.0	0.0
12 17	4.044	2.979	1.793	1.702	0.0	0.0
12 18	0.030	3.047	3.640	0.744	0.0	0.0
12 19	0.346	3.659	4.853	0.302	0.0	0.0
13 14	5.072	6.722	10.120	-1.337	0.0	0.0
13 15	1.101	5.685	8.624	0.186	0.0	0.0
13 16	1.618	6.240	10.652	-1.446	0.0	0.0
13 17	2.865	8.786	10.528	1.634	0.0	0.0
13 18	-1.149	8.854	12.375	0.676	0.0	0.0
13 19	-0.833	9.466	13.588	0.234	0.0	0.0
14 15	-3.971	-1.037	-1.496	1.523	0.0	0.0
14 16	-3.454	-0.482	0.532	-0.109	0.0	0.0
14 17	-2.207	2.064	0.408	2.971	0.0	0.0
14 18	-6.221	2.132	2.255	2.013	0.0	0.0
14 19	-5.905	2.744	3.468	1.571	0.0	0.0
15 16	0.517	0.555	2.028	-1.632	0.0	0.0
15 17	1.764	3.101	1.904	1.448	0.0	0.0
15 18	-2.250	3.169	3.751	0.490	0.0	0.0
15 19	-1.934	3.781	4.964	0.048	0.0	0.0

LTR1144 38

B28

\* \* STRESS COMPONENT RANGES - NOTE THAT A TRANSIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*

\* \* THESE VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS

\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS SAAS3 OUTPUT-STRESS COLUMNS X,Y,Z, AND XY  
CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY

TRAN. PAIR	SIG X	SIG Y	SIG Z	TAU XY	TAU XZ	TAU YZ
16 17	1.247	2.546	-0.124	3.080	0.0	0.0
16 18	-2.767	2.614	1.723	2.122	0.0	0.0
16 19	-2.451	3.226	2.936	1.680	0.0	0.0
17 18	-4.014	0.068	1.847	-0.958	0.0	0.0
17 19	-3.698	0.680	3.060	-1.400	0.0	0.0
18 19	0.316	0.612	1.213	-0.442	0.0	0.0

LTR1144 38

B29

\*\* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM AX\*\*3+BX\*\*2+CX+D=0

TRAN. PAIR	A	B	C	D
1 0	1.000	0.24000-01	0.0	0.0
2 0	1.000	0.56000-01	0.0	0.0
3 0	1.000	-0.21720 03	0.12640 05	-0.11460 06
4 0	1.000	-0.18100 03	0.84130 04	-0.21340 05
5 0	1.000	-0.11770 03	0.34520 04	-0.28680 03
6 0	1.000	-0.50190 02	0.65540 03	-0.10140 04
7 0	1.000	-0.32590 02	0.28170 03	-0.34800 03
8 0	1.000	-0.16800 02	0.93080 02	-0.16970 03
9 0	1.000	-0.23600 02	0.17560 03	-0.40490 03
10 0	1.000	-0.66650 01	0.61450 01	0.10600 01
11 0	1.000	0.13500 00	-0.29050 02	-0.58810 02
12 0	1.000	-0.20590 02	0.13880 03	-0.30610 03
13 0	1.000	-0.33950 02	0.34350 03	-0.95140 03
14 0	1.000	-0.12040 02	0.32300 02	0.20000 02
15 0	1.000	-0.18540 02	0.10720 03	-0.18600 03
16 0	1.000	-0.15440 02	0.75480 02	-0.11280 03
17 0	1.000	-0.11780 02	0.34000 02	0.36200 00
18 0	1.000	-0.13870 02	0.60460 02	-0.81050 02
19 0	1.000	-0.11730 02	0.42860 02	-0.48880 02
1 2	1.000	-0.32000-01	0.0	0.0
1 3	1.000	0.21720 03	0.12650 05	0.11470 06
1 4	1.000	0.18100 03	0.84150 04	0.21340 05
1 5	1.000	0.11770 03	0.34530 04	0.28790 03
1 6	1.000	0.50210 02	0.65610 03	0.10150 04
1 7	1.000	0.32620 02	0.28220 03	0.34860 03
1 8	1.000	0.16830 02	0.93360 02	0.17050 03
1 9	1.000	0.23620 02	0.17590 03	0.40610 03
1 10	1.000	0.66890 01	0.63030 01	-0.89540 00
1 11	1.000	-0.11100 00	-0.28990 02	0.58270 02
1 12	1.000	0.20620 02	0.13910 03	0.30720 03
1 13	1.000	0.33980 02	0.34400 03	0.95330 03
1 14	1.000	0.12060 02	0.32460 02	-0.20080 02
1 15	1.000	0.18570 02	0.10750 03	0.18670 03
1 16	1.000	0.15470 02	0.75710 02	0.11330 03
1 17	1.000	0.11800 02	0.34200 02	-0.83630-01
1 18	1.000	0.13900 02	0.60710 02	0.81720 02
1 19	1.000	0.11760 02	0.43080 02	0.49350 02
2 3	1.000	0.21720 03	0.12650 05	0.11470 06
2 4	1.000	0.18110 03	0.84180 04	0.21350 05
2 5	1.000	0.11770 03	0.34550 04	0.28930 03
2 6	1.000	0.50250 02	0.65710 03	0.10170 04
2 7	1.000	0.32650 02	0.28280 03	0.34960 03
2 8	1.000	0.16860 02	0.93730 02	0.17150 03
2 9	1.000	0.23660 02	0.17640 03	0.40780 03
2 10	1.000	0.67210 01	0.63140 01	-0.67580 00
2 11	1.000	-0.79000-01	-0.28920 02	0.57570 02

LTR1144 38

\* \* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM AX\*\*3+BX\*\*2+CX+D=0

TRAN. PAIR	A	B	C	D
2 12	1.000	0.2065D 02	0.1396D 03	0.3088D 03
2 13	1.000	0.3401D 02	0.3447D 03	0.9559D 03
2 14	1.000	0.1210D 02	0.3267D 02	-0.2019D 02
2 15	1.000	0.1860D 02	0.1079D 03	0.1877D 03
2 16	1.000	0.1550D 02	0.7602D 02	0.1139D 03
2 17	1.000	0.1183D 02	0.3447D 02	0.2876D 00
2 18	1.000	0.1393D 02	0.6105D 02	0.8260D 02
2 19	1.000	0.1179D 02	0.4337D 02	0.4998D 02
3 4	1.000	-0.3613D 02	0.2699D 03	-0.1644D 02
3 5	1.000	-0.9948D 02	0.2761D 04	-0.1865D 05
3 6	1.000	-0.1670D 03	0.7536D 04	-0.5619D 05
3 7	1.000	-0.1846D 03	0.9147D 04	-0.7129D 05
3 8	1.000	-0.2003D 03	0.1031D 05	-0.5000D 05
3 9	1.000	-0.1936D 03	0.9722D 04	-0.5241D 05
3 10	1.000	-0.2105D 03	0.1142D 05	-0.5831D 05
3 11	1.000	-0.2173D 03	0.1205D 05	-0.5474D 05
3 12	1.000	-0.1966D 03	0.9930D 04	-0.4661D 05
3 13	1.000	-0.1832D 03	0.8764D 04	-0.4870D 05
3 14	1.000	-0.2051D 03	0.1137D 05	-0.1056D 06
3 15	1.000	-0.1986D 03	0.1034D 05	-0.6658D 05
3 16	1.000	-0.2017D 03	0.1069D 05	-0.7401D 05
3 17	1.000	-0.2054D 03	0.1121D 05	-0.8556D 05
3 18	1.000	-0.2033D 03	0.1061D 05	-0.4967D 05
3 19	1.000	-0.2054D 03	0.1086D 05	-0.5405D 05
4 5	1.000	-0.6335D 02	0.1079D 04	-0.2348D 04
4 6	1.000	-0.1308D 03	0.4338D 04	-0.3812D 04
4 7	1.000	-0.1484D 03	0.5594D 04	-0.6568D 04
4 8	1.000	-0.1642D 03	0.6469D 04	0.2142D 05
4 9	1.000	-0.1574D 03	0.5997D 04	0.1521D 05
4 10	1.000	-0.1744D 03	0.7342D 04	0.2161D 05
4 11	1.000	-0.1812D 03	0.7861D 04	0.2928D 05
4 12	1.000	-0.1604D 03	0.6158D 04	0.2161D 05
4 13	1.000	-0.1471D 03	0.5244D 04	0.1189D 05
4 14	1.000	-0.1690D 03	0.7390D 04	-0.2198D 05
4 15	1.000	-0.1625D 03	0.6506D 04	0.6845D 04
4 16	1.000	-0.1656D 03	0.6821D 04	0.1436D 04
4 17	1.000	-0.1692D 03	0.7193D 04	-0.3120D 04
4 18	1.000	-0.1672D 03	0.6698D 04	0.2407D 05
4 19	1.000	-0.1693D 03	0.6898D 04	0.2156D 05
5 6	1.000	-0.6748D 02	0.1078D 04	0.2072D 04
5 7	1.000	-0.8508D 02	0.1747D 04	0.2603D 04
5 8	1.000	-0.1009D 03	0.2219D 04	0.1616D 05
5 9	1.000	-0.9408D 02	0.1951D 04	0.1239D 05
5 10	1.000	-0.1110D 03	0.2750D 04	0.1820D 05
5 11	1.000	-0.1178D 03	0.3066D 04	0.2313D 05
5 12	1.000	-0.9708D 02	0.2038D 04	0.1552D 05

LTR1144 38

B31

\*\* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM AX\*\*3+BX\*\*2+CX+D=0

TRAN. PAIR	A	B	C	D
5 13	1.000	-0.8372D 02	0.1531D 04	0.9459D 04
5 14	1.000	-0.1056D 03	0.2811D 04	-0.1642D 04
5 15	1.000	-0.9913D 02	0.2256D 04	0.9738D 04
5 16	1.000	-0.1022D 03	0.2451D 04	0.7690D 04
5 17	1.000	-0.1059D 03	0.2674D 04	0.6755D 04
5 18	1.000	-0.1038D 03	0.2348D 04	0.1796D 05
5 19	1.000	-0.1059D 03	0.2478D 04	0.1719D 05
6 7	1.000	-0.1760D 02	0.7739D 02	-0.2091D 02
6 8	1.000	-0.3339D 02	0.1867D 03	0.1337D 04
6 9	1.000	-0.2659D 02	0.1183D 03	0.7254D 03
6 10	1.000	-0.4352D 02	0.3722D 03	0.1998D 04
6 11	1.000	-0.5032D 02	0.4880D 03	0.3156D 04
6 12	1.000	-0.2960D 02	0.1361D 03	0.1143D 04
6 13	1.000	-0.1624D 02	0.3106D 02	0.2881D 03
6 14	1.000	-0.3815D 02	0.3928D 03	-0.7126D 03
6 15	1.000	-0.3165D 02	0.2078D 03	0.5398D 03
6 16	1.000	-0.3475D 02	0.2666D 03	0.3502D 03
6 17	1.000	-0.3841D 02	0.3512D 03	0.2557D 03
6 18	1.000	-0.3632D 02	0.2288D 03	0.1705D 04
6 19	1.000	-0.3846D 02	0.2727D 03	0.1660D 04
7 8	1.000	-0.1579D 02	0.9455D 01	0.4236D 03
7 9	1.000	-0.8992D 01	-0.8006D 01	0.1514D 03
7 10	1.000	-0.2593D 02	0.1010D 03	0.8827D 03
7 11	1.000	-0.3273D 02	0.1658D 03	0.1588D 04
7 12	1.000	-0.1200D 02	-0.8046D 01	0.2988D 03
7 13	1.000	0.1363D 01	-0.7955D 01	0.5184D 01
7 14	1.000	-0.2055D 02	0.1202D 03	-0.1657D 03
7 15	1.000	-0.1405D 02	0.2646D 02	0.1596D 03
7 16	1.000	-0.1715D 02	0.5479D 02	0.1163D 03
7 17	1.000	-0.2082D 02	0.9334D 02	0.1597D 03
7 18	1.000	-0.1872D 02	0.2564D 02	0.6212D 03
7 19	1.000	-0.2086D 02	0.4847D 02	0.6380D 03
8 9	1.000	0.6797D 01	0.7220D 01	-0.9079D 01
8 10	1.000	-0.1014D 02	0.2699D 02	-0.6912D 01
8 11	1.000	-0.1694D 02	0.6709D 02	0.3204D 02
8 12	1.000	0.3789D 01	0.3328D 01	0.3992D 00
8 13	1.000	0.1715D 02	0.5953D 02	-0.7589D 02
8 14	1.000	-0.4762D 01	-0.9890D 01	-0.3524D 01
8 15	1.000	0.1742D 01	-0.4844D 01	-0.6447D 01
8 16	1.000	-0.1358D 01	-0.5420D 01	-0.2610D 01
8 17	1.000	-0.5027D 01	0.9411D 00	0.3935D 01
8 18	1.000	-0.2928D 01	0.1405D 01	0.6651D 00
8 19	1.000	-0.5069D 01	0.6748D 01	-0.8640D 00
9 10	1.000	-0.1693D 02	0.6705D 02	0.3211D 02
9 11	1.000	-0.2373D 02	0.1216D 03	0.1724D 03
9 12	1.000	-0.3008D 01	-0.4750D 01	0.3494D 01

LTR1144 38

B32

\* \* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM AX\*\*3+BX\*\*2+CX+C=0

TRAN. PAIR	A	B	C	D
9 13	1.000	0.1036D 02	0.2441D 02	-0.7255D 01
9 14	1.000	-0.1156D 02	0.4008D 02	-0.4014D 02
9 15	1.000	-0.5055D 01	0.8206D 01	-0.4325D 01
9 16	1.000	-0.8155D 01	0.1749D 02	-0.4127D 01
9 17	1.000	-0.1182D 02	0.4399D 02	-0.5017D 02
9 18	1.000	-0.9725D 01	0.1788D 02	0.2601D 02
9 19	1.000	-0.1187D 02	0.3039D 02	0.2156D 02
10 11	1.000	-0.6800D 01	0.7231D 01	0.9070D 01
10 12	1.000	0.1393D 02	0.5138D 02	0.2107D 02
10 13	1.000	0.2729D 02	0.1727D 03	-0.1336D 03
10 14	1.000	0.5375D 01	-0.3588D 02	-0.1938D 03
10 15	1.000	0.1188D 02	0.2204D 02	-0.8331D 02
10 16	1.000	0.8779D 01	0.2007D 01	-0.8670D 02
10 17	1.000	0.5110D 01	-0.1487D 02	-0.7233D 02
10 18	1.000	0.7209D 01	0.1433D 02	0.4750D 01
10 19	1.000	0.5068D 01	0.6745D 01	0.8639D 00
11 12	1.000	0.2073D 02	0.1021D 03	-0.2578D 02
11 13	1.000	0.3409D 02	0.2552D 03	-0.4307D 03
11 14	1.000	0.1218D 02	-0.3854D 02	-0.5784D 03
11 15	1.000	0.1868D 02	0.5632D 02	-0.2745D 03
11 16	1.000	0.1558D 02	0.2641D 02	-0.2896D 03
11 17	1.000	0.1191D 02	-0.1060D 02	-0.2766D 03
11 18	1.000	0.1401D 02	0.4517D 02	-0.1390D 02
11 19	1.000	0.1187D 02	0.3041D 02	-0.2153D 02
12 13	1.000	0.1336D 02	0.3357D 02	-0.5984D 02
12 14	1.000	-0.8551D 01	0.1403D 02	-0.5691D 01
12 15	1.000	-0.2047D 01	-0.5822D 00	-0.3804D 01
12 16	1.000	-0.5147D 01	0.5504D 01	0.1318D 01
12 17	1.000	-0.8816D 01	0.2174D 02	-0.1641D 02
12 18	1.000	-0.6717D 01	0.1074D 02	0.1682D 01
12 19	1.000	-0.8858D 01	0.2061D 02	-0.5701D 01
13 14	1.000	-0.2191D 02	0.1517D 03	-0.3269D 03
13 15	1.000	-0.1541D 02	0.6475D 02	-0.5368D 02
13 16	1.000	-0.1851D 02	0.9171D 02	-0.8527D 02
13 17	1.000	-0.2218D 02	0.1452D 03	-0.2369D 03
13 18	1.000	-0.2008D 02	0.8472D 02	0.1315D 03
13 19	1.000	-0.2222D 02	0.1094D 03	0.1079D 03
14 15	1.000	0.6504D 01	0.9290D 01	0.2690D 01
14 16	1.000	0.3404D 01	-0.4410D 00	-0.8794D 00
14 17	1.000	-0.2650D 00	-0.1344D 02	0.5460D 01
14 18	1.000	0.1834D 01	-0.2654D 02	0.3905D 02
14 19	1.000	-0.3070D 00	-0.2963D 02	0.6475D 02
15 16	1.000	-0.3100D 01	-0.2025D 00	0.4820D 01
15 17	1.000	-0.6769D 01	0.1254D 02	-0.6423D 01
15 18	1.000	-0.4670D 01	-0.3923D 01	0.2765D 02
15 19	1.000	-0.6811D 01	0.1854D 01	0.3631D 02

LTR144 38

\*\* COEFFICIENTS FOR TRIAXIAL STRESS EQUATION - CORRELATE COLUMN HEADINGS TO FORM  $AX^3+BX^2+CX+D=0$

TRAN. PAIR	A	B	C	D
16 17	1.000	-0.3669D 01	-0.6782D C1	-0.7826D C0
16 18	1.000	-0.1570D 01	-0.1200D C2	0.2022D C2
16 19	1.000	-0.3711D 01	-0.8454D C1	0.3150D 02
17 18	1.000	0.2099D 01	-0.8479D C1	0.2199D 01
17 19	1.000	-0.4200D-01	-0.1371D 02	0.1369D 02
18 19	1.000	-0.2141D 01	0.1124D 01	0.2392D-02

LTR114438

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN. PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
1 0	0.0	-0.000	-0.024	0.024	0.022
2 0	0.0	0.0	-0.056	0.056	0.050
3 0	119.000	87.089	11.061	107.939	97.113
4 0	93.387	84.948	2.689	90.698	81.601
5 C	62.665	54.926	0.083	62.582	56.305
6 0	28.294	20.114	1.782	26.512	23.853
7 0	18.051	13.065	1.475	16.576	14.913
8 0	5.919	6.413	4.470	1.943	1.748
9 0	10.901	8.129	4.569	6.332	5.697
10 0	5.516	1.297	-0.148	5.664	5.096
11 0	6.147	-2.595	-3.687	9.834	8.847
12 0	8.460	6.848	5.283	3.177	2.858
13 0	17.195	12.237	4.522	12.673	11.402
14 0	7.075	5.481	-0.516	7.591	6.829
15 0	8.571	6.766	3.207	5.364	4.826
16 0	6.543	6.051	2.850	3.693	3.323
17 0	6.667	5.119	-0.011	6.678	6.008
18 0	6.445	4.820	2.609	3.836	3.451
19 0	5.782	3.607	2.344	3.438	3.094
1 2	0.0	0.032	0.000	0.032	0.029
1 3	-11.061	-87.113	-119.000	107.939	97.113
1 4	-2.690	-84.971	-93.387	90.697	81.600
1 5	-0.084	-54.949	-62.665	62.581	56.304
1 6	-1.782	-20.138	-28.294	26.512	23.853
1 7	-1.476	-13.088	-18.051	16.575	14.913
1 8	-4.484	-5.919	-6.423	1.939	1.745
1 9	-4.571	-8.151	-10.901	6.330	5.695
1 10	0.125	-1.297	-5.517	5.642	5.076
1 11	3.687	2.571	-6.147	9.834	8.848
1 12	-5.291	-6.864	-8.460	3.169	2.851
1 13	-4.522	-12.261	-17.195	12.673	11.402
1 14	0.516	-5.505	-7.075	7.591	6.829
1 15	-3.209	-6.788	-8.571	5.362	4.824
1 16	-2.851	-6.074	-6.543	3.692	3.322
1 17	0.002	-5.134	-6.667	6.669	6.000
1 18	-2.629	-4.820	-6.449	3.820	3.437
1 19	-2.365	-3.607	-5.785	3.419	3.076
2 3	-11.061	-87.145	-119.000	107.939	97.113
2 4	-2.690	-85.003	-93.387	90.697	81.600
2 5	-0.084	-54.981	-62.665	62.581	56.304
2 6	-1.782	-20.170	-28.294	26.512	23.853
2 7	-1.476	-13.120	-18.051	16.575	14.913
2 8	-4.502	-5.919	-6.437	1.935	1.741
2 9	-4.573	-8.181	-10.901	6.328	5.693
2 10	0.094	-1.297	-5.518	5.613	5.050
2 11	3.687	2.540	-6.148	9.835	8.848

LTR114438

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN.	PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
2	12	-5.301	-6.886	-8.460	3.159	2.843
2	13	-4.522	-12.293	-17.195	12.673	11.402
2	14	0.515	-5.536	-7.075	7.590	6.829
2	15	-3.212	-6.817	-8.571	5.359	4.822
2	16	-2.852	-6.105	-6.543	3.691	3.321
2	17	-0.008	-5.156	-6.667	6.659	5.991
2	18	-2.655	-4.820	-6.455	3.800	3.419
2	19	-2.394	-3.607	-5.788	3.394	3.053
3	4	25.613	10.452	0.061	25.552	22.989
3	5	56.335	33.153	9.988	46.347	41.699
3	6	90.706	67.010	9.244	81.462	73.291
3	7	100.949	74.077	9.533	91.416	82.247
3	8	113.081	81.866	5.401	107.680	96.880
3	9	108.099	79.342	6.110	101.989	91.759
3	10	117.703	87.094	5.688	112.015	100.780
3	11	122.687	89.619	4.979	117.708	105.902
3	12	110.540	80.800	5.219	105.321	94.757
3	13	101.805	75.015	6.376	95.429	85.857
3	14	111.925	81.629	11.556	100.369	90.302
3	15	110.429	82.707	7.470	102.959	92.632
3	16	112.457	81.138	8.111	104.346	93.880
3	17	112.333	83.972	9.070	103.263	92.905
3	18	114.180	83.911	5.185	108.995	98.063
3	19	115.393	84.479	5.545	109.848	98.831
4	5	30.722	30.088	2.540	28.182	25.355
4	6	5.093	64.838	0.903	64.190	57.752
4	7	75.336	71.884	1.213	74.123	66.689
4	8	87.468	79.822	-3.068	90.536	81.455
4	9	82.486	77.324	-2.385	84.871	76.359
4	10	92.090	85.028	-2.759	84.849	85.336
4	11	97.074	87.531	-3.446	100.520	90.438
4	12	84.927	78.738	-3.232	88.159	79.317
4	13	76.192	73.016	-2.138	78.330	70.473
4	14	86.312	79.467	3.205	83.107	74.771
4	15	84.816	78.690	-1.026	85.842	77.232
4	16	86.844	78.945	-0.209	87.053	78.322
4	17	86.720	82.091	0.438	86.282	77.628
4	18	88.567	81.702	-3.319	91.886	82.670
4	19	89.780	82.424	-2.913	92.693	83.396
5	6	34.371	34.344	-1.731	36.574	32.906
5	7	44.614	41.863	-1.394	46.008	41.393
5	8	56.746	49.841	-5.715	62.461	56.196
5	9	51.764	47.365	-5.054	55.818	51.119
5	10	61.368	55.030	-5.389	68.757	60.061
5	11	66.352	57.318	-6.061	72.413	65.150
5	12	54.205	48.751	-5.873	60.078	54.052

17R-4438

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOWS \* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN. PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
5 13	45.470	43.079	-4.829	50.299	45.254
5 14	55.590	49.447	0.597	54.993	49.477
5 15	54.094	48.730	-3.694	57.788	51.992
5 16	56.122	48.910	-2.802	58.924	53.014
5 17	55.998	52.211	-2.310	58.308	52.460
5 18	57.845	51.934	-5.979	63.824	57.422
5 19	59.058	52.434	-5.551	64.609	58.129
6 7	10.243	7.067	0.289	9.954	8.956
6 8	22.375	14.998	-3.985	26.360	23.716
6 9	17.393	12.527	-3.329	20.722	18.644
6 10	26.997	20.193	-3.665	30.662	27.586
6 11	31.981	22.693	-4.349	36.330	32.686
6 12	19.834	13.908	-4.143	23.977	21.572
6 13	11.099	8.274	-3.137	14.236	12.808
6 14	21.219	14.636	2.295	18.924	17.026
6 15	19.723	13.893	-1.970	21.693	19.517
6 16	21.751	14.134	-1.139	22.890	20.594
6 17	21.627	17.465	-0.677	22.304	20.067
6 18	23.474	17.092	-4.250	27.724	24.943
6 19	24.687	17.593	-3.823	28.510	25.650
7 8	12.132	8.014	-4.357	16.489	14.835
7 9	7.150	5.614	-3.772	10.922	9.827
7 10	16.754	13.172	-4.000	20.754	18.672
7 11	21.738	15.655	-4.667	26.405	23.757
7 12	9.591	6.914	-4.505	14.096	12.682
7 13	1.590	0.856	-3.809	5.399	4.857
7 14	10.976	7.584	1.991	8.985	8.084
7 15	9.480	6.980	-2.413	11.893	10.700
7 16	11.508	7.069	-1.430	12.938	11.640
7 17	11.384	10.739	-1.307	12.691	11.418
7 18	13.231	10.124	-4.638	17.869	16.076
7 19	14.444	10.586	-4.172	18.616	16.749
8 9	0.719	-2.534	-4.982	5.701	5.129
8 10	5.229	4.622	0.286	4.943	4.447
8 11	9.606	7.761	-0.430	10.036	9.029
8 12	-0.142	-1.106	-2.541	2.399	2.158
8 13	0.981	-6.857	-11.276	12.257	11.028
8 14	6.395	-0.477	-1.156	7.551	6.793
8 15	2.079	-1.169	-2.652	4.731	4.257
8 16	3.264	-0.624	-1.282	4.545	4.089
8 17	4.642	1.133	-0.748	5.390	4.849
8 18	2.115	1.099	-0.286	2.401	2.160
8 19	2.614	2.312	0.143	2.471	2.223
9 10	9.604	7.761	-0.431	10.035	9.028
9 11	14.588	10.294	-1.148	15.736	14.158
9 12	2.441	1.513	-0.946	3.387	3.047

LTR1144 38

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOW\* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN. PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
9 13	0.266	-4.327	-6.294	6.560	5.902
9 14	5.978	3.826	1.755	4.223	3.799
9 15	2.330	1.366	1.359	0.971	0.873
9 16	4.358	3.529	0.268	4.090	3.679
9 17	5.393	4.234	2.197	3.195	2.875
9 18	6.081	4.578	-0.934	7.015	6.312
9 19	7.294	5.146	-0.574	7.868	7.079
10 11	4.984	2.534	-0.718	5.702	5.130
10 12	-0.467	-6.296	-7.163	6.696	6.024
10 13	0.695	-12.086	-15.898	16.593	14.929
10 14	5.997	-5.594	-5.778	11.775	10.594
10 15	1.791	-6.396	-7.274	9.065	8.156
10 16	2.666	-5.246	-6.199	8.865	7.976
10 17	3.802	-3.542	-5.370	9.172	8.252
10 18	-0.412	-3.274	-3.523	3.111	2.799
10 19	-0.143	-2.310	-2.615	2.472	2.224
11 12	0.241	-8.820	-12.147	12.388	11.145
11 13	1.411	-14.618	-20.882	22.293	20.057
11 14	6.658	-8.071	-10.762	17.420	15.673
11 15	2.508	-8.929	-12.258	14.766	13.285
11 16	3.281	-8.630	-10.230	13.511	12.155
11 17	4.449	-6.005	-10.354	14.803	13.318
11 18	0.283	-5.785	-8.507	8.790	7.908
11 19	0.573	-5.147	-7.294	7.867	7.078
12 13	1.180	-5.808	-8.735	9.915	8.920
12 14	6.537	1.385	0.629	5.909	5.316
12 15	2.307	-0.111	-0.149	2.455	2.209
12 16	3.430	1.917	-0.200	3.631	3.267
12 17	5.295	1.793	1.728	3.567	3.209
12 18	3.640	3.220	-0.143	3.783	3.404
12 19	4.853	3.686	0.319	4.534	4.080
13 14	10.120	7.468	4.326	5.794	5.213
13 15	8.624	5.693	1.093	7.531	6.775
13 16	10.652	6.655	1.203	9.449	8.501
13 17	10.528	9.207	2.444	8.084	7.273
13 18	12.375	8.899	-1.194	13.569	12.208
13 19	13.588	9.471	-0.838	14.426	12.979
14 15	-0.389	-1.496	-4.619	4.229	3.805
14 16	0.532	-0.478	-3.458	3.990	3.590
14 17	3.587	0.408	-3.730	7.318	6.584
14 18	-6.681	2.592	2.255	9.273	8.343
14 19	-6.182	3.468	3.021	9.650	8.682
15 16	2.028	2.168	-1.096	3.264	2.937
15 17	4.027	1.904	0.838	3.190	2.870
15 18	3.751	3.213	-2.294	5.045	5.439
15 19	4.964	3.781	-1.934	6.898	6.206

LTRI 1 4 38

\* \* PRINCIPAL STRESSES, MAXIMUM STRESS INTENSITY AND ALTERNATING STRESS INTENSITY FOLLOWS \* \*

\* \* NOTE THAT ALL STRESSES IN THIS PROGRAM ARE IN KSI \* \*

\* NOTE THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CONCENTRATION FACTOR AND E RATIO \* \*

TRAN. PAIR	SIGMA 1	SIGMA 2	SIGMA 3	S INT	ALT S.I.
16 17	5.044	-0.124	-1.251	6.295	5.664
16 18	3.350	1.723	-3.503	6.853	6.166
16 19	3.686	2.936	-2.911	6.597	5.935
17 18	1.847	0.282	-4.228	6.075	5.465
17 19	3.060	1.089	-4.107	7.167	6.449
18 19	1.213	0.930	-0.002	1.215	1.093

LTR1144 38

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR	SPECIFIED NO. CYCLES	ALT. S.I.	N	U	TRAN.	CYCLES REMAINING	TRAN.	CYCLES REMAINING	TRAN. ELIMINATED
3 11	500	105.902	1150	.4348	3	0	11	998850	3
3 10	500	100.780							
3 19	500	98.831							
3 18	260	98.063							
3 0	500	97.113							
1 3	100	97.113							
2 3	500	97.113							
3 8	500	96.880							
3 12	500	94.757							
3 16	500	93.880							
3 17	260	92.905	1900	.1368	4	0	11	996950	4
3 15	500	92.632							
3 9	500	91.759							
4 11	260	90.438							
3 14	500	90.302							
3 13	500	85.857							
4 10	260	85.336							
4 19	260	83.396							
4 18	260	82.670							
3 7	260	82.247							
4 0	260	81.601	7000	.0371	5	0	11	989950	5
1 4	100	81.600							
2 4	260	81.600							
4 8	260	81.455							
4 12	260	79.317							
4 16	260	78.322							
4 17	260	77.628							
4 15	260	77.232							
4 9	260	76.359							
4 14	260	74.771							
3 6	260	73.291	TRANSIENTS #3, #4, & #5 ELIMINATED						
4 13	260	70.473							
4 7	260	66.689							
5 11	260	65.150							
5 10	260	60.061							
5 19	260	58.129							
4 6	260	57.752							
5 18	260	57.423							
5 0	260	56.305							
1 5	100	56.304							
2 5	260	56.304	TRANSIENTS #3, #4, & #5 ELIMINATED						
5 8	260	56.196							
5 12	260	54.052							
5 16	260	53.014							
5 17	260	52.460							
5 15	260	51.992							

LTR1144 38

B40

\*\* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\*\* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR	SPECIFIED NO. CYCLES	ALT. S.I.	N	U	TRAN.	CYCLES REMAINING	TRAN.	CYCLES REMAINING	TRAN. ELIMINATED
5 9	260	51.119	}						
5 14	260	49.477							
5 13	260	45.254							
3 5	260	41.699							
5 7	260	41.393							
5 6	260	32.906	}		6	0	11	689950	6
6 11	260	32.686							
6 10	260	27.586	TRANSIENT #6 ELIMINATED						
6 19	260	25.650	<u><math>\Sigma K = 0.6095</math></u>						
4 5	260	25.355	NO USAGE BELOW 26.0 KSI						
6 18	260	24.943							
6 0	260	23.853							
1 6	100	23.853							
2 6	260	23.853							
7 11	260	23.757							
6 8	260	23.716							
3 4	260	22.989							
6 12	260	21.572							
6 16	260	20.594							
6 17	260	20.067							
11 13	11000	20.057							
6 15	260	19.517							
7 10	260	18.672							
6 9	260	18.644							
6 14	260	17.026							
7 19	260	16.749							
7 18	260	16.076							
11 14	1500	15.673							
10 13	11000	14.929							
7 0	260	14.913							
1 7	100	14.913							
2 7	260	14.913							
7 8	260	14.835							
9 11	1000000	14.158							
11 17	260	13.318							
11 15	1500	13.285							
13 19	11000	12.979							
6 13	260	12.808							
7 12	260	12.682							
13 18	260	12.208							
11 16	1500	12.155							
7 16	260	11.640							
7 17	260	11.418							
13 0	11000	11.402							
1 13	100	11.402							
2 13	2600	11.402							

LTR 1144 38

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR SPECIFIED NO. CYCLES ALT. S.I.

11	12	11000	11.145
8	13	11000	11.028
7	15	260	10.700
10	14	1500	10.594
7	9	260	9.827
8	11	1000000	9.029
9	10	1000000	9.028
6	7	260	8.956
12	13	11000	8.920
2	11	2600	8.848
1	11	100	8.848
11	0	1000000	8.847
14	19	1500	8.682
13	16	1500	8.501
14	18	260	8.343
10	17	260	8.252
10	15	1500	8.156
7	14	260	8.084
10	16	1500	7.976
11	18	260	7.908
13	17	260	7.273
9	19	1000000	7.079
11	19	1000000	7.078
14	0	1500	6.829
1	14	100	6.829
2	14	1500	6.829
8	14	1500	6.793
13	15	1500	6.775
14	17	260	6.584
17	19	260	6.449
9	18	260	6.312
15	19	1500	6.206
16	18	260	6.166
10	12	11000	6.024
17	0	260	6.008
1	17	100	6.000
2	17	260	5.991
16	19	1500	5.935
9	13	11000	5.902
9	0	1000000	5.697
1	9	100	5.695
2	9	2600	5.693
16	17	260	5.664
17	18	260	5.465
15	18	260	5.439
12	14	1500	5.316

LTR 1144 38

B42

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR SPECIFIED NO. CYCLES ALT. S.I.

13	14	1500	5.213
10	11	1000000	5.130
8	9	1000000	5.129
10	0	1000000	5.096
1	10	100	5.076
2	10	2600	5.050
7	13	260	4.857
8	17	260	4.849
15	0	1500	4.826
1	15	100	4.824
2	15	1500	4.822
8	10	1000000	4.447
8	15	1500	4.257
8	16	1500	4.089
12	19	11000	4.080
14	15	1500	3.805
9	14	1500	3.799
9	16	1500	3.679
14	16	1500	3.590
18	0	260	3.451
1	18	100	3.437
2	18	260	3.419
12	18	260	3.404
16	0	1500	3.323
1	16	100	3.322
2	16	1500	3.321
12	16	1500	3.267
12	17	260	3.209
19	0	1000000	3.094
1	19	100	3.076
2	19	2600	3.053
9	12	11000	3.047
15	16	1500	2.937
9	17	260	2.875
15	17	260	2.870
12	0	11000	2.858
1	12	100	2.851
2	12	2600	2.843
10	18	260	2.799
10	19	1000000	2.224
8	19	1000000	2.223
12	15	1500	2.209
8	18	260	2.160
8	12	11000	2.158
8	0	1000000	1.748
1	8	100	1.745

LTR 1142  
38

B43

\* \* ALTERNATING STRESS INTENSITIES ORDERED FROM MAX TO MIN

\* \* NOTE THAT ZERO TRANSIENT NUMBER INDICATES NULL CONDITIONS

TRAN. PAIR	SPECIFIED NO. CYCLES	ALT. S.I.
2 8	2600	1.741
18 19	260	1.093
9 15	1500	0.873
2 0	2600	0.050
1 2	100	0.029
1 0	100	0.022

LTR 1 1 1 3 8

244

LTR1144 38

EMERGENCY CONDITIONS

PARAGRAPH NB-3224 DEFINES STRESS LIMITS FOR EMERGENCY CONDITIONS. SAFE SHUTDOWN EARTHQUAKE (SSE) IS THE EMERGENCY LOAD WHICH MUST BE CONSIDERED. THE LOAD CASE COMBINATION LISTED AS DBE IN COMBINATION WITH OPERATING TEMPERATURE AND PRESSURE, AS SHOWN ON PAGE 4-36 OF VOLUME 1 OF THE BTI REPORT, IS INCORRECTLY LISTED AS A FAULTED CONDITION LOAD. USING THE BTI CALCULATIONS, THE RESULTS OF WHICH ARE SHOWN ON PAGE 4-38 OF VOLUME 1 OF THE BTI REPORT, IT CAN BE SEEN THAT GENERAL PRIMARY MEMBRANE STRESSES ARE WITHIN THE  $1.2 S_m$  ALLOWABLE STRESS LIMIT. AS LISTED IN THE AFOREMENTIONED RESULTS, THE MAXIMUM VALUE OF 6,580 PSI FOR THE NOZZLE OCCURS NEAR PROFILE 1. THE ALLOWABLE LIMIT OF  $1.2 S_m$  ( $1.2 \times 16600 = 19920$  PSI) OR 19,920 PSI IS CONSIDERABLY HIGHER THAN THE STRESS LEVEL. AS LISTED IN THE BTI REPORT, THE EMERGENCY CONDITION STRESSES IN THE PRESSURIZER SHELL PORTION OF THE MODEL ARE SOMEWHAT HIGHER THAN THE SURGE NOZZLE STRESSES BUT ARE STILL WITHIN ALLOWABLE LIMITS.

FAULTED CONDITIONS

AS LISTED IN APPENDIX F, PAGE 483, OF THE ASME CODE, THE PRIMARY STRESS LIMITS FOR FAULTED CONDITIONS ARE  $2.4 S_m$  OR  $0.7 S_u$ , WHICHEVER IS LESS. LOSS OF COOLANT ACCIDENT (LOCA) PLUS SSE (DBE IN BTI REPORT) LOADS COMPRISE THE FAULTED CONDITION LOADS. GENERAL PRIMARY MEMBRANE STRESS VALUES FOR LOCA + SSE + PRESSURE LOADS ARE SHOWN IN TABLE 4.1.2-6, PAGE 4-6, VOLUME 1, OF THE BTI REPORT. USING THESE VALUES, IT CAN BE SEEN THAT FAULTED CONDITION STRESS INTENSITIES ARE WITHIN ALLOWABLE LIMITS AS SHOWN BELOW:

MAX. GEN. PRIMARY MEMBRANE STRESS  
IN NOZZLE (PROFILE 1) = 8,540 PSI

$$2.4 S_M = 2.4 (16,600) = 39,840 \text{ PSI}$$

$$.7 S_H = .7 (75,000) = 52,500 \text{ PSI}$$

⇒ 39,840 PSI IS LIMIT

$$8,540 < 39,840$$

⇒ FAULTED CONDITION STRESS REQUIREMENTS ARE SATISFIED.

APPENDIX C

SAAS III SPRAY NOZZLE OUTPUT

\*\*\*\*\*  
TIME REMAINING AT BEGINNING OF RUN IS 114 SECONDS.  
\*\*\*\*\*

\*\*\*\*\*  
TIME REMAINING AFTER TRANSFER OF INPUT DATA TO UNIT 9 IS 110 SECONDS.  
\*\*\*\*\*

C-1

LR1144 38

SURGE NOZZLE STEP CHANGE

START PARAMETER----- 1

STCP PARAMETER----- 0

DEFORMED GRID PLCT. IF 1, PLCT.----- 0

PLCT SIZE. 1=SMALL,2=LARGE,101 OR 102=SMALL  
OR LARGE WITH SPECIFIED DIMENSIONS.----- 2

NUMBER OF APPROXIMATIONS----- 0

MESH PARAMETER. IF 1, GENERATE MESH----- 0

NUMBER OF TEMPERATURE CARDS----- -3

NUMBER OF NODAL POINTS----- 397

NUMBER OF ELEMENTS----- 349

NUMBER OF INTERNAL PRESSURES----- 0

NUMBER OF MATERIALS----- 1

NUMBER OF EXTERNAL PRESSURES----- 80

NUMBER OF SHEAR CARDS----- 0

REFERENCE TEMPERATURE----- 0.7000E 02

2-2 PLCTSHRINK FACTOR. IF 1, NO SHRINK----- 1.000

IF NOT 0, OUTPUT GENERATED FOR TAP OR COUPLE-- 0

IF 1, STRESS OUTPUT STORED ON TAPE----- 0

TAP OR COUPLE OUTPUT UNIT. 7=DECK,8=TAPE----- 0

MAXIMUM # OF MATERIAL PROPERTY CARDS ALLOWED-- 7

CONNECTIVITY. MAXI IF IMESH=1, OTHERWISE,  
MAX. NODE DIFFERENCE.----- 18

STORAGE FOR MAXJ IF IMESH=1. OTHERWISE,1----- 1

INPUT UNIT FOR NODE AND ELEMENT DATA----- 9

CONCUR PLOTS. IF 1, CONTOURS ARE REQUESTED-- 0

NUMBER OF BLOCK ASSIGNMENT CARDS----- 0

PLOT UNIT DEVICE. 1=SMALL CALCOMP PLOTTER OR  
MICROFILM. 2=LARGE CALCOMP PLOTTER OR  
MICROFI ----- 1

LTR1144 38

\*\*\*\*\*

BLANK COMMON IS NOW 17000  
UNUSED STORAGE= 11000

\*\*\*\*\*  
TIME REMAINING, 110 SECONDS  
\*\*\*\*\*

\*\*\* TRANSIENT TEMPERATURES WILL BE INPUT ON UNIT 11.

NUMBER OF TENSION-COMPRESSION APPROXIMATIONS---- 0

MESH GENERATION WOULD OCCUR HERE IF REQUESTED.

\*\*\*\*\*  
TIME REMAINING, 110 SECONDS  
\*\*\*\*\*

C-3

LTR 1144 38

NODAL POINT	TYPE	R-ORDINATE	Z-ORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
1	0.0	0.407	9.120	0.0	0.0	0.0	0.0
2	0.0	0.457	9.120	0.0	0.0	0.0	0.0
3	0.0	0.507	9.120	0.0	0.0	0.0	0.0
4	0.0	0.558	9.120	0.0	0.0	0.0	0.0
5	0.0	0.608	9.120	0.0	0.0	0.0	0.0
6	0.0	0.658	9.120	0.0	0.0	0.0	0.0
7	0.0	0.407	8.920	0.0	0.0	0.0	0.0
8	0.0	0.457	8.920	0.0	0.0	0.0	0.0
9	0.0	0.507	8.920	0.0	0.0	0.0	0.0
10	0.0	0.558	8.920	0.0	0.0	0.0	0.0
11	0.0	0.608	8.920	0.0	0.0	0.0	0.0
12	0.0	0.658	8.920	0.0	0.0	0.0	0.0
13	0.0	0.407	8.720	0.0	0.0	0.0	0.0
14	0.0	0.457	8.720	0.0	0.0	0.0	0.0
15	0.0	0.507	8.720	0.0	0.0	0.0	0.0
16	0.0	0.558	8.720	0.0	0.0	0.0	0.0
17	0.0	0.608	8.720	0.0	0.0	0.0	0.0
18	0.0	0.658	8.720	0.0	0.0	0.0	0.0
19	0.0	0.407	8.520	0.0	0.0	0.0	0.0
20	0.0	0.457	8.520	0.0	0.0	0.0	0.0
21	0.0	0.507	8.520	0.0	0.0	0.0	0.0
22	0.0	0.558	8.520	0.0	0.0	0.0	0.0
23	0.0	0.608	8.520	0.0	0.0	0.0	0.0
24	0.0	0.658	8.520	0.0	0.0	0.0	0.0
25	0.0	0.407	8.320	0.0	0.0	0.0	0.0
26	0.0	0.457	8.320	0.0	0.0	0.0	0.0
27	0.0	0.507	8.320	0.0	0.0	0.0	0.0
28	0.0	0.558	8.320	0.0	0.0	0.0	0.0
29	0.0	0.608	8.320	0.0	0.0	0.0	0.0
30	0.0	0.658	8.320	0.0	0.0	0.0	0.0
31	0.0	0.407	8.120	0.0	0.0	0.0	0.0
32	0.0	0.457	8.120	0.0	0.0	0.0	0.0
33	0.0	0.507	8.120	0.0	0.0	0.0	0.0
34	0.0	0.558	8.120	0.0	0.0	0.0	0.0
35	0.0	0.608	8.120	0.0	0.0	0.0	0.0
36	0.0	0.658	8.120	0.0	0.0	0.0	0.0
37	0.0	0.407	7.920	0.0	0.0	0.0	0.0
38	0.0	0.457	7.920	0.0	0.0	0.0	0.0
39	0.0	0.507	7.920	0.0	0.0	0.0	0.0
40	0.0	0.558	7.920	0.0	0.0	0.0	0.0

P-1

LTR : 4 3 1

NODAL POINT	TYPE	R-ORDINATE	Z-ORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
41	0.C	0.608	7.920	C.C	0.0	0.0	0.0
42	0.0	0.658	7.920	C.C	0.0	0.0	0.0
43	C.C	0.407	7.720	0.0	C.C	C.C	C.C
44	0.C	0.457	7.720	C.C	0.0	0.0	0.0
45	0.C	0.507	7.720	C.C	0.0	0.0	0.0
46	0.C	0.558	7.720	C.C	0.0	0.0	0.0
47	0.C	0.608	7.720	C.C	0.0	0.0	0.0
48	0.0	0.658	7.720	C.C	0.0	0.0	0.0
49	0.0	0.407	7.520	C.C	0.0	C.C	C.C
50	0.C	0.457	7.520	0.0	0.0	0.0	0.0
51	0.C	0.507	7.520	C.C	0.0	0.0	0.0
52	0.0	0.558	7.520	0.0	C.C	0.0	0.0
53	C.C	0.608	7.520	0.0	0.0	C.C	C.C
54	0.0	0.658	7.520	C.C	0.0	0.0	0.0
55	0.C	0.407	7.320	C.C	0.0	0.0	0.0
56	0.C	0.457	7.320	0.0	0.0	0.0	0.0
57	0.C	0.507	7.320	C.C	0.0	0.0	C.C
58	0.0	0.558	7.320	0.0	0.0	0.0	0.0
59	0.C	0.608	7.320	C.C	0.0	0.0	0.0
60	C.C	0.658	7.320	0.0	0.0	0.0	C.C
61	0.0	0.407	7.120	0.0	0.0	0.0	0.0
62	0.0	0.457	7.120	0.0	0.0	0.0	0.0
63	0.C	0.507	7.120	C.C	0.0	C.C	C.C
64	0.0	0.558	7.120	C.C	0.0	0.0	0.0
65	0.0	0.608	7.120	C.C	0.0	0.0	0.0
66	0.0	0.658	7.120	0.0	0.0	0.0	0.0
67	0.C	0.407	6.920	0.0	0.0	0.0	C.C
68	0.0	0.457	6.920	C.C	0.0	0.0	0.0
69	0.C	0.507	6.920	C.C	0.0	C.C	C.C
70	C.C	0.558	6.920	0.0	0.0	0.0	C.C
71	0.0	0.608	6.920	C.C	0.0	0.0	0.0
72	0.0	0.658	6.920	0.0	C.C	0.0	0.0
73	0.C	0.744	6.970	0.0	0.0	0.0	C.C
74	0.0	0.407	6.720	C.C	0.0	0.0	0.0
75	0.0	0.457	6.720	C.C	0.0	0.0	0.0
76	0.0	0.507	6.720	0.0	0.0	0.0	C.C
77	0.0	0.558	6.720	C.C	0.0	0.0	C.C
78	0.0	0.608	6.720	C.C	0.0	0.0	0.0
79	0.0	0.658	6.720	0.0	0.0	0.0	C.C
80	0.0	0.739	6.767	0.0	0.0	0.0	C.C

P

NODAL POINT	TYPE	R-COORDINATE	Z-COORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
81	0.0	0.831	6.820	0.0	0.0	0.0	0.0
82	0.0	0.407	6.520	0.0	0.0	0.0	0.0
83	0.0	0.457	6.520	0.0	0.0	0.0	0.0
84	0.0	0.507	6.520	0.0	0.0	0.0	0.0
85	0.0	0.558	6.520	0.0	0.0	0.0	0.0
86	0.0	0.608	6.520	0.0	0.0	0.0	0.0
87	0.0	0.658	6.520	0.0	0.0	0.0	0.0
88	0.0	0.733	6.564	0.0	0.0	0.0	0.0
89	0.0	0.825	6.617	0.0	0.0	0.0	0.0
90	0.0	0.917	6.670	0.0	0.0	0.0	0.0
91	0.0	0.407	6.320	0.0	0.0	0.0	0.0
92	0.0	0.457	6.320	0.0	0.0	0.0	0.0
93	0.0	0.507	6.320	0.0	0.0	0.0	0.0
94	0.0	0.558	6.320	0.0	0.0	0.0	0.0
95	0.0	0.608	6.320	0.0	0.0	0.0	0.0
96	0.0	0.658	6.320	0.0	0.0	0.0	0.0
97	0.0	0.727	6.360	0.0	0.0	0.0	0.0
98	0.0	0.819	6.413	0.0	0.0	0.0	0.0
99	0.0	0.912	6.467	0.0	0.0	0.0	0.0
100	0.0	1.004	6.520	0.0	0.0	0.0	0.0
101	0.0	0.407	6.120	0.0	0.0	0.0	0.0
102	0.0	0.457	6.120	0.0	0.0	0.0	0.0
103	0.0	0.507	6.120	0.0	0.0	0.0	0.0
104	0.0	0.558	6.120	0.0	0.0	0.0	0.0
105	0.0	0.608	6.120	0.0	0.0	0.0	0.0
106	0.0	0.658	6.120	0.0	0.0	0.0	0.0
107	0.0	0.722	6.157	0.0	0.0	0.0	0.0
108	0.0	0.814	6.210	0.0	0.0	0.0	0.0
109	0.0	0.906	6.263	0.0	0.0	0.0	0.0
110	0.0	0.998	6.317	0.0	0.0	0.0	0.0
111	0.0	1.090	6.370	0.0	0.0	0.0	0.0
112	0.0	0.407	5.920	0.0	0.0	0.0	0.0
113	0.0	0.457	5.920	0.0	0.0	0.0	0.0
114	0.0	0.507	5.920	0.0	0.0	0.0	0.0
115	0.0	0.558	5.920	0.0	0.0	0.0	0.0
116	0.0	0.608	5.920	0.0	0.0	0.0	0.0
117	0.0	0.658	5.920	0.0	0.0	0.0	0.0
118	0.0	0.716	5.954	0.0	0.0	0.0	0.0
119	0.0	0.808	6.007	0.0	0.0	0.0	0.0
120	0.0	0.900	6.060	0.0	0.0	0.0	0.0

C-6

NODAL POINT	TYPE	R-COORDINATE	Z-COORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
121	0.0	0.993	6.113	0.0	0.0	0.0	0.0
122	0.0	1.085	6.167	0.0	0.0	0.0	0.0
123	0.0	1.177	6.220	0.0	0.0	0.0	0.0
124	0.0	0.407	5.720	0.0	0.0	0.0	0.0
125	0.0	0.457	5.720	0.0	0.0	0.0	0.0
126	0.0	0.507	5.720	0.0	0.0	0.0	0.0
127	0.0	0.558	5.720	0.0	0.0	0.0	0.0
128	0.0	0.608	5.720	0.0	0.0	0.0	0.0
129	0.0	0.658	5.720	0.0	0.0	0.0	0.0
130	0.0	0.744	5.770	0.0	0.0	0.0	0.0
131	0.0	0.802	5.804	0.0	0.0	0.0	0.0
132	0.0	0.895	5.857	0.0	0.0	0.0	0.0
133	0.0	0.987	5.910	0.0	0.0	0.0	0.0
134	0.0	1.079	5.963	0.0	0.0	0.0	0.0
135	0.0	1.171	6.017	0.0	0.0	0.0	0.0
136	0.0	1.264	6.070	0.0	0.0	0.0	0.0
137	0.0	0.407	5.520	0.0	0.0	0.0	0.0
138	0.0	0.457	5.520	0.0	0.0	0.0	0.0
139	0.0	0.507	5.520	0.0	0.0	0.0	0.0
140	0.0	0.558	5.520	0.0	0.0	0.0	0.0
141	0.0	0.608	5.520	0.0	0.0	0.0	0.0
142	0.0	0.658	5.520	0.0	0.0	0.0	0.0
143	0.0	0.744	5.570	0.0	0.0	0.0	0.0
144	0.0	0.831	5.620	0.0	0.0	0.0	0.0
145	0.0	0.889	5.654	0.0	0.0	0.0	0.0
146	0.0	0.981	5.707	0.0	0.0	0.0	0.0
147	0.0	1.074	5.760	0.0	0.0	0.0	0.0
148	0.0	1.166	5.813	0.0	0.0	0.0	0.0
149	0.0	1.258	5.867	0.0	0.0	0.0	0.0
150	0.0	1.350	5.920	0.0	0.0	0.0	0.0
151	0.0	0.407	5.320	0.0	0.0	0.0	0.0
152	0.0	0.457	5.320	0.0	0.0	0.0	0.0
153	0.0	0.507	5.320	0.0	0.0	0.0	0.0
154	0.0	0.558	5.320	0.0	0.0	0.0	0.0
155	0.0	0.608	5.320	0.0	0.0	0.0	0.0
156	0.0	0.658	5.320	0.0	0.0	0.0	0.0
157	0.0	0.744	5.370	0.0	0.0	0.0	0.0
158	0.0	0.831	5.420	0.0	0.0	0.0	0.0
159	0.0	0.917	5.470	0.0	0.0	0.0	0.0
160	0.0	0.976	5.504	0.0	0.0	0.0	0.0

C-7

NODAL POINT	TYPE	R-COORDINATE	Z-COORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
161	0.0	1.068	5.557	0.0	0.0	0.0	0.0
162	0.0	1.160	5.610	0.0	0.0	0.0	0.0
163	0.0	1.252	5.663	0.0	0.0	0.0	0.0
164	0.0	1.345	5.717	0.0	0.0	0.0	0.0
165	0.0	1.437	5.770	0.0	0.0	0.0	0.0
166	0.0	0.407	5.120	0.0	0.0	0.0	0.0
167	0.0	0.457	5.120	0.0	0.0	0.0	0.0
168	0.0	0.507	5.120	0.0	0.0	0.0	0.0
169	0.0	0.558	5.120	0.0	0.0	0.0	0.0
170	0.0	0.608	5.120	0.0	0.0	0.0	0.0
171	0.0	0.658	5.120	0.0	0.0	0.0	0.0
172	0.0	0.712	5.225	0.0	0.0	0.0	0.0
173	0.0	0.768	5.329	0.0	0.0	0.0	0.0
174	0.0	0.877	5.340	0.0	0.0	0.0	0.0
175	0.0	1.004	5.320	0.0	0.0	0.0	0.0
176	0.0	1.062	5.354	0.0	0.0	0.0	0.0
177	0.0	1.155	5.407	0.0	0.0	0.0	0.0
178	0.0	1.247	5.460	0.0	0.0	0.0	0.0
179	0.0	1.339	5.513	0.0	0.0	0.0	0.0
180	0.0	1.431	5.567	0.0	0.0	0.0	0.0
181	0.0	1.524	5.620	0.0	0.0	0.0	0.0
182	0.0	0.407	4.920	0.0	0.0	0.0	0.0
183	0.0	0.457	4.920	0.0	0.0	0.0	0.0
184	0.0	0.507	4.920	0.0	0.0	0.0	0.0
185	0.0	0.558	4.920	0.0	0.0	0.0	0.0
186	0.0	0.608	4.920	0.0	0.0	0.0	0.0
187	0.0	0.658	4.920	0.0	0.0	0.0	0.0
188	0.0	1.149	5.204	0.0	0.0	0.0	0.0
189	0.0	1.241	5.263	0.0	0.0	0.0	0.0
190	0.0	1.333	5.322	0.0	0.0	0.0	0.0
191	0.0	1.426	5.381	0.0	0.0	0.0	0.0
192	0.0	1.518	5.441	0.0	0.0	0.0	0.0
193	0.0	1.610	5.500	0.0	0.0	0.0	0.0
194	0.0	0.407	4.720	0.0	0.0	0.0	0.0
195	0.0	0.457	4.720	0.0	0.0	0.0	0.0
196	0.0	0.507	4.720	0.0	0.0	0.0	0.0
197	0.0	0.558	4.720	0.0	0.0	0.0	0.0
198	0.0	0.608	4.720	0.0	0.0	0.0	0.0
199	0.0	0.658	4.720	0.0	0.0	0.0	0.0
200	0.0	1.236	5.054	0.0	0.0	0.0	0.0

2-2

NODAL POINT	TYPE	R-ORDINATE	Z-ORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
201	C.C	1.328	5.107	0.0	0.0	0.0	0.0
202	0.C	1.420	5.160	C.C	0.0	0.0	C.C
203	0.0	1.512	5.213	C.C	0.0	0.0	0.0
204	C.0	1.604	5.267	0.C	C.0	0.0	C.0
205	0.0	1.697	5.320	C.0	C.0	0.0	0.0
206	0.0	0.407	4.520	C.0	0.0	0.0	C.0
207	0.0	0.457	4.520	C.0	C.0	0.0	0.0
208	0.C	0.507	4.520	0.0	0.0	0.0	C.0
209	0.0	0.558	4.520	C.0	0.0	0.0	0.0
210	0.0	0.608	4.520	C.C	0.0	0.0	0.0
211	0.C	0.658	4.520	0.C	0.0	0.0	C.0
212	0.C	1.322	4.904	C.0	0.0	0.0	C.0
213	0.C	1.414	4.957	C.C	0.0	0.0	0.0
214	0.0	1.507	5.010	C.C	C.0	0.0	C.0
215	0.C	1.599	5.063	0.0	0.0	0.0	C.C
216	0.0	1.691	5.117	C.0	0.0	0.0	0.0
217	0.0	1.783	5.170	0.C	C.0	0.0	0.0
218	0.0	0.407	4.320	0.0	C.0	0.0	0.C
219	0.C	0.457	4.320	C.C	0.0	0.0	C.0
220	0.0	0.507	4.320	C.C	0.0	0.0	0.0
221	0.0	0.558	4.320	0.0	0.0	C.0	0.0
222	0.0	0.608	4.320	0.0	0.0	0.0	C.C
223	0.0	0.658	4.320	C.C	0.0	0.0	C.0
224	0.0	1.495	4.604	0.0	C.0	0.0	0.0
225	0.C	1.588	4.657	0.0	C.0	C.0	C.C
226	0.0	1.680	4.710	0.0	0.0	0.0	0.0
227	0.0	1.772	4.763	C.0	C.0	0.0	0.0
228	0.0	1.864	4.817	0.0	0.0	C.0	C.C
229	0.0	1.956	4.870	C.C	0.0	0.0	C.0
230	0.0	0.407	4.120	C.C	0.0	0.0	0.0
231	0.0	0.457	4.120	0.0	0.0	0.0	0.0
232	0.C	0.507	4.120	0.0	0.0	0.0	C.C
233	0.0	0.558	4.120	C.C	0.0	0.0	0.0
234	0.0	0.608	4.120	0.C	C.0	C.0	C.0
235	0.C	0.658	4.120	0.0	0.0	0.0	C.C
236	0.0	1.668	4.304	C.C	0.0	0.0	C.0
237	0.0	1.761	4.357	C.0	C.0	0.0	0.0
238	0.0	1.853	4.410	0.0	0.0	0.0	C.0
239	0.0	1.945	4.463	C.0	0.0	0.0	C.0
240	0.0	2.038	4.517	C.C	0.0	0.0	0.0

C-9

LTR1144 38

NODAL POINT	TYPE	R-ORDINATE	Z-ORDINATE	R LCAD OR DISPLACEMENT	Z LCAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
241	J.C	2.130	4.570	0.C	0.0	0.0	0.C
242	J.C	0.407	3.920	0.C	0.0	0.C	0.C
243	J.C	0.457	3.920	0.0	0.0	0.C	0.C
244	J.C	0.507	3.920	0.0	0.0	0.0	0.C
245	J.O	0.558	3.920	0.0	0.0	0.0	0.C
246	D.C	0.608	3.920	0.0	0.0	0.0	0.C
247	D.C	0.658	3.920	0.0	0.0	0.0	0.C
248	D.O	1.718	4.219	C.C	0.0	0.0	0.0
249	O.O	1.824	4.248	C.C	0.0	0.0	0.0
250	O.C	1.931	4.276	C.C	0.0	0.C	0.C
251	O.C	2.037	4.305	C.C	0.0	0.0	0.C
252	O.O	2.144	4.333	0.0	0.C	0.0	0.0
253	C.C	2.250	4.362	0.0	0.0	0.0	0.C
254	O.O	0.407	3.720	0.0	0.0	0.0	0.C
255	O.O	0.457	3.720	0.0	0.0	0.0	0.0
256	C.O	0.507	3.720	0.0	0.0	0.C	0.C
257	O.O	0.558	3.720	0.0	0.0	0.0	0.C
258	O.O	0.608	3.720	C.C	0.0	0.0	0.C
259	O.C	0.658	3.720	0.0	0.0	0.0	0.C
260	O.C	1.718	4.000	0.0	0.0	0.0	0.C
261	O.O	1.824	4.000	0.0	0.0	0.0	0.0
262	O.C	1.931	4.000	0.0	0.0	0.0	0.0
263	C.C	2.037	4.000	0.0	0.0	0.0	0.C
264	O.O	2.144	4.000	C.C	0.0	0.0	0.0
265	O.O	2.250	4.000	0.0	0.0	0.0	0.0
266	O.C	0.407	3.520	0.0	0.0	0.0	0.C
267	O.O	0.457	3.520	0.0	0.0	0.0	0.0
268	O.O	0.507	3.520	C.C	0.0	0.0	0.0
269	O.C	0.558	3.520	0.0	0.0	0.C	0.0
270	O.C	0.608	3.520	0.0	0.0	0.0	0.C
271	O.O	0.658	3.520	C.C	0.0	0.0	0.0
272	O.C	1.718	3.500	0.0	0.0	0.0	0.0
273	O.C	1.824	3.500	0.0	0.0	0.0	0.0
274	O.O	1.931	3.500	0.0	0.0	0.0	0.0
275	O.O	2.037	3.500	0.0	0.0	0.0	0.0
276	O.C	2.144	3.500	0.0	0.0	0.0	0.C
277	O.O	2.250	3.500	0.0	0.0	0.0	0.C
278	O.O	0.407	3.320	0.C	0.0	0.0	0.0
279	O.C	0.457	3.320	0.0	0.0	0.0	0.0
280	O.O	0.507	3.320	0.0	0.0	0.0	0.C

C-10

LTR1144 38

NODAL POINT	TYPE	R-COORDINATE	Z-COORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
281	0.C	0.558	3.320	0.0	0.0	0.0	C.C
282	0.0	0.608	3.320	C.C	0.0	0.0	C.0
283	0.0	0.658	3.320	0.0	C.0	0.0	0.0
284	0.C	1.718	3.000	0.0	0.0	0.0	C.C
285	0.0	1.824	3.000	C.C	0.0	0.0	C.0
286	0.0	1.931	3.000	C.C	0.0	0.0	0.0
287	0.0	2.037	3.000	0.0	C.0	0.0	C.0
288	0.C	2.144	3.000	C.C	0.0	0.0	C.C
289	0.0	2.250	3.000	C.C	0.0	0.0	0.0
290	0.0	0.407	3.120	C.C	C.0	C.0	C.0
291	0.C	0.457	3.120	0.0	0.0	0.0	C.C
292	0.C	0.507	3.120	C.C	C.0	0.0	C.0
293	0.0	0.558	3.120	C.C	C.0	0.0	0.0
294	0.C	0.608	3.120	0.0	0.0	C.C	C.C
295	0.0	0.658	3.120	0.0	0.0	0.0	0.0
296	0.0	1.718	2.500	C.C	C.0	0.0	0.0
297	0.C	1.824	2.500	0.0	0.0	C.C	C.0
298	0.C	1.931	2.500	C.C	0.0	0.0	C.C
299	0.0	2.037	2.500	C.C	0.0	0.0	0.0
300	0.0	2.144	2.500	0.0	C.0	0.0	0.0
301	0.C	2.250	2.500	0.0	0.0	0.0	C.0
302	0.0	0.407	2.920	C.C	0.0	0.0	0.0
303	0.0	0.457	2.920	C.0	C.0	0.0	0.0
304	0.C	0.507	2.920	0.0	0.0	0.0	C.C
305	0.0	0.558	2.920	C.C	C.0	0.0	0.0
306	0.0	0.608	2.920	C.C	C.0	0.0	0.0
307	0.0	0.658	2.920	0.0	0.0	C.C	0.0
308	0.C	1.718	2.000	C.C	0.0	0.0	C.C
309	0.0	1.824	2.000	C.C	0.0	0.0	0.0
310	0.C	1.931	2.000	0.0	C.0	0.0	0.0
311	0.C	2.037	2.000	0.0	0.0	0.0	C.0
312	0.C	2.144	2.000	0.0	0.0	0.0	C.0
313	0.0	2.250	2.000	0.0	C.0	0.0	0.0
314	0.C	0.407	2.720	0.0	0.0	C.0	C.0
315	0.0	0.457	2.720	0.0	0.0	0.0	C.0
316	0.0	0.507	2.720	0.C	C.0	0.0	0.0
317	0.0	0.558	2.720	0.0	0.0	0.0	0.0
318	0.C	0.608	2.720	0.0	0.0	0.0	C.C
319	0.0	0.658	2.720	0.0	0.0	0.0	0.0
320	0.0	1.718	1.500	0.0	0.0	0.0	0.0

C-11

LTR1144 38

NODAL POINT	TYPE	R-ORDINATE	Z-ORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
321	0.0	1.824	1.500	0.0	0.0	0.0	0.0
322	0.0	1.931	1.500	0.0	0.0	0.0	0.0
323	0.0	2.037	1.500	0.0	0.0	0.0	0.0
324	0.0	2.144	1.500	0.0	0.0	0.0	0.0
325	0.0	2.250	1.500	0.0	0.0	0.0	0.0
326	0.0	0.407	2.520	0.0	0.0	0.0	0.0
327	0.0	0.457	2.520	0.0	0.0	0.0	0.0
328	0.0	0.507	2.520	0.0	0.0	0.0	0.0
329	0.0	0.558	2.520	0.0	0.0	0.0	0.0
330	0.0	0.608	2.520	0.0	0.0	0.0	0.0
331	0.0	0.658	2.520	0.0	0.0	0.0	0.0
332	0.0	1.718	1.000	0.0	0.0	0.0	0.0
333	0.0	1.824	1.000	0.0	0.0	0.0	0.0
334	0.0	1.931	1.000	0.0	0.0	0.0	0.0
335	0.0	2.037	1.000	0.0	0.0	0.0	0.0
336	0.0	2.144	1.000	0.0	0.0	0.0	0.0
337	0.0	2.250	1.000	0.0	0.0	0.0	0.0
338	0.0	0.407	2.320	0.0	0.0	0.0	0.0
339	0.0	0.457	2.320	0.0	0.0	0.0	0.0
340	0.0	0.507	2.320	0.0	0.0	0.0	0.0
341	0.0	0.558	2.320	0.0	0.0	0.0	0.0
342	0.0	0.608	2.320	0.0	0.0	0.0	0.0
343	0.0	0.658	2.320	0.0	0.0	0.0	0.0
344	0.0	1.718	0.500	0.0	0.0	0.0	0.0
345	0.0	1.824	0.500	0.0	0.0	0.0	0.0
346	0.0	1.931	0.500	0.0	0.0	0.0	0.0
347	0.0	2.037	0.500	0.0	0.0	0.0	0.0
348	0.0	2.144	0.500	0.0	0.0	0.0	0.0
349	0.0	2.250	0.500	0.0	0.0	0.0	0.0
350	0.0	0.407	2.120	0.0	0.0	0.0	0.0
351	0.0	0.457	2.120	0.0	0.0	0.0	0.0
352	0.0	0.507	2.120	0.0	0.0	0.0	0.0
353	0.0	0.558	2.120	0.0	0.0	0.0	0.0
354	0.0	0.608	2.120	0.0	0.0	0.0	0.0
355	0.0	0.658	2.120	0.0	0.0	0.0	0.0
356	2.00	1.718	0.0	0.0	0.0	0.0	0.0
357	2.00	1.824	0.0	0.0	0.0	0.0	0.0
358	2.00	1.931	0.0	0.0	0.0	0.0	0.0
359	2.00	2.037	0.0	0.0	0.0	0.0	0.0
360	2.00	2.144	0.0	0.0	0.0	0.0	0.0

C-12

LRI 144 38

NODAL POINT	TYPE	R-COORDINATE	Z-COORDINATE	R LOAD OR DISPLACEMENT	Z LOAD OR DISPLACEMENT	TEMPERATURE	PRESSURE
361	2.00	2.250	C.C	C.0	0.0	0.0	C.0
362	0.0	0.407	1.920	C.C	C.0	0.0	0.0
363	0.0	0.457	1.920	0.0	C.0	0.0	C.0
364	C.0	0.507	1.920	C.C	0.0	C.C	C.C
365	0.0	0.558	1.920	C.C	C.0	0.0	0.0
366	C.0	0.608	1.920	0.0	C.0	C.C	C.0
367	0.0	0.658	1.920	C.0	0.0	C.0	C.C
368	0.0	0.407	1.720	C.C	0.0	0.0	0.0
369	0.0	0.457	1.720	C.C	C.0	0.0	0.0
370	0.0	0.507	1.720	C.0	0.0	C.C	C.C
371	0.0	0.558	1.720	C.C	0.0	0.0	C.0
372	0.0	0.608	1.720	C.C	C.0	0.0	C.0
373	0.0	0.658	1.720	C.0	0.0	C.C	C.0
374	C.C	0.407	1.520	C.C	0.0	C.0	C.C
375	0.0	0.457	1.520	C.C	C.0	0.0	0.0
376	0.0	0.507	1.520	0.0	C.0	C.C	C.0
377	0.0	0.558	1.520	0.0	0.0	C.C	C.C
378	0.0	0.608	1.520	C.C	0.0	0.0	C.0
379	0.0	0.658	1.520	0.0	C.0	0.0	0.0
380	0.0	0.407	1.320	0.0	C.0	C.0	C.C
381	0.0	0.457	1.320	C.0	0.0	0.0	0.0
382	0.0	0.507	1.320	C.C	C.0	0.0	0.0
383	0.0	0.558	1.320	0.0	0.0	C.C	C.0
384	0.0	0.608	1.320	C.0	0.0	0.0	C.0
385	0.0	0.658	1.320	C.0	0.0	0.0	C.0
386	C.0	0.407	1.120	0.0	C.0	0.0	C.0
387	0.0	0.457	1.120	0.0	0.0	0.0	C.C
388	0.0	0.507	1.120	C.0	0.0	0.0	C.C
389	0.0	0.558	1.120	C.0	C.0	0.0	0.0
390	C.0	0.608	1.120	0.0	0.0	C.0	C.C
391	0.0	0.658	1.120	C.C	0.0	0.0	C.0
392	0.0	0.407	0.920	C.C	C.0	0.0	0.0
393	0.0	0.457	0.920	0.0	0.0	0.0	C.0
394	0.0	0.507	0.920	0.0	0.0	0.0	C.C
395	0.0	0.558	0.920	C.0	0.0	0.0	0.0
396	0.0	0.608	0.920	0.0	0.0	C.C	C.0
397	0.0	0.658	0.920	0.0	0.0	0.0	C.0

CTIME= 0.00780 NUMBER OF NODES= 397

TIME= 0.00833

TEMPERATURES  
\*\*\*\*\*

200.7595	201.4814	202.0468	202.4458	202.6740	202.7339	200.7570	201.4758	202.0388
202.4364	202.6639	202.7236	200.7570	201.4762	202.0401	202.4380	202.6659	202.7258
200.7573	201.4772	202.0412	202.4393	202.6672	202.7272	200.7570	201.4764	202.0401
202.4377	202.6654	202.7254	200.7564	201.4750	202.0379	202.4352	202.6625	202.7224
200.7567	201.4766	202.0409	202.4391	202.6671	202.7270	200.7552	201.4691	202.0288
202.4242	202.6512	202.7124	200.7704	201.5075	202.0837	202.4877	202.7143	202.7653
200.6766	201.3585	201.9764	202.4040	202.6794	202.8053	201.1857	201.2482	201.2115
201.0583	200.7816	200.3832	208.6357	216.5027	223.1301	228.5427	232.7599	235.8053
225.9036	219.7702	238.8772	255.3183	269.3054	280.9873	290.4766	286.5696	272.2559
230.1555	259.5002	284.9939	307.1052	326.1677	342.4253	350.4890	345.9182	329.8550
237.2275	273.1709	304.5510	332.0469	356.1406	377.1851	395.1804	405.8489	405.0625
390.5801	241.3029	280.9524	315.6636	346.2319	373.2356	397.1072	420.1826	442.8730
455.0376	455.1113	443.8149	243.3428	284.8950	321.3225	353.5007	382.0610	407.4688
432.1370	462.7385	483.6599	494.7505	496.1960	487.3569	244.1418	285.9448	322.6089

Q-13

LTR1144

38

569.3319	511.9000	508.0340	401.7740	321.1901	315.0012	717.7251	717.0000	717.0000
528.8535	566.0798	614.7461	633.1309	619.3154	611.0410	601.8518	597.7910	594.2974
588.0869	261.5586	319.7092	370.8401	416.4050	457.4485	494.7566	650.4353	643.0105
636.6958	629.4246	622.2456	613.9446	261.4722	319.6887	370.8850	416.5063	457.6106
494.9717	649.8635	650.4468	648.8206	646.2307	642.3655	636.9341	261.4805	319.6958
370.8875	416.5085	457.6042	494.9595	649.4441	649.1797	649.2056	648.9866	648.4792
647.5913	261.4802	319.6941	370.8853	416.5049	457.6025	494.9590	649.4270	649.0654
648.7327	648.5220	648.3865	648.2976	261.4797	319.6941	370.8867	416.5068	457.6023
494.9595	649.5076	649.1570	648.8923	648.5874	648.3113	648.0713	261.4805	319.6953
370.8865	416.5063	457.6030	494.9592	649.5176	649.2607	649.0178	648.7917	648.5823
648.3909	261.4800	319.6960	370.8911	416.5088	457.6057	494.9612	649.6011	649.4307
649.2776	649.1375	649.0112	648.8984	261.4812	319.6956	370.8855	416.5059	457.6038
494.9612	649.5964	649.4172	649.2527	649.1042	648.9712	648.8525	261.4810	319.6965
370.8894	416.5098	457.6060	494.9619	649.5898	649.4089	649.2434	649.0942	648.9617
648.8435	261.4795	319.6917	370.8845	416.5054	457.6016	494.9590	649.5886	649.4070
649.2407	649.0920	648.9600	648.8420	261.4802	319.6980	370.8896	416.5066	457.6030
494.9600	649.5867	649.4043	649.2388	649.0891	648.9548	648.8367	261.4805	319.6960
370.8884	416.5093	457.6067	494.9624	649.5874	649.4048	649.2371	649.0867	648.9536
648.8354	261.4805	319.6970	370.8882	416.5088	457.6045	494.9617	649.5894	649.4080
649.2432	649.0933	648.9604	648.8425	261.4807	319.6931	370.8884	416.5093	457.6047
494.9602	649.5862	649.4048	649.2397	649.0911	648.9578	648.8396	261.4805	319.6980
370.8867	416.5056	457.6040	494.9602	649.5757	649.3853	649.2141	649.0613	648.9270
648.8096	261.4817	319.6956	370.8892	416.5098	457.6057	494.9622	261.4805	319.6973
370.8889	416.5090	457.6050	494.9602	261.4802	319.6936	370.8877	416.5056	457.6028
494.9592	261.4805	319.6909	370.8828	416.5027	457.6021	494.9585	261.4802	319.6946
370.8835	416.5044	457.5996	494.9573	261.4849	319.7039	370.8970	416.5117	457.6040
494.9580								

C-14

LTR 4 38

N	R	Z	T
1	0.4075	9.1200	200.7595
2	0.4575	9.1200	201.4814
3	0.5075	9.1200	202.0468
4	0.5575	9.1200	202.4458
5	0.6075	9.1200	202.6740
6	0.6575	9.1200	202.7339
7	0.4075	8.9200	200.7570
8	0.4575	8.9200	201.4758
9	0.5075	8.9200	202.0388
10	0.5575	8.9200	202.4364
11	0.6075	8.9200	202.6639
12	0.6575	8.9200	202.7236
13	0.4075	8.7200	200.7570
14	0.4575	8.7200	201.4762
15	0.5075	8.7200	202.0401
16	0.5575	8.7200	202.4380
17	0.6075	8.7200	202.6659
18	0.6575	8.7200	202.7258
19	0.4075	8.5200	200.7573
20	0.4575	8.5200	201.4772
21	0.5075	8.5200	202.0412
22	0.5575	8.5200	202.4393
23	0.6075	8.5200	202.6672
24	0.6575	8.5200	202.7272
25	0.4075	8.3200	200.7570
26	0.4575	8.3200	201.4764
27	0.5075	8.3200	202.0401
28	0.5575	8.3200	202.4377
29	0.6075	8.3200	202.6654
30	0.6575	8.3200	202.7254
31	0.4075	8.1200	200.7564
32	0.4575	8.1200	201.4750
33	0.5075	8.1200	202.0379
34	0.5575	8.1200	202.4352
35	0.6075	8.1200	202.6625
36	0.6575	8.1200	202.7224
37	0.4075	7.9200	200.7567
38	0.4575	7.9200	201.4766
39	0.5075	7.9200	202.0409
40	0.5575	7.9200	202.4391

C-15

LTR1144 38

N	R	Z	T
41	0.6075	7.9200	202.6671
42	0.6575	7.9200	202.7270
43	0.4075	7.7200	200.7552
44	0.4575	7.7200	201.4691
45	0.5075	7.7200	202.0288
46	0.5575	7.7200	202.4242
47	0.6075	7.7200	202.6512
48	0.6575	7.7200	202.7124
49	0.4075	7.5200	200.7704
50	0.4575	7.5200	201.5075
51	0.5075	7.5200	202.0837
52	0.5575	7.5200	202.4877
53	0.6075	7.5200	202.7143
54	0.6575	7.5200	202.7653
55	0.4075	7.3200	200.6766
56	0.4575	7.3200	201.3985
57	0.5075	7.3200	201.9764
58	0.5575	7.3200	202.4040
59	0.6075	7.3200	202.6794
60	0.6575	7.3200	202.8053
61	0.4075	7.1200	201.1857
62	0.4575	7.1200	201.2482
63	0.5075	7.1200	201.2115
64	0.5575	7.1200	201.0583
65	0.6075	7.1200	200.7816
66	0.6575	7.1200	200.3832
67	0.4075	6.9200	208.6357
68	0.4575	6.9200	216.5027
69	0.5075	6.9200	223.1301
70	0.5575	6.9200	228.5427
71	0.6075	6.9200	232.7599
72	0.6575	6.9200	235.8053
73	0.7441	6.9700	225.9036
74	0.4075	6.7200	219.7702
75	0.4575	6.7200	238.8772
76	0.5075	6.7200	255.3183
77	0.5575	6.7200	269.3054
78	0.6075	6.7200	280.9873
79	0.6575	6.7200	290.4766
80	0.7385	6.7667	286.5696

C-16

LTR1144 38

N	R	Z	T
81	0.8307	6.8200	272.2559
82	0.4075	6.5200	230.1595
83	0.4575	6.5200	259.5002
84	0.5075	6.5200	284.9939
85	0.5575	6.5200	307.1052
86	0.6075	6.5200	326.1677
87	0.6575	6.5200	342.4253
88	0.7328	6.5635	350.4890
89	0.8249	6.6167	345.9182
90	0.9170	6.6700	329.8550
91	0.4075	6.3200	237.2275
92	0.4575	6.3200	273.1709
93	0.5075	6.3200	304.5510
94	0.5575	6.3200	332.0469
95	0.6075	6.3200	356.1406
96	0.6575	6.3200	377.1851
97	0.7272	6.3602	395.1804
98	0.8194	6.4135	405.8489
99	0.9117	6.4667	405.0625
100	1.0039	6.5200	390.5801
101	0.4075	6.1200	241.3029
102	0.4575	6.1200	280.9524
103	0.5075	6.1200	315.6636
104	0.5575	6.1200	346.2319
105	0.6075	6.1200	373.2356
106	0.6575	6.1200	397.1072
107	0.7216	6.1570	420.1826
108	0.8138	6.2102	442.8730
109	0.9060	6.2635	455.0376
110	0.9983	6.3167	455.1113
111	1.0905	6.3700	443.8149
112	0.4075	5.9200	243.3428
113	0.4575	5.9200	284.8950
114	0.5075	5.9200	321.3225
115	0.5575	5.9200	353.5007
116	0.6075	5.9200	382.0610
117	0.6575	5.9200	407.4688
118	0.7159	5.9537	432.1370
119	0.8081	6.0069	462.7385
120	0.9004	6.0602	483.6699

C-17

LTR1144 38

N	R	Z	T
121	0.9926	6.1134	494.7505
122	1.0849	6.1667	496.1960
123	1.1771	6.2200	487.3569
124	0.4075	5.7200	244.1418
125	0.4575	5.7200	285.9448
126	0.5075	5.7200	322.6089
127	0.5575	5.7200	355.0120
128	0.6075	5.7200	383.7964
129	0.6575	5.7200	409.4399
130	0.7441	5.7700	446.6504
131	0.8025	5.8037	469.2881
132	0.8947	5.8569	497.0178
133	0.9870	5.9102	516.0129
134	1.0792	5.9634	526.7056
135	1.1715	6.0167	528.9312
136	1.2637	6.0700	522.3645
137	0.4075	5.5200	247.8280
138	0.4575	5.5200	292.1069
139	0.5075	5.5200	330.9539
140	0.5575	5.5200	365.3450
141	0.6075	5.5200	395.9810
142	0.6575	5.5200	423.3923
143	0.7441	5.5700	455.5549
144	0.8307	5.6200	482.6243
145	0.8891	5.6537	497.0181
146	0.9814	5.7069	522.1321
147	1.0736	5.7602	539.9375
148	1.1659	5.8134	550.4351
149	1.2581	5.8667	553.6414
150	1.3504	5.9200	549.3511
151	0.4075	5.3200	258.3701
152	0.4575	5.3200	314.9807
153	0.5075	5.3200	364.8235
154	0.5575	5.3200	409.2988
155	0.6075	5.3200	449.4236
156	0.6575	5.3200	485.9565
157	0.7441	5.3700	515.0198
158	0.8307	5.4200	527.6431
159	0.9173	5.4700	539.9805
160	0.9757	5.5037	546.9407

c-18

FRI 144 38

N	R	Z	T
161	1.0679	5.5569	550.6316
162	1.1602	5.6102	561.5874
163	1.2524	5.6634	569.3379
164	1.3446	5.7167	571.9668
165	1.4369	5.7700	568.6348
166	0.4075	5.1200	261.9946
167	0.4575	5.1200	321.1501
168	0.5075	5.1200	373.1641
169	0.5575	5.1200	419.5137
170	0.6075	5.1200	461.2651
171	0.6575	5.1200	499.2153
172	0.7124	5.2250	528.8535
173	0.7677	5.3290	566.0798
174	0.8769	5.3400	614.7461
175	1.0038	5.3202	633.1309
176	1.0623	5.3537	619.3154
177	1.1545	5.4069	611.0410
178	1.2468	5.4602	601.8518
179	1.3390	5.5134	597.7910
180	1.4313	5.5667	594.2974
181	1.5235	5.6200	588.0869
182	0.4075	4.9200	261.5586
183	0.4575	4.9200	319.7092
184	0.5075	4.9200	370.8401
185	0.5575	4.9200	416.4050
186	0.6075	4.9200	457.4485
187	0.6575	4.9200	494.7566
188	1.1489	5.2037	650.4353
189	1.2412	5.2629	643.0105
190	1.3334	5.3222	636.6958
191	1.4257	5.3814	629.4246
192	1.5179	5.4407	622.2456
193	1.6102	5.5000	613.9446
194	0.4075	4.7200	261.4722
195	0.4575	4.7200	319.6887
196	0.5075	4.7200	370.8850
197	0.5575	4.7200	416.5063
198	0.6075	4.7200	457.6106
199	0.6575	4.7200	494.9717
200	1.2355	5.0537	649.8635

61-0

LRI 44 38

N	R	Z	T
201	1.3278	5.1069	650.4468
202	1.4200	5.1602	648.8206
203	1.5122	5.2134	646.2307
204	1.6044	5.2667	642.3655
205	1.6967	5.3200	636.9341
206	0.4075	4.5200	261.4805
207	0.4575	4.5200	319.6958
208	0.5075	4.5200	370.8875
209	0.5575	4.5200	416.5085
210	0.6075	4.5200	457.6042
211	0.6575	4.5200	494.9595
212	1.3222	4.9037	649.4441
213	1.4144	4.9569	649.1797
214	1.5066	5.0102	649.2056
215	1.5989	5.0634	648.9866
216	1.69	5.1167	648.4792
217	1.7833	5.1700	647.5913
218	0.4075	4.3200	261.4802
219	0.4575	4.3200	319.6941
220	0.5075	4.3200	370.8853
221	0.5575	4.3200	416.5049
222	0.6075	4.3200	457.6025
223	0.6575	4.3200	494.9590
224	1.4953	4.6037	649.4270
225	1.5876	4.6569	549.0654
226	1.6799	4.7102	648.7327
227	1.7720	4.7634	648.5220
228	1.8642	4.8167	648.3865
229	1.9565	4.8700	648.2976
230	0.4075	4.1200	261.4797
231	0.4575	4.1200	319.6941
232	0.5075	4.1200	370.8867
233	0.5575	4.1200	416.5068
234	0.6075	4.1200	457.6023
235	0.6575	4.1200	494.9595
236	1.6685	4.3037	649.5076
237	1.7607	4.3569	649.1970
238	1.8530	4.4102	648.8923
239	1.9452	4.4634	648.5874
240	2.0375	4.5167	648.3113

C20

LTR1144 3B

N	R	Z	T
241	2.1298	4.5700	648.0713
242	0.4075	3.9200	261.4805
243	0.4575	3.9200	319.6953
244	0.5075	3.9200	370.8865
245	0.5575	3.9200	416.5063
246	0.6075	3.9200	457.6030
247	0.6575	3.9200	494.9592
248	1.7176	4.2190	649.5176
249	1.8240	4.2475	649.2607
250	1.9305	4.2761	649.0178
251	2.0370	4.3046	648.7917
252	2.1435	4.3332	648.5823
253	2.2500	4.3618	648.3909
254	0.4075	3.7200	261.4800
255	0.4575	3.7200	319.6960
256	0.5075	3.7200	370.8911
257	0.5575	3.7200	416.5088
258	0.6075	3.7200	457.6057
259	0.6575	3.7200	494.9612
260	1.7176	4.0000	649.6011
261	1.8240	4.0000	649.4307
262	1.9305	4.0000	649.2776
263	2.0370	4.0000	649.1375
264	2.1435	4.0000	649.0112
265	2.2500	4.0000	648.8984
266	0.4075	3.5200	261.4812
267	0.4575	3.5200	319.6956
268	0.5075	3.5200	370.8855
269	0.5575	3.5200	416.5059
270	0.6075	3.5200	457.6038
271	0.6575	3.5200	494.9612
272	1.7176	3.5000	649.5964
273	1.8240	3.5000	649.4172
274	1.9305	3.5000	649.2527
275	2.0370	3.5000	649.1042
276	2.1435	3.5000	648.9712
277	2.2500	3.5000	648.8525
278	0.4075	3.3200	261.4810
279	0.4575	3.3200	319.6965
280	0.5075	3.3200	370.8894

C-21

LTR 144 3B

N	R	Z	T
281	0.5575	3.3200	416.5098
282	0.6075	3.3200	457.6060
283	0.6575	3.3200	494.9619
284	1.7176	3.0000	649.5898
285	1.8240	3.0000	649.4089
286	1.9305	3.0000	649.2434
287	2.0370	3.0000	649.0942
288	2.1435	3.0000	648.9617
289	2.2500	3.0000	648.8435
290	0.4075	3.1200	261.4795
291	0.4575	3.1200	319.6917
292	0.5075	3.1200	370.8845
293	0.5575	3.1200	416.5054
294	0.6075	3.1200	457.6016
295	0.6575	3.1200	494.9590
296	1.7176	2.5000	649.5886
297	1.8240	2.5000	649.4070
298	1.9305	2.5000	649.2407
299	2.0370	2.5000	649.0920
300	2.1435	2.5000	648.9600
301	2.2500	2.5000	648.8420
302	0.4075	2.9200	261.4802
303	0.4575	2.9200	319.6980
304	0.5075	2.9200	370.8896
305	0.5575	2.9200	416.5066
306	0.6075	2.9200	457.6030
307	0.6575	2.9200	494.9600
308	1.7176	2.0000	649.5867
309	1.8240	2.0000	649.4043
310	1.9305	2.0000	649.2388
311	2.0370	2.0000	649.0891
312	2.1435	2.0000	648.9548
313	2.2500	2.0000	648.8367
314	0.4075	2.7200	261.4805
315	0.4575	2.7200	319.6960
316	0.5075	2.7200	370.8884
317	0.5575	2.7200	416.5093
318	0.6075	2.7200	457.6067
319	0.6575	2.7200	494.9624
320	1.7176	1.5000	649.5874

2-22

LTR1144 38

N	R	Z	T
321	1.8240	1.5000	649.4048
322	1.9305	1.5000	649.2371
323	2.0370	1.5000	649.0867
324	2.1435	1.5000	648.9536
325	2.2500	1.5000	648.8354
326	0.4075	2.5200	261.4805
327	0.4575	2.5200	319.6970
328	0.5075	2.5200	370.8882
329	0.5575	2.5200	416.5088
330	0.6075	2.5200	457.6045
331	0.6575	2.5200	494.9617
332	1.7176	1.0000	649.5894
333	1.8240	1.0000	649.4080
334	1.9305	1.0000	649.2432
335	2.0370	1.0000	649.0933
336	2.1435	1.0000	648.9604
337	2.2500	1.0000	648.8425
338	0.4075	2.3200	261.4807
339	0.4575	2.3200	319.6931
340	0.5075	2.3200	370.8884
341	0.5575	2.3200	416.5093
342	0.6075	2.3200	457.6047
343	0.6575	2.3200	494.9602
344	1.7176	0.5000	649.5862
345	1.8240	0.5000	649.4048
346	1.9305	0.5000	649.2397
347	2.0370	0.5000	649.0911
348	2.1435	0.5000	648.9578
349	2.2500	0.5000	648.8396
350	0.4075	2.1200	261.4805
351	0.4575	2.1200	319.6980
352	0.5075	2.1200	370.8867
353	0.5575	2.1200	416.5056
354	0.6075	2.1200	457.6040
355	0.6575	2.1200	494.9602
356	1.7176	0.0	649.5757
357	1.8240	0.0	649.3853
358	1.9306	0.0	649.2141
359	2.0370	0.0	649.0613
360	2.1436	0.0	648.9270

C-23

LTR1144 38

N	R	Z	T
361	2.2500	0.0	648.8096
362	0.4075	1.9200	261.4817
363	0.4575	1.9200	319.6956
364	0.5075	1.9200	370.8892
365	0.5575	1.9200	416.5098
366	0.6075	1.9200	457.6057
367	0.6575	1.9200	494.9622
368	0.4075	1.7200	261.4805
369	0.4575	1.7200	319.6973
370	0.5075	1.7200	370.8889
371	0.5575	1.7200	416.5090
372	0.6075	1.7200	457.6050
373	0.6575	1.7200	494.9602
374	0.4075	1.5200	261.4802
375	0.4575	1.5200	319.6936
376	0.5075	1.5200	370.8877
377	0.5575	1.5200	416.5056
378	0.6075	1.5200	457.6028
379	0.6575	1.5200	494.9592
380	0.4075	1.3200	261.4805
381	0.4575	1.3200	319.6909
382	0.5075	1.3200	370.8828
383	0.5575	1.3200	416.5027
384	0.6075	1.3200	457.6021
385	0.6575	1.3200	494.9585
386	0.4075	1.1200	261.4802
387	0.4575	1.1200	319.6946
388	0.5075	1.1200	370.8835
389	0.5575	1.1200	416.5044
390	0.6075	1.1200	457.5996
391	0.6575	1.1200	494.9573
392	0.4075	0.9200	261.4849
393	0.4575	0.9200	319.7039
394	0.5075	0.9200	370.8970
395	0.5575	0.9200	416.5117
396	0.6075	0.9200	457.6040
397	0.6575	0.9200	494.9580

C-24

LTR1144 38

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
1	1	7	8	2	1	0.0	201.118	C.0
2	2	8	9	3	1	0.0	201.761	C.0
3	3	9	10	4	1	0.0	202.242	C.0
4	4	10	11	5	1	0.0	202.555	C.0
5	5	11	12	6	1	0.0	202.699	C.0
6	7	13	14	8	1	0.0	201.116	C.0
7	8	14	15	9	1	0.0	201.758	C.0
8	9	15	16	10	1	0.0	202.238	C.0
9	10	16	17	11	1	0.0	202.551	C.0
10	11	17	18	12	1	0.0	202.695	C.0
11	13	19	20	14	1	0.0	201.117	C.0
12	14	20	21	15	1	0.0	201.759	C.0
13	15	21	22	16	1	0.0	202.240	C.0
14	16	22	23	17	1	0.0	202.552	C.0
15	17	23	24	18	1	0.0	202.696	C.0
16	19	25	26	20	1	0.0	201.117	C.0
17	20	26	27	21	1	0.0	201.759	C.0
18	21	27	28	22	1	0.0	202.239	C.0
19	22	28	29	23	1	0.0	202.552	C.0
20	23	29	30	24	1	0.0	202.696	C.0
21	25	31	32	26	1	0.0	201.116	C.0
22	26	32	33	27	1	0.0	201.757	C.0
23	27	33	34	28	1	0.0	202.238	C.0
24	28	34	35	29	1	0.0	202.550	C.0
25	29	35	36	30	1	0.0	202.694	C.0
26	31	37	38	32	1	0.0	201.116	C.0
27	32	38	39	33	1	0.0	201.758	C.0
28	33	39	40	34	1	0.0	202.238	C.0
29	34	40	41	35	1	0.0	202.551	C.0
30	35	41	42	36	1	0.0	202.695	C.0
31	37	43	44	38	1	0.0	201.114	C.0
32	38	44	45	39	1	0.0	201.754	C.0
33	39	45	46	40	1	0.0	202.233	C.0
34	40	46	47	41	1	0.0	202.545	C.0
35	41	47	48	42	1	0.0	202.689	C.0
36	43	49	50	44	1	0.0	201.125	C.0
37	44	50	51	45	1	0.0	201.772	C.0
38	45	51	52	46	1	0.0	202.256	C.0
39	46	52	53	47	1	0.0	202.569	C.0
40	47	53	54	48	1	0.0	202.711	C.0

LTR 144 38

C-25

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
41	49	55	56	50	1	0.0	201.088	C.0
42	50	56	57	51	1	0.0	201.741	C.C
43	51	57	58	52	1	0.0	202.238	C.0
44	52	58	59	53	1	0.C	202.571	C.0
45	53	59	60	54	1	0.0	202.741	C.C
46	55	61	62	56	1	0.0	201.127	C.0
47	56	62	63	57	1	0.0	201.459	C.0
48	57	63	64	58	1	C.C	201.662	C.C
49	58	64	65	59	1	C.0	201.731	C.C
50	59	65	66	60	1	0.0	201.662	C.0
51	61	67	68	62	1	C.C	206.893	C.0
52	62	68	69	63	1	0.0	210.523	C.C
53	63	69	70	64	1	0.0	213.486	C.0
54	64	70	71	65	1	C.C	215.786	C.0
55	65	71	72	66	1	0.0	217.432	C.C
56	66	72	73	73	1	C.0	221.999	C.0
57	67	74	75	68	1	0.0	220.946	C.0
58	68	75	76	69	1	C.0	233.457	C.0
59	69	76	77	70	1	0.0	244.074	C.0
60	70	77	78	71	1	0.0	252.899	C.0
61	71	78	79	72	1	0.0	260.007	C.0
62	72	79	80	80	1	0.0	274.855	C.0
63	72	80	73	73	1	0.0	243.545	C.0
64	73	80	81	81	1	C.0	264.246	0.0
65	74	82	83	75	1	C.C	237.077	C.C
66	75	83	84	76	1	0.0	259.672	C.0
67	76	84	85	77	1	0.0	279.181	0.0
68	77	85	86	78	1	0.0	295.891	C.0
69	78	86	87	79	1	0.0	310.014	C.0
70	79	87	88	88	1	0.0	333.470	C.0
71	79	88	80	80	1	0.0	303.526	0.0
72	80	88	89	89	1	0.0	332.224	C.C
73	80	89	90	81	1	0.0	308.650	C.0
74	82	91	92	83	1	0.0	250.015	0.0
75	83	92	93	84	1	0.0	280.554	0.0
76	84	93	94	85	1	0.0	307.174	C.0
77	85	94	95	86	1	0.0	330.365	0.0
78	86	95	96	87	1	0.0	350.479	0.0
79	87	96	97	97	1	0.0	377.493	C.C
80	87	97	88	88	1	0.0	359.646	0.0

0-26

LRI 144 3B

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
81	88	97	98	98	1	0.0	389.342	C.0
82	88	98	99	89	1	0.0	376.830	C.0
83	89	99	100	90	1	0.0	367.854	C.0
84	91	101	102	92	1	0.0	258.163	C.0
85	92	102	103	93	1	0.0	293.584	C.0
86	93	103	104	94	1	0.0	324.623	C.0
87	94	104	105	95	1	0.0	351.914	C.0
88	95	105	106	96	1	0.0	375.917	C.0
89	96	106	107	107	1	0.0	403.664	C.0
90	96	107	97	97	1	0.0	396.932	C.0
91	97	107	108	108	1	0.0	425.277	C.0
92	97	108	109	98	1	0.0	424.735	C.0
93	98	109	110	99	1	0.0	430.265	C.0
94	99	110	111	100	1	0.0	423.642	C.0
95	101	112	113	102	1	0.0	262.623	C.0
96	102	113	114	103	1	0.0	300.708	C.0
97	103	114	115	104	1	0.0	334.180	C.0
98	104	115	116	105	1	0.0	363.757	C.0
99	105	116	117	106	1	0.0	389.968	C.0
100	106	117	118	107	1	0.0	417.212	C.0
101	106	118	107	107	1	0.0	417.402	C.0
102	107	118	119	108	1	0.0	444.449	C.0
103	107	119	120	108	1	0.0	452.366	C.0
104	108	120	121	109	1	0.0	469.083	C.0
105	109	121	122	110	1	0.0	475.274	C.0
106	110	122	123	111	1	0.0	470.620	C.0
107	112	124	125	113	1	0.0	264.581	C.0
108	113	125	126	114	1	0.0	303.693	C.0
109	114	126	127	115	1	0.0	338.111	C.0
110	115	127	128	116	1	0.0	368.593	C.0
111	116	128	129	117	1	0.0	395.691	C.0
112	117	129	130	130	1	0.0	427.552	C.0
113	117	130	118	118	1	0.0	429.598	C.0
114	118	130	131	131	1	0.0	454.341	C.0
115	118	131	132	119	1	0.0	465.295	C.0
116	119	132	133	120	1	0.0	489.860	C.0
117	120	133	134	121	1	0.0	505.285	C.0
118	121	134	135	122	1	0.0	511.646	C.0
119	122	135	136	123	1	0.0	508.712	C.0
120	124	137	138	125	1	0.0	267.505	C.0

C-27

LTR1144 38

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
121	125	138	139	126	1	0.0	307.904	0.0
122	126	139	140	127	1	0.0	343.480	0.0
123	127	140	141	128	1	0.0	375.033	0.0
124	128	141	142	129	1	0.0	403.152	0.0
125	129	142	143	143	1	0.0	435.985	0.0
126	129	143	130	130	1	0.0	439.574	0.0
127	130	143	144	144	1	0.0	466.863	0.0
128	130	144	145	131	1	0.0	473.895	0.0
129	131	145	146	132	1	0.0	496.264	0.0
130	132	146	147	133	1	0.0	518.775	0.0
131	133	147	148	134	1	0.0	533.273	0.0
132	134	148	149	135	1	0.0	539.928	0.0
133	135	149	150	136	1	0.0	538.572	0.0
134	137	151	152	138	1	0.0	278.321	0.0
135	138	152	153	139	1	0.0	325.716	0.0
136	139	153	154	140	1	0.0	367.605	0.0
137	140	154	155	141	1	0.0	405.012	0.0
138	141	155	156	142	1	0.0	438.688	0.0
139	142	156	157	157	1	0.0	484.847	0.0
140	142	157	143	143	1	0.0	462.380	0.0
141	143	157	158	158	1	0.0	506.465	0.0
142	143	158	144	144	1	0.0	487.112	0.0
143	144	158	159	159	1	0.0	522.557	0.0
144	144	159	145	145	1	0.0	504.160	0.0
145	145	159	160	160	1	0.0	532.720	0.0
146	145	160	161	146	1	0.0	529.180	0.0
147	146	161	162	147	1	0.0	543.572	0.0
148	147	162	163	148	1	0.0	555.324	0.0
149	148	163	164	149	1	0.0	561.345	0.0
150	149	164	165	150	1	0.0	560.898	0.0
151	151	166	167	152	1	0.0	289.124	0.0
152	152	167	168	153	1	0.0	343.530	0.0
153	153	168	169	154	1	0.0	391.700	0.0
154	154	169	170	155	1	0.0	434.875	0.0
155	155	170	171	156	1	0.0	473.965	0.0
156	156	171	172	172	1	0.0	510.720	0.0
157	156	172	173	157	1	0.0	523.977	0.0
158	157	173	174	158	1	0.0	555.872	0.0
159	158	174	175	159	1	0.0	578.875	0.0
160	159	175	176	176	1	0.0	602.936	0.0

LTR1144 38

C-28

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
161	159	176	160	160	1	0.0	563.294	C.0
162	160	176	161	161	1	C.C	566.880	C.0
163	161	176	177	177	1	0.0	558.007	C.C
164	161	177	178	162	1	0.0	581.278	C.C
165	162	178	179	163	1	C.0	582.642	C.0
166	163	179	180	164	1	0.0	583.348	C.0
167	164	180	181	165	1	0.0	580.746	C.C
168	166	182	183	167	1	0.0	291.103	C.0
169	167	183	184	168	1	0.0	346.216	C.C
170	168	184	185	169	1	0.0	394.981	C.C
171	169	185	186	170	1	0.0	438.658	C.0
172	170	186	187	171	1	0.0	478.171	C.0
173	175	188	176	176	1	C.C	630.549	C.0
174	176	188	177	177	1	0.0	622.958	C.0
175	177	188	189	189	1	C.0	636.874	C.0
176	177	189	190	178	1	0.0	623.150	C.0
177	178	190	191	179	1	0.0	616.441	C.0
178	179	191	192	180	1	0.0	610.939	C.0
179	180	192	193	181	1	0.0	604.644	C.C
180	182	194	195	183	1	0.0	290.607	C.C
181	183	195	196	184	1	0.0	345.281	C.0
182	184	196	197	185	1	0.0	393.659	C.0
183	185	197	198	186	1	0.0	436.992	C.C
184	186	198	199	187	1	0.0	476.197	C.0
185	188	200	201	189	1	0.0	648.439	C.0
186	189	201	202	190	1	0.0	644.743	C.0
187	190	202	203	191	1	0.0	640.293	C.0
188	191	203	204	192	1	0.0	635.066	C.0
189	192	204	205	193	1	0.0	628.872	C.0
190	194	206	207	195	1	0.0	290.584	C.0
191	195	207	208	196	1	0.0	345.289	C.0
192	196	208	209	197	1	C.C	393.697	C.0
193	197	209	210	198	1	C.0	437.057	C.0
194	198	210	211	199	1	0.0	476.286	C.C
195	200	212	213	201	1	0.0	649.733	C.0
196	201	213	214	202	1	0.0	649.413	C.0
197	202	214	215	203	1	0.0	648.311	C.0
198	203	215	216	204	1	0.0	646.515	C.0
199	204	216	217	205	1	0.0	643.843	C.0
200	206	218	219	207	1	0.0	290.588	C.0

G-27

LFRI 44 3B

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
201	207	219	220	208	1	0.0	345.291	C.0
202	208	220	221	209	1	0.0	393.697	C.0
203	209	221	222	210	1	0.0	437.055	C.0
204	210	222	223	211	1	0.0	476.281	C.0
205	212	224	225	213	1	0.0	649.279	C.C
206	213	225	226	214	1	0.0	649.046	C.0
207	214	226	227	215	1	0.0	648.862	C.C
208	215	227	228	216	1	0.0	648.594	C.C
209	216	228	229	217	1	0.0	648.188	C.0
210	218	230	231	219	1	0.0	290.587	C.0
211	219	231	232	220	1	0.0	345.290	C.C
212	220	232	233	221	1	0.0	393.696	C.0
213	221	233	234	222	1	0.0	437.054	C.0
214	222	234	235	223	1	0.0	476.281	C.0
215	224	236	237	225	1	0.0	649.299	C.C
216	225	237	238	226	1	0.0	648.972	C.0
217	226	238	239	227	1	0.0	648.684	C.0
218	227	239	240	228	1	0.0	648.452	C.C
219	228	240	241	229	1	0.0	648.267	C.0
220	230	242	243	231	1	0.0	290.587	0.0
221	231	243	244	232	1	0.0	345.291	0.0
222	232	244	245	233	1	0.0	393.697	0.0
223	233	245	246	234	1	0.0	437.054	C.0
224	234	246	247	235	1	0.0	476.281	C.0
225	236	248	249	237	1	0.0	649.371	C.C
226	237	249	250	238	1	0.0	649.092	0.0
227	238	250	251	239	1	0.0	648.822	C.0
228	239	251	252	240	1	0.0	648.568	C.C
229	240	252	253	241	1	0.0	648.339	0.0
230	242	254	255	243	1	0.0	290.588	0.0
231	243	255	256	244	1	0.0	345.292	0.0
232	244	256	257	245	1	0.0	393.698	C.0
233	245	257	258	246	1	0.0	437.056	C.0
234	246	258	259	247	1	0.0	476.282	C.0
235	248	260	261	249	1	0.0	649.452	C.C
236	249	261	262	250	1	0.0	649.247	0.0
237	250	262	263	251	1	0.0	649.056	0.0
238	251	263	264	252	1	0.0	648.881	C.0
239	252	264	265	253	1	0.0	648.721	C.0
240	254	266	267	255	1	0.0	290.588	C.0

E-30

APR 14 3 41 PM '44

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
241	255	267	268	256	1	0.0	345.292	C.0
242	256	268	269	257	1	0.0	393.698	C.0
243	257	269	270	258	1	0.0	437.056	C.0
244	258	270	271	259	1	0.0	476.283	C.0
245	260	272	273	261	1	0.0	649.511	C.0
246	261	273	274	262	1	0.0	649.344	C.C
247	262	274	275	263	1	0.0	649.193	C.C
248	263	275	276	264	1	0.0	649.056	C.0
249	264	276	277	265	1	0.0	648.933	C.C
250	266	278	279	267	1	0.0	290.588	C.C
251	267	279	280	268	1	0.0	345.292	C.0
252	268	280	281	269	1	0.0	393.698	C.0
253	269	281	282	270	1	0.0	437.056	C.C
254	270	282	283	271	1	0.0	476.283	C.0
255	272	284	285	273	1	0.0	649.503	0.0
256	273	285	286	274	1	0.0	649.331	C.C
257	274	286	287	275	1	0.0	649.174	C.0
258	275	287	288	276	1	0.0	649.033	C.0
259	276	288	289	277	1	0.0	648.907	C.C
260	278	290	291	279	1	0.0	290.587	C.0
261	279	291	292	280	1	0.0	345.291	0.0
262	280	292	293	281	1	0.0	393.697	C.0
263	281	293	294	282	1	0.0	437.056	C.C
264	282	294	295	283	1	0.0	476.282	C.0
265	284	296	297	285	1	0.0	649.499	C.0
266	285	297	298	286	1	0.0	649.325	C.0
267	286	298	299	287	1	0.0	649.167	C.0
268	287	299	300	288	1	0.0	649.027	C.0
269	288	300	301	289	1	0.0	648.902	C.0
270	290	302	303	291	1	0.0	290.587	C.0
271	291	303	304	292	1	0.0	345.291	0.0
272	292	304	305	293	1	0.0	393.697	C.0
273	293	305	306	294	1	0.0	437.054	C.C
274	294	306	307	295	1	0.0	476.281	C.0
275	296	308	309	297	1	0.0	649.497	0.0
276	297	309	310	298	1	0.0	649.323	0.0
277	298	310	311	299	1	0.0	649.165	C.0
278	299	311	312	300	1	0.0	649.024	C.0
279	300	312	313	301	1	0.0	648.898	0.0
280	302	314	315	303	1	0.0	290.589	C.0

C-31

LTR1144 3B

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
281	303	315	316	304	1	0.0	345.293	C.0
282	304	316	317	305	1	0.0	393.698	C.0
283	305	317	318	306	1	0.0	437.056	C.0
284	306	318	319	307	1	0.0	476.283	C.0
285	308	320	321	309	1	0.0	649.496	C.0
286	309	321	322	310	1	0.0	649.321	C.0
287	310	322	323	311	1	0.0	649.163	C.0
288	311	323	324	312	1	0.0	649.021	C.0
289	312	324	325	313	1	0.0	648.895	C.0
290	314	326	327	315	1	C.0	290.588	0.0
291	315	327	328	316	1	C.0	345.292	C.0
292	316	328	329	317	1	0.0	393.698	C.0
293	317	329	330	318	1	0.0	437.057	C.0
294	318	330	331	319	1	C.0	476.284	C.0
295	320	332	333	321	1	C.0	649.497	C.0
296	321	333	334	322	1	C.0	649.323	C.0
297	322	334	335	323	1	C.0	649.165	C.0
298	323	335	336	324	1	0.0	649.023	C.0
299	324	336	337	325	1	0.0	648.898	C.0
300	326	338	339	327	1	0.0	290.588	0.0
301	327	339	340	328	1	C.0	345.292	C.0
302	328	340	341	329	1	0.0	393.698	C.0
303	329	341	342	330	1	C.0	437.057	0.0
304	330	342	343	331	1	0.0	476.283	C.0
305	332	344	345	333	1	0.0	649.497	C.0
306	333	345	346	334	1	0.0	649.324	C.0
307	334	346	347	335	1	0.0	649.167	C.0
308	335	347	348	336	1	0.0	649.026	C.0
309	336	348	349	337	1	0.0	648.900	0.0
310	338	350	351	339	1	0.0	290.588	0.0
311	339	351	352	340	1	C.0	345.292	C.0
312	340	352	353	341	1	0.0	393.698	C.0
313	341	353	354	342	1	0.0	437.056	C.0
314	342	354	355	343	1	0.0	476.282	C.0
315	344	356	357	345	1	0.0	649.488	C.0
316	345	357	358	346	1	0.0	649.311	C.0
317	346	358	359	347	1	0.0	649.151	0.0
318	347	359	360	348	1	0.0	649.009	C.0
319	348	360	361	349	1	0.0	648.883	0.0
320	350	362	363	351	1	C.0	290.589	0.0

C-32

LIBRARY  
B3

EL	I	J	K	L	MATERIAL	ANGLE	TEMPERATURE	PRESSURE
321	351	363	364	352	1	0.0	345.292	C.0
322	352	364	365	353	1	0.0	393.698	C.0
323	353	365	366	354	1	0.0	437.056	C.0
324	354	366	367	355	1	0.0	476.283	C.0
325	362	368	369	363	1	0.0	290.589	C.0
326	363	369	370	364	1	0.0	345.293	C.0
327	364	370	371	365	1	0.0	393.699	C.0
328	365	371	372	366	1	0.0	437.057	C.0
329	366	372	373	367	1	C.C	476.283	C.C
330	368	374	375	369	1	0.0	290.588	C.0
331	369	375	376	370	1	0.0	345.292	C.0
332	370	376	377	371	1	C.C	393.698	C.0
333	371	377	378	372	1	0.0	427.055	C.C
334	372	378	379	373	1	0.0	476.282	0.0
335	374	380	381	375	1	0.0	290.586	0.0
336	375	381	382	376	1	0.0	345.289	C.C
337	376	382	383	377	1	0.0	393.695	C.C
338	377	383	384	378	1	0.0	437.053	C.0
339	378	384	385	379	1	0.0	476.281	C.C
340	380	386	387	381	1	0.0	290.586	C.0
341	381	387	388	382	1	C.0	345.288	C.0
342	382	388	389	383	1	0.0	393.693	C.C
343	383	389	390	384	1	0.0	437.052	C.0
344	384	390	391	385	1	0.0	476.279	C.0
345	386	392	393	387	1	0.0	290.591	C.0
346	387	393	394	388	1	0.0	345.295	C.0
347	388	394	395	389	1	0.0	393.699	C.0
348	389	395	396	390	1	C.0	437.055	C.0
349	390	396	397	391	1	0.0	476.280	C.C

2-33

\*\*\*\*\*  
 \*THE MAXIMUM NODE DIFFERENCE OF 17 OCCURS AT ELEMENT # 172.\*  
 \*\*\*\*\*

\*\*\*\*\*  
 TIME REMAINING, 105 SECONDS  
 \*\*\*\*\*

ELEMENT PLOTTING OCCURS HERE.

\*\*\*\*\*  
 TIME REMAINING, 96 SECONDS  
 \*\*\*\*\*

LIRIL 32

MATERIAL = 1 NC. OF TEMPERATURES AT WHICH PROPERTIES ARE SPECIFIED = 7  
MASS DENSITY = 0.0 PCRODITY = 0.0  
ANISOTROPY PARAMETER = 2

TEMP= 0.  
TENSILE PROPERTIES  
EMT= 28300000. ENT= 28300000. ETT= 28300000. NUMNT=0.0 NUMTT=0.0 NUNTT=0.0 EPT= 28300000.  
COMPRESSIVE PROPERTIES  
EMC= 28300000. ENC= 28300000. ETC= 28300000. NUMNC=0.0 NUMTC=0.0 NUNTC=0.0 EPC= 28300000.  
THERMAL AND YIELD PROPERTIES  
AM= 0.524E-05 AN= 0.524E-05 AT= 0.524E-05 YM= 0. YN= 0. YT= 0. PEPR= 0.0

TEMP= 200.  
TENSILE PROPERTIES  
EMT= 27700000. ENT= 27700000. ETT= 27700000. NUMNT=0.0 NUMTT=0.0 NUNTT=0.0 EPT= 27700000.  
COMPRESSIVE PROPERTIES  
EMC= 27700000. ENC= 27700000. ETC= 27700000. NUMNC=0.0 NUMTC=0.0 NUNTC=0.0 EPC= 27700000.  
THERMAL AND YIELD PROPERTIES  
AM= 0.572E-05 AN= 0.572E-05 AT= 0.572E-05 YM= 0. YN= 0. YT= 0. PEPR= 0.0

TEMP= 300.  
TENSILE PROPERTIES  
EMT= 27100000. ENT= 27100000. ETT= 27100000. NUMNT=0.0 NUMTT=0.0 NUNTT=0.0 EPT= 27100000.  
COMPRESSIVE PROPERTIES  
EMC= 27100000. ENC= 27100000. ETC= 27100000. NUMNC=0.0 NUMTC=0.0 NUNTC=0.0 EPC= 27100000.  
THERMAL AND YIELD PROPERTIES  
AM= 0.605E-05 AN= 0.605E-05 AT= 0.605E-05 YM= 0. YN= 0. YT= 0. PEPR= 0.0

TEMP= 400.  
TENSILE PROPERTIES  
EMT= 26600000. ENT= 26600000. ETT= 26600000. NUMNT=0.0 NUMTT=0.0 NUNTT=0.0 EPT= 26600000.  
COMPRESSIVE PROPERTIES  
EMC= 26600000. ENC= 26600000. ETC= 26600000. NUMNC=0.0 NUMTC=0.0 NUNTC=0.0 EPC= 26600000.  
THERMAL AND YIELD PROPERTIES  
AM= 0.636E-05 AN= 0.636E-05 AT= 0.636E-05 YM= 0. YN= 0. YT= 0. PEPR= 0.0

TEMP= 500.  
TENSILE PROPERTIES  
EMT= 26100000. ENT= 26100000. ETT= 26100000. NUMNT=0.0 NUMTT=0.0 NUNTT=0.0 EPT= 26100000.  
COMPRESSIVE PROPERTIES  
EMC= 26100000. ENC= 26100000. ETC= 26100000. NUMNC=0.0 NUMTC=0.0 NUNTC=0.0 EPC= 26100000.  
THERMAL AND YIELD PROPERTIES  
AM= 0.666E-05 AN= 0.666E-05 AT= 0.666E-05 YM= 0. YN= 0. YT= 0. PEPR= 0.0

TEMP= 600.  
TENSILE PROPERTIES  
EMT= 25400000. ENT= 25400000. ETT= 25400000. NUMNT=0.0 NUMTT=0.0 NUNTT=0.0 EPT= 25400000.  
COMPRESSIVE PROPERTIES  
EMC= 25400000. ENC= 25400000. ETC= 25400000. NUMNC=0.0 NUMTC=0.0 NUNTC=0.0 EPC= 25400000.  
THERMAL AND YIELD PROPERTIES  
AM= 0.694E-05 AN= 0.694E-05 AT= 0.694E-05 YM= 0. YN= 0. YT= 0. PEPR= 0.0

TEMP= 700.  
TENSILE PROPERTIES  
EMT= 24800000. ENT= 24800000. ETT= 24800000. NUMNT=0.0 NUMTT=0.0 NUNTT=0.0 EPT= 24800000.  
COMPRESSIVE PROPERTIES  
EMC= 24800000. ENC= 24800000. ETC= 24800000. NUMNC=0.0 NUMTC=0.0 NUNTC=0.0 EPC= 24800000.  
THERMAL AND YIELD PROPERTIES  
AM= 0.708E-05 AN= 0.708E-05 AT= 0.708E-05 YM= 0. YN= 0. YT= 0. PEPR= 0.0

LTR1144 38

PRESSURE BOUNDARY CONDITIONS

I	J	INT	TY
1	7	2	0
7	13		2280.0
13	19		2280.0
19	25		2280.0
25	31		2280.0
31	37		2280.0
37	43		2280.0
43	49		2280.0
49	55		2280.0
55	61		2280.0
61	67		2280.0
67	74		2280.0
74	82		2280.0
82	91		2280.0
91	101		2280.0
101	112		2280.0
112	124		2280.0
124	137		2280.0
137	151		2280.0
151	166		2280.0
166	182		2280.0
182	194		2280.0
194	206		2280.0
206	218		2280.0
218	230		2280.0
230	242		2280.0
242	254		2280.0
254	266		2280.0
266	278		2280.0
278	290		2280.0
290	302		2280.0
302	314		2280.0
314	326		2280.0
326	338		2280.0
338	350		2280.0
350	362		2280.0
362	368		2280.0
368	374		2280.0
374	380		2280.0
380	386		2280.0
386	392		2280.0
171	172		2250.0
172	173		2250.0
173	174		2250.0
174	188		2250.0
188	200		2250.0
200	212		2250.0
212	224		2250.0
224	236		2250.0
236	248		2250.0
248	260		2250.0
260	272		2250.0
272	284		2250.0
284	296		2250.0
296	308		2250.0
308	320		2250.0
320	332		2250.0
332	344		2250.0
344	356		2250.0
171	187		2250.0
187	199		2250.0
199	211		2250.0

LTR1144 38

211	223	2250.0
223	235	2250.0
235	247	2250.0
247	259	2250.0
259	271	2250.0
271	283	2250.0
283	295	2250.0
295	307	2250.0
307	319	2250.0
319	331	2250.0
331	343	2250.0
343	355	2250.0
355	367	2250.0
367	373	2250.0
373	379	2250.0
379	385	2250.0
385	391	2250.0
391	397	2250.0

\*\*\*\*\*

\* TIME REMAINING AT BEGINNING OF SOLUTION IS 96 SECONDS.

\*\*\*\*\*

C-36

LFR1144 38

## NCCAL POINT

UR

UZ

1	0.3822387C-03	0.2608009C-01
2	0.4163501C-03	0.2608053C-01
3	0.4519277C-03	0.2608111C-01
4	0.4884840C-03	0.2608169C-01
5	0.5257794C-03	0.2608220C-01
6	0.5635959C-03	0.2608260C-01
7	0.3836924C-03	0.2592927C-01
8	0.4178569C-03	0.2592956C-01
9	0.4534064C-03	0.2592987C-01
10	0.4899499C-03	0.2593018C-01
11	0.5272203C-03	0.2593049C-01
12	0.5650239C-03	0.2593078C-01
13	0.3844996C-03	0.2577823C-01
14	0.4186621C-03	0.2577842C-01
15	0.4542137C-03	0.2577863C-01
16	0.4907674C-03	0.2577885C-01
17	0.5280496C-03	0.2577906C-01
18	0.5658583C-03	0.2577926C-01
19	0.3852718C-03	0.2562689C-01
20	0.4194382C-03	0.2562709C-01
21	0.4549958C-03	0.2562727C-01
22	0.4915528C-03	0.2562744C-01
23	0.5288344C-03	0.2562762C-01
24	0.5666420C-03	0.2562782C-01
25	0.3861312C-03	0.2547594C-01
26	0.4203008C-03	0.2547602C-01
27	0.4558638C-03	0.2547601C-01
28	0.4924237C-03	0.2547597C-01
29	0.5297066C-03	0.2547598C-01
30	0.5675146C-03	0.2547606C-01
31	0.3859967C-03	0.2532641C-01
32	0.4201653C-03	0.2532588C-01
33	0.4557270C-03	0.2532519C-01
34	0.4922886C-03	0.2532445C-01
35	0.5295734C-03	0.2532378C-01
36	0.5673823C-03	0.2532326C-01
37	0.3820338C-03	0.2517911C-01
38	0.4161858C-03	0.2517707C-01
39	0.4517152C-03	0.2517487C-01
40	0.4882535C-03	0.2517261C-01

C-37

LTR1144 38

NODAL POINT

	UR	UZ
41	0.5255342C-03	0.2517C4CC-01
42	0.5633442C-03	0.2516E34C-01
43	0.3696174C-03	0.2503386C-01
44	0.4037292C-03	0.25C2934C-01
45	0.4391886C-03	0.2502496C-01
46	0.4756813C-03	0.2502061C-01
47	0.5129415C-03	0.25C1622C-01
48	0.5507549C-03	0.25C1168C-01
49	0.3453188C-03	0.2488572C-01
50	0.3793755C-03	0.2487947C-01
51	0.4147719C-03	0.2487431C-01
52	0.4513106C-03	0.2486931C-01
53	0.4887232C-03	0.2486375C-01
54	0.5265822C-03	0.2485727C-01
55	0.3183702C-03	0.2471996C-01
56	0.3521069C-03	0.2471822C-01
57	0.3867592C-03	0.2471903C-01
58	0.4223253C-03	0.2472047C-01
59	0.4589154C-03	0.2472040C-01
60	0.4967629C-03	0.2471588C-01
61	0.3275005C-03	0.2451951C-01
62	0.3615280C-03	0.2453264C-01
63	0.3959006C-03	0.2455138C-01
64	0.4302673C-03	0.2457207C-01
65	0.4643884C-03	0.2459532C-01
66	0.4981833C-03	0.2462109C-01
67	0.4178651C-03	0.2428153C-01
68	0.4558039C-03	0.2431449C-01
69	0.4973039C-03	0.2435144C-01
70	0.5415000C-03	0.2439286C-01
71	0.5877557C-03	0.2443952C-01
72	0.6355766C-03	0.2449268C-01
73	0.6661418C-03	0.2463488C-01
74	0.5684971C-03	0.2400668C-01
75	0.6122041C-03	0.2405090C-01
76	0.6638217C-03	0.2409971C-01
77	0.7215820C-03	0.2415328C-01
78	0.7840955C-03	0.2421189C-01
79	0.8501420C-03	0.2427579C-01
80	0.8996919C-03	0.2444842C-01

C-38

LFR1144 38

NCCAL POINT

UR

UZ

81	0.9409672C-03	0.2465001C-01
82	C.7473031D-03	0.2368906C-01
83	0.7966672C-03	0.2373747C-01
84	0.8582876C-03	0.2379021C-01
85	C.9294917C-03	0.2384731C-01
86	0.1008290C-02	C.2390890C-01
87	0.1093151C-02	0.2397522C-01
88	0.1171085C-02	0.2415679C-01
89	0.1253472C-02	C.2438886C-01
90	0.1309920C-02	0.2464483C-01
91	C.9348306C-03	0.2333185C-01
92	0.9886347C-03	0.2338016C-01
93	0.1058415C-02	0.2343150C-01
94	0.1140641C-02	0.2348613C-01
95	0.1232765C-02	0.2354432C-01
96	0.1332902C-02	0.2360632C-01
97	0.1433422C-02	0.2377976C-01
98	0.1561422C-02	0.2402402C-01
99	0.1675280C-02	C.2429081C-01
100	0.1764808C-02	0.2458061C-01
101	0.1119738C-02	0.2294948C-01
102	0.1176608C-02	0.2299456C-01
103	0.1252326C-02	0.2304042C-01
104	0.1342594C-02	0.2308779C-01
105	0.1444403C-02	0.2313735C-01
106	0.1555514C-02	0.2318970C-01
107	0.1668642C-02	0.2334336C-01
108	C.1833630C-02	0.2358323C-01
109	0.1993975C-02	0.2334665C-01
110	0.2142116C-02	0.2413265C-01
111	C.2268205C-02	0.2444122C-01
112	0.1290375C-02	0.2256661C-01
113	0.1349256C-02	0.2260360C-01
114	0.1429225C-02	0.2263847C-01
115	0.1525480C-02	0.2267280C-01
116	0.1634690C-02	0.2270785C-01
117	0.1754388C-02	0.2274454C-01
118	0.1872633C-02	0.2287059C-01
119	0.2066532C-02	0.2309222C-01
120	0.2261640C-02	0.2334045C-01

C-39

LTR1144 38

NCCAL PCINT

UR

UZ

121	0.2452772C-02	0.2361443C-01
122	0.2632595C-02	0.2391181C-01
123	0.2794188C-02	0.2422898C-01
124	0.1418456C-02	0.2221397C-01
125	0.1478924C-02	0.2223276C-01
126	0.1562605C-02	0.2224843C-01
127	0.1664535C-02	0.2226283C-01
128	0.1781105C-02	0.2227734C-01
129	0.1909500C-02	0.2229307C-01
130	0.2118768C-02	0.2244876C-01
131	0.2259768C-02	0.2257209C-01
132	0.2485204C-02	0.2279290C-01
133	0.2709565C-02	0.2304640C-01
134	0.2927441C-02	0.2332821C-01
135	0.3134433C-02	0.2363318C-01
136	0.3326477C-02	0.2395488C-01
137	0.1444531C-02	0.2189735C-01
138	0.1507868C-02	0.2188606C-01
139	0.1597195C-02	0.2187590C-01
140	0.1707704C-02	0.2186592C-01
141	0.1835760C-02	0.2185554C-01
142	0.1978356C-02	0.2184475C-01
143	0.2237310C-02	0.2195392C-01
144	0.2493067C-02	0.2210199C-01
145	0.2663068C-02	0.2222207C-01
146	0.2922418C-02	0.2244619C-01
147	0.3174778C-02	0.2270637C-01
148	0.3417189C-02	0.2299578C-01
149	0.3646524C-02	0.2330816C-01
150	0.3861058C-02	0.2363621C-01
151	0.1323021C-02	0.2155545C-01
152	0.1389248C-02	0.2151697C-01
153	0.1482213C-02	0.2148430C-01
154	0.1597153C-02	0.2145227C-01
155	0.1730773C-02	0.2141670C-01
156	0.1880596C-02	0.2127387C-01
157	0.2220101C-02	0.2142450C-01
158	0.2562467C-02	0.2152065C-01
159	0.2880705C-02	0.2167657C-01
160	0.3082908C-02	0.2181012C-01

Q-40

LTR1144 38

NODAL POINT	UR	UZ
161	0.3381009C-02	0.2205733C-01
162	0.3664738C-02	0.2233051C-01
163	0.3931319C-02	0.2252988C-01
164	0.4180062C-02	0.2255087C-01
165	0.4409414C-02	0.2229035C-01
166	0.1131051C-02	0.2112367C-01
167	0.1196602C-02	0.2108642C-01
168	0.1284865C-02	0.2105112C-01
169	0.1390750C-02	0.2101415C-01
170	0.1510642C-02	0.2097145C-01
171	0.1641990C-02	0.2091739C-01
172	0.1927869C-02	0.2106948C-01
173	0.2256842C-02	0.2127023C-01
174	0.2757654C-02	0.2123628C-01
175	0.3355720C-02	0.2115589C-01
176	0.3575541C-02	0.2132878C-01
177	0.3896178C-02	0.2161773C-01
178	0.4199435C-02	0.2191913C-01
179	0.4484710C-02	0.2223414C-01
180	0.4751187C-02	0.2256592C-01
181	0.4994628C-02	0.2291881C-01
182	0.1028135C-02	0.2064715C-01
183	0.1093845C-02	0.2063158C-01
184	0.1182901C-02	0.2061399C-01
185	0.1291067C-02	0.2059592C-01
186	0.1415734C-02	0.2057925C-01
187	0.1555692C-02	0.2056760C-01
188	0.4170420C-02	0.2082177C-01
189	0.4469577C-02	0.2116921C-01
190	0.4760958C-02	0.2151659C-01
191	0.5044677C-02	0.2186785C-01
192	0.5313898C-02	0.2223252C-01
193	0.5563423C-02	0.2261877C-01
194	0.1007911C-02	0.2019273C-01
195	0.1073621C-02	0.2019120C-01
196	0.1162974C-02	0.2018793C-01
197	0.1271792C-02	0.2018428C-01
198	0.1396916C-02	0.2018135C-01
199	0.1535725C-02	0.2017961C-01
200	0.4767221C-02	0.2032955C-01

15-2

LTR1144 38

NODAL POINT

UR

UZ

201	0.50617880-02	0.20667770-01
202	0.53652960-02	0.20995190-01
203	0.56679170-02	0.21324740-01
204	0.59650370-02	0.21662410-01
205	0.62497440-02	0.22014880-01
206	0.10165310-02	0.19763690-01
207	0.10822260-02	0.19766120-01
208	0.11714850-02	0.19767810-01
209	0.12801110-02	0.19769250-01
210	0.14050140-02	0.19770950-01
211	0.15439490-02	0.19773470-01
212	0.53076850-02	0.19866040-01
213	0.56142000-02	0.20183130-01
214	0.59233580-02	0.20500020-01
215	0.62343690-02	0.20818900-01
216	0.65451730-02	0.21141530-01
217	0.68553580-02	0.21465670-01
218	0.10283090-02	0.19345840-01
219	0.10940490-02	0.19348180-01
220	0.11833910-02	0.19350340-01
221	0.12920880-02	0.19352450-01
222	0.14170470-02	0.19354670-01
223	0.15559690-02	0.19357080-01
224	0.62725080-02	0.18875220-01
225	0.65985090-02	0.19158990-01
226	0.69256950-02	0.19445120-01
227	0.72543300-02	0.19732790-01
228	0.75846820-02	0.20020820-01
229	0.79167690-02	0.20308080-01
230	0.10357560-02	0.18931220-01
231	0.11015240-02	0.18932510-01
232	0.11909190-02	0.18933850-01
233	0.12596540-02	0.18935200-01
234	0.14246190-02	0.18936540-01
235	0.15635440-02	0.18937860-01
236	0.71275950-02	0.17797090-01
237	0.74687580-02	0.18054860-01
238	0.78103410-02	0.18316270-01
239	0.81528580-02	0.18579820-01
240	0.84971300-02	0.18843280-01

C-72

LTR 1144 38

NODAL POINT

UR

UZ

241	0.8844436C-02	0.1910378C-01
242	0.1038805C-02	0.1851661C-01
243	0.1104584C-02	0.1851706C-01
244	0.1193997C-02	0.1851760C-01
245	0.1302744C-02	0.1851816C-01
246	0.1427712C-02	0.1851869C-01
247	0.1566634C-02	0.1851914C-01
248	0.1735268C-02	0.1747804C-01
249	0.1776576C-02	0.1763341C-01
250	0.1817966C-02	0.1779207C-01
251	0.1859546C-02	0.1795095C-01
252	0.1901363C-02	0.1810876C-01
253	0.1943449C-02	0.1826526C-01
254	0.1039395C-02	0.1810071C-01
255	0.1105177C-02	0.1810076C-01
256	0.1194595C-02	0.1810085C-01
257	0.1303345C-02	0.1810096C-01
258	0.1428313C-02	0.1810105C-01
259	0.1567235C-02	0.1810109C-01
260	0.1742304C-02	0.1658786C-01
261	0.1847408C-02	0.1661605C-01
262	0.1827375C-02	0.1664555C-01
263	0.1870177C-02	0.1667555C-01
264	0.1913139C-02	0.1670563C-01
265	0.1956256C-02	0.1673592C-01
266	0.1039107C-02	0.1768405C-01
267	0.1104888C-02	0.1768397C-01
268	0.1194305C-02	0.1768391C-01
269	0.1303052C-02	0.1768386C-01
270	0.1428020C-02	0.1768380C-01
271	0.1566942C-02	0.1768371C-01
272	0.1752701C-02	0.1453954C-01
273	0.1795135C-02	0.1455535C-01
274	0.1837796C-02	0.1457149C-01
275	0.1880647C-02	0.1458779C-01
276	0.1923659C-02	0.1460398C-01
277	0.1966805C-02	0.1461965C-01
278	0.1038717C-02	0.1726729C-01
279	0.1104496C-02	0.1726721C-01
280	0.1193910C-02	0.1726713C-01

C-4/3

LTR1144 38

NOCAL PCINT

UR

UZ

281	0.1302656C-02	0.1726705C-01
282	0.1427623C-02	0.1726697C-01
283	0.1566545C-02	0.1726688C-01
284	0.7570862C-02	0.1248290C-01
285	0.7995193C-02	0.1248831C-01
286	0.8421743C-02	0.1249442C-01
287	0.8850165C-02	0.1250071C-01
288	0.9280176C-02	0.1250675C-01
289	0.9711567C-02	0.1251210C-01
290	0.1038431C-02	0.1685023C-01
291	0.1104209C-02	0.1685016C-01
292	0.1193621C-02	0.1685008C-01
293	0.1302365C-02	0.1685000C-01
294	0.1427331C-02	0.1684993C-01
295	0.1566252C-02	0.1684985C-01
296	0.7579245C-02	0.1041368C-01
297	0.8003588C-02	0.1041387C-01
298	0.8430165C-02	0.1041493C-01
299	0.8858599C-02	0.1041533C-01
300	0.9288606C-02	0.1041596C-01
301	0.9719994C-02	0.1041613C-01
302	0.1038157C-02	0.1643322C-01
303	0.1103934C-02	0.1643313C-01
304	0.1193344C-02	0.1643304C-01
305	0.1302087C-02	0.1643295C-01
306	0.1427053C-02	0.1643286C-01
307	0.1565974C-02	0.1643277C-01
308	0.7573366C-02	0.8335941C-02
309	0.7997702C-02	0.8334386C-02
310	0.8424269C-02	0.8333064C-02
311	0.8852697C-02	0.8331809C-02
312	0.9282702C-02	0.8330468C-02
313	0.9714085C-02	0.8328892C-02
314	0.1037733C-02	0.1601649C-01
315	0.1103508C-02	0.1601636C-01
316	0.1192916C-02	0.1601626C-01
317	0.1301658C-02	0.1601615C-01
318	0.1426625C-02	0.1601604C-01
319	0.1565547C-02	0.1601591C-01
320	0.7564940C-02	0.6253079C-02

0-44

LTR1144 38

NOCAL POINT

UR

LZ

321	0.7989271C-02	0.6251499C-02
322	0.8415827C-02	0.6245955C-02
323	0.8844246C-02	0.6248512C-02
324	0.9274249C-02	0.6247001C-02
325	0.9705633C-02	0.6245413C-02
326	0.1037167C-02	0.1559931C-01
327	0.1102940C-02	0.1559922C-01
328	0.1192344C-02	0.1559917C-01
329	0.1301083C-02	0.1559912C-01
330	0.1426049C-02	0.1559906C-01
331	0.1564970C-02	0.1559896C-01
332	0.7558586C-02	0.4168743C-02
333	0.7982913C-02	0.4167700C-02
334	0.8409462C-02	0.4166660C-02
335	0.8837878C-02	0.4165620C-02
336	0.9267885C-02	0.4164577C-02
337	0.9699273C-02	0.4163529C-02
338	0.1036922C-02	0.1518150C-01
339	0.1102695C-02	0.1518166C-01
340	0.1192097C-02	0.1518191C-01
341	0.1300835C-02	0.1518218C-01
342	0.1425798C-02	0.1518242C-01
343	0.1564718C-02	0.1518257C-01
344	0.7555111C-02	0.2084287C-02
345	0.7979430C-02	0.2083807C-02
346	0.8405968C-02	0.2083314C-02
347	0.8834375C-02	0.2082816C-02
348	0.9264374C-02	0.2082320C-02
349	0.9695754C-02	0.2081832C-02
350	0.1038383C-02	0.1476271C-01
351	0.1104161C-02	0.1476360C-01
352	0.1193574C-02	0.1476459C-01
353	0.1302317C-02	0.1476562C-01
354	0.1427281C-02	0.1476662C-01
355	0.1566201C-02	0.1476751C-01
356	0.7554054C-02	0.0
357	0.7978272C-02	0.0
358	0.8405097C-02	0.0
359	0.8833304C-02	0.0
360	0.9263587C-02	0.0

C-45

LTR1144 38

NCCAL PCINT

UR

UZ

361	0.9694655C-02	0.C
362	0.1044051C-02	0.1434228C-01
363	0.1109850C-02	0.1434450C-01
364	0.1199301C-02	0.1434672C-01
365	0.1308069C-02	0.1434894C-01
366	0.1433038C-02	0.1435118C-01
367	0.1571956C-02	0.1435343C-01
368	0.1056383C-02	0.1392233C-01
369	0.1122223C-02	0.1392590C-01
370	0.1211749C-02	0.1392905C-01
371	0.1320571C-02	0.1393209C-01
372	0.1445556C-02	0.1393533C-01
373	0.1584475C-02	0.1393899C-01
374	0.1073379C-02	0.1350954C-01
375	0.1139304C-02	0.1351222C-01
376	0.1228971C-02	0.1351356C-01
377	0.1337880C-02	0.1351451C-01
378	0.1462878C-02	0.1351602C-01
379	0.1601786C-02	0.1351891C-01
380	0.1079487C-02	0.1311655C-01
381	0.1145301C-02	0.1311121C-01
382	0.1234833C-02	0.1310310C-01
383	0.1343798C-02	0.1309426C-01
384	0.1469012C-02	0.1308628C-01
385	0.1608058C-02	0.1308097C-01
386	0.1030873C-02	0.1276153C-01
387	0.1097029C-02	0.1273240C-01
388	0.1186786C-02	0.1270162C-01
389	0.1295147C-02	0.1267020C-01
390	0.1419234C-02	0.1263934C-01
391	0.1557688C-02	0.1261017C-01
392	0.8582712C-03	0.1244208C-01
393	0.9229122C-03	0.1238398C-01
394	0.1010759C-02	0.1231186C-01
395	0.1119463C-02	0.1223724C-01
396	0.1245713C-02	0.1216828C-01
397	0.1385452C-02	0.1211250C-01

2-46

LTR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAMAX	SIGMAMIN	ANGLE	SIGMAP	SIGMAN	SIGMAMN	SIGMAINT
1	0.43	9.02	-1865.	107.	4832.	0.	107.	-1865.	90.00	-1865.	107.	0.	6697.
2	0.48	9.02	-1207.	26.	4068.	21.	26.	-1207.	89.03	-1207.	26.	21.	5274.
3	0.53	9.02	-732.	-18.	3516.	21.	-18.	-732.	88.30	-732.	-18.	21.	4248.
4	0.58	9.02	-379.	-39.	3115.	13.	-39.	-380.	87.79	-379.	-39.	13.	3494.
5	0.63	9.02	-112.	-42.	2826.	-4.	-42.	-112.	-86.83	-112.	-42.	-4.	2938.
6	0.43	8.82	-1862.	147.	4905.	12.	147.	-1862.	89.65	-1862.	147.	12.	6766.
7	0.48	8.82	-1203.	51.	4134.	16.	51.	-1203.	89.27	-1203.	51.	16.	5336.
8	0.53	8.82	-732.	-19.	3576.	16.	-18.	-732.	88.69	-732.	-19.	16.	4308.
9	0.58	8.82	-382.	-59.	3170.	16.	-58.	-383.	87.24	-382.	-59.	16.	3552.
10	0.63	8.82	-113.	-70.	2876.	10.	-68.	-115.	78.16	-113.	-70.	10.	2991.
11	0.43	8.62	-1861.	167.	4955.	1.	167.	-1861.	89.98	-1861.	167.	1.	6816.
12	0.48	8.62	-1200.	60.	4179.	1.	60.	-1200.	89.98	-1200.	60.	1.	5379.
13	0.53	8.62	-728.	-17.	3617.	-1.	-17.	-728.	-89.90	-728.	-17.	-1.	4345.
14	0.58	8.62	-379.	-64.	3208.	0.	-64.	-379.	89.97	-379.	-64.	0.	3587.
15	0.63	8.62	-113.	-87.	2911.	1.	-87.	-113.	88.18	-113.	-87.	1.	3023.
16	0.43	8.42	-1859.	123.	5008.	-21.	123.	-1859.	-89.39	-1859.	123.	-21.	6867.
17	0.48	8.42	-1197.	35.	4226.	-36.	36.	-1198.	-88.31	-1197.	35.	-36.	5424.
18	0.53	8.42	-727.	-20.	3660.	-42.	-18.	-729.	-86.60	-727.	-20.	-42.	4389.
19	0.58	8.42	-379.	-47.	3247.	-35.	-43.	-383.	-84.00	-379.	-47.	-35.	3630.
20	0.63	8.42	-113.	-51.	2948.	-20.	-45.	-119.	-73.31	-113.	-51.	-20.	3066.
21	0.43	8.22	-1858.	-28.	5031.	-52.	-26.	-1860.	-88.36	-1858.	-28.	-52.	6891.
22	0.48	8.22	-1196.	-48.	4247.	-87.	-41.	-1203.	-85.67	-1196.	-48.	-87.	5449.
23	0.53	8.22	-725.	-34.	3680.	-98.	-20.	-739.	-82.06	-725.	-34.	-98.	4418.
24	0.58	8.22	-378.	8.	3265.	-84.	26.	-355.	-78.23	-378.	8.	-84.	3660.
25	0.63	8.22	-112.	73.	2964.	-50.	85.	-125.	-75.78	-112.	73.	-50.	3088.
26	0.43	8.02	-1863.	-286.	4900.	-79.	-282.	-1867.	-87.13	-1863.	-286.	-79.	6766.
27	0.48	8.02	-1205.	-186.	4129.	-125.	-171.	-1220.	-83.13	-1205.	-186.	-125.	5348.
28	0.53	8.02	-731.	-58.	3572.	-137.	-31.	-758.	-78.92	-731.	-58.	-137.	4329.
29	0.58	8.02	-379.	99.	3166.	-119.	128.	-407.	-76.74	-379.	99.	-119.	3572.
30	0.63	8.02	-112.	287.	2873.	-77.	302.	-126.	-79.48	-112.	287.	-77.	2998.
31	0.43	7.82	-1879.	-503.	4375.	-46.	-501.	-1880.	-88.07	-1879.	-503.	-46.	6254.
32	0.48	7.82	-1233.	-289.	3656.	-47.	-287.	-1235.	-87.13	-1233.	-289.	-47.	4891.
33	0.53	7.82	-749.	-76.	3142.	-46.	-73.	-752.	-86.13	-749.	-76.	-46.	3893.
34	0.58	7.82	-384.	166.	2772.	-42.	169.	-388.	-85.65	-384.	166.	-42.	3159.
35	0.63	7.82	-109.	464.	2510.	-42.	467.	-112.	-85.86	-109.	464.	-42.	2622.
36	0.43	7.62	-1907.	-144.	3196.	194.	-123.	-1928.	83.78	-1907.	-144.	194.	5124.
37	0.48	7.62	-1273.	-81.	2595.	368.	23.	-1377.	74.17	-1273.	-81.	368.	3972.
38	0.53	7.62	-753.	-64.	2177.	396.	116.	-934.	65.50	-753.	-64.	396.	3110.
39	0.58	7.62	-352.	9.	1892.	305.	182.	-526.	60.32	-352.	9.	305.	2417.
40	0.63	7.62	-99.	200.	1701.	150.	262.	-162.	67.50	-99.	200.	150.	1862.

C-47

LTR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAPAX	SIGMAPIN	ANGLE	SIGMAP	SIGMAN	SIGMAPN	SIGMAINT
41	0.43	7.42	-2005.	1858.	1556.	770.	2006.	-2153.	79.12	-2005.	1858.	770.	4158.
42	0.48	7.42	-1491.	1021.	1107.	1311.	1580.	-2051.	66.88	-1491.	1021.	1311.	3631.
43	0.53	7.42	-1006.	77.	805.	1480.	1111.	-2041.	55.05	-1006.	77.	1480.	3151.
44	0.58	7.42	-538.	-805.	615.	1255.	590.	-1933.	41.96	-538.	-805.	1255.	2548.
45	0.63	7.42	-95.	-1350.	514.	540.	105.	-1550.	20.36	-95.	-1350.	540.	2064.
46	0.43	7.22	-2019.	5867.	578.	1073.	6010.	-2163.	82.39	-2019.	5867.	1073.	8172.
47	0.48	7.22	-1726.	3540.	625.	1927.	4170.	-2357.	71.90	-1726.	3540.	1927.	6526.
48	0.53	7.22	-1510.	1000.	385.	2473.	2518.	-3028.	58.46	-1510.	1000.	2473.	5546.
49	0.58	7.22	-1306.	-1957.	220.	2744.	1132.	-4395.	41.62	-1306.	-1957.	2744.	5526.
50	0.63	7.22	-1036.	-5656.	121.	2703.	209.	-6901.	24.74	-1036.	-5656.	2703.	7110.
51	0.43	7.02	-1839.	9878.	3240.	125.	9879.	-1841.	89.39	-1839.	9878.	125.	11719.
52	0.48	7.02	-1381.	6619.	2145.	795.	6697.	-1459.	84.38	-1381.	6619.	795.	8155.
53	0.53	7.02	-1147.	3346.	1338.	1234.	3663.	-1463.	75.61	-1147.	3346.	1234.	5126.
54	0.58	7.02	-1042.	-101.	749.	1550.	1049.	-2191.	53.45	-1042.	-101.	1550.	3239.
55	0.63	7.02	-984.	-3891.	237.	1891.	-53.	-4823.	26.23	-984.	-3891.	1891.	5159.
56	0.70	6.99	-3620.	-6566.	-21.	8060.	3100.	-13286.	39.82	-3620.	-6566.	8060.	16386.
57	0.43	6.82	-1583.	13015.	6649.	59.	13015.	-1583.	89.77	-1583.	13015.	59.	14598.
58	0.48	6.82	-601.	9212.	5554.	694.	9261.	-650.	85.97	-601.	9212.	694.	9911.
59	0.53	6.82	-41.	5679.	3213.	1147.	5900.	-262.	79.08	-41.	5679.	1147.	6162.
60	0.58	6.82	261.	2456.	1445.	1530.	3242.	-524.	62.82	261.	2456.	1530.	3766.
61	0.63	6.82	387.	-366.	137.	1962.	2008.	-1987.	39.57	387.	-366.	1962.	3994.
62	0.70	6.79	204.	-3765.	-1247.	5909.	4454.	-8014.	35.72	204.	-3765.	5909.	12467.
63	0.72	6.91	386.	-3607.	-642.	-630.	483.	-3704.	-8.76	386.	-3607.	-630.	4186.
64	0.79	6.84	-619.	-7683.	-1520.	6873.	3577.	-11879.	31.40	-619.	-7683.	6873.	15455.
65	0.43	6.62	-1249.	16519.	16455.	251.	16523.	-1252.	89.19	-1249.	16519.	251.	17775.
66	0.48	6.62	275.	11887.	10838.	935.	11962.	200.	85.42	275.	11887.	935.	11761.
67	0.53	6.62	1046.	7819.	6495.	1374.	8087.	778.	78.96	1046.	7819.	1374.	7308.
68	0.58	6.62	1343.	4300.	3100.	1653.	5039.	603.	65.90	1343.	4300.	1653.	4436.
69	0.63	6.62	1338.	1327.	460.	1817.	3150.	-484.	44.91	1338.	1327.	1817.	3634.
70	0.70	6.59	3135.	-3198.	-2158.	4407.	5395.	-5459.	27.15	3135.	-3198.	4407.	10853.
71	0.72	6.70	-301.	-463.	-2246.	-676.	299.	-1063.	-41.57	-301.	-463.	-676.	2544.
72	0.78	6.64	2190.	-6072.	-3932.	4509.	4174.	-8056.	23.75	2190.	-6072.	4509.	12230.
73	0.83	6.2	-206.	-5836.	-3251.	2574.	794.	-6835.	21.22	-206.	-5836.	2574.	7629.
74	0.43	6.42	-760.	19936.	25891.	246.	19939.	-763.	89.32	-760.	19936.	246.	26653.
75	0.48	6.42	1459.	14436.	17903.	819.	14488.	1408.	86.40	1459.	14436.	819.	16495.
76	0.53	6.42	2546.	9750.	11680.	1200.	9944.	2352.	80.79	2546.	9750.	1200.	9328.
77	0.58	6.42	2950.	5804.	6753.	1460.	6419.	2336.	67.18	2950.	5804.	1460.	4416.
78	0.63	6.42	2930.	2514.	2790.	1638.	4373.	1070.	41.38	2930.	2514.	1638.	3302.
79	0.69	6.39	5336.	-2377.	-614.	3004.	6368.	-3409.	18.96	5336.	-2377.	3004.	9776.
80	0.71	6.50	120.	304.	-2620.	263.	491.	-66.	54.62	120.	304.	263.	3110.

2-58

LTR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAMAX	SIGMAMIN	ANGLE	SIGMAP	SIGMAN	SIGMAMN	SIGMAINT
81	0.77	6.44	3912.	-5595.	-4591.	3372.	4987.	-6669.	17.67	3912.	-5595.	3372.	11656.
82	0.82	6.52	1094.	-4811.	-5558.	1710.	1554.	-5271.	15.64	1094.	-4811.	1710.	7111.
83	0.91	6.57	-167.	-4681.	-5974.	1853.	497.	-5344.	19.69	-167.	-4681.	1853.	6470.
84	0.43	6.22	-156.	22076.	26289.	24.	22076.	-156.	89.94	-156.	22076.	24.	36445.
85	0.48	6.22	2903.	16103.	26357.	237.	16107.	2899.	88.97	2903.	16103.	237.	23458.
86	0.53	6.22	4451.	11149.	18635.	412.	11174.	4425.	86.50	4451.	11149.	412.	14209.
87	0.58	6.22	5055.	7031.	12449.	587.	7192.	4894.	74.65	5055.	7031.	587.	7555.
88	0.63	6.22	5067.	3628.	7402.	775.	5405.	3290.	23.58	5067.	3628.	775.	4112.
89	0.69	6.19	7471.	-1145.	3493.	1112.	7612.	-1286.	7.23	7471.	-1145.	1112.	8898.
90	0.71	6.30	1759.	946.	-136.	721.	2210.	535.	29.70	1799.	946.	721.	2345.
91	0.77	6.23	5567.	-4709.	-2280.	2084.	5974.	-5116.	11.04	5567.	-4709.	2084.	11089.
92	0.82	6.31	2428.	-4131.	-5132.	1589.	2792.	-4496.	12.93	2428.	-4131.	1589.	7924.
93	0.91	6.37	1038.	-4961.	-7827.	1722.	1497.	-5420.	14.93	1038.	-4961.	1722.	9324.
94	1.00	6.42	73.	-3329.	-8309.	1115.	406.	-3662.	16.62	73.	-3329.	1115.	8714.
95	0.43	6.02	434.	21657.	46768.	-511.	21669.	421.	-88.62	434.	21657.	-511.	46346.
96	0.48	6.02	4350.	15867.	35276.	-901.	15937.	4280.	-85.56	4350.	15867.	-901.	30995.
97	0.53	6.02	6433.	11193.	26368.	-1107.	11438.	6188.	-77.53	6433.	11193.	-1107.	20180.
98	0.58	6.02	7360.	7378.	19206.	-1161.	8530.	6208.	-45.22	7360.	7378.	-1161.	12997.
99	0.63	6.02	7541.	4295.	13331.	-1098.	7878.	3959.	-17.03	7541.	4295.	-1098.	9372.
100	0.69	5.99	9888.	-22.	9076.	-1597.	10139.	-273.	-8.93	9888.	-22.	-1597.	10411.
101	0.70	6.10	4101.	1802.	4623.	45.	4102.	1801.	1.13	4101.	1802.	45.	2821.
102	0.76	6.03	7759.	-3586.	2154.	-34.	7759.	-3586.	-0.17	7759.	-3586.	-34.	11344.
103	0.81	6.11	4335.	-2948.	-2055.	683.	4398.	-3012.	5.31	4335.	-2948.	683.	7409.
104	0.90	6.16	2321.	-4525.	-6735.	1407.	2599.	-4803.	11.18	2321.	-4525.	1407.	9334.
105	1.00	6.22	910.	-4388.	-9261.	1502.	1306.	-4784.	14.77	910.	-4388.	1502.	10566.
106	1.09	6.27	106.	-2137.	-9758.	697.	305.	-2336.	15.94	106.	-2137.	697.	10063.
107	0.43	5.82	1065.	17888.	55885.*	-1186.	17971.	981.	-85.99	1065.	17888.	-1186.	54903.*
108	0.48	5.82	5956.	13173.	42305.	-2067.	13723.	5406.	-75.10	5956.	13173.	-2067.	37898.
109	0.53	5.82	8827.	9340.	33597.	-2609.	11706.	6462.	-47.81	8827.	9340.	-2609.	27135.
110	0.58	5.82	10375.	6210.	25824.	-2922.	11881.	4704.	-27.26	10375.	6210.	-2922.	21119.
111	0.63	5.82	11016.	3695.	19467.	-3061.	12127.	2584.	-19.95	11016.	3695.	-3061.	16882.
112	0.70	5.79	14830.	-1200.	13631.	-3701.	15643.	-2014.	-12.39	14830.	-1200.	-3701.	17656.
113	0.71	5.90	6662.	2500.	9783.	-2382.	7743.	1418.	-24.43	6662.	2500.	-2382.	8364.
114	0.77	5.83	11088.	-2638.	7102.	-2215.	11437.	-2987.	-8.94	11088.	-2638.	-2215.	14423.
115	0.81	5.91	7259.	-1537.	2742.	-1241.	7431.	-1708.	-7.88	7259.	-1537.	-1241.	9139.
116	0.90	5.96	4513.	-3201.	-3427.	18.	4513.	-3201.	0.14	4513.	-3201.	18.	7940.
117	0.99	6.01	2318.	-3914.	-7582.	985.	2470.	-4066.	8.77	2318.	-3914.	985.	10051.
118	1.08	6.07	681.	-3376.	-9894.	1303.	1064.	-3759.	18.36	681.	-3376.	1303.	10957.
119	1.17	6.12	-61.	-1329.	-10460.	576.	162.	-1552.	21.14	-61.	-1329.	576.	10621.
120	0.43	5.62	1755.	13218.	60258.*	-854.	13281.	1691.	-85.76	1755.	13218.	-854.	58566.*

0-49

LTR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAMAX	SIGMAPIN	ANGLE	SIGMAP	SIGMAN	SIGMAMN	SIGMAINT
121	0.48	5.62	7709.	9541.	47075.	-1405.	10302.	6948.	-61.56	7709.	9541.	-1405.	40127.
122	0.53	5.62	11638.	6231.	26971.	-2017.	12307.	5562.	-18.36	11638.	6231.	-2017.	31408.
123	0.58	5.62	14158.	3473.	28948.	-2716.	14809.	2822.	-13.47	14158.	3473.	-2716.	26126.
124	0.63	5.62	15627.	1405.	22444.	-3446.	16418.	614.	-12.93	15627.	1405.	-3446.	21830.
125	0.70	5.60	21724.	-3330.	16275.	-5002.	22686.	-4292.	-10.88	21724.	-3330.	-5002.	26977.
126	0.72	5.71	9615.	2135.	13386.	-2930.	10626.	1124.	-19.04	9615.	2135.	-2930.	12261.
127	0.79	5.64	18158.	-3373.	9522.	-4070.	18901.	-4117.	-10.36	18158.	-3373.	-4070.	23018.
128	0.82	5.71	12090.	-368.	6838.	-3069.	12805.	-1083.	-13.11	12090.	-368.	-3069.	13887.
129	0.89	5.76	9113.	-1274.	1583.	-2093.	9519.	-1680.	-10.98	9113.	-1274.	-2093.	11198.
130	0.98	5.81	5919.	-2333.	-3741.	-519.	5951.	-2366.	-3.59	5919.	-2333.	-519.	9691.
131	1.08	5.86	3123.	-2757.	-7459.	578.	3179.	-2814.	5.56	3123.	-2757.	578.	10638.
132	1.17	5.92	961.	-2311.	-9668.	1040.	1264.	-2614.	16.22	961.	-2311.	1040.	10932.
133	1.26	5.97	-210.	-951.	-10378.	649.	167.	-1327.	30.14	-210.	-951.	649.	10544.
134	0.43	5.42	1366.	14478.	55249.*	1395.	14625.	1219.	83.99	1366.	14478.	1395.	54029.*
135	0.48	5.42	6888.	9005.	41244.	2099.	10297.	5596.	58.38	6888.	9005.	2099.	35648.
136	0.52	5.42	10478.	4010.	30359.	1922.	11007.	3482.	15.36	10478.	4010.	1922.	26877.
137	0.58	5.42	12782.	-130.	21615.	1054.	12867.	-216.	4.64	12782.	-130.	1054.	21830.
138	0.63	5.42	14165.	-3005.	14453.	-388.	14174.	-3014.	-1.29	14165.	-3005.	-388.	17466.
139	0.70	5.39	23409.	-10211.	5669.	-3755.	23823.	-10625.	-6.30	23409.	-10211.	-3755.	34448.
140	0.72	5.51	9775.	2039.	11365.	-2402.	10460.	1354.	-15.92	9775.	2039.	-2402.	10010.
141	0.79	5.45	25762.	-6988.	3326.	-4336.	26327.	-7552.	-7.42	25762.	-6988.	-4336.	23879.
142	0.81	5.56	10242.	3820.	6857.	-4101.	12239.	1823.	-25.97	10242.	3820.	-4101.	10416.
143	0.87	5.49	21587.	-3496.	1335.	-2891.	21916.	-3825.	-6.49	21587.	-3496.	-2891.	25740.
144	0.88	5.60	10572.	3149.	3593.	-4743.	12884.	838.	-25.98	10572.	3149.	-4743.	12045.
145	0.94	5.53	17726.	-1920.	-208.	-957.	17773.	-1967.	-2.78	17726.	-1920.	-957.	19739.
146	0.98	5.61	11359.	325.	-445.	-1653.	11601.	83.	-8.34	11359.	325.	-1653.	12046.
147	1.07	5.66	8694.	-1245.	-3693.	-633.	8734.	-1285.	-3.63	8694.	-1245.	-633.	12427.
148	1.16	5.71	5438.	-1835.	-6623.	86.	5440.	-1836.	0.68	5438.	-1835.	86.	12062.
149	1.26	5.77	2556.	-1607.	-8585.	425.	2599.	-1650.	5.77	2556.	-1607.	425.	11183.
150	1.35	5.82	353.	-747.	-9412.	449.	513.	-907.	19.60	353.	-747.	449.	9924.
151	0.43	5.22	-3.	22787.	42340.	2779.	23121.	-337.	83.15	-3.	22787.	2779.	43677.
152	0.48	5.22	3238.	12592.	29081.	3975.	14054.	1777.	69.82	3238.	12592.	3975.	27303.
153	0.53	5.22	4541.	3767.	17694.	4259.	8431.	-123.	42.40	4541.	3767.	4259.	17816.
154	0.58	5.22	4658.	-3950.	8317.	3755.	6065.	-5358.	20.55	4658.	-3950.	3755.	13675.
155	0.63	5.22	4007.	-10587.	384.	2340.	4373.	-10953.	8.89	4007.	-10587.	2340.	15325.
156	0.68	5.22	-620.	-17309.	-6647.	-5247.	893.	-18822.	-16.08	-620.	-17309.	-5247.	19714.
157	0.72	5.31	5585.	-10381.	-4636.	2868.	6085.	-10881.	9.88	5585.	-10381.	2868.	16965.
158	0.80	5.36	23077.	-2806.	-6910.	-4767.	23927.	-3656.	-10.11	23077.	-2806.	-4767.	30837.
159	0.91	5.39	21959.	-2097.	-8092.	-7910.	24326.	-4465.	-16.66	21959.	-2097.	-7910.	32418.
160	1.01	5.37	12378.	4955.	-9942.	-343.	12394.	4939.	-2.64	12378.	4955.	-343.	22335.

C-50

LR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGNAT	SIGMARZ	SIGMAX	SIGMAMIN	ANGLE	SIGMAP	SIGMAN	SIGMAMN	SIGMAIAT
161	0.98	5.46	16589.	619.	-4153.	-8186.	20040.	-2832.	-22.86	16589.	619.	-8186.	24152.
162	1.04	5.49	11376.	4228.	-4791.	-5679.	14512.	1092.	-28.91	11376.	4228.	-5679.	19302.
163	1.11	5.43	10595.	-2718.	-8617.	124.	10596.	-2719.	0.52	10595.	-2718.	124.	19613.
164	1.16	5.51	9706.	-1156.	-6403.	-1776.	9989.	-1439.	-9.05	9706.	-1156.	-1776.	16391.
165	1.25	5.56	7174.	-1859.	-7037.	-1172.	7323.	-2008.	-7.27	7174.	-1859.	-1172.	14360.
166	1.34	5.62	4562.	-1394.	-7826.	-952.	4710.	-1543.	-8.87	4562.	-1394.	-952.	12536.
167	1.43	5.67	1883.	-11.	-8189.	-738.	2137.	-265.	-18.97	1883.	-11.	-738.	10325.
168	0.43	5.02	-506.	27065.	33694.	-192.	27066.	-507.	-89.60	-506.	27065.	-192.	34201.
169	0.48	5.02	1678.	13939.	20279.	-230.	13944.	1674.	-88.92	1678.	13939.	-230.	18604.
170	0.53	5.02	2094.	2028.	9474.	-618.	2679.	1442.	-43.47	2094.	2028.	-618.	8031.
171	0.58	5.02	1534.	-9553.	516.	-1416.	1712.	-9730.	-7.16	1534.	-9553.	-1416.	11442.
172	0.63	5.02	558.	-21939.	-7106.	-2676.	872.	-22253.	-6.69	558.	-21939.	-2676.	23124.
173	1.07	5.31	15537.	-2295.	-12174.	-7348.	18175.	-4933.	-19.75	15537.	-2295.	-7348.	30348.
174	1.13	5.34	11846.	914.	-10556.	-7370.	15556.	-2796.	-26.72	11846.	914.	-7370.	26111.
175	1.20	5.28	5557.	-2081.	-10322.	-2413.	6256.	-2780.	-16.14	5557.	-2081.	-2413.	16578.
176	1.24	5.36	6903.	-2226.	-9467.	-3379.	8018.	-3341.	-18.26	6903.	-2226.	-3379.	17484.
177	1.34	5.42	5888.	-2318.	-8742.	-2713.	6703.	-3134.	-16.74	5888.	-2318.	-2713.	15445.
178	1.43	5.48	4576.	-989.	-8439.	-2502.	5536.	-1948.	-20.98	4576.	-989.	-2502.	13974.
179	1.52	5.53	2990.	1579.	-8209.	-2475.	4859.	-289.	-37.05	2990.	1579.	-2475.	13067.
180	0.43	4.82	-372.	24677.	29925.	-950.	24713.	-408.	-87.83	-372.	24677.	-950.	30332.
181	0.48	4.82	2148.	12404.	17050.	-1454.	12606.	1946.	-82.08	2148.	12404.	-1454.	15103.
182	0.53	4.82	3134.	1111.	6723.	-1587.	4005.	240.	-28.75	3134.	1111.	-1587.	6483.
183	0.58	4.82	3250.	-9281.	-1789.	-1330.	3389.	-9421.	-5.99	3250.	-9281.	-1330.	12810.
184	0.63	4.82	2918.	-18666.	-8984.	-486.	2929.	-18677.	-1.29	2918.	-18666.	-486.	21606.
185	1.24	5.16	2534.	-1926.	-8160.	-3053.	4084.	-3476.	-26.93	2534.	-1926.	-3053.	12244.
186	1.33	5.21	2979.	-2891.	-8325.	-2934.	4194.	-4106.	-22.49	2979.	-2891.	-2934.	12518.
187	1.42	5.27	3428.	-1998.	-8263.	-3147.	4870.	-3440.	-24.62	3428.	-1998.	-3147.	13133.
188	1.52	5.33	3335.	266.	-8073.	-3386.	5518.	-1917.	-32.81	3335.	266.	-3386.	13590.
189	1.61	5.38	2617.	4087.	-7805.	-3713.	7137.	-433.	-50.60	2617.	4087.	-3713.	14941.
190	0.43	4.62	-371.	21955.	29565.	-463.	21965.	-381.	-88.81	-371.	21955.	-463.	29945.
191	0.48	4.62	2201.	11010.	16727.	-789.	11080.	2131.	-84.92	2201.	11010.	-789.	14595.
192	0.53	4.62	3249.	968.	6436.	-854.	3533.	683.	-18.41	3249.	968.	-854.	5753.
193	0.58	4.62	3299.	-8212.	-2048.	-704.	3342.	-8255.	-3.49	3299.	-8212.	-704.	11596.
194	0.63	4.62	2632.	-16643.	-9235.	-435.	2642.	-16653.	-1.29	2632.	-16643.	-435.	19294.
195	1.32	5.01	-1073.	-3888.	-3723.	-312.	-1039.	-3923.	-6.25	-1073.	-3888.	-312.	2883.
196	1.42	5.06	809.	-2489.	-4682.	-1658.	1499.	-3178.	-22.58	809.	-2489.	-1658.	6180.
197	1.51	5.11	1633.	-699.	-5312.	-2243.	2996.	-2061.	-31.27	1633.	-699.	-2243.	8307.
198	1.60	5.17	2204.	1967.	-5728.	-2966.	5054.	-883.	-43.86	2204.	1967.	-2966.	10782.
199	1.69	5.22	2819.	6180.	-5961.	-4537.	9338.	-339.	-55.16	2819.	6180.	-4537.	15298.
200	0.43	4.42	-364.	20676.	30205.	-152.	20677.	-365.	-89.59	-364.	20676.	-152.	30570.

c-51

LTR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAX	SIGMA MIN	ANGLE	SIGMAP	SIGMAN	SIGMANN	SIGMAINT
201	0.48	4.42	2198.	10318.	17296.	-281.	10327.	2188.	-88.02	2198.	10318.	-281.	15107.
202	0.53	4.42	3216.	875.	6545.	-322.	3260.	832.	-7.68	3216.	875.	-322.	6113.
203	0.58	4.42	3256.	-7739.	-1589.	-276.	3263.	-7746.	-1.43	3256.	-7739.	-276.	11008.
204	0.63	4.42	2663.	-15617.	-8815.	-142.	2664.	-15618.	-0.45	2663.	-15617.	-142.	18281.
205	1.45	4.78	-2045.	-3293.	712.	460.	-1894.	-3445.	18.21	-2045.	-3293.	460.	4157.
206	1.55	4.83	-929.	-1110.	-214.	-487.	-525.	-1515.	-39.74	-929.	-1110.	-487.	1301.
207	1.64	4.89	90.	1080.	-1012.	-1330.	2004.	-834.	-55.21	90.	1080.	-1330.	3016.
208	1.73	4.94	971.	3440.	-1689.	-2256.	4777.	-366.	-59.35	971.	3440.	-2256.	6465.
209	1.82	4.99	1915.	5807.	-2255.	-3484.	7852.	-130.	-59.59	1915.	5807.	-3484.	10107.
210	0.43	4.22	-344.	20303.	30810.	-12.	20303.	-344.	-89.97	-344.	20303.	-12.	31153.
211	0.48	4.22	2235.	10100.	17835.	-34.	10100.	2234.	-89.75	2235.	10100.	-34.	15600.
212	0.53	4.22	3246.	841.	7423.	-42.	3246.	840.	-0.99	3246.	841.	-42.	6593.
213	0.58	4.22	3273.	-7588.	-1145.	-30.	3273.	-7588.	-0.16	3273.	-7588.	-30.	10860.
214	0.63	4.22	2660.	-15311.	-8409.	-8.	2660.	-15311.	-0.03	2660.	-15311.	-8.	17971.
215	1.63	4.48	-2579.	-1543.	3956.	447.	-1377.	-2745.	69.61	-2579.	-1543.	447.	6701.
216	1.77	4.53	-1819.	466.	3217.	-121.	473.	-1826.	-86.98	-1819.	466.	-121.	5042.
217	1.81	4.59	-1011.	2274.	2565.	-746.	2436.	-1172.	-77.79	-1011.	2274.	-746.	3737.
218	1.90	4.64	-110.	3865.	1990.	-1504.	4370.	-615.	-71.44	-110.	3865.	-1504.	4985.
219	2.00	4.69	936.	5293.	1489.	-2474.	6411.	-182.	-65.68	936.	5293.	-2474.	6593.
220	0.43	4.02	-333.	20321.	31140.	30.	20321.	-333.	89.92	-333.	20321.	30.	31473.
221	0.48	4.02	2254.	10103.	18129.	46.	10103.	2253.	89.67	2254.	10103.	46.	15875.
222	0.53	4.02	3259.	844.	7659.	49.	3260.	843.	1.16	3259.	844.	49.	6855.
223	0.58	4.02	3275.	-7586.	-903.	43.	3275.	-7586.	0.23	3275.	-7586.	43.	10861.
224	0.63	4.02	2660.	-15329.	-8188.	29.	2660.	-15329.	0.09	2660.	-15329.	29.	17988.
225	1.74	4.28	-2534.	-113.	5068.	106.	-108.	-2538.	87.51	-2534.	-113.	106.	7606.
226	1.84	4.32	-1957.	1691.	4494.	-260.	1710.	-1976.	-85.95	-1957.	1691.	-260.	6469.
227	1.94	4.36	-1311.	2947.	3995.	-646.	3043.	-1407.	-81.56	-1311.	2947.	-646.	5401.
228	2.04	4.40	-586.	3857.	3569.	-1083.	4107.	-836.	-77.00	-586.	3857.	-1083.	4942.
229	2.14	4.45	239.	4302.	3210.	-1507.	4799.	-259.	-71.72	239.	4302.	-1507.	5058.
230	0.43	3.82	-330.	20432.	31254.	28.	20432.	-330.	89.92	-330.	20432.	28.	31584.
231	0.48	3.82	2260.	10159.	18231.	45.	10159.	2260.	89.67	2260.	10159.	45.	15971.
232	0.53	3.82	3262.	853.	7790.	49.	3263.	852.	1.16	3262.	853.	49.	6938.
233	0.58	3.82	3276.	-7624.	-820.	43.	3276.	-7624.	0.22	3276.	-7624.	43.	10900.
234	0.63	3.82	2659.	-15420.	-8112.	25.	2659.	-15420.	0.08	2659.	-15420.	25.	18078.
235	1.77	4.12	-2150.	712.	5742.	-158.	721.	-2159.	-86.84	-2150.	712.	-158.	7901.
236	1.88	4.13	-1746.	1841.	5283.	-83.	1842.	-1748.	-88.67	-1746.	1841.	-83.	7030.
237	1.98	4.15	-1257.	2822.	4893.	-222.	2834.	-1269.	-86.90	-1257.	2822.	-222.	6162.
238	2.09	4.16	-735.	3575.	4567.	-404.	3612.	-772.	-84.68	-735.	3575.	-404.	5339.
239	2.20	4.17	-196.	4110.	4297.	-534.	4175.	-261.	-83.03	-196.	4110.	-534.	4558.
240	0.43	3.62	-329.	20517.	31264.	14.	20517.	-329.	89.96	-329.	20517.	14.	31593.

C-52

LRI 144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAX	SIGMA MIN	ANGLE	SIGMAP	SIGMAN	SIGMANN	SIGMAINT
241	0.48	3.62	2261.	10205.	12240.	25.	10205.	2261.	89.82	2261.	10205.	25.	15978.
242	0.53	3.62	3263.	860.	7798.	27.	3263.	860.	0.64	3263.	860.	27.	6938.
243	0.58	3.62	3275.	-7655.	-813.	23.	3275.	-7655.	0.12	3275.	-7655.	23.	10930.
244	0.63	3.62	2659.	-15489.	-8106.	12.	2659.	-15489.	0.04	2659.	-15489.	12.	18147.
245	1.77	3.75	-1932.	1197.	7006.	-16.	1197.	-1932.	-89.70	-1932.	1197.	-16.	8938.
246	1.88	3.75	-1398.	1876.	6547.	76.	1878.	-1400.	88.66	-1398.	1876.	76.	7946.
247	1.98	3.75	-947.	2586.	6161.	106.	2589.	-950.	88.28	-947.	2586.	106.	7111.
248	2.09	3.75	-543.	3305.	5836.	92.	3308.	-545.	88.63	-543.	3305.	92.	6380.
249	2.20	3.75	-180.	4045.	5559.	64.	4046.	-180.	89.13	-180.	4045.	64.	5739.
250	0.43	3.42	-330.	20555.	31243.	4.	20555.	-330.	89.99	-330.	20555.	4.	31572.
251	0.48	3.42	2260.	10226.	18221.	8.	10226.	2260.	89.94	2260.	10226.	8.	15961.
252	0.53	3.42	3262.	863.	7781.	8.	3262.	863.	0.20	3262.	863.	8.	6917.
253	0.58	3.42	3275.	-7669.	-828.	7.	3275.	-7669.	0.04	3275.	-7669.	7.	10944.
254	0.63	3.42	2659.	-15520.	-8120.	3.	2659.	-15520.	0.01	2659.	-15520.	3.	18178.
255	1.77	3.25	-1934.	1543.	8056.	150.	1549.	-1941.	87.54	-1934.	1543.	150.	9956.
256	1.88	3.25	-1372.	2090.	7538.	211.	2102.	-1385.	86.52	-1372.	2090.	211.	8922.
257	1.98	3.25	-896.	2623.	7103.	234.	2639.	-911.	86.21	-896.	2623.	234.	8013.
258	2.09	3.25	-492.	3157.	6733.	214.	3169.	-504.	86.65	-492.	3157.	214.	7237.
259	2.20	3.25	-149.	3696.	6415.	146.	3701.	-155.	87.83	-149.	3696.	146.	6570.
260	0.43	3.22	-331.	20562.	31222.	-1.	20562.	-331.	-90.00	-331.	20562.	-1.	31552.
261	0.48	3.22	2258.	10230.	18202.	-1.	10230.	2258.	-89.99	2258.	10230.	-1.	15943.
262	0.53	3.22	3261.	864.	7764.	-2.	3261.	864.	-0.05	3261.	864.	-2.	6899.
263	0.58	3.22	3275.	-7673.	-844.	-1.	3275.	-7673.	-0.01	3275.	-7673.	-1.	10947.
264	0.63	3.22	2659.	-15526.	-8134.	-2.	2659.	-15526.	-0.01	2659.	-15526.	-2.	18184.
265	1.77	2.75	-1933.	2044.	8427.	119.	2048.	-1937.	88.29	-1933.	2044.	119.	10363.
266	1.88	2.75	-1374.	2346.	7888.	188.	2356.	-1384.	87.12	-1374.	2346.	188.	9272.
267	1.98	2.75	-904.	2652.	7434.	207.	2664.	-916.	86.68	-904.	2652.	207.	8350.
268	2.09	2.75	-503.	2954.	7047.	181.	2963.	-513.	87.01	-503.	2954.	181.	7559.
269	2.20	2.75	-157.	3244.	6713.	113.	3248.	-161.	88.09	-157.	3244.	113.	6874.
270	0.43	3.02	-331.	20556.	31204.	-2.	20556.	-331.	-89.99	-331.	20556.	-2.	31535.
271	0.48	3.02	2257.	10227.	18186.	-4.	10227.	2257.	-89.97	2257.	10227.	-4.	15928.
272	0.53	3.02	3260.	863.	7750.	-4.	3260.	863.	-0.11	3260.	863.	-4.	6886.
273	0.58	3.02	3275.	-7671.	-856.	-3.	3275.	-7671.	-0.02	3275.	-7671.	-3.	10945.
274	0.63	3.02	2659.	-15521.	-8146.	-3.	2659.	-15521.	-0.01	2659.	-15521.	-3.	18179.
275	1.77	2.25	-1932.	2411.	8445.	67.	2412.	-1933.	89.11	-1932.	2411.	67.	10378.
276	1.88	2.25	-1372.	2538.	7906.	109.	2541.	-1375.	88.41	-1372.	2538.	109.	9280.
277	1.98	2.25	-903.	2671.	7451.	121.	2675.	-907.	88.06	-903.	2671.	121.	8357.
278	2.09	2.25	-504.	2800.	7063.	106.	2803.	-507.	88.16	-504.	2800.	106.	7569.
279	2.20	2.25	-157.	2918.	6728.	65.	2919.	-159.	88.79	-157.	2918.	65.	6887.
280	0.43	2.82	-332.	20554.	31182.	1.	20554.	-332.	90.00	-332.	20554.	1.	31513.

C-53

LTR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAPAX	SIGMAPIN	ANGLE	SIGMAP	SIGMAN	SIGMAPN	SIGMAINT
281	0.48	2.82	2256.	10227.	18166.	2.	10227.	2256.	89.98	2256.	10227.	2.	15910.
282	0.53	2.82	3259.	863.	7732.	2.	3259.	863.	0.04	3259.	863.	2.	6868.
283	0.58	2.82	3274.	-7670.	-873.	2.	3274.	-7670.	0.01	3274.	-7670.	2.	10944.
284	0.63	2.82	2659.	-15519.	-8161.	-0.	2659.	-15519.	-0.00	2659.	-15519.	-0.	18177.
285	1.77	1.75	-1934.	2600.	8344.	27.	2600.	-1934.	89.66	-1934.	2600.	27.	10277.
286	1.88	1.75	-1374.	2640.	7810.	45.	2640.	-1375.	89.36	-1374.	2640.	45.	9184.
287	1.98	1.75	-904.	2681.	7360.	51.	2682.	-905.	89.19	-904.	2681.	51.	8265.
288	2.09	1.75	-504.	2719.	6977.	44.	2719.	-504.	89.22	-504.	2719.	44.	7481.
289	2.20	1.75	-157.	2748.	6647.	26.	2748.	-158.	89.49	-157.	2748.	26.	6804.
290	0.43	2.62	-333.	20576.	31151.	9.	20576.	-333.	89.97	-333.	20576.	9.	31483.
291	0.48	2.62	2254.	10239.	18139.	17.	10239.	2254.	89.88	2254.	10239.	17.	15884.
292	0.53	2.62	3258.	865.	7707.	18.	3258.	865.	0.43	3258.	865.	18.	6842.
293	0.58	2.62	3274.	-7679.	-896.	16.	3274.	-7679.	0.08	3274.	-7679.	16.	10953.
294	0.63	2.62	2659.	-15536.	-8182.	7.	2659.	-15536.	0.02	2659.	-15536.	7.	18194.
295	1.77	1.25	-1935.	2667.	8239.	5.	2667.	-1935.	89.94	-1935.	2667.	5.	10173.
296	1.88	1.25	-1377.	2676.	7711.	10.	2676.	-1377.	89.86	-1377.	2676.	10.	9087.
297	1.98	1.25	-906.	2684.	7266.	11.	2684.	-906.	89.82	-906.	2684.	11.	8172.
298	2.09	1.25	-504.	2689.	6887.	9.	2689.	-504.	89.83	-504.	2689.	9.	7391.
299	2.20	1.25	-157.	2689.	6562.	4.	2689.	-157.	89.91	-157.	2689.	4.	6719.
300	0.43	2.42	-334.	20647.	31125.	25.	20647.	-334.	89.93	-334.	20647.	25.	31458.
301	0.48	2.42	2253.	10278.	18116.	43.	10278.	2253.	89.69	2253.	10278.	43.	15863.
302	0.53	2.42	3257.	870.	7686.	47.	3258.	870.	1.12	3257.	870.	47.	6816.
303	0.58	2.42	3273.	-7706.	-914.	40.	3274.	-7706.	0.21	3273.	-7706.	40.	10979.
304	0.63	2.42	2658.	-15594.	-8199.	22.	2658.	-15594.	0.07	2658.	-15594.	22.	18252.
305	1.77	0.75	-1936.	2675.	8169.	-2.	2675.	-1936.	-89.97	-1936.	2675.	-2.	10105.
306	1.88	0.75	-1379.	2681.	7645.	-3.	2681.	-1379.	-89.96	-1379.	2681.	-3.	9023.
307	1.98	0.75	-908.	2685.	7203.	-3.	2685.	-908.	-89.96	-908.	2685.	-3.	8110.
308	2.09	0.75	-505.	2685.	6828.	-3.	2685.	-505.	-89.95	-505.	2685.	-3.	7332.
309	2.20	0.75	-158.	2682.	6505.	-2.	2682.	-158.	-89.95	-158.	2682.	-2.	6663.
310	0.43	2.22	-332.	20782.	31163.	43.	20783.	-332.	89.88	-332.	20782.	43.	31495.
311	0.48	2.22	2255.	10350.	18150.	69.	10350.	2255.	89.51	2255.	10350.	69.	15895.
312	0.53	2.22	3258.	882.	7717.	75.	3261.	880.	1.80	3258.	882.	75.	6837.
313	0.58	2.22	3273.	-7754.	-886.	65.	3274.	-7755.	0.34	3273.	-7754.	65.	11028.
314	0.63	2.22	2658.	-15704.	-8173.	39.	2658.	-15704.	0.12	2658.	-15704.	39.	18361.
315	1.77	0.25	-1936.	2668.	8139.	-2.	2668.	-1936.	-89.98	-1936.	2668.	-2.	10074.
316	1.88	0.25	-1379.	2678.	7617.	-2.	2678.	-1379.	-89.97	-1379.	2678.	-2.	8995.
317	1.98	0.25	-907.	2685.	7177.	-2.	2685.	-907.	-89.96	-907.	2685.	-2.	8084.
318	2.09	0.25	-504.	2688.	6803.	-2.	2688.	-504.	-89.96	-504.	2688.	-2.	7306.
319	2.20	0.25	-157.	2688.	6482.	-1.	2688.	-157.	-89.97	-157.	2688.	-1.	6638.
320	0.43	2.02	-325.	20929.	31387.	37.	20929.	-325.	89.90	-325.	20929.	37.	31712.

0.54

LTR1144 38

EL	R	Z	SIGMAR	SIGMAZ	SIGMAT	SIGMARZ	SIGMAPAX	SIGMAPIN	ANGLE	SIGMAM	SIGMAN	SIGMAMN	SIGMAINT
321	0.48	2.02	2268.	10423.	18350.	49.	10423.	2268.	89.66	2268.	10423.	49.	16082.
322	0.53	2.02	3266.	895.	7898.	51.	3266.	895.	1.23	3266.	895.	51.	7004.
323	0.58	2.02	3275.	-7802.	-722.	48.	3275.	-7803.	0.25	3275.	-7802.	48.	11077.
324	0.63	2.02	2657.	-15824.	-8023.	34.	2657.	-15824.	0.11	2657.	-15824.	34.	18481.
325	0.43	1.82	-308.	20863.	31954.	-53.	20863.	-308.	-89.86	-308.	20863.	-53.	32262.
326	0.48	1.82	2299.	10375.	18854.	-113.	10377.	2299.	-89.20	2299.	10375.	-113.	16557.
327	0.53	1.82	3287.	891.	8353.	-129.	3294.	884.	-3.08	3287.	891.	-129.	7468.
328	0.58	1.82	3280.	-7765.	-308.	-103.	3281.	-7766.	-0.53	3280.	-7765.	-103.	11047.
329	0.63	1.82	2657.	-15774.	-7644.	-45.	2657.	-15774.	-0.14	2657.	-15774.	-45.	18431.
330	0.43	1.62	-274.	20076.	32876.	-308.	20081.	-279.	-89.13	-274.	20076.	-308.	33155.
331	0.48	1.62	2357.	9932.	19678.	-550.	9972.	2317.	-85.87	2357.	9932.	-550.	17360.
332	0.53	1.62	3325.	829.	5097.	-618.	3470.	684.	-13.18	3325.	829.	-618.	8412.
333	0.58	1.62	3288.	-7454.	368.	-517.	3313.	-7479.	-2.75	3288.	-7454.	-517.	10791.
334	0.63	1.62	2654.	-15144.	-7026.	-275.	2659.	-15148.	-0.89	2654.	-15144.	-275.	17807.
335	0.43	1.42	-281.	17840.	33602.	-772.	17873.	-314.	-87.57	-281.	17840.	-772.	33915.
336	0.48	1.42	2359.	8711.	20321.	-1309.	8970.	2100.	-78.80	2359.	8711.	-1309.	18221.
337	0.53	1.42	3364.	639.	9677.	-1443.	3986.	17.	-23.32	3364.	639.	-1443.	9659.
338	0.58	1.42	3349.	-6622.	898.	-1252.	3504.	-6777.	-7.05	3349.	-6622.	-1252.	10281.
339	0.63	1.42	2688.	-13322.	-6538.	-723.	2721.	-13355.	-2.58	2688.	-13322.	-723.	16075.
340	0.43	1.22	-218.	13763.	32271.	-1392.	13900.	-355.	-84.37	-218.	13763.	-1392.	32626.
341	0.48	1.22	2383.	6625.	19145.	-1990.	7413.	1596.	-68.41	2383.	6625.	-1990.	17549.
342	0.53	1.22	3218.	316.	8615.	-2165.	4373.	-839.	-28.09	3218.	316.	-2165.	9454.
343	0.58	1.22	3109.	-5213.	-81.	-1857.	3504.	-5609.	-12.03	3109.	-5213.	-1857.	9112.
344	0.63	1.22	2569.	-10032.	-7447.	-1237.	2689.	-10152.	-5.55	2569.	-10032.	-1237.	12841.
345	0.43	1.02	-538.	9289.	25307.	-74.	9290.	-538.	-89.57	-538.	9289.	-74.	25844.
346	0.48	1.02	1929.	3799.	12927.	-2063.	5129.	599.	-57.19	1929.	3799.	-2063.	12328.
347	0.53	1.02	3147.	108.	3007.	-2434.	4497.	-1242.	-29.01	3147.	108.	-2434.	5738.
348	0.58	1.02	3382.	-3053.	-5156.	-1631.	3771.	-3442.	-13.44	3382.	-3053.	-1631.	8927.
349	0.63	1.02	2751.	-6685.	-12068.	198.	2755.	-6689.	1.20	2751.	-6685.	198.	14823.

C-55

LR 1144 38

EL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EPSM	EPSN	EPSMN	TEMPERATURE
1	-0.007	0.000	C.C17	C.000	0.000	-0.007	0.0	-0.007	0.000	0.000	201.
2	-0.004	0.000	C.C15	0.000	0.000	-0.004	85.03	-0.004	0.000	0.000	202.
3	-0.003	-0.000	C.C13	0.000	-0.000	-0.003	88.30	-0.003	-0.000	0.000	202.
4	-0.001	-0.000	C.C11	0.000	-0.000	-0.001	87.79	-0.001	-0.000	0.000	203.
5	-0.000	-0.000	C.C10	-0.000	-0.000	-0.000	-86.83	-0.000	-0.000	-0.000	203.
6	-0.007	0.001	C.C18	0.000	0.001	-0.007	89.65	-0.007	0.001	0.000	201.
7	-0.004	0.000	C.C15	0.000	0.000	-0.004	89.27	-0.004	0.000	0.000	202.
8	-0.003	-0.000	C.C13	0.000	-0.000	-0.003	88.69	-0.003	-0.000	0.000	202.
9	-0.001	-0.000	C.C11	0.000	-0.000	-0.001	87.24	-0.001	-0.000	0.000	203.
10	-0.000	-0.000	C.C10	0.000	-0.000	-0.000	78.16	-0.000	-0.000	0.000	203.
11	-0.007	0.001	C.C18	0.000	0.001	-0.007	0.0	-0.007	0.001	0.000	201.
12	-0.004	0.000	C.C15	0.000	0.000	-0.004	0.0	-0.004	0.000	0.000	202.
13	-0.003	-0.000	C.C13	-0.000	-0.000	-0.003	0.0	-0.003	-0.000	-0.000	202.
14	-0.001	-0.000	C.C12	0.000	-0.000	-0.001	0.0	-0.001	-0.000	0.000	203.
15	-0.000	-0.000	C.C11	0.000	-0.000	-0.000	0.0	-0.000	-0.000	0.000	203.
16	-0.007	0.000	C.C18	-0.000	0.000	-0.007	-89.39	-0.007	0.000	-0.000	201.
17	-0.004	0.000	C.C15	-0.000	0.000	-0.004	-88.31	-0.004	0.000	-0.000	202.
18	-0.003	-0.000	C.C13	-0.000	-0.000	-0.003	-86.60	-0.003	-0.000	-0.000	202.
19	-0.001	-0.000	C.C12	-0.000	-0.000	-0.001	-84.00	-0.001	-0.000	-0.000	203.
20	-0.000	-0.000	C.C11	-0.000	-0.000	-0.000	-73.31	-0.000	-0.000	-0.000	203.
21	-0.007	-0.000	C.C18	-0.000	-0.000	-0.007	-88.36	-0.007	-0.000	-0.000	201.
22	-0.004	-0.000	C.C15	-0.001	-0.000	-0.004	-85.67	-0.004	-0.000	-0.001	202.
23	-0.003	-0.000	C.C13	-0.001	-0.000	-0.003	-82.06	-0.003	-0.000	-0.001	202.
24	-0.001	0.000	C.C12	-0.001	0.000	-0.001	-78.23	-0.001	0.000	-0.001	203.
25	-0.000	0.000	C.C11	-0.000	0.000	-0.000	-75.78	-0.000	0.000	-0.000	203.
26	-0.007	-0.001	C.C18	-0.001	-0.001	-0.007	-87.13	-0.007	-0.001	-0.001	201.
27	-0.004	-0.001	C.C15	-0.001	-0.001	-0.004	-83.13	-0.004	-0.001	-0.001	202.
28	-0.003	-0.000	C.C13	-0.001	-0.000	-0.003	-78.92	-0.003	-0.000	-0.001	202.
29	-0.001	0.000	C.C12	-0.001	0.000	-0.001	-76.74	-0.001	0.000	-0.001	203.
30	-0.000	0.001	C.C10	-0.001	0.001	-0.000	-79.48	-0.000	0.001	-0.001	203.
31	-0.007	-0.002	C.C16	-0.000	-0.002	-0.007	-88.07	-0.007	-0.002	-0.000	201.
32	-0.004	-0.001	C.C13	-0.000	-0.001	-0.004	-87.13	-0.004	-0.001	-0.000	202.
33	-0.003	-0.000	C.C11	-0.000	-0.000	-0.003	-86.13	-0.003	-0.000	-0.000	202.
34	-0.001	0.001	C.C10	-0.000	0.001	-0.001	-85.65	-0.001	0.001	-0.000	203.
35	-0.000	0.002	C.C09	-0.000	0.002	-0.000	-85.86	-0.000	0.002	-0.000	203.
36	-0.007	-0.001	C.C12	0.001	-0.000	-0.007	83.78	-0.007	-0.001	0.001	201.
37	-0.005	-0.000	C.C09	0.003	0.000	-0.005	74.17	-0.005	-0.000	0.003	202.
38	-0.003	-0.000	C.C08	0.003	0.000	-0.003	65.50	-0.003	-0.000	0.003	202.
39	-0.001	0.000	C.C07	0.002	0.001	-0.002	60.32	-0.001	0.000	0.002	203.
40	-0.000	0.001	C.C06	0.001	0.001	-0.001	67.50	-0.000	0.001	0.001	203.

2-56

LTR144 38

EL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EPSM	EPSN	EPSMN	TEMPERATURE
41	-0.007	0.007	0.006	0.006	0.007	-0.008	79.12	-0.007	0.007	0.006	201.
42	-0.005	0.004	0.004	0.009	0.006	-0.007	66.88	-0.005	0.004	0.009	202.
43	-0.004	0.000	0.003	0.011	0.004	-0.007	55.05	-0.004	0.000	0.011	202.
44	-0.002	-0.003	0.002	0.009	0.002	-0.007	41.96	-0.002	-0.003	0.009	203.
45	-0.000	-0.005	0.002	0.004	0.000	-0.006	20.36	-0.000	-0.005	0.004	203.
46	-0.007	0.021	0.004	0.008	0.022	-0.008	82.39	-0.007	0.021	0.008	201.
47	-0.006	0.013	0.002	0.014	0.015	-0.009	71.90	-0.006	0.013	0.014	201.
48	-0.005	0.004	0.001	0.018	0.009	-0.011	58.46	-0.005	0.004	0.018	202.
49	-0.005	-0.007	0.001	0.020	0.004	-0.016	41.62	-0.005	-0.007	0.020	202.
50	-0.004	-0.020	0.000	0.020	0.001	-0.025	24.74	-0.004	-0.020	0.020	202.
51	-0.007	0.036	0.012	0.001	0.036	-0.007	89.39	-0.007	0.036	0.001	207.
52	-0.005	0.024	0.008	0.006	0.024	-0.005	84.38	-0.005	0.024	0.006	211.
53	-0.004	0.012	0.005	0.009	0.012	-0.005	75.61	-0.004	0.012	0.009	213.
54	-0.004	-0.000	0.003	0.011	0.004	-0.008	53.45	-0.004	-0.000	0.011	216.
55	-0.004	-0.014	0.001	0.014	-0.000	-0.017	26.23	-0.004	-0.014	0.014	217.
56	-0.013	-0.024	-0.000	0.058	0.011	-0.048	39.82	-0.013	-0.024	0.058	222.
57	-0.006	0.047	0.031	0.000	0.047	-0.006	89.77	-0.006	0.047	0.000	221.
58	-0.002	0.033	0.020	0.005	0.034	-0.002	85.97	-0.002	0.033	0.005	233.
59	-0.000	0.021	0.012	0.008	0.022	-0.001	79.08	-0.000	0.021	0.008	244.
60	0.001	0.009	0.005	0.011	0.012	-0.002	62.82	0.001	0.009	0.011	253.
61	0.001	-0.001	0.001	0.014	0.007	-0.007	39.57	0.001	-0.001	0.014	260.
62	0.001	-0.014	-0.005	0.043	0.016	-0.029	35.72	0.001	-0.014	0.043	275.
63	0.001	-0.013	-0.002	-0.005	0.002	-0.013	-8.76	0.001	-0.013	-0.005	244.
64	-0.002	-0.028	-0.006	0.050	0.013	-0.043	31.40	-0.002	-0.028	0.050	264.
65	-0.005	0.060	0.060	0.002	0.060	-0.005	89.19	-0.005	0.060	0.002	237.
66	0.001	0.043	0.040	0.007	0.044	0.001	85.42	0.001	0.043	0.007	260.
67	0.004	0.029	0.024	0.010	0.030	0.003	78.96	0.004	0.029	0.010	279.
68	0.005	0.016	0.011	0.012	0.019	0.002	65.90	0.005	0.016	0.012	296.
69	0.005	0.005	0.002	0.013	0.012	-0.002	44.91	0.005	0.005	0.013	310.
70	0.012	-0.012	-0.008	0.033	0.020	-0.020	27.15	0.012	-0.012	0.033	333.
71	-0.001	-0.002	-0.008	-0.005	0.001	-0.004	-41.57	-0.001	-0.002	-0.005	304.
72	0.008	-0.023	-0.015	0.033	0.015	-0.030	23.75	0.008	-0.023	0.033	332.
73	-0.001	-0.022	-0.012	0.019	0.003	-0.025	21.22	-0.001	-0.022	0.019	309.
74	-0.003	0.073	0.094	0.002	0.073	-0.003	89.32	-0.003	0.073	0.002	250.
75	0.005	0.053	0.066	0.006	0.053	0.005	86.40	0.005	0.053	0.006	281.
76	0.009	0.036	0.043	0.009	0.037	0.009	80.79	0.009	0.036	0.009	307.
77	0.011	0.022	0.025	0.011	0.024	0.009	67.18	0.011	0.022	0.011	330.
78	0.011	0.009	0.010	0.012	0.016	0.004	41.38	0.011	0.009	0.012	350.
79	0.020	-0.009	-0.002	0.022	0.024	-0.013	18.96	0.020	-0.009	0.022	377.
80	0.000	0.001	-0.010	0.002	0.002	-0.000	54.62	0.000	0.001	0.002	360.

C-57

LTR1144 38

EL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EFSP	EPSN	EPSMN	TEMPERATURE
81	0.015	-0.021	-C.C17	0.025	0.019	-0.025	17.67	C.C15	-C.C21	0.C25	389.
82	C.C04	-C.C18	-C.C21	0.C13	0.C06	-0.020	15.04	0.C04	-C.018	0.C13	377.
83	-0.001	-C.C17	-C.C22	0.C14	C.CC2	-C.C2C	19.69	-0.C01	-0.017	0.014	368.
84	-0.001	0.081	0.133	0.000	0.081	-0.C01	89.94	-C.CC1	C.C81	0.C0C	258.
85	C.C11	0.059	C.C97	0.002	0.C59	0.011	88.97	C.C11	0.059	C.C02	294.
86	0.C16	0.C41	C.C69	C.CC3	0.C41	C.C16	86.5C	C.C16	C.041	0.C03	325.
87	0.019	0.026	0.C46	0.C04	0.027	C.018	74.65	C.C19	C.C26	0.C04	352.
88	0.C19	0.C14	C.028	0.006	0.020	0.012	23.58	C.C19	C.C14	C.C06	376.
89	0.C28	-0.C04	C.C13	C.C08	0.C29	-0.C05	7.23	C.C28	-C.C04	0.008	404.
90	0.007	0.004	-C.C01	0.CC5	C.CC8	C.C02	29.7C	C.CC7	C.C04	0.005	397.
91	0.021	-0.018	-C.C09	0.016	0.023	-0.C19	11.04	0.C21	-C.C18	0.C16	425.
92	0.C09	-C.C16	-C.C19	0.012	0.C11	-C.C17	12.93	0.C09	-0.016	0.012	425.
93	0.C04	-0.019	-C.C30	C.C13	C.CC6	-C.C2C	14.93	0.C04	-0.C19	0.013	430.
94	0.C00	-0.013	-C.C31	0.C08	0.C02	-0.C14	16.62	0.CC0	-C.C13	C.C08	424.
95	C.C02	0.079	C.171	-0.C04	0.C79	0.C02	-88.62	0.C02	0.079	-0.004	263.
96	0.C16	0.059	C.130	-0.C07	0.C59	C.C16	-85.56	C.C16	0.059	-0.007	301.
97	0.024	0.C42	C.098	-0.C08	0.C42	0.023	-77.53	C.C24	0.C42	-0.008	334.
98	0.C27	C.C28	C.C72	-0.009	0.032	0.023	-45.22	C.027	C.028	-0.009	364.
99	0.028	0.C16	C.C50	-C.C08	0.C3C	C.C15	-17.03	0.028	0.016	-0.008	390.
100	0.037	-0.C00	C.034	-0.012	0.038	-C.C01	-8.93	C.C37	-C.C00	-0.012	417.
101	0.015	C.C07	C.C17	0.C00	0.C15	0.007	1.13	0.C15	C.C07	C.C00	417.
102	0.029	-0.C14	C.C08	-C.C00	0.C29	-0.C14	-3.17	C.C29	-C.014	-0.C00	444.
103	0.016	-C.011	-C.C08	C.C05	0.C17	-C.C11	5.31	C.C16	-C.C11	0.005	452.
104	0.C09	-0.017	-C.026	0.011	0.010	-0.018	11.18	C.C09	-C.017	C.011	469.
105	0.C03	-C.C17	-C.C35	0.C11	0.C05	-0.018	14.77	C.C03	-0.017	C.011	475.
106	0.C00	-0.C08	-C.C37	0.C05	0.CC1	-C.C09	15.94	0.CC0	-0.C08	0.005	471.
107	0.004	0.065	C.205	-0.009	0.C66	C.C04	-85.99	0.C04	C.C65	-C.C09	265.
108	0.C22	0.049	C.160	-0.015	0.C51	0.020	-75.10	0.022	0.049	-0.015	304.
109	0.033	0.035	C.125	-0.C19	0.C43	C.C24	-47.81	C.C33	0.035	-0.019	338.
110	0.039	0.023	C.097	-0.022	0.044	C.018	-27.26	0.C39	C.C23	-0.022	369.
111	C.C41	0.C14	C.073	-0.023	0.046	0.C10	-19.95	0.C41	0.014	-0.023	396.
112	0.056	-C.095	C.C52	-C.C28	0.C59	-C.C08	-12.39	0.C56	-C.C05	-0.028	428.
113	0.025	0.C.9	0.037	-0.018	0.C29	0.C05	-24.43	C.C25	0.C09	-0.018	430.
114	C.C42	-0.C10	C.C27	-0.017	0.043	-0.011	-8.94	C.C42	-C.010	-0.017	454.
115	0.C28	-0.C06	C.C10	-C.C09	0.028	-0.007	-7.88	C.028	-0.006	-0.009	465.
116	0.017	-0.012	-C.C13	0.CC0	0.C17	-C.C12	C.14	C.C17	-C.012	0.C00	490.
117	0.009	-0.015	-C.C29	0.008	0.C09	-0.016	8.77	C.C09	-0.C15	C.C08	505.
118	C.C03	-0.013	-C.C38	C.010	0.C04	-0.014	16.36	C.C03	-C.013	0.010	512.
119	-0.000	-0.005	-C.C40	C.C04	0.CC1	-C.C06	21.14	-0.C00	-0.005	0.004	509.
120	0.006	0.048	0.221	-C.C06	0.049	0.C06	-85.76	C.C06	C.048	-C.C06	268.

LTR 1144 38

EL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EPSM	EPSN	EPSMN	TEMPERATURE
121	0.028	0.035	0.174	-0.010	0.038	0.026	-61.56	0.028	0.035	-0.010	308.
122	0.043	0.023	0.138	-0.015	0.046	0.021	-18.36	0.042	0.023	-0.015	343.
123	0.053	0.013	0.108	-0.020	0.055	0.011	-13.47	0.053	0.013	-0.020	375.
124	0.059	0.005	0.084	-0.026	0.062	0.002	-12.93	0.059	0.005	-0.026	403.
125	0.082	-0.013	0.062	-0.038	0.086	-0.016	-10.88	0.082	-0.013	-0.038	436.
126	0.036	0.008	0.051	-0.022	0.040	0.004	-19.04	0.036	0.008	-0.022	440.
127	0.069	-0.013	0.036	-0.031	0.072	-0.016	-10.36	0.069	-0.013	-0.031	467.
128	0.046	-0.001	0.026	-0.023	0.049	-0.004	-13.11	0.046	-0.001	-0.023	474.
129	0.035	-0.005	0.006	-0.016	0.036	-0.006	-10.98	0.035	-0.005	-0.016	496.
130	0.023	-0.009	-0.014	-0.004	0.023	-0.009	-3.59	0.023	-0.009	-0.004	519.
131	0.012	-0.011	-0.029	0.004	0.012	-0.011	5.56	0.012	-0.011	0.004	533.
132	0.004	-0.009	-0.037	0.008	0.005	-0.010	16.22	0.004	-0.009	0.008	540.
133	-0.001	-0.004	-0.040	0.005	0.001	-0.005	30.14	-0.001	-0.004	0.005	539.
134	0.005	0.053	0.203	0.010	0.054	0.004	83.59	0.005	0.053	0.010	278.
135	0.026	0.033	0.153	0.016	0.038	0.021	58.38	0.026	0.033	0.016	326.
136	0.039	0.015	0.113	0.014	0.041	0.013	15.36	0.039	0.015	0.014	368.
137	0.048	-0.000	0.081	0.008	0.048	-0.001	4.64	0.048	-0.000	0.008	405.
138	0.054	-0.011	0.055	-0.003	0.054	-0.011	-1.29	0.054	-0.011	-0.003	439.
139	0.089	-0.039	0.022	-0.029	0.091	-0.041	-6.30	0.089	-0.039	-0.029	485.
140	0.037	0.008	0.043	-0.018	0.040	0.005	-15.92	0.037	0.008	-0.018	462.
141	0.099	-0.027	0.013	-0.033	0.101	-0.029	-7.42	0.099	-0.027	-0.033	506.
142	0.039	0.015	0.026	-0.031	0.047	0.007	-25.97	0.039	0.015	-0.031	487.
143	0.083	-0.013	0.005	-0.022	0.084	-0.015	-6.49	0.083	-0.013	-0.022	523.
144	0.041	0.012	0.014	-0.036	0.049	0.003	-25.98	0.041	0.012	-0.036	504.
145	0.069	-0.007	-0.001	-0.007	0.069	-0.008	-2.78	0.069	-0.007	-0.007	533.
146	0.044	0.001	-0.002	-0.013	0.045	0.000	-8.34	0.044	0.001	-0.013	529.
147	0.034	-0.005	-0.014	-0.005	0.034	-0.005	-3.63	0.034	-0.005	-0.005	544.
148	0.021	-0.007	-0.026	0.001	0.021	-0.007	0.68	0.021	-0.007	0.001	555.
149	0.010	-0.006	-0.033	0.003	0.010	-0.006	5.77	0.010	-0.006	0.003	561.
150	0.001	-0.003	-0.037	0.003	0.002	-0.004	19.60	0.001	-0.003	0.003	561.
151	-0.000	0.084	0.160	0.020	0.085	-0.001	83.15	-0.000	0.084	0.020	289.
152	0.012	0.047	0.108	0.030	0.052	0.007	69.82	0.012	0.047	0.030	344.
153	0.017	0.014	0.066	0.032	0.032	-0.000	42.40	0.017	0.014	0.032	392.
154	0.018	-0.015	0.031	0.028	0.023	-0.020	20.55	0.018	-0.015	0.028	435.
155	0.015	-0.040	0.001	0.018	0.017	-0.042	8.89	0.015	-0.040	0.018	474.
156	-0.002	-0.067	-0.026	-0.040	0.003	-0.072	-16.08	-0.002	-0.067	-0.040	511.
157	0.022	-0.040	-0.018	0.022	0.023	-0.042	9.88	0.022	-0.040	0.022	524.
158	0.090	-0.011	-0.027	-0.037	0.093	-0.014	-10.11	0.090	-0.011	-0.037	556.
159	0.086	-0.008	-0.032	-0.062	0.095	-0.017	-16.66	0.086	-0.008	-0.062	579.
160	0.049	0.020	-0.039	-0.003	0.049	0.019	-2.64	0.049	0.020	-0.003	603.

LTR14438

C-59

EL	EPSR	EPSZ	EPST	EPSRZ	EPSNAX	EPSMIN	ANGLE	EPSM	EPSN	EPSMN	TEMPERATURE
161	0.065	0.002	-C.C16	-0.064	0.07E	-C.C11	-22.86	0.065	C.C02	-0.064	563.
162	0.044	0.016	-C.C19	-0.044	0.057	0.004	-28.91	0.044	C.C16	-C.C44	567.
163	0.043	-0.011	-C.C34	C.C01	0.043	-0.011	0.52	0.043	-C.C11	C.C01	598.
164	0.038	-0.005	-C.C25	-0.014	0.039	-C.C06	-9.05	0.038	-0.005	-0.014	581.
165	0.028	-0.007	-C.C28	-0.009	0.029	-C.C08	-7.27	0.028	-C.C07	-C.C09	583.
166	0.018	-0.005	-C.C31	-0.007	0.018	-0.006	-8.87	0.018	-C.C05	-0.007	583.
167	0.007	-0.000	-C.C32	-C.C06	0.008	-C.C01	-18.97	0.007	-0.000	-0.006	581.
168	-0.002	0.100	C.124	-0.001	0.100	-C.C02	-89.60	-C.C02	C.100	-0.001	291.
169	0.006	0.052	C.075	-0.002	0.052	C.C06	-88.92	0.006	C.052	-C.C02	346.
170	0.008	0.008	C.C36	-C.C05	0.010	0.005	-43.47	0.008	0.008	-0.005	395.
171	0.006	-0.036	C.C02	-C.C11	0.006	-C.C037	-7.16	0.006	-C.C36	-0.011	439.
172	0.002	-0.084	-C.C27	-0.020	0.003	-0.085	-6.59	0.002	-C.C84	-C.C20	478.
173	0.062	-C.C09	-C.C48	-C.C58	0.072	-0.020	-19.75	0.062	-C.C09	-C.058	631.
174	0.047	0.004	-C.C42	-C.C58	0.062	-C.C11	-26.72	0.047	C.C04	-0.058	623.
175	0.022	-0.008	-C.C41	-0.019	0.025	-C.C11	-16.14	0.022	-C.C08	-C.019	637.
176	0.027	-C.C09	-C.C37	-0.027	0.032	-0.013	-18.26	0.027	-C.C09	-0.027	603.
177	0.023	-C.C09	-C.C35	-C.C21	0.026	-C.C12	-16.74	0.023	-C.C09	-0.021	616.
178	0.018	-C.C04	-C.C33	-0.020	0.022	-C.C08	-20.98	0.018	-C.C04	-0.020	611.
179	0.012	0.006	-C.C32	-0.020	0.019	-0.001	-37.05	0.012	0.006	-0.020	605.
180	-0.001	0.091	C.110	-C.C07	0.091	-C.C02	-87.83	-C.C01	0.091	-0.007	291.
181	0.008	0.046	C.C63	-0.011	0.047	0.007	-82.08	0.008	C.C46	-0.011	345.
182	0.012	0.004	C.C25	-0.012	0.015	0.001	-28.75	0.012	C.C04	-C.012	394.
183	0.012	-0.035	-C.C07	-0.010	0.013	-0.036	-5.99	0.012	-C.035	-0.010	437.
184	0.011	-C.C71	-C.C34	-0.004	0.011	-C.C71	-1.29	0.011	-C.C71	-0.004	476.
185	0.010	-0.008	-C.C32	-0.021	0.016	-0.014	-26.93	0.010	-C.C08	-C.024	648.
186	0.012	-0.012	-C.C33	-C.C23	0.017	-0.016	-22.49	0.012	-0.012	-0.023	645.
187	0.014	-0.008	-C.C33	-0.025	0.019	-C.C14	-24.62	0.014	-C.C08	-0.025	640.
188	0.013	0.001	-C.C32	-0.027	0.022	-C.C08	-32.81	0.013	C.C01	-0.027	635.
189	0.010	0.016	-C.C31	-0.029	0.028	-C.C02	-50.60	0.010	0.016	-0.029	629.
190	-0.001	0.081	C.109	-C.C03	0.081	-C.C01	-88.81	-C.C01	0.081	-0.003	291.
191	0.008	0.041	C.C62	-0.006	0.041	C.C08	-84.92	0.008	C.C41	-0.006	345.
192	0.012	0.004	C.C24	-0.006	0.013	0.003	-18.41	0.012	C.C04	-0.006	394.
193	0.012	-0.031	-C.C08	-C.C05	0.013	-0.031	-3.49	0.012	-C.031	-0.005	437.
194	0.010	-0.063	-C.C35	-C.C03	0.010	-C.C64	-1.29	0.010	-0.063	-0.003	476.
195	-0.004	-0.015	-C.C15	-0.002	-0.004	-C.C16	-6.25	-0.004	-C.C15	-0.002	650.
196	0.003	-C.C10	-C.C19	-C.C13	0.006	-0.013	-22.58	0.003	-C.C10	-C.C13	649.
197	0.007	-0.003	-C.C21	-0.018	0.012	-C.C08	-31.27	0.007	-C.C03	-0.013	648.
198	0.009	0.008	-C.C23	-0.024	0.020	-C.C04	-43.86	0.009	C.C08	-0.024	647.
199	0.011	0.025	-C.C24	-C.C36	0.037	-C.C01	-55.16	0.011	0.025	-0.036	644.
200	-0.001	0.076	C.111	-0.001	0.076	-C.C01	-89.55	-C.C01	0.076	-0.001	291.

17R1144  
B3

FL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EPSM	EPSN	EPSMN	TEMPERATURE
201	C.C08	0.038	C.C64	-0.C02	C.C3E	C.C0E	-88.C2	C.C08	C.038	-0.C02	345.
202	0.012	0.003	C.C26	-0.C02	C.C12	C.C03	-7.68	C.C12	C.C03	-0.002	394.
203	C.C12	-0.C29	-C.C06	-0.C02	C.C12	-0.C29	-1.43	C.C12	-0.C29	-C.C02	437.
204	0.010	-0.C60	-C.C34	-C.C01	C.C10	-0.C60	-0.45	0.C10	-C.C60	-0.C01	476.
205	-0.008	-0.013	C.C03	0.C04	-C.C0E	-C.C14	18.21	-C.C0E	-C.C13	C.C04	649.
206	-0.004	-0.004	-C.C01	-0.C04	-0.C02	-0.C06	-39.74	-C.CC4	-C.CC4	-C.004	649.
207	0.CC0	0.C04	-C.C04	-C.C11	0.C08	-0.C03	-55.21	0.CC0	C.C04	-0.011	649.
208	0.004	0.014	-C.C07	-C.C18	C.C19	-C.C01	-59.35	0.C04	0.014	-0.018	649.
209	0.008	0.023	-0.C09	-0.028	0.C21	-0.C01	-59.59	C.C08	C.C23	-C.028	648.
210	-C.C01	0.C75	0.113	-0.C00	0.C75	-C.C01	-89.97	-C.C01	C.C75	-0.C00	291.
211	0.CC8	0.038	C.C66	-0.C00	0.C3E	C.CC8	-89.75	C.C08	C.038	-0.C00	345.
212	0.012	0.003	C.028	-0.C00	0.C12	C.C03	-0.99	C.C12	C.C03	-0.C00	394.
213	0.012	-0.C29	-C.C04	-0.C00	0.012	-0.029	-0.16	C.C12	-0.C29	-0.C00	437.
214	0.010	-0.058	-C.C32	-C.CC0	0.010	-0.05E	-0.03	0.C10	-0.058	-0.C00	476.
215	-0.010	-0.C06	C.C16	C.004	-0.C0E	-0.011	69.61	-C.C10	-0.C06	0.004	649.
216	-0.007	0.C02	C.C13	-C.001	0.C02	-0.C07	-86.98	-C.CC7	G.C02	-C.C01	649.
217	-0.C04	0.C09	C.C10	-C.C06	0.010	-0.C05	-77.79	-0.C04	0.C09	-C.006	649.
218	-0.C00	0.015	C.C08	-0.C12	0.C17	-0.C02	-71.44	-C.CC0	C.C15	-0.012	648.
219	0.004	0.021	C.C06	-0.020	0.026	-0.C01	-65.68	C.CC4	0.C21	-C.020	648.
220	-C.C01	0.C75	C.115	C.C00	0.075	-C.C01	89.92	-C.C01	C.075	C.C00	291.
221	0.C08	0.038	C.C67	0.C00	0.C3E	C.C08	89.67	0.C08	C.038	0.C00	345.
222	0.C12	0.003	0.C29	0.000	0.C12	C.C03	1.16	C.C12	C.C03	C.C00	394.
223	0.C12	-0.029	-C.C03	0.000	0.012	-0.029	0.23	0.C12	-0.029	0.C00	437.
224	0.C10	-C.C58	-C.C31	0.C00	0.C10	-C.058	0.09	0.C10	-0.058	0.000	476.
225	-0.010	-0.C00	C.C20	0.C01	-0.C00	-0.010	87.51	-C.C10	-C.C00	0.001	649.
226	-0.C08	0.C07	C.C18	-0.C02	0.007	-C.008	-85.95	-C.C08	C.C07	-0.002	649.
227	-0.005	0.012	C.C16	-C.C05	0.012	-0.C06	-81.56	-0.C05	C.C12	-0.005	649.
228	-0.002	0.015	C.C14	-0.009	0.016	-C.C03	-77.00	-C.CC2	C.015	-0.009	649.
229	0.001	0.C17	C.C13	-0.012	0.019	-0.C01	-71.72	C.C01	0.C17	-C.C12	648.
230	-0.C01	0.075	C.115	C.C00	0.075	-0.C01	89.92	-0.C01	C.C75	C.C00	291.
231	0.008	0.038	C.C68	0.C00	0.C3E	C.C08	89.67	0.C08	C.038	0.000	345.
232	0.012	0.003	0.C29	0.000	0.012	C.C03	1.16	C.C12	C.C03	C.C00	394.
233	0.C12	-0.029	-C.C03	C.C00	0.012	-0.029	0.22	0.C12	-0.029	0.000	437.
234	0.010	-0.059	-C.C31	C.C00	C.C10	-0.059	C.08	0.C10	-0.059	0.C00	476.
235	-0.C09	0.003	0.C23	-0.001	0.C03	-0.C09	-86.84	-C.CC9	C.C03	-C.C01	649.
236	-C.C07	C.C07	C.C21	-0.001	0.C07	-0.C07	-88.67	-C.CC7	C.C07	-C.C01	649.
237	-0.005	0.011	C.C19	-0.C02	0.C11	-0.C05	-86.90	-0.C05	0.011	-0.002	649.
238	-0.003	0.014	C.C18	-0.003	0.014	-0.C03	-84.68	-C.C03	0.014	-0.003	649.
239	-0.001	0.016	C.C17	-0.004	0.C17	-0.C01	-83.03	-0.C01	C.C16	-C.004	649.
240	-0.C01	0.076	C.115	0.C00	0.076	-0.C01	89.96	-0.C01	0.076	0.000	291.

C-61

LTR 144 3B

EL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EPSM	EPSN	EPSMN	TEMPERATURE
241	0.008	0.038	0.068	0.000	0.038	0.008	89.82	0.008	0.038	0.000	345.
242	0.012	0.003	0.029	0.000	0.012	0.003	0.64	0.012	0.003	0.000	394.
243	0.012	-0.029	-0.003	0.000	0.012	-0.029	0.12	0.012	-0.029	0.000	437.
244	0.010	-0.059	-0.031	0.000	0.010	-0.059	0.04	0.010	-0.059	0.000	476.
245	-0.008	0.005	0.028	-0.000	0.005	-0.008	-89.70	-0.008	0.005	-0.000	650.
246	-0.006	0.007	0.026	-0.001	0.007	-0.006	88.66	-0.006	0.007	0.001	649.
247	-0.004	0.010	0.025	0.001	0.010	-0.004	88.28	-0.004	0.010	0.001	649.
248	-0.002	0.013	0.023	0.001	0.013	-0.002	88.63	-0.002	0.013	0.001	649.
249	-0.001	0.016	0.022	0.001	0.016	-0.001	89.13	-0.001	0.016	0.001	649.
250	-0.001	0.076	0.115	0.000	0.076	-0.001	89.99	-0.001	0.076	0.000	291.
251	0.008	0.038	0.068	0.000	0.038	0.008	89.94	0.008	0.038	0.000	345.
252	0.012	0.003	0.029	0.000	0.012	0.003	0.20	0.012	0.003	0.000	394.
253	0.012	-0.029	-0.003	0.000	0.012	-0.029	0.04	0.012	-0.029	0.000	437.
254	0.010	-0.059	-0.031	0.000	0.010	-0.059	0.01	0.010	-0.059	0.000	476.
255	-0.008	0.006	0.032	0.001	0.006	-0.008	87.54	-0.008	0.006	0.001	650.
256	-0.005	0.008	0.030	0.002	0.008	-0.005	85.52	-0.005	0.008	0.002	649.
257	-0.004	0.010	0.028	0.002	0.010	-0.004	85.21	-0.004	0.010	0.002	649.
258	-0.002	0.013	0.027	0.002	0.013	-0.002	85.65	-0.002	0.013	0.002	649.
259	-0.001	0.015	0.026	0.001	0.015	-0.001	87.63	-0.001	0.015	0.001	649.
260	-0.001	0.076	0.115	-0.000	0.076	-0.001	0.0	-0.001	0.076	-0.000	291.
261	0.008	0.038	0.068	-0.000	0.038	0.008	0.0	0.008	0.038	-0.000	345.
262	0.012	0.003	0.029	-0.000	0.012	0.003	0.0	0.012	0.003	-0.000	394.
263	0.012	-0.029	-0.003	-0.000	0.012	-0.029	0.0	0.012	-0.029	-0.000	437.
264	0.010	-0.059	-0.031	-0.000	0.010	-0.059	0.0	0.010	-0.059	-0.000	476.
265	-0.008	0.008	0.034	0.001	0.008	-0.008	88.29	-0.008	0.008	0.001	649.
266	-0.005	0.009	0.031	0.001	0.009	-0.005	87.12	-0.005	0.009	0.001	649.
267	-0.004	0.011	0.030	0.002	0.011	-0.004	86.68	-0.004	0.011	0.002	649.
268	-0.002	0.012	0.028	0.001	0.012	-0.002	87.01	-0.002	0.012	0.001	649.
269	-0.001	0.013	0.027	0.001	0.013	-0.001	88.09	-0.001	0.013	0.001	649.
270	-0.001	0.076	0.115	-0.000	0.076	-0.001	0.0	-0.001	0.076	-0.000	291.
271	0.008	0.038	0.068	-0.000	0.038	0.008	-89.97	0.008	0.038	-0.000	345.
272	0.012	0.003	0.029	-0.000	0.012	0.003	-0.11	0.012	0.003	-0.000	394.
273	0.012	-0.029	-0.003	-0.000	0.012	-0.029	-0.02	0.012	-0.029	-0.000	437.
274	0.010	-0.059	-0.031	-0.000	0.010	-0.059	-0.01	0.010	-0.059	-0.000	476.
275	-0.008	0.010	0.034	0.001	0.010	-0.008	89.11	-0.008	0.010	0.001	649.
276	-0.005	0.010	0.031	0.001	0.010	-0.005	88.41	-0.005	0.010	0.001	649.
277	-0.004	0.011	0.030	0.001	0.011	-0.004	88.06	-0.004	0.011	0.001	649.
278	-0.002	0.011	0.028	0.001	0.011	-0.002	88.16	-0.002	0.011	0.001	649.
279	-0.001	0.012	0.027	0.001	0.012	-0.001	88.79	-0.001	0.012	0.001	649.
280	-0.001	0.076	0.115	0.000	0.076	-0.001	0.0	-0.001	0.076	0.000	291.

LTR144 38

EL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EPSM	EPSN	EPSMN	TEMPERATURE
281	0.008	0.038	0.068	0.000	0.038	0.008	0.0	0.008	0.038	0.000	345.
282	0.012	0.003	0.029	0.000	0.012	0.003	0.0	0.012	0.003	0.000	394.
283	0.012	-0.029	-0.003	0.000	0.012	-0.029	0.0	0.012	-0.029	0.000	437.
284	0.010	-0.059	-0.031	-0.000	0.010	-0.059	0.0	0.010	-0.059	-0.000	476.
285	-0.008	0.010	0.033	0.000	0.010	-0.008	89.66	-0.008	0.010	0.000	649.
286	-0.005	0.011	0.031	0.000	0.011	-0.005	89.36	-0.005	0.011	0.000	649.
287	-0.004	0.011	0.029	0.000	0.011	-0.004	89.19	-0.004	0.011	0.000	649.
288	-0.002	0.011	0.028	0.000	0.011	-0.002	89.22	-0.002	0.011	0.000	649.
289	-0.001	0.011	0.026	0.000	0.011	-0.001	89.49	-0.001	0.011	0.000	649.
290	-0.001	0.076	0.115	0.000	0.076	-0.001	89.97	-0.001	0.076	0.000	291.
291	0.008	0.038	0.067	0.000	0.038	0.008	89.88	0.008	0.038	0.000	345.
292	0.012	0.003	0.029	0.000	0.012	0.003	0.43	0.012	0.003	0.000	394.
293	0.012	-0.029	-0.003	0.000	0.012	-0.029	0.08	0.012	-0.029	0.000	437.
294	0.010	-0.059	-0.031	0.000	0.010	-0.059	0.02	0.010	-0.059	0.000	476.
295	-0.008	0.011	0.033	0.000	0.011	-0.008	89.94	-0.008	0.011	0.000	649.
296	-0.005	0.011	0.031	0.000	0.011	-0.005	89.86	-0.005	0.011	0.000	649.
297	-0.004	0.011	0.029	0.000	0.011	-0.004	89.82	-0.004	0.011	0.000	649.
298	-0.002	0.011	0.027	0.000	0.011	-0.002	89.83	-0.002	0.011	0.000	649.
299	-0.001	0.011	0.026	0.000	0.011	-0.001	89.91	-0.001	0.011	0.000	649.
300	-0.001	0.076	0.115	0.000	0.076	-0.001	89.93	-0.001	0.076	0.000	291.
301	0.008	0.038	0.067	0.000	0.038	0.008	89.69	0.008	0.038	0.000	345.
302	0.012	0.003	0.029	0.000	0.012	0.003	1.12	0.012	0.003	0.000	394.
303	0.012	-0.029	-0.003	0.000	0.012	-0.029	0.21	0.012	-0.029	0.000	437.
304	0.010	-0.059	-0.031	0.000	0.010	-0.059	0.07	0.010	-0.059	0.000	476.
305	-0.008	0.011	0.033	-0.000	0.011	-0.008	0.0	-0.008	0.011	-0.000	649.
306	-0.005	0.011	0.030	-0.000	0.011	-0.005	-89.96	-0.005	0.011	-0.000	649.
307	-0.004	0.011	0.029	-0.000	0.011	-0.004	-89.96	-0.004	0.011	-0.000	649.
308	-0.002	0.011	0.027	-0.000	0.011	-0.002	-89.95	-0.002	0.011	-0.000	649.
309	-0.001	0.011	0.026	-0.000	0.011	-0.001	0.0	-0.001	0.011	-0.000	649.
310	-0.001	0.077	0.115	0.000	0.077	-0.001	89.88	-0.001	0.077	0.000	291.
311	0.008	0.039	0.068	0.001	0.039	0.008	89.51	0.008	0.039	0.001	345.
312	0.012	0.003	0.029	0.001	0.012	0.003	1.80	0.012	0.003	0.001	394.
313	0.012	-0.029	-0.003	0.000	0.012	-0.029	0.34	0.012	-0.029	0.000	437.
314	0.010	-0.060	-0.031	0.000	0.010	-0.060	0.12	0.010	-0.060	0.000	476.
315	-0.008	0.011	0.032	-0.000	0.011	-0.008	0.0	-0.008	0.011	-0.000	649.
316	-0.005	0.011	0.030	-0.000	0.011	-0.005	0.0	-0.005	0.011	-0.000	649.
317	-0.004	0.011	0.029	-0.000	0.011	-0.004	0.0	-0.004	0.011	-0.000	649.
318	-0.002	0.011	0.027	-0.000	0.011	-0.002	0.0	-0.002	0.011	-0.000	649.
319	-0.001	0.011	0.026	-0.000	0.011	-0.001	0.0	-0.001	0.011	-0.000	649.
320	-0.001	0.077	0.116	0.000	0.077	-0.001	89.90	-0.001	0.077	0.000	291.

C-63

LTR 144 38

EL	EPSR	EPSZ	EPST	EPSRZ	EPSMAX	EPSMIN	ANGLE	EPSM	EPSA	EPSMN	TEMPERATURE
321	0.008	0.039	C.C68	C.C00	0.C39	C.C08	89.66	C.C08	C.C39	0.000	345.
322	0.012	0.C03	C.C30	0.C00	0.C12	0.C03	1.23	0.C12	C.CC3	C.C00	394.
323	0.012	-C.C03	-C.C03	C.C00	0.C12	-0.030	0.25	0.C12	-C.C30	0.C00	437.
324	0.010	-0.C60	-C.C31	C.C00	0.C10	-C.C60	0.11	0.C10	-C.C60	C.C00	476.
325	-0.001	0.077	0.118	-C.C00	0.077	-C.C01	-89.86	-C.C01	C.C77	-C.C00	291.
326	0.C09	0.C39	C.C70	-C.C01	0.C39	0.C09	-89.20	0.C09	C.039	-C.C01	345.
327	0.C12	0.C03	C.C31	-C.C01	0.C12	C.C03	-3.08	0.012	0.C03	-0.001	394.
328	0.012	-0.029	-0.C01	-0.001	0.C12	-C.C29	-C.53	C.C12	-C.C29	-0.C01	437.
329	0.C10	-0.C60	-C.C29	-0.C00	0.C10	-0.060	-0.14	0.C10	-0.060	-0.C00	476.
330	-0.001	C.C74	C.121	-C.C02	0.C74	-C.C01	-89.13	-C.C01	0.074	-0.002	291.
331	0.C09	0.C37	C.C73	-0.C04	0.037	C.C09	-85.87	C.C09	C.037	-0.C04	345.
332	0.C12	C.C03	C.C34	-0.005	0.C13	C.C03	-13.18	C.C12	C.C03	-C.C05	394.
333	0.012	-C.C28	C.C01	-C.C04	0.C13	-0.028	-2.75	C.C12	-0.C28	-0.004	437.
334	0.010	-0.058	-C.C27	-C.C02	0.C10	-C.C58	-C.89	C.C10	-C.C58	-0.C02	476.
335	-0.001	0.066	0.124	-C.C06	0.066	-0.C01	-87.57	-C.C01	C.C66	-0.C06	291.
336	0.C09	0.C32	C.C76	-C.C10	0.033	0.C08	-78.80	0.C09	0.032	-0.010	345.
337	0.C13	C.C02	C.C36	-C.C11	0.C15	C.C00	-23.32	0.C13	C.C02	-0.011	394.
338	0.013	-0.025	0.C03	-0.009	0.C13	-0.C26	-7.05	0.C13	-C.C25	-0.C09	437.
339	0.C10	-0.C51	-C.C25	-0.006	0.C10	-0.051	-2.58	0.C10	-0.C51	-0.C06	476.
340	-0.001	0.C51	0.119	-0.C10	0.C51	-C.C01	-84.37	-0.C01	0.051	-0.010	291.
341	0.009	0.025	0.C71	-0.015	0.028	0.C06	-68.41	C.C09	C.C25	-0.015	345.
342	0.C12	C.C01	C.C32	-0.016	0.016	-0.C03	-28.09	0.C12	C.C01	-0.016	394.
343	0.012	-0.C20	-C.C00	-C.C14	0.C13	-0.C21	-12.03	0.C12	-0.020	-0.014	437.
344	0.010	-0.038	-C.C28	-0.C09	0.C10	-0.C39	-5.55	0.C10	-C.C38	-0.009	476.
345	-0.C02	0.C34	C.093	-0.C00	0.034	-0.C02	-89.57	-0.C02	C.C34	-0.C01	291.
346	0.C07	0.C14	C.C48	-C.C15	0.C19	0.C02	-57.19	0.C07	C.014	-0.015	345.
347	0.012	0.C00	0.C11	-0.018	0.C17	-C.C05	-29.01	C.C12	C.C00	-0.018	394.
348	0.013	-0.012	-0.C20	-0.012	0.C14	-0.013	-13.44	0.C13	-C.C12	-0.C12	437.
349	0.C10	-0.C25	-C.C46	C.C02	0.C11	-0.026	1.20	0.010	-0.025	0.C02	476.

\*\*\*\*\*  
TIME REMAINING AT END OF SOLUTION FOR TIME STEP 1 OF CASE 1 IS 60 SECONDS.  
\*\*\*\*\*

LTR1144 38

OVERALL TIME LOG

TRANSFER OF DATA TO UNIT 9-----	4.23
MESH GENERATION-----	0.0
ELEMENT PLOTTING-----	8.15
STIFFNESS MATRIX FORMATION-----	12.93
DISPLACEMENTS-----	13.26
STRESSES-----	9.52
DEFORMED GRID AND/OR CONTROL PLCTS-----	0.0

4-65

4444  
38

LTR1144 38

APPENDIX D

INTENS PROGRAM SOURCE LISTING

COMPILER OPTIONS - NAME= MAIN,CPT=00,LINECNT=58,SIZE=0000K,  
SOURCE,EBCDIC,NOLIST,NODECK,LOAD,MAP,NOEDIT,IO,NOXREF

```

C
C * * * * *
C
C * PROGRAM -- INTENS
C
C * PROGRAM WILL CALCULATE STRESS INTENSITIES FOR NB-3200 ANALYSIS
C
C * PROGRAM WILL BE WRITTEN TO HANDLE 20 TRANSIENT CASES
C
C * NTRAN = NO. OF TRANSIENTS
C * NPROB = NO. OF POINTS OR PROBLEMS, .GT.1-PROG. CONTINUES
C * SCCN = STRESS CONCENTRATION FACTOR
C * ERAT = RATIO OF ELASTIC MODULI - SEE NB-3222.4(E)(4)
C * STRESS(I,J) = STRESS COMPONENT ARRAY, I= NO. OF TRANSIENT
C * NCY(I) = NO. OF CYCLES ARRAY
C * NPT = PROBLEM NUMBER
C
C * * N O T E - - IF R, Z, THETA COORDINATE SYSTEM IS USED, STRESS
C COLUMNS HEADED X, Y, Z, AND XY CORRESPOND TO R, Z,
C THETA, AND RZ STRESSES
C
C * * * * *

```

1-D

```

ISN 0002      IMPLICIT REAL*8(A-H,C-Z)
ISN 0003      COMMON STRESS(20,6),SCOM(210,6),COEF(210,4),PSTRS(210,5),
1             TEST(210,3),
2             NCCM(210,2),NCY(20)
ISN 0004      DIMENSION SDIF(3)
ISN 0005      CALL ECHO
ISN 0006      READ(5,1)NPROB
ISN 0007      1 FORMAT(I5)
ISN 0008      WRITE(6,2)NPROB
ISN 0009      2 FORMAT('1'/////T15,75H * * PROGRAM -- INTENS -- CALCULATION OF T
TRANSIENT STRESS INTENSITIES * *////T15,44H NO. OF PROBLEMS OR POIN
2TS TO BE ANALYZED IS,2X,I2////)

```

```

C
C * INITIALIZE ARRAYS
C

```

```

ISN 0010      5 DO 800 I=1,210
ISN 0011      DO 799 J=1,6
ISN 0012      799 SCOM(I,J)=0.
ISN 0013      DO 798 J=1,5
ISN 0014      798 PSTRS(I,J)=0.
ISN 0015      DO 797 J=1,4
ISN 0016      797 CCEF(I,J)=0.
ISN 0017      TEST(I,1)=0.
ISN 0018      TEST(I,2)=0.
ISN 0019      TEST(I,3)=0.
ISN 0020      NCOM(I,1)=100
ISN 0021      800 NCOM(I,2)=100
ISN 0022      DO 850 I=1,20
ISN 0023      NCY(I)=0
ISN 0024      DO 850 J=1,6
ISN 0025      850 STRESS(I,J)=0.

```

FR1144  
38

C

C \* READ PROBLEM NO. STRESS CONCENTRATION FACTOR, AND E RATIO

C

ISN 0026 READ(5,3)NPT,NTRAN,SCCN,ERAT  
 ISN 0027 3 FORMAT(2I5,2F10.0)  
 ISN 0028 WRITE(6,4)NPT,NTRAN,SCCN,ERAT  
 ISN 0029 4 FORMAT('1'///T15,14H PROBLEM NO. ,12/T15,19H NO. OF TRANSIENTS ,  
 112/T15,30H STRESS CONCENTRATION FACTOR =,F10.3/T15,24H ELASTIC MOD  
 2ULUS RATIO =,F10.3///)

C

C \* READ ONE CARD FOR EACH TRANSIENT CASE  
 C \* CARDS ARE READ IN ORDER FROM 1 TO NTRAN  
 C \* EACH CARD CONTAINS NO. OF CYCLES FOR THAT TRANSIENT AND 6 STRESS  
 C \* COMPONENTS.  
 C \* STRESS COMPONENTS ARE READ IN ORDER: SX,SY,SZ,TSY,TSZ,TSZ  
 C \* IF SAAS3 STRESS COMPONENTS, THE ORDER IS: SR,SZ,ST,TRZ

C

ISN 0030 DO 10 I=1,NTRAN  
 ISN 0031 10 READ(5,6)NCY(I),(STRESS(I,J),J=1,6)  
 ISN 0032 6 FORMAT(I10,6F10.0)  
 ISN 0033 WRITE(6,7)  
 ISN 0034 7 FORMAT(T15,30H \* \* TRANSIENT STRESS DATA \* \*//T15,38H \* \* NOTE THA  
 1T STRESSES ARE IN KSI \* \*//T15, 17HTRANS NO. CYCLES,  
 5 T38,80HSIGMA X  
 2 SIGMA Y SIGMA Z TAU XY TAU XZ TAU  
 3YZ//)

ISN 0035 DO 15 I=1,NTRAN  
 ISN 0036 15 WRITE(6,8)I,NCY(I),(STRESS(I,J),J=1,6)  
 ISN 0037 8 FORMAT(T16,12,T22,18,T35,F10.3,5(5X,F10.3))

C

C \* CALCULATE AND PRINT COMPONENT RANGES FOR ALL TRANSIENT PAIRS

C

ISN 0038 WRITE(6,16)  
 ISN 0039 16 FORMAT('1'///T15,94H\* \* STRESS COMPONENT RANGES - NOTE THAT A TRAN  
 ISIENT NUMBER OF ZERO IMPLIES NULL CONDITIONS \* \*//T15, 71H\* \* THES  
 2E VALUES FOUND BY SUBTRACTING COMPONENTS OF THE TRANSIENT PAIRS//  
 5T5, 99H\* \* NOTE THAT IF AXISYMMETRIC STRESS DATA IS USED-SUCH AS S  
 6AAS3 CUTPUT-STRESS COLUMNS X,Y,Z, AND XY/T9,  
 7 50H-CORRESPOND TO R,Z,T, AND RZ STRESSES, RESPECTIVELY//  
 3T5,83HTRAN. PAIR SIG X SIG Y SIG Z TAU XY  
 4 TAU XZ TAU YZ//)

ISN 0040 N1=0  
 ISN 0041 M=NTRAN-1  
 ISN 0042 M2=NTRAN  
 ISN 0043 DO 20 I=1,NTRAN  
 ISN 0044 DO 19 J=1,6  
 ISN 0045 19 SCOM(I,J)=STRESS(I,J)  
 ISN 0046 NCOM(I,1)=I  
 ISN 0047 NCCM(I,2)=0  
 ISN 0048 WRITE(6,36)(NCOM(I,K),K=1,2),(SCOM(I,L),L=1,6)  
 ISN 0049 20 CCNTINUE  
 ISN 0050 25 N1=N1+1  
 ISN 0051 DO 50 I=N1,M  
 ISN 0052 N3= I+1  
 ISN 0053 DO 40 J=N3,NTRAN  
 ISN 0054 M2=M2+1

LTR 1 4 38

```

ISN 0055      NCOM(M2,1)=1
ISN 0056      NCOM(M2,2)=J
ISN 0057      DO 30 K=1,6
ISN 0058      30 SCCM(M2,K)= (STRESS(I,K)-STRESS(J,K))
ISN 0059      40 WRITE(6,36)(NCOM(M2,L),L=1,2),(SCOM(M2,L2),L2=1,6)
ISN 0060      36 FORMAT(T5,2I4,T19,F10.3,5(2X,F10.3))
ISN 0061      50 CONTINUE

```

```

C
C * CALCULATE AND PRINT COEFFICIENTS FOR TRIAXIAL STRESS EQUATION
C

```

```

ISN 0062      WRITE(6,58)
ISN 0063      58 FORMAT('1'/////T15, 994* * COEFFICIENTS FOR TRIAXIAL STRESS EQUATIO
IN - CORRELATE COLUMN HEADINGS TO FORM AX**3+BX**2+CX+D=0//T5,60HTR
2AN. PAIR      A          B          C          D/I)
ISN 0064      DO 60 I=1,M2
ISN 0065      CCEF(I,1)=1.0
ISN 0066      CCEF(I,2)=- (SCOM(I,1)+SCOM(I,2)+SCOM(I,3))
ISN 0067      CCEF(I,3)= SCOM(I,1)*SCOM(I,2) + SCOM(I,2)*SCOM(I,3) +
1 SCOM(I,1)*SCOM(I,3) - SCOM(I,6)*SCOM(I,6)-SCOM(I,4)*SCOM(I,4)
ISN 0068      CCEF(I,4)= -(SCOM(I,1)*SCOM(I,2)*SCOM(I,3) + 2.*SCOM(I,6)*SCOM(I,5
1)*SCOM(I,4) - SCOM(I,1)*SCOM(I,6)*SCOM(I,6)
2-SCOM(I,2)*SCOM(I,5)*SCOM(I,5)-SCOM(I,3)*SCOM(I,4)*SCOM(I,4))
ISN 0069      60 WRITE(6,59)(NCOM(I,J),J=1,2),(CCEF(I,L),L=1,4)
ISN 0070      59 FORMAT(T5,2I4,T19,F10.3,3(2X,D12.4))

```

```

C
C * SOLVE TRIAXIAL STRESS EQUATION FOR PRINC. STRESSES OF EACH
C * TRANSIENT PAIR
C
C * FIRST DETERMINE INITIAL TEST VALUES
C

```

```

ISN 0071      DO 70 I=1,M2
ISN 0072      DO 65 J=1,3
ISN 0073      65 TEST(I,J)=DABS(SCOM(I,J))
ISN 0074      66 IND = 0
ISN 0075      X22=0.
ISN 0076      DO 67 L=1,2
ISN 0077      IF(TEST(I,L).LE.TEST(I,L+1))GO TO 67
ISN 0079      IND=1
ISN 0080      X22= TEST(I,L)
ISN 0081      TEST(I,L)=TEST(I,L+1)
ISN 0082      TEST(I,L+1)= X22
ISN 0083      67 CONTINUE
ISN 0084      IF(IND.EQ.1) GO TO 66
ISN 0086      69 CONTINUE
ISN 0087      G = TEST(I,3)+10.
ISN 0088      CALL TRYERR(I,G,IR)
ISN 0089      IF(IR.EQ.1) GO TO 927

```

```

C
C * CALCULATE MAXIMUM STRESS INTENSITY
C

```

```

ISN 0091      SCIF(1) =DABS(PSTRS(I,1) - PSTRS(I,2))
ISN 0092      SCIF(2) =DABS(PSTRS(I,2) - PSTRS(I,3))
ISN 0093      SCIF(3) =DABS(PSTRS(I,3) - PSTRS(I,1))
ISN 0094      X22 = 0.
ISN 0095      71 IND = 0
ISN 0096      DO 68 L1=1,2

```

LTR1144 38

D-3

```

ISN 0097      IF(SCIF(L1).LE.SDIF(L1+1)) GO TO 68
ISN 0099      IND = 1
ISN 0100      X22 = SDIF(L1)
ISN 0101      SDIF(L1) = SDIF(L1+1)
ISN 0102      SDIF(L1+1) = X22
ISN 0103      69 CONTINUE
ISN 0104      IF(IND.EQ.1) GO TO 71
ISN 0106      903 CONTINUE
ISN 0107      PSTRS(I,4) = SDIF(3)
ISN 0108      PSTRS(I,5) = PSTRS(I,4)*SCON*ERAT*0.50
ISN 0109      GO TO 70
ISN 0110      927 WRITE(6,928)(NCOM(I,L23),L23=1,2)
ISN 0111      928 FORMAT(T15,'TRAN. PAIR ',2I4,' HAS COMPLEX ROOTS IN TRIAXIAL STRES
                15 EQUATION')

```

```

C
C * NOTE PSTRS ARRAY NOW CONTAINS PRINC. STRESSES IN FIRST THREE
C * POSITIONS, MAXIMUM STRESS INTENSITY IN POSITION 4, AND ALTERNATING
C * STRESS INTENSITY MULTIPLIED BY STRESS CONC. FACTOR AND E RATIO IN
C * POSITION 5.
C

```

```

ISN 0112      70 CONTINUE
ISN 0113      WRITE(6,81)
ISN 0114      81 FORMAT('1'///T15, 91H* * PRINCIPAL STRESSES, MAXIMUM STRESS INTENS
                1ITY AND ALTERNATING STRESS INTENSITY FOLLOW* *//T15, 57H* * NOTE T
                2HAT ALL STRESSES IN THIS PROGRAM ARE IN <SI * *//T15,109H * NOTE
                3THAT ALTERNATING STRESS INTENSITY HAS BEEN MULTIPLIED BY STRESS CO
                4NCENTRATION FACTOR AND E RATIO * *//T5,69HTRAN. PAIR . SIGMA 1
                5 SIGMA 2      SIGMA 3      S INT      ALT S.I./)

```

```

ISN 0115      DC 80 I=1,M2
ISN 0116      80 WRITE(6,82)(NCOM(I,J),J=1,2),(PSTRS(I,L),L=1,5)
ISN 0117      82 FORMAT(T5,2I4,T16,F10.3,4(2X,F10.3))

```

```

C
C * ORDER ALTERNATING STRESS INTENSITIES FROM MAX. TO MIN.
C

```

```

ISN 0118      M6=M2-1
ISN 0119      90 IND=0
ISN 0120      DC 100 I=1,M6
ISN 0121      IF(PSTRS(I,5).GE.PSTRS(I+1,5))GO TO 100
ISN 0123      IND = 1
ISN 0124      X22 = PSTRS(I,5)
ISN 0125      PSTRS(I,5) = PSTRS(I+1,5)
ISN 0126      PSTRS(I+1,5)=X22
ISN 0127      IC1= NCOM(I,1)
ISN 0128      IC2= NCOM(I,2)
ISN 0129      NCOM(I,1)= NCOM(I+1,1)
ISN 0130      NCOM(I,2)= NCOM(I+1,2)
ISN 0131      NCOM(I+1,1)= IC1
ISN 0132      NCOM(I+1,2)=IC2
ISN 0133      100 CONTINUE
ISN 0134      IF(IND.EQ.1) GO TO 90
ISN 0136      937 CONTINUE
ISN 0137      WRITE(6,105)
ISN 0138      105 FORMAT('1'/////T15,58H* * ALTERNATING STRESS INTENSITIES ORDERED F
                1ROM MAX TO MIN//T15,61H* * NOTE THAT ZERO TRANSIENT NUMBER INDICAT
                2ES NULL CONDITIONS///T5, 46HTRAN. PAIR      SPECIFIED NO. CYCLES      A
                3LT. S.I./)

```

LTR1144 38

```
ISN 0139      DC 120 I=1,M2
ISN 0140      IF(NCOM(I,2).EQ.0) GC TO 117
ISN 0142      IF(NCY(NCOM(I,1)).LE.NCY(NCOM(I,2))) GC TO 117
ISN 0144      ICY = NCY(NCOM(I,2))
ISN 0145      GC TO 118
ISN 0146      117 ICY = NCY(NCOM(I,1))
ISN 0147      118 WRITE(6,119)(NCOM(I,J),J=1,2),ICY,PSTRS(1,5)
ISN 0148      119 FORMAT(T5,2I4,T22,I8,T40,F10.3)
ISN 0149      120 CONTINUE
ISN 0150      IF(NPT.GE.NPROB) GC TO 1000
ISN 0152      GC TO 5
ISN 0153      1000 STOP
ISN 0154      END
```

D-5

LTR 1144 38

NAME	TAG	TYPE	ADD.	NAME	TAG	TYPE	ADD.	NAME	TAG	TYPE	ADD.	NAME	TAG	TYPE	ADD.
G SFA		R*8	000838	I SFA		I*4	000804	J SFA		I*4	000808	K SF		I*4	00080C
L SF		I*4	000810	M SF		I*4	000814	IR SFA		I*4	000818	L1 SF		I*4	00081C
L2 F		I*4	000820	M2 SF		I*4	000824	M6 SF		I*4	000828	N1 SF		I*4	00082C
N3 SF		I*4	000830	ICY SF		I*4	000834	IC1 SF		I*4	000838	IC2 SF		I*4	00083C
INL S		I*4	000840	L23 F		I*4	000844	NCY SF	C	I*4	008070	NPT SF		I*4	000848
X22 SF		R*8	000930	CCEF SF	C	R*3	002820	ECHO SF	XF	R*8	000C00	ERAT SF		R*8	000868
NCCM SF	C	I*4	0079E0	SCCM SFA	C	R*3	0003C0	SCON SF		R*8	000870	SDIF SF		R*8	000878
TEST SF	C	R*8	006630	NPROB SF		I*4	00084C	NTRAN SF		I*4	000850	PSTRS SFA	C	R*8	004560
IBCON# F	XF	R*8	000000	STRESS SF	C	R*3	000C00	TRYERR SF	XF	R*8	000C00				

\*\*\*\*\* COMMON INFORMATION \*\*\*\*\*

NAME OF COMMON BLOCK	*	SIZE OF BLOCK	0080C0 HEXADECIMAL BYTES
VAR. NAME	TYPE	REL. ADDR.	VAR. NAME TYPE REL. ADDR.
STRESS	R*8	000000	SCCM R*8 0003C0
TEST	R*8	006630	NCCM I*4 0079E0
			NCY I*4 008070
			PSTRS R*8 004560

0-0

LTR144  
38

LABEL ADDR

LABEL ADDR

LABEL ADDR

LABEL ADDR

PAGE 007

5 000B14  
800 000C6A  
19 000EFO  
40 0010FA  
66 0015EC  
68 001844  
80 001950  
117 001BEA

799 000B24  
850 000CB8  
20 00100C  
50 0011AE  
67 0016E4  
903 00186E  
90 001A0E  
118 001C08

798 000B70  
10 000D84  
25 001022  
60 0014C8  
69 001708  
927 0018C2  
100 001B30  
120 001C80

797 000BBC  
15 000E24  
30 001078  
65 00158A  
71 0017C6  
70 00191C  
937 001B54  
1000 001CAA

\*OPTIONS IN EFFECT\* NAME= MAIN,CPT=00,LINECNT=58,SIZE=0000K,

\*OPTIONS IN EFFECT\* SOURCE,EBCDIC,NDLIST,NODECK,LOAD,MAP,NOEDIT,NOXREF

\*STATISTICS\* SOURCE STATEMENTS = 153 ,PROGRAM SIZE = 7384

\*STATISTICS\* NO DIAGNOSTICS GENERATED

\*\*\*\*\* END OF COMPILATION \*\*\*\*\*

0-7

171144 35

COMPILER OPTIONS - NAME= MAIN,OPT=CC,LINECNT=58,SIZE=0000K,  
SOURCE,EBCCIC,NOLIST,NODECK,LOAD,MAP,NOEDIT,ID,NOXREF

ISN 0002 SUBROUTINE TRYERR(K,G,IK)  
ISN 0003 IMPLICIT REAL\*8(A-F,C-Z)  
ISN 0004 COMMON STRESS(20,6),SCCM(210,6),COEF(210,4),PSTRS(210,5),  
1 TEST(210,3),  
2 NSCM(210,2),ACY(20)

C  
C  
C  
C  
C  
C

\* SUBROUTINE USES TRIAL AND ERROR METHOD TO FIND FIRST ROOT  
\* ADDITIONAL ROOTS FOUND FROM QUADRATIC EQUATION

ISN 0005 N2 = 1  
ISN 0006 NSOL=0  
ISN 0007 R1=0.  
ISN 0008 R2=0.  
ISN 0009 IR = 0  
ISN 0010 IF(COEF(K,4).NE.0.D+0) GO TO 18  
ISN 0012 AA = CCEF(K,1)  
ISN 0013 BB = CCEF(K,2)  
ISN 0014 CC = COEF(K,3)  
ISN 0015 PSTRS(K,1) = 0.G  
ISN 0016 GC TO 476  
ISN 0017 18 B=1.0  
ISN 0018 N=0  
ISN 0019 X=G  
ISN 0020 10 N=N+1  
ISN 0021 Y=CCEF(K,4)  
ISN 0022 DC 15 I=1,3  
ISN 0023 EI=1  
ISN 0024 INDS = 0  
ISN 0025 X1= DABS(X)  
ISN 0026 IF(X.GE.0.D+0) GC TO 500  
ISN 0028 INDS = 1  
ISN 0029 500 Y22 = COEF(K,4-I)\*X1\*\*EI  
ISN 0030 IF(INDS.EQ.1.AND.I.NE.2) Y22 = -Y22  
ISN 0032 15 Y = Y + Y22  
ISN 0033 R1=X  
ISN 0034 CHK1 =DABS(Y)  
ISN 0035 IF(CHK1.LE.10-05)GC TO 100  
ISN 0037 IF(Y.LT.0.D+0) IND=0  
ISN 0039 IF(Y.GT.0.D+0) IND=1  
ISN 0041 IF(N.EQ.1) IND2=INC  
ISN 0043 IF(IND.NE.IND2) GO TO 70  
ISN 0045 R2=R1  
ISN 0046 RK=-G  
ISN 0047 IF(X.EQ.RK) GC TO 150  
ISN 0049 X=X-B  
ISN 0050 GC TO 10  
ISN 0051 70 B=0.10\*8  
ISN 0052 X=R2-B  
ISN 0053 INC=IND2  
ISN 0054 GC TO 10  
ISN 0055 100 NSOL=NSCL+1  
ISN 0056 PSTRS(K,NSOL) = X

8-0

LTR1144 38

```
ISN 0057      NC=3-NSCL
ISN 0058      IF(N0.EQ.0) GO TO 1000
ISN 0060      AA = 1.0
ISN 0061      BB = C0FF(K,2)+X
ISN 0062      CC = C0FF(K,3) - BB*(-X)
ISN 0063      476 C21 = (BB*BB - 4.*AA*CC)
ISN 0064      C23 = CABS(C21)
ISN 0065      IF(C23.LT..1D-6) C21=0.D+0
ISN 0067      IF(C21.LT.0.D+0) GO TO 826
ISN 0069      PSTRS(K,2) = (-BB + DSQRT(C21))/(2.*AA)
ISN 0070      PSTRS(K,3) = (-BB - DSQRT(C21))/(2.*AA)
ISN 0071      GC TO 1000
ISN 0072      826 IR = 1
ISN 0073      GC TO 1000
ISN 0074      150 N2 = N2+1
ISN 0075      IF(N2.EC.6) GO TO 155
ISN 0077      G = G+10.
ISN 0078      GC TO 18
ISN 0079      155 WRITE(6,200)(NCOM(K,M3),M3=1,2)
ISN 0080      200 FORMAT(/T15,'* * AFTER 6 DIFFERENT INITIAL VALUES HAVE BEEN TRIED
                1 FOR TRANSIENT PAIR',2X,2I4)
ISN 0081      WRITE(6,151)
ISN 0082      151 FORMAT(/T10,'NO ADDITIONAL ROOTS WERE FOUND IN THE INPUT TEST VAL
                1UE RANGE. RETURNING TO MAIN LINE'/)
ISN 0083      1000 RETURN
ISN 0084      END
```

6-D

LTR1144 38

NAME	TAG	TYPE	ADD.	NAME	TAG	TYPE	ADD.	NAME	TAG	TYPE	ADD.	NAME	TAG	TYPE	ADD.		
B	SF	R*8	0001F0	G	SF	R*8	0001F8	I	SF	I*4	0001C0	K	F	I*4	0001C4		
N	SF	I*4	0001C8	X	SFA	R*8	000200	Y	SFA	R*8	000208	AA	SF	R*8	000210		
BB	SF	R*8	000218	CC	SF	R*8	000220	EI	SF	R*8	000228	IR	S	I*4	0001C0		
M3	F	I*4	0001C0	NC	S	I*4	000104	N2	SF	I*4	000108	RK	S	R*8	000230		
R1	SF	R*8	000238	R2	SF	R*8	000240	X1	SF	R*8	000248	C21	SFA	R*8	000250		
C23	S	R*8	000258	IND	SF	I*4	0001DC	NCY	C	I*4	N.R.	Y22	SF	R*8	000260		
CHK1	S	R*8	000268	COEF	F	C	R*8	002B20	INDS	S	I*4	0001E0	INC2	SF	I*4	0001E4	
NCOM	F	C	I*4	0079E0	NSGL	SF	I*4	0001F8	SCOM	C	R*8	N.R.	TEST	C	R*8	N.R.	
PSTRS	S	C	R*8	004560	DSGRT	XF	R*8	000000	FDXPD#	XF	R*8	000000	IBCOM#	F	XF	I*4	000000
STRESS	C	R*8	N.R.	TRYERR		R*8	000270										

\*\*\*\*\* COMMON INFORMATION \*\*\*\*\*

NAME OF COMMON BLOCK \* \* SIZE OF BLOCK 0080C0 HEXADECIMAL BYTES

VAR. NAME	TYPE	REL. ADDR.	VAR. NAME	TYPE	REL. ADDR.	VAR. NAME	TYPE	REL. ADDR.	VAR. NAME	TYPE	REL. ADDR.
STRESS	R*8	N.R.	SCOM	R*8	N.R.	COEF	R*8	002B20	PSTRS	R*8	004560
TEST	R*8	N.R.	NCCM	I*4	0079E0	NCY	I*4	N.R.			

D-10

LRR144 38

LABEL ADDR

LABEL ADDR

LABEL ADDR

LABEL ADDR

PAGE 004

18 0003F0  
70 0005B4  
150 000754

10 000408  
100 0005E8  
155 00077C

500 000488  
476 000660  
1000 0007E8

15 0004F8  
826 000746

\*OPTIONS IN EFFECT\* NAME= MAIN,OPT=00,LINECNT=59,SIZE=0000K,

\*OPTIONS IN EFFECT\* SOURCE,EBCDIC,NOLIST,NODECK,LOAD,MAP,NOEDIT,IO,NCXREF

\*STATISTICS\* SOURCE STATEMENTS = 83 ,PROGRAM SIZE = 2114

\*STATISTICS\* NO DIAGNOSTICS GENERATED

\*\*\*\*\* END OF COMPILATION \*\*\*\*\*

29K BYTES OF CORE NOT USED

\*STATISTICS\* NO DIAGNOSTICS THIS STEP

0-11

LTR1144  
38

IEF142I - STEP WAS EXECUTED - CCNE CODE 0000  
 IEF285I SYS77283.T120647.SV000.MEN2#BFA.RC000224 SYSOUT  
 IEF285I VOL SER NCS= SPCL31.  
 IEF285I SYS77283.T120647.RV000.MEN2#BFA.LCADSET PASSED  
 IEF285I VOL SER NCS= DSKC06.  
 IEF285I SYS77283.T123456.I0007.MEN2#BFA.SCC00086 SYSIN  
 IEF285I VOL SER NCS= SPCL02.  
 IEF285I SYS77283.T123456.I0007.MEN2#BFA.SC000086 DELETED  
 IEF285I VOL SER NCS= SPCL02.  
 IEF373I STEP /C / START 77283.1406  
 IEF374I STEP /C / STOP 77283.1408 CPU OMIN 04.35SEC MAIN 168K LCS OK  
 WAIT 0000MIN 16.20SEC SYSIN 00022REC UNUSED CORE 002K EXCPS 000062 SYSHRS .002036  
 354 000032X;331 000012X;235 000018X  
 XXL EXEC PGM=IEWL,PARM='ELMAP,LET,LIST,&CVLY', 00000140  
 IEF653I SUBSTITUTION JCL - PGM=IEWL,PARM='MAP,LET,LIST,',  
 XX CCND=(4,LT,C),REGION=100K,TIME=&LTIME 00000150  
 IEF653I SUBSTITUTION JCL - COND=(4,LT,C),REGION=100K,TIME=5  
 XXSYSLIN DD DSNAME=&LOAD,DISP=(OLD,DELETE) 00000160  
 IEF653I SUBSTITUTION JCL - DSNAME=&&LOADSET,DISP=(OLD,DELETE)  
 XX DD DDNAME=SYSIN 00000170  
 XXSYSUT1 DD SPACE=(3072,(30,10)),UNIT=DKSCRA 00000180  
 XXSYSLIB DD DSNAME=SYS1.FORTLIB,DISP=SHR 00000190  
 XX DD DSNAME=SYS1.FORTRAN,DISP=SHR 00000200  
 XXSYSPRINT DD SYSOUT=A,SPACE=(TRK,(3,10)) 00000210  
 XXSYSLMOD DD DSNAME=&G0SET&MEMR,DISP=&DISP,UNIT=&UNIT,SPACE=&SPACE 00000220  
 IEF653I SUBSTITUTION JCL - DSNAME=&&G0SET(MAIN),DISP=(NEW,PASS),UNIT=DKSCRA,SPACE=(3072,(30,10,1),RLSE)  
 IEF236I ALLOC. FOR MEN2#BFA L  
 IEF237I 331 ALLOCATED TO SYSLIN  
 IEF237I 230 ALLOCATED TO SYSUT1  
 IEF237I 137 ALLOCATED TO SYSLIB  
 IEF237I 137 ALLOCATED TO  
 IEF237I 354 ALLOCATED TO SYSPRINT  
 IEF237I 231 ALLOCATED TO SYSLMOD

012

LR1144 38

F88-LEVEL LINKAGE EDITOR OPTIONS SPECIFIED MAP,LET,LIST  
 DEFAULT OPTION(S) USED - SIZE=(92160,8192)

MODULE MAP

CONTROL SECTION

ENTRY

NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION
MAIN	00	1CD8								
TRYERR	1CD8	842								
IHCLSORT*	2520	158								
			DSQRT	2520						
ECHC *	2680	50C								
IHCCEOMH*	2890	F41								
			I8COM#	2890	FDIOCS#	2C4C	INTSWTCH	3AB6		
IHCCOMH2*	3AD8	65C								
			SECCASD	3E50						
IHCFCVTH*	4138	119C								
			ADCON#	4138	FCVAOUTP	41E2	FCVLOUTP	4272	FCVZOUTP	43C2
			FCVICOUTP	4770	FCVEOUTP	4C72	FCVCOUTP	4E8C	INT6SWCH	5173
IHCFNTH*	52D8	512								
			ARITH#	52D8	ADJSWTCH	5644				
IHCFIOS*	57F0	1378								
			FICCS#	57F0	FIOCSBEP	57F6				
IHCDOPT *	6868	320								
IHCERRM *	6E88	58C								
			ERRMON	6E88	IHCERRE	6EAO				
IHCUATBL*	7448	638								
IHCETRCH*	7A80	28E								
			IHCTRCH	7A80	ERRTRA	7A88				
IHCFOXPD*	7D10	1A0								
			FOXPD#	7D10						
IHCLEXP *	7E80	288								
			DEXP	7E80						
IHCLLOG *	8138	200								
			DLOG10	8138	DLOG	8150				
\$BLANKCOM	8338	80C0								

ENTRY ADDRESS 00  
 TOTAL LENGTH 103F8 = 66,552(10)

\*\*\*\*MAIN DOES NOT EXIST BUT HAS BEEN ADDED TO DATA SET

D-13

LTR1144 38

```

IEF142I - STEP WAS EXECUTED - COND CODE 0000
IEF285I SYS77283.T120647.RV000.MEN2#BFA.LOADSET DELETED
IEF285I VOL SER NCS= DSK006.
IEF285I SYS77283.T120647.RV000.MEN2#BFA.RCCCG225 DELETED
IEF285I VOL SER NCS= DSK002.
IEF285I SYS1.FCRTLIB KEPT
IEF285I VOL SER NCS= DSKIPL.
IEF285I SYS1.FORTRAN KEPT
IEF285I VOL SER NCS= DSKIPL.
IEF285I SYS77283.T120647.SVC00.MEN2#BFA.RC000226 SYSCUT
IEF285I VOL SER NOS= SPOL31.
IEF285I SYS77283.T120647.RV000.MEN2#BFA.GCSET PASSED
IEF285I VOL SER NCS= DSK005.
IEF373I STEP /L / START 77283.140F
IEF374I STEP /L / STOP 77283.1406 CPU OMI 01.22SEC MAIN 98K LCS OK
WAIT 000MIN 13.75SEC SYSIN C000REC UNUSED C0RE 002K EXCPS 000166 SYSHRS .001069
331 000013X;000 C00000X;230 C0C032X;137 0C0044X;137 000000X;354 C0C043X;231 0C0034X
XXX EXEC PGM=*.L.SYSLMDD,COND=((4,LT,C),(4,LT,L)), C0000230
XX REGION=&XREG,TIME=&XTIME C0000240
IEF653I SUBSTITUTION JCL - REGION=200K,TIME=2
XXFT05F001 DD DDNAME=SYSIN 00000250
XXFT06F001 DD SYSOUT=A,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=1596), C0000260
XX SPACE=(7980,(&XPGS,16),RLSE) 0C000270
IEF653I SUBSTITUTION JCL - SPACE=(7980,(299,16),RLSE)
XXPLOT DD &PLOT,SPACE=(TRK,(&TP1,&TP2)),UNIT=DKSPDL 00000280
IEF653I SUBSTITUTION JCL - CUMY,SPACE=(TRK,(20,20)),UNIT=DKSPOL
//X.SYSIN DD DSN=SYS77283.T123456.10007.MEN2#BFA.S0000091,
// VOL=SER=(SPOL03),DISP=(OLD,DELETE),UNIT=DKSPOL
//
IEF236I ALLOC. FOR MEN2#BFA X
IEF237I 231 ALLOCATED TO PGM=*.DD
IEF237I 136 ALLOCATED TO FT05F001
IEF237I 236 ALLOCATED TO FT06F001

```

D-14

LTR1144 38

LTR1144 38

APPENDIX E

MICROFICHE LISTINGS AND OUTPUT