

ornl

OAK
RIDGE
NATIONAL
LABORATORY

UNION
CARBIDE

NUREG/CR-1530, Part 2
ORNL/NUREG-80/P2

MASTER

Potential Radiological Impact
of Tornadoes on the Safety of
Nuclear Fuel Services' West
Valley Fuel Reprocessing Plant

2. Reentrainment and Discharge
of Radioactive Materials

W. Davis, Jr.

NUCLEAR
OVER

Prepared for the
U.S. Nuclear Regulatory Commission
Division of Fuel Cycle and Material Safety
Office of Nuclear Material Safety and Safeguards
Under Interagency Agreement DOE 40-549-75

OPERATED BY
UNION CARBIDE CORPORATION
FOR THE UNITED STATES
DEPARTMENT OF ENERGY

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

JTS

Printed in the United States of America. Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road, Springfield, Virginia 22161

Available from
GPO Sales Program
Division of Technical Information and Document Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

COVER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

NUREG/CR-1530, Part 2
ORNL/NUREG-80/P2

Contract No. W-7405-eng-26

NUREG/CR--1530-Pt.2

CHEMICAL TECHNOLOGY DIVISION

TI86 000954

POTENTIAL RADIOLOGICAL IMPACT OF TORNADOES ON THE SAFETY
OF NUCLEAR FUEL SERVICES' WEST VALLEY FUEL REPROCESSING PLANT

2. REENTRAINMENT AND DISCHARGE OF RADIOACTIVE MATERIALS

W. Davis, Jr.

Manuscript Completed: November 1979


Date Published: July 1981

Prepared for the
U.S. Nuclear Regulatory Commission
Division of Fuel Cycle and Material Safety
Office of Nuclear Material Safety and Safeguards
Washington, D.C. 20555
Under Interagency Agreement DOE 40-549-75
NRC FIN No. B0102

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
DEPARTMENT OF ENERGY

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

mf
JES



CONTENTS

| | <u>Page</u> |
|---|-------------|
| ACKNOWLEDGMENTS. | v |
| ABSTRACT | 1 |
| 1. SUMMARY AND CONCLUSIONS | 1 |
| 2. INTRODUCTION | 2 |
| 3. RADIAOCTIVE MATERIALS IN NFS CELLS | 4 |
| 3.1 Elemental and Nuclide Composition | 5 |
| 3.2 Dose-Rate Calculations | 6 |
| 3.3 Surface Concentrations of Reference Fuel in Head-End Cells | 14 |
| 3.3.1 Concerning dose-rate measurements in the PMC (Table 8) | 14 |
| 3.3.2 Concerning dose-rate measurements in the GPC (Table 9) | 20 |
| 4. RESUSPENSION OR REENTRAINMENT | 21 |
| 4.1 A Model of Reentrainment | 21 |
| 4.2 Reentrainment in the Head-End Cells | 28 |
| 4.2.1 Assumed air-space shape | 32 |
| 4.2.2 Differential area/wind speed analysis | 47 |
| 4.3 Source Term for Radioactive Airborne Releases | 53 |
| 5. APPENDIXES. | 59 |
| 5.1 Appendix A: Analysis of Samples from the General Purpose Cell | 61 |
| 5.1.1 Radioactivity from gamma-ray analyses | 61 |
| 5.1.2 Distribution of sizes of particles on wipe papers | 65 |
| 5.2 Appendix B: Calculation of Fractional Resuspension . . | 75 |
| 6. REFERENCES. | 79 |



ACKNOWLEDGMENTS

I am very pleased to acknowledge the guidance of A. T. Clark, L. S. Person, and C. J. Haughney of the Office of Nuclear Material Safety and Safeguards, U.S. Nuclear Regulatory Commission, during the development of this report. Calculations with the TVENT and SOLA-ICE codes were performed by L. J. Holloway and R. W. Andrae, authors of Part 1 of this report. I thank Alden Pierce, Clyde Alday, and their colleagues at Nuclear Fuel Services for providing details of the head-end cells of the plant, for the new data on dose rates in these cells, and for obtaining the cladding hulls and wipe samples from the Central Purpose Cell. Finally, I thank C. W. Nestor, Jr., of the Computer Sciences Division, for valuable discussions concerning several mathematical aspects of this report and members of the ORNL Analytical Chemistry Division for gamma-ray spectroscopic and particle counting data on the samples obtained from Nuclear Fuel Services.

POTENTIAL RADIOLOGICAL IMPACT OF TORNADOES ON THE SAFETY OF
NUCLEAR FUEL SERVICES' WEST VALLEY FUEL REPROCESSING PLANT
2. REENTRAINMENT AND DISCHARGE OF RADIOACTIVE MATERIALS

W. Davis, Jr.

ABSTRACT

This report describes results of a parametric study of quantities of radioactive materials that might be discharged by a tornado-generated depressurization on contaminated process cells within the presently inoperative Nuclear Fuel Services' (NFS) fuel reprocessing facility near West Valley, New York. The study involved the following tasks: determining approximate quantities of radioactive materials in the cells and characterizing particle-size distribution; estimating the degree of mass reentrainment from particle-size distribution and from air speed data presented in Part 1; and estimating the quantities of radioactive material (source term) released from the cells to the atmosphere. The study has shown that improperly sealed manipulator ports in the Process Mechanical Cell (PMC) present the most likely pathway for release of substantial quantities of radioactive material in the atmosphere under tornado accident conditions at the facility.

1. SUMMARY AND CONCLUSIONS

This is the second of a two-part report on methods used to estimate the potential radiological impacts of a tornado strike at the presently inoperative Nuclear Fuel Services' (NFS) fuel reprocessing plant near West Valley, N.Y. This part includes estimating the quantities of radioactive materials (irradiated nuclear fuels) in the Process Mechanical Cell (PMC) and the General Purpose Cell (GPC) and evaluating the degree of reentrainment of these materials. Finally, estimated ranges of reentrainment are combined with the near-floor wind speeds presented in Part 1 to derive source terms for tornadoes with maximum wind speeds of 100, 200, and 300 mph. Estimates of quantities of radioactive materials in the PMC and GPC are based on combining measured in-cell gamma-ray dose-rate measurements with a defined reference fuel and calculations with the ORIGEN and SDC computer codes. Parametric reentrainment calculations are based on several factors, including previously reported particle-size distributions and particulate terminal settling and threshold friction speeds.

In Part 1 it is concluded that the most direct pathway involves the discharge of air through inadequately sealed manipulator ports in the PMC. From the volume of air so discharged, we conclude that no radioactive material will be discharged if the tornado has a maximum speed of 100 mph. However, radioactive materials will be discharged from the PMC when wind speeds are 200 or 300 mph whether building walls surrounding this cell remain intact or are destroyed. With the walls and doors intact, the quantities of fission products discharged into the PMC operating aisles will be in the order of 60 to 4000 Ci at 200 mph and 200 to 10,000 Ci at 300 mph. Corresponding quantities of actinides are 10 to 800 Ci and 50 to 2000 Ci. This material would most likely settle in the operating aisle; however, winds accompanying the tornado could generate high enough air flows in the corridors to carry the radioactive particles out of the building. With the building walls and doors destroyed, still larger quantities of radioactive materials would be discharged directly to the environment.

The average age of the reactor fuel particles in which these radioactive materials are contained is ~10 years as of November 1978. Three cladding hulls and three wipe samples obtained from NFS were analyzed by gamma-ray spectroscopy. Frequencies of particle sizes on the wipe samples are shown to conform to a lognormal distribution.

The analyses of the two parts of this report show clearly that the simplest method for eliminating any potential for significant radiological impact from a tornado strike at the NFS plant would be to install secure plugs in all manipulator ports of the PMC and GPC that are now lightly covered with cardboard or plywood, including the port in the GPC now used as an inlet for a hose carrying carbon dioxide for fire extinguishing. Analysis of the facility with these proposed modifications included indicates that radiological releases from the head-end cells during a tornado strike would essentially be eliminated by these alterations.

2. INTRODUCTION

Nuclear Fuel Services (NFS), Inc., established the first commercial facility for processing irradiated Nuclear fuels at West Valley, New York, on the property of the Western New York Nuclear Service Center (WNYNSC) in 1966. The plant was operated until 1972 during which time 640 metric tons of irradiated fuel were processed. The plant was originally shut down in 1972 because of plans to expand capacity; on September 22, 1976, NFS announced its decision to withdraw from the nuclear fuel reprocessing business. The history of the WNYNSC and the interactions of local residents, and local, state, and federal agencies have been documented in ref. 1.

The NRC is concerned with the ability of the NFS plant in its present shutdown status to contain radioactive materials within the head-end processing cells in the event of a tornado strike at the facility.² Gamma-ray dose rate measurements have shown that there are significant quantities of radioactive materials in the Process Mechanical Cell (PMC), the General Purpose Cell (GPC), and the Chemical Process Cell (CPC). The NRC has sponsored a study by Los Alamos Scientific Laboratory (LASL) of tornado-induced air flow in nuclear facilities in an effort to learn how radioactive materials might be transferred through ventilation systems under tornado conditions.³ The LASL study led to the development of the TVENT computer code^{3,4} used in Part 1 of this two-part analysis.⁵ This Part 2 describes a complimentary study of the quantities of radioactive materials in the head-end cells and of the reentrainment of this material by tornado-induced air flows.

The need for this study arises from the fact that there is radioactive material in the head-end cells, but no detailed analyses have been made of factors that could lead to the transport of this material into the atmosphere. The scope of this report includes identifying these factors, estimating ranges of their numerical values, and finally, estimating ranges of the quantities of radioactive materials that could be discharged from the head-end cells as a result of tornadoes defined in Part 1. The steps in this procedure are as follows:

1. Defining a mass-averaged reference fuel, including burnup and decay time, on the basis of documented information pertaining to fuels processed at NFS.
2. Obtaining gamma-ray dose-rate measurements in the head-end cells at known distances from surfaces on which radioactive materials are believed to be located (obtained by the staff of NFS).
3. Using the ORIGEN code to calculate the gamma-ray spectrum of the reference fuel at a series of decay times spanning the time at which the gamma-ray dose measurements were made.
4. Utilizing a gamma-ray shielding code, the SDC code in this case, to calculate dose conversion factors applicable to the gamma-ray spectrum obtained in step 3.
5. Using the measured dose rates and the dose-conversion factors to estimate the quantities of radioactive materials on head-end cell horizontal surfaces.
6. Estimating the particle size distribution of radioactive materials on head-end cell surfaces. The particulate matter of significance in this report was derived, primarily, from shearing irradiated light-water reactor (LWR) fuels which consist of UO₂. It is presumed to have the same size distribution ranges as obtained from analyses of sieve fractions from laboratory-scale shearing of single-irradiated LWR fuel rods.

7. Obtaining near-floor air speeds in head-end cells for each case in which discharge of radioactive materials cannot be ruled out. As described by Holloway and Andrae in Part 1,⁵ the calculations were performed by use of the SOLA-ICE code.
8. Combining near-floor wind speeds, particle-size distribution data, and terminal settling and threshold friction speeds to estimate the fractional (weight) reentrainment of UO₂ particles as a function of wind speed.
9. Combining information from steps 5 and 8 to calculate the quantity of radioactive material that becomes airborne per unit surface area.
10. Defining the shape of the air space within each head-end cell from which air will be discharged. From this and the volume of air discharged, as defined in Part 1, calculate the dimensions of the air space. In particular, determine whether the air space intersects the floor. If the air space does not intersect the floor, conclude that no radioactive material is discharged from the cell. If air space intersects the floor, calculate the extent of reentrainment. Assume that all radioactive material reentrained from this segment of the floor is contained in the air discharged from the cell.

One topic not analyzed in either part of this report concerns the structural integrity of process building walls and doors under tornado-induced loadings. The potential radiological consequences of a tornado are much greater if exterior walls and doors are destroyed than if they remain intact.

3. RADIOACTIVE MATERIALS IN NFS CELLS

The primary reason for analyzing the potential radiological impacts of a tornado strike at the Nuclear Fuel Services' (NFS) fuel reprocessing plant is the presence of considerable quantities of radioactive materials in the head-end cells [Process Mechanical Cell (PMC), General Purpose Cell (GPC), and Chemical Process Cell (CPC)].⁶ A quantitative estimate of the potential radiological impact requires an estimate of the quantity of radioactive material in each cell, particularly the PMC and the GPC, wherein the highest dose rates were measured. The CPC is of only minor importance in this analysis since most of the radioactivity in this cell is believed to be contained within various process vessels. In this section we describe the successive steps in making such estimates and the various assumptions at each step.

3.1 Elemental and Nuclide Composition

During the period April 22, 1966, to December 12, 1971, reprocessing of 28 batches of nuclear fuel was initiated at NFS. Only two types of fuel were represented in these 28 batches, namely LWR fuels and New Production Reactor (NPR) fuels from Hanford, Washington. A summary of the distribution of fuels processed at the NFS plant that will be significant in this report, from Table I-2-2 of ref. 7, the Safety Analysis Report of the NFS facility, is as follows:

| <u>Reactor type</u> | <u>No. of batches</u> | <u>Total weight (MTU)</u> | <u>Total burnup (MWd)</u> | <u>Average burnup (MWd/MTU)</u> |
|-------------------------------|-----------------------|---------------------------|---------------------------|---------------------------------|
| NPR | 11 | 379.4 | 774,481 | 2,041 |
| LWR | 16 | 245.1 | 2,848,674 | 11,623 |
| Indian Pt-1 (special case) | 1 | 16 (U + Th) | | |

Fuel from the NPR consisted of uranium in Zircaloy cladding; all of the LWR fuels, including the special ThO₂-UO₂ test fuel from the Indian Point-1 reactor, were in the form of metal oxide. From the above summary we calculate that the LWR oxide fuels (including the Indian Point-1 special material) constituted about 41 wt % of the fuel reprocessed at NFS and (excluding the ThO₂-UO₂ from Indian Point-1) in excess of 79% of the burnup.

In Sect. 4 we will be concerned with the reentrainment of radioactive particles as a result of abnormal flow of air near the floors of the GPC and PMC. Distribution of oxide particle sizes from the shearing of LWR fuels has been characterized, as will be discussed.⁸ In addition, data have been presented concerning the fraction of fuel that is dislodged from segments of cladding as a function of the lengths into which single fuel rods are sheared.⁸ No similar quantitative characterization of the sizes of particles from shearing NPR fuel has been performed. Finney,⁹ using unirradiated NPR fuels, and Dymmel,¹⁰ at the NFS plant, observed that the product from shearing this material, was in the form of chunks and that fine particles constituted only a small fraction of the total. From burnup data, a specified radiation dose rate would require about 4 times as much NPR fuel as power reactor fuel. Based particularly on this datum and the observations of Finney and Dymmel, we have made the apparently conservative assumption that all radiation in the PMC and GPC is derived from oxide fuel. The contribution of NPR to radiation dose rate is assumed to be within the large uncertainties inherent in this analysis.

On the basis of the above analysis, the sources of radioactivity in the head-end cells are assumed to be spent oxide fuel (excluding noble gases) and pieces of Zircaloy cladding. More specifically, the fuel-to-cladding ratio is assumed to be the same as that of the reference PWR

described by Croff et al.¹¹ It should be noted that no separation of uranium and/or plutonium from fission products occurred in the PMC or GPC, or in the dissolver of the CPC, during the operational life of the NFS plant. Thus, whether the fuel in the GPC was simply dislodged from pieces of cladding or was partly deposited as dissolver solution from the CPC, the nuclide and elemental composition will be essentially that of the irradiated fuel (excluding noble gases).

The reference fuel is assumed to have been UO₂, enriched to about 3.3 wt % in ²³⁵U, irradiated at an average power density of 30 MW/MTU to a burnup of 16,171 MWd/MTU. The burnup value is an average for lots 13, 15, 16, 17, 19, 20, 23, 24, 25, and 26 of Table I-2-2 of the Safety Analysis Report of NFS.⁷ The fuel is assumed to have been removed from reactors an average of 10 years prior to the radiation measurements made November 6, 1978. Of the fuels processed at NFS assumed not to contribute to the reference fuel, the Indian Point-1 material was the most unusual.

The significance of the uncertainty in the assumption of an average fuel age of 10 years at the time of dose-rate measurements was analyzed two ways. First, we compared data in Table I-2-2 of ref. 7 with similar data in US LWR Spent Fuel Inventory and Projection.¹² Such comparisons are possible only for the 4 reactors listed in Table 1. It should be noted that batches 4 and 5 of this table were used only to ensure cross identification, not to obtain an average age. From Table 1 the calculated mass-weighted average age of spent fuel in batches 13, 15, 16, 17, 19, 20, 24, and 26 in November 1978 was about 10 years and 4 months.

The second analysis of the effect of the uncertainty concerning average decay time was made by performing ORIGEN calculations¹¹ for decay times of 9, 10, and 11 years. Information pertinent to subsequent dose-rate calculations is summarized in Tables 2-4. An examination of numerical values or principal nuclide listings shows that "Total source strength" decreases only 5 to 6% per year and that there are only minor changes in the relative importance of various radioactive nuclides. Both analyses support the use of an average decay time of 10 years. Also, it is apparent that fission-product photons are by far the most important in dose-rate measurements and calculations.

3.2 Dose-Rate Calculations

Calculations of radiation dose rates to be expected from the reference fuel were performed with the Shield Design Code (SDC).¹³ Variables in these calculations are as follows: (1) the fuel γ -ray spectrum, defined by the mean energy (column 1) and source strength (column 8 and note c) information in Tables 2-4; (2) the distribution of radioactive materials on surfaces, assumed to be uniform; (3) the dose rate measured at any point in a head-end cell, assumed to be expressible in terms of a perpendicular distance (D_0) from dose-rate meter to the center of a disk source, of radius r_0 , the effective value of which is a function of the cell dimensions. Tables 5-7 summarize results of the

Table 1. Data on fuels reprocessed at NFS and dates of fuel discharge and initiation of reprocessing

| Lot No. | Reactor | Entries from NFS Table I-2-2 | | | | Entries from Y/OMI/SUB-77/42500 | | | | | | Time from discharge to 11/78 (years/months) | | |
|---------|----------------------|-------------------------------|-------------------|---------------|--------------------------|---------------------------------|------------------------------|-----------------------------|----------------------|---------------|--------------------|---|-------|------|
| | | Date of start of fuel reproc. | Fuel weight (MTU) | Total Pu (kg) | Average burnup (MWd/MTU) | Discharge date (month/year) | Assemblies discharged Number | Discharge burnup (MWd/MTHM) | ²³⁵ U (%) | Total Pu (kg) | Fissionable Pu (%) | | | |
| 19 | Big Rock Point (BWR) | 11/26/70 | 18.4 | 72.8 | 9,212 | 4/66 | 24 | 3.34 | 5,000 | 2.42 | 13 | 95.0 | 12/7 | |
| | | | | | | 9/66 | 36 | 5.00 | 7,000 | 2.31 | 22 | 95.3 | 12/2 | |
| | | | | | | 5/67 | 30 | 4.17 | 8,000 | 2.26 | 20 | 92.0 | 11/6 | |
| | | | | | | 2/68 | 39 | 5.39 | 12,310 | 2.04 | 30 | 90.0 | 10/9 | |
| 26 | | 11/30/71 | 9.8 | 27.9 | 13,567 | 6/68 | 48 | 6.64 | 11,870 | 2.06 | 37 | 83.4 | 10/5 | |
| | | | | | | | | | | | | | | |
| 5 | Dresden-1 (BWR) | 11/12/66 | 50.0 | 191.0 | 8,500 | 11/62 | 7 | 0.79 | 6,680 | 1.73 | 3 | 84.1 | 16/0 | |
| | | | | | | | 1 | 0.11 | 6,380 | 1.68 | 1 | 84.0 | | |
| | | | | | | | 182 | 20.30 | 6,480 | 0.68 | 76 | 82.0 | | |
| | | | | | | 4/64 | 5 | 0.56 | 6,000 | 1.70 | 2 | 85.0 | 14/7 | |
| | | | | | | | 3 | 0.33 | 10,270 | 1.54 | 1 | 82.0 | | |
| | | | | | | | 89 | 9.90 | 9,590 | 0.63 | 48 | 79.6 | | |
| | | | | | | | 97 | 10.78 | 10,320 | 0.62 | 55 | 78.7 | 13/8 | |
| | | | | | | | 1 | 0.11 | 14,630 | 1.32 | 1 | 79.0 | | |
| | | | | | | | 102 | 11.38 | 7,820 | 1.60 | 50 | 83.0 | | |
| | | | | | | | 487 | 54.26 | 8,120 | | 237 | | | |
| 15 | | 10/01/69 | 21.5 | 104.6 | 10,900 | 1/67 | 17 | 1.89 | 12,200 | 0.58 | 11 | 75.0 | 11/10 | |
| | | | | | | | 2 | 0.20 | 12,307 | 0.76 | 1 | 76.0 | | |
| | | | | | | | 4 | 0.37 | 8,590 | 1.40 | 2 | 79.0 | | |
| | | | | | | | 83 | 9.21 | 12,200 | 0.58 | 53 | 76.0 | | |
| | | | | | | 9/68 | 65 | 7.23 | 8,960 | 0.64 | 34 | 78.8 | 10/2 | |
| | | | | | | | 27 | 2.73 | 15,050 | 0.70 | 17 | 76.5 | | |
| | | | | | | | 4 | 0.37 | 11,820 | 1.23 | 2 | 76.0 | | |
| | | | | | | | 202 | 22.00 | 11,425 | | 120 | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| 16 | Indian Point-1 (PWR) | 11/23/69 | 15.6 | 107.6 | 15,794 | 9/67 | 40 | 7.95 | 12,670 | 1.51 | 50 | 82.8 | 11/2 | |
| | | | | | | | 270 | 40 | 7.90 | 19,040 | 1.50 | 63 | 81.6 | 8/9 |
| | | | | | | | | 80 | 15.85 | 15,845 | | 113 | | |
| 20 | | 01/11/71 | 7.6 | 68.1 | 23,445 | 12/70 | 40 | 7.64 | 23,460 | 1.82 | 66 | 80.5 | 7/11 | |
| | | | | | | | | | | | | | | |
| 5 | Yankee Rowe (PWR) | 06/07/67 | 49.8 | 185.1 | 11,200 | 5/62 | 74 | 20.59 | 8,470 | 2.70 | 85 | 88.2 | 16/6 | |
| | | | | | | | 7/63 | 40 | 11.13 | 10,150 | 2.60 | 66 | 86.4 | 15/4 |
| | | | | | | | 8/64 | 36 | 9.99 | 12,900 | 2.80 | 64 | 85.9 | 14/3 |
| | | | | | | | 8/65 | 38 | 10.22 | 16,500 | 2.50 | 72 | 84.7 | 13/3 |
| | | | | | | | | 188 | 51.93 | 11,265 | | 287 | | |
| 13 | | 05/14/69 | 19.6 | 176.0 | 20,500 | 10/66 | 36 | 9.68 | 17,270 | 2.40 | 73 | 84.9 | 12/1 | |
| | | | | | | | 3/68 | 36 | 9.62 | 22,520 | 2.10 | 71 | 84.5 | 10/8 |
| | | | | | | | | 72 | 19.30 | 19,885 | | 144 | | |
| 17 | | 06/02/70 | 9.3 | 95.6 | 24,381 | 8/69 | 36 | 9.61 | 24,450 | 2.00 | 89 | 84.3 | 9/3 | |
| | | | | | | | | | | | | | | |
| 24 | | 07/16/71 | 9.5 | 95.7 | 23,653 | 10/70 | 36 | 9.62 | 23,190 | 2.10 | 86 | 84.9 | 8/1 | |

Table 2. Energy-dependent γ -ray source strength data, from ORIGEN calculations, 9 years after fuel discharge^a

| Photon mean energy (MeV) | Heavy metals | | Cladding and hardware | | Fission products | | Total source strength ^{b,c} (phot $s^{-1}MTU^{-1}$) |
|-----------------------------------|---|----------------------------------|---|--------------------------|---|--|--|
| | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | |
| 0.015 | 1.055E13 | Am-241, Pu-238 Pu-240, Pu-241 | | | | | 1.055E13 |
| 0.025 | 5.990E11 | Am-241, Np-239 | | | | | 5.990E11 |
| 0.0375 | 6.101E10 | Am-241 | | | | | 6.101E10 |
| 0.0575 | 8.753E12 | Am-241 | | | | | 8.753E12 |
| 0.085 | 4.997E10 | Am-243, Np-239 | | | | | 4.997E10 |
| 0.125 | 3.989E10 | Np-239, U-237 | | | | | 3.989E10 |
| 0.150 | | | 1.349E12 | Sb-125, Co-60 Te-125m | 9.820E14 | Y-90, Sr-90, Cs-137 Eu-154, Ba-137m, Rh-106 Eu-155, Sb-125, Pr-144 | 9.833E14 |
| 0.225 | 2.573E10 | Np-239, U-237 | | | | | 2.573E10 |
| 0.375 | 4.580E09 | Np-239 | 1.196E12 | Sb-125 | 9.213E13 | Y-90, Sb-125, Rh-106 Pr-144 | 9.333E13 |
| 0.575 | 5.253E08 | | 1.533E12 | Sb-125 | 1.668E15 | Ba-137m, Cs-134, Y-90 Sb-125, Rh-106, Eu-154 | 1.670E15 |
| 0.850 | 2.819E08 | | 4.664E10 | Mn-54 | 9.957E13 | Cs-134, Eu-154, Y-90 Rh-106 | 9.962E13 |
| 1.25 | 1.299E08 | | 8.707E13 | Co-60 | 3.191E13 | Eu-154, Cs-134, Y-90 | 1.190E14 |
| 1.75 | 1.566E07 | | 3.366E07 | | 1.112E12 | | 1.112E12 |
| 2.25 | 1.076E06 | | 4.614E08 | | 1.104E11 | Pr-144 | 1.109E11 |
| 2.75 | 1.459E07 | | 1.428E06 | | 4.035E09 | | 4.051E09 |
| 3.50 | 5.565E05 | | 0 | | 5.176E08 | | 5.182E08 |
| Total | 2.009E13 | | 9.119E13 | | 2.875E15 | | 2.986E15 |
| MeV/sec | 6.964E11 | | 1.104E14 | | 1.268E15 | | 1.379E15 |

^aCalculations were made with the ORIGEN version described by Croff et al. (ref. 11). The reference fuel is analyzed as though it had been in a PWR with initial U-235 content of 3.2%, irradiated to a burnup of 16,171 MWd/MTU at a specific power of 30 MW/MTU, where MTU means metric tons of uranium charged to the reactor. Croff et al. use the terminology Metric Ton Initial Heavy Metal (MTIHM); in this case heavy metal and uranium are synonymous since no plutonium recycle or thorium utilization occurs.

^bPhot = photons.

^cTo compensate for the fact that the lowest energy accepted by SDC is 0.1 MeV, as well as to reduce the number of energy groups to 12 (the maximum accepted by SDC) or less, the first 5 groups were converted to an approximate equivalent of a 0.1-MeV group by multiplying each of the 5 source strengths by the square of the ratio (group energy/0.1). This was done at the suggestion of E. D. Arnold, one of the authors of the SDC code. The result is 3.213E12 photons $s^{-1}MTU^{-1}$ at 0.1 MeV.

Table 3. Energy-dependent γ -ray source strength data, from ORIGEN calculations, 10 years after fuel discharge^a

| Photon mean energy (MeV) | Heavy metals | | Cladding and hardware | | Fission products | | Total source strength ^{b,c} (phot $s^{-1}MTU^{-1}$) |
|-----------------------------------|---|----------------------------------|---|--------------------------|---|--|--|
| | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | |
| 0.015 | 1.091E13 | Am-241, Pu-238 Pu-240, Pu-241 | | | | | 1.091E13 |
| 0.025 | 6.474E11 | Am-241, Np-239 | | | | | 6.474E11 |
| 0.0375 | 6.490E10 | Am-241 | | | | | 6.490E10 |
| 0.0575 | 9.465E12 | Am-241 | | | | | 9.465E12 |
| 0.085 | 5.031E10 | Am-243, Np-239 | | | | | 5.031E10 |
| 0.125 | 4.013E10 | Np-239, U-237 | | | | | 4.013E10 |
| 0.150 | | | 1.099E12 | Sb-125, Co-60 Te-125m | 9.461E14 | Y-90, Sr-90, Cs-137 Ba-137m, Eu-154, Eu-155 Rh-106, Sb-125, Pr-144 | 9.472E14 |
| 0.225 | 2.554E10 | Np-239, U-237 | | | | | 2.554E10 |
| 0.375 | 4.607E09 | Np-239 | 9.317E13 | Sb-125 | 8.707E13 | Y-90, Sb-125, Rh-106 Pr-144 | 8.801E13 |
| 0.575 | 5.389E08 | | 1.194E12 | Sb-125 | 1.599E15 | Ba-137m, Cs-134, Y-90 Sb-125, Eu-154, Rh-106 | 1.600E15 |
| 0.850 | 2.854E08 | | 4.536E10 | Mn-54 | 7.868E13 | Cs-134, Eu-154, Y-90 Rh-106 | 7.873E13 |
| 1.25 | 1.296E08 | | 7.634E13 | Co-60 | 2.852E13 | Eu-154, Y-90, Cs-134 | 1.049E14 |
| 1.75 | 1.565E07 | | 3.049E07 | | 1.001E12 | | 1.001E12 |
| 2.25 | 1.049E06 | | 4.046E08 | | 4.783E10 | Pr-144 | 4.824E10 |
| 2.75 | 1.485E07 | | 1.252E06 | | 2.022E09 | | 2.038E09 |
| 3.50 | 5.421E05 | | 0 | | 2.602E08 | | 2.607E08 |
| Total | 2.120E13 | | 7.961E13 | | 2.740E15 | | 2.841E15 |
| MeV/sec | 7.440E11 | | 9.666E13 | | 1.198E15 | | 1.295E15 |

^aCalculations were made with the ORIGEN version described by Croff et al. (ref. 11). The reference fuel is analyzed as though it had been in a PWR with initial U-235 content of 3.2%, irradiated to a burnup of 16,171 MWd/MTU at a specific power of 30 MW/MTU, where MTU means metric tons of uranium charged to the reactor. Croff et al. use the terminology Metric Ton Initial Heavy Metal (MTIHM); in this case heavy metal and uranium are synonymous since no plutonium recycle or thorium utilization occurs.

^bPhot = photons.

^cTo compensate for the fact that the lowest energy accepted by SDC is 0.1 MeV, as well as to reduce the number of energy groups to 12 (the maximum accepted by SDC) or less, the first 5 groups were converted to an approximate equivalent of a 0.1-MeV group by multiplying each of the 5 source strengths by the square of the ratio (group energy/0.1). This was done at the suggestion of E. D. Arnold, one of the authors of the SDC code. The result is 3.461E12 photons $s^{-1}MTU^{-1}$ at 0.1 MeV.

Table 4. Energy-dependent γ -ray source strength data, from ORIGEN calculations, 11 years after fuel discharge^a

| Photon mean energy (MeV) | Heavy metals | | Cladding and hardware | | Fission products | | Total source strength ^{b,c} (phot $s^{-1}MTU^{-1}$) |
|-----------------------------------|---|----------------------------------|---|--------------------------|---|--|--|
| | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | Source strength ^b (phot $s^{-1}MTU^{-1}$) | Principal nuclides | |
| 0.015 | 1.124E13 | Am-241, Pu-238 Pu-240, Pu-241 | | | | | 1.124E13 |
| 0.025 | 6.933E11 | Am-241, Np-239 | | | | | 6.933E11 |
| 0.0375 | 6.860E10 | Am-241 | | | | | 6.860E10 |
| 0.0575 | 1.014E13 | Am-241 | | | | | 1.014E13 |
| 0.085 | 5.063E10 | Am-243, Np-239 | | | | | 5.063E10 |
| 0.125 | 4.035E10 | Np-239, U-237 | | | | | 4.035E10 |
| 0.150 | | | 8.983E11 | Sb-125, Co-60 Te-125m | 9.161E14 | Y-90, Sr-90, Cs-123 Ba-137m, Eu-154, Eu-155 Sb-125, Rh-106, Pm-147 | 9.170E14 |
| 0.225 | 2.535E10 | Np-239, U-237 | | | | | 2.535E10 |
| 0.375 | 4.632E09 | Np-239 | 7.258E11 | Sb-125 | 8.303E13 | Y-90, Sb-125, Rh-106 Pr-144 | 8.376E13 |
| 0.575 | 5.516E08 | | 9.296E11 | Sb-125 | 1.541E15 | Ba-137m, Cs-134, Y-90 Sb-125, Eu-154, Rh-106 | 1.542E15 |
| 0.850 | 2.887E08 | | 4.457E10 | Mn-54 | 6.340E13 | Cs-134, Eu-154, Y-90 Rh-106 | 6.344E13 |
| 1.25 | 1.293E08 | | 6.693E13 | Co-60 | 2.577E13 | Eu-154, Y-90, Cs-134 | 9.270E13 |
| 1.75 | 1.562E07 | | 2.792E07 | | 9.202E11 | | 9.202E11 |
| 2.25 | 1.023E06 | | 3.547E08 | | 2.091E10 | Pr-144 | 2.127E10 |
| 2.75 | 1.502E07 | | 1.098E06 | | 1.014E09 | | 1.030E09 |
| 3.50 | 5.283E05 | | 0 | | 1.308E08 | | 1.313E08 |
| Total | 2.227E13 | | 6.953E13 | | 2.630E15 | | 2.722E15 |
| MeV/sec | 7.892E11 | | 8.464E13 | | 1.142E15 | | 1.227E15 |

^aCalculations were made with the ORIGEN version described by Croff et al. (ref. 11). The reference fuel is analyzed as though it had been in a PWR with initial U-235 content of 3.2%, irradiated to a burnup of 16,171 MWd/MTU at a specific power of 30 MW/MTU, where MTU means metric tons of uranium charged to the reactor. Croff et al. use the terminology Metric Ton Initial Heavy Metal (MTIHM); in this case heavy metal and uranium are synonymous since no plutonium recycle or thorium utilization occurs.

^bphot = photons.

^cTo compensate for the fact that the lowest energy accepted by SDC is 0.1 MeV, as well as to reduce the number of energy groups to 12 (the maximum accepted by SDC) or less, the first 5 groups were converted to an approximate equivalent of a 0.1-MeV group by multiplying each of the 5 source strengths by the square of the ratio (group energy/0.1). This was done at the suggestion of E. D. Arnold, one of the authors of the SDC code. The result is 3.695E12 photons $s^{-1}MTU^{-1}$ at 0.1 MeV.

Table 5. Conversion factors for dose rate to surface contamination density for 9.0-year decayed reference fuel

| Perpendicular distance between disk source center and dose rate meter (m) (ft) | Ratio of disk-source radius to source distance | | | | | | | |
|---|--|--|--|--|--|--|--|--|
| | 2/3 | | 1 | | 4/3 | | 2 | |
| | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \cdot U}{m^2 \cdot R/hr}$) | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \cdot U}{m^2 \cdot R/hr}$) | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \cdot U}{m^2 \cdot R/hr}$) | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \cdot U}{m^2 \cdot R/hr}$) |
| 0.3 0.98 | 161,100 | 4.94 | 136,980 | 2.58 | 114,990 | 1.73 | 81,916 | 1.08 |
| 0.6 1.97 | 42,574 | 4.67 | 35,939 | 2.46 | 29,987 | 1.66 | 21,184 | 1.04 |
| 0.9 2.95 | 19,287 | 4.58 | 16,240 | 2.42 | 13,523 | 1.63 | 9,527 | 1.03 |
| 1.2 3.94 | 10,956 | 4.54 | 9,214 | 2.40 | 7,664 | 1.62 | 5,392 | 1.02 |
| 1.5 4.92 | 7,055 | 4.51 | 5,928 | 2.39 | 4,928 | 1.61 | 3,464 | 1.02 |
| 1.8 5.91 | 4,920 | 4.49 | 4,132 | 2.38 | 3,433 | 1.61 | 2,412 | 1.02 |
| 2.1 6.89 | 3,626 | 4.48 | 3,043 | 2.37 | 2,528 | 1.61 | 1,775 | 1.02 |
| 2.4 7.87 | 2,782 | 4.47 | 2,335 | 2.37 | 1,939 | 1.60 | 1,361 | 1.02 |
| 2.7 8.86 | 2,202 | 4.46 | 1,848 | 2.36 | 1,534 | 1.60 | 1,076 | 1.01 |
| 3.0 9.84 | 1,787 | 4.45 | 1,498 | 2.36 | 1,244 | 1.60 | 873 | 1.01 |

Table 6. Conversion factors for dose rate to surface contamination density for 10.0-year decayed reference fuel

| Perpendicular distance between disk source center and dose rate meter (m) (ft) | | Ratio of disk-source radius to source distance | | | | | | | |
|--|------|--|--|--|--|--|--|--|--|
| | | 2/3 | | 1 | | 4/3 | | 2 | |
| | | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \text{ U/m}^2}{R/hr}$) | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \text{ U/m}^2}{R/hr}$) | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \text{ U/m}^2}{R/hr}$) | Specific dose rate ($\frac{R}{hr \cdot MTU}$) | Conversion factor ($\frac{kg \text{ U/m}^2}{R/hr}$) |
| 0.3 | 0.98 | 151,470 | 5.25 | 128,790 | 2.75 | 108,110 | 1.84 | 77,015 | 1.15 |
| 0.6 | 1.97 | 40,026 | 4.97 | 33,788 | 2.62 | 28,192 | 1.76 | 19,917 | 1.11 |
| 0.9 | 2.95 | 18,133 | 4.88 | 15,269 | 2.57 | 12,713 | 1.74 | 8,957 | 1.10 |
| 1.2 | 3.94 | 10,301 | 4.83 | 8,662 | 2.55 | 7,205 | 1.73 | 5,069 | 1.09 |
| 1.5 | 4.92 | 6,633 | 4.80 | 5,573 | 2.54 | 4,633 | 1.72 | 3,257 | 1.09 |
| 1.8 | 5.91 | 4,625 | 4.78 | 3,884 | 2.53 | 3,227 | 1.71 | 2,267 | 1.08 |
| 2.1 | 6.89 | 3,409 | 4.76 | 2,861 | 2.52 | 2,377 | 1.71 | 1,669 | 1.08 |
| 2.4 | 7.87 | 2,616 | 4.75 | 2,195 | 2.52 | 1,823 | 1.71 | 1,280 | 1.08 |
| 2.7 | 8.86 | 2,071 | 4.74 | 1,737 | 2.51 | 1,442 | 1.70 | 1,012 | 1.08 |
| 3.0 | 9.84 | 1,680 | 4.74 | 1,409 | 2.51 | 1,169 | 1.70 | 820 | 1.08 |

Table 7. Conversion factors for dose rate to surface contamination density for 11.0-year decayed reference fuel

| Perpendicular distance between disk source center and dose rate meter (m) (ft) | Ratio of disk-source radius to source distance | | | | | | | |
|--|---|---|---|---|---|---|---|---|
| | 2/3 | | 1 | | 4/3 | | 2 | |
| | Specific dose rate $\left(\frac{R}{hr \cdot MTU} \right)$ | Conversion factor $\left(\frac{kg \cdot U}{R \cdot hr} \right) \times 100$ | Specific dose rate $\left(\frac{R}{hr \cdot MTU} \right)$ | Conversion factor $\left(\frac{kg \cdot U}{R \cdot hr} \right) \times 100$ | Specific dose rate $\left(\frac{R}{hr \cdot MTU} \right)$ | Conversion factor $\left(\frac{kg \cdot U}{R \cdot hr} \right) \times 100$ | Specific dose rate $\left(\frac{R}{hr \cdot MTU} \right)$ | Conversion factor $\left(\frac{kg \cdot U}{R \cdot hr} \right) \times 100$ |
| 0.3 0.98 | 143,620 | 5.54 | 122,110 | 2.90 | 102,510 | 1.94 | 73,024 | 1.21 |
| 0.6 1.97 | 37,952 | 5.24 | 32,038 | 2.76 | 26,731 | 1.86 | 18,885 | 1.17 |
| 0.9 2.95 | 17,193 | 5.14 | 14,477 | 2.71 | 12,055 | 1.83 | 8,493 | 1.16 |
| 1.2 3.94 | 9,767 | 5.09 | 8,214 | 2.69 | 6,832 | 1.82 | 4,806 | 1.15 |
| 1.5 4.92 | 6,287 | 5.06 | 5,284 | 2.68 | 4,393 | 1.81 | 3,088 | 1.15 |
| 1.8 5.91 | 4,386 | 5.04 | 3,683 | 2.67 | 3,060 | 1.81 | 2,150 | 1.14 |
| 2.1 6.89 | 3,232 | 5.02 | 2,713 | 2.66 | 2,253 | 1.80 | 1,582 | 1.14 |
| 2.4 7.87 | 2,480 | 5.01 | 2,081 | 2.66 | 1,728 | 1.80 | 1,213 | 1.14 |
| 2.7 8.86 | 1,963 | 5.00 | 1,647 | 2.65 | 1,367 | 1.80 | 960 | 1.14 |
| 3.0 9.84 | 1,593 | 5.00 | 1,336 | 2.65 | 1,109 | 1.79 | 778 | 1.14 |

parametric calculations for decay times of 9, 10, and 11 years for air-filled spaces. In each table the parameters are (1) the perpendicular distance (D_o) between disk-source center and dose-rate meter (0.3 to 3.0 m), and (2) the ratio of disk-source radius to source distance ($r_o/D_o = 2/3, 1, 4/3, \text{ or } 2$). Specific dose rates are expressed in $R/(\text{hr MTU})$. In each table and at each value of D_o and r_o/D_o a conversion factor, in units $(\text{kg U/m}^2)/(\text{R/hr})$, is listed. When any measured dose rate (R/hr) is multiplied by the appropriate conversion factor, an estimate is obtained of surface concentration of radioactive material in units of (kg U/m^2) . By comparing corresponding factors in Tables 5-7, it is again apparent that calculated doses are relatively insensitive to the average decay age in the time frame 9 to 11 years. It is also apparent that the factors decrease only slightly with increasing distance, D_o , between dose-rate meter and source, an expected conclusion since air is the only material between source and meter. The most significant changes in Tables 5-7 are due to changes in r_o/D_o .

3.3 Surface Concentrations of Reference Fuel in Head-End Cells

As mentioned in Sect. 3.2, the ORIGEN and SDC calculations are summarized in terms of conversion factors, which, when multiplied by a measured dose rate, yield values of surface contamination in terms of kilograms of reference fuel per square meter of area. Dose rates, measured by staff of NFS, at various locations in PMC and GPC are presented in Tables 8 and 9; locations of measurements are further defined in Figs. 1 and 2. Surfaces to which contamination values apply are floors in many cases; in the PMC, other surfaces are the shear, the DIPO Table, and Saw Table (Fig. 1).

3.3.1 Concerning dose-rate measurements in the PMC (Table 8)

Measurements 1 and 2 (70 and 320 R/hr). These values might both be due to radioactive materials on the shear, which is about 4.3 by 2.5 ft^2 . The radius of a circle of this same area ($\sim 10.75 \text{ ft}^2$) is 1.85 ft. Measurement 1 was taken 8 ft above the shear, in which case $r_o/D_o = 1.85/8 = 0.23$, and the dose-rate conversion factor, from Fig. 3, is in the order of 0.1 $[(\text{kg U/m}^2)/(\text{R/hr})]$. Thus, measurement 1 is equivalent to $\sim 7 \text{ kg U/m}^2$ (on the shear table), and to 7 kg U on the whole table, whose area is $\sim 1 \text{ m}^2$. On this same basis, measurement 2 corresponds to $r_o/D_o = 1.85/1.5 = 1.2$, and the dose rate conversion factor is ~ 0.02 $[(\text{kg U/m}^2)/(\text{R/hr})]$. Measurement 2 thus is equivalent to $\sim 6.8 \text{ kg U/m}^2$, essentially the same as measurement 1. However, instead of being due only to 7 kg U on the shear table, measurements 1 and 2 could be due to a still larger quantity of fuel on the table and floor under and around the shear.

Table 8. Radiation dose rates measured in the PMC
of the NFS Plant on November 6, 1978^a


| No. | Measurement location Detailed description | Measured dose rate (R/hr) |
|-----|---|------------------------------|
| 1 | 6 ft from north end, 5 ft from east wall, 8 ft above shear | 70 |
| 2 | 18 in. directly above shear | 320 |
| 3 | 18 in. south of shear at magazine opening level 5 ft above floor | 370 |
| 4 | 8 ft south of shear, 5 ft above floor, 4 ft from east wall | 145 |
| 5 | 5 ft from C window, directly in front, 16 in. from DIPO table | 80 |
| 6 | 5 ft from west wall, even with saw blade 18 in. from table | 185 |
| 7 | Directly in front of B window, 2 ft above table, 1 ft above saw rail, 5 ft from window | 240 |
| 8 | Directly in front of PMC transfer port, center of cell, 4 ft above rail | 335 |
| 9 | Same as (8) but 1 ft above rail | 450 |
| 10 | 3 ft from PMC port, 2.5 ft above rail level In front of B window. | 600 |

^aThe radiation survey was made by staff of the Nuclear Fuel Services Company and reported to the U.S. Nuclear Regulatory Commission. Measurement numbers and locations are shown in Fig. 1.


Table 9. Radiation dose rates measured in the GPC
of the NFS Plant on November 6, 1978^a

| No. | Measurement location Detailed description | Measured dose rate (R/hr) |
|-----|--|------------------------------|
| 1 | Southwest corner, 18 in. from south wall, 3 ft from door at crane room floor level ~12 ft above floor | 65 |
| 2 | 2 ft from south wall, 3 ft from west wall, 5 ft above floor, 18 in. from basket | 115 |
| 3 | 18 in. from hull hopper, middle of cell (N-S), 4 ft from floor | 230 |
| 4 | Same as (3), only 1 ft from floor (hulls on floor) | 480 |
| 5 | Middle of cell, 7 ft from floor, in front of cell cooler | 175 |
| 6 | Middle of cell, front of cell cooler, 2.5 from floor, 10 in. from top of scrap drum with empty lids, miscellaneous | 435 |
| 7 | Middle of cell, 11 ft above floor, in front of cell cooler | 105 |
| 8 | 2 ft over No. 2 basket, 3 ft from south wall, ~10 ft above floor | 140 |
| 9 | 1 ft in front of No. 2 basket, 2.5 ft from floor, ~7 ft from fuel chute | 350 |
| 10 | 2.5 ft in front of No. 2 window, 2 ft from floor, just east of hull dumper | 650 |
| 11 | In front of No. 3 (west) window (2 ft from window), 18 in. from floor, 1 ft west of dumping station | 500 |

^aThe radiation survey was made by the staff of the Nuclear Fuel Services Company and reported to the U.S. Nuclear Regulatory Commission. Measurement numbers and locations are shown in Fig. 2.




ORNL DWG 79-10



A - GPC HATCH

B - FRS HATCH

Fig. 1. Plan and dose-rate measurement locations: Process Mechanical Cell.



ORNL DWG 79-9




Fig. 2. Plan and dose-rate measurement locations: General Purpose Cell.




Fig. 3. Variation of dose-rate conversion factor with source-to-meter distance and with r_o/D_o .

Measurement 3 (370 R/hr). This measurement was taken at about the same height above the shear table as measurement 2, but offset 1.5 ft. While material on or under the shear table contributed to the 370 R/hr of measurement 3, other material, presumably on the floor or at the NE corner of the Saw Table must also have contributed. Using a source-to-meter distance of 2 to 5 ft, the dose-rate conversion factor from Fig. 3 changes from about 0.011 to 0.025-0.03 as r_o/D_o decreases from 2 to 1. Thus, the dose rate corresponds to 4 to 11 kg U/m².

Measurements 4 and 10 (145 and 600 R/hr). Between the Saw Table and the east wall of PMC is an area not normally visible through any viewing window. It is likely that fuel hardware fell from the Saw Table into this area and was not removed during normal cleaning operations employed to remove visible quantities of fuel and hardware. At a height of 5 ft above the floor for measurement 4 and an r_o/D_o of 1, the dose-rate conversion factor of 0.027 suggests ~4 kg U/m²; by contrast, the 145 R/hr reading might be due to hardware and cladding from about 13 times that much fuel (the total source strength divided by hardware and cladding source strength, Table 3). Measurement 10 corresponds to 6 to 16 kg U/m² or to a correspondingly larger quantity of hardware and cladding.

Measurements 5 through 9 (80 to 450 R/hr). On the bases of $1 \leq r_o/D_o \leq 2$, all of these measurements (except 5) correspond to 2 to 10 kg U/m² or to appropriately larger quantities of hardware and cladding. Measurement 5 corresponds to 1 to 2 kg U/m².

3.3.2 Concerning dose-rate measurements in the GPC (Table 9)

Dose-rate measurements in the GPC are in the same range as in the PMC. Based on $1 \leq r_o/D_o \leq 2$, these readings correspond to a little less than 1 kg U/m² (measurement 1 with $r_o/D_o = 2$) to 18 kg U/m² (measurement 10 with $r_o/D_o = 1$). As discussed above, instead of being due primarily to fission products from these quantities of uranium, the measured dose rates in some cases may be due to the presence of correspondingly larger amounts of hardware and cladding.

In both PMC and GPC, contamination values range from 1 to >10 kg U/m²; in Sects. 4.2 and 4.3, we used the range 5 to 15 kg U/m² for the purpose of calculating the source term for radioactive airborne releases from the PMC. It is apparent from the dose-rate measurements that surface concentrations of reference fuel in PMC and GPC are very nearly equal. Using floor surface dimensions of 12 by 52 ft² for the PMC and 11 by 46 ft² for the GPC, the total quantities of fuel on surfaces in these cells are calculated to be in the range of 60 to 600 kg in the PMC and 50 to 500 kg in the GPC; probable values are in the order of 200 kg in each cell. In both cells hardware and cladding, relatively free of fuel, may be making more of a contribution to estimated quantities of fuel than expected as a result of accumulation in unviewable areas.

The primary uncertainty in calculated values of surface contamination is due to uncertainty in the effective value of r_0/D_0 . From cell dimensions and dose-rate meter locations, it is probable that the effective value of r_0/D_0 is < 2 in many cases, particularly at the greater distances between meter and surfaces.

4. RESUSPENSION OR REENTRAINMENT

Resuspension or reentrainment is of primary concern in any analysis of the potential radiological consequences of a tornado grounding at a fuel reprocessing plant such as the NFS plant at West Valley, N.Y. Many authors, as summarized in refs. 14 and 15, have presented resuspension data* with values in the range 10^{-3} to 10^{-10} m^{-1} . These data would appear to be of uncertain utility in evaluating reentrainment of particles of irradiated nuclear fuel from the floors (and other surfaces) of head-end cells at the NFS plant, as noted by Andrae et al.³ and by Healy.¹⁶ There are varied reasons for this conclusion including dissimilarity between the material being resuspended (sand, ZnS, limestone, etc.) and UO_2 , the absence of information on particle size distribution of material from which resuspension occurred and on resuspended matter, wind speeds, humidity, etc.

4.1 A Model of Reentrainment

The model of resuspension presented in this report is based on the concept that air, flowing close to the floor and other surfaces where irradiated UO_2 /fission product particulate matter is located, will reentrain some of this matter. There are many variables that will influence the amount of particulate matter that is reentrained including: air speed; particle size distribution when shearing of fuel was performed; degree of agglomeration during the decade since shearing was performed (Appendix A); particle shape; the magnitude of eddy velocities. In the simplified approach used in this report, we assume that the eddy currents will be of sufficient magnitude to cause entrainment of any particle whose terminal settling speed is less than the local average air speed. Most of the concepts of such an approach to resuspension have been presented by Corn¹⁷ and by Davies.¹⁸⁻²⁰ Table 10 and Fig. 4 show the variation of settling speeds in air of spherical particles of density 10 g/cm^3 , namely the density of UO_2 . These values are based on the following two equations presented by Davies:²⁰

*A common representation is in terms of a resuspension factor K defined as [air concentration ($\mu\text{Ci}/\text{m}^3$)]/[surface deposit concentration ($\mu\text{Ci}/\text{m}^2$)].

Table 10. Relaxation times and terminal and threshold friction speeds of spheres of density 10.0 g/cm³ in air at one atmosphere pressure and 20°C

| Particle diameter (μm) | Relaxation time (τ) ^a (s) | Terminal speed of fall (V _s) (cm/s) | Friction speed at threshold (cm/s) ^b | | | | Weight in sizes less than the indicated value (%) ^c | |
|------------------------|--------------------------------------|---|---|-----------------------|-----------------------------|-----------------------|--|----------|
| | | | without interparticle cohesion | | with interparticle cohesion | | | |
| | | | B≤0.22 [Eq. (4-5)] | 0.22≤B≤10 [Eq. (4-6)] | B≤0.22 [Eq. (4-3)] | 0.22≤B≤10 [Eq. (4-4)] | Minimum | Maximum |
| 0.01 | 3.09 E-9 | 3.03 E-6 | 7.74 E-1 | NA | 1.81 E+3 | NA | NS | 0.000027 |
| 0.02 | 1.23 E-8 | 1.21 E-5 | 1.09 E+0 | NA | 1.27 E+3 | NA | NS | 0.00010 |
| 0.03 | 2.77 E-8 | 2.72 E-5 | 1.34 E+0 | NA | 1.04 E+3 | NA | NS | 0.00021 |
| 0.05 | 7.72 E-8 | 7.57 E-5 | 1.73 E+0 | NA | 7.98 E+2 | NA | NS | 0.00052 |
| 0.1 | 3.09 E-7 | 3.03 E-4 | 2.45 E+0 | NA | 5.58 E+2 | NA | NS | 0.0017 |
| 0.2 | 1.23 E-6 | 1.21 E-3 | 3.46 E+0 | NA | 3.89 E+2 | NA | NS | 0.0051 |
| 0.3 | 2.77 E-6 | 2.72 E-3 | 4.23 E+0 | NA | 3.15 E+2 | NA | NS | 0.011 |
| 0.5 | 7.72 E-6 | 7.57 E-3 | 5.46 E+0 | NA | 2.40 E+2 | NA | 0.0000024 | 0.031 |
| 1 | 3.09 E-5 | 3.03 E-2 | 7.70 E+0 | NA | 1.66 E+2 | NA | 0.000038 | 0.12 |
| 2 | 1.23 E-4 | 1.21 E-1 | 1.08 E+1 | NA | 1.14 E+2 | NA | 0.00045 | 0.39 |
| 5 | 7.72 E-4 | 7.57 E-1 | 1.64 E+1 | NA | 6.90 E+1 | 6.88 E+1 | 0.0091 | 1.54 |
| 10 | 3.08 E-3 | 3.02 E+0 | 2.15 E+1 | NA | NA | 4.65 E+1 | 0.056 | 3.71 |
| 15 | 6.88 E-3 | 6.75 E+0 | 2.45 E+1 | 2.42 E+1 | NA | 3.84 E+1 | 0.15 | 5.88 |
| 20 | 1.21 E-2 | 1.19 E+1 | NA | 2.49 E+1 | NA | 3.46 E+1 | 0.30 | 7.95 |
| 25 | 1.36 E-2 | 1.82 E+1 | NA | 2.56 E+1 | NA | 3.27 E+1 | 0.49 | 9.90 |
| 30 | 2.60 E-2 | 2.55 E+1 | NA | 2.63 E+1 | NA | 3.17 E+1 | 0.71 | 11.7 |
| 50 | 6.21 E-2 | 6.09 E+1 | NA | 2.89 E+1 | NA | 3.14 E+1 | 1.90 | 18.1 |
| 100 | 1.68 E-1 | 1.65 E+2 | NA | 3.54 E+1 | NA | 3.63 E+1 | 5.87 | 29.6 |
| 150 | 2.76 E-1 | 2.71 E+2 | NA | 4.13 E+1 | NA | 4.18 E+1 | 7.93 | 37.6 |
| 200 | 3.81 E-1 | 3.74 E+2 | NA | 4.66 E+1 | NA | 4.69 E+1 | 9.65 | 44.7 |
| 250 | 4.83 E-1 | 4.74 E+2 | NA | 5.14 E+1 | NA | 5.17 E+1 | 11.2 | 50.2 |
| 300 | 5.80 E-1 | 5.69 E+2 | NA | NA | NA | NA | 12.5 | 54.7 |
| 400 | 7.61 E-1 | 7.46 E+2 | NA | NA | NA | NA | 14.9 | 61.7 |
| 500 | 9.26 E-1 | 9.08 E+2 | NA | NA | NA | NA | 16.9 | 66.9 |
| 1000 | 1.58 E+0 | 1.55 E+3 | NA | NA | NA | NA | 24.2 | 80.7 |

^aCalculated at $\tau = V_s/g$, where g = acceleration of gravity (980.7 cm/s²).

^bNA means "not applicable."

^cNS means "not significant."

ORNL DWG 78-5212 R




Fig. 4. Terminal settling and threshold friction speeds of spherical particles of density = 10 g/cm^3 in air at 20°C and 1 atm pressure.

For $N_{Re} < 4$,

$$N_{Re} = \Omega/24 - 2.3363 \times 10^{-4} \Omega^2 + 2.0154 \times 10^{-6} \Omega^3 - 6.9105 \times 10^{-9} \Omega^4; \quad (1)$$

For $3 \leq N_{Re} \leq 10^4$,

$$\begin{aligned} \log N_{Re} = & -1.29536 + 0.986 \log \Omega - 4.6677 \times 10^{-2} \log \Omega^2 \\ & + 1.1235 \times 10^{-3} \log \Omega^3. \end{aligned} \quad (2)$$

In these equations,

N_{Re} = Reynolds number,

$$\Omega = C_D N_{Re}^2,$$

and

C_D = drag coefficient.

Very small particles (smaller than $\sim 30 \mu\text{m}$ for spheres of density 10 g/cm^3), however, do not become reentrained at air speeds as small as their settling speeds. Instead, there is for any particular size a threshold friction speed below which a particle will not move on the surface and will not become entrained; in turn, this speed depends on whether there is or is not any interparticulate cohesion. Iversen et al.²¹ performed dust-resuspension experiments in wind tunnels and analyzed these and other data in terms of the threshold friction speed. Iversen et al.²² used the resulting equations, given below, to estimate quantities of dust resuspended on Venus, Earth, and Mars.

With interparticulate cohesion:

(a) $B \leq 0.22$,

$$A = 0.266 \left(\frac{1 + 0.055/\rho_p g D_p^2}{1 + 2.123B} \right)^{1/2} \quad (3)$$

(b) $0.22 \leq B \leq 10$,

$$A = (0.108 + 0.0323/B - 0.00173/B^2)(1 + 0.055/\rho_p g D_p^2)^{1/2} \quad (4)$$

Without interparticulate cohesion:

(a) $B \leq 0.22$,

$$A = 0.266/(1 + 2.123B)^{1/2}. \quad (5)$$

(b) $0.22 \leq B \leq 10$,

$$A = 0.108 + 0.0323/B - 0.00173/B^2. \quad (6)$$

In Eqs. (3)-(6) the following definitions apply:

$$A = U_{xt}/[(\rho_p - \rho)gD_p/\rho]^{1/2} \text{ (threshold coefficient)} \quad (7)$$

$$B = U_{xt} D_p/\nu \text{ (particle friction Reynolds number)} \quad (8)$$

D_p = particle diameter

g = gravitational acceleration

U^* = friction speed $(\tau/\rho)^{1/2}$

U_{xt} = friction speed at threshold

ρ = fluid (air) density

ρ_p = particle (UO_2) density

μ = viscosity


ν = kinematic viscosity

τ = shear stress

Friction threshold speeds are plotted in Fig. 4 and listed in Table 10, in both cases for the applicable range of values of B and for the presence or absence of interparticulate cohesion. It is apparent that essentially no resuspension of particles $> 1 \mu m$ will occur until the air speed attains a value in the order of 10 to 100 cm/s, depending on the strength of interparticulate cohesion.

The above calculations are based on the assumption that particles of UO_2 /fission products are spherical. In fact, all photographs and photo-micrographs of products obtained from shearing single rods from the H. B. Robinson-2 reactor and from the Peach Bottom-2 reactor show that the particles are not spherical; instead, they are elongated, as shown in Figs. 5 and 6 for H. B. Robinson fuel. (Burnup of fuel from the H. B. Robinson-2 reactor was in the range 11,000 to 28,000 MWd/Mg U and 9,000 to 11,000 MWd/Mg U from the Peach Bottom-2 reactor.⁸) However, ratios of maximum to minimum linear dimension rarely exceeded 3. Thus,

ORNL DWG 78-17587



GRID=1mm x 1mm

Fig. 5. Photomicrographs of sieve fractions from shearing one rod of irradiated fuel from the H. B. Robinson reactor.




Fig. 6. Photomicrographs of fine particles from shearing H. B. Robinson fuel rods.

on the basis of Davies' sedimentation study,²⁰ fuel particles assumed to be representative of material that is on the floors (and other surfaces) of cells at NFS, are "spherical" within the accuracy of the model.

As noted previously, there is a considerable range in the parameters that define a lognormal distribution of particles produced by shearing unirradiated bundles or single irradiated rods of LWR fuels. The last two columns of Table 10 contain estimates of the minimum and maximum percentages of mass that will be of size less than values listed in column 1. In the present model we consider, for example, that a minimum of 0.30% and a maximum of 7.95% of the weight of dislodged fuel from the shearing of irradiated fuel will be in particle sizes of 20 μm or less.

As will be discussed in Sect. 4.2, the highest velocities of air near the floor in either the GPC or PMC under the worst tornado conditions considered in this report will be 450 cm/s (\sim 15 fps). Thus, we will be concerned (Table 10) with the movement of particles up to 250 μm in size wherever these large velocities occur. As the air velocities decrease to about 30 cm/s (1 fps), particle movement becomes influenced by friction, in the presence or absence of interparticulate cohesion (Fig. 4); at still lower velocities, particles are nearly immobilized.

There is a question of response time that must be asked in analyzing the effects of a tornado strike, namely: "Will particles on the floor be exposed to higher-than-normal air velocities for a time long enough to become airborne?" Davies has presented values,¹⁸ and a method for calculation of values, of a kind of relaxation time, τ , which is the time an isolated particle needs to adapt itself, or relax, to an applied force. For example, a spherical particle at rest and having a density of 10.0 g/cm³ would acquire 1/e (\sim 0.368) of the velocity of a suddenly applied air stream in the times listed in Table 10. For a 100- μm particle, this time is 0.17 s. Thus particles whose terminal settling or threshold friction speeds, Fig. 4, are exceeded will move, and are assumed to become airborne in the time frame of tornado effects, which are in the range of 0 to 20 or 30 s.

4.2 Reentrainment in the Head-End Cells

Four steps already taken in our evaluation of reentrainment of radioactive materials in head-end cells at NFS are as follows:

1. determining the distribution of particle sizes from shearing LWR oxide fuels;⁸
2. relating particle size with air velocity required to move and retrain the particle (Sect. 4.1);
3. specifying the magnitude of the tornado, evaluating air flows at the boundaries when building walls remain intact and when they are destroyed, and identifying cases to be analyzed in more detail;⁵

4. obtaining air velocity data pertaining to near-floor locations by use of the SOLA-ICE code.^{5,23}

As discussed by Holloway and Andrae,⁵ air flows in head-end cells and tornado conditions requiring more detailed analysis involve discharge of air through manipulator ports into the PMC and GPC operating aisles, discharge of GPC ventilation air into the atmosphere via the adjoining Master Slave Manipulator building, with and without building walls remaining intact, and discharge of air from the CPC. Air flows and air paths are summarized in Table 11 and Fig. 7, as discussed in ref. 5.

Several aspects of the numbers in Table 11 need to be noted. First, when the building walls and doors remain intact, nearly as much air flows from the GPC to the PMC (Branch 4) as is discharged from the PMC to the operating aisles (Branch 3). Air flowing from the GPC to the PMC passes through a 4 by 3 ft² hatch that is located very close to the floor area directly below the lightly covered manipulator ports in the northwest corner of the PMC. For this reason, much of the air leaving the PMC (e.g., 1273 ft³ in Case 1B1, Table 11) will have originated in the GPC. This does not mean, however, that 1142 ft³ of the 1273 ft³ discharged from the PMC in this case originated in the GPC. However, air flowing from the GPC to the PMC will largely originate from the upper volumes of the GPC, which is 19.5 ft high, where the only contaminant at the time of the tornado strike is radon. The point of these comments is that a significant, but unquantified, factor of conservatism will be introduced when it is assumed that all air discharged from the PMC actually was derived from air originally in the PMC; this assumption neglects dilution by air, initially containing no particulate matter, from the GPC.

Another aspect of the numbers in Table 11 that will be considered below is specification of the lightly covered ports in the PMC through which air will be discharged. When air discharged from the PMC is assumed to have been derived from a particular geometric shape, such as quarter sphere or truncated half cone, the parameters of that geometry will be a function of the volume. Thus, another factor that introduces an over estimation of the quantity of particulate matter discharged from the PMC is the assumption that all air is discharged through the three lightly covered ports in the northwest corner instead of equally through all seven lightly covered ports in this cell. This factor will be addressed below.

Finally, we note that numbers in the last column of Table 11 are the sums of discharges of contaminated and uncontaminated air.

The final step of the analysis involves combining the particle-size distribution data,⁸ terminal settling and threshold friction speeds (Sect. 4.1), and the air-volumetric discharge and near-floor and spatial air-speed calculations presented by Holloway and Andrae.⁵ The detail with which this combining can be performed is somewhat limited because of the complexity of the task and because the SOLA-ICE code is two-dimensional, not three-dimensional. For these reasons two simplified approaches have

Table 11. Air volumes discharged from cells during postulated tornado strike
(from TVENT calculations)^a

| Case | Maximum tornado wind speed (mph) | Volume ^b released from PMC (ft ³) | Volume ^b released from GPC (ft ³) | Volume ^b released from CPC (ft ³) | Total discharge ^c to ambient from pathway (ft ³) |
|-------------|---|---|---|---|--|
| 1A1 Outer | 100 | 362 | 275 | 0 | Branch (1) 570 |
| 1B1 Walls | 200 | 1273 | 1142 | 0 | 2300 |
| 1C1 Intact | 300 | 1983 | 1922 | 0 | 3953 |
| 1A2 Outer | 100 | 484 | 439 | 0 | Branches (2) and (3) 568 |
| 1B2 Walls | 200 | 1947 | 2222 | 0 | 2792 |
| 1C2 Removed | 300 | 3057 | 3913 | 0 | 5098 |
| 2A | 100 | 0 | 0 | Branch (29) 896 | Branch (28) 919 |
| 2B | 200 | 0 | 0 | 2552 | 2584 |
| 2C | 300 | 0 | 45 | 3934 | 3976 |
| 3A1 Outer | 100 | 0 | 0.4 | 0 | Branch (10) and (12) 149 |
| 3B1 Walls | 200 | 0 | 11.6 | 0 | 570 |
| 3C1 Intact | 300 | 0 | 4.0 | 0 | 1001 |
| 3A2 Outer | 100 | 0 | 289 | 0 | Branches (10) and (11) 300 |
| 3B2 Walls | 200 | 0 | 928 | 0 | 970 |
| 3C2 Removed | 300 | 0 | 1428 | 0 | 1515 |
| 4A | 100 | 0 | 0 | 0 | Branch (13) Branch (27) 0 |
| 4B | 200 | 0 | 2344 | 0 | 57 |
| 4C | 300 | 0 | 4004 | 0 | 810 |
| 5A | 100 | 0 | 1281 | 0 | 1026 |
| 5B | 200 | 0 | 2515 | 0 | 1843 |
| 5C | 300 | 0 | 3657 | 0 | 2544 |

^aSee Fig. 4 for branch specifications and ref. 5 for detailed analyses.

^bAir potentially contaminated with radioactive materials.

^cCombined potentially contaminated air and uncontaminated air.




Fig. 7. Block diagram of NFS head-end cells, including air-flow branches of potential significance in releases of radioactive materials.

been used: (1) a method based on defining a spatial shape from which air within a cell is derived combined with the use of the maximum near-floor wind speeds calculated from the TVENT/SOLA-ICE combination; (2) a method based on evaluating fractional reentrainment within differential surface areas using the varying near-floor wind speeds calculated from the TVENT/SOLA-ICE combination. In either case, the degree to which reentrained particulate matter is discharged from a cell depends on the length of the path from the surface (floor or table) on which it is contained to a port that opens onto an operating aisle.

All cases in Table 11, except Cases 1A1 - 1C1 and 1A2 - 1C2, will be shown by simple arguments in Sect. 4.2.1 to involve no calculable discharge of radioactive particulate materials. Cases 2A - 2C involve discharge of air from the CPC. This is a large cell with a volume⁷ of 88,000 ft³; actual discharge of air would occur from an elevated port at the south end of the cell. Only in Case 2C does any air flow from the GPC to the CPC (Table 11) through the hatch at the north end of the CPC. In addition to there being significantly lower radiation readings in the CPC than in the GPC or PMC,² nearly all radioactive materials in the CPC are believed to be contained within process equipment. Thus, there are several factors that imply there will be no calculable quantities of particulate matter in air discharged from the CPC.

4.2.1 Assumed air-space shape

TVENT calculations yield values of air volumes discharged from cells during a strike by a tornado of specified maximum wind speed.⁵ This air will always contain small quantities of radon from the decay chains of uranium and plutonium isotopes in fuel still in the head-end cells. However, the discharged air may not contain any particulate matter. In the absence of a three-dimensional model of air flow into and out of the PMC and GPC, cases requiring further analysis were identified on the basis of assuming a shape for the air space prior to its discharge through manipulator ports. A volumetric shape is used to determine whether there is, or is not, an intersection with surfaces on which particulate matter is contained. The concept is shown for a quarter sphere in the northwest corner of the PMC in Fig. 8 and in more detail in Fig. 9. A quarter-spherical volume of radius 10 ft (the distance of manipulator ports in the PMC and GPC above the floor) is about 1050 ft³; a hemispherical volume of this radius is 2100 ft³. Any cases involving smaller discharges, when these geometries can be assumed, are deleted from further consideration as containing no calculable amounts of particulate radioactivity.

An analysis of the problem of steady irrotational flow of air through an orifice provides a rationale for the choice of hemispherical or quarter-spherical volumetric shapes. This problem has been discussed by Morse and Feshback.²⁴ In the context of this report, a single open manipulator port (~10 in. in diameter), in the middle of a very thin wall with dimensions of 20 by 50 ft would, to a close approximation, be an orifice.




Fig. 8. Diametric cutaway of the head-end cells of the NFS fuel reprocessing plant showing estimated air-speed contours in the GPC and the quarter-spherical geometry of air discharged from the PMC.

ORNL DWG 79-1272 R




Fig. 9. Definition of quarter-spherical geometry used in calculating releases from the Process Mechanical Cell.

Equipotential surfaces of air flow under these idealized conditions are those of an oblate spheroid centered at the orifice, with the minor axis normal to the wall. The ratio of major to minor axes of the oblate spheroid is $\sqrt{R^2 + (d/2)^2}/R$, where d is the orifice diameter and R is the radius, on the wall, of the spheroid. Thus, for values of $R \gg d/2$, the major axis is only slightly larger than the minor axis and the spheroid differs only slightly from spherical. For example, a 10-in.-diam hole centered in a large wall would have an oblate-spheroidal axis ratio of 1.0009 for a value of R equal to 10 ft. As mentioned above, a hemisphere, and also the hemioblate spheroid, of $R = 10$ ft would have a volume of about 2100 ft³.

Idealized orifice flow of air from PMC or GPC into operating aisles through manipulator ports would be distorted by several factors, primarily: (1) the cell walls are thick; (2) in the PMC there are seven, not just one, ports that would become open in the case of a tornado; (3) there would be flow of air from GPC to PMC; and (4) three of the seven ports of concern in the PMC are in or near the northwest corner of the cell, not in the middle of a wall.

Within the context of the definitions of this model, Cases 3A1 - 3C1 and 3A2 - 3C2 involve discharge of air from the GPC through a port to the GPC operating aisle. The port is 10 ft above the floor of the GPC; any air flowing through this port would originate from an approximately hemispherical volume with its center at the port. As noted above, any hemispherical volume smaller than 2100 ft³ would not contain particulate matter from the floor of the GPC in this case. The largest volumetric discharge from the GPC to the operating aisle is 1428 ft³ in Case 3C2. 1428 ft³ in Case 3C2. The radius of a hemisphere of this volume is only 8.8 ft. Case 3C2 and Cases 3A1, 3B1, 3C1, 3A2, and 3B2 (Table 11) are therefore eliminated from further analysis.

The ventilation exhaust in the GPC is 19.5 ft above the floor; a quarter-spherical volume of this radius exceeds 7700 ft³. Since this volume exceeds all volumetric discharges from the GPC (Table 11) in Cases 4A - 4C and 5A - 5C, none of these require further analysis.

Three of the 7 ports in the PMC that are covered only with tape or cardboard, both of which would be blown out by a tornado, are located in the northwest corner, Fig. 8. Air and particulate matter could be discharged from each of these seven; however, we first use the conservative assumption, for the purpose of identifying the possible need for further analysis of Cases 1A1 - 1C1 and 1A2 - 1C2, that all discharges will be from the three in the northwest corner. In all of these cases the shape of the space from which air will originate is assumed to be a quarter sphere with its vertical diameter located in the northwest corner of the PMC, and its center at the manipulator ports, as shown in Fig. 8. Cases 1B1, 1C1, 1B2, and 1C2, with air discharges of 1142, 1922, 2222, and 3913 ft³, respectively (Table 11), require further analysis on the basis of the criterion given above. However, we will include Cases 1A1 and 1A2 in subsequent discussion.

Air velocities near the floor of the PMC change greatly as a result of tornado touchdown, as shown in Fig. 10 for Case 1C1. Prior to touchdown, these velocities are <1 fps except at the north end of the cell, where they rise to about 2.7 fps. After tornado strike the air speeds near the floor at the north end of the PMC rise rapidly, first downward, to about 10 fps in Case 1B1 and about 14 fps in Case 1C1, then upward to about 8 and 9 fps, respectively. The change in direction of airflow corresponds to movement of air from the GPC to PMC. The duration of the wind disturbances is more important in the case of the PMC than the GPC because of the increasing cell area (Fig. 10) affected. The time scale and the air velocities, as determined from TVENT calculations, at the boundaries of the PMC are shown in Fig. 11 for Case 1C1. From Fig. 7 it may be seen that air normally enters the PMC at manipulator ports [Branch (3)] and inleakage locations [Branch (2)] and exhausts through the hatch to the GPC [Branch (4)]. However, within a few tenths of a second after the tornado strike, the air flow directions reverse and remain reversed until 10 to 11 s after touchdown in Cases 1B1 and 1C1. During this time an increasing portion of the PMC floor (measured from north to south, or grid number 19 to 1, Figs. 8 and 10) is subjected to higher speed winds, as presented in Table 12 for Case 1C1. The maximum speed along the floor is about 15 fps (460 cm/s). According to Table 10 or Fig. 4, the maximum sized particle of UO₂ that will move and become entrained, due to wind of this speed, is about 250 μ m; according to Fig. 12, this corresponds to the potential reentrainment of 11 to 50% of the particulate matter on the segment of floor area of the PMC over which this wind speed applies, if this matter has the particle-size distribution of sheared fuel discussed in ref. 8.

Calculations with the TVENT code⁵ show that air discharged from the PMC will flow mainly through manipulator ports that are covered with cardboard, plywood, or tape (ports labeled 2 or 4 in Fig. 8). The most conservative assessment of discharges of radioactive materials from the PMC is based on the assumptions that all of the vented air flows through the three ports in the northwest corner of the PMC and that the wind speed is the maximum 15 mph over all the intercepted surface. This, and the further assumption that the vented air is from the nearly quarter spherical volume shown in Figs. 8 and 9 was combined with TVENT data to calculate particulate discharges described below.

Figure 9 defines several parameters needed in these calculations, as follows:

R = the radius of the quarter-spherical segment;

a = the radius of the quarter-circular floor segment subtended by the quarter-spherical segment;

A = the floor surface area subtended by the quarter-spherical segment;

V = the volume of air vented from the PMC and assumed to be vented through the manipulator ports in the northwest corner of the PMC.




Fig. 10. (a) SOLA-ICE calculational grid and (b) air velocities near the floor on the south-north centerline of the PMC for normal ventilation (at t_0) and at successive times after touchdown of a 300-mph tornado (Case 1C1).

ORNL DWG 79-1004 R




Fig. 11. Process mechanical cell boundary air velocities generated by the TVENT code for a 300-mph tornado with walls and doors intact (Case 1C1).

Table 12. Air velocities in PMC for Case 1C1 (300-mph tornado)^a

| Grid number | Air velocity (fps) in excess of 1 fps at tornado touchdown | | | | | | | | | | | |
|-------------|--|--------|--------|------|--------|--------|--------|--------|--------|--------|--------|------|
| | 0 s | 1 s | 2 s | 3 s | 4 s | 5 s | 6 s | 7 s | 8 s | 9 s | 10 s | 11 s |
| 2 | | | | | | | | | | | | |
| 3 | - 1.90 | - 2.10 | - 1.55 | | - 2.00 | - 1.08 | - 1.07 | - 1.66 | - 2.48 | - 2.75 | - 2.22 | |
| 4 | - 2.41 | - 2.63 | - 1.99 | | - 3.48 | - 2.01 | - 1.98 | - 3.28 | - 4.61 | - 4.55 | - 3.77 | |
| 5 | - 2.49 | - 2.69 | - 2.07 | | - 4.63 | - 3.21 | - 3.31 | - 5.57 | - 6.89 | - 6.46 | - 5.93 | |
| 6 | - 2.35 | - 2.51 | - 1.97 | | - 4.67 | - 4.78 | - 5.45 | - 8.36 | - 9.19 | - 8.67 | - 8.57 | |
| 7 | - 2.09 | - 2.22 | - 1.77 | | - 3.45 | - 6.72 | - 8.73 | -11.25 | -11.41 | -10.86 | -10.97 | |
| 8 | - 1.75 | - 1.87 | - 1.48 | | - 1.80 | - 8.70 | -12.69 | -13.81 | -13.13 | -12.39 | -12.28 | |
| 9 | - 1.33 | - 1.44 | - 1.12 | | | - 9.53 | -15.55 | -15.28 | -13.77 | -12.71 | -12.13 | |
| 10 | | | | | | - 6.81 | -14.27 | -14.50 | -12.98 | -11.86 | -11.00 | |
| 11 | | | | | 1.25 | 2.00 | - 6.29 | -10.54 | -10.99 | -10.46 | - 9.79 | |
| 12 | | | | | 2.31 | 6.24 | 6.65 | - 3.29 | - 7.75 | - 8.87 | - 9.01 | |
| 13 | | | | | 3.98 | 8.03 | 12.79 | 6.69 | - 2.70 | - 6.70 | - 8.35 | |
| 14 | | | | | 6.02 | 8.52 | 13.68 | 12.19 | 4.17 | - 3.38 | - 7.04 | |
| 15 | | | | 1.52 | 7.59 | 8.72 | 12.44 | 14.62 | 8.79 | 1.60 | - 4.31 | |
| 16 | | | 1.13 | 3.05 | 8.18 | 8.60 | 10.59 | 14.14 | 11.51 | 5.54 | 1.11 | |
| 17 | 1.59 | - 2.56 | | 1.22 | 6.63 | 9.38 | 9.04 | 9.61 | 12.50 | 12.63 | 8.99 | 5.05 |
| 18 | 2.74 | -10.25 | -14.32 | 9.84 | 8.00 | 9.22 | 8.22 | 7.65 | 7.73 | 7.84 | 7.02 | 6.32 |
| 19 | | | | | | | | | | | | |

^aAll blank spaces correspond to an absolute velocity (air speed) <1 fps.




Fig. 12. Maximum and minimum quantities of irradiated fuel of size less than (or greater than) a specified value.

When there is intersection of a quarter sphere with the floor we must consider three possible relationships between R and V for ports 10 ft above the floor:

$10 < R \leq 12$ (the width of the cell), then

$$V = (\pi/12)[4R^3 - (R - 10)^2(2R + 10)]; \quad (9)$$

$12 < R \leq 15$ (the height of the cell above the ports), then

$$V = (\pi/12)[4R^3 - (R - 10)^2(2R + 10) - (R - 12)^2(2R + 12)]; \quad (10)$$

$15 < R$, then

$$V = (\pi/12)[4R^3 - (R - 10)^2(2R + 10) - (R - 12)^2(2R + 12) - (R - 15)^2(2R + 15)]. \quad (11)$$

If the volume of vented air is such that R is < 10 ft then no particulate matter will be vented. As noted above, this volume is ~ 1050 ft³.

Table 13 summarizes geometry and mass discharges from the PMC on the basis of the building walls and local doors remaining intact or being destroyed. The upper section of this table is based on the very conservative assumption that all air leaves the PMC only through the 3 ports in the northwest corner; the lower part of the table is based on the more realistic assumption that only 3/7 of the air will be so discharged since only 3 of the 7 potentially uncovered ports are in that location. It should be noted that the appropriate assumed shapes of air prior to discharge from the other 4 ports, marked 2 in Fig. 8, would be hemispheres. The radius of each of these, corresponding to 1/7 of the volumes listed in Table 13, would be significantly less than the 10-ft distance to the floor. Even in Case 1C2 (building walls and doors destroyed), the hemispherical radius is only 6.1 ft. Cases in Table 13 were evaluated on the basis of the following product:

$$(\text{PMC})_{\text{dis}} = (A - A_h) W f_1 f_2. \quad (12)$$

A and V are defined above. Other parameters are as follows:

A_h = the hatch area correction, m²;

W = weight of UO₂ per unit area of PMC floor, 5 to 15 kg/m²;

f_1 = fraction of available UO₂ (namely that dislodged from the cladding) that would become resuspended at the maximum near-floor wind speed of 15 mph, 0.1 to 0.5;

f_2 = fraction of fuel dislodged from the cladding, 0.5 to 1, as indicated in ref. 8.

An alternate shape, that corresponds to the SOLA-ICE model (but which differs somewhat from reality) is a truncated half-cone, suggested by the air-flow patterns shown in Fig. 6.10, particularly at 10 s after touchdown (20 s after time zero of the calculations), of Holloway and Andrae.

Table 13. Geometric parameters and discharges of particulate matter from the PMC to operating aisles for quarter-spherical geometry

| | Building walls and local doors remain intact | | Building walls and local doors are destroyed | |
|---|--|-------------------------------|--|-------------------------------|
| | Case 1B1 (200-mph tornado) | Case 1C1 (300-mph tornado) | Case 1B2 (200-mph tornado) | Case 1C2 (300-mph tornado) |
| | 1273 | 1983 | 1947 | 3057 |
| Parameters based on assuming all air is discharged via ports in northwest corner | | | | |
| Radius, R, of quarter-spherical segment, ft | 10.68 ^a | 12.49 ^b | 12.41 ^b | 14.77 ^b |
| Radius, a, of intersected floor segment, ft | 3.76 ^c | 7.48 ^c | 7.35 ^c | 10.87 ^c |
| Intersected floor area, A, ft ² m ² | 11.1 1.0 | 44.0 4.1 | 42.4 3.9 | 92.8 8.6 |
| Intersected hatch area, A _h , ft ² m ² | 0. 0. | 9.0 0.8 | 8.3 0.8 | 12. 1.1 |
| Quantity of particulate matter discharged, kg | 0.25 - 7.5 | 0.8 - 25 | 0.8 - 23 | 2 - 55 |
| Parameters based on assuming 3/7 of air is discharged via ports in northwest corner | | | | |
| Radius, R, of quarter-spherical segment, ft | 8.16 ^a | 9.34 ^a | 9.29 ^a | 10.79 ^a |
| Radius, a, of intersected floor segment, ft | 0. | 0. | 0. | 4.05 ^c |
| Intersected floor area, A, ft ² m ² | 0. 0. | 0. 0. | 0. 0. | 12.9 1.2 |
| Intersected hatch area, A _h , ft ² m ² | 0. 0. | 0. 0. | 0. 0. | 0. 0. |
| Quantity of particulate matter discharged, kg | 0. | 0. | 0. | 0.3 - 9 |

^aCalculated from Eq. (9).

^bCalculated from Eq. (10).

^cCalculated as a $(R^2 - 100)^{1/2}$.

This half-cone is actually limited in the east-west direction to 12 ft, the width of the PMC, as shown in Fig. 13. The following definitions are used:

y_o = half-width of the cell, 6 ft;

R_1 = radius of the base of the half-cone, ft;

H = height of the half-cone, ft;

V = volume of half-cone, ft³.

When the radius, R_1 , of the half-cone does not exceed y_o , then

$$V = \pi R_1^2 H / 6 \quad (R_1 \leq y_o) \quad (13)$$

However, this case is significant only for discharges of small air volumes and small quantities of particulate matter from the PMC. When R_1 exceeds y_o , then

$$\begin{aligned} V = & (R_1^2 H / 3) \{ \sin^{-1}(y_o/R_1) - (\pi/2)(y_o/R_1)^3 \\ & + 2(y_o/R_1) [\sqrt{1-(y_o/R_1)^2} - 0.5 (y_o/R_1)^2 \ln [(1 + \sqrt{1 - (y_o/R_1)^2})/(y_o/R_1)]] \\ & + \pi H (y_o/R_1) y_o^2 / 6 \quad (R_1 > y_o) \end{aligned} \quad (14)$$

In Eq. (14) the last term is the volume of that portion of the half-cone that lies entirely within the width of the cell (although it may be higher than the 25-ft height of the PMC), while all other terms comprise the volume of the lower portion of the half-cone that is cut by the two north-south walls of the PMC.

Figure 14 contains plots of the base area of a truncated half-cone as a function of the volume and height. Only the volume contained in the lower 15 ft of the truncated cone is included to correspond to discharge of air only from the lower 15 ft of the PMC. It is apparent that the floor area corresponding to a specified air volume is another parameter that must be specified as a range, rather than a single value. Such ranges are listed in Table 14.

From Eq. (13), the volume of a half-cone lying entirely in the PMC and with $R_1 = 6$ ft and $H = 10$ ft, is $V = 188$ ft³. A half-cone with these parameters just touches the floor and corresponds to the largest volumetric discharge that will not contain particulate matter. This calculation shows that Cases 1A1 and 1A2 (Table 11) must be considered further, at least when it is assumed that all air leaving the PMC flows through the ports in the northwest corner of the cell. When the more realistic assumption is made, that only 3/7 of the total volume discharged from the PMC will leave via ports in the northwest corner, Case 1A1 (building walls and doors intact) ceases to be of concern; however, particulate matter would be discharged in Case 1A2.

ORNL DWG 80-191 R




Fig. 13. Geometry of a truncated half-cone in the north end of the PMC.




Fig. 14. Variation of intercepted floor area with volume of truncated half-cone and conical height.

Table 14. Geometric parameters and discharges of particulate matter from the PMC to operating aisles for truncated half-conical geometry

| | Building walls and local doors remain intact | | | Building walls and local doors are destroyed | | |
|---|--|-------------------------------|-------------------------------|--|-------------------------------|-------------------------------|
| | Case 1A1 (100-mph tornado) | Case 1B1 (200-mph tornado) | Case 1C1 (300-mph tornado) | Case 1A2 (100-mph tornado) | Case 1B2 (200-mph tornado) | Case 1C2 (300-mph tornado) |
| Air volume, V , discharged from PMC to operating aisles, ft^3 | 362 | 1273 | 1983 | 484 | 1947 | 3057 |
| Parameters based on assuming all air is discharged via ports in northwest corner | | | | | | |
| Intersected floor area, A , ft^2 | $40 - 70^a$ $3.7 - 6.5$ | $110 - 180^a$ $10 - 17$ | $200 - 275^a$ $19 - 26$ | $50 - 80^a$ $4.6 - 7.4$ | $200 - 275^a$ $19 - 26$ | $(300 - 400)^a$ $28 - 37$ |
| Intersected hatch area, A_h , ft^2 | 12 1.1 | 12 1.1 | 12 1.1 | 12 1.1 | 12 1.1 | 12 1.1 |
| Radius, R_1 , of base of truncated half-conical segment, ft | $<6 - 7^b$ | $10.5 - 16^b$ | $19 - 23.5^b$ | $<6 - 8^b$ | $19 - 23.5^b$ | $\sim 38^c$ |
| Quantity of particulate matter discharged, kg | 0.6 - 40 | 2 - 120 | 4 - 190 | 0.9 - 50 | 4 - 190 | 7 - 270 |
| Parameters based on assuming 3/7 of air is discharged via ports in northwest corner | | | | | | |
| Intersected floor area, A , ft^2 | 0. 0. | $60 - 90^a$ $5.6 - 8.4$ | $90 - 130^a$ $8.4 - 12$ | 41^d 3.9 | $90 - 130^a$ $8.4 - 12$ | $130 - 210^a$ $12 - 20$ |
| Intersected hatch area, A_h , ft^2 | 0. 0. | 12 1.1 | 12 1.1 | 12 1.1 | 12 1.1 | 12 1.1 |
| Radius, R_1 , of base of truncated half-conical segment, ft | - | $6.5 - 8.5^b$ | $8 - 11.5^b$ | 5.1 | $8 - 11.5^b$ | $11.5 - 17.5$ |
| Quantity of particulate matter discharged, kg | 0. | 1.1 - 55 | 1.8 - 80 | 0.7 - 21 | 1.8 - 80 | 3 - 140 |

^aFrom Fig. 14.

^bFrom Eq. (14).

^cExtrapolation of calculations with Eq. (14).

^dFrom Eq. (13) with $H = 15$ ft.

A comparison of discharges calculated for quarter-spherical and truncated half-cones, Tables 13 and 14, shows that the latter leads to higher calculated releases. Qualitatively, significant quantities of radioactive material will be released from the PMC in Cases 1B1, 1C1, 1B2, and 1C2 if it is assumed that all air leaves via the ports in the northwest corner of that cell. When the more realistic assumption that only 3/7 of the air will leave via those ports, then releases of particulate matter will probably not occur in Cases 1A1 or 1A2 but nearly certainly will occur in Cases 1B1, 1C1, 1B2, and 1C2, particularly in the latter two wherein building walls and local doors are destroyed.

4.2.2 Differential area/wind speed analysis

More detailed analyses of reentrainment of particles from horizontal surfaces can be performed by use of near-floor wind speeds obtained from the SOLA-ICE program. In this subsection we use point values of near-floor wind speeds rather than just the maximum in Subsect. 4.2.1.

Data from SOLA-ICE calculations for the GPC are shown in Figs. 15 and 16 for normal ventilation and for Cases 1B1 (200-mph tornado) and 1C1 (300-mph tornado) wherein building walls remain intact. Normal near-floor ventilation air speeds are of particular interest because they attain values up to 9 fps (270 cm/s), corresponding to the probable reentrainment of particles sized up to 150 μm . Thus, we would expect there to be essentially no particulate matter of sizes less than $\sim 100 \mu\text{m}$ near the center of the GPC floor. Smaller-sized particles presumably were blown to the outer areas of this floor and may have been the cause of the need to provide additional gamma-ray shielding around the ventilation exhaust at ceiling level in the GPC operating aisle. As discussed in Appendix A, particles on smear samples taken on or close to walls of the GPC are considerably smaller than those produced by shearing single rods of irradiated fuel.⁸

The highest air speeds near the floor are attained in Case 1C1 at 3s after grounding of the tornado. Interpolated grid values for this case were read from Fig. 15 and replotted as the ends of conceptual, elliptical, constant air-speed profiles shown in Fig. 8. In order to approximate the fraction of particulate matter that would become airborne from a floor over which the air velocity was varying, we performed a finite-difference integration using the specified velocity profiles, areas within these, and the differential areas between successive profiles (Appendix B). Derived quantities, as well as final estimates of the fractional reentrainment, are given in Tables 15-17 for normal ventilation and for 200- and 300-mph tornados at $t_0 + 2$ and $t_0 + 3$, respectively. (t_0 is the time the tornado touches ground.) The size of particle that would have a threshold friction speed or terminal settling speed corresponding to the mid-point velocity of successive velocity contours was then obtained from Table 10 or Fig. 4. Finally, from the upper and lower lines of Fig. 12, or from more detailed calculations shown in Table 10, we calculated maximum and minimum fractions of the UO_2 mass that are in the form of particles of size smaller than that calculated. These quantities were then used to obtain estimates of the minimum and maximum fractional reentrainments based on a model of uniform dispersion of particulate matter over the floor of the GPC.




Fig. 15. (a) SOLA-ICE calculational grid, and (b) air velocities near the floor on east-west centerline of GPC for normal ventilation and at 2 s after tornado touchdown (Cases 1B1 and 1C1).

ORNL-DWG 79-953 R




Fig. 16. (a) SOLA-ICE calculational grid, and (b) air velocities near the floor on east-west centerline of GPC for normal ventilation and at 3 s after tornado touchdown (Cases 1B1 and 1C1).

Table 15. Resuspension of UO₂ under normal ventilation flows in the GPC at NFS^a

| Air velocity near floor of General Purpose Cell (GPC) | Floor length over which air velocity equals or exceeds stated value | Floor area within elliptical contour | Differential area A_i | Fraction of GPC area within differential area | | Maximum size of particle becoming airborne | Fraction of UO ₂ mass of size \leq stated value ^d | |
|--|--|---|-------------------------------|---|-------------------|--|--|--------------|
| | | | | (ft ²) | (m ²) | | (μm) ^c | (min) (max) |
| (ft/s) | (m/s) | (Grid Units) ^b | | | | | | |
| 0. | 0. | 15.0 | 397 | 36.9 | | | | |
| 1 | 0.30 | | | | 10.87 | 0.231 | 30 | 0.0072 0.115 |
| 2 | 0.61 | 12.6 | 280 | 26.1 | | | | |
| 3 | 0.91 | | | | 6.56 | 0.139 | 65 | 0.030 0.22 |
| 4 | 1.22 | 10.9 | 210 | 19.5 | | | | |
| 5 | 1.52 | | | | 7.08 | 0.151 | 95 | 0.053 0.28 |
| 6 | 1.83 | 8.7 | 134 | 12.4 | | | | |
| 7 | 2.13 | | | | 7.98 | 0.170 | 125 | 0.07 0.34 |
| 8 | 2.44 | 5.2 | 48 | 4.4 | | | | |
| 8.5 | 2.59 | | | | 4.44 | 0.094 | 145 | 0.078 0.37 |
| 9 | 2.74 | 0.0 | 0. | 0. | | | | |

^aThe minimum and maximum area-weighted fractional resuspension values, $f_1(\text{min})$ and $f_1(\text{max})$ of Eq. (12), are calculated as $f_1(\text{min}) = \sum A_i^1 f_{1i} / \sum A_i$ and $f_1(\text{max}) = \sum A_i^2 f_{1i} / \sum A_i$. For this case, $f_1(\text{min}) = 0.033$ and $f_1(\text{max}) = 0.192$.

^bTaken from Fig. 14(b) or 15(b).

^cTaken from Fig. 4 at velocities corresponding to those in column 2.

^dTaken from Fig. 12 or Table 10.

Table 16. Resuspension of UO_2 at 2 s after onset of tornado conditions 1B1 (200 mph) at NFS^a

| Air velocity near floor of General Purpose Cell (GPC) | Floor length over which air velocity equals or exceeds stated value | | Floor area within elliptical contour | Differential area A_i | Fraction of GPC area within differential area | Maximum size of particle becoming airborne | Fraction of UO_2 mass of size \leq stated value ^d | |
|--|--|-------|---|--------------------------------------|---|--|---|--------------|
| | (ft/s) | (m/s) | (Grid Units) ^b | (ft ²) (m ²) | (m ²) | (μm) ^c | (min) | (max) |
| 0. | 0. | 15.0 | 397 | 36.9 | | | | |
| 1 | 0.30 | | | | 9.19 | 0.195 | 30 | 0.0072 0.115 |
| 2 | 0.61 | 13.0 | 298 | 27.7 | | | | |
| 3 | 0.91 | | | | 5.27 | 0.112 | 65 | 0.030 0.22 |
| 4 | 1.22 | 11.7 | 242 | 22.5 | | | | |
| 5 | 1.52 | | | | 5.39 | 0.115 | 95 | 0.053 0.28 |
| 6 | 1.83 | 10.2 | 184 | 17.1 | | | | |
| 7 | 2.13 | | | | 5.49 | 0.117 | 125 | 0.07 0.34 |
| 8 | 2.44 | 8.4 | 125 | 11.6 | | | | |
| 9 | 2.74 | | | | 7.31 | 0.156 | 150 | 0.08 0.37 |
| 10 | 3.05 | 5.1 | 46 | 4.3 | | | | |

^aThe minimum and maximum area-weighted fractional resuspension values, $f_1(\min)$ and $f_1(\max)$ of Eq. (12), are calculated as $f_1(\min) = \sum A_i^{-1} f_{1i} / \sum A_i$ and $f_1(\max) = \sum A_i^{-2} f_{1i} / \sum A_i$. For this case $f_1(\min) = 0.039$ and $f_1(\max) = 0.210$.

^bTaken from Fig. 14(b) corresponding to 2 s after tornado touchdown (the time of maximum floor velocities).

^cTaken from Fig. 4 at velocities corresponding to those in column 2.

^dTaken from Fig. 12 or Table 10.

Table 17. Resuspension of UO_2 at 3 s after onset of tornado condition 1C1 (300 mph) at NFS^a

| Air velocity near floor of General Purpose Cell (GPC) | Floor length over which air velocity equals or exceeds stated value | Floor area within elliptical contour | Differential | | Fraction of GPC area within differential area | Maximum size of particle becoming airborne | Fraction of UO_2 mass of size \leq stated value ^d | |
|--|--|---|--------------------|----------------------------------|---|--|---|--------------|
| | | | A_i | $\frac{f_{li}}{\sum A_i f_{li}}$ | | | $\frac{f_{li}}{\sum A_i f_{li}}$ | |
| (ft/s) | (m/s) | (Grid Units) ^b | (ft ²) | (m ²) | | | | |
| 0 | 0 | 15.0 | 397 | 36.9 | | | | |
| 1 | 0.30 | | | | 8.33 | 0.177 | 30 | 0.0072 0.115 |
| 2 | 0.61 | 13.2 | 308 | 28.6 | | | | |
| 3 | 0.91 | | | | 4.96 | 0.106 | 65 | 0.030 0.22 |
| 4 | 1.22 | 12.0 | 254 | 23.6 | | | | |
| 5 | 1.52 | | | | 4.49 | 0.096 | 95 | 0.053 0.28 |
| 6 | 1.83 | 10.8 | 206 | 19.1 | | | | |
| 7 | 2.13 | | | | 4.95 | 0.105 | 125 | 0.07 0.34 |
| 8 | 2.44 | 9.3 | 153 | 14.2 | | | | |
| 9 | 2.74 | | | | 6.15 | 0.131 | 150 | 0.08 0.37 |
| 10 | 3.05 | 7.0 | 87 | 8.0 | | | | |
| 10.75 | 3.28 | | | | 6.93 | 0.147 | 180 | 0.09 0.42 |
| 11.5 | 3.51 | 2.6 | 12 | 1.1 | | | | |

152

^aThe minimum and maximum area-weighted fractional resuspension values, $f_1(\min)$ and $f_1(\max)$ of Eq. (12), are calculated as $f_1(\min) = \sum A_i^1 f_{li} / \sum A_i$ and $f_1(\max) = \sum A_i^2 f_{li} / \sum A_i$. For this case $f_1(\min) = 0.043$ and $f_1(\max) = 0.226$.

^bTaken from Fig. 15(b) corresponding to 3 s after tornado touchdown (the time of maximum floor velocities).

^cTaken from Fig. 4 at velocities corresponding to those in column 2.

^dTaken from Fig. 12 or Table 10.

Air velocities in the first two columns of Tables 15-17 pertain to cases in which the building walls and local doors remain intact. Minimum and maximum quantities of UO_2 that will be reentrained, given in footnote a of each of these tables, also refer to this same structural integrity. These fractional ranges are 0.03 to 0.19, 0.04 to 0.21, and 0.04 to 0.22 of the available UO_2 for normal ventilation, 200-mph tornado, and 300-mph tornado, respectively. The significance of these ranges is that they are smaller, as would be expected, than values of 0.1 to 0.5 obtained by assuming that the maximum wind speed of 15 mph applies to all of the GPC floor. Specifically, the ranges of fractional reentrainment are 2 to 3 times smaller than the maximum range.

More detailed calculations were made of reentrainment in the PMC. The grid used in these calculations is shown in Fig. 8; the correlation between floor area and north-to-south distance from the north end of the PMC (for half-cones truncated at a 12-ft width and a 15-ft height) is shown in Fig. 17. SOLA-ICE calculations are listed for Case 1C1 (walls and doors intact) in Table 12. Similar calculations are presented by Holloway and Andrae⁵ for 100- and 200-mph tornados. The 200-mph tornado produces the highest near-floor wind speeds at about 15 s after tornado strike. These wind speeds were combined with data from other figures and tables in this report to calculate more realistic values, shown in Tables 18 and 19, of reentrainment than that given by the assumption of $f_1 = 0.1$ to 0.5 of Sect. 4.2.1. In Case 1B1, Table 18, the area-weighted fractional reentrainment is 0.036 to 0.23. The lower end of this range, 0.036, is only about a third of the value 0.1 used in calculations of Table 14, while the upper end of the range, 0.23, is less than half that used in Table 14. Similar calculations of fractional reentrainment for Case 1C1 show that use of the range 0.1 to 0.5 in Table 14 did not greatly exceed the range 0.081 to 0.39 shown in Table 19.

4.3 Source Term for Radioactive Airborne Releases

Calculations in Sect. 4.2 on weights of radioactive materials resuspended as a result of tornado strikes can be used to calculate source terms for airborne releases of these materials. As stated in Sect. 4.2, Tables 13 and 14 overestimate the quantities of particulate matter that become resuspended. In particular, a relatively large factor of conservatism is contained within the assumption that all air discharged from the PMC originated in that cell. Actually, much, perhaps 50 to 90%, of the air came through the hatch (Figs. 8 and 9) into the PMC from elevated spaces in the GPC where there would be no particulate matter.

The most realistic, yet conservative, estimates of resuspension are contained in the lower portion of Table 14. Specifically the values to be considered, with walls and local doors intact, are: (1) no releases in Case 1A1, (2) 1.1 to 55 kg released in Case 1B1, and (3) 1.8 to 80 kg released in Case 1C1. However, these need to be corrected on the basis of more realistic values of fractional entrainment [f_1 of Eq. (12)]. These are given as 0.036 to 0.23 for Case 1B1 in Table 18 and 0.081 to 0.39 for Case 1C1 in Table 19. By contrast, a range 0.1 to 0.5 was used to calculate




Fig. 17. Variation of PMC floor area with distance from north end of cell.

Table 18. Resuspension of UO_2 in Case 1B1 (200-mph wind) with building walls and doors intact^a

| Grid No. (i) | Area within grid ^b (ft ²) | Differential area (ft ²) | A_i (m ²) | Maximum near-floor air speed (at $t_o + 5$ s) | | Max size of reentrained particle (μm) ^d | Fraction of particles reentrained ^e | |
|--------------|--|--------------------------------------|-------------------------|---|--------|--|--|------------------|
| | | | | (fps) ^c | (cm/s) | | $^1f_{li}$ (min) | $^2f_{li}$ (max) |
| 19 | 0 | 13 | 1.2 | 0 | 125 | 82 | 0.043 | 0.26 |
| 18 | 13 | 39 | 3.6 | 8.13 | 245 | 140 | 0.076 | 0.36 |
| 17 | 52 | 42 | 3.9 | 7.95 | 215 | 125 | 0.070 | 0.34 |
| 16 | 94 | 37 | 3.4 | 6.31 | 175 | 105 | 0.052 | 0.305 |
| 15 | 131 | 37 | 3.4 | 5.06 | 130 | 85 | 0.046 | 0.265 |
| 14 | 168 | 37 | 3.4 | 3.39 | 80 | 60 | 0.027 | 0.21 |
| 13 | 205 | 36 | 3.3 | 2.01 | 50 | 45 | 0.016 | 0.165 |
| 12 | 241 | 35 | 3.3 | 1.22 | 30 | 33 | 0.009 | 0.125 |
| 11 | 276 | 35 | 3.3 | 0.83 | 20 | 33 | 0.009 | 0.125 |
| 10 | 311 | 35 | 3.3 | 0.53 | 10 | 33 | 0.009 | 0.125 |
| 9 | 346 | 35 | 3.3 | 0.22 | 0 | 0 | 0. | 0. |
| 8 | 381 | | | (-0.28) ^f | | | | |

^aThe minimum and maximum area-weighted fractional resuspension values, f_1 (min) and f_1 (max) of Eq. (12), are calculated as f_1 (min) = $\sum A_i^1 f_{li} / \sum A_i$ and f_1 (max) = $\sum A_i^2 f_{li} / \sum A_i$. For this case f_1 (min) = 0.036 and f_1 (max) = 0.23.

^bFrom Fig. 16.

^cFrom SOLA-ICE calculations similar to those in Table 12. The maximum wind speeds occur at $t_o + 5$ s in this case.

^dFrom Fig. 4.

^eFrom Table 10 and Fig. 12.

^fNegative values, corresponding to downflow of air, were not used in calculating values listed in note a.

Table 19. Resuspension of UO_2 in Case 1C1 (300-mph wind) with building walls and doors intact^a

| Grid No. (i) | Area within grid ^b (ft ²) | Differential area | | Maximum near-floor air speed (at $t_o + 8$ sec) | | Max size of reentrained particle ^d (μm) | Fraction of particles reentrained ^e | |
|--------------|--|--------------------|-------------------|---|--------|---|--|------------------------------------|
| | | (ft ²) | (m ²) | (fps) ^c | (cm/s) | | ¹ f _{1i} (min) | ² f _{1i} (max) |
| 19 | 0 | 13 | 1.2 | 0. | 120 | 80 | 0.041 | 0.23 |
| 18 | 13 | 39 | 3.6 | 7.73 | 310 | 170 | 0.083 | 0.405 |
| 17 | 52 | 42 | 3.9 | 12.50 | 405 | 220 | 0.102 | 0.47 |
| 16 | 94 | 37 | 3.4 | 14.14 | 440 | 235 | 0.108 | 0.485 |
| 15 | 131 | 37 | 3.4 | 14.62 | 410 | 220 | 0.102 | 0.47 |
| 14 | 168 | 37 | 3.4 | 12.19 | 290 | 160 | 0.082 | 0.395 |
| 13 | 205 | 36 | 3.3 | 6.69 | 50 | 44 | 0.015 | 0.16 |
| 12 | 241 | 35 | 3.3 | (-3.29) ^f | 0 | 0 | 0. | 0. |
| 11 | 276 | | | (-10.54) ^f | | | | |

^aThe minimum and maximum area-weighted fractional resuspension values, f_1 (min) and f_1 (max) of Eq. (12), are calculated as f_1 (min) and $\sum A_i f_{1i} / \sum A_i$ and f_1 (max) = $\sum A_i^2 f_{1i} / \sum A_i$. For this case f_1 (min) = 0.081 and f_1 (max) = 0.39.

^bFrom Fig. 16.

^cFrom Table 12.

^dFrom Fig. 4.

^eFrom Table 10 and Fig. 12.

^fNegative values, corresponding to downflow of air, were not used in calculating values listed in note a.

values in Table 14. Using these changes in f_1 , the source terms in Table 20 were calculated. These values are conservative due to still another assumption, namely that none of the particles settle back onto horizontal surfaces in the PMC; instead, they are all discharged into operating aisles.

If the building walls and doors remain intact, much of the material vented from the PMC into operating aisles will probably settle in those aisles. If, however, building walls and doors are destroyed in 200- or 300-mph tornadoes, then releases in excess of those listed in Table 20 may reach the atmosphere and be widely dispersed.

Particle-size distributions of solids discharged from the PMC, as in Cases 1B1 and 1C1, can be calculated within the accuracies of the various other assumptions by interpolating in Table 10 and using areas and fractional discharges listed in Tables 18 or 19 (or 15-17). Referring to Table 18, we see that the maximum-sized particles that can be reentrained between grids 19 and 18 are sized 82 μm . The particle-size distribution of particles between these grids for minimum reentrainment is obtained by dividing values in the penultimate column of Table 10 by the value $^1f_{11}$ ($=0.043$) from Table 18; the distribution for maximum reentrainment for this same differential area is obtained by dividing values in the last column of Table 10 by the value $^2f_{11}$ ($=0.26$) from Table 18. The operations are performed only for particles sized up to 82 μm for this segment. By repeating these calculations for each differential area up to the maximum size of particle that can be reentrained in that area, a distribution of sizes of all material discharged from the PMC can be obtained. In Case 1B1 all discharged particles will be smaller than 140 μm while in Case 1C1 all particles will be $<235 \mu\text{m}$.

As described in Sect 3.1, the average decay time of fuel particles in the PMC and GPC prior to November 1978, was ~ 10 years. Particle agglomeration undoubtedly occurred during this time as shown by the figures in the appendix. However, such agglomeration is apparently not important in this case since agglomerates on three wipe samples taken in the GPC attain a maximum size of about 40 to 50 μm . They, and the smaller particles which form them, would have been moved (had their critical friction speeds exceeded) and reentrained at the near-floor air speeds induced by tornadoes considered in this report. As noted in Table 10, the critical friction speed of a 50- μm particle is, with adhesion, $<35 \text{ cm/s}$; near-floor air speeds considered in this report range up to 450 cm/s (15 fps). We cannot, of course, be certain that particles on the three wipe samples taken in the GPC are representative of all material in this cell or in the PMC.

Table 20. Radioactive materials in particulate matter potentially discharged from the PMC: condition - building walls and local doors remain intact^a

| ORIGEN yield (11 years' decay) (Ci/MTU) | Quantities of radioactivity (Ci) | |
|---|----------------------------------|---------------|
| | Case 1B1 | Case 1C1 |
| Quantity of particulate matter discharged, kg | 0.4 - 25 | 1.5 - 65 |
| ⁹⁰ Sr | 3.2E+4 | 1.E+1 - 8.E+2 |
| ⁹⁰ Y | 3.2E+4 | 1.E+1 - 8.E+2 |
| ⁹⁹ Tc | 6.8E+0 | 3.E-3 - 2.E-1 |
| ¹⁰⁶ Ru | 1.3E+2 | 5.E-2 - 3.E+0 |
| ^{113m} Cd | 1.2E+1 | 5.E-3 - 3.E-1 |
| ¹²⁵ Sb | 4.6E+2 | 2.E-1 - 1.E+1 |
| ^{125m} Te | 1.1E+2 | 4.E-2 - 3.E+0 |
| ¹³⁴ Cs | 1.0E+3 | 4.E-1 - 3.E+1 |
| ¹³⁷ Cs | 4.0E+4 | 2.E+1 - 1.E+3 |
| ^{137m} Ba | 3.8E+4 | 2.E+1 - 1.E+3 |
| ¹⁴⁴ Ce | 5.0E+1 | 2.E-2 - 1.E+0 |
| ¹⁴⁴ Pr | 5.0E+1 | 2.E-2 - 1.E+0 |
| ¹⁵¹ Sm | 2.4E+2 | 1.E-1 - 6.E+0 |
| ¹⁵² Eu | 2.7E+0 | 1.E-3 - 7.E-2 |
| ¹⁵⁴ Eu | 9.9E+2 | 4.E-1 - 2.E+1 |
| ¹⁵⁵ Eu | 4.1E+2 | 2.E-1 - 1.E+1 |
| Total fission products | 1.5E+5 | 6.E+1 - 4.E+3 |
| ²³⁹ Np | 1.1E+0 | 4.E-4 - 3.E-2 |
| ²³⁸ Pu | 3.7E+2 | 1.E-1 - 9.E+0 |
| ²³⁹ Pu | 2.6E+2 | 1.E-1 - 7.E+0 |
| ²⁴⁰ Pu | 2.5E+2 | 1.E-1 - 6.E+0 |
| ²⁴¹ Pu | 3.1E+4 | 1.E+1 - 8.E+2 |
| ²⁴¹ Am | 7.4E+2 | 3.E-1 - 2.E+1 |
| ²⁴³ Am | 1.1E+0 | 4.E-4 - 3.E-2 |
| ²⁴⁴ Cm | 2.6E+1 | 1.E-2 - 7.E-1 |
| Total actinides | 3.2E+4 | 1.E+1 - 8.E+2 |

^aNo material is discharged in Case 1A1 (100-mph tornado).

59/60

APPENDICES



5.1 Appendix A: Analysis of Samples from the General Purpose Cell

On June 4, 1979, members of the staff of NFS, at the request of A. T. Clark of NRC, recovered three pieces of cladding hulls and took three smears of surfaces from the GPC. These samples were transferred to a hot cell in the analytical chemistry area and placed in individual polyethylene bags. The bags were then placed in a stainless steel container that constitutes the inner vessel of a General Electric Model 8400 radioactive materials shipping container. This was subsequently shipped to the Oak Ridge National Laboratory for various analyses.

According to A. C. Pierce of NFS, the three unflattened cladding samples were obtained as follows: hull A, from the GPC floor in front of the east window; hull B, from the center of the cell; hull C, from an unknown location, previously stored in analytical cells (see Fig. 2). Smears were taken from the following locations: smear 1, a 6-in. swipe from inside the dumping station; smear 2, an 8-in. swipe from the top surface of the basket cooler in front of the middle window; and smear 3, an 8-in. swipe from the vertical wall in front of the east window.

Two types of analyses of the samples were performed: first, the obtaining of gamma-ray spectra from a 4096-channel analyzer; second, the obtaining of photomicrographs of the three wipe papers.

5.1.1 Radioactivity from gamma-ray analyses

Results of the gamma-ray scans are summarized in Table A-1. This summary also contains a $^{134}\text{Cs}/^{137}\text{Cs}$ age, which was read from Fig. A-1. This figure is based on ORIGEN calculations described in Sect. 3.1. The data of Table A-1 are expressed in Table A-2 after normalization with respect to ^{137}Cs activity in the fuel. Also included in Table A-2 are values of these ratios for cladding and fuel activity ratios calculated from ORIGEN.

The presence of the fission products ^{125}Sb , ^{134}Cs , ^{137}Cs , ^{154}Eu , and ^{155}Eu on smear and cladding samples clearly implies that irradiated fuel is present on all of them. However, only the $^{134}\text{Cs}/^{137}\text{Cs}$ ages and the ratios $^{154}\text{Eu}/^{137}\text{Cs}$ are in good agreement with values expected from ORIGEN calculations.

Radioactivity contamination, at ORNL or NFS, is indicated from the ratios for ^{51}Cr , ^{54}Mn , and ^{95}Zr , all with half-lives less than 1 year, given in Table A-2. Each of these nuclides should be present in quantities below analytical limits, as is the case with ^{51}Cr on smears 2 and 3, Table A-1. Contamination is further implied by the presence of any radioactivity on the stainless steel container. The $^{60}\text{Co}/^{137}\text{Cs}$ value for cladding sample A in Table A-2 implies contamination. Values of this ratio for the other samples are also of uncertain significance since ^{60}Co (cladding)/ ^{137}Cs (fuel), given as 2.3E-2 in the last column of Table A-2, corresponds to the ratio expected for a cladding sample (from a PWR) that is essentially full of reference fuel or, in the case of smear samples, that contains hardware and fuel in the ratio 260 kg of hardware per Mg U.

Table A-1. Gamma-ray analyses of samples from NFS and the $^{134}\text{Cs}/^{137}\text{Cs}$ age.

| Nuclide | Stainless steel container (dps on 6/27/79) | Smear (μCi on 7/10/79) | | | Cladding (μCi on 7/10/79) | | |
|-----------------------------------|--|------------------------------------|------------|---------------|---------------------------------------|---------|---------------|
| | | 1 | 2 | 3 | A | B | C |
| ^{51}Cr | - | 2.7E-1 | ≤ 4.2 | $\leq 6.$ E-1 | - | 9.02 | 5.82 |
| ^{54}Mn | - | - | - | - | 6.08E+1 | - | - |
| ^{60}Co | 1.6 E+3 | 2.7 | 1.0 | 1.3 E-1 | 1.32E+4 | 1.34E+2 | 3.23E+1 |
| ^{95}Zr | - | 7. E-2 | 8.1 E-1 | 8. E-2 | - | 2.6 | 5.4 E-1 |
| ^{106}Ru | 2.0 E+3 | - | - | - | - | - | - |
| ^{125}Sb | 2.3 E+3 | 6.22 | 3.85 | - | - | 3.42E+2 | 1.33E+2 |
| ^{134}Cs | 4.8 E+3 | 2.0 | 2.2 E+1 | 1.86 | 9.2 E+1 | 4.0 E+1 | 9.08 |
| ^{137}Cs | 1.01E+5 | 5.1E+1 | 3.88E+2 | 4.89E+1 | 1.26E+3 | 1.48E+3 | 4.47E+2 |
| ^{152}Eu | - | - | - | - | - | - | $\leq 5.$ E-1 |
| ^{154}Eu | 3.3 E+3 | 9.7E-1 | 1.16E+1 | 1.23 | 3.5 E+1 | 3.7 E+1 | 6.5 |
| ^{155}Eu | 3.3 E+2 | 2.7E-1 | 2.6 | 3.3 E-1 | - | 5.8 | 1.73 |
| $^{134}\text{Cs}/^{137}\text{Cs}$ | 4.8 E-2 | 3.9E-2 | 5.7 E-2 | 3.8 E-2 | 7.3 E-02 | 2.7 E-2 | 2.0 E-2 |
| Cesium age, year | 12 | 13 | 11.5 | 13 | 11 | 14 | 15 |




Fig. A-1. Variation of $^{134}\text{Cs}/^{137}\text{Cs}$ activity age with decay time.

Table A-2. Activity ratios compared with ORIGEN calculations

| Nuclide | Half-life | Stainless steel container | Nuclide activity/ ¹³⁷ Cs activity (Ci/Ci) | | | | | | ORIGEN calculations (11-year decay of reference fuels ^a) | | |
|-------------------|-----------|---------------------------|--|---------|---------|------------------|--------|---------|--|--------------|--|
| | | | Smear samples | | | Cladding samples | | | | | |
| | | | 1 | 2 | 3 | A | B | C | Fiss. Prod. | Activ. Prod. | |
| ⁵¹ Cr | 27.71 d | - | 5.3E-3 | <1.1E-2 | <1.2E-2 | - | 6.1E-3 | 1.3E-2 | 0. | 1.3E-44 | |
| ⁵⁴ Mn | 312.5 d | - | - | - | - | 4.8E-2 | - | - | 0. | 2.0E-7 | |
| ⁶⁰ Co | 5.272 y | 1.6E-2 | 5.3E-2 | 2.6E-3 | 2.7E-3 | 1.0E+1 | 9.1E-2 | 7.2E-2 | 0. | 2.3E-2 | |
| ⁹⁵ Zr | 65.5 d | - | 1.4E-3 | 2.1E-3 | 1.6E-3 | - | 1.8E-3 | 1.2E-3 | 4.5E-18 | 1.1E-19 | |
| ¹⁰⁶ Ru | 369 d | 2.0E-2 | - | - | - | - | - | - | 3.2E-3 | 1.1E-22 | |
| ¹²⁵ Sb | 2.73 y | 2.3E-2 | 1.2E-1 | 9.9E-3 | - | - | 2.3E-1 | 3.0E-1 | 1.1E-2 | 1.4E-3 | |
| ¹³⁴ Cs | 2.06 y | 4.8E-2 | 3.9E-2 | 5.7E-2 | 3.8E-2 | 7.3E-2 | 2.7E-2 | 2.0E-2 | 2.6E-2 | 1.0E-26 | |
| ¹³⁷ Cs | 30.1 y | 1. | 1. | 1. | 1. | 1. | 1. | 1. | 1. | 2.3E-44 | |
| ¹⁵² Eu | 13 y | - | - | - | - | - | - | <1.1E-3 | 6.7E-5 | 1.6E-15 | |
| ¹⁵⁴ Eu | 8.6 y | 3.3E-2 | 1.9E-2 | 3.0E-2 | 2.5E-2 | 2.8E-2 | 2.5E-2 | 1.5E-2 | 2.5E-2 | 1.2E-6 | |
| ¹⁵⁵ Eu | 4.8 y | 3.3E-3 | 7.6E-4 | 6.7E-3 | 6.7E-3 | - | 3.9E-3 | 3.9E-3 | 1.0E-2 | 2.4E-7 | |

^aThe reference fuel is defined in Sect. 4. Both fission products and activation products refer to irradiation in a PWR and cladding composition for PWR fuels as given by Croff et al.¹¹. These are 235 kg Zircaloy per Mg U, 12.8 kg Inconel per Mg U, 2.6 kg Nicrobrazo 50 per Mg U, and 9.94 kg SS per Mg U.

5.1.2 Distribution of sizes of particles on wipe papers

Photomicrographs of particulate matter on the three wipe samples are shown in Figs. A-2 to A-5. Of these, Figs. A-2, A-4, and A-5 illustrate the central sections of smears 1, 2, and 3, respectively; Fig. A-3 contains photomicrographs of an outer segment of smear 1.

The frequency of occurrence of particles of size between two specified values was determined by use of Carl Zeiss Particle Size Analyzer, model TGZ 3, with photomicrographs of 600X magnification. Data from these frequency measurements were plotted in several ways in a search for a mathematical model of frequency distribution. Figure A-6 suggests that neither the number of particles nor their weight conform to the normal distribution function. However, Figs. A-7 and A-8 support a conclusion that the number frequency is lognormally distributed according to particle size. On the basis of these plots, the number frequency distribution of each of the four portions of the three wipe samples was analyzed in a manner similar to that used previously,⁸ namely by use of the Marquardt program^{25,26} for estimating the one linear and two nonlinear parameters of the lognormal distribution function. This function, discussed in detail by Aitchison and Brown,²⁷ is given as

$$d\Lambda(x) = B \frac{e^{-(\ln x - m)^2/(2s^2)}}{xs} dx, \quad (A-1)$$

where

$d\Lambda(x)$ = probability that a particle will have a size (diameter) between x and $x + dx$,

B = $1/(2\pi)^{1/2}$ if the lognormal distribution does apply and the photomicrographs are representative of particles on the smear sample,

= $1/(2\pi)^{1/2} x$ (a constant), if the lognormal distribution does not truly apply, but the computer program is still able to fit the data to the model,

x = particle size,

s = estimated standard deviation of the natural logarithms of particle sizes,

m = estimated median of the natural logarithm of particle sizes.

Solid curves drawn through the data and extrapolated below a 1- μm particle size in Figs. A-7 and A-8 were calculated from the parameters obtained from a nonlinear least-squares analysis of the lognormal distribution function. This analysis is based on numerical integration of Eq. (A-1):




Fig. A-2. Photomicrographs of central area of smear 1.

ORNL DWG 79-20560




Fig. A-3. Photomicrographs of outer area of smear 1.




Fig. A-4. Photomicrographs of central area of smear 2.




Fig. A-5. Photomicrographs of central area of smear 3.




Fig. A-6. Normal distribution plots of number and weight of particles as a function of particle size. This distribution does not appear to apply.




Fig. A-7. Lognormal distributions of number and weight of particles on the central section of smear 1 as a function of particle size. The number distribution describes the data very well.




Fig. A-8. Lognormal distributions of number of particles as a function of particle size for three smear samples.

$$\Lambda(x) = \Lambda(x') + B \int_{x'}^x \frac{e^{-(\ln t - m)^2/(2s^2)}}{ts} dt, \quad (A-2)$$

where $\Lambda(x') = B \int_0^{x'} \frac{e^{-(\ln t - m)^2/(2s^2)}}{ts} dt, \quad (A-3)$

and t is a dummy integration variable.

As noted previously,⁸ splitting $\Lambda(x)$ into two terms, one of which, namely $\Lambda(x')$, is very small in comparison with the other, provides an easy method for avoiding the numerical difficulties of $-\infty$ due to $\ln t$ as $t \rightarrow 0$. In particular, $\Lambda(x')$ is in the order of 10^{-5} to 10^{-9} for x' in the range 0.1 to 0.01 μm ; by contrast, the integral term of Eq. (2) is in the range 0.1 to 0.99, corresponding to 10 to 99% of the number distribution being in the form of particles between 1 and 50 μm . Once a set of parameters B , m , and s has been estimated, these can be used with graphical or numerical methods to improve the estimate of $\Lambda(x')$, where x' can be made a very small positive number.

Results of the particle-size distribution analyses, based on $B = 1/(2\pi)^{1/2}$, are presented in Table A-3. B was set to this value after it was first determined, with B as a parameter, that $B(2\pi)^{1/2} = 1.0$ within experimental error. It is apparent that particles on the wipe samples from the GPC at NFS are considerably smaller than particles produced by shearing irradiated or unirradiated light-water reactor (LWR) fuels.⁸ Thus, mode, median, and mean particle sizes on the wipe samples are in the range 2, 3, and 4 μm , respectively; corresponding values of mode and median for particles from shearing LWR fuels were in the range 6 to 60 μm and 100 to 6000 μm , respectively.

Table A-3. Analysis of data on sizes of particles on
wipe samples from the General Purpose Cell of the
NFS West Valley Plant^a

| Sample designation | Parameter ^b | | Standard deviation of fit | Mode ^c (μm) | Median ^c (μm) | Mean ^c (μm) |
|--|------------------------|-------------------|---------------------------|------------------------|--------------------------|------------------------|
| | m and \hat{S}_m | s and \hat{S}_s | | | | |
| <u>Constant error in the fraction of particles of size smaller than specified^d</u> | | | | | | |
| Smear 1 center | 1.0447 0.0058 | 0.7352 0.0075 | 4.702E-3 | 1.66 | 2.84 | 3.73 |
| Smear 1 outer area | 1.0481 0.0093 | 0.7426 0.0119 | 7.487E-3 | 1.64 | 2.85 | 3.76 |
| Smear 2 center | 1.3576 0.0084 | 0.5952 0.0113 | 1.103E-2 | 2.73 | 3.89 | 4.64 |
| Smear 3 center | 1.1162 0.0031 | 0.6758 0.0041 | 2.942E-3 | 1.93 | 3.05 | 3.84 |
| <u>Constant fractional error in the fraction of particles of size smaller than specified^e</u> | | | | | | |
| Smear 1 center | 1.0384 0.0037 | 0.7467 0.0065 | 5.844E-3 | 1.62 | 2.83 | 3.73 |
| Smear 1 outer area | 1.0506 0.0056 | 0.7377 0.0100 | 9.331E-3 | 1.66 | 2.86 | 3.75 |
| Smear 2 center | 1.3699 0.0072 | 0.5379 0.0099 | 2.230E-2 | 2.95 | 3.94 | 4.55 |
| Smear 3 center | 1.1144 0.0018 | 0.6799 0.0034 | 3.646E-3 | 1.92 | 3.05 | 3.84 |

^aBased on the distribution of the number of particles of size smaller than a specified value.

^bSee Eq. (A-1) for definitions of m and s as used in this table. The symbol \hat{S} is used to specify standard deviation of the parameter estimated from the data. Thus, \hat{S}_m is the estimated standard deviation of m, \hat{S}_s is the estimated standard deviation of s.

^cMode = $\exp(m - s^2)$; Median = $\exp(m)$; Mean = $\exp(m + s^2/2)$ (ref. 26).

^dIn this analysis the statistical weighting factor was 1.0.

^eIn this analysis the statistical weighting factor was (1.0/fraction of particles of size smaller than specified).

5.2 Appendix B: Calculation of Fractional Resuspension

Calculations of the fractions of UO_2 particles that will become resuspended for specific particle-size distribution, air-velocity distribution, and for elliptically shaped floor segments were performed by use of the computer program listed on the next two pages of this appendix. Input to this program consist of air speeds (ft/s), the maximum size (in micrometers) of particles that would remain entrained at the specified air speed, the minimum fractional and maximum fractional weights contained as particles of sizes less than the stated values (Table 10 or Fig. 4), and the floor lengths over which the air velocities exceed the stated values. These data are listed in columns 1, 8, 9, and 10, and 3, respectively, in Tables 15-17. As an example, the input for Case 1C1 (a 300-mpm tornado with building walls intact) are given on page 78. Output from the program, including calculated floor areas and fractional floor areas within air-velocity contours, are given for this case on page 78. This corresponds to Table 17.

```
DIMENSION AFT2(20), AM2(20)
DIMENSION CON(10)
DIMENSION DIFAM2(20)
DIMENSION FAREA(20), FRMIN(20), FRMAX(20)
DIMENSION GU(20)
DIMENSION PSMAX(20)
DIMENSION WINDSF(20), WINDSM(20), WNDEIF(20), WNDSIM(20)
CON(1) = 3.14159 * (11. / 15.) * (46. / 15.) / 4.
CON(2) = 0.3048
CON(3) = 0.0929
CON(4) = 46. * 11. * CON(3)
41 TYPE 1031
ACCEPT 901, NOF
IF (NOF.EQ.0) CALL EXIT
TYPE 1041
ACCEPT 901, NO
GO TO (51,61,71,81) NOF
51 OPEN (UNIT=1, FILE='CASE1.DAT')
GO TO 91
61 OPEN (UNIT=1, FILE='CASE2.DAT')
GO TO 91
71 OPEN (UNIT=1, FILE='CASE3.DAT')
GO TO 91
81 OPEN (UNIT=1, FILE='CASE4.DAT')
91 I = 0
121 I = I + 1
READ (1,911) WINDSF(I), GU(I)
READ (1,921) WNDEIF(I), PSMAX(I), FRMIN(I), FRMAX(I)
IF (WNDEIF(I).GE.0.0) GO TO 121
NDP = I - 1
NDF1 = I
GO TO (151,161,171,181) NOF
151 CLOSE (UNIT=1, FILE='CASE1.DAT')
GO TO 191
161 CLOSE (UNIT=1, FILE='CASE2.DAT')
GO TO 191
171 CLOSE (UNIT=1, FILE='CASE3.DAT')
GO TO 191
181 CLOSE (UNIT=1, FILE='CASE4.DAT')
191 CONTINUE
DO 201 I = 1,NDP1
  AFT2(I) = CON(1) * GU(I) * GU(I)
  AM2(I) = AFT2(I) * CON(3)
  WINDSM(I) = WINDSF(I) * CON(2)
201 CONTINUE
SUMMIN = 0.0
SUMMAX = 0.0
DO 251 I = 1,NDP
  DIFAM2(I) = AM2(I) - AM2(I+1)
  FAREA(I) = DIFAM2(I) / CON(4)
  WNDSIM(I) = WNDEIF(I) * CON(2)
  TEMP = AM2(I) / CON(4)
  IF (I .GT. 1) GO TO 231
  TERM1 = FRMIN(I)
  TERM2 = FRMAX(I)
  GO TO 241
```

```
231 TERM1 = FRMIN(I) - FFRMIN(I-1)
241 TERM2 = FRMAX(I) - FFRMAX(I-1)
241 SUMMIN = SUMMIN + TEMP * TERM1
241 SUMMAX = SUMMAX + TEMP * TERM2
251 CONTINUE
      WRITE (NO,1101)
      WRITE (NO,1111)
      WRITE (NO,1121)
      WRITE (NO,1131)
      WRITE (NO,1141)
      WRITE (NO,1151)
      WRITE (NO,1171)
      DC 401 I = 1,NDP
      WRITE (NO,1201) WINDSF(I), WINDSM(I), GU(I), AFT2(I), AM2(I)
      WRITE (NO,1211) WNDSD(I), WNDSDM(I), DIFAM2(I), FAREA(I),
      PSMAX(I), FRMIN(I), FRMAX(I)
401 CONTINUE
      WRITE (NO,1231) WINDSF(NDP1), WINDSM(NDP1), GU(NDP1), AFT2(NDP1),
      AM2(NDP1)
      WRITE (NO,1241)
      WRITE (NO,1251) SUMMIN, SUMMAX
      WRITE (NO,1301)
      GO TO 41
901 FORMAT (I1)
911 FORMAT (E15.0, 3X, E10.0)
921 FORMAT (7E10.0)
1031 FORMAT (' PLEASE TYPE A FILE NUMBER TO SPECIFY WHETHER THE      //'
      ' TORNADO CONDITION FILE IS 1, 2, 3, OR 4      //')
1041 FORMAT (' PLEASE TYPE A UNIT NUMBER TO SPECIFY DESTINATION OF      //'
      ' THE OUTPUT.      //')
1101 FORMAT ('          FLOOR          FRACT
      ' MAX          ' / )
1111 FORMAT ('          WIND SPEED          LENGTH          OF GPC
      ' SIZE          FRACTION OF ' / )
1121 FORMAT ('          NEAR FLOOR          OVER          FLOOR AREA          AREA
      ' OF          PARTICULATE ' / )
1131 FORMAT ('          OF GENERAL          WHICH          WITHIN          IN
      ' PARTI          WEIGHT THAT ' / )
1141 FORMAT ('          PURPOSE          SPEED IS          ELLIPTICAL          DIFF          DIFF
      ' AIR-          BECOMES ' / )
1151 FORMAT ('          CELL (GPC)          EXCEEDED          CONTOUR          AREA          AREA
      ' BORNE          AIRBORNE ' / )
1171 FORMAT ('          FT/S          M/S          GRID UN.          FT**2          M**2          M**2
      ' M          ' / )
1201 FORMAT (F8.2, F7.2, F9.1, F10.0, F6.1)
1211 FORMAT (F8.2, F7.2, 25X, F7.2, F8.3, F7.0, F7.2, ' - ', F5.2)
1241 FORMAT (///)
1251 FORMAT (' BASED ON UNIFORM DISTRIBUTION OF SOLIDS ON THE FLOOR,
      ' /
      ' THE FRACTION OF SOLIDS THAT BECOMES AIRBORNE IS BETWEEN
      ' /
      ' F7.3, ' AND', F6.3)
1301 FORMAT (1H1)
      RETURN
      END
```

Sample Input Data

| | | | | |
|-------|------|--------|-------|------|
| 0.0 | | | | 15. |
| 1.0 | 30. | 0.0072 | 0.115 | |
| 2.0 | | | | 13.2 |
| 3.0 | 65. | 0.030 | 0.22 | |
| 4.0 | | | | 12.0 |
| 5.0 | 95. | 0.053 | 0.28 | |
| 6.0 | | | | 10.8 |
| 7.0 | 125. | 0.07 | 0.34 | |
| 8.0 | | | | 9.3 |
| 9.0 | 150. | 0.08 | 0.37 | |
| 10.0 | | | | 7.0 |
| 10.75 | 180. | 0.09 | 0.42 | |
| 11.5 | | | | 2.6 |
| -1.0 | | | | |

Output Results

| WIND SPEED NEAR FLOOR OF GENERAL PURPOSE CELL (GPC) | FLOOR LENGTH OVER WHICH | FLOOR AREA WITHIN ELLIPTICAL SPEED IS EXCEEDED | CONTOUR | FRACT OF GPC | MAX SIZE IN DIFF | FRACTION OF PARTICULATE PARTI WEIGHT THAT BECOMES AIRBORNE | AIRBORNE |
|---|----------------------------------|--|---------|-----------------|---------------------------|---|----------|
| FT/S | M/S | GRID UN. | FT**2 | M**2 | M**2 | μ m | |
| 0.00 | 0.00 | 15.0 | 397. | 36.9 | | | |
| 1.00 | 0.30 | | | | 8.33 | 0.177 | 30. |
| 2.00 | 0.61 | 13.2 | 308. | 28.6 | 4.96 | 0.106 | 65. |
| 3.00 | 0.91 | | | | 4.49 | 0.096 | 95. |
| 4.00 | 1.22 | 12.0 | 254. | 23.6 | 4.49 | 0.105 | 125. |
| 5.00 | 1.52 | | | | 4.95 | 0.131 | 150. |
| 6.00 | 1.83 | 10.8 | 206. | 19.1 | 6.15 | 0.147 | 180. |
| 7.00 | 2.13 | | | | 6.93 | 0.147 | |
| 8.00 | 2.44 | 9.3 | 153. | 14.2 | | | |
| 9.00 | 2.74 | | | | | | |
| 10.00 | 3.05 | 7.6 | 87. | 8.0 | | | |
| 10.75 | 3.28 | | | | | | |
| 11.50 | 3.51 | 2.6 | 12. | 1.1 | | | |

BASED ON UNIFORM DISTRIBUTION OF SOLIDS ON THE FLOOR,
THE FRACTION OF SOLIDS THAT BECOMES AIRBORNE IS BETWEEN
0.043 AND 0.226

6. REFERENCES

1. U.S. Department of Energy, Western New York Nuclear Service Center Study, TID-28905-3 (December 1978).
2. U.S. Nuclear Regulatory Commission, Interim Safety Evaluation I. Nuclear Fuel Services, Inc., and New York State Energy Research and Authority, Western New York Nuclear Service Center, Docket No. 50-201 (August 1977).
3. R. W. Andrae, R. A. Martin, and W. S. Gregory, Analysis of Nuclear Facilities for Tornado-Induced Flow and Reentrainment, Los Alamos Scientific Laboratory, NUREG/CR-0521 (LA-7571-MS, Informal report) (January 1979).
4. K. H. Duerre, R. W. Andrae, and W. S. Gregory, TVENT, A Computer Program for Analysis of Tornado-Induced Transients in Ventilation Systems, LA-7397-M (July 1978).
5. L. J. Holloway and R. W. Andrae, Potential Radiological Impact of Tornadoes on the Safety of Nuclear Fuel Services' West Valley Fuel Reprocessing Plant. I. Tornado Effects on Head-End Cell Airflow, ORNL/NUREG-80/P1 (NUREG/CR-1530, Part 1) (1981).
6. Nuclear Regulatory Staff, NFS-Interim SER I, Docket No. 50-201 (May 1977).
7. Staff of Nuclear Fuel Services, Safety Analysis Report, NFS' Reprocessing Plant, West Valley, New York, Docket 50-201 (1973).
8. W. Davis, Jr., G. A. West, and R. G. Stacy, Oxide Particle Size Distribution from Shearing Irradiated and Unirradiated LWR Fuels in Zircaloy and Stainless-Steel Cladding: Significance for Risk Assessment ORNL/NUREG-60 (NUREG/CR-0866) (October 1979).
9. B. C. Finney, Oak Ridge National Laboratory, personal communication, May 30, 1979.
10. G. Dymmel, Boeing Engineering and Construction Co. (formerly at the West Valley Plant of NFS) personal communication, May 31, 1979.
11. A. G. Croff, M. A. Bjerke, G. W. Morrison, and L. A. Petrie, Revised Uranium-Plutonium Cycle PWR and BWR Models for the ORIGEN Computer Code, ORNL/TM-6051 (September 1978).
12. C. B. Woodall, U.S. LWR Spent Fuel Inventory and Projection, Nuclear Assurance Corporation, Y/OWI/SUB-77/42500 (June 1977).

13. E. D. Arnold and B. F. Maskewitz, SDC, A Shielding-Design Code for Fuel Handling Facilities, ORNL-3041 (March 1966). Also available from the Radiation Shielding Information Center of Oak Ridge National Laboratory as SDC, Kernel Integration Shield Design Code for Radioactive Fuel Handling Facilities, CCC-60 (Nov. 25, 1973).
14. K. Stewart, "The Resuspension of Particulate Material from Surfaces," pp. 63-74 in Proceedings of the International Symposium on Surface Contamination, Gatlinburg, Tenn., June 1964, ed. by B. R. Fish, Pergamon, New York (1967).
15. U.S. Nuclear Regulatory Commission, Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants, WASH-1400 (NUREG-75/014) (October 1975).
16. J. W. Healy, Surface Contamination: Decision Levels, Los Alamos Scientific Laboratory, LA-4558-MS (September 1971).
17. M. Corn, "Adhesion of Particles," Aerosol Science, ed. by C. N. Davies, Academic, New York (1966).
18. C. N. Davies, "Deposition from Moving Aerosols," Aerosol Science, ed. by C. N. Davies, Academic, New York (1966).
19. C. N. Davies, "The Sedimentation of Small Suspended Solids," p. 25 in Symposium on Particle Size Analysis, Institution of Chemical Engineers and Society of Chemical Industry, Feb. 4, 1947 (Trans. Inst. Chem. Eng. Suppl. 25, 25-39 1947).
20. C. N. Davies, "Definitive Equations for the Fluid Resistance of Spheres," Proc. Phys. Soc. (London) 57, 259 (1945).
21. J. D. Iversen, J. B. Pollack, R. Greeley, and B. R. White, "Saltation Threshold on Mars: The Effect of Interparticle Force, Surface Roughness, and Low Atmospheric Density," Icarus 29, 381 (1976).
22. J. D. Iversen, R. Greeley, and J. B. Pollack, "Windblown Dust on Earth, Mars, and Venus," J. Atmos. Sci. 33, 2425 (1976).
23. L. D. Cloutman, C. W. Hirt, and N. C. Romero, SOLA-ICE: A Numerical Solution Algorithm for Transient Compressible Fluid Flows, Los Alamos Scientific Laboratory, LA-6236 (July 1976).
24. P. M. Morse and H. Feshback, Methods of Theoretical Physics, McGraw-Hill Book Co., New York, 1953. See particularly Chapter 5 of Part 1, and pp. 1292-1295 of Part 2 of the 3rd edition.

25. D. W. Marquardt, "An Algorithm for Least-Squares Estimation of Non-linear Parameters," *J. Soc. Ind. Appl. Math.* 11, 431 (1963).
26. D. W. Marquardt, Least-Squares Estimation of Nonlinear Parameters (NLIN), SHARE Program Library, SDA 3094 01 (Aug. 15, 1966).
27. J. Aitchison and J. A. C. Brown, The Lognormal Distribution, Cambridge University Press, New York, 1957.



INTERIM DISTRIBUTION

- 1-3. W. Davis, Jr.
4. D. E. Ferguson
5. E. J. Frederick
6. L. J. Holloway
7. A. L. Lotts
8. C. D. Scott
9. C. H. Shappert
10. V.C.A. Vaughn
11. Laboratory Records, RC
12. Laboratory Records
13. ORNL Patent Section
- 14-15. Technical Information Center, Oak Ridge, Tenn. 37830
16. Office of Assistant Manager, Energy Research and Development
Department of Energy, Oak Ridge Operations Office,
Oak Ridge, TN 37830