

322
2-21-78

LA-6923

(ISPO-9)

YC-15 & Suppl

Sh. 1852

UC-15

Issued: January 1978

MASTER

Nondestructive Assay Methods for Irradiated Nuclear Fuels

S. T. Hsue
T. W. Crane
W. L. Talbert, Jr.
John C. Lee*

*Consultant. University of Michigan, Ann Arbor, MI 48104.



An Affirmative Action/Equal Opportunity Employer

USA
IAEA

PROGRAM FOR
TECHNICAL ASSISTANCE
TO IAEA SAFEGUARDS
Department of Energy
Safeguards & Security

UNITED STATES
DEPARTMENT OF ENERGY
CONTRACT W-7405-ENG. 36

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CONTENTS

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

ABSTRACT	1
I. INTRODUCTION	1
A. Basis and Development of NDA	1
B. Burnup Definition	2
II. GAMMA-SPECTROSCOPY MEASUREMENT	3
A. Choice of Fission Product	3
1. Fission-Yield Variation with Fissionable Nuclide	4
2. Neutron-Capture Cross Section	5
3. Half-Life Relative to Irradiation Period	5
B. Migration	5
1. ^{85}Zr , ^{144}Ce - ^{144}Pr , and ^{184}Eu	5
2. ^{106}Ru - ^{106}Rh	5
3. ^{134}Cs and ^{137}Cs	5
C. Attenuation	6
1. Fuel Pin	6
2. Fuel Assembly	6
D. Absolute Activity Measurement	7
1. ^{85}Zr	8
2. ^{106}Ru - ^{106}Rh	8
3. ^{137}Cs	9
4. ^{144}Ce - ^{144}Pr	9
E. Activity Ratio Measurement	9
1. ^{134}Cs / ^{137}Cs	11
2. ^{184}Eu / ^{137}Cs	14
F. MTR Spent Fuel	14
III. NEUTRON MEASUREMENTS	14
A. Passive Neutron Counting	15
B. Active Interrogation with Isotopic Source	15
1. LWR Spent-Fuel Assay System	15
2. Highly Enriched Spent-Fuel Assay System	16
C. Active Interrogation with an Accelerator	17
1. LWR Spent-Fuel Assay	17
2. Highly Enriched Spent-Fuel Assay	17
D. Slowing-Down Spectrometer	18
E. Neutron Resonance Absorption	18
IV. OTHER MEASUREMENT TECHNIQUES	18
A. Reactivity Measurement	18
B. Calorimetric Measurement	19

V. SUMMARY AND DISCUSSION	19
A. MTR Spent-Fuel Assemblies	19
B. LWR Spent-Fuel Assemblies	19
ACKNOWLEDGMENTS	21
APPENDIX: BURNUP PREDICTION CAPABILITY FOR PWR, BWR, AND CANDU REACTORS	
I. INTRODUCTION	21
II. COMPARISON OF REACTOR TYPES	22
A. PWR	22
B. BWR	22
C. CANDU	22
III. CALCULATIONAL METHODS FOR BURNUP DETERMINATION	23
IV. EXPERIMENTAL METHODS FOR BURNUP DETERMINATIONS	24
A. Burnup Distribution	24
B. Power Distribution	24
V. ACCURACY IN BURNUP PREDICTIONS	25
A. PWR	25
1. Burnup Distribution	25
2. Power Distribution	25
3. Isotopes Distribution	26
B. BWR	27
1. Burnup Distribution	27
2. Power Distribution	27
3. Isotopes Distribution	27
C. CANDU	27
1. Burnup Distribution	27
2. Power Distribution	28
3. Isotopes Distribution	28
D. Summary	28
VI. CONCLUDING REMARKS	28
REFERENCES	29

FIGURES

1.	Diametral isotopic distributions of ^{106}Rh , ^{137}Cs , and ^{95}Zr for a FBR fuel rod.	6
2.	Differences in per cent of ^{137}Cs activity measured from a fuel rod with and without radial migration.	7
3.	Typical absolute gamma activity measuring equipment with the scanning mechanism.	8
4.	Typical gamma activity ratio measuring equipment.	11
5.	Error (Δ) in the intrinsic calibration method caused by a 20% nonuniform burnup. Point A is the transmission through the assembly at 662-keV gamma, interpolated from various ^{134}Cs gamma-ray peaks. Point B is transmission from actual ^{137}Cs activity distribution.	13
6.	Neutrons per second from ^{239}Pu , ^{240}Pu , ^{242}Cm , and ^{244}Cm isotopes at a burnup of 26 884 MWD/MTU. The total number of neutrons includes contributions from the other uranium, plutonium, and americium isotopes of the Trino reactor fuel.	15
7.	Total number of neutrons per second vs burnup at discharge and after 2 yr cooling for the Trino reactor fuel.	15
8.	Conceptual design of an LWR fuel assembly assay system.	16
9.	Irradiation region of the radium (γ, n) beryllium assay system for measuring ^{235}U content in irradiated Rover fuel rod tubes.	17

TABLES

I.	RADIOACTIVE FISSION ISOTOPES FOR BURNUP MONITORING	4
II.	STANDARD ERRORS OF BURNUP OR Pu/U RATIO FROM NONDESTRUCTIVE MEASUREMENT OF ^{137}Cs ACTIVITY	10
III.	STANDARD ERRORS OF BURNUP OR Pu/U RATIO FROM NONDESTRUCTIVE MEASUREMENT OF $^{136}\text{Cs}/^{137}\text{Cs}$ ACTIVITY RATIO	12
IV.	SUMMARY OF NDA TECHNIQUES ON SPENT FUEL	20
A-I.	FUEL BURNUP PREDICTION ACCURACY	26

NONDESTRUCTIVE ASSAY METHODS FOR IRRADIATED NUCLEAR FUELS

by

**S. T. Hsue, T. W. Crane,
W. L. Talbert, Jr., and John C. Lee**

ABSTRACT

This report is a review of the status of nondestructive assay (NDA) methods used to determine burnup and fissile content of irradiated nuclear fuels.

The gamma-spectroscopy method measures gamma activities of certain fission products that are proportional to the burnup. Problems associated with this method are migration of the fission products and gamma-ray attenuation through the relatively dense fuel material. The attenuation correction is complicated by generally unknown activity distributions within the assemblies.

The neutron methods, which usually involve active interrogation and prompt or delayed signal counting, are designed to assay the fissile content of the spent-fuel elements. Systems to assay highly enriched spent-fuel assemblies have been tested extensively. Feasibility studies have been reported of systems to assay light-water reactor spent-fuel assemblies. The slowing-down spectrometer and neutron resonance absorption methods can distinguish between the uranium and plutonium fissile contents, but they are limited to the assay of individual rods.

We have summarized the status of NDA techniques for spent-fuel assay and present some subjects in need of further investigation. Accuracy of the burnup calculations for power reactors is also reviewed.

I. INTRODUCTION

A. Basis and Development of NDA

Nondestructive assay (NDA) methods used to determine burnup and fissile content of irradiated nuclear fuels are needed to safeguard against diversion of fissile materials to illegal weapon use. A capability for nondestructive assay of individual fuel assemblies is particularly important in view of

the present trend of delay and cancellation in the construction of fuel reprocessing facilities. Because spent fuels are a major source of plutonium, measurement capability by the International Atomic Energy Agency (IAEA) is essential for effective international safeguards. Such assay capability can provide fissile inventory on irradiated fuel, either stored or shipped, for reprocessing. NDA can improve reprocessing plant accountability information before fuel dissolution and thereby enhance

operational efficiency and overall safeguards for the nuclear fuel cycle.

The inspection agency and the reprocessing plant have different viewpoints on acceptable assay systems. From the inspector's point of view, the preferred NDA method should use portable equipment for rapid and reasonably accurate assays. For reprocessing plants, however, a method is wanted that approaches the accuracy obtainable with radiochemical or mass-spectrometric destructive analyses, and that can separate uranium and plutonium fissile content; equipment portability is less important.

In this review, we assume that the irradiated fuel assembly to be assayed can be isolated from other assemblies in storage. Assay in a storage pool without isolation capability is outside the scope of this review.

The last comprehensive review on this subject was by Edwards¹ in 1968. Since then there has been substantial development of NDA methods and vast improvement in instrumentation. A review on gamma-spectroscopy NDA techniques was reported by Dragnev² in 1974. Our review, which includes passive and active neutron techniques and gamma-spectroscopy assay method, covers studies published through January 1977.

Gamma-spectroscopy measurements and associated difficulties, and activity migration and attenuation are discussed in Sec. II. The neutron measurements, both passive and active interrogation, are reviewed in Sec. III. The reactivity and calorimetric methods are discussed in Sec. IV. The summary and discussions are presented in Sec. V, and in the Appendix, present burnup calculation accuracies are reviewed.

B. Burnup Definition

Because the principal goal of assaying spent fuel is to determine burnup and/or fissile content, definition of burnup is needed. The two common definitions are:

(1) Burnup is the number of fissions per 100 heavy nuclides initially present in fuel.

(2) Burnup is the integrated energy released from the fission of heavy nuclides initially present in fuel.

The first definition is used for dissolved irradiated fuel, and concentrations of a selected fission-product burnup monitor and the heavy nuclide atoms are determined.

The burnup computational relationship is then

$$BU (\%) = 100 \frac{P/Y}{P/Y + H} , \quad (1)$$

in which

BU (%) = per cent fission,

P = atom concentration of fission-product burnup monitor,

Y = effective fractional fission-yield value, and

H = final atom concentration of heavy nuclides (mass \geq 232).

The second definition is used mainly for power reactors, where burnup is expressed in MWD/MTU (megawatt days per metric ton uranium initial). In NDA of spent fuel, this definition is used because heavy nuclides are not determined.

The burnup relationship is

$$\text{Number of fission/MTU} = \frac{N}{Y} . \quad (2)$$

$$BU (\text{MWD/MTU}) = 1.8563 \times 10^{-24} \times E \times \frac{N}{Y} , \quad (3)$$

in which

N = number of atoms of burnup monitor formed during irradiation per metric ton of initial heavy metal,

Y = effective fractional fission-yield value, and

E = effective energy released per fission in MeV.

The two burnup expressions are related by the conversion

$$BU (\text{MWD/MTU}) = 46.977 \times E \times BU (\%) . \quad (4)$$

Both the effective fission yield and the energy released per fission depend on the relative fission contribution from plutonium and uranium.

$$Y = \frac{\sum_f^{235} Y^{235} + \sum_f^{238} Y^{238} + \sum_f^{239} Y^{239} + \sum_f^{241} Y^{241}}{\sum_f^{235} + \sum_f^{238} + \sum_f^{239} + \sum_f^{241}}, \quad (5)$$

and

$$E = \frac{\sum_f^{235} E^{235} + \sum_f^{238} E^{238} + \sum_f^{239} E^{239} + \sum_f^{241} E^{241}}{\sum_f^{235} + \sum_f^{238} + \sum_f^{239} + \sum_f^{241}}, \quad (6)$$

in which

$\sum_f^{(1)}$ = time-averaged macroscopic fission cross section of I = ^{235}U , ^{238}U , ^{239}Pu , and ^{241}Pu ,
 $Y^{(1)}$ = fission yield of isotope I, and
 $E^{(1)}$ = energy released per fission in MeV of isotope I.

Assuming an effective energy release of 202 MeV per fission, a burnup of 1% corresponds to a burnup of 9489 MWD/MTU.

II. GAMMA-SPECTROSCOPY MEASUREMENT

Gamma spectroscopy for determination of burnup of spent fuel has been investigated for a long time. The two NDA methods of gamma-ray assay are the absolute gamma activity measurement and the activity ratio measurement. The latter method was developed during the last several years and is still under intense investigation. Both methods measure


que (ICT). General problems pertaining to all gamma burnup measurements and particular difficulties pertaining to each gamma assay method are discussed later in this section.

A. Choice of Fission Product

A radioactive fission-product burnup monitor should have


- near equal fission yields for the major fissioning nuclides in the fuel,
- low neutron-capture cross sections (including capture by precursors),
- long half-life relative to irradiation period,
- low migration (including precursors) in the fuel, and
- easily revolvable gamma-ray spectra with high-energy gamma rays to minimize attenuation.

The radioactive fission products that satisfy most of these criteria are summarized in Table I. As shown, the ^{90}Zr , ^{106}Ru , ^{137}Cs , and ^{144}Ce isotopes arise directly from the beta decay of precursor fission products, e.g.,




the gamma activity of some selected fission products. The methods do not yield the fissile content directly, but it may be inferred from burnup calculation or from the isotopic correlation tech-

The ^{134}Cs and ^{154}Eu isotopes are shielded nuclides—not direct products of fission. They are formed by (n, γ) reactions on ^{133}Cs and ^{163}Eu , respectively, which are produced in fission



and



These two nuclides, which are used in the activity ratio method to determine burnup, are discussed later in this section.

1. Fission-Yield Variation with Fissionable Nuclide. For effective fission-yield value to be constant with burnup level, the fission-product monitor

TABLE I
RADIOACTIVE FISSION ISOTOPES FOR BURNUP MONITORING

Isotope	Half-Life^a	Thermal Fission Yield (%)^b		Principal Gamma Rays^c	
		²³⁵ U	²³⁹ Pu	Energy (keV)	Branching (%)
⁹⁰ Zr	65.5 d	6.50	5.01	724.18 756.72	44.4 54.6
¹⁰⁶ Ru- ¹⁰⁶ Rh	369. d	0.39	4.48	511.85 621.87 1050.39 1128.07	20.6 9.8 1.5 0.4
¹³⁴ Cs	2.06	6.75 (Yield of ¹³³ Cs)	7.42	569.35 604.73 795.84 801.94 1365.00	15.4 97.6 85.4 8.7 3.3
¹³⁷ Cs	30.12 y	6.26	6.65	661.64	85.0
¹⁴⁴ Ce- ¹⁴⁴ Pr	284.4 d	5.39	3.80	696.49 1489.15 2185.70	1.51 0.29 0.74
¹⁵⁴ Eu	8.6 y	0.164 (Yield of ¹⁵³ Eu)	0.285	591.78 723.31 873.25 996.37 1274.50	4.9 19.7 11.7 10.1 34.7

^aHalf-lives of the isotopes were obtained from ENDF/B-IV Fission-Product Files as reported in Los Alamos Scientific Laboratory report LA-6116-MS (1975).

^bThermal fission yields were obtained from the Atomic Energy of Canada Limited report AECL-4704 (February 1974).

^cGamma-ray energies and branchings were obtained from Nuclear Data Sheets, Oak Ridge National Laboratory.

should have equal fission yields for the major fissioning nuclides in the fuel. If the fission yields are substantially different, the effective fission yield will depend somewhat on the reactor's operating history.

2. Neutron-Capture Cross Section. The neutron-capture cross-section value must be low enough that the ratio of produced fission-product atoms to fission is virtually independent of burnup.

3. Half-Life Relative to Irradiation Period. If the irradiation time is less than the half-life of the fission product, the number of fission-product monitor nuclides formed is approximately proportional to the number of fissions [Eq. (2)]. However, if the irradiation time exceeds the half-life, this relation will not be valid and an irradiation or power history correction will be necessary.

B. Migration

If the fission-product precursors are volatile, they may undergo migration relative to their formation positions in uranium and plutonium fission. Radial migration of precursors generally is much more drastic than axial migration because the radial temperature differential is much larger than the axial for oxide fuel. The following discussions include some postirradiation results from fast breeder reactor (FBR) fuels. We include FBR results because (1) more migration studies have been reported for FBR fuel than for light-water reactor (LWR) fuel, and (2) FBR fuels usually are operated with higher temperatures and can serve as limiting cases for LWR fuels.

1. ^{95}Zr , ^{144}Ce - ^{144}Pr , and ^{154}Eu . Forsyth et al.³ measured the migration of ^{95}Zr and ^{144}Ce in fuel rods irradiated for 3 yr and with fuel centerline temperatures between 1750 and 2050°C. Phillips et al.^{4,5} also studied the migration of ^{95}Zr and ^{144}Ce in FBR fuel rods. Rein⁶ studied the migration of rare earth elements in mixed-oxide FBR fuels. These studies show that apparently ^{95}Zr , ^{144}Ce , and ^{154}Eu do not migrate significantly, either radially or axially relative to the heavy metal.

2. ^{106}Ru - ^{106}Rh . However, ^{106}Ru - ^{106}Rh is volatile, and both radial and axial migrations have been observed.^{3,4} In the radial direction, the ^{106}Rh isotope tends to concentrate around the centerline of the fuel pellet; peripheral-to-center concentration of 1:20 has been observed.⁴

3. ^{134}Cs and ^{137}Cs . The ^{137}Cs migration has been detected in LWR fuel,³ in Canadian Deuterium Uranium (CANDU) fuel,^{7,8} and in FBR fuel.^{4,6,9} The ^{134}Cs migration has been studied mainly with FBR fuel.^{4,5,9}

The ^{134}Cs and ^{137}Cs isotopes tend to migrate toward the cooler regions of the fuel section. In the radial direction, both isotopes migrate toward the cladding; in the axial direction, they tend to concentrate in interpellet gaps. In their study of FBR fuels, Phillips et al.^{4,9} found differences in the relative concentrations of ^{134}Cs and ^{137}Cs as a function of axial positions. The authors attributed these differences to ^{137}Cs migration mainly as the metal, and final ^{134}Cs distribution is the result of migration of either the ^{133}I or ^{133}Xe precursor. The amount of migration seems to depend on temperature, oxygen-to-metal ratio, and fuel density. The higher the oxygen-to-metal ratio, the less migration tends to occur. In their fission-product migration studies on LWR fuels, Forsyth et al.³ found no ^{137}Cs migration at a fuel centerline temperature <1200°C; however, there was migration at a fuel centerline temperature between 1750 and 2050°C. The temperature threshold of the migration effect of ^{137}Cs has not been resolved. Dragnev² proposed a threshold temperature of 1500°C; Hiller¹⁰ suggested 2000°C. Published data on the degree of ^{137}Cs migration vary widely. Peripheral-to-center concentrations of 10:1 have been reported by Forsyth et al.,³ and up to 1000:1 by Bates¹¹ for UO_2 thermal reactor fuels. Figure 1 shows typical diametral isotopic distributions⁴ of ^{137}Cs , ^{106}Rh , and ^{95}Zr , in which the ^{95}Zr distribution represents no migration.

The ^{134}Cs migration for LWR fuel has not been studied and is thus speculative. The ^{134}Cs and ^{137}Cs migrations may be different because the nuclides responsible for the migration are different.




Fig. 1.

Diametral isotopic distributions of ^{106}Rh , ^{137}Cs , and ^{95}Zr for a FBR fuel rod.

C. Attenuation

1. Fuel Pin. Gamma-ray intensities are attenuated as they emerge from the fuel pin. The attenuation depends on gamma-ray energy and on activity distribution within the pins. To minimize the attenuation effect, only relatively high-energy fission-product gamma rays ($E > 500$ keV) are used in the spent-fuel gamma assay. On the other hand, the oxide fuel density is comparatively high (10.9 g/cm³); for the 661-keV gamma ray of ^{137}Cs , the self-attenuation factor within the 1-cm-diam fuel pin is ~ 0.63 , or $\sim 37\%$ of the gamma intensity is attenuated within the pin, assuming a uniform activity distribution.

The attenuation correction is complicated by fracturing and/or formation of center voids in the fuel rods and by the activity distribution within the rods. It is difficult to predict void formation or fuel fracture; the processes depend on the fuel temperature and irradiation history, among other factors. The activity distribution within the rod depends on migration and burnup distribution throughout the irradiation.

Migration of the various radioactive fission-product burnup monitors was discussed in the previous section. The activities of ^{95}Zr , ^{144}Ce , and ^{154}Eu do not migrate relative to the heavy metals, whereas those of ^{106}Ru , ^{106}Rh , ^{134}Cs , and ^{137}Cs have been observed to migrate.

To estimate the activity distribution effect on attenuation correction, assume that ^{137}Cs migrates radially toward the fuel periphery to produce a concentration profile described empirically by

$$A(r) = K e^{-B(R-r)}, \quad (10)$$

where

$A(r)$ = activity per unit length at r ,

K = arbitrary constant,

R = fuel pin radius,

$B = (1/2) \text{arcosh} (A_2/A_1)$,

A_2 = peripheral activity per unit length, and

A_1 = center activity per unit length.

The 662-keV gamma flux values received by a detector from a fuel rod with this activity distribution were calculated by numerical integration and compared with those from a fuel rod containing the same total quantity of the ^{137}Cs activity but homogeneously distributed. The calculation was performed for the collimated case (collimator width $\ll R$) and uncollimated case (collimator width $\sim 2R$). Figure 2 shows a series of curves for fuel rod densities of 10.5 g/cm³ (96% of UO_2 density) and diameters of 0.7, 1.0, 1.3, and 1.6 cm. The degree of activity distribution varies from $A_2/A_1 = 1$ (uniform distribution) to $A_2/A_1 = 100$. The counting rate from the nonuniformly distributed activity is consistently higher. The error from assuming a uniform distribution depends on fuel pin radius and activity distribution within the pin. Radial activity distribution within a rod can be determined by horizontal scanning with narrow collimation in a hot-cell environment, but it will be difficult to determine in field inspection.

2. Fuel Assembly. In measuring spent fuels, there is a distinct advantage in assaying a whole assembly instead of individual fuel pins because the assembly does not have to be taken apart. However,




Fig. 2.

Differences in per cent of ^{137}Cs activity measured from a fuel rod with and without radial migration.

the advantage must be weighed against complications introduced by attenuation through the whole assembly and nonuniform burnup within the assembly. In whole, square-assembly assay, corner measurements are preferable to side measurements. Experience has shown that for side measurements on fuel assemblies, a 30% variation in the 1.60-MeV ^{140}La gamma activity was produced by a 10° angular variation of the collimator-detector axis, but the same angular deviation caused $\sim 1.5\%$ variation in corner measurements.¹²

Because of strong attenuation in the fuel rods, only the rods closest to the corner in front of the collimator contribute significantly to the measured gamma activity. The gamma-ray transmission through a boiling water reactor (BWR) fuel pin (1-cm o.d.) is ~ 0.29 at 661 keV. For an 8-by-8 BWR fuel assembly submerged in water, only $\sim 1\%$ of the

total ^{137}Cs activity of the four central rods is measured. There is a "black-out zone" in the center of the assembly where gamma activity *cannot* be assayed. The same situation prevails for a CANDU bundle and is even more drastic for a pressurized water reactor (PWR) fuel assembly.

A further complication in whole-assembly assay is nonuniform distribution of the flux during irradiation. In a BWR assembly, the rods at the edge of the assembly sometimes experience a higher burnup because they are near the water gap. In a CANDU fuel bundle, similar burnup variations among fuel pins have been found.⁸

It is difficult to measure activity distribution within the assembly. If detailed reactor operation conditions are known, the activity distribution of fission products can be calculated by some burnup computer codes. From the rod-to-rod distribution of the fission-product activity, the assembly attenuation factor can be calculated. Therefore, the accuracy of the attenuation calculation depends critically on the accuracy of the burnup calculation, and is probably the most uncertain factor in the whole-assembly assay.

D. Absolute Activity Measurement

When the number N of burnup monitor atoms formed during irradiation is determined, the burnup can be calculated by Eq. (3). N is related to the gamma-ray intensities by

$$N = \frac{X_i}{k_i \epsilon_i S_i} \frac{e^{\lambda T_c}}{\lambda}, \quad (11)$$

in which

X_i = number in the i th gamma-ray peak observed per unit time,

k_i = number of the i th gamma ray per disintegration,

ϵ_i = absolute detector efficiency at the energy of the gamma-ray peak,

S_i = the effective attenuation at the energy of the gamma-ray peak,

λ = decay constant, and

T_c = cooling time.

In Eq. (11), the k_i and λ depend on the status of the nuclear data; and for these radioactive fission-product monitors, they are generally known to ~ 1 to 2%. The X_i can be measured to 1% or better. The attenuation factor S_i may be determined fairly accurately for a single rod if diametral rod scan is performed; the uncertainty in S_i is considerably larger for a whole assembly. The most crucial and difficult factor to determine is the absolute detector efficiency ϵ_i , which depends on the measurement geometry, the collimator, and the intrinsic efficiency of the detector. The absolute efficiency may be determined by a calibration source of known total activity. The geometries for assay and efficiency calibration must be identical.

In a well-controlled hot-cell environment, the absolute activity measurement can be fairly accurate in a burnup determination. The accuracy, advantages, and disadvantages of each fission-product monitor are discussed below. Accuracy can be achieved only under well-controlled geometry, which normally cannot be achieved in field inspection. The absolute activity method is probably limited to reprocessing plants. A typical experimental arrangement⁴ is shown in Fig. 3.

1. ^{95}Zr . The fission yield of ^{95}Zr is relatively constant for ^{238}U and ^{239}Pu fission. Also the neutron absorption cross section is low and the activity does not seem to migrate. However, its relatively short half-life (65 days) limits its use as a burnup monitor to cases of not excessively long irradiation and cooling times.

Zirconium-95 ($T_{1/2} = 65.5$ days) decays to ^{96}Nb ($T_{1/2} = 35.15$ days) and the two nuclides are in secular equilibrium if the production rate of ^{95}Zr is constant. The ratio of ^{95}Zr to ^{96}Nb is a constant during irradiation, but it drops to a different constant after a long cooling time. For a cooling time < 300 days, the ratio can be used to determine the cooling time,^{2,13,14} and accuracies within 7% have been achieved.¹⁶

2. ^{106}Ru - ^{106}Rh . Although the low neutron absorption cross section and the 1-yr half-life of ^{106}Ru make it a more suitable candidate as a burnup monitor, it has been known to migrate.^{3,4} The thermal neutron fission yield from ^{239}Pu is ~ 11 times that from ^{238}U .




Fig. 3.
Typical absolute gamma activity measuring equipment with the scanning mechanism.

Forsyth and Blackadder¹⁶ explored this drastic difference in fission yields to determine relative fission events in ^{238}U and ^{239}Pu . Agreement was obtained between experimental results and calculation, but careful irradiation history and decay correction were necessary to deduce the percentage of ^{239}Pu fission. For spent fuels that have been irradiated for a relatively long time (e.g., 3 yr), the uncertainty caused by irradiation history and decay corrections can be substantial. Previous studies also showed a substantial deviation between nondestructive and destructive determinations of the amount of ^{106}Ru - ^{106}Rh in Trino reactor fuels¹⁷ (7.7%) and Dodewaard reactor fuels¹⁸ (14.9%).

3. ^{137}Cs . Cesium-137 is often considered the most suitable fission product for burnup measurements because (1) it has a relatively long half-life, (2) its neutron absorption cross sections (and those of its precursors) are negligible, and (3) it has approximately the same yields for both ^{235}U and ^{239}Pu . The 30-yr half-life of ^{137}Cs makes the power history correction unnecessary.

The major drawback of ^{137}Cs as a burnup monitor is that it migrates at high temperature and at low oxygen-to-metal ratio. Axial cesium migration can be checked by comparing ^{137}Cs with nonmigrating isotopes, for example, zirconium or praseodymium. The radial cesium migration introduces uncertainty in the attenuation correction. Also, in case of clad failure, ^{137}Cs cannot be used as a burnup monitor.

The results of several studies on the use of ^{137}Cs as a burnup monitor of spent fuels either in pellet or total assembly form are summarized in Table II. Burnup is determined by mass-spectroscopy measurements unless otherwise specified. Table II shows that with fuel rods, NDA of ^{137}Cs activity can determine burnup to an accuracy of 1 to 4% within a wide burnup range. When the whole assembly or bundle is assayed, the ^{137}Cs activity can determine burnup from 2 to 6%. Because the Trino, Garigliano, and Bohunice reactors have been studied intensively, ^{137}Cs activity distributions within their assemblies or bundles (and therefore the attenuation factors) can be calculated accurately. The uncertainties of the whole-assembly assay for other reactor fuels depend largely on the uncertainties of the attenuation calculation. These uncertainties may be substantially larger than 6%. In the assembly assays, measurements were performed at four corners of the assembly and at eight or nine levels. The ^{137}Cs activities at all the measuring points were totaled to obtain an integral value for the fuel assembly.

4. $^{144}\text{Ce-144Pr}$. The $^{144}\text{Ce-144Pr}$ activity has a distinct advantage because it and its precursors do not migrate relative to the heavy metals. In addition, ^{144}Pr emits a 2.18-MeV gamma radiation. The relatively high energy of this gamma radiation makes an accurate attenuation factor calculation less important. Nondestructive determinations of the amount of $^{144}\text{Ce-144Pr}$, therefore, are generally

quite accurate compared with destructive analyses (within 1.7% in Trino fuel pellets¹⁷).

These advantages must be weighed against its relatively short half-life of 284 days, and the somewhat different fission yields of ^{235}U and ^{239}Pu (Table I). These two drawbacks require a careful power history correction. In their study of $^{144}\text{Ce-144Pr}$ as a fission monitor for CANDU reactor fuels, Chen et al.²⁴ found that the overall uncertainty in burnup determination can be as high as +30 to -20%, relative to calculated values for a 500-day irradiation period. The uncertainty decreases (± 12 to 15%) for a shorter irradiation period (~ 300 days).

E. Activity Ratio Measurement

Activity ratios have been suggested^{18,25} for use as burnup monitors. Several experiments since 1971 have explored this possibility and development is continuing. If we assume that the flux is constant during irradiation, the activity from a direct fission product N_D formed (such as ^{137}Cs), and that from neutron capture of fission products N_I (such as ^{134}Cs) are respectively proportional to [see Eqs. (7) and (8)]

$$N_D \propto \Sigma_f \cdot (\phi T) \text{ and} \quad (12)$$

$$N_I \propto \Sigma_f \cdot \sigma(n, \gamma) \cdot (\phi T)^2 \quad , \quad (13)$$

in which

ϕ = spectrum and time-averaged neutron flux,

Σ_f = spectrum and time-averaged fission cross section,

$\sigma(n, \gamma)$ = spectrum and time-averaged neutron-capture cross section of the fission product,

and

T = irradiation time.

Equations (12) and (13) show that the N_I/N_D ratio is also proportional to (ϕT) and, in principle, can be used as a burnup monitor. The activity ratios that have been explored up to now are $^{134}\text{Cs}/^{137}\text{Cs}$ and $^{144}\text{Eu}/^{137}\text{Cs}$.

TABLE II

STANDARD ERRORS OF BURNUP OR Pu/U RATIO FROM NONDESTRUCTIVE MEASUREMENT OF ^{137}Cs ACTIVITY

Reactor (Type) Fuel Cycle	Correlation Between	Standard Error ^a (%)	Burnup Range (MWD/MTU)	Source Configuration	Reference No.
Trino (PWR) 2nd Cycle	Bu, ^{137}Cs	4.1	15 000-28 000	Rod	19
Garigliano (BWR)	Bu, ^{137}Cs	1.5	9 000-12 000	Rod	20
Trino (PWR) 2nd Cycle	Bu, ^b ^{137}Cs <u>Pu</u> , ^b ^{137}Cs U	2.3 1.8	19 000-22 000	Assembly ^c	21-22
Trino (PWR) 3rd Cycle	Bu, ^b ^{137}Cs	2.5	19 700-28 700	Assembly ^c	23
Garigliano (BWR)	Bu, ^b ^{137}Cs	1.5	7 000-18 500	Assembly ^c	12
Bohunice (CANDU-type)	Bu, ^{137}Cs	6	1 800-8 000	Bundle	15

^aThe standard error is calculated, whenever possible, by fitting the data to a linear regression equation $Y = a + bx$. The standard error about the regression =

$$\sqrt{\sum_{i=1}^n (y_i - Y_i)^2 / (n - 2)}$$

where y = experimental values, Y = values predicted from the regression line, and n = number of observations.

^bBurnup and Pu/U values from calculation.

^cAssemblies were measured at eight to nine levels and four corners, and the ^{137}Cs activity was summed.

For an absolute activity measurement, absolute detector efficiency must be known, and the measurement must be performed under strictly controlled geometry. The activity ratio measurement, however, is less sensitive to the geometrical arrangement and requires only that the relative detector efficiency be known. This distinct advantage makes the activity ratio measurement much more suitable for use in field inspection. However, a disadvantage is that effective fission yields of the activity ratios

are unknown. Thus, to deduce burnup, correlations between burnup and activity ratios must be determined empirically. Correlations have been observed between the burnup or Pu/U mass ratio and the $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratio. There are also indications of a possible correlation with the $^{154}\text{Eu}/^{137}\text{Cs}$ activity ratio. These correlations are rather limited and it is doubtful whether such simple correlations exist for BWR fuels. To obtain burnup or plutonium content

of fuel assemblies, correlations should be determined for each irradiation batch, or at least for each reactor. The status of the correlations will be reviewed later.

A recent improvement in the activity ratio measurement²⁸⁻²⁸ is to introduce an intrinsic calibration, where measured intensity ratios for gamma rays of a given isotope are compared with established branching ratios. Using these data, an overall relative efficiency curve that includes mass attenuation and detector efficiency can be determined. This curve can be used to determine the activity ratios of two different isotopes. The advantage of this method is its simplicity; all necessary information to determine the activity ratio (relative efficiency and cooling time) is contained in a single gamma-spectrum measurement. However, this method relies on a fundamental assumption that may or may not be valid in an actual situation. It is accurate only if the measured isotopes (^{134}Cs , ^{137}Cs , ^{134}Eu) have the same spatial distribution within the assembly. The inaccuracy caused by different isotopic spatial distributions may be significant.

A typical experimental arrangement is shown in Fig. 4 (from Ref. 14). Other activity ratios could also be used, such as the $^{106}\text{Rh}/^{144}\text{Pr}$ suggested in Ref. 13. However, there is no experimental support for such a correlation, and this ratio may be sensitive to migration effects (see ^{106}Rh profile in Fig. 1).

1. $^{134}\text{Cs}/^{137}\text{Cs}$. The results of recent studies of the $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratio as a burnup monitor are summarized in Table III. Table III shows that for PWR fuels, correlations apparently exist between burnup or Pu/U mass ratio and $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratio (within 1 to 4%) for Trino and Senec reactor spent fuels. The correlation is far from established for BWR fuels. With Garigliano reactor fuel assemblies,¹² no correlation can be established; with JPDR-I reactor fuel rods,^{29,30} the correlation separates into two straight lines, depending on the upper or lower parts of the fuel, and for the two portions, the interceptions differ by 20%.

The latter study also found that the $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratio is sensitive to the epithermal-to-thermal flux ratio. The correlations for the two segments can be made to agree better if the appropriate flux correction is made. This is not surprising consider-




Fig. 4.
Typical gamma activity ratio measuring equipment.

ing that the thermal-neutron-capture cross section and resonance integral of ^{133}Cs are 30 and 450 barns, respectively, so that the resonance capture reaction is much more probable than thermal-neutron capture. In contrast, the formation of ^{137}Cs depends predominantly on the thermal flux.

It should be emphasized that because the Trino and Bohunice reactors have been studied well, and their attenuation factors can be calculated accurately, standard errors are small (1 to 7%).

Some theoretical studies^{12,22,31} have been made to evaluate the correlations between burnup or Pu/U mass ratio and $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratios. Reactor parameters that seem to influence the correlations are fuel enrichment, power history, void fraction (BWR), and moderator-to-fuel ratio.

TABLE III

STANDARD ERRORS OF BURNUP OR Pu/U RATIO FROM NONDESTRUCTIVE MEASUREMENT OF $^{134}\text{Cs}/^{137}\text{Cs}$ ACTIVITY RATIO

Reactor (Type) Fuel Cycle	Correlation Between	Standard Error ^a (%)	Burnup Range (MWD/MTU)	Source Configuration	Reference No.
Sena (PWR) 1st cycle	^{137}Cs , $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	3	12 600-13 150	Rod	32
Sena (PWR) 2nd cycle	^{137}Cs , $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	13 ^b	18 600-20 300	Rod	32
Sena (PWR) 1st cycle	Bu, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	3.7	12 600-13 150	Assembly midpoint	27
Trino (PWR) 2nd cycle	Bu, ^c $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	1.1	18 500-22 500	Assembly ^d	21-22
	$\frac{\text{Pu}}{\text{U}}$, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	1.2			
Trino (PWR) 3rd cycle	$\frac{\text{Pu}}{\text{U}}$, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	2.1	19 700-28 700	Assembly ^d	23
Dodewaard (BWR)	Bu, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	8.5	6 000-17 000	Rod	18
JDPR-I (BWR)	Bu, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	upper and lower segments differ by 20%	1 900-7 000	Rod	29-30
Garigliano (BWR)	$\frac{\text{Pu}}{\text{U}}$, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	no correlation ^e	7 000-18 500	Assembly ^d	12
Bohunice (CANDU-Type)	Bu, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	5-7.6	1 800-8 000	Bundle	15
NPD (CANDU)	Bu, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	1-7.3	6 000-10 150	Bundle midpoint	33
PRTR ^f	Bu, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	2.0	9 000-14 000	Rod	2
	$\frac{\text{Pu}}{\text{U}}$, $\frac{^{134}\text{Cs}}{^{137}\text{Cs}}$	1.3			

^aThe standard error is calculated, whenever possible, by fitting the data to a linear regression equation $Y = a + bx$. The standard error about the regression =

$$\sqrt{\sum_{i=1}^n (y_i - \bar{y}_i)^2 / (n - 2)}$$

where y = experimental values, \bar{y} = values predicted from the regression line, and n = number of observations.

^bThe error quoted is systematic error. This deviation is attributed to the lack of power history correction.

^cCalculated burnup and Pu/U ratios.

^dAssemblies were assayed at eight to nine levels and four corners, and the ^{134}Cs and ^{137}Cs activity ratios were summed.

^eIf power history correction is made, the standard error is 3.9% (Ref. 23).

^fPlutonium recycle test reactor with naturally enriched uranium oxide fuel.

Because the half-life of ^{134}Cs is 2.06 yr, a correction for the decay, based on operating power history, is necessary for long irradiation. The correction can be applied relatively simply by using weighted burnup,²⁷ or fairly elaborately by using burnup codes such as FLARE or PDQ. Perhaps a correction method using the transmutation equation would be sufficiently accurate and simple to apply.

The possible error in the intrinsic calibration method is considered next. This method relies on a fundamental assumption that mass attenuations of ^{134}Cs and ^{137}Cs gamma rays through the assembly are related by the same energy-dependent function. This assumption is correct only if the measured isotopes (^{134}Cs , ^{137}Cs) have the same spatial distribution within the assembly. Different isotopic spatial distributions may be caused by nonuniform burnup across the assembly and/or by different migrations within the fuel pins. It is generally accepted that ^{137}Cs activity is proportional to burnup. If the $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratio is also proportional to burnup, then the ^{134}Cs activity should be proportional to the square of the ^{137}Cs activity. Thus, for non-uniform burnup, the ^{134}Cs and ^{137}Cs isotopes would have different distributions across the assembly even if there is no migration.

To estimate the possible uncertainty caused by different activity distributions in the intrinsic calibration method, the following calculations were performed for an 8-by-8 BWR assembly. The corner rods were assumed to have 20% higher burnup than the central rods, whereas burnups of the other rods were linearly interpolated. (Postirradiation examinations show burnup variations as high as 40%.²⁰) A Monte Carlo gamma transport code was used to calculate the gamma-ray transmission from the assembly. The collimator, viewing the corner of the assembly, was considered to be perpendicular to the length of the fuel assembly, which was submerged in water. The transmission is defined as the ratio of the number of gamma rays that reach the detector at their emitted energy to the number of gamma rays from the fuel assembly with a trajectory that would pass through the collimator and reach the detector. The ^{137}Cs activities were distributed proportionally to the burnups within the assembly (Fig. 5).

From the calculated transmissions for various ^{134}Cs gamma-ray peaks (two are shown as squares in




Fig. 5.

Error (Δ) in the intrinsic calibration method caused by a 20% nonuniform burnup. Point A is the transmission through the assembly at 662-keV gamma, interpolated from various ^{134}Cs gamma-ray peaks. Point B is transmission from actual ^{137}Cs activity distribution.

the lower half of Fig. 5), the transmission at the 662-keV gamma was interpolated to be 0.233 ± 0.002 (point A in Fig. 5). However, the transmission at the same energy from the ^{137}Cs activity distribution was calculated to be 0.201 ± 0.002 (point B). The difference in these transmissions, $16.1 \pm 1.5\%$, is the error expected in the intrinsic calibration method. This error is the result of a 20% nonuniform burnup across the assembly; the higher the nonuniformity, the larger the error.

The possible error in the intrinsic calibration method was also calculated for a collimator angle of 45° to the length of the fuel assembly. Under these conditions, assuming a 20% nonuniform burnup

across the assembly, the intrinsic calibration method could be in error by 16.8%. Clearly, corrections for nonuniform burnup and migration must be applied to the intrinsic calibration method.

2. $^{154}\text{Eu}/^{137}\text{Cs}$. To avoid complications caused by decay during irradiation or power history correction, the $^{154}\text{Eu}/^{137}\text{Cs}$ activity ratio can be used. The 8.6-yr half-life of ^{154}Eu makes power history a minor, or negligible, correction. However, the thermal neutron-capture cross section of ^{154}Eu is relatively high (1500 b) and this activity ratio is calculated to be proportional only up to 20 000 MWD/MTU burnup.^{22,23} Because the fission yield of ^{154}Eu is much smaller than that of ^{133}Cs , the ^{154}Eu activity can be measured only after a long cooling time.

Only a few experimental points exist for the burnup vs $^{154}\text{Eu}/^{137}\text{Cs}$ activity ratio correlation. For the Trino (PWR) assembly assay, correlations were found for burnup vs $^{154}\text{Eu}/^{137}\text{Cs}$ (within 5.5%), and for Pu/U vs $^{154}\text{Eu}/^{137}\text{Cs}$ (within 2.5%).²² For the JPDR-I (BWR) fuel,^{28,30} the burnup vs $^{154}\text{Eu}/^{137}\text{Cs}$ correlation again separated into two straight lines, corresponding to the upper and lower halves of the fuel pin, indicating that this correlation is also sensitive to the void fraction.

F. MTR Spent Fuel

Burnup determination of materials testing reactor (MTR) assemblies is simpler than for LWR assemblies because (1) practically only ^{235}U fissions take place, (2) the maximum fuel temperatures during irradiation are relatively low; there is probably little or no migration of fission products, and (3) attenuation correction can be taken into account more accurately. However, the irradiation histories are usually more irregular for these research reactors than for power reactors. This makes power history correction more complicated.

Since the early work by Rasmussen et al.,³⁴ there have been several experiments on MTR spent fuel. Tzou and Yang,³⁵ who used the absolute ^{137}Cs activity measurement method and a somewhat different approach to power history correction, found an ~1% uncertainty in burnup determination. Using the activity ratio method, Beets et al.³⁸ measured 21 MTR fuel assemblies and found that

the calculated and measured $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratios had a correlation factor of 0.91 and a relative error of 9%. Dragnev et al.³⁶ measured 16 MTR fuel assemblies and found that between declared burnups and burnups from the measured $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratios the differences ranged from 0 to 22.7%, with an average difference of 4.9%. In the last two experiments mentioned, the assemblies were measured at midassembly only; the possible axial burnup variation from one assembly to another may be responsible for some error in the burnup determination.

The absorption measurement method may also be used to determine MTR assembly burnup. Kreyger et al.³⁷ demonstrated that by measuring the 145-keV gamma-ray absorption, the burnup determinations of MTR fuel elements can be accurate to more than 2% of the initial uranium content.

III. NEUTRON MEASUREMENTS

Neutron counting has several advantages over gamma-ray assay of spent fuels. Active neutron interrogation offers the possibility of assaying the spent-fuel fissile content directly, whereas in the gamma-ray assay, the fissile content can only be inferred. Fast neutrons have relatively high penetrability in nuclear fuel material, thus attenuation correction is less critical. Also, because the half-lives of uranium and plutonium isotopes are relatively long, there is little or no reason to correct for decays during irradiation or cooling periods of the fuel. Neutron assay can be made immediately after discharge, but gamma-ray assay can be made only after a certain cooling period.

However, neutron assay involves gross counting and it is impossible to say which isotope is the source of the measured neutrons. Neutron counting is also influenced by the presence of moderators and neutron poisons that may cause errors in the assay. Furthermore, the generic active neutron interrogation system is heavily shielded and therefore not easily portable. Thermal-neutron interrogation requires self-shielding corrections that may or may not be determined easily.

A. Passive Neutron Counting

Irradiated fuels normally have a relatively high neutron emission rate (10^7 to 10^8 n/s per assembly), but passive neutron counting has not been actively considered as a possible method to determine burnup. The neutron emission rate depends on the quantity of curium isotopes in the fuel. A recent postirradiation examination of Trino fuel¹⁹ shows that the ^{242}Cm and ^{244}Cm activities are proportional to burnup from 13 000 to 27 000 MWD/MTU.

With uranium, plutonium, and americium isotopic compositions from this study,¹⁹ neutron yields from each isotope can be calculated. Figure 6 shows neutron yield at various cooling times for a relatively high burnup fuel sample. At discharge, most of the passive neutrons originate from the

^{242}Cm isotope; 2 yr after discharge, most of the neutrons originate from the ^{244}Cm isotope. Figure 7 shows total neutrons emitted per second as a function of burnup. At discharge, total neutrons emitted per second is a linear function of burnup from 13 000 to 27 000 MWD/MTU. After 2 yr cooling, the total neutrons emitted per second are proportional to burnup from 18 000 to 27 000 MWD/MTU. For burnups <18 000 MWD/MTU, the contributions from ^{240}Pu and ^{238}Pu isotopes are significant. After >2 yr cooling, the neutron emission rate is still proportional to the burnup over the same range.

Passive neutron assay can be used as a consistency check over the burnup range of 18 000 to 27 000 MWD/MTU for various cooling times, and over a wider burnup range at discharge. This conclusion is drawn from the Trino reactor fuel; it is not certain however that the number of curium isotope atoms is proportional to burnup for other reactor fuels. The passive neutron assay of burnup is a promising alternative to gamma-ray assay and should be investigated further. If the assay is to be performed under water, neutron multiplication effects may be significant.




Fig. 6.

Neutrons per second from ^{238}Pu , ^{240}Pu , ^{242}Cm , and ^{244}Cm isotopes at a burnup of 26 884 MWD/MTU. The total number of neutrons includes contributions from the other uranium, plutonium, and americium isotopes of the Trino reactor fuel.

B. Active Interrogation with Isotopic Source

1. LWR Spent-Fuel Assay System. Gozani^{38,39} reported a feasibility study on an assay system using the layout shown in Fig. 8. The system consists of




Fig. 7.
Total number of neutrons per second vs burnup at discharge and after 2 yr cooling for the Trino reactor fuel.




Fig. 8.
Conceptual design of an LWR fuel assembly assay system.

either a ^{252}Cf or an antimony-beryllium neutron source that can be shuffled for prompt- and delayed-neutron counting.

The main (acceptable) conclusion of this study is that an assay system can be built to determine the fissile content of LWR spent fuel; there are, however, reasons to disagree with some specific points of the study. With ^{252}Cf interrogation and prompt-neutron counting, the detectors near the source should be deleted because they reduce the fission-to-source-neutron discrimination ratio. Measurements have shown⁴⁰ that BF_3 neutron detectors are not suitable for use in the high neutron fields of either the spent fuel or the interrogation source in that they do not recover rapidly for delayed-neutron counting. The possibility of measuring uranium and plutonium fissile contents separately by using either the delayed-to-prompt ratios or the gadolinium filtered and unfiltered measurements, could be difficult to achieve in practice.

This approach, or a modified version, can probably be used to assay the fissile content of spent fuel with reasonable accuracy; for this purpose, prompt-neutron counting has the advantage of the

better signal-to-background ratio. A similar system using prompt-neutron response to determine fissile content by interrogating with rhodium-deuterium neutron sources was proposed by Ragan et al.⁴¹ for FBR fuel. They concluded that the system could assay the fissile content with 1 to 5% uncertainty. However, this type of LWR spent-fuel assay system has not been built. Baumung et al.⁴² reported a similar system for assay of fresh fuel assemblies that combines irradiation by an antimony-beryllium neutron source, fuel bundle rotation, and prompt-neutron detection.

2. Highly Enriched Spent-Fuel Assay System.

Highly enriched spent fuels are simpler to assay because of the higher fissile content (mostly ^{235}U), and the reduced neutron background.

Augustson et al.⁴³ designed and operated an automated system for the slightly irradiated, 93%-enriched Rover fuel accumulated from the U.S. Nuclear Rocket Propulsion program. Up to seven fuel rods were put in cardboard tubes and assayed by active neutron interrogation. The assay system, shown in Fig. 9, consisted of two radium-beryllium sources and ^4He gas proportional counters for




Fig. 9.

Irradiation region of the radium (γ, n) beryllium assay system for measuring ^{235}U content in irradiated Rover fuel rod tubes.

prompt-neutron detection. To correct for the neutron thermalization caused by the cardboard tubes, two fission chambers were used as flux monitors near the sample. Tests of the axial and radial material distributions within the assay tube showed that the response was quite independent of material distributions. The assay system was calibrated with a series of seven standards identical in geometry and packaging to the unknown tubes. A 150-s assay showed a typical 2.1% (2σ) uncertainty in the ^{235}U mass. Numerous field tests were run in which more than 2 000 tubes were assayed. The total assayed fissile content amounted to 99.44% of the book value, indicating little or no bias. For higher burnup fuels, the system may need some slight modification to shield the detectors better and to measure the self-interrogation from the fission-product gamma rays.

Filss^{44,45} reported a system that can assay high-temperature gas-cooled reactor (HTGR) spent fuels in 6-cm-diam spheres. This system used two antimony-beryllium sources for active neutron interrogation. Fission and source neutrons were separated by transport differences in boron-poisoned water. For well-characterized samples like the HTGR spheres, thermal interrogation was

recommended. The self-shielding effect could be determined by a series of standards. The uncertainty in the fissile content determination of this system was 4%.

C. Active Interrogation with an Accelerator

1. LWR Spent-Fuel Assay. No experiment has been performed using accelerators to assay LWR spent-fuel assemblies. However, a study was made by Weisbin et al.⁴⁶ using 200- to 500-keV neutrons produced from a Van de Graaff accelerator to interrogate *fresh* fuel assemblies. A steel reflector around the assembly flattened the ^{235}U spatial response within the assembly. Both prompt and delayed signals were measured. For a 30-min assay, the ^{235}U content of an entire fuel assembly could be measured with an overall 2% uncertainty. The possibility of differentiating the ^{235}U and ^{239}Pu fissile contents by a prompt-to-delayed-response ratio was mentioned but not demonstrated. The same assay technique, with some simple modifications, such as adding lead shielding around the steel reflector, should be applicable to the assay of an irradiated fuel assembly.

2. Highly Enriched Spent-Fuel Assay. Augustson et al.⁴⁷ performed an experiment to assay the fissile content of MTR-type spent fuel using the delayed-neutron yield technique. A Cockcroft-Walton accelerator producing 14-MeV neutrons by the (D,T) reaction was used for interrogation. The neutron spectrum was moderated by 21.5 cm of lead (mainly from the shipping cask) to enhance fissile response compared with fertile materials. A correction was made for the delayed-neutron response from the fertile isotopes. A fresh fuel element was used as the calibration standard. Over a wide range of loadings (250 to 340 g), the assay was accurate to within 2% with a measurement standard deviation of 0.6%.

Rotter⁴⁸ has reported an assay method using a sealed pulsed-neutron tube for interrogation. The shape of the prompt-neutron response (first and second time moments measured 100 to 600 μs after pulsing) could be used to discern poison and the fissile content in the fuel element. For highly

enriched spent fuels, the fissile content was determined to within an accuracy of ~4% and the poison content to within 7%. Rotter claimed that the assay method could be used on LWR fuel elements with little or no modification.

D. Slowing-Down Spectrometer

A slowing-down spectrometer (SDS) has been proposed^{49,50} for assaying spent-fuel rods. Because of the time-energy correlation, the SDS can be considered a neutron interrogation system with a variable energy. The ^{235}U and ^{239}Pu fissile contents can be distinguished by differences in the cross sections at certain neutron energies.

Interrogating *fresh* rods with neutrons of mean energies of 0.025 and 0.3 eV, Krinninger et al.^{49,51} reported that a $^{239}\text{Pu}/^{235}\text{U}$ discrimination factor of 4 could be attained. The relatively large resonance self-shielding at these energies required a careful shielding correction calculation. It was claimed that the ^{235}U and ^{239}Pu contents in fuel rods could be assayed to within a 2% (1σ) accuracy.⁵¹ Baumung et al.⁵² explored the higher neutron energy regions to reduce the self-shielding correction, but the $^{239}\text{Pu}/^{235}\text{U}$ discrimination factor dropped to <2 making plutonium and uranium fissile separation difficult.

The problems of assaying spent-fuel rods with SDS have been examined.^{49,50} Fission-product build-up does not appear to affect the assay accuracy.⁴⁹ The neutron detectors must operate in a relatively high radiation field or they should be separated from the sample by shielding material. The method loses accuracy in assaying spent-fuel rods because the 1-eV resonance of the unknown ^{240}Pu content may overlap the 0.3-eV ^{239}Pu resonance. Also, it is questionable whether the SDS method can assay the whole assembly because of the nonuniform response across the assembly, and that the increased sample size deteriorates the energy resolution.

E. Neutron Resonance Absorption

Individual plutonium and uranium fissile contents in spent fuel also can be determined by

neutron resonance absorption analysis. Priesmeyer et al.⁵² used a fast chopper and time-of-flight (TOF) spectrometer to select the neutron resonances in the 0.2- to 50-eV energy range. The ^{235}U , ^{236}U , ^{238}U , ^{239}Pu , ^{240}Pu , and ^{242}Pu isotopes were found to have isolated resonances in this energy range that can be used for assay. The interference from fission-product resonances seems to be negligible. The study indicates that this technique could measure the contents of pulverized pellet samples to within ~10% accuracy. Lazarev⁵³ reported a study on FBR fuel rods where the neutron resonance absorption technique was used, and he quoted an ~2% measurement uncertainty in ^{239}Pu . This technique, however, probably cannot be applied to assay fuel assemblies, except for certain MTR assemblies, because (1) the absorption from the larger resonances tends to saturate as sample thickness increases, and (2) the method requires the sample to be in slab geometry. This method requires an intensive epithermal neutron source (probably from a reactor) and the rather complicated chopper TOF spectrometer.

IV. OTHER MEASUREMENT TECHNIQUES

Besides the assay techniques based on gamma and neutron measurements, two other NDA techniques reported for irradiated fuel are the reactivity and calorimetric methods, both of which are integral measurements.

A. Reactivity Measurement

The reactivity measurement has been used for many years to assay nuclear material. Beyster⁵⁴ evaluated the advantages and disadvantages of both the critical and subcritical reactivity methods. Reactivity is basically an integral quantity, although poison and fuel content can be differentiated by tailoring the neutron flux or the adjoint flux. In addition to the poison-fissile content separation, Baumung et al.⁵² found that a $^{239}\text{Pu}/^{235}\text{U}$ discrimination factor of 2.6 could be achieved with this method. Green et al.⁵⁵ applied the technique to assay $^{235}\text{UO}_2\text{-ThO}_2$ irradiated rods. They found that the fission-product reactivity worth is <3% of the fuel worth; the spontaneous neutron (6×10^3 n/s)

reactivity is much below the measurement sensitivity ($\Delta k/k = 10^{-7}$). The total accuracy (systematic and random) for an assay of 500 rods was estimated to be 0.5%.

This assay technique seems to be applicable to whole assemblies,⁵⁸ especially the MTR-type assembly that has a relatively small self-shielding effect. The main problem of the technique to assay an LWR spent assembly is to determine the plutonium and uranium fissile contents of the assembly separately. The cost of such an assay system is relatively high.⁵⁴

B. Calorimetric Measurement

Another interesting approach to determine spent-fuel burnup is to measure its heat output. The heat, generated predominantly from fission products, depends not only on burnup, but on irradiation history and cooling time. Ramthun and Debertin^{67,68} found that the ^{144}Ce - ^{144}Pr ($T_{1/2} = 284$ days) and $^{89}\text{Sr} + ^{91}\text{Y} + ^{95}\text{Zr}$ activities ($T_{1/2} \approx 60$ days) contributed the major portion of heat generated from MTR fuel sections. They claimed an accuracy of 1.5 to 2.7% in calorimetric burnup determination and a possible 2 to 3% systematic error from nuclear data, gamma-ray energy absorption. It is hard to comprehend that the gross heat measurement can be more accurate than the gamma spectrometric measurement in which the isotopes can be identified by gamma-ray signatures. Perhaps because the authors knew the detailed irradiation history within a maximum 330-day irradiation period, careful irradiation history and cooling corrections were possible. Good agreement was obtained between calorimetric and mass-spectrometric measurements.

V. SUMMARY AND DISCUSSION

A summary of the status of NDA techniques as applied to spent fuels is given in Table IV. Since the last review in 1968, several NDA techniques have proved reliable to determine burnup or fissile content of irradiated nuclear fuels for safeguards purposes.

A. MTR Spent-Fuel Assemblies

The status of NDA techniques for MTR or other highly enriched fuel assemblies is quite good. Both the absolute gamma activity and the gamma activity ratio methods can determine burnup of an MTR assembly with reasonable accuracy. If the fissile content of the assembly were desired, either the gamma-ray absorption method or the neutron interrogation with isotopic source method could be used.

B. LWR Spent-Fuel Assemblies

The status of NDA techniques for LWR fuel assemblies is not yet satisfactory and must be studied further to develop reliable techniques.

To determine burnup, the activity ratio method is desirable for field inspection because of simplicity of measurement. Several aspects of this method, however, require further examination.

1. At present, indications are that no correlation exists between the burnup and the $^{134}\text{Cs}/^{137}\text{Cs}$ activity ratios for BWR assemblies.¹² More studies are needed to evaluate the influence of obvious reactor variables (enrichment, poison content, moderator-to-fuel ratio, etc.) on the correlation.

2. Approximately four experiments have been reported in which correlations in LWR spent-fuel assemblies were determined to within 4%. Most of the experiments relied on detailed specific burnup calculations to derive the assembly attenuation corrections. An inspection agency would not have enough information nor time to perform these calculations. Inspectors need a set of empirical correlations between burnups and activity ratios *without* the attenuation correction. An agreement should be reached between the investigators and inspection agencies that similar measurement techniques (assembly corner measurement, power history correction, etc.) be used in establishing the correlations to be relied upon in field inspection. We question whether correlations established from postirradiation examinations of fuel pellets or dissolver solutions can be used to assay fuel assemblies

TABLE IV
SUMMARY OF NDA TECHNIQUES ON SPENT FUEL

Technique	Gamma Source or Interrogating Neutron	Spent-Fuel Type	Present Accuracy (%)	Comments
Absolute gamma activity	^{137}Cs	LWR rod LWR assembly	1.4 1.6	Accuracy can be attained only if the assembly attenuation can be calculated to higher accuracy.
		MTR assembly	1	
Gamma activity ratio	$^{134}\text{Cs}/^{137}\text{Cs}$	LWR rod LWR assembly	3.8 1.4	Accuracy can be attained only if the assembly attenuation can be calculated to higher accuracy.
		MTR assembly	5.9	
Gamma-ray absorption	145-keV gamma ray	MTR assembly	2	
Passive neutron counting		LWR rod		Needs experimental study.
Neutron interrogation with isotopic source	^{252}Cf , Sb-Be, Rh-D Ra-Be Sb-Be	LWR assembly Rover fuel HTGR fuel	2 4	Feasibility study only. System extensively tested. System tested.
Neutron interrogation with accelerator	Van de Graaff (200- to 500-keV neutron)	LWR assembly		Feasibility study only.
	Cockcroft-Walton (14-MeV neutron)	MTR assembly	2	System tested.
	Sealed neutron tube (14-MeV neutron)	MTR-type assembly	4	System tested.
Slowing-down spectrometer	Sealed neutron tube (14-MeV neutron)	LWR rod		Feasibility study. A $^{239}\text{Pu}/^{235}\text{U}$ discrimination ratio of 4 has been achieved for fresh fuel.
Neutron resonance absorption	Intense epithermal neutron	LWR fuel powder	9	Can determine the isotopic content. Probably applicable to MTR assembly.
		FBR rod	2	
Reactivity	Critical assembly	($^{235}\text{UO}_2$ - ThO_2) rod	0.5	Needs investigation to apply this method to LWR rod or assembly.
Calorimetry		MTR fuel plates	1-3	Requires careful irradiation and cooling correction.

because of the very large attenuation factor, unless the intrinsic calibration method is proved valid.

3. The intrinsic calibration method simplifies the activity ratio measurement significantly, but the activity migration and nonuniform burnup cause errors. Changes in the present LWR fuel design

could reduce these errors and enhance the usefulness of the method (smaller fuel pin diameter and lower linear power ratings reduce both probability of cesium migration and the influence of the different radial distribution of ^{134}Cs and ^{137}Cs ; different enrichment loading within the assembly

ensures a more uniform burnup). Understanding of applicability of the intrinsic calibration method to various generations of reactor fuels is required.

4. A reliable method of scanning the assembly to obtain burnup profiles by some integral gamma or neutron measurement will expedite the measuring process. After determination of burnup profile, only measurement of assembly activity ratio at one or a few points is necessary.

In a gamma assay, the outer rods of a spent-fuel assembly contribute most of the activity; an alternative method is needed for burnup determination in which the contribution from the center rods is more significant. Passive neutron counting of the fast neutrons appears promising, and the measurement can be performed with portable equipment. Because the possibilities of this method have not been established, it should be explored. If fissile content of LWR fuel is required by an inspection agency, then neutron interrogation with sealed neutron tubes is a possibility, but it has not been actively investigated.

For reprocessing plants, it seems that systems using the approach of neutron interrogation with isotopic sources^{38,39,41} could determine the total fissile content of LWR fuel assemblies. At present, no method can accurately differentiate between the

plutonium and uranium fissile contents of the assembly. A method that could differentiate between the two dominant fissile components would be advantageous for a reprocessing facility.

Accuracy of burnup calculations for PWR, BWR, and CANDU reactors is discussed in the Appendix. Based on previous bench-mark calculations, the assembly-averaged burnups can be calculated to within 3 to 7%. However, without detailed simulations of the actual reactor operating history, an additional error (within 5 to 7% for PWR, 10 to 15% for BWR) may be made in predicting assembly-averaged burnups. If a substantial deviation is found between measured and declared burnups, the logical conclusion would be that either fuel substitution has taken place or there is a large error in the declared burnup. Therefore, the inspection agency should have the capability to check the burnup calculation in case of discrepancy.

ACKNOWLEDGMENTS

We wish to thank R. H. Augustson, M. Bresesti, H. O. Menlove, J. R. Phillips, R. B. Walton, and W. F. Staley for valuable discussions and aid in the preparation of this manuscript.

APPENDIX

BURNUP PREDICTION CAPABILITY FOR PWR, BWR, AND CANDU REACTORS

I. INTRODUCTION

Strict monitoring of special nuclear materials is necessary to prevent their diversion from legitimate uses to illegal weapons applications. Specifically, the burnup and heavy-element isotopic content of spent fuels from power reactors must be known to detect unsanctioned activities. Various experimental techniques can verify spent-fuel burnup declared by reactor operators. In addition, it is desirable to provide additional verification of declared burnup by comparison with calculated burnup predictions. This Appendix is a brief review of our ability to

predict fuel burnup in power reactor cores in order to understand better the usefulness of burnup calculations for nuclear materials safeguards considerations.

For accurate fuel burnup predictions in a power reactor core, we rely heavily on computer code systems to account for material heterogeneities and complex space- and energy-dependence of reaction cross sections of materials in the core, as well as for accurate determination of various nuclide concentrations as a function of fuel burnup. Accurate burnup calculations also require a detailed simulation

of the actual operating history and fuel management scheme of the reactor core.

During the past decade, the accuracy of fuel burnup predictions in reactor cores has been the subject of several reviews.⁵⁹⁻⁶³ This report updates earlier reviews by incorporating recent experimental and calculational results. In addition, credit is given to industry's efforts to evaluate and improve the accuracy of power distribution predictions and measurements. The accuracy of fuel burnup predictions is, of course, limited by the difficulty in making accurate power distribution predictions. Here we discuss only the capability for predicting power and burnup distributions in LWR and CANDU reactor cores.

II. COMPARISON OF REACTOR TYPES

A. PWR

The distinctive feature of the PWR design (which represents about two-fifths of the world's operating reactors) is the use of light-water moderator and coolant. The water, at a system pressure of 155 bars (2250 psia or 15.7 MPa), normally is not permitted to boil in the reactor pressure vessel. The reactor core is further characterized by uniform enrichment within each fuel assembly, small water gaps between assemblies, and a distributed control poison system.

The reactivity variation caused by power level change is controlled by a combination of distributed control rods and boric acid dissolved in the coolant. The gross reactivity change caused by fuel depletion is compensated for by a combination of soluble boron and distributed burnable poisons usually containing B₄C. During normal operations, the control rods are essentially removed from the reactor core. Fuel elements, which typically contain 1.9 to 3.5% enriched uranium dioxide, are exposed to 33 000 MWD/MTU of burnup before discharge.

B. BWR

The BWR design (which represents about one-third of operating reactors) also uses light-water moderator and coolant. In BWR cores, however, the

coolant water is at a system pressure of 72 bars (1050 psia or 7.3 MPa) and is allowed to undergo bulk boiling in the reactor core, thus causing an appreciable amount of void formation. The most significant manifestation of this is a strong negative reactivity feedback effect.

Other differences from the PWR design are caused by additional heterogeneities in the core structure. Fuel assemblies with nonuniform enrichment distributions are separated by large water gaps that accommodate control elements. The control elements, in the form of cruciform blades, are strong localized neutron absorbers that usually control reactivity variation associated with power level changes and fuel depletion. Control of reactivity changes caused by load variations may also be augmented by flow rate controls in BWR cores. Control of reactivity variation from fuel burnup is also augmented by distributed burnable poisons consisting of Gd₂O₃ mixed with fuel material in selected rod locations. Fuel assemblies, which are typically loaded with uranium dioxide pellets of 1.5 to 3.0% enrichment, are exposed to 27 500 MWD/MTU of burnup before discharge.

The cruciform control blades also obtain the desired power distribution in BWR cores that, uncontrolled, would be distorted considerably from symmetric distributions caused by the distributed void feedback effect. Thus, at the beginning-of-cycle (BOC) in a BWR core, about a quarter of the control rod full-length equivalent would be inserted into the core so that reactivity and power distribution requirements would be met. Control rods are interchanged at subsequent intervals in the fuel cycle and are gradually removed until at the end-of-cycle (EOC) the core is free of control rods.

C. CANDU

The most distinct feature of the CANDU design is that heavy water serves as both moderator and coolant, which permits the use of natural uranium as fuel instead of enriched uranium (as in LWR designs). In CANDU reactor cores,⁶⁴ short bundles of fuel rods, typically 50 cm long, are placed end to end horizontally in individual pressure tubes containing heavy-water coolant. The pressure tubes are

loaded horizontally in a calandria, which contains the cool, low-pressure heavy-water moderator.

The CANDU design is also characterized by its on-power, continuous refueling scheme, which minimizes the control requirements associated with fuel depletion. Lumped poisons consisting of cobalt rods and tubes of light water control the reactivity changes associated with power level variation, shape the desired power distribution, and control spatial xenon oscillations. This control system is augmented by a soluble boron system that overrides excess reactivity during the initial phase of reactor operation. About 0.2% of fuel bundles may be reloaded on a daily basis in a typical CANDU operation, resulting in a discharge burnup of 8000 MWD/MTU.

III. CALCULATIONAL METHODS FOR BURNUP DETERMINATION

Various methods have been developed⁶³ to determine power and burnup distributions in reactor cores, with varying degrees of approximations to the solution of the neutron transport equation. These approximations are necessary because of numerous material heterogeneities, and because of the complex energy dependence of microscopic neutron cross sections over the energy spectrum encountered in reactor cores. One basic approximation in these methods results in a time-dependent isotopic depletion equation coupled with a sequence of steady-state solutions for neutron flux and power distributions. The energy- and space-dependent neutron flux distribution is obtained, based on varying degrees of geometric variable separability assumptions.

Power burnup calculations in PWR cores are usually initiated by unit-cell codes, such as LEOPARD,⁶⁵ which represent individual fuel rods. The few-group microscopic or macroscopic cross sections obtained from these calculations are used in fine-mesh diffusion theory codes such as PDQ-7,⁶⁶ which simulate individual fuel rods discretely in two-dimensional x-y geometry. These two-dimensional x-y calculations are then coupled in a single-channel synthesis scheme with one-dimensional axial calculations to generate three-dimensional flux and power distributions. The

assumption of separability of power distribution in the radial and axial directions is acceptable in PWR cores, where the spatial variation of moderator density is small and the neutron absorbers are nearly uniformly distributed. However, increased efforts have been made recently to perform full three-dimensional diffusion theory calculations for PWR cores rather than the traditional radial-axial synthesis calculations.

The discrete two- or three-dimensional flux distributions can then be used explicitly with microscopic cross sections to calculate fuel burnup and isotopic depletion for individual fuel rods. In more routine calculations for PWR cores, macroscopic group constants generated from unit-cell calculations are used parametrically to determine fuel burnup for each fuel rod, and isotopic concentrations are determined from the unit-cell calculations.

In contrast, large spatial variations of moderator density, additional heterogeneities introduced by the control blades, and the enrichment distribution within each fuel assembly in BWR cores make full three-dimensional calculations necessary for determination of power and burnup distributions. For economic reasons, however, coarse-mesh three-dimensional calculations are usually coupled with thermal-hydraulic feedback effects in BWR cores using codes such as FLARE,⁶⁷ and the BWR Core Simulator.⁶⁸ Thus, fine-mesh calculations are necessary for one or more fuel assemblies where individual fuel rods, control blades, and other material heterogeneities are discretely represented.⁶⁹ The macroscopic group constants from these fine-mesh assembly calculations are then used parametrically to determine global power distributions and fuel burnup distributions in coarse-mesh three-dimensional calculations, and isotopic compositions are determined.

In CANDU reactor cores, the cool heavy-water moderator surrounding the pressure tube indicates a degree of heterogeneity similar to BWR cores. In CANDU and BWR cores, group constants are generated for fuel bundles; in PWR cores, the group constants are generated for individual fuel rods. The few-group constants generated from the bundle calculations (for example, based on the LATREP code⁷⁰) are then used in two- and three-dimensional

diffusion theory calculations to determine power and burnup distributions.

IV. EXPERIMENTAL METHODS FOR BURN-UP DETERMINATIONS

A. Burnup Distribution

Methods available for the experimental determination of fuel burnup are nondestructive analysis (NDA) and destructive analysis (DA).

NDA methods are described in Sec. II of the main text. Briefly, they entail gamma assay of a spent-fuel assembly or rod to determine burnup; the theory is that the fission-product yield relates the number of fissions, or fuel burnup, to the amount of fission product produced. The calculation also requires the energy released per fission for each of the fissionable nuclides.

DA methods involve chemical dissolution of the spent fuel. Specific methods are mass spectroscopy and radiochemical assay. Mass spectroscopy is perhaps the most direct method because it actually measures the absolute and/or relative concentrations of the nuclides and relates them to burnup using simple equations. Two ways to relate isotopic concentrations to burnup are the heavy-element (HE) and ^{148}Nd methods. The HE method⁷¹ determines the number of atoms present for each fissionable nuclide and, using the information on fission energy for each isotope, calculates burnup in MWD/MTU. The ^{148}Nd method⁷² differs from other fission-product methods because ^{148}Nd is not radioactive so no correction is necessary for radioactive decay. The essential quantities are the EOC atom ratios of ^{148}Nd to fissioning nuclides, effective energy per fission, and fission yields.

B. Power Distribution

Accuracy in the fuel burnup predictions is effectively limited by the corresponding accuracy in the power distribution predictions because fuel burnup is obtained as a time-integral of power. Hence, to evaluate accuracy of burnup predictions, accuracy of power distribution predictions is investigated. Experimental techniques used to measure power

distribution in operating power reactors are reviewed; in particular, gamma-scan techniques and in-core power distribution monitoring methods are discussed.

The gamma-scan techniques (see Sec. II) involve analysis of fuel elements or assemblies for photopaks of certain fission products. A burnup monitor must have a long half-life. For power distribution determination, instantaneous or recent fission events are important, as opposed to burnup determinations where cumulative fission events are desired. Therefore, the fission product used as a power distribution monitor should have a short half-life. A commonly used isotope in this application⁷³ is ^{140}La , which has a half-life of 40.2 h.

If the power distribution were held constant for 60 days (which corresponds to about five half-lives of ^{140}Ba , whose decay product is ^{140}La) the spatial distribution of the ^{140}La gamma activity is assumed to be directly proportional to the power distribution. To be more accurate, however, the actual power distribution history during the two months of operation before shutdown is closely simulated by diffusion theory calculations, and the predicted ^{140}La activity distribution is compared with the measured distribution. The accuracy in predicting the ^{140}La can then be interpreted as the accuracy in the power distribution predictions.⁷⁴

Movable and/or fixed in-core neutron detectors are used in LWR cores to determine three-dimensional power maps at operating conditions.⁷⁵⁻⁷⁷ Miniature fission chambers or self-powered neutron detectors normally are used in power distribution monitoring systems. The movable detector system provides spatially continuous axial power distributions at discrete time intervals, whereas the fixed detector system yields timewise continuous information at a few discrete spatial points. In some older cores, either flux wire or aeroball activation systems were also used.

It is a general practice to deduce from the detector signals the average power distribution in the assembly or assemblies surrounding each detector. This conversion to assembly-average power distribution is based on the power-to-detector signal ratios obtained from the multigroup diffusion theory calculations. Power distribution in uninstrumented assemblies is obtained from interpolations and/or extrapolations of the measured power distribution

in instrumented assemblies, again based on the calculated assembly power distribution. Local pin-to-pin power distributions from multigroup diffusion theory calculations are then superimposed on the assembly power distribution to obtain a global pin-to-pin power distribution in the x-y plane. For movable detector systems, the measured axial power distributions are coupled with this x-y distribution to obtain a three-dimensional power map.⁷⁶ For a fixed detector system, axial power distributions are generated by Fourier analysis of discrete detector signals, and then combined with the x-y power distribution as in the movable detector system.⁷⁷

V. ACCURACY IN BURNUP PREDICTIONS

To better understand the usefulness of burnup predictions for nuclear safeguards purposes, we will summarize burnup prediction capabilities of PWR, BWR, and CANDU reactors. The discussions concentrate on accuracy of predicting burnup and power distributions (assembly average, relative rod-to-assembly, and relative axial within rod), and isotopic distributions for ²³⁶U and fissile plutonium isotopes (assembly average and relative rod-wise within assembly). The accuracy of these predictions is evaluated in terms of the standard deviation of relative errors between calculational and experimental values, based on comparisons from the open literature. In many cases, standard deviations were generated using published raw data. In some cases, because the limited number of data points did not warrant meaningful calculations of standard deviations, only the range of accuracy is reported. Discussions on the accuracy of the data bases are presented, followed by a summary in Table A-I.

A. PWR

1. Burnup Distribution. Most available data on burnup distribution predictions are from two older reactors, Yankee-Rowe and Trino-Vercellese. Both reactors are relatively small but they are well documented.

Accuracy of assembly-averaged burnup predictions ranges from a $\pm 3\%$ standard deviation for

Trino⁷⁸ to $\pm 4.7\%$ for Yankee-Rowe.⁵⁹ Values of $\pm 3.5\%$ (Ref. 79), $\pm 3.8\%$ (Ref. 80), and $\pm 3.9\%$ (Ref. 81) were found in Yankee evaluations. An independent evaluation⁸² on Yankee data also indicates a $\pm 3.8\%$ standard deviation. The 4.7% value should not be regarded too highly because it was determined by a coarse-mesh description in the FLARE code; the other PWR calculations were performed using fine-mesh diffusion theory codes. A typical estimate of the experimental error for assembly-average burnup determination is $\pm 5\%$ (Ref. 79) for both radiochemical (¹³⁷Cs) and heavy-element evaluations.

Relative rod-to-assembly data are somewhat scarce. A $\pm 1.1\%$ standard deviation was obtained¹⁷ for the Trino reactor. A $\pm 1.7\%$ rod-to-assembly standard deviation was found for two fuel assemblies from the Beznau reactor.⁸³ There was no estimate of the accuracy of experimental methods for this particular category, but data should not deviate significantly from that on an assembly-wise or local axial basis. Calculational accuracy in predicting relative axial burnup distributions within rods is available for Trino spent-fuel studies. Values obtained are $\pm 3.8\%$ (Ref. 78) and $\pm 5.0\%$ (Ref. 17). The experimental accuracy in determining the local burnup distributions appears to depend somewhat on the method used. Typical results are $\pm 4\%$ for heavy element,⁷⁸ $\pm 2\%$ for neodymium,¹⁷ and $\pm 5\%$ for ¹³⁷Cs methods.¹⁷

2. Power Distribution. For assembly power distributions, reports indicate a ± 2 to 3% standard deviation for reactor cores made by Combustion Engineering, Inc.,^{77,84-87} and ± 1.6 to 3.3% for the Trino.⁸⁸ Similarly, a $\pm 2.3\%$ standard deviation was obtained in predictions of assembly-averaged power distribution for the Keweenaw reactor.⁸⁹ For the San Onofre reactor, power distributions were measured experimentally by aeroball activation, and a $\pm 6.2\%$ standard deviation in assembly-averaged power distribution prediction was reported.⁹⁰ However, a ± 5 to 9% standard deviation in the experimental measurement of assembly-averaged power distribution was estimated by Fenech for the aeroball system.⁹¹ Thus, the somewhat large $\pm 6.2\%$ standard deviation reported for the San Onofre reactor seems to be partly from inaccuracies in the aeroball system itself, and is not included in Table A-I. For other

TABLE A-I
FUEL BURNUP PREDICTION ACCURACY

	Standard Deviation (%) ^a		
	<u>PWR</u>	<u>BWR</u>	<u>CANDU</u>
<u>Burnup Distribution</u>			
Assembly average	3.5	(3.5) ^b	(4.7)
Relative rod-to-assembly	1.2	2.4	1.2 ^c
Relative axial within rod	4.5	6	(5-10)
<u>Power Distribution</u>			
Assembly average	2.4	3.5	4
Relative rod-to-assembly	1.4	1.6	4 ^c
Relative axial within rod	(5-10)	4.9	(5-10)
<u>Isotopics Distribution</u>			
Assembly average			
²³⁵ U	5	(5-10)	(5-10)
Fissile Pu	5	(5-10)	(5-10)
Relative rod-to-assembly			
²³⁵ U	5	5	5 ^c
Fissile Pu	8	4	5 ^c

^aStandard deviation between calculational and experimental values divided by experimental value.

^bNumbers in parentheses indicate best estimates.

^cIndicates ranges of error only.

reactors, better experimental accuracy is expected because in-core neutron detectors and/or flux wire activations were used to determine power distributions experimentally.

Ariemma et al.⁶⁸ reported ± 0.8 to 3.4% standard deviation in their predictions of relative power distribution within assemblies, based on analyses of Saxton critical facilities data.

3. Isotopics Distribution. Most available data on isotopics distributions are also from Yankee-Rowe and Trino. Although the Yankee evaluations were quite extensive and included a careful evaluation on experimental accuracy in assembly-averaged isotopics distributions, no comparison bet-

ween calculations and measurements can be found in the literature. However, a recent evaluation by Swedish researchers⁶² includes some isotopics comparisons.

On an assembly-averaged basis, standard deviations of $\pm 4.1\%$ for ²³⁵U and $\pm 4.3\%$ for fissile plutonium concentrations were obtained⁶² as an indication of calculational accuracy for Yankee-Rowe. Similarly, standard deviations of $\pm 3.8\%$ for ²³⁵U and $\pm 4.0\%$ for fissile plutonium concentrations were generated for Trino.⁷² Standard deviations of $\pm 1.0\%$ for ²³⁵U and $\pm 1.6\%$ for fissile plutonium concentrations in the experimental isotopics determination on an assembly-wise basis were obtained from the Yankee evaluations.⁷⁹

Absolute isotopics comparisons for the local axial distributions within fuel rods were presented in a report on Trino spent fuel,¹⁷ which suggests standard deviations of $\pm 5.5\%$ for ^{235}U and $\pm 8.3\%$ for fissile plutonium as the calculational accuracies. If the errors in the assembly-averaged isotopics calculations reported for Trino, that is, $\pm 3.8\%$ for ^{235}U and $\pm 4.0\%$ for fissile plutonium, are not included in the above absolute local isotopics errors, we obtain a conservative estimate of isotopics calculational errors of relative rod-wise distributions within fuel assemblies as $\pm 4.0\%$ for ^{235}U and $\pm 7.3\%$ for fissile plutonium concentrations. Evaluations of the Yankee-Rowe isotopics⁶² indicate calculational errors of 1.4 to 2.8% for ^{235}U and 0.3 to 3.4% for fissile plutonium concentrations.

B. BWR

1. Burnup Distribution. As for PWRs, available information on burnup distribution for BWRs is based on a limited number of studies. The BWRs most extensively studied are Garigliano and the Japanese Power Demonstration Reactor (JPDR). The former approaches typical commercial size, whereas the latter, as the name implies, is a small demonstration reactor.

Relative rod-to-assembly burnup distributions calculated for Garigliano²⁰ show a 1.5 to 3.4% standard deviation compared with the experiment. For this study the gamma-scan technique was used, with ^{137}Cs as a burnup monitor. The gamma scan results showed relative burnup distributions, which were later calibrated to DA results using the ^{146}Nd method.

Relative axial-to-rod burnup distributions estimated³⁰ for JPDR-1 produced a $\pm 5.9\%$ standard deviation. The experimental methods were as outlined above, that is, gamma scan plus DA. This method has an accuracy, on a local basis, of $\pm 3.5\%$ (Ref. 20).

2. Power Distribution. There is more information for power distributions in BWRs than for burnup distributions. Other reactors providing data are: Jersey Central, KKM, KRB, Tsuruga, Quad Cities Unit 1, and Dodewaard.

Values for the standard deviation of assembly power range from $\pm 2.1\%$ (Ref. 92) to $\pm 4.5\%$ (Ref. 93). The low 2.1% is for a group of four adjacent assemblies. Most recent results indicate a range of ± 2.4 to 3.5% (Refs. 74, 94), based on studies done for several operating BWRs mentioned above. The $\pm 2.4\%$ accuracy by Carew⁹⁴ is based on a fine-mesh diffusion theory calculation, whereas the ± 2.4 to 3.5% standard deviation by Parkos⁷⁴ is based on standard coarse-mesh three-dimensional calculations. The usual experimental method is gamma scanning of ^{140}La activities.

The calculational accuracy of relative rod-to-assembly power distributions in BWRs was well represented recently,⁶⁹ and calculational errors from ± 1 to 6% were reported, based on an analysis of Jersey Central, KRB, and Tsuruga. This range is within previously reported values of $\pm 3.5\%$ (Ref. 94), $\pm 4.2\%$ (Ref. 92), $\pm 1.3\%$ (Ref. 95), and $\pm 4.6\%$ (Ref. 96).

A recent study⁷⁴ suggests standard deviations from ± 3.7 to 8.3% for the accuracy in calculating axial power peaking factors for individual fuel assemblies in BWR cores, as compared to gamma-scan results. Although these error estimates are considered somewhat optimistic for relative axial power distribution calculation in BWR cores, they have been included without subjective bias introduced by the authors. The experimental error for the gamma-scan measurements based on ^{140}La distribution is ± 2 to 3% (Ref. 73).

3. Isotopics Distribution. Prediction capability for assembly-averaged uranium and plutonium fissile content is not readily available. However, there are data that compare rod-to-assembly predictions and experiments. Calculational results were compared with mass spectrometric results for a chosen x-y plane in Garigliano.²⁰ The study indicated a standard deviation of $\pm 4.5\%$ for ^{235}U and a $\pm 4\%$ standard deviation for determination of fissile plutonium content.

C. CANDU

1. Burnup Distribution. The concept of spatially varying burnup distributions from one

assembly to another is less meaningful when applied to CANDU because of continuous refueling.⁶⁷ Fuel bundles are continuously moved in the reactor, and burnup predictive capability at a given point is less useful. The quantity usually noted in CANDU literature is the equilibrium discharge burnup, which is the operator's goal for each bundle. Calculations to determine this quantity have yielded accuracy to $\pm 2\%$ for 7000 MWD/MTU, and approximately $\pm 5\%$ for 7000 MWD/MTU for the NPD reactor.⁶⁸ Experimental data for such comparisons were from DA, where the calculated $^{235}\text{U}/^{238}\text{U}$ atom ratios were normalized to the experimental values. Hence, because these error estimates are considered optimistic, a 2% error has been added arbitrarily to obtain more realistic error estimates for bundle-average burnup predictions.

Calculations based on the isotopics data presented for the NPD reactor,⁶⁸ the heavy-element method,⁷¹ and typical nuclear parameters⁷² yielded an approximate estimate on prediction accuracy of the relative rod-to-assembly burnup distribution from ± 1 to 2%.

2. Power Distribution. Comparisons of calculated and measured channel power distributions for the Douglas Point reactor indicate a $\pm 4\%$ standard deviation.⁷³ Channel power in CANDU is the power produced by all the bundles in a pressure tube and hence, is equivalent to the assembly-averaged power in LWR cores.

Thermal neutron flux distributions from CANDU compared with calculations¹⁰⁰ indicate that axial peaking factors within assemblies could be calculated to a 1.6% accuracy. This accuracy, however, only refers to the peaking factors within short bundles. An overall axial power distribution calculation is expected to be much less accurate. Similarly, the calculation of the relative rod-to-bundle thermal flux distribution has been shown to lie within 3.3% of experimental results. These calculations were made using a two-dimensional transport theory code.

3. Isotopics Distribution. The results from isotopics studies⁶⁸ done on an assembly-wise basis were only from the $^{235}\text{U}/^{238}\text{U}$ atom ratios normalized to the experimental values. Errors of the relative rod-to-bundle isotopics calculation range up to

$\pm 4.5\%$ for ^{235}U and $\pm 4.3\%$ for fissile plutonium concentration.

D. Summary

Discussions in this section are based on published information and are summarized in Table A-I, where we round off the available error estimates to the next larger integer values. Whenever actual data exist, the published information has been presented in an attempt not to introduce subjective estimates. When no actual data were available, best estimates were provided in parentheses.

Because experimental errors involved in the various burnup and power distribution measurements have not been accounted for explicitly, the fuel burnup prediction accuracies summarized in Table A-I are only relative to measurements and are by no means absolute accuracies. Also, most of our information is based on *bench-mark* calculations on burnup, power, and isotopics distributions. Thus, the accuracy estimates in Table A-I may often represent rather optimistic estimates on burnup prediction capability.

VI. CONCLUDING REMARKS

We have presented reasonable estimates on the fuel burnup prediction capabilities for LWR and CANDU, based on published results (mostly from *bench-mark* calculations). These calculations are invariably performed with detailed simulations of the actual operating history of the plants, including control poison variations. For nuclear materials safeguards, however, it is important to verify declared fuel burnup based on predicted calculations performed without detailed simulations of the plant operating history.

An estimate of the error bounds for burnup prediction calculations without detailed simulations of the actual operating history might be obtained by studying changes in power distributions caused by power level changes and/or control rod motions. Thus, in PWR cores, a maximum difference of 7% in assembly-averaged power distribution may be observed between hot full-power conditions with and without equilibrium xenon poisoning.¹⁰¹ This 7%

difference would represent an upper bound on the expected changes in the assembly-averaged power distribution caused by power plant operations at less than full-power levels. Thus, an additional error from 5 to 7% in the assembly-averaged burnup distributions might be suggested to account for the lack of detailed simulations of the plant operating data.

Without detailed simulations of the operating data, somewhat larger errors could be expected for predicted axial burnup distributions in individual fuel assemblies or rods because of the tilting of axial power distributions under the presence of negative moderator temperature coefficients in PWR cores, that vary as a function of power level. Relative rod-wise burnup distributions within fuel assemblies are not expected to change significantly because of power level changes.

In BWR cores, control blades are interchanged and gradually removed in a sequential manner as a function of core fuel burnup, in contrast to PWR cores which are normally operated without insertion of any control rods. Thus, a substantial error could be made in predicting burnup distributions in BWR cores if detailed control rod histories are not simulated.

In BWR cores, average power in a fuel assembly could change by ~35% by the insertion or removal of an adjacent control blade.¹⁰² Control blades, however, usually are rotated among a group of four adjacent units to match predicted Haling power distributions as closely as possible.¹⁰³ Perhaps a maximum additional error of ~10 to 15% in the assembly-averaged burnup predictions might be suggested for BWR cores where detailed control rod histories are not simulated. Substantially larger errors in burnup predictions for relative rod-to-assembly and axial distributions could possibly be expected in BWR cores if detailed simulations are not made of control rod motions, power levels, and/or flow distributions.

Burnup predictions based on in-core power distribution measurements should be used whenever possible to provide additional verification of declared fuel burnup. There should be increased emphasis on assessment of the accuracy of the power distribution monitoring systems so that they

will be more meaningful for control of nuclear materials.

REFERENCES

1. E. R. Edwards, "A Review of Recent Studies of Nondestructive Assay Methods for Irradiated Nuclear Fuel," *Nucl. App.* 4, 245-259 (1968).
2. T. N. Dragnev, "Experimental Techniques for Measuring Burn-up Non-destructive Techniques: Gamma Spectroscopy," International Atomic Energy Agency report IAEA/STR-48 (October 1974).
3. R. S. Forsyth, W. H. Blackadder, and N. Ronquist, "Burn-up Determination by High-Resolution Gamma Spectrometry: Fission Product Migration Studies," *Aktiebolaget Atomenergi* (Sweden) report AE-272 (April 1967).
4. J. R. Phillips, "New Techniques in Precision Gamma Scanning, Application to Fast-Breeder Reactor Fuel Pins," *Los Alamos Scientific Laboratory* report LA-5260-T (July 1973).
5. J. R. Phillips, G. R. Waterbury, N. E. Vandeborgh, and T. K. Marshall, "Quantitative Determination of Fission Products in Irradiated Fuel Pins Using Nondestructive Gamma Scanning," *Anal. Chem.* 47, 71-75 (1975).
6. J. E. Rein, "Status of Burnup Measurement Methodology," in *Anal. Meth. in the Nucl. Fuel Cycle*, Proc. Symp., Vienna, November 29—December 3, 1971 (International Atomic Energy Agency, Vienna, 1972), Paper SM-149/40, pp. 449-472.
7. R. W. Durham, "Burnup of Ceramic Fuel by Gamma-Ray Scanning," *Atomic Energy of Canada Limited* report AECL-2688 (April 1967).
8. D. G. Boase, J. D. Chen, and L. T. Felawka, "Gamma Spectrometry of Irradiated Reactor Fuels,

Experience at the Whiteshell Nuclear Research Establishment," Atomic Energy of Canada Limited report AECL-3952 (October 1971).

9. J. R. Phillips, G. R. Waterbury, and G. E. Vandervoragh, "Distributions of ^{134}Cs and ^{137}Cs in the Axial UO_2 Blankets of Irradiated $(\text{U},\text{Pu})\text{O}_2$ Fuel Pins," *J. Inorg. Nucl. Chem.* 36, 17-23 (1974).

10. S. Hiller, "Gamma-Spectrometric Burnup Determination in Reactor Fuel Rods," *Kerntechnik* 12; No. 11, 485-490 (1970).

11. J. L. Bates, "Fission Product Distribution in Irradiated UO_2 ," Battelle Pacific Northwest Laboratory report BNWL-58 (March 1965).

12. G. Adiletta, N. Benatti, R. Guidotti, M. Paoletti Gualandi, P. Peroni, A. M. Bresesti, M. Bresesti, and D. D'Adamo, "Investigations on Radioactive Fission Product Correlations: Gamma Spectrometry Measurements on Spent Fuel Assemblies of the Garigliano Reactor," Joint Nuclear Research Centre (Ispra) report EUR-5289e (1974).

13. H. Hick and M. Lammer, "Interpretation of Gamma Spectrometric Measurements on Burnt Fuel Elements," in *Safeguards Techniques*, Proc. Symp., Karlsruhe, July 6-10, 1970 (International Atomic Energy Agency, Vienna, 1970), Paper IAEA-SM-133/5, Vol. I, pp. 533-537.

14. T. Dragnev and C. Beets, "Identification of Irradiated Fuel Elements," Euratom report EUR-4576e, Karlsruhe report KFK 1100, Chap. 3, Joint Integral Safeguards Experiment (JEX 70) at the Eurochemic Reprocessing Plant, Mol, Belgium (January 1970—July 1971).

15. J. Valovic, V. Petenyi, S. B. Rana, D. Mikusova, and J. Kmosena, "The Application of Gamma and Isotopic Correlation Techniques for Safeguards Identification and Verification Purposes," final report, International Atomic Energy Agency research contract 1443, Bohunice Nuclear Power Plant, Bohunice, Czechoslovakia (1975).

16. R. S. Forsyth and W. H. Blackadder, "Use of the Fission Product ^{106}Ru Gamma Activity as a Method

for Estimating the Relative Number of Fission Events in ^{239}Pu in Low-Enriched Fuel Elements," in *Safeguards Techniques*, Proc. Symp., Karlsruhe, July 6-10, 1970 (International Atomic Energy Agency, Vienna, 1970), Paper IAEA-SM-133/4, Vol. I, pp. 521-532.

17. A. M. Bresesti, M. Bresesti, S. Facchetti, F. Mannone, P. Barbero, C. Cerutti, F. Marell, A. Peil, R. Pietra, R. Klersy, A. Schürenkämper, A. Frigo, E. Ghezzi, J. P. Meerschman, A. Pollicini, K. H. Schrader, J. Biteau, A. Cricchio, and L. Koch, "Post-Irradiation Analysis of Trino Vercellese Reactor Fuel Elements," Joint Nuclear Research Centre (Ispra and Karlsruhe) report EUR-4909e (1972).

18. P. Brand, A. Cricchio, and L. Koch, "Feasibility Study of the Use of Radioactive Fission Product Correlations for the Determination of Burnup and Heavy Isotopes Composition of BWR Dodewaard Fuel," Joint Nuclear Research Centre (Karlsruhe) report EUR-5141e (1974).

19. P. Barbero, G. Bidoglio, M. Bresesti, R. Chevalier, D. D'Adamo, S. Facchetti, A. Federici, G. Guzzi, L. Lezzoli, F. Mannone, F. Marell, P. R. Trincherini, G. Buscaglia, A. Drago, R. Faccelli, A. Frigo, E. Ghezzi, R. Klersy, K. H. Schrader, A. Schürenkämper, R. Dierckx, J. Biteau, G. Cottone, A. Cricchio, L. Koch, R. Bannella, M. Paoletti Gualandi, and P. Peroni, "Post Irradiation Examination of the Fuel Discharged From the Trino Vercellese Reactor After the 2nd Irradiation Cycle," Joint Nuclear Research Centre (Ispra and Karlsruhe) and Ente Nazionale per l'Energia Elettrica-Rome (Italy) report EUR-5605e (1976).

20. A. Ariemma, L. Bramati, M. Galliani, M. Paoletti Gualandi, B. Zaffiro, A. Cricchio, and L. Koch, "Experimental and Theoretical Determination of Burnup and Heavy Isotope Content in a Fuel Assembly Irradiated in the Garigliano Boiling Water Reactor," Ente Nazionale per l'Energia Elettrica-Rome (Italy) report EUR-4638e (1971).

21. R. Bannella, A. Giuriato, M. Paoletti Gualandi, A. M. Bresesti, M. Bresesti, D. D'Adamo, "Relative Measurements of Burnup and Plutonium Content

in PWR Assemblies," *Trans. Am. Nucl. Soc.* 15, 681-682 (1972).

22. A. M. Bresesti, M. Bresesti, M. Cuypers, D. D'Adamo, L. Lezzoli, R. Bannella, A. Giuriato, M. Paoletti Gualandi, and P. Peroni, "Investigations on Radioactive Fission Product Correlations: Gamma Spectrometry Measurements on Spent Fuel Assemblies Discharged from the Trino Vercellese Reactor at the End of the 2nd Irradiation Cycle," Joint Nuclear Research Centre (Ispra) and Ente Nazionale per l'Energia Electtrica-Rome (Italy) report EUR-5334e (1975).

23. M. Paoletti Gualandi, P. Peroni, M. Bresesti, M. Cuypers, D. D'Adamo, L. Lezzoli, "Determination of Burnup and Plutonium Content in Irradiated Fuels by Gamma-Spectrometry Measurements of Radioactive Fission Products," in *Safeguarding Nuclear Materials*, Proc. Symp., Vienna, October 20-24, 1975 (International Atomic Energy Agency, Vienna, 1976), Vol. II, Paper IAEA-SM-201/3, pp. 613-624.

24. J. D. Chen, D. G. Boase, and R. B. Lypka, "Non-destructive Determination of Burn-up by Gamma-Scanning: an Assessment of $^{144}\text{Ce}/\text{Pr}$ as a Fission Monitor in CANDU Fuels," Atomic Energy of Canada Limited report AECL-5236 (January 1976).

25. R. L. Heath, "The Potential of High-Resolution Gamma-Ray Spectrometry for the Assay of Irradiated Reactor Fuel," *Safeguards Res. Devel.*, Proc. Symp. Argonne National Laboratory, June 26, 1967, report WASH-1076, pp. 115-129 (1967).

26. H. G. Mehner, "Bestimmung der Relativen Effektivität in γ -Spektrometrischen Abbrandmeßeinrichtungen," *Kernenergie* 19, No. 1, 3-5 (1976).

27. C. Beets, P. Bemelmans, and R. Pirard, "Gamma Measurements on SENA Spent Fuel Assemblies and Dissolver Solutions," Contributions to the Joint Safeguards Experiment Mol IV at the Eurochemic Reprocessing Plant, Mol, Belgium, report BLG-486 (September 1973).

28. T. N. Dragnev, "Intrinsic Self-Calibration of Nondestructive Gamma Spectrometric Measurements (Determination of U, Pu, and Am-241 Isotopic Ratios)," International Atomic Energy Agency report IAEA/STR-60 (August 1976).

29. S. Matsuura, H. Tsuruta, T. Suzuki, H. Okashita, H. Umezawa, and H. Natsume, "Non-destructive Gamma-Ray Spectrometry on Spent Fuels of a Boiling Water Reactor," *J. Nucl. Sci. and Technol.* 12, 24-34 (1975).

30. H. Natsume, S. Matsuura, H. Okashita, H. Umezawa, and H. Ezure, "Gamma-Ray Spectrometry and Chemical Analysis on JPDR-1 Spent Fuels," Japan Atomic Energy Research Institute report JAERI-memo-6291 (October 1975).

31. C. Foggi, F. Frenquellucci, and G. Perdisa, "Isotopic Correlations Based on Fission-Product Nuclides in LWR Irradiated Fuels, a Theoretical Evaluation," in *Safeguarding Nuclear Materials*, Proc. Symp., Vienna, October 20-24, 1975 (International Atomic Energy Agency, Vienna, 1976), Vol. II, Paper IAEA-SM-201/44, pp. 425-438.

32. L. Leenders, "Contribution to the Investigation of Isotopic Correlations Among Non-destructive Measurements on Fuel Rods," Contributions to the Joint Safeguards Experiment Mol IV at the Eurochemic Reprocessing Plant, Mol, Belgium, report BLG-486 (September 1973).

33. C. Beets, P. Bemelmans, T. Dragnev, and R. Hecq, "Gamma Measurements on Spent Fuel Elements," *Trans. Am. Nucl. Soc.* 15, 673-674 (1972).

34. N. C. Rasmussen, J. A. Sovka, and S. A. Mayman, "The Non-destructive Measurement of Burn-up by Gamma-Ray Spectroscopy," in *Nuclear Materials Management*, Proc. Symp., Vienna, August 30—September 3, 1965 (International Atomic Energy Agency, Vienna, 1966), Paper IAEA-SM-67/45, pp. 829-849.

35. C. K. Tzou and C. M. Yang, "Nondestructive Burnup Determination by Gamma-Ray Spectroscopy," *Nucl. Technol.* 24, 246-251 (1974).

36. T. N. Dragnev, M. deCarolis, A. Keddar, Yu. Konnov, G. Martinez-Garcia, A. J. Waligura, "Some Agency Contributions to the Development of Instrumental Techniques in Safeguards," in *Safeguarding Nuclear Materials*, Proc. Symp., Vienna, October 20-24, 1975 (International Atomic Energy Agency, Vienna, 1976), Paper IAEA-SM-201/96, Vol. II, pp. 37-62.

37. P. J. Kreyger, R. J. S. Harry, H. Krockel, "Non-destructive Burn-up Determination by 145-keV Gamma-Ray Absorption," in *Safeguards Techniques*, Proc. Symp., Karlsruhe, July 6-10, 1970 (International Atomic Energy Agency, Vienna, 1970), Paper IAEA-SM-133/6, Vol. I, pp. 545-550.

38. T. Gozani, "Active Direct Measurement of Residual Fissile Content in Spent Fuel Assemblies," Electric Power Research Institute report EPRI 278-1 (July 1975).

39. T. Gozani, "Non-destructive Assay of Spent Fuel for Determination of Residual Fissile Content," Proc. 17th Annual Meeting of the Institute of Nucl. Mater. Manage., Seattle, Washington, June 22-24, 1976, pp. 514-524.

40. H. O. Menlove, Los Alamos Scientific Laboratory, personal communication, May 1977.

41. G. L. Ragan, R. S. Booth, T. J. Burns, J. D. Jenkins, C. R. Weisbin, and L. R. Williams, "System for Assay of Fissile Content of Spent LMFBR Fuel Subassemblies," Trans. Am. Nucl. Soc. 23, 95-96 (1976).

42. K. Baumung, K. Böhnel, J. Klunker, M. Küchle, and J. Wolff, "Investigations into Non-destructive Safeguards Techniques," in *Safeguards Techniques*, Proc. Symp., Karlsruhe, July 6-10, 1970 (International Atomic Energy Agency, Vienna, 1970), Paper IAEA-SM-133/90, Vol. II, pp. 177-193.

43. R. H. Augustson, H. O. Menlove, D. B. Smith, A. L. Bond, D. C. Durrill, W. P. Hollowell, and C. P. Bromley, "An Automated Nondestructive Assay System for the Measurement of Irradiated Rover Fuel," Proc. 16th Annual Meeting of the Institute of Nucl. Mater. Manage., New Orleans, Louisiana, June 18-20, 1975, pp. 152-166.

44. P. Filss, "Non-destructive Control of Fissile Material Containing Radioactive Fission Products with a Sb-Be-Neutron Source by Selective Transport of Fission Neutrons in Hydrogenous Material," Kernforschungsanlage Julich report Jul-1046-CT (February 1974).

45. P. Filss, "Non-destructive Control of Fissile Material in Solid and Liquid Samples Arising from a Reactor and Fuel Reprocessing Plant," in *Safeguarding Nuclear Materials*, Proc. Symp., Vienna, October 20-24, 1975 (International Atomic Energy Agency, Vienna, 1976), Paper IAEA-SM-201/53, Vol. II, pp. 471-484.

46. C. R. Weisbin, R. H. Augustson, J. S. Hendricks, A. E. Evans, and G. D. Turner, "Non-destructive Assay of Power Reactor Fuel Assemblies," Nucl. Technol. 15, 455-461 (1972).

47. R. H. Augustson, C. N. Henry, and C. R. Weisbin, "Measurement of the Uranium-235 Content in a Spent MTR Fuel Element Using the Delayed-Neutron Yield Technique," Nucl. Technol. 4, 197-199 (1972).

48. W. Rotter, "Determination of Burn-up of Irradiated Fuel Elements by Pulsed Neutron Interrogation," Ann. Nucl. Sci. Eng. 1, 451-458 (1974).

49. H. Krinninger, S. Wiesner, and C. Faber, "Pulsed Neutron Method for Non-destructive and Simultaneous Determination of the ^{235}U and ^{239}Pu Contents of Irradiated and Non-irradiated Reactor Fuel Elements," Nucl. Instrum. Methods 73, 13-33 (1969).

50. M. P. Navalkar, K. Chandramoleshwar, and D. V. S. Ramakrishna, "A Feasibility Study of Non-destructive Assay of Pu-239 and U-235 in Irradiated Samples Using Slowing Down Time Lead Spectrometer," Nucleonik 11, No. 1, 54-56 (1968).

51. H. Krinninger and E. Ruppert, "Operational Experience with the Automatic Lead Spectrometer

Facility for Nuclear Safeguards," *Trans. Am. Nucl. Soc.* 15, 683-684 (1972).

52. H. G. Priesmeyer and M. Harz, "Isotopic Assay in Irradiated Fuel by Neutron Resonance Analysis," in *Safeguarding Nuclear Materials*, Proc. Symp., Vienna, October 20-24, 1975 (International Atomic Energy Agency, Vienna, 1976), Paper IAEA-SM-201/4, Vol. II, pp. 625-632.

53. L. N. Lazarev, "Nondestructive Methods of Analysis of the Nuclear Fuel of Fast Neutron Reactors," in *LMFBR Fuel Reprocessing*, Proc. Symp., Leningrad, May 17-21, 1976 (International Atomic Energy Agency, Vienna, 1976), US Energy Research and Development Administration report ERDA-TR-205.

54. J. R. Beyster, "Evaluation of Reactivity Methods of Nuclear Materials Assay," Brookhaven National Laboratory report BNL-50251 (T-584) (June 1970).

55. L. Green, J. T. Kriese, and M. Natelson, "The Reactivity Perturbation Assay of Irradiated Fuel Rods," *Nucl. Technol.* 32, 186-204 (1977).

56. J. A. Vreeland, "Assay Capabilities of a Reactor Fuels Measurement Facility," Westinghouse Electric Corporation report WCAP-6041 (December 1959).

57. R. Ramthun and K. Debertin, "Burn-up Determination of Irradiated Fuels by Means of Their Heat Output," *Atomkernenergie* 19, No. 1, 17-22 (1972).

58. K. Debertin and H. Ramthun, "Burn-up Determination of Irradiated Fuels by Means of Their Heat Output," *Atomkernenergie* 21, No. 2, 119-122 (1973).

59. M. Valerino and Z. Rosztoczy, "Analytical and Experimental Methods of Determining Heavy-Isotope Content of Operating Fuel Elements," *Combustion Engineering Incorporated* report CEND-540 (September 1965).

60. Proc. Panel on Fuel Burnup Predictions in Thermal Reactors, Vienna, April 1967 (International Atomic Energy Agency, Vienna, 1968), pp. 227-240.

61. R. G. Clarke, H. J. Svoboda, V. O. Uotinen, and W. Wolkenhauer, "Status of Burnup Calculational Technology as Applied to the Nuclear Materials Safeguards Accounting System," Battelle Pacific Northwest Laboratory report BNWL-1599 (June 1971).

62. Proc. Panel on Reactor Burn-Up Physics, Vienna, July 12-16, 1971, in *Reactor Burn-Up Physics* (International Atomic Energy Agency, Vienna, 1973), pp. 277-291.

63. R. L. Crowther, "Methods of Fuel Management—An Overview," Am. Nucl. Soc. Conf. Mathematical Models and Computational Techniques for Analysis of Nuclear Systems (Ann Arbor, Michigan, April 9-11, 1973), CONF-730414-Pl.

64. Hydro Electric Power Commission of Ontario, Atomic Energy of Canada Limited Power Projects, "Pickering Generating Station," report PP-4 (1969) 197-217.

65. R. Barry, "LEOPARD—A Spectrum-Dependent Non-spatial Depletion Code for the IBM-7094," Westinghouse Electric Corporation report WCAP-6058 (1964).

66. W. Cadwell, "PDQ-7—A Program for the Solution of the Neutron Diffusion Equations in Two Dimensions," Westinghouse Electric Corporation report WAPD-TM-678 (1967).

67. D. Delp, D. Fischer, J. Harriman, and M. Stedwell, "FLARE, A Three-Dimensional Boiling Water Reactor Simulator," General Electric Company report GEAP-4518 (1964).

68. J. Woolley, "Three-Dimensional BWR Core Simulator," General Electric Company report NEDO-20953 (May 1976).

69. C. Martin, "Lattice Physics Methods Verification," General Electric Company report NEDO-20939 (June 1976).

70. G. Phillips and J. Griffiths, "LATREP User's Manual," Atomic Energy of Canada Limited report AECL-3857 (1971).

71. L. Chajson, "Yankee Core Evaluation Program Quarterly Progress Report for the Period Ending June 30, 1963," Westinghouse Electric Corporation report WCAP-6055 (July 1963).

72. A. Moncassoli-Tosi, "Burn-up Prediction for Pressurized-Water-Reactor Cores," in *Reactor Burn-Up Physics*, Proc. Panel on Reactor Burn-Up Physics, Vienna, July 12-16, 1971 (International Atomic Energy Agency, Vienna, 1973), 1-22.

73. M. Cutrone and G. Valby, "Gamma Scan Measurements at Quad Cities Nuclear Power Station Unit 1 Following Cycle 2," Electric Power Research Institute report EPRI-NP-214 (July 1976).

74. G. Parkos, "BWR Simulator Methods Verification," General Electric Company report NEDO-20946 (May 1976).

75. J. J. Loving, "In-Core Instrumentation," Westinghouse Electric Corporation report WCAP-7607 (1971).

76. C. Meyer and R. Stover, "In-Core Power Distribution Determination in Westinghouse Pressurized Water Reactors," Westinghouse Electric Corporation report WCAP-8498 (1975).

77. R. Hellens and R. Ober, "A Method of Analyzing In-Core Detector Data in Power Reactors," *Trans. Am. Nucl. Soc.* 12, 820-821 (1969).

78. A. Moncassoli-Tosi, P. Rama, A. Bresesti, M. Bresesti, S. Facchetti, R. Klersy, F. Mannone, A. Schürenkämper, A. Cricchio, and L. Koch, "Postirradiation Burnup Analysis of Trino-Vercellese Reactor Fuel Elements. Comparison with Theoretical Results," in *Reactor Burn-Up Physics*, Proc. Panel on Reactor Burn-Up Physics, Vienna, July 12-16, 1971 (International Atomic Energy Agency, Vienna, 1973), pp. 197-225.

79. J. Jedruch and R. Nodvik, "Experimentally Determined Burnup and Spent Fuel Composition of Yankee Core 1," Westinghouse Electric Corporation report WCAP-6071 (1965).

80. P. Lacey and R. Radcliffe, "Diffusion-Theory Depletion Analysis of the Yankee Core," Westinghouse Electric Corporation report WCAP-6077 (1966).

81. R. Nodvik, "Evaluation of Gamma Activity Distributions in Yankee Core I and Core II Spent Fuel," Westinghouse Electric Corporation report WCAP-6067 (June 1965).

82. D. Linstroem Jensen, "Development and Verification of Nuclear Calculation Methods for Light-Water Reactors," Danish Atomic Energy Commission, Risoe Research Establishment report RISO-235 (December 1970).

83. J. T. Dawson, "Results of Burn-Up Measurements on Two Assemblies from Beznau 1 (PWR)," Berkeley Nuclear Laboratory report RD/B/N-3239 (1975).

84. J. Humphries, A. Kadak, and R. Knapp, "On-Line Power Distribution Monitoring with In-Core Detectors," *Trans. Am. Nucl. Soc.* 22, 647-648 (1975).

85. W. Terney, T. Ober, and E. Williamson, "Three-Dimensional Calculational Verification of the INCA In-Core Instrumentation System with Lifetime," *Trans. Am. Nucl. Soc.* 22, 681-682 (1975).

86. W. Terney, G. Marks, E. Williamson, and T. Ober, "Axial Power Distributions from Fourier Fitting of Fixed In-Core Detector Powers," *Trans. Am. Nucl. Soc.* 22, 682-683 (1975).

87. P. Gavin and I. Rickard, "Performance of the Combustion Engineering PWR Physics Design System," *Atomkernenergie* 25, 87-90 (1975).

88. A. Ariemma, G. Lesnoni La Parola, M. Puoletti Gualandi, P. Peroni, and B. Zaffiro, "Accuracy of Power-Distribution Calculation Methods for Uranium and Plutonium Lattices," *Nucl. Appl. Technol.* **8**, 328-354 (1970).

89. Initial Startup Report, Kewaunee Nuclear Power Plant, Docket number 50305-241 (September 1974).

90. A. Impink, J. Easter, and W. Leggett, "Comparison of Predicted and Measured Nuclear Design Parameters at Beginning of Life Cycle 1 in the San Onofre Reactor," Westinghouse Electric Corporation report WCAP-3269-66 (1968).

91. H. Fenech, "Statistical Analysis of In-Core Measurements in Operating Nuclear Reactors," *Trans. Am. Nucl. Soc.* **15**, 364-379 (1972).

92. P. L. Crowther, W. P. Petrick, and A. Weitzberg, "Three-Dimensional BWR Simulation," *Proc. Conf. on the Effective Use of Computers in the Nuclear Industry*, Knoxville, Tennessee, CONF-690401 (April 1969).

93. T. Shimooke, "Prediction of Three-Dimensional Core Performance of JPDR (a BWR) for Burnup Cases," *Nucl. Technol.* **10**, 257-272 (1971).

94. J. F. Carew, "Process Computer Performance Evaluation Accuracy," General Electric Company report NEDO-20340 (June 1974).

95. P. G. Aline, N. H. Barth, W. R. Chancey, R. L. Crowther, D. L. Fisher, J. W. Hallam, A. Weitzberg, F. G. Warzek, and I. B. Wall, "The Physics of Non-uniform BWR Lattices," in *Physics Problems in Thermal Reactor Design* (British Nuclear Energy Society, June 1967).

96. H. Bairiot, P. Devamaix, C. Vandenberg, L. Leenders, and P. Mostert, "Plutonium Assemblies in Reload 1 of the Dodewaard Reactor," *Nucl. Technol.* **33**, 184-202 (1977).

97. C. Miller, "Fuel Management in CANDU Reactors," *Ann. Nucl. Energy* **3**, 359-366 (1976).

98. J. Griffiths, "The Effectiveness of LATREP Calculations: A Survey and Detailed Comparison with Experiment," Atomic Energy of Canada Limited report AECL-3739 (1971).

99. A. A. Pasanen and J. F. Blansche, "Douglas Point HWR Startup Physics Measurements and Predictions," Atomic Energy of Canada Limited report AECL-2712 (October 1967).

100. K. W. Dormuth, "Calculation of Axial Flux Distribution in CANDU Fuel Bundles," Atomic Energy of Canada Limited report AECL-5390 (1976).

101. "Reference Safety Analysis Report," Westinghouse Electric Corporation Report, RESAR 414, Vol. II, Sec. 4.3 (1976).

102. "General Electric Standard Safety Analysis Report for BWR/6," General Electric Company report GESSIONAR, Vol. II (1973).

103. R. K. Haling, "Operating Strategy for Maintaining an Optimum Power Distribution Throughout Life," *Proc. Am. Nucl. Soc. Topical Meeting on Nuclear Performance of Power-Reactor Cores*, TID-7672 (1963).