

14 77
10715
H20/3987-1/3

SOLAR TOTAL ENERGY SYSTEM

LARGE SCALE EXPERIMENT
SHENANDOAH, GEORGIA



MASILA

FINAL TECHNICAL PROGRESS REPORT

VOLUME III

APPENDIX

CONTRACT NO. EG-77-C-04-3987

ERDA
ALBUQUERQUE OPERATIONS OFFICE
ALBUQUERQUE, NEW MEXICO

C-19650
17 OCTOBER 1977

STEARNS-ROGER
McDONNELL DOUGLAS

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

SOLAR TOTAL ENERGY SYSTEM

LARGE SCALE EXPERIMENT
SHENANDOAH, GEORGIA



FINAL TECHNICAL PROGRESS REPORT

VOLUME III

APPENDIX

CONTRACT NO. EG-77-C-04-3987

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

**ERDA
ALBUQUERQUE OPERATIONS OFFICE
ALBUQUERQUE, NEW MEXICO**

**C-19650
17 OCTOBER 1977**

**STEARNS-ROGER
McDONNELL DOUGLAS**

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

TABLE OF CONTENTS

APPENDIX A1	HOURLY TEMPERATURES
APPENDIX A2	DISPLACEMENT
APPENDIX A3	UTILITY RATES
APPENDIX B1	DRAWINGS (SHADOW STUDY)
APPENDIX B2	POWER CONVERSION SYSTEM SEASONAL DESIGN LOAD SUMMARY
APPENDIX B3	AVERAGE COLLECTOR TEMPERATURE OPTIMIZATION STUDY
APPENDIX B4	SYSTEM OPERATING TEMPERATURE OPTIMIZATION STUDY
APPENDIX B5	POWER CONVERSION SYSTEM SEASONAL PERFORMANCE
APPENDIX B6	THERMAL STORAGE/FLUID LOOP
APPENDIX B7	SYSTEM INTEGRATION
APPENDIX B8	COST ESTIMATES

APPENDIX A-1

HOURLY TEMPERATURES

(Ref. Section 2.1)

APPENDIX A-1.1 AVERAGE MONTHLY TEMPERATURES (1975)

	JANUARY					FEBRUARY				
Time	DBT		DPT		WBT	DBT		DPT		WBT
	°C	°F	°C	°F	°F	°C	°F	°C	°F	°F
1am	6.3	43.3	2.3	36.1	39.7	6.5	43.7	2.6	36.9	40.5
3am	6.0	42.8	2.3	36.1	39.5	5.7	42.3	2.6	36.7	39.6
5am	5.5	41.9	2.1	35.8	39.0	5.2	41.4	2.5	36.5	39.0
7am	5.4	41.7	1.8	35.2	38.9	5.3	41.5	2.3	36.1	39.0
8 am	4.9	40.8	1.8	35.2	38.4	6.4	43.5	3.0	37.4	40.5
10 am	7.6	45.7	2.5	36.5	41.4	7.6	45.7	3.6	38.5	42.1
12 noon	10.4	50.7	3.2	37.8	44.3	10.5	50.9	4.1	39.4	45.0
2 pm	12.1	53.8	3.1	37.6	45.8	12.3	54.1	4.1	39.4	46.7
4 pm	12.5	54.5	3.0	37.8	46.4	12.6	54.7	3.8	38.8	46.8
6 pm	10.3	50.5	2.5	36.5	43.8	11.3	52.3	3.4	38.1	45.3
8 pm	8.5	47.3	2.6	36.7	42.2	9.0	48.2	3.0	37.4	43.0
10 pm	7.2	45.0	2.5	36.5	41.0	7.7	45.9	2.7	36.9	41.6
12 midnight	6.5	43.7	2.1	35.8	39.9	6.8	44.2	2.7	36.9	40.8

DBT = DRY BULB TEMPERATURE

DPT = DEW POINT TEMPERATURE

WBT = WET BULB TEMPERATURE

°C = DEGREES CELCIUS (FROM WEATHER TAPE)

°F = DEGREES FAHRENHEIT (CONVERTED FROM °C)

WBT IS READ FROM PSYCHROMETRIC CHART
CORRESPONDING TO GIVEN DBT & DPT.

APPENDIX A-1.2

AVERAGE MONTHLY TEMPERATURES (1975)

	MARCH					APRIL				
Time	DBT		DPT		WBT	DBT		DPT		WBT
	°C	°F	°C	°F	°F	°C	°F	°C	°F	°F
1am	8.2	46.8	2.5	36.5	41.8	12.7	54.9	6.6	43.9	43.0
3am	7.4	45.3	2.5	36.5	40.2	11.2	52.2	6.5	43.7	47.7
5am	6.5	43.7	2.3	36.1	39.8	10.4	50.7	6.1	43.0	46.7
7am	5.9	42.6	2.4	36.3	39.4	10.4	50.7	6.5	43.7	47.0
8 am	6.6	43.9	2.7	36.9	40.6	12.1	53.8	6.9	44.4	48.7
10 am	9.2	48.6	3.0	37.4	43.2	15.8	60.4	6.8	44.2	51.5
12 noon	11.6	52.9	3.0	37.4	45.2	18.1	64.6	6.5	43.7	53.2
2 pm	13.4	56.1	3.5	38.3	47.2	19.9	67.8	6.7	44.1	54.6
4 pm	14.5	58.1	3.5	38.3	48.1	20.2	68.4	6.6	43.9	55.0
6 pm	13.4	56.1	3.3	37.9	47.0	19.3	66.7	6.3	43.3	53.8
8 pm	11.4	52.5	3.2	37.8	45.0	16.4	61.5	6.6	43.9	52.0
10 pm	9.7	49.5	2.7	36.9	43.4	14.6	58.3	7.2	45.0	49.0
12 midnight	8.5	47.3	2.3	36.1	42.0	12.9	55.2	6.4	43.5	48.5

DBT = DRY BULB TEMPERATURE

DPT = DEW POINT TEMPERATURE

WBT = WET BULB TEMPERATURE

°C = DEGREES CELCIUS (FROM WEATHER TAPE)

°F = DEGREES FAHRENHEIT (CONVERTED FROM °C)

WBT IS READ FROM PSYCHROMETRIC CHART
CORRESPONDING TO GIVEN DBT & DPT.

APPENDIX A-1.3

AVERAGE MONTHLY TEMPERATURES (1975)

	MAY					JUNE				
Time	DBT		DPT		WBT	DBT		DPT		WBT
	°C	°F	°C	°F	°F	°C	°F	°C	°F	°F
1am	18.7	65.7	15.6	60.1	62.0	20.1	68.2	17.4	63.3	65.0
3am	17.9	64.2	15.6	60.1	61.6	19.5	67.1	17.3	63.1	64.4
5am	17.6	63.7	15.4	59.7	61.0	18.9	66.0	17.0	62.6	63.8
7am	18.3	64.9	16.0	60.8	62.2	20.2	68.4	17.4	63.3	65.0
8 am	19.7	67.5	16.5	61.7	63.7	21.9	71.4	17.8	64.0	66.4
10 am	22.5	72.5	16.4	61.5	65.3	24.8	76.6	18.4	65.1	68.8
12 noon	24.1	75.4	16.2	61.2	66.0	26.8	80.2	18.1	64.6	68.7
2pm	24.8	76.6	15.8	60.4	65.8	27.9	82.2	17.9	64.2	69.9
4pm	25.3	77.5	15.6	60.1	64.4	27.7	81.9	17.8	64.0	69.7
6pm	24.5	76.1	15.9	60.6	66.0	26.4	79.5	17.7	63.9	68.3
8pm	22.1	71.8	15.9	60.6	64.5	23.6	74.5	17.9	64.2	65.8
10pm	20.1	68.2	16.2	61.2	63.7	21.8	71.2	17.9	64.2	66.4
12 midnight	19.1	66.4	15.7	60.3	62.4	20.7	69.3	17.6	63.7	65.5

DBT = DRY BULB TEMPERATURE

DPT = DEW POINT TEMPERATURE

WBT = WET BULB TEMPERATURE

°C = DEGREES CELCIUS (FROM WEATHER TAPE)

°F = DEGREES FAHRENHEIT (CONVERTED FROM °C)

WBT IS READ FROM PSYCHROMETRIC CHART
CORRESPONDING TO GIVEN DBT & DPT.

APPENDIX A-1.4 AVERAGE MONTHLY TEMPERATURES (1975)

	JULY					AUGUST				
Time	DBT		DPT		WBT	DBT		DPT		WBT
	°C	°F	°C	°F	°F	°C	°F	°C	°F	°F
1am	21.6	70.9	20.4	68.7	69.4	22.2	72.0	21.3	70.3	70.8
3am	21.1	70.0	20.1	68.2	68.7	21.7	71.1	21.2	70.2	70.4
5am	20.9	69.6	19.9	67.8	68.4	21.4	70.5	20.8	69.4	69.7
7am	21.3	70.3	20.3	68.5	69.1	21.8	71.2	21.1	70.0	70.3
8 am	23.3	73.9	20.7	69.3	70.7	23.1	73.6	21.6	70.9	71.7
10 am	24.5	76.1	20.7	69.3	71.4	25.9	78.6	21.9	71.4	73.5
12 noon	26.4	79.5	20.9	69.6	72.4	27.7	81.9	21.9	71.4	74.3
2 pm	27.6	81.7	20.6	69.1	72.2	28.7	83.7	21.5	70.7	74.3
4 pm	27.6	81.7	20.2	68.4	72.3	28.8	83.8	21.4	70.5	72.2
6 pm	25.7	78.3	20.4	68.7	71.6	27.4	81.3	21.7	71.1	74.1
8 pm	23.7	74.7	20.3	68.5	75.3	24.8	76.6	21.7	71.1	72.7
10 pm	22.4	72.3	20.5	68.9	69.9	23.5	74.3	21.9	71.4	72.1
12 midnight	21.8	71.2	20.4	68.7	69.5	22.9	73.2	21.6	70.9	71.5

DBT = DRY BULB TEMPERATURE

DPT = DEW POINT TEMPERATURE

WBT = WET BULB TEMPERATURE

°C = DEGREES CELCIUS (FROM WEATHER TAPE)

°F = DEGREES FAHRENHEIT (CONVERTED FROM °C)

WBT IS READ FROM PSYCHROMETRIC CHART
CORRESPONDING TO GIVEN DBT & DPT.

APPENDIX A-1.5

AVERAGE MONTHLY TEMPERATURES (1975)

	SEPTEMBER					OCTOBER				
Time	DBT		DPT		WBT	DBT		DPT		WBT
	°C	°F	°C	°F	°F	°C	°F	°C	°F	°F
1 am	18.5	65.3	16.7	62.6	63.6	14.7	58.5	12.3	54.1	55.9
3 am	17.7	63.9	16.2	61.2	62.0	13.8	56.8	11.7	53.1	54.5
5 am	17.5	63.5	16.1	61.0	61.9	13.4	56.1	11.5	52.7	54.1
7 am	17.5	63.5	16.1	61.0	61.9	13.0	55.4	11.3	52.3	53.5
8 am	18.6	65.5	16.4	61.5	62.8	14.2	57.6	11.9	53.4	55.2
10 am	21.5	70.7	16.9	62.4	64.8	17.6	63.7	12.9	55.2	58.4
12 noon	23.7	74.7	17.5	63.5	67.1	20.2	68.4	13.2	55.8	60.4
2 pm	24.6	76.3	17.4	63.3	67.5	21.6	70.9	12.7	54.9	60.3
4 pm	24.2	75.6	17.6	63.7	67.5	21.7	71.1	12.2	54.0	58.8
6 pm	22.9	73.2	17.2	63.0	66.4	19.1	66.4	12.6	54.7	58.8
8 pm	20.8	69.4	17.0	62.6	64.7	17.1	62.8	12.6	54.7	57.5
10 pm	19.4	66.9	16.7	62.1	63.8	15.5	59.9	12.3	54.1	56.4
12 midnight	18.9	66.0	16.7	62.1	63.5	15.2	59.4	12.6	54.7	56.5

DBT = DRY BULB TEMPERATURE

DPT = DEW POINT TEMPERATURE

WBT = WET BULB TEMPERATURE

°C = DEGREES CELCIUS (FROM WEATHER TAPE)

°F = DEGREES FAHRENHEIT (CONVERTED FROM °C)

WBT IS READ FROM PSYCHROMETRIC CHART
CORRESPONDING TO GIVEN DBT & DPT.

APPENDIX A-1-6

AVERAGE MONTHLY TEMPERATURES (1975)

	NOVEMBER					DECEMBER				
Time	DBT		DPT		WBT	DBT		DPT		WBT
	°C	°F	°C	°F	°F	°C	°F	°C	°F	°F
1am	10.0	50.0	5.4	41.7	45.3	4.5	40.1	-0.9	30.4	36.0
3am	9.0	48.2	5.3	41.7	45.0	3.7	38.7	-1.0	30.2	34.9
5am	8.1	46.6	4.8	40.6	43.8	3.6	38.5	-1.0	30.2	34.7
7am	8.0	46.4	4.9	40.8	43.5	3.1	37.6	-1.2	29.8	34.0
8 am	8.3	46.9	5.1	41.2	44.0	3.1	37.6	-1.4	29.5	33.9
10 am	12.0	53.6	6.3	43.3	48.2	5.6	42.1	-0.6	30.9	37.2
12 noon	15.3	59.5	6.6	43.9	56.0	8.3	46.9	-0.4	31.3	40.2
2 pm	16.7	62.1	6.2	43.2	51.8	10.0	50.0	-0.2	31.6	41.5
4 pm	16.6	61.9	6.3	43.3	51.6	10.2	50.4	-0.6	30.9	41.5
6 pm	14.1	57.4	6.4	43.5	50.0	7.7	45.9	-0.8	30.6	39.2
8 pm	12.3	54.1	6.4	43.5	48.5	6.5	43.7	-1.1	30.0	37.5
10 pm	11.4	52.5	6.2	43.2	47.5	5.3	41.5	-1.2	29.8	36.2
12 midnight	10.3	50.5	5.5	41.9	46.0	4.8	40.6	-0.8	30.6	36.2

DBT = DRY BULB TEMPERATURE

DPT = DEW POINT TEMPERATURE

WBT = WET BULB TEMPERATURE

°C = DEGREES CELCIUS (FROM WEATHER TAPE)

°F = DEGREES FAHRENHEIT (CONVERTED FROM °C)

WBT IS READ FROM PSYCHROMETRIC CHART
CORRESPONDING TO GIVEN DBT & DPT.

APPENDIX A-2

DISPLACEMENT

(Ref. Section 2.2)

APPENDIX A2

DISPLACEMENT

Displacements were calculated for a number of other collector/field options. The methodology for calculating the displacement was basically the same as that described for the baseline system in Section 2.2 of this report. Figures A2-1 through A2-5 present field performance data for several combinations of collectors and field orientations and spacing. These figures compare the initial collector/field options which were limited to two types of collectors: parabolic trough and linear fresnel lens. Field performance was determined for several different parabolic collector orientations (North-South and East-West horizontal and North-South tilted at latitude) and two different packing factors (ground cover ratio - GCR) for the North-South tilted and the fresnel. All of these collector/field options were limited to $17,199 \text{ m}^2$ (4.25 acres) field size, as compared to the $14,694 \text{ m}^2$ (3.631 acre) field in the baseline.

The facility demand was based on an initial estimate of demand as shown in Table A2-1. This demand differs somewhat from the baseline demand in that it does not utilize an economizer cycle during the spring, fall and winter seasons for reduction of air conditioning load. Also, shown in this table are the pertinent power conversion system parameters. This data also differs from the baseline in that the baseline power conversion meets all of the electrical demand by rejecting a portion of the cycle heat in an air cooled condenser while the initial system relied entirely on the process heat and absorption cooling as a condenser load. Thus, less than 100 percent of the electric load was produced as noted in the table. For this reason, the calculation of facility demand used in determining displacement differed slightly for the baseline case as follows:

Baseline

$$\text{demand} = \text{Power conversion load} \times 16 \text{ hrs}$$

Initial

$$\text{demand} = \text{Power conversion load} \times 16 \text{ hrs} + \text{nonproduced electricity for 16 hrs}$$

DAC 2/5/77 7/6/77 7/11/77

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG. A2-1

DAC 7/5/77 7/6/77 7/11/77

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG. A2-2

DAC 7/5/77 2/4/77 7/11/77

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG. A2-3

DAL 7/8/77 7/6/77 7/11/77

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG A2-4

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG A2-5

TABLE A2-1

INITIAL
SIZING LOADS

<u>FACILITY</u>	<u>JULY</u>	<u>OCT-APRIL</u>	<u>DEC</u>
ELECTRICAL	383.4 KW	383.4 KW	383.4 KW
NIGHT HEATING	0	31.21 KW (106,500 BTU/HR)	97.55 KW (332,900 BTU/HR)
AIR CONDITIONING	220.05 TONS	213 TONS	65.57 TONS
PROCESS STEAM	0.2772 KG/SEC @ 786,000 PA (2,200 LB/HR @ 114 PSIA)		

POWER CONVERSION

DAILY LOADS - GIGA JOULES	125.92	124.73	75.65
(10 ⁶ BTU)	(119.36)	(118.24)	(71.71)
AVERAGE COLLECTOR	281.7	277	277
TEMPERATURE °C/(°F)	(539.1)	(530.6)	(530.6)
PERCENT ELECTRICAL			
DEMAND FURNISHED	51.6	96.5	96.7

where nonproduced electricity equals

(1- percent electricity produced) x ELECTRICITY required
in consistent energy units

The seasonal and annual displacement for each of the initial collection/field options is shown in Figures A2-6 through A2-11. The electrical and process-absorption heating displacements differ numerically from the overall seasonal displacements because of the power conversion system's varying electrical output (always less than facility electrical demand). As in the baseline, the annual displacement is the numerical average of the seasonal displacements. The displacement, along with the required fuel oil energy and purchased electricity to bring the total output up to the facility demand, is summarized in Table A2-2. On the basis of this initial comparison, the N-S horizontal parabolic trough was selected as the baseline collector/field system.

Two additional collectors (the SLATS and the fresnel rotary array) were analyzed. The SLATS performance was determined using two different optical efficiencies. The rotary array was analyzed at two different ground cover ratios (GCR). The performance of these collector/field options is shown in Figures A2-12 through A2-16. Also shown, for comparison, is the performance of the baseline collector field (N-S horizontal parabolic trough GCR - 0.464). The displacement for these collector/field options are summarized in Table A2-3 along with the fossil fuel energy and purchased electricity. These displacements are also based on the initial estimates of facility demand and the power conversion system parameters shown in Table A2-1.

LSE #2 STES #1 SOLAR DISPLACEMENT

EAST-WEST HORIZONTAL PARABOLIC TROUGH GCR = 0.464




FIG. A2-6

LSE #2 STES #1 SOLAR DISPLACEMENT

NORTH-SOUTH-HORIZONTAL PARABOLIC TROUGH GCR=0.464




FIG. A2-7

LSE #2 STES #1 SOLAR DISPLACEMENT

NORTH-SOUTH-POLAR PARABOLIC TROUGH GCR = 0.463




FIG. A2-8

LSE #2 STES #1 SOLAR DISPLACEMENT

NORTH-SOUTH-POLAR PARABOLIC TROUGH

GCR=0.313




FIG. A2-9

LSE #2 STES #1 SOLAR DISPLACEMENT

2-AXIS FRESNEL GCR=0.463




FIG A2-10

LSE #2 STES #1 SOLAR DISPLACEMENT

2 AXIS FRESNEL GCR = 0.314




FIG A2-11

TABLE A2-2

INITIAL

SOLAR DISPLACEMENT SUMMARY

COLLECTOR FIELD	ANNUAL DISPLACEMENT	(PERCENT OF FACILITY DEMAND)			
		SEASONAL DISPLACEMENT			
		WINTER	SPRING	SUMMER	FALL
1. E-W HORIZONTAL PARABOLIC TROUGH GCR = 0.464	22,953 ¹ 234 ² 36.2 ³	3,803 193 32.9	5,654 14 44.3	6,704 13 34.3	6,792 14 33.2
2. N-S HORIZONTAL PARABOLIC TROUGH GCR = 0.464	20,178 234 41.5	5,157 193 13.9	3,800 14 62.3	4,088 13 59.7	7,133 14 29.9
3. N-S POLAR PARABOLIC TROUGH GCR = 0.463	21,747 234 38.0	4,861 193 18.1	3,971 14 60.7	6,374 13 37.5	6,541 14 35.6
4. N-S POLAR PARABOLIC TROUGH GCR = 0.313	26,116 234 27.4	4,816 193 18.7	6,052 14 40.4	7,671 13 24.9	7,577 14 25.6
5. TWO AXIS NORTH-SOUTH FRESNEL GCR = 0.463	21,452 234 38.6	4,941 193 16.9	3,993 14 60.4	5,851 13 42.5	6,667 14 34.4
6. TWO AXIS NORTH-SOUTH FRESNEL GCR = 0.313	25,341 234 29.6	4,531 193 22.7	6,018 14 40.7	7,284 13 28.6	7,508 14 26.2

¹Fossil fuel energy in giga Joules (80% heater efficiency) 1 BBL #2 fuel oil contains 6.145 giga Joules

²Purchased electricity (MW-HR)

³Solar displacement

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG. A2-12

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG. A2-13

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG A2-14

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)




FIG. A2-15

DAILY COLLECTOR FIELD OUTPUT (GIGA JOULES/DAY)


FIG A2-16
1-1-76

TABLE A2-3
ALTERNATE COLLECTORS
SOLAR DISPLACEMENT SUMMARY
(4.25 ACRE FIELD)

COLLECTOR FIELD	ANNUAL DISPLACEMENT	PERCENT OF FACILITY DEMAND			
		WINTER	SPRING	SUMMER	FALL
1. N-S Horizontal Trough GCR = 0.464	41.5 20,178 ¹ 234 ²	13.9 5,157 193	62.3 3,800 14	59.7 4,088 13	29.9 7,133 14
2. Rotating Array GCR = 0.313	38.8 21,736 234	28.1 4,145 193	52.0 4,858 14	40.1 6,101 13	34.8 6,632 14
3. Rotating Array GCR = .353	43.0 20,062 234	30.4 3,985 193	58.7 4,175 14	45.3 5,566 13	37.6 6,336 14
4. SLATS Reduced Opt. Factor GCR = 0.464	42.9 20,343 234	37.8 3,457 193	53.6 4,699 14	40.1 6,101 13	40.1 6,086 14
(5. SLATS Sheldahl Predictions GCR = 0.464)	55.1 15,675 234	48.9 2,666 193	67.8 3,243 14	51.9 4,884 13	51.8 4,882 14

Purchased fossil fuel and electricity to meet portion of facility demand not supplied by solar.

1. Fossil fuel in giga Joules (assumes 80 percent heater η) 1BBL #2 fuel oil contains 6.145 giga Joules
2. Electricity in MW-hr

APPENDIX A-3

UTILITY RATES

(Ref. Section 2.2)

GEORGIA POWER COMPANY

SCHEDULE GS-3

<u>kWh Range</u>	<u>Correction Factor</u>		<u>¢/kWh</u>
0 - 25	\$ 3.05	+	.00¢, plus F.A.
26 - 100	1.30	+	7.0 ¢, plus F.A.
101 - 1500	3.12	+	5.18¢, plus F.A.
1501 - 10000	15.87	+	4.33¢, plus F.A.
10001 - 200000	148.87	+	3.0 ¢, plus F.A.
200001 - Over	1148.87	+	2.5 ¢, plus F.A.

Add Sales Tax and Excess Reactive Charge of \$0.20/RKVA When Applicable

Over 200 Hours Use

<u>kW Range</u>	<u>Correction Factor</u>		<u>\$/kW</u>		<u>¢/kWh</u>
5 - 7	\$ 3.12	+	\$8.64	+	.86¢, plus F.A.
8 - 50	15.87	+	6.94	+	.86¢, plus F.A.
51 - 1000	148.87	+	4.28	+	.86¢, plus F.A.
1001 - Over	1148.87	+	3.28	+	.86¢, plus F.A.

Add Sales Tax and Excess Reactive Charge of \$0.20/RKVA When Applicable

Over 400 Hours Use

<u>kW Range</u>	<u>Correction Factor</u>		<u>\$/kW</u>		<u>¢/kWh</u>
5 - 7	\$ 3.12	+	\$9.60	+	.62¢, plus F.A.
8 - 50	15.87	+	7.90	+	.62¢, plus F.A.
51 - 1000	148.87	+	5.24	+	.62¢, plus F.A.
1001 - Over	1148.87	+	4.24	+	.62¢, plus F.A.

Add Sales Tax and Excess Reactive Charge of \$0.20/RKVA When Applicable

Minimum Bill: \$3.05 per kW of billing demand less \$12.20 plus fuel adjustment

GEORGIA POWER COMPANY
Schedule of Fuel Adjustment Rates (FA-1)
(Cents Per KWH)

1977

<u>Sales Month</u>	<u>Fuel Adjustment Rate</u>
January 1977	1.113
February 1977	1.048
March 1977	0.860
April 1977	0.932
May 1977	0.863
June 1977	0.698
July 1977	0.887
August 1977	1.056
September 1977	0.799*
October 1977	0.803*
November 1977	0.801*
December 1977	0.848*

*Estimated

E.T.H.
8/3/77

ATLANTA GAS LIGHT COMPANY

APPENDIX A-3c

N-2 SHORTCUT
(12-9-76)
$$T_A = \text{AIR COND THERMS} \quad T_0 = \text{OTHER THERMS} \quad T = T_A + T_0 = \text{TOTAL THERMA}$$

I. GAS AIR COND. CUSTOMERS

A. IF TOTAL THERMS = 50 USE SCHEDULE II.

B. OCTOBER - APRIL (INCLUSIVE):

<u>RANGE (T)</u>	<u>corr</u> <u>FACTOR</u>		<u>\$/T</u>		<u>ADJ</u>		<u>ST</u>
0-4	2.50	+	0	+	ADJ	+	ST
4-20	1.916	+	.146	+	ADJ	+	ST
20-600	2.736	+	.105	+	ADJ	+	ST
OVER 600	13.536	+	.087	+	ADJ	+	ST

C. MAY - SEPTEMBER (INCLUSIVE):

<u>RANGE(TO)</u>	<u>CORR</u> <u>FACTOR</u>		<u>\$/T₀</u>		<u>\$/ (50-T₀)</u>		<u>\$/ (T-50)</u>		<u>S/T_A</u>	<u>ADJ</u>		<u>ST</u>	
0-50	2.736	+	.105	+	.105	+	.076	+	0	ADJ	+	ST	
50-600	2.736	+	.105	+	0	+	0	+	.076	+	ADJ	+	ST
OVER 600	13.536	+	.087	+	0	+	0	+	.076	+	ADJ	+	ST


II. NON GAS AIR COND CUSTOMERS


<u>RANGE(T)</u>	<u>CORR FACTOR</u>		<u>\$/T</u>		<u>ADJ</u>		<u>ST</u>
0-4	2.50	+	0	+	ADJ	+	ST
4-20	1.916	+	.146	+	ADJ	+	ST
20-600	2.736	+	.105	+	ADJ	+	ST
OVER-600	13.536	+	.087	+	ADJ	+	ST

GAS USED FOR SPACE HEATING ONLY SHALL NOT AVERAGE LESS THAN \$0.13 PER THERM PLUS GAS ADJUSTMENT PLUS SALES TAX.


APPENDIX B1

DRAWINGS (SHADOW STUDIES)
(Ref. Section 3.1)





KNITWEAR
PLANT



10' SANITARY SEWER EASEMENT

12' PERIMETER ROAD

940

COLLECTOR FIELD

12' PERIMETER ROAD

42

HEAT
EXCH.

18' HI
18' HI

THERMAL STOR.

STE/LSE
POWER PLANT
22' HIGH

PARKING
CLG. TOWER

2 PM
4 PM
5 PM

6 PM

5 PM
6 PM
4 PM

2.0%

44

22' ACCESS ROAD

110'


500.52

PLANT LOCATION / SHADOW STUDY
SUMMER SOLSTICE
SCALE: 1" = 50'

SK. MIB
7-28-77


B1-2






PLANT LOCATION / SHADOW STUDY
WINTER SOLSTICE
SCALE: 1" = 50'

SK MIC
7-28-77





AREAS

TRACT	4.946
STE/LSE PLANT AREA	0.354
PERIMETER ROADS EASEMENT & GRADING	0.851
COLLECTOR FIELD	3.741



PLANT LOCATION / SHADOW STUDY
EQUINOX
SCALE: 1" = 50'



SK. M2A
7-28-77



PLANT LOCATION / SHADOW STUDY
SUMMER SOLSTICE
SCALE: 1" = 50'


SK. M2B
7-28-77

B1-5



PLANT LOCATION / SHADOW STUDY
WINTER SOLSTICE
SCALE: 1" = 50'


SK. M 2 C
7-28-77




PLANT LOCATION / SHADOW STUDY
EQUINOX
SCALE: 1" = 50'

SK. M3A
7-28-77

BI-7





SK M3C
7-28-77

APPENDIX B2

POWER CONVERSION SYSTEM SEASONAL DESIGN LOAD SUMMARY

The following is the analysis resulting in the loads used to size the power conversion system. The results of this analyses were used in Section 3.2.3 of the report.

Power Conversion System Thermal Design Load Summary

The following is the analysis resulting in the loads used to size the power conversion system. The results of this analysis were used in Section 3.7.3 of the report.

LSE #2 LOAD SUMMARY

8-2-77

D

JANUARY

NIGHT HEATING LOAD = 105195 BTU/Hr

COOLING LOAD W/ ECONIMIZER = 0

✓ ✓ W/O ✓ = 150.78 TONS = 1.809×10^6 BTU/Hr

ELECT LOAD (NET) = 383.4 KW = 1.308×10^6 BTU/Hr

✓ ✓ @ TURBINE = 479.3 KW = 1.465×10^6 BTU/Hr

PROCESS STEAM = 2.27×10^6 BTU/Hr

APRIL

NIGHT HEATING LOAD = 34650 BTU/Hr

COOLING LOAD W/ ECONIMIZER = 35 TONS = 42000 BTU/Hr

COOLING LOAD W/O ECONIMIZER = 169 TONS = 202800 BTU/Hr

ELECT LOAD (NET) = 383.4 KW = 1.308×10^6 BTU/Hr

✓ ✓ @ TURBINE = 479.3 KW = 1.465×10^6 BTU/Hr

PROCESS STEAM = 2.27×10^6 BTU/Hr

JULY

NIGHT HEATING LOAD = 0

COOLING LOAD W/ ECONIMIZER = 215.78 TONS = 2.5893×10^6 BTU/Hr

COOLING LOAD W/O ECONIMIZER = 215.78 TONS = 2.5893×10^6 BTU/Hr

ELECTRICAL LOAD NET = 383.4 KW = 1.308×10^6 BTU/Hr

✓ ✓ @ TURBINE = 479.3 KW = 1.465×10^6 BTU/Hr

PROCESS STEAM LOAD = 2.27×10^6 BTU/Hr

OCTOBER

NIGHT HEATING LOAD = 54850 BTU/Hr

COOLING LOAD W/ ECONOMIZER = 48.4 TONS = 581333 BTU/Hr

✓ ✓ W/O ✓ = 171.33 TONS = 2.056 X 10⁶ BTU/Hr

ELECT LOAD NET = 383.1 KW = 1.305 X 10⁶ BTU/Hr

✓ @ TURBINE = 479.3 KW = 1.45 X 10⁶ BTU/Hr

PROCESS STEAM = 2.27 X 10⁶ BTU/Hr

DECEMBER

HEAT LOSS THROUGH ROOF = 142925 BTU/Hr

COOLING LOAD W/ ECONOMIZER = 0

COOLING LOAD W/O ECONOMIZER = 147.67 TONS = 1.77 X 10⁶ BTU/Hr

ELECT LOAD NET = 383.4 KW = 1.308 X 10⁶ BTU/Hr

✓ @ TURBINE = 479.3 KW = 1.465 X 10⁶ BTU/Hr

PROCESS STEAM LOAD = 2.27 X 10⁶ BTU/Hr

NIGHT HEATING LOAD

$$\text{JANUARY} = \frac{107 + 112 + 170 + 157}{4} = 115250 \text{ BTU/Hr}$$

$$\text{APRIL} = \frac{97 + 26 + 40 + 40}{4} = 42500 \text{ BTU/Hr}$$

$$\text{JULY} = 0$$

$$\text{OCTOBER} = \frac{75 + 55 + 70 + 77}{4} = 66500 \text{ BTU/Hr}$$

$$\text{DECEMBER} = \frac{157 + 150 + 110 + 140}{4} = 149750 \text{ BTU/Hr}$$

WEEK ENDS =

$$\text{DATELINE JAN} = \frac{130 + 10 + 4.6 + 70.6}{4} = 61300 \text{ BTU/Hr}$$

$$\text{APRIL} = 0$$

$$\text{JULY} = 0$$

$$\text{OCTOBER} = 20750 \text{ BTU/Hr}$$

$$\text{DECEMBER} = 95250 \text{ BTU/Hr}$$

WEEK FOR CYCLE

$$\text{JANUARY} = \frac{115250 \times 8 \times 5 + 61300 \times 16 \times 2 + 115250 \times 8 \times 2}{5 \times 16} = 1051950$$

$$\text{APRIL} = \frac{49500 \times 5 \times 8 + 40500 \times 2 \times 8}{5 \times 16} = 34650$$

$$\text{JULY} = 0$$

$$\text{OCTOBER} = \frac{66500 \times 5 \times 8 + 20750 \times 16 \times 2 + 66500 \times 2 \times 8}{5 \times 16} = 111150$$

$$\text{DECEMBER} = \frac{149750 \times 5 \times 8 + 95250 \times 16 \times 2 + 149750 \times 8 \times 2}{5 \times 16} = 1429500$$

COOLING LOAD WITH ECONOMIZER

JANUARY = 0

APRIL = 35 Tons = 420000 BTU/Hr

JULY = 215.78 Tons = 2.5893×10^6 BTU/Hr

OCTOBER = 48.44 Tons = 581333 BTU/Hr

DECEMBER = 0

COOLING LOAD W/O ECONOMIZER

JANUARY = 150.78 Tons = 1.809×10^6 BTU/Hr

APRIL = 169.11 Tons = 2.029×10^6 BTU/Hr

JULY = 215.78 Tons = 2.5893×10^6 BTU/Hr

OCTOBER = 171.33 Tons = 2.056×10^6 BTU/Hr

DECEMBER = 143.67 Tons = 1.722×10^6 BTU/Hr

ELECTRICAL LOAD (REQUIREMENT)

NET = 383.4 KW

AT TURBINE $\frac{383.4}{.95 \times .44} = 429.3 \text{ KW} = 1.465 \times 10^6 \text{ BTU/Hr}$

PROPOSED STEAM LOAD = $2.27 \times 10^6 \text{ BTU/Hr}$

APPENDIX B3

APPENDIX B3


AVERAGE COLLECTOR TEMPERATURE OPTIMIZATION STUDY

The following is the analysis used in a study to determine optimum flow rate ratios across the Therminol 66 to toluene heat exchanger to minimize the average collector temperature. The results of this analysis are presented in Section 3.2.3.

Average Collector Temperature Optimization Study

The following is the analysis used in a study to determine optimum flow rate ratios across the Thermomol 66 to toluene heat exchanger to minimize the average collector temperature. The results of the analysis is presented in Section 3.2.3

AVERAGE COLLECTOR TEMPERATURE OPTIMIZATION STUDY



WHERE

T_{D1} = COLLECTOR SUPPLY TEMP

T_{D2} = COLLECTOR RETURN TEMP

T_{F1} = TURBINE INLET TEMPERATURE

T_{F2} = FEED WATER RETURN TEMP

$$T_{DAV} = \frac{T_{D1} + T_{D2}}{2}$$

WHEN $C_{MIN} = TOLUENE$

$$E_{TOT} = \frac{T_{F1} - T_{F2}}{T_{D1} - T_{F2}} \quad \& \quad C_{RAT} = \frac{T_{D1} - T_{D2}}{T_{F1} - T_{F2}}$$

$$T_{D1} = T_{F2} + \frac{(T_{F1} - T_{F2})}{E_{TOT}}$$

$$T_{D2} = T_{D1} - (T_{F1} - T_{F2}) C_{RAT}$$

$$T_{D2} = T_{F2} + \frac{(T_{F1} - T_{F2})}{E_{TOT}} - C_{RAT} (T_{F1} - T_{F2})$$

$$T_{D2} = T_{F2} + \left[\frac{1 - E_{TOT} C_{RAT}}{E_{TOT}} \right] (T_{F1} - T_{F2})$$

$$T_{DAV} = \left(\frac{T_{D1} + T_{D2}}{2} \right) = T_{D2} + \left[\frac{2 - E_{TOT} C_{RAT}}{2 E_{TOT}} \right] (T_{F1} - T_{F2})$$

WHEN $C_{MIN} = HT \text{ FLUID}$

$$E_{TOT} = \frac{T_{D1} - T_{D2}}{T_{D1} - T_{F2}} \quad \& \quad C_{RAT} = \frac{T_{F1} - T_{F2}}{T_{D1} - T_{D2}}$$

$$T_{D1} = T_{D2} + \frac{(T_{F1} - T_{F2})}{C_{RAT}}$$

$$T_{D2} = T_{D1} - (T_{D1} - T_{F2}) E_{TOT}$$

$$T_{D2} = T_{D2} + \frac{(T_{F1} - T_{F2})}{C_{RAT}} - (T_{D1} - T_{F2}) E_{TOT}$$

$$T_{D1} = T_{F2} + \frac{(T_{F1} - T_{F2})}{E_{TOT} C_{RAT}}$$

$$T_{D2} = T_{F2} + \frac{(T_{F1} - T_{F2})}{E_{TOT} C_{RAT}} - \left[\frac{T_{F2} + \frac{(T_{F1} - T_{F2})}{E_{TOT} C_{RAT}} - T_{F2}}{E_{TOT} C_{RAT}} \right] E_{TOT}$$

$$T_{D2} = T_{F2} + \left[\frac{1 - E_{TOT}}{E_{TOT} C_{RAT}} \right] (T_{F1} - T_{F2})$$

$$T_{DAV} = \left(\frac{T_{D1} + T_{D2}}{2} \right) = T_{F2} + \left[\frac{2 - E_{TOT}}{2 E_{TOT} C_{RAT}} \right] (T_{F1} - T_{F2})$$

NTU = 2 3 PASS HX

Wt Cpr U ₁	$\frac{T_{DAV} - T_{T2}}{T_{T1} - T_{T2}}$	E _{TOT}	E _{PASS}
.2	.9086	.9915	.8160
.4	.8743	.9762	.7646
.6	.7577	.9454	.7130
.8	.7173	.8950	.6629
1	.7083	.8776	.6154
1.2	.75630	.8848	.6548
1.4	.8234	.9190	.6841
1.6	.9018	.9402	.7066
1.8	.9870	.9539	.7212
2.0	1.0765	.9631	.7388

2.2	1.1689	.9696	.7505
2.4	1.2652	.9744	.7603

NTU = 3 3 PASS HX

.2	.9011	.9799	.9086
.4	.8063	.9938	.8567
.6	.7243	.9762	.7993
.8	.6694	.9351	.7408
1.0	.6587	.8630	.6842
1.2	.6967	.9254	.7311
1.4	.7642	.9562	.7458
1.6	.8451	.9726	.7920
1.8	.9333	.9818	.8123
2.0	1.0758	.9873	.8284
2.2	1.1657	.9907	.8411
2.4	1.2171	.9929	.8521

NTU = 4 3 PASS

Wt Cpr U ₁	$\frac{T_{DAV} - T_{T2}}{T_{T1} - T_{T2}}$	E _{TOT}	E _{PASS}
.2	.9002	.9998	.9513
.4	.8020	.9980	.9045
.6	.7125	.9877	.8467
.8	.6480	.9542	.7846
1	.6282	.8864	.7235
1.2	.6694	.9153	.7743
1.4	.7397	.9724	.8114
1.6	.7742	.9851	.8391
1.8	.9157	.9914	.8551
2.0	1.0059	.9981	.9150
2.4	1.2057	.9976	.9000

NTU = 5 3 PASS

.2	.9000	.9997	.9775
.4	.8008	.9992	.9319
.6	.7073	.9927	.8758
.8	.6564	.9649	.8174
1.0	.6149	.8969	.7490
1.2	.6542	.9578	.8017
1.4	.7274	.9808	.8399
1.6	.8147	.9709	.8651
1.8	.9085	.9953	.8892
2.0	1.0052	.9973	.9053
2.2	1.1054	.9985	.9178
2.4	1.2023	.9990	.9277

APPENDIX B4

SYSTEM OPERATING TEMPERATURE OPTIMIZATION STUDY

The following is the analysis, from the power conversion system side, used in conjunction with a similar study for the solar collector system to determine the optimum temperature for operating the collector/power conversion system to maximize total system performance.

The results of this study are discussed in Section 3.2.3.

Air-Cool Operating Temperature Optimization Study.

The following is the analysis, from the power conversion system side, used in conjunction with a similar study for the solar collector system to determine the optimum temperature for operating the condenser / power conversion system to maximize total system performance.

The results of this study are discussed in Section 5.1.2.

SYSTEM OPERATING TEMP
OPTIMIZATION STUDY
(POWER CONVERSION)

NO OF	TR OF	CHILLER EFF NO	NETEE (INVERTER) / UNIT	HP	TD OF	TD	TELEC AU	1/2 0.75 0.50	% STATION 49.3 KW	REACT 220.05 1500 VC	ADJ TON	TOTAL ELECT (PUL) SEPERATE VC	Q545 BTU (10 ⁶)	US45 #/12
PER	725	LT.185	.159	24.62										
		ST.276	.256	30.54	750	515.5	637.8		100%	2875	191.8	457.09	7.118	37072
		LT.169	.141	26.74										
TOTAL	650	ST.256	.235	35.08	671.2	441.8	556.5		100%	7.39	212.66	436.56	7.401	35674
		LT.159	.130	26.79										
	675	ST.244	.222	36.80	646.2	411.8	532.0		96.7%	0	220.05	415.32	7.480	37200
B4-4		LT.157	.134	21.86										
	675	ST.248	.230	30.90	646.1	679.1	571.9		100%	1.50	218.55	430.77	7.49	40391
		LT.145	.126	16.95										
	550	ST.216	.214	20.49	568	567.66	546.9		92.6%	0	220.5	371.59	7.40	38587

SMALL TURBINE

$$T_{\text{COND}} = 200^{\circ}\text{F} \quad P_{\text{COND}} = 8.70878 \text{ psia}$$

$$T_{\text{S}} = 478.9^{\circ}\text{R} \quad h_{\text{S}} = 5.4473 \text{ BTU/lb} \quad \eta_{\text{T}} = .74 \quad \text{NTU}_{\text{S}} = 4 \quad 3 \text{ PIES}$$

$$T_{\text{VS}} 530.06^{\circ}\text{F} \quad h_{\text{VS}} = 29.2177 \text{ BTU/lb} \quad \text{COT} = .79 \quad L_{\text{FAS}} = .57889$$

$$L_{\text{TOT}} = .85082 \quad P_{\text{S}} = 50 \text{ #/hr} = \Delta P_{\text{PUMP}} = 700 \text{ psia}$$

$$T_{\text{S}} = 757.18^{\circ}\text{F} \quad T_{\text{S}} = 478.9^{\circ}\text{R} = h_{\text{S}} = -15.1458 \text{ BTU/lb} \quad T_{\text{C}} = 427.57^{\circ}\text{F} \quad h_{\text{C}} = -11.5415$$

$$T_{\text{PUMP}} = 205.79^{\circ}\text{F} \quad h_{\text{PUMP}} = -26.5727 \text{ BTU/lb} \quad \Delta h_{\text{PUMP}} = 4.3188 \text{ BTU/lb}$$

$$\eta_{\text{C}} = .27566 \quad \Delta h_{\text{PUMP}} @ \text{TURBINE} = 4.3188 = 4.8363 \text{ BTU/lb}$$

$$\eta_{\text{NET}} = .25595 \text{ (INCLUDING PUMP)} \quad .95 \times .94$$

SPITE

$$\text{COT} = .79 \quad \eta_{\text{C}} = .27566 \quad @ \text{TURBINE} = 4 \times .95 \times .94 = 5.57$$

LARGE TURBINE

$$\text{SEP ELECT. (GENERATED)} = 514934 \text{ BTU/hr} = 150.88 \text{ KW} @ \text{TURBINE}$$

$$Q_{\text{SYS}} = 2.785106 \text{ BTU/hr} \quad W_{\text{SYS}} = 14514 \text{ #/hr}$$

SMALL TURBINE

$$\text{SEP ELECT. (COND)} = 4793 - 150.88 = 278.12 \text{ KW} = 950164 \text{ BTU/hr}$$

$$\text{SEP ELECT. (TURB)} = 950164 \text{ BTU/hr} = 268.44 \text{ KW} @ \text{TURBINE}$$

$$\text{ELECTRIC (GEN FOR VC)} P_{\text{GEN}} = 165008 \text{ BTU/hr} = 48.35$$

$$P_{\text{GEN}} = 49.12 \text{ TONS} \quad Q_{\text{WSS}} = 2.950 \times 10^6 \text{ BTU/hr} \quad P_{\text{GEN}} = 170.93 \text{ TONS}$$

$$W_{\text{ABS}} = 16483 \text{ #/hr} \quad Q_{\text{SYS}} = 4.045156 \text{ BTU/hr} \quad W_{\text{SYS}} = 16483 \text{ #/hr}$$

CALCULATE T_{MIN} & L_{MIN}

$$L_{\text{MIN}} = -118.1459 \text{ BTU/lb} \quad T_{\text{MIN}} = 32185 \text{ #/hr} \quad T_{\text{MIN}} = 478.9^{\circ}\text{R}$$

$$Q_{\text{TOT}} = 6.83 \times 10^6 \text{ BTU/hr}$$

$$\eta_{\text{C}} = \frac{Q_{\text{GEN}} + Q_{\text{FAS}}}{Q_{\text{TOT}}} = \frac{514934 + 1.115 \times 10^6}{6.83 \times 10^6}$$

LARGE TURBINE
 $T = 650^{\circ}\text{F}$ $P = 700\text{ PSI}$ $h_v = 41.7735605$ $S_v = .037272$

$T_{\text{COND}} = 350^{\circ}\text{F}$ $P_{\text{COND}} = 76.019547$

$T_2 = 477.36^{\circ}\text{F}$ $h_{s2} = 1143.68 \text{ BTU/lb}$

$T_2 = 499.89^{\circ}\text{F}$ $h_{s2} = 11.9750$ $E_{\text{PASS}} = .57888$ $E_{\text{TOT}} = .85082$

$T_3 = 375.12^{\circ}\text{F}$ $T_5 = 416.87^{\circ}\text{F}$ $h_5 = -137.1494 \text{ BTU/lb}$ $T_6 = 451.31^{\circ}\text{F}$ $h_6 = -134.4758 \text{ BTU/lb}$

$T_P = 353.24^{\circ}\text{F}$ $h_P = -190.7910 \text{ BTU/lb}$ $\Delta h_{\text{pump}} = 4.4559 \text{ BTU/lb}$

$\eta_c = .16955$ $\Delta h_{\text{pump @ TURBINE}} = \frac{4.4559}{.95214} = 4.6898 \text{ BTU/lb}$

$\eta_{\text{NET}} = .14104 \text{ (PUMP INCLUDED)}$

SMALL TURBINE

$T_1 = 650^{\circ}\text{F}$ $P_1 = 700\text{ PSI}$ $h_{v1} = 41.7735605 \text{ BTU/lb}$ $S_{v1} = .037272$

$T_{\text{COND}} = 200^{\circ}\text{F}$ $P_{\text{COND}} = 8.70878 \text{ PSI}$

$T_{s2} = 379.69^{\circ}\text{F}$ $h_{s2} = -377.16 \text{ BTU/lb}$

$T_2 = 428.32^{\circ}\text{F}$ $h_{s2} = -10.5575 \text{ BTU/lb}$ $E_T = .5722$ $E_{\text{TOT}} = .82920$

$T_3 = 239.89^{\circ}\text{F}$ $T_5 = 352.64^{\circ}\text{F}$ $h_5 = -191.1208$ $T_6 = 357.55^{\circ}\text{F}$ $h_6 = -188.5396 \text{ BTU/lb}$

$T_P = 205.79^{\circ}\text{F}$ $h_P = -766.5277 \text{ BTU/lb}$ $\Delta h_{\text{pump}} = 4.3182$

$\eta_c = .25556$ $\Delta h_{\text{pump @ TURBINE}} = \frac{4.3182}{.95214} = 4.5352 \text{ BTU/lb}$

$\eta_{\text{NET}} = .23455 \text{ (PUMP INCLUDED)}$

$$T_1 = 625^\circ\text{F}$$

④

LARGE TURBINE

$$T_1 = 625^\circ\text{F} \quad P_1 = 700 \text{ PSIA} \quad \dot{Q}_1 = 27.3389 \text{ BTU/hr} \quad \dot{Q}_1 = .0201165$$

$$T_{\text{COND}} = 350^\circ\text{F} \quad P_{\text{COND}} = 71.019547 \text{ PSIA}$$

$$T_{S_2} = 447.71^\circ\text{F} \quad \dot{Q}_{S_2} = -14.3707 \text{ BTU/hr}$$

$$T_2 = 463.73^\circ\text{F} \quad \dot{Q}_2 = -4.7892 \text{ BTU/hr} \quad E_P = .57888 \quad E_{\text{TOT}} = .85082$$

$$T_3 = 369.73^\circ\text{F} \quad T_5 = 423.75^\circ\text{F} \quad \dot{Q}_{S_5} = -15.0762 \text{ BTU/hr} \quad T_6 = 420.31^\circ\text{F} \quad \dot{Q}_6 = -14.8586 \text{ BTU/hr}$$

$$T_P = 353.71^\circ\text{F} \quad \dot{Q}_P = -19.0720 \text{ BTU/hr} \quad \Delta \dot{Q}_{\text{pump}} = 4.4559 \text{ BTU/hr}$$

$$\dot{M}_e = .15919 \quad \Delta \dot{Q}_{\text{pump @ TURBINE}} = \frac{4.4559}{.95594} = 4.9508 \text{ BTU/hr}$$

$$\dot{M}_{\text{NET}} = .12990 \text{ (PUMP INCLUDED)}$$

SMALL TURBINE

$$T_1 = 625^\circ\text{F} \quad P_1 = 700 \text{ PSIA} \quad \dot{Q}_1 = 27.3389 \text{ BTU/hr} \quad \dot{Q}_1 = .0201165$$

$$T_{\text{COND}} = 200^\circ\text{F} \quad P_{\text{COND}} = 8.70897$$

$$T_{S_2} = 346.33^\circ\text{F} \quad \dot{Q}_{S_2} = -51.38812 \text{ BTU/hr}$$

$$T_2 = 392.91^\circ\text{F} \quad \dot{Q}_2 = -32.7152 \text{ BTU/hr} \quad E_P = .57122 \quad E_{\text{TOT}} = .82920$$

$$T_3 = 234.70^\circ\text{F} \quad T_5 = 329.19^\circ\text{F} \quad \dot{Q}_{S_5} = -203.87201 \text{ BTU/hr} \quad T_6 = 354^\circ\text{F} \quad \dot{Q}_6 = -201.28076 \text{ BTU/hr}$$

$$T_P = 203.78^\circ\text{F} \quad \dot{Q}_P = -766.52771 \text{ BTU/hr} \quad \Delta \dot{Q}_{\text{pump}} = 4.315 \text{ BTU/hr}$$

$$\dot{M}_e = .24396 \quad \Delta \dot{Q}_{\text{pump @ TURBINE}} = \frac{4.319}{.95594} = 4.836$$

$$\dot{M}_{\text{NET}} = .22233 \text{ (INCLUDE PUMP)}$$

SMALL TURBINE (SUPERHEATED) (44)

$$T_1 = 1250^\circ\text{F} \quad P = 500 \text{ psia} \quad Q_1 = 49.791 \text{ BTU/hr} \quad S_1 = .048101$$

$$T_{\text{COND}} = 200^\circ\text{F} \quad P_{\text{COND}} = 8.70878$$

$$T_{S_2} = 407.84^\circ\text{F} \quad Q_{S_2} = -28.0118 \text{ BTU/hr}$$

$$T_2 = 449.49^\circ\text{F} \quad Q_2 = -2.95315 \text{ BTU/hr} \quad E_P = .57177 \quad E_{\text{TOT}} = .85970$$

$$T_3 = 242.86^\circ\text{F} \quad T_5 = 366.50^\circ\text{F} \quad Q_{S_5} = -185.1503 \text{ BTU/hr} \quad T_6 = 370.51^\circ\text{F} \quad Q_6 = -18.1156 \text{ BTU/hr}$$

$$T_P = 203.77^\circ\text{F} \quad Q_P = -266.7599 \text{ BTU/hr} \quad Q_{\text{PUMP}} = 3.7756 \text{ BTU/hr}$$

$$M = 5.74826 \quad \Delta h_{\text{pump}} @ \text{TURBINE} = \frac{3.7756}{.95 \times .94} = 4.172 \text{ BTU/hr}$$

$$M_{\text{NET}} = .23016$$

LARGE TURBINE

$$T_1 = 615^\circ\text{F} \quad P = 500 \text{ psia} \quad Q_1 = 49.791 \text{ BTU/hr} \quad S_1 = .048101$$

$$T_{\text{COND}} = 350^\circ\text{F} \quad P_{\text{COND}} = 71.019547 \text{ psia}$$

$$T_{S_2} = 499.52^\circ\text{F} \quad Q_{S_2} = 11.7557 \text{ BTU/hr}$$

$$T_2 = 520.10^\circ\text{F} \quad Q_2 = 21.5 \text{ BTU/hr} \quad E_P = .57882 \quad E_{\text{TOT}} = .85082$$

$$T_3 = 377.70^\circ\text{F} \quad T_5 = 459.50^\circ\text{F} \quad Q_{S_5} = -128.5485 \text{ BTU/hr} \quad T_6 = 425.7^\circ\text{F} \quad Q_6 = -77.7751 \text{ BTU/hr}$$

$$T_P = 352.75^\circ\text{F} \quad Q_P = -191.0726 \text{ BTU/hr} \quad Q_{\text{PUMP}} = 3.7518 \text{ BTU/hr}$$

$$M = .15752 \quad \Delta h_{\text{pump}} @ \text{TURBINE} = \frac{3.7518}{.94 \times .95} = 4.2014 \text{ BTU/hr}$$

$$M_{\text{NET}} = .13358 \text{ (INCLUDES PUMP)}$$

$$T_1 = 550^\circ\text{F}$$

LARGE TURBINE

$$T_1 = 550^\circ\text{F} \quad P = 400 \text{ PSIA} \quad h_1 = 14.27914 \text{ BTU/lb} \quad S_1 = 0.017975 \quad (4D)$$

$$T_{\text{COND}} = 350^\circ\text{F} \quad P_{\text{COND}} = 71.019547 \text{ PSIA}$$

$$T_{5_1} = 438.11^\circ\text{F} \quad h_{5_1} = -16.21707 \text{ BTU/lb}$$

$$T_2 = 485.70 \quad h_2 = -8.3065 \text{ BTU/lb} \quad E_P = .57882 \quad E_{T_2} = .85882$$

$$T_3 = 371.86^\circ\text{F} \quad T_5 = 457.2^\circ\text{F} \quad h_5 = -142.8076 \text{ BTU/lb} \quad T_6 = 457.2^\circ\text{F} \quad h_6 = -142.8076 \text{ BTU/lb}$$

$$T_P = 351.90^\circ\text{F} \quad h_P = -191.5501 \text{ BTU/lb} \quad \Delta h_{\text{pump}} = 2.6079 \text{ BTU/lb}$$

$$\eta_c = .14572 \quad \Delta h_{\text{pump @ TURBINE}} = \frac{2.6079}{.95828} = 2.7204 \text{ BTU/lb}$$

$$\eta_{\text{NET}} = .12645 \quad (\text{INCLUDING PUMP})$$

SMALL TURBINE

$$T_1 = 550^\circ\text{F} \quad P = 400 \text{ PSIA} \quad h_1 = 14.27914 \text{ BTU/lb} \quad S_1 = 0.017975$$

$$T_{\text{COND}} = 200^\circ\text{F} \quad P_{\text{COND}} = 8.70878 \text{ PSIA}$$

$$T_{5_1} = 342.52 \quad h_{5_1} = -52.956 \text{ BTU/lb}$$

$$T_2 = 385.71^\circ\text{F} \quad h_2 = -35.4561 \text{ BTU/lb} \quad E_P = .57127 \quad E_{T_2} = .839.0$$

$$T_3 = 231.55^\circ\text{F} \quad T_5 = 323.51 \quad h_5 = -766.9171 \text{ BTU/lb} \quad T_6 = 323.51^\circ\text{F} \quad h_6 = -766.9171 \text{ BTU/lb}$$

$$T_P = 202.10^\circ\text{F} \quad h_P = -267.7949 \text{ BTU/lb} \quad \Delta h_{\text{pump}} = 2.3881 \text{ BTU/lb}$$

$$\eta_c = .22623 \quad \Delta h_{\text{pump @ TURBINE}} = \frac{2.3881}{.95828} = 2.6743 \text{ BTU/lb}$$

$$\eta_{\text{NET}} = .21420 \quad (\text{INCLUDING PUMP})$$

$T = 70.5^\circ F$

REF SPLIT

LARGE TURBINE

SEPARATE ELECTRICAL GENERATED = $428847 \text{ BTU/HR} = 125.66 \text{ KW}$

$Q_{STR} = 2.699 \times 10^6 \text{ BTU/HR}$ $W_{SYS} = 14066 \text{ #/HR}$

SMALL TURBINE

$Q_{ELECT} \text{ REQ'D} = 1.036 \times 10^6 \text{ BTU/HR} = 303.62 \text{ KW @ TURBINE}$

SEPERATE GEN = $1.036 \times 10^6 \text{ BTU/HR} = 303.62 \text{ KW @ TURBINE}$

TOTAL ELECT = $1.131 \times 10^6 \text{ BTU/HR} = 331.43 \text{ KW @ TURBINE (INC. VC REF)}$

$Q_{VC} = 91905 \text{ BTU/HR}$ $R_{VC} = 28.25 \text{ TONS}$

$Q_{ADS} = 3.722 \times 10^6 \text{ BTU/HR}$ $R_{ADS} = 191.80 \text{ TONS}$

$W_{VLC} = 12006 \text{ #/HR}$ $Q_{SYS} = 4.419 \times 10^6 \text{ BTU/HR}$ $W_{SYS} = 18006$

$$T_1 = 650^\circ\text{F}$$

KCF SPLITS

LARGE TURBINE

$$\text{SEPARATE ELECTRIC GENERATED} = 37731 \text{ BTU/HR} = 109.22 \text{ KW}$$

$$Q_{\text{OYST}} = 7.643 \times 10^6 \text{ BTU/HR} \quad W_{\text{OYST}} = 14994 \text{ #/HR}$$

SMALL TURBINE

$$Q_{\text{ELECT RQD}} = 1.0923 \times 10^6 \text{ BTU/HR}$$

$$\text{SEP FLEET (GEN)} = 1.0923 \times 10^6 \text{ BTU/HR} = 327.74 \text{ KW}$$

$$\text{TOTAL ELECT} = 1.117 \times 10^6 \text{ BTU/HR} = 327.74 \text{ KW (inc. U.C.)}$$

$$Q_{\text{H}_2\text{O}} = 74814 \text{ BTU/HR} \quad P_{\text{H}_2\text{O}} = 7.39 \text{ Tons}$$

$$Q_{\text{H}_2\text{O}} = 3.646 \times 10^6 \text{ BTU/HR} \quad P_{\text{H}_2\text{O}} = 717.2 \text{ Tons}$$

$$W_{\text{H}_2\text{O}} = 20680 \text{ #/HR} \quad Q_{\text{OYST}} = 4.763 \times 10^6 \text{ BTU/HR} \quad W_{\text{OYST}} = 20680 \text{ #/HR}$$

$$T_1 = 675^\circ\text{F}$$

REF SPLITS

LARGE TURBINE

$$\text{SEPARATE ELECTRICAL GEN} = 33859 \text{ BTU/hr} = 99.30 \text{ KW}$$

$$Q_{545} = 2.604 \times 10^6 \text{ BTU/hr} \quad W_{545} = 15308 \text{ #/hr}$$

SMALL TURBINE

$$Q_{\text{ELECT}} \text{ (hr)} = 1.170 \times 10^6 \text{ BTU/hr} = 34.17 \text{ KW}$$

$$Q_{\text{SEPT}} \text{ (hr)} = 1.170 \times 10^6 \text{ BTU/hr} = 34.17 \text{ KW}$$

$$\text{SVC} = 0$$

$$Q_{\text{SEPT}} = 3.772 \times 10^6 \text{ BTU/hr} \quad P_{\text{AES}} = 220.05 \text{ Tons}$$

$$W_{\text{AES}} = 21692 \text{ #/hr} \quad Q_{\text{STE}} = 4.051 \times 10^6 \text{ BTU/hr} \quad W_{\text{STE}} = 21692 \text{ #/hr}$$

675°F

(8)

REF SPLITS (SEQUENTIAL)

LARGE TURBINE

SEPARATE ELECTRICAL GENERATED = $34996 \text{ BTU/HR} = 102.55 \text{ KW}$

$Q_{STE} = 7620 \times 10^6 \text{ BTU/HR}$ $N_{SYS} = 14537 \text{ #/HR}$

SMALL TURBINE

HEAT - REF = $1.115 \times 10^6 \text{ BTU/HR} = 326.75 \text{ KW @ TURBINE}$

HEAT LOSS (HEAT) = $1.115 \times 10^6 \text{ BTU/HR} = 326.75 \text{ KW @ TURBINE}$

TOTAL HEAT - $Q_{HEAT} = 1.120 \times 10^6 \text{ BTU/HR} = 327.75 \text{ KW @ TURBINE (INCL)}$

$Q_{WC} = 5034 \text{ BTU/HR}$ $R_{WC} = 1.50 \text{ TONS}$

$Q_{HDS} = 3.747 \times 10^6 \text{ BTU/HR}$ $R_{HDS} = 218.55 \text{ TONS}$

$W_{ARS} = 21113 \text{ #/HR}$ $Q_{STE} = 4.516 \times 10^6 \text{ BTU/HR}$ $N_{STE} = 21113 \text{ #/HR}$

550°F (SUBCRITICAL)

LARGE TURBINE

SEPARATE ELECTRICAL GENERATED = $3759.15 \text{ MW} = 96.75 \text{ KW}$

$Q_{S15} = 2.598 \times 10^6 \text{ BTU/HR}$ $W_{S15} = 16542 \text{ #/HR}$

SMALL TURBINE

$Q_{ELE} = 1.156 \times 10^6 \text{ BTU/HR} = 330.01 \text{ KW}$

SEP ELECT GEN = $1.078 \times 10^6 \text{ BTU/HR} = 301.31 \text{ KW}$

$Q_{VE} = 0$

$Q_{AB3} = 3.772 \times 10^6 \text{ BTU/HR}$ $R_{AB3} = 220.05 \text{ TONS}$

$W_{AB3} = 21845 \text{ #/HR}$ $Q_{S15} = 4.821 \times 10^6 \text{ BTU/HR}$ $W_{S15} = 21845 \text{ #/HR}$

25

LANGSTURBINE $W_{515} = 14066 \frac{\text{Wh}}{\text{h}} = 9.00 \frac{\text{MWh}}{\text{h}} = 515.91^\circ$

$$Q_{5.5} = 2.690 \cdot 10^6 \text{ t/m}$$

SMALL TURBINE INSTS = 18006 $\frac{1}{2}$ $h_b = -148.52 \text{ D.F.}$ $\frac{1}{2} \text{ TL} = 427.52 \text{ D.F.}$

Q545- 4.419X10⁶ BTU/ft²

$$U_{61112} = -175.0145 \text{ kcal} \quad U_{41112} = 32077 \text{ #/Hz} \quad Q_{TOT} = 2118000 \text{ e}$$

$$\overline{161111} = 466.79 \text{ } ^\circ\text{F}$$

$$K_{\text{OFAIR}} = \frac{428847 + 1.131 \times 10^6}{7.118 \times 10^6} = .21900$$

$$\overline{T} = 65.2^\circ =$$

LONG TERM $\sigma = 11.75 = 1.2 \times 10^8 \text{ Pa}$ $T_L = 451.31^\circ\text{F}$

$$Q_{\text{loss}} = 2.643 \times 10^6 \text{ BTU/hr}$$

Small turbine $W_{547} = 20680 \text{ } \frac{\text{kg}}{\text{hr}}$ $\dot{Q}_4 = -182 \text{ MW}$ $T_6 = 350^\circ \text{F}$

Q505 = $4.76 \times 10^6 \text{ BTU/hr}$

$$I_{6100} = -115.75 \text{ ft-lb} \quad M_{100} = 35674 \frac{\text{ft-lb}}{\text{ft}} \quad Q_{\text{TOTAL}} = 1.68 \frac{\text{ft-lb}}{\text{ft}}$$

$$T_{6414} = 39.54^\circ\text{F} \quad \mu_{\text{OVERALL}} = \frac{372734 \text{ lb} \cdot \text{ft}^2/\text{s}^2}{7.405 \times 10^6} = 0.20115$$

$$T_1 = 675^\circ\text{F}$$

LARGE TURBINE. $\dot{W}_{SHE} = 1508 \text{ kW}$ $\dot{Q}_6 = -158.05 \text{ kJ/s}$ $T_6 = 420^\circ\text{F}$

$$Q_{50} = 2.609 \times 10^6 \text{ STB} \cdot \text{ft}^3$$

FREE TURKINE $W_{50} = 216.9 \text{ g/l}$ $\Delta G = -201.507 \text{ J/g}$ $T_b = 334^\circ \text{C}$

$$C_{p, \text{air}} = 4.871 \times 10^6 \text{ BTU/lb}$$

$$h_{h11} = -19.775 \text{ PT/V} \quad \omega_{h11} = 37000 \text{ rad/s} \quad Q_{h11} = 7.480 \times 10^4$$

$$T_{6114} = 373.02^\circ\text{F} \quad \eta_{\text{eff}} = \frac{357895 + 1.0785 \times 10^6}{7.18 \times 10^6} = .18919$$

1) = 625 °F (SUBSTITUTIONAL)

(11)

LARGE TURBINE

$$\dot{W}_{SYS} = 14837 \text{ #/Hr} \quad \dot{Q}_L = -1772975 \text{ BTU/Hr} \quad T_6 = 463.77^\circ\text{F}$$

$$\dot{Q}_{SYS} = 2.62 \times 10^6 \text{ BTU/Hr}$$

SMALL TURBINE

$$\dot{W}_{SYS} = 27560 \text{ #/Hr} \quad \dot{Q}_L = -18125 \text{ BTU/Hr} \quad T_6 = 370.51^\circ\text{F}$$

$$\dot{Q}_{SYS} = 4.867 \times 10^6 \text{ BTU/Hr}$$

$$\dot{Q}_{SHIV} = -127.3413 \text{ BTU/Hr}$$

$$\dot{W}_{SHIV} = 42397 \text{ #/Hr} \quad \dot{Q}_{TOT} = 7.487 \times 10^6 \text{ BTU/Hr}$$

$$T_{6SHIV} = 402.97^\circ\text{F}$$

$$\eta_{OVERALL} = \frac{349976 + 1.1704 \times 10^6}{7.487 \times 10^6} = .19634$$

$T_1 = 550^\circ\text{F}$ (SUBSTITUTIONAL)

LARGE TURBINE

$$\dot{W}_{SYS} = 1654 \text{ #/Hr} \quad \dot{Q}_L = -142.8076 \text{ BTU/Hr} \quad T_6 = 439.92^\circ\text{F}$$

$$\dot{Q}_{SYS} = 2.1 \times 10^6 \text{ BTU/Hr}$$

SMALL TURBINE

$$\dot{W}_{SYS} = 21845 \text{ #/Hr} \quad \dot{Q}_L = 205.4792 \text{ BTU/Hr} \quad T_6 = 376.19^\circ\text{F}$$

$$\dot{Q}_{SYS} = 4.801 \times 10^6 \text{ BTU/Hr}$$

$$\dot{Q}_{SHIV} = -178.1523 \text{ BTU/Hr}$$

$$\dot{W}_{SHIV} = 35557 \text{ #/Hr} \quad \dot{Q}_{TOT} = 7.399 \times 10^6 \text{ BTU/Hr}$$

$$T_{6SHIV} = 335.01^\circ\text{F}$$

$$\eta_{OVERALL} = \frac{328592 + 1.028 \times 10^6}{7.399 \times 10^6} = .18355$$

HX PERFORMANCE (SUPERCRITICAL CYCLE)

SUPERCRITICAL $ETOT = .92253$ PASS 4 NTU/PASS HX
725°F

$$TD_1 = T_{T2} + \frac{(T_{T1} - T_{T2})}{E_{TOT}} = 427.52 + \frac{(725 - 427.52)}{.9225} = 750^\circ F$$

$$U_{T1} = 96.872 \text{ BTU/ft}^2 \cdot \text{h} \cdot ^\circ F \quad U_{T2} = 175.0674 \quad U_{ST2} = 37072$$

$$T_{T2} = 466.29^\circ F$$

$$TD_2 = 555.55^\circ F \quad W_D/W_T = 1.50375 \quad W_{D,HX} = 15720 \text{ #/hr}$$

$$E_1 = .75578 \quad E_{TOT} = .92253 \quad C_{rat} = .90630$$

$$TD_{AV} = 632.77$$

650°F

$$TD_1 = 396.84 + \frac{(650 - 396.84)}{.92253} = 671.26^\circ F$$

$$U_{T1} = 41.7720 \text{ BTU/ft}^2 \cdot \text{h} \cdot ^\circ F \quad U_{T2} = 165.81625 \text{ BTU/ft}^2 \cdot \text{h} \cdot ^\circ F \quad U_{ST2} = 35674$$

$$T_{T2} = 396.8^\circ F$$

$$TD_2 = 441.82^\circ F \quad W_D/W_T = 1.50152 \quad W_{D,HX} = 53565 \text{ #/hr}$$

$$E_1 = .3728 \quad E_{TOT} = .92253 \quad C_{rat} = .90630$$

$$TD_{AV} = 556.54^\circ F$$

625°F

$$TD_1 = 373.02 + \frac{(625 - 373.02)}{.92253} = 646.16^\circ F$$

$$U_{T1} = 22.3389 \text{ BTU/ft}^2 \cdot \text{h} \cdot ^\circ F \quad U_{T2} = 179.2735 \text{ BTU/ft}^2 \cdot \text{h} \cdot ^\circ F \quad U_{ST2} = 37000$$

$$T_{T2} = 373.02^\circ F$$


$$TD_2 = 417.79^\circ F \quad W_D/W_T = 1.48784 \quad W_{D,HX} = 55050 \text{ #/hr}$$

$$E_1 = .75178 \quad E_{TOT} = .92253 \quad C_{rat} = .90630$$

$$TD_{AV} = 531.97^\circ F$$

HX PERFORMANCE (SUBCRITICAL CYCLE)

SUBCRITICAL CYCLE BOILER $E_{BC} = .9$



$$T_{H1} = 625^{\circ}\text{F}$$

$$T_{D1} = 646.16^{\circ}\text{F}$$

$$\dot{Q}_{T1} = 49.29110 \text{ BTU/hr} \quad \dot{Q}_{T2} = 19.486145 \text{ BTU/hr} \quad \dot{Q}_{T3} = -45.31381 \text{ BTU/hr} \quad \dot{Q}_{T4} =$$

$$T_{F1} = 675^{\circ}\text{F} \quad T_{F2} = 572.16^{\circ}\text{F}$$

$$T_{F4} = 335.01^{\circ}\text{F}$$

$$T_{D2} = 672.1^{\circ}\text{F} \quad T_{D3} = 577.6^{\circ}\text{F} \quad T_{D4} = 400.1^{\circ}\text{F}$$

$$E_I = .15011 \quad E_{II} = .9 \quad E_{III} = .97997 \quad W_D/W_S = 7.5467$$

$$W_{D,HX} = 98222 \text{ #/hr}$$

$$T_{H,U} = 572.93^{\circ}\text{F}$$

$$T_{F1} = 550^{\circ}\text{F} \quad T_{D1} = 568$$

$$\dot{Q}_{T1} = 14.279142 \text{ BTU/hr} \quad \dot{Q}_{T2} = 17.699415 \text{ BTU/hr} \quad \dot{Q}_{T3} = -71.1785 \text{ BTU/hr} \quad \dot{Q}_{T4} = 178.4^{\circ}\text{F}$$

$$T_{F1} = 550^{\circ}\text{F}$$

$$T_{H,2} = 547.33^{\circ}\text{F}$$

$$T_{F4} = 335.01^{\circ}\text{F}$$

$$T_{D2} = 567.66$$

$$T_{D3} = 569.1^{\circ}\text{F}$$

$$T_{D4} = 575.5^{\circ}\text{F}$$

$$E_I = .15011$$

$$E_{II} = .9$$

$$E_{III} = .97997$$

$$W_D/W_S = 7.6085$$

$$W_{D,HX} = 292069 \text{ #/hr}$$

$$T_{H,U} = 546.91^{\circ}\text{F}$$

7-17-77 FRIENDSHIP TO SYSTEM CIVEN TEMP OPERATIONS OF
(POWER CONVERSION)
LARGE TURBINE

$$T_1 = 500^\circ\text{F} \quad P_1 = 200^\circ\text{F} \quad h_1 = 4413356 \text{ BTU/lb} \quad S_1 = .01914$$

$$T_{\text{COND}} = 350^\circ\text{F} \quad P_{\text{COND}} = 71.019547 \text{ PSIA}$$

$$T_{S1} = 440.80 \quad h_{S1} = -151753$$

$$T_2 = 457.12^\circ\text{F} \quad h_2 = -10.08225 \text{ BTU/lb} \quad EP = .57313 \quad ETOT = .84214$$

$$T_3 = 566.71^\circ\text{F} \quad T_5 = 417.32^\circ\text{F} \quad h_{S2} = -154.51012 \text{ BTU/lb} \quad T_6 = 118.31^\circ\text{F} \quad h_{S3} = -153.93088 \text{ BTU/lb}$$

$$T_P = 350.70^\circ\text{F} \quad h_P = -197.1875 \text{ BTU/lb} \quad h_{\text{PUMP}} = .96509 \text{ BTU/lb}$$

$$\eta_C = .09154 \quad h_{\text{PUMP}} @ \text{TURBINE} = \frac{.96509}{.95594} = 1.0807$$

$$\eta_{\text{NET}} = .08472 \text{ (INCLUDING PUMP)}$$

7-18-77

$$T_1 = 500^\circ\text{F} \quad P_1 = 200^\circ\text{F} \quad h_1 = 4413356 \text{ BTU/lb} \quad S_1 = .019164$$

$$T_{\text{COND}} = 200^\circ\text{F} \quad P_{\text{COND}} = 8.70578$$

$$T_{S1} = 344.52^\circ\text{F} \quad h_{S1} = -52.1123 \text{ BTU/lb}$$

$$T_2 = 312.11^\circ\text{F} \quad h_2 = -37.1578 \quad EP = .57313 \quad ETOT = .84214$$

$$T_3 = 218.68^\circ\text{F} \quad T_5 = 221.34^\circ\text{F} \quad h_{S2} = -252.4899 \text{ BTU/lb} \quad T_6 = 235.79^\circ\text{F} \quad h_{S3} = -251.3691 \text{ BTU/lb}$$

$$T_P = 201.07^\circ\text{F} \quad h_P = -267.7615 \text{ BTU/lb} \quad h_{\text{PUMP}} = 1.2217$$

$$\eta_C = .17731 \quad h_{\text{PUMP}} @ \text{TURBINE} = \frac{1.2217}{.95594} = 1.3681 \text{ BTU/lb}$$

$$\eta_{\text{NET}} = .17141 \text{ (INCLUDING PUMP)}$$

LOADS

$$Q_{COOL} = 264062 \text{ BTU/hr} = 220.05 \text{ Tons}$$

$$Q_{HEAT} = 0$$

$$Q_{APL} = 7.77 \times 10^6 \text{ BTU/hr}$$

$$Q_{ELECT} = 1465072 \text{ BTU/hr @ Turbine} = 479.3 \text{ KW}$$

REF = JILITE
LARGE TURBINE

$$Q_{ELECT} \text{ GENERATED} = 710115 \text{ BTU/hr} = 61.5 \text{ KW}$$

$$Q_{SUS} = 2148040 \text{ BTU/hr} \quad W_{STE} = 15664 \text{ #/hr}$$

$$Q_L = -153.9208 \text{ BTU/hr} \quad T_L = 316.21^\circ \text{F}$$

SMALL TURBINE

$$Q_{ELECT} \text{ REQD} = 367.73 \text{ KW} = 1254.95 \text{ BTU/hr @ Turbine}$$

$$Q_{ELECT} \text{ GEN} = 780374 \text{ BTU/hr} = 778.67 \text{ KW @ Turbine}$$

$$Q_L = -231.7569 \text{ BTU/hr} \quad T_L = 275.79^\circ \text{F}$$

$$Q_{APL} = 3.77 \times 10^6 \text{ BTU/hr} \quad Q_{SUS} = 220.05 \text{ Tons}$$

$$W_{HEAT} = 19777 \text{ #/hr} \quad Q_{STE} = 4553 \times 10^6 \text{ BTU/hr} \quad Q_{SUS} = 19777 \text{ #/hr}$$

$$Q_{L \text{ min}} = -196.8676 \text{ BTU/hr} \quad W_{HEAT} = 34241 \text{ #/hr} \quad Q_{SUS} = 7.033 \times 10^6 \text{ BTU/hr}$$

$$T_{L \text{ min}} = 339.68^\circ \text{F} \quad \text{Efficiency} = \frac{990459}{7.033 \times 10^6} = .14083$$

APPENDIX B5

POWER CONVERSION SYSTEM SEASONAL PERFORMANCE

Attached is the analysis for the final conceptual design for the power conversion system. The results of this analysis are discussed in Section 3.2.3 of the report.

Power Conversion System Thermal Performance

Attached is the analysis for the final conceptual design for the power conversion system. The results of this analysis is discussed in section 3.2.3 of the final report.

SECOND STAGE

$$T_{\text{COND}} = 175^{\circ}\text{F} \quad i_{\text{COND}} = 1.87849/\text{min}$$

$$T_1 = 463.73^{\circ}\text{F} \quad \dot{Q}_1 = -4.7892 \text{ BTU/\#} \quad P_1 = 71.01954 \text{ psia} \quad S_1 = .05054$$

$$T_{S_1} = 300.95^{\circ}\text{F} \quad \dot{Q}_{S_1} = -68.6575 \text{ BTU/\#}$$

$$T_2 = 349.52^{\circ}\text{F} \quad \dot{Q}_2 = -51.0517 \text{ BTU/\#} \quad E_T = .5717 \quad E_{\text{TOT}} = .8397$$

$$T_3 = 163.63^{\circ}\text{F} \quad T_5 = 271.28^{\circ}\text{F} \quad \dot{Q}_5 = -734.035 \text{ BTU/\#} \quad T_6 = 276.11^{\circ}\text{F} \quad \dot{Q}_6 = -731.594$$

$$T_P = 129.16^{\circ}\text{F} \quad \dot{Q}_P = -798.579 \text{ BTU/\#} \quad L_{\text{pump}} = 4.069 \quad \text{Pressure} = 708.32$$

$$\eta_{\text{overall}} = \frac{22.3389 + 52.0717 - 4.069}{22.3389 + 731.594} = .27698$$

JANUARY

FIRST STAGE (PROCESS HEAT + NIGHT HEATING)

$$Q_{PROCESS} = 2.27 \times 10^6 \text{ BTU/Hr}$$

$$Q_{HEAT} = 105195 \text{ BTU/Hr}$$

$$Q_{ELECT REQ'D @ TURBINE} = 429.3 \text{ KW} = 1465072 \text{ BTU/Hr}$$

$$Q_{ELECT GENERATED} = 354600 \text{ BTU/Hr} = 103.9 \text{ BTU/Hr}$$

$$T_6 = 428.31^\circ\text{F} \quad Q_6 = -148.0586 \text{ BTU/Hr}$$

$$Q_{SYS} = 2.73 \times 10^6 \text{ BTU/Hr} \quad W_{SYSTEM} = 16017 \text{ #/Hr}$$

SECOND STAGE (CONDENSE @ 125°F THRO AWAY)

$$Q_{ELECT REQ'D} = 429.3 - 103.9 = 325.4 \text{ KW} = 1110495 \text{ BTU/Hr}$$

$$N = 2.6104$$

$$Q_{REQ} = 2.6104 \times 1110495 = 2.898231 \text{ BTU/Hr}$$

$$Q_{ELECT GENERATED} = 325.4 \text{ KW} = 1.11 \times 10^6 \text{ BTU/Hr}$$

$$Q_{SYS} = 4.01 \times 10^6 \text{ BTU/Hr} \quad W_{SYS} = 15789 \text{ #/Hr}$$

$$T_6 = 276.11^\circ\text{F} \quad Q_6 = -731.594 \text{ BTU/Hr}$$

$$Q_{WATER} = -189.542 \text{ BTU/Hr}$$

$$W_{WATER} = 31806 \text{ #/Hr}$$

$$T_{6 \text{ MIX}} = 354.5^\circ\text{F} \quad Q_{T_6} = 671.04 \text{ BTU/Hr}$$

HK 3 PASS ψ NTU/PRES $C_{int} = .98$ OR $T_{D_1} = 650^\circ\text{F MAX}$

$$T_{D_1} = 650^\circ\text{F} \quad T_{D_2} = 399.31^\circ\text{F} \quad T_{DAV} = 514.65^\circ\text{F} \quad C_{int} = .977$$

$$W_{D \text{ HK}} = 45508 \text{ #/Hr} \quad W_D / W_T = 1.431$$

APRIL

5

FIRST STAGE (PROCESS HEAT ONLY)

$$Q_{PROCESS} = 7.77 \times 10^6 \text{ BTU/HR}$$

$$Q_{ELECT REQ'D} = 479.3 \text{ KW} = 1465072 \text{ BTU/HR}$$

$$Q_{ELECT GENERATED} = 338895 \text{ BTU/HR} = 99.30 \text{ KW}$$

$$Q_{SYS} = 2.609 \times 10^6 \text{ BTU/HR} \quad W_{SYS} = 15308 \text{ #/HR}$$

$$T_C = 478.31^\circ\text{F} \quad Q_L = -14.8,0886 \text{ BTU/HR}$$

SECOND STAGE (COOL + NIGHT HEATING + THROW AROUND COOLING)

$$Q_{ELECT REQ'D} = 479.3 - 99.30 = 380 \text{ KW} = 1176191 \text{ BTU/HR}$$

$$Q_{COOLING} = 35 \text{ TONS} = 420000 \text{ BTU/HR}$$

$$Q_{HEAT} = 34650 \text{ BTU/HR}$$

$$N = 3.4977$$

$$Q_{RES} = 3.4978 \times 1176191 - 34650 - \frac{420000}{.7} = 3.304 \times 10^6 \text{ BTU/HR}$$

$$Q_{ELECT GENERATED} = 1.76191 \text{ BTU/HR} = 330 \text{ KW}$$

$$Q_{SYS} = 5.065 \times 10^6 \text{ BTU/HR} \quad W_{SYS} = 22652 \text{ #/HR}$$

$$Q_{ABS} = 599996 \text{ BTU/HR} \quad R_{ABS} = 35 \text{ TONS} \quad W_{AIR} = 3450 \text{ #/HR}$$

$$W_{FAN} = 19201 \text{ #/HR}$$

$$T_C = 334^\circ\text{F} \quad Q_L = -201.7807 \text{ BTU/HR}$$

$$Q_{LHV} = -179.8301 \text{ BTU/HR} \quad T_{COOL} = 377.31^\circ\text{F} \quad Q_{TOT} = 7.674 \times 10^6 \text{ BTU/HR}$$

$$W_{WATER} = 37960 \text{ #/HR}$$

$$HX \quad 3 \text{ PHS} \quad 4 \text{ NTU/PHS} \quad C_{min} = .987 \quad C_{R(TD)} = 65^\circ\text{F/HX}$$

$$T_{C1} = 650^\circ\text{F} \quad T_{D2} = 477.10^\circ\text{F} \quad T_{DAV} = 531.06^\circ\text{F} \quad C_{min} = .9415$$

$$W_{DHY} = 57018 \text{ #/HR}$$

JULY

(4)

FIRST STAGE (PROCESS HEAT ONLY)

$$Q_{PROCESS} = 7.27 \times 10^6 \text{ BTU/HR}$$

$$Q_{HEAT REQ'D} = 429.3 \text{ KW} = 1465072 \text{ BTU/HR}$$

$$Q_{HEAT GENERATED} = 358895 \text{ BTU/HR} = 99.30 \text{ KW}$$

$$Q_{SYSTEM} = 2.609 \times 10^6 \text{ BTU/HR} \quad W_{SYS} = 15308 \text{ #/HR}$$

SECOND STAGE (Q_{COOL} + THROW AWAY COND @ 200°F)

$$Q_{HEAT REQ'D} = 429.3 - 99.3 = 330 \text{ KW} = 1126191 \text{ BTU/HR}$$

$$Q_{COOL} = 215.78 \text{ TONS} = 2589360 \text{ BTU/HR}$$

$$Q_{HEAT} = 0$$

$$L = 3.4978$$

$$Q_{RES} = 3.4978 \times 1126191 - 2589360 = 240058 \text{ BTU/HR}$$

$$Q_{HEAT GEN} = 1126191 \text{ BTU/HR} = 320 \text{ KW}$$

$$Q_{SYSTEM} = 5.065 \times 10^6 \text{ BTU/HR} \quad W_{SYS} = 22652 \text{ #/HR}$$

$$Q_{AIR} = 2.7 \times 10^6 \text{ BTU/HR} \quad Q_{AIR} = 215.78 \text{ TONS}$$

$$Q_{LEAK} = -179.530 \text{ BTU/HR}$$

$$T_{bmin} = 372.31^\circ \text{ F} \quad Q_{TOT} = 7.674 \times 10^6 \text{ BTU/HR}$$

$$W_{WAT} = 37960 \text{ #/HR}$$

$$HX \quad 3 \text{ PASS} \quad 4 \text{ HTU/PTES} \quad C_{HT} = .98202 \quad T_{D1} = 650^\circ \text{ F/HTU}$$

$$T_{D1} = 650^\circ \text{ F} \quad T_{D2} = 412.10^\circ \text{ F} \quad T_{DAN} = 531.06^\circ \text{ F} \quad C_{HT} = .9415$$

$$W_{DAN} = 57018 \text{ #/HR}$$

OCTOBER

FIRST STAGE (PROCESS HEAT ONLY)

$$Q_{PROCESS} = 2.77 \times 10^6 \text{ BTU/HR}$$

$$Q_{ELECT REQ'D} = 429.3 \text{ KW} = 1465072 \text{ BTU/HR}$$

$$Q_{ELECT GENERATED} = 538895 \text{ BTU/HR} = 99.30 \text{ KW}$$

$$Q_{SYS} = 2.609 \times 10^6 \text{ BTU/HR} \quad W_{SYS} = 15308 \text{ #/HR}$$

SECOND STAGE ($Q_{COOL} + Q_{HEAT} + \text{THROW AWAY @ } 200^\circ\text{F}$)

$$Q_{ELECT REQ'D} = 330 \text{ KW} = 1126191 \text{ BTU/HR}$$

$$Q_{COOL} = 48144 \text{ TONS} = 581333 \text{ BTU/HR}$$

$$Q_{HEAT} = 54850 \text{ BTU/HR}$$

$$n = 3.4978$$

$$Q_{RES} = 3.4978 \times 1126191 - 54850 - 581333 = 3.053818 \text{ BTU/HR}$$

$$Q_{ELECT GENERATED} = 1126191 \text{ BTU/HR} = 330 \text{ KW}$$

$$Q_{SYS} = 5.065334 \text{ BTU/HR} \quad W_{SYS} = 22652 \text{ #/HR}$$

$$Q_{ABSE} = 832472 \text{ BTU/HR} \quad W_{ABSE} = 4976 \text{ #/HR}$$

$$W_{PABSE} = 17876 \text{ #/HR}$$

$$Q_{6min} = -179,830 \text{ BTU/HR} \quad T_{6min} = 37.31^\circ\text{F} \quad Q_{TOT} = 7.674 \times 10^4 \text{ BTU/HR}$$

$$W_{6min} = 37960 \text{ #/HR}$$

$$HX \quad 3 \text{ PASS} \quad 4 \text{ NTU/PT} \quad \text{Cmt} = .982 \quad \text{OR } T_{R1} = 65.5^\circ\text{F/1HX}$$

$$T_{D1} = 650^\circ\text{F} \quad T_{D2} = 472.10^\circ\text{F} \quad T_{DAV} = 531.06^\circ\text{F} \quad \text{Cmt} = .9815$$

$$W_{D12} = 57018 \text{ #/HR}$$

LEAVE JANUARY & JULY THE SAME

(6)

FOR APRIL & OCTOBER CONDENSE AT 125°F WITH
THIRD STAGE CONDENSER & MAKE ALL COOLING VAPOR
CYCLE & LET PROCESS HEAT DO NIGHT HEATING

APRIL

FIRST STAGE $N_2 = .175$

$$Q_{PROC} = 2.77 \times 10^6 \text{ BTU/Hr}$$

$$Q_{HEAT} = 34050 \text{ BTU/Hr}$$

$$Q_{ELECT \text{ REFR}} = 42.4 \text{ KW} = 145572 \text{ BTU/Hr}$$

$$Q_{ELECT \text{ GEN}} = 100.52 \text{ KW} = 340052 \text{ BTU/Hr}$$

$$Q_{SYS} = 2.649 \times 10^6 \text{ BTU/Hr} \quad W_{SYS} = 15542 \text{ #/Hr}$$

$$T_6 = 478.31^\circ\text{F} \quad Q_{L6} = -148.0886 \text{ BTU/#}$$

SECOND STAGE

$$Q_{COOL} = 35 \text{ Tons} = 420000 \text{ BTU/Hr (ALL VAPOR CYCLE)}$$

$$Q_{SEP \text{ ELECT}} = 429.5 - 150.52 = 378.48 \text{ KW} = 1.171 \times 10^6 \text{ BTU/Hr}$$

$$Q_{REF} = 2.6104 \left(\frac{420000}{3.572} + 1.171 \times 10^6 \right) = 3.233 \times 10^6 \text{ BTU/Hr}$$

$$Q_{TOT \text{ ELECT GEN}} = 1.4662 \times 10^6 \text{ BTU/Hr} = 429.63 \text{ KW (inc A/C)}$$

$$Q_{SEP \text{ ELECT GEN}} = 1.171 \times 10^6 \text{ BTU/Hr} = 378.48 \text{ KW}$$

$$Q_{REF \text{ CYCLE}} = 34.45 \text{ KW} = 117.6 \times 10^3 \text{ BTU/Hr} \quad R_{VC} = 35 \text{ Tons}$$

$$Q_{SYS} = 4.472 \times 10^6 \text{ BTU/Hr} \quad W_{SYS} = 19997 \text{ #/Hr}$$

$$Q_{TOT} = 7.121 \times 10^6 \text{ BTU/Hr}$$

$$Q_{L6 \text{ min}} = -178.019 \text{ BTU/#} \quad T_{6 \text{ min}} = 375.61^\circ\text{F} \quad W_{min} = 35539 \text{ #/Hr}$$

$$T_{D1} = 650^\circ\text{F} \quad T_{D2} = 414.49^\circ\text{F} \quad T_{D30} = 532.75^\circ\text{F} \quad C_{ref} = .9444$$

$$W_{DHL} = 50948 \text{ #/Hr}$$

OCTOBER 12
FIRST STAGE

$$Q_{KBC} = 2.27 \times 10^6 \text{ BTU/HR}$$

$$Q_{HEAT} = 54850 \text{ BTU/HR}$$

$$Q_{ELECT} \text{ (GENERATED)} = 347084 \text{ BTU/HR} = 101.70 \text{ KW}$$

$$Q_{SYS} = 2.672 \times 10^6 \text{ BTU/HR} \quad \dot{W}_{SYS} = 15678 \text{ #/HR}$$

$$T_L = 429.31^\circ \text{F}$$

$$\dot{Q}_6 = -148.0586 \text{ BTU/s}$$

SECOND STAGE

$$Q_{ELECT} \text{ REQ'D} = 429.3 - 101.70 = 327.6 \text{ KW} = 1.118 \times 10^6 \text{ BTU/HR}$$

$$Q_{WCL} = 48,444 \text{ TONS} = 581333 \text{ BTU/HR}$$

$$N = 2.6104$$

$$Q_{REQ} = 2.6104 \left(\frac{581333}{5.572} + 1.118 \times 10^6 \right) = 3.343 \times 10^6$$

$$Q_{TOT} \text{ ELECT (GENERATED)} = 1.281 \times 10^6 \text{ BTU/HR} = 375.29 \text{ KW}$$

$$Q_{SEP} \text{ ELECT (GENERATED)} = 1.118 \times 10^6 \text{ BTU/HR} = 327.6 \text{ KW}$$

$$Q_{VAP} \text{ CYCLE} = 47.69 \text{ KW} = 162752 \text{ BTU/HR} \quad R_{VAP} \text{ CYCLE} = 48,444 \text{ TONS}$$

$$Q_{SYS} = 4.624 \times 10^6 \text{ BTU/HR} \quad \dot{W}_{SYS} = 20678 \text{ #/HR}$$

$$Q_{TOT} = 7.296 \times 10^6 \text{ BTU/HR}$$

$$T_L = 334^\circ \text{F}$$

$$\dot{Q}_6 = -201.2807 \text{ BTU/s}$$

$$\dot{Q}_{6min} = -178.347 \text{ BTU/s} \quad T_{6min} = 375.3^\circ \text{F} \quad \dot{Q}_{6max} = 36356 \text{ #/HR}$$

$$T_1 = 650^\circ \text{F} \quad T_{D1} = 414.08^\circ \text{F} \quad T_{D1V} = 532.00^\circ \text{F} \quad \dot{Q}_{D1} = .9452$$

$$\dot{W}_{D1X} = 50951 \text{ #/HR}$$

APPENDIX B6

THERMAL STORAGE/FLUID LOOP

This appendix discusses the baseline concepts for the ullage and fluid maintenance units. A detailed description of the other major components of the Thermal Storage System (TSS) appears in Section 3.2.4 of this report.

ULLAGE MAINTENANCE UNIT

The basic requirement of this unit is to provide a controlled-pressure, inert gas atmosphere above the fluid in the thermal storage system. It is necessary to have an inert gas above the heat transfer fluid surface to prevent fire hazards and long-term oxidation of the fluid. The ullage pressure must be controlled within a moderately narrow band to avoid underpressurizing or overpressurizing the tank. When the heat transfer fluid is heated over the operating temperature range, the volume expands by about six percent. If the inert gas in the ullage in the reservoir tank were not released, the pressure would rise above the allowable upper limit. The gas released must be replaced or stored and returned to the ullage space during the cooling cycle since an equal amount of gas is required to prevent the pressure from going below the allowable lower limit as the fluid cools and contracts.

These functions must be accomplished in as simple a manner as possible with minimum capital, maintenance, and operating costs. The design also must permit reliable operational control and have the flexibility and measurement capabilities needed for the STES.

The major specific requirements on the ullage maintenance unit are as follows:

- A. The gas in the ullage space must not react with the fluid. Therefore, oxygen and air must be excluded from the entire system and an inert gas such as nitrogen or carbon dioxide must be substituted.


- B. A control system with suitable backups must be provided to ensure that the pressure in the ullage space will remain within the proper gage pressure range. A pressure below this range is not tolerable since this might permit collapse of the tank.
- C. Since the emerging gases will be hot and will carry with them vapors given off by the fluid, they must be cooled and the condensate must be returned to the tank. Cooling the gas is required to accommodate storage of the gas in one form or another. Those gases which do not condense when cooled to near ambient temperature will be considered undesirable and will be removed from the inert gas, while the latter will be stored and used to refill the ullage space during the cooling cycle.

Several types of ullage maintenance units have been identified in previous MDAC studies. The following alternatives have been examined and evaluated during these studies:

- A. Nonrecovered gas systems
 - o Using GN_2
 - o Using CO_2
- B. Condensible Vapor Systems
 - o Using water
 - o Using a hydrocarbon such as heptane or hexane
 - o Using other compounds
- C. Recovered gas systems
 - o Storage at TSU pressure (gas holder)
 - o Storage of compressed gas

As a result of these studies, a recovered gas (N_2) system utilizing storage of compressed gas has been selected for analysis in this study.

The ullage maintenance unit is shown in conceptual form in Figure B6-1. The unit controls the pressure and vapor quality in the ullage space of the tank. Air is excluded since it will accelerate the heat transfer fluid degradation rate, and could in extreme instances create a hazardous condition. An inert ullage gas is added and vented as the fluid in the system expands and contracts



**FIGURE B6-1 : CONCEPTUAL SCHEMATIC OF
BASELINE ULLAGE MAINTENANCE SUBSYSTEM**

during thermal cycling. Nitrogen was selected as the ullage gas for its economy and ready availability.

The baseline ullage control unit has the following features:

- A. Ullage pressure automatically maintained at a few centimeters of water above ambient atmospheric pressure.
- B. Low boiling condensable gases removed from expelled ullage gas so that the gas can be reused for subsequent repressurization; simultaneously the unit provides a low-boiler stripping operation for the fluid.
- C. A redundant system of emergency pressure and vacuum relief valves to protect the tank in case the pressure control system is unable to handle the necessary reduction or increase in gas flow into the ullage space.
- D. A liquid alarm (which also shuts off the compressor used to remove ullage gas) in case the liquid should overflow to the top of the tank.
- E. Nitrogen storage at a working pressure of 1 MNg/m^2 (150 psig) and with a nitrogen volume of approximately 45.5 m^3 ($1,605 \text{ ft}^3$) at 0°C and 1 atm, which is sufficient gas to provide one complete filling of the reservoir tank.
- F. Measurement of inert gas flow into the tank for monitor and record of proper system operation; tank pressure and liquid level are also measured and recorded.
- G. An explosive mixture detector/indicator and alarm with its sensor located in the upper ullage space to guard against the possibility that accumulations of noncondensable gases such as hydrogen do not reach a dangerous level should a sudden expulsion to the atmosphere occur. (If such gases accumulate over a period of time, they can be vented to the atmosphere or mixed with natural gas and torched. Make-up gas will automatically come in from the reserve with nitrogen storage providing the required inert gas dilution.)

FLUID MAINTENANCE UNIT

The general requirement imposed on the fluid maintenance unit is that it maintain the heat transfer fluid in satisfactory condition for continual operation of the Thermal Storage Subsystem. Some of the detailed requirements to be met by the unit related to fluid stability, degradation products, and degradation rates are as follows.

The fluid maintenance unit will be required to:

- A. Maintain the level of high-boilers (polymerized materials) below a given value. There are indications that 20 to 40 percent is acceptable; 20 percent was used as a requirement on this design.
- B. Remove suspended solids from the circulating fluid, both during normal operations and during initial start-up with an unconditioned rock bed in the thermal storage unit.
- C. Provide fresh heat transfer fluid to make up for materials removed from the circulating fluid.
- D. Provide virtually automatic operation using a simple direct method which requires relatively inexpensive equipment.
- E. Use existing state-of-the-art technology and, as far as practicable, use existing commercial components.
- F. Use only a modest quantity of parasitic electrical power and thermal energy.

The analysis and design of the fluid maintenance unit depends critically on the thermal stability characteristics of the heat transfer fluid. Discussions were held with suppliers and users of the baseline heat transfer fluids in order to obtain information about the characteristics of the fluids.

Commercial experience with lubricating oils shows that routine cleanup procedures will permit reuse of the oil almost indefinitely. Experience with rehabilitation and cleanup of lubricating oils and fuels utilized in large commercial and jet engines facilities is directly applicable to the cleanup

of the thermal storage fluid. These processes use distillation to remove low-boiling-point fractions in combination with filtration to remove solids. The lubrication-oil reclaiming industry recently developed several new processes which utilize solvent extraction to extract various additives and metals. Another new method adds recycled naphtha combined with a mild caustic (sodium carbonate) to the oil, causing the carbonaceous material to separate. After centrifugation, the oil is vacuum fraction distilled.

From the standpoint of the fluid maintenance unit, increasing the allowable concentration of high boilers which can be tolerated decreases the size of the clean-up limit. However, the following considerations affect the upper value of the concentration:

- A. The viscosity increase at working temperatures requires greater pumping power.
- B. If system shutdown and cooling are required, the room temperature viscosity should not be so great as to make a restart impossible.
- C. High concentration may increase or decrease the degradation rate; however, the effect of high boiler concentration on decomposition is unknown.

The baseline fluid maintenance unit for the STES TSS is shown schematically in Figure B6-2. It performs three functions to maintain fluid stably within its operating range: filtration to remove suspended solids, distillation of a side stream to remove high boiling compounds, and addition of fresh make-up fluid to replace the material removed. The unit is designed to use existing commercial components.

A screen of about 20-mesh is provided at the entrance to each pump. This removes trash and large particles which are prevalent primarily at startup or immediately after repairs have been made. Once the system has been cycled a number of times, the likelihood of large particles being carried along is very highly reduced. The TSS bed acts as an effective filtration bed, and only the smallest particles can be picked up by the fluid because its velocity is extremely low. At typical fluid design velocities, particles of spherical shape and of the same density as rock will gradually settle back down to the




FIGURE B6-2 CONCEPTUAL SCHEMATIC
OF BASELINE FLUID MAINTENANCE UNIT.

bed if the diameter of the particle is greater than 16 micron (0.0016 cm); only particles smaller than this could be carried along with the fluid. This particle size is so small, however, that as long as their concentration is low they will not harm the system. Nevertheless, filtration equipment capable of removing particles down to 10-micron diameter is being provided for the following reasons:

- A. The material collected by several filters having different pore sizes is valuable for determining the extent and source of system contamination and will be of great value in system design scale-up.
- B. The solid material found in the fluid may be a product of polymerization and carburization of the fluid itself, and is therefore expected to have a density close to that of the fluid. Hence, it will not settle out by gravity in the TSS as is the case for relatively dense particles of sand or rock. This light material may prove to be detrimental from a chemical standpoint in that it may be found to catalyze polymerization of the fluid producing even more high boilers. Thus, its removal is considered desirable until further confirmation is available.

APPENDIX B7

SYSTEM INTEGRATION

The system operating temperature trade study was discussed in Section 3.2.5 of this report using the baseline collector/field option. The trade study was also performed using the performance of several other collector/field options. The candidate collector fields used in the trade are listed in Table C-2-1.

The season collector performances for the five other candidate fields are shown in Figures C-2-1 through C-2-5. Their performances, along with the baseline collector field, are summarized in Table C-2-2.

System efficiencies were calculated, using the methodology discussed in Section 3.2.5 for all of the collector field options using both organic rankine and steam power conversion cycles. This data is presented in Figures C-2-6 through C-2-7. The results of the trade study and its conclusions are discussed in Sections 1.4.1 and 3.2.5 of the main report.

TABLE C-1
CANDIDATE COLLECTOR FIELDS

1. EAST WEST HORIZONTAL PARABOLIC TROUGH	GCR* = 0.464
2. NORTH SOUTH HORIZONTAL PARABOLIC TROUGH	GCR = 0.464
3. NORTH SOUTH POLAR PARABOLIC TROUGH	GCR = 0.463
4. NORTH SOUTH POLAR PARABOLIC TROUGH	GCR = 0.313
5. TWO AXIS NORTH SOUTH FRESNEL	GCR = 0.463
6. TWO AXIS NORTH SOUTH FRESNEL	GCR = 0.313

GCR = GROUND COVER RATIO

DOUGLAS

(OF)

450 475 500 525 550 575 600 625 650 675

LSE #2
E-W PARABOLIC TROUGH
(SANDIA WEEKS)

SEASONAL COLLECTOR FIELD EFFICIENCY (%)

40

35

30

25

20

15

10

5

0

240

260

280

300

320

340

360

AVERAGE COLLECTOR FIELD TEMPERATURE (°C)

JANUARY

OCTOBER

JULY

APRIL

FIGURE C-2-1

DOUGLAS

(OF)

460 475 500 525 550 575 600 625 650 675

LSE #2

N-S (POLAR) PARABOLIC TROUGH
(SANDIA WEEKS)

40

35

30

25

20

15

10

5

0

240 260 280 300 320 340 360
AVERAGE COLLECTOR FIELD TEMPERATURE (°C)

APRIL

OCTOBER

JULY

JANUARY

SEASONAL COLLECTOR FIELD EFFICIENCY (%)

53

FIGURE C-2-2

DOUGLAS

(OF)

450 475 500 525 550 575 600 625 650 675

LSE # 2

N-S (POLAR) PARABOLIC TROUGH
(SANDIA WORKS)

SEASONAL COLLECTOR FIELD EFFICIENCY (%)

40

35

30

25

20

15

10

5

0

240

260

280

300

320

340

360

AVERAGE COLLECTOR FIELD TEMPERATURE (°C)

APRIL

OCT

JAN

JULY

FIGURE C-2-3

SEASONAL COLLECTOR FIELD EFFICIENCY (%)




FIGURE C-2-4

SEASONAL COLLECTOR FIELD EFFICIENCY (%)




FIGURE C-2-5

TABLE C-2-2
COLLECTOR FIELD EFFICIENCY
SUMMARY

COLLECTOR	SEASONAL ORDER OF PERFORMANCE BEST → POOREST	BEST SEASON PERFORMANCE @ 300°C (%)	SEASONAL VARIATION $\Delta \eta_c$ @ 300°C (%)
1. E-W HORIZONTAL PARABOLIC TROUGH GCR = 0.464	JAN, OCT-APR, JULY	25.6	7.3
2. N-S HORIZONTAL PARABOLIC TROUGH GCR = 0.464	JULY, APR, OCT, JAN	32.7	22.9
3. N-S POLAR PARABOLIC TROUGH GCR = 0.464	APR, OCT, JULY, JAN	28.2	14.9
4. N-S POLAR PARABOLIC TROUGH GCR = 0.313	APR, OCT, JAN, JULY	27.8	8.7
5. TWO AXIS N-S FRESNEL GCR = 0.463	APR, JULY, OCT, JAN	27.5	15.7
6. TWO AXIS N-S FRESNEL GCR = 0.313	APR, JAN, OCT, JULY	27.1	5.6

B7-8

SYSTEM EFFICIENCY $\eta_s = \eta_{\text{collector}} \times \eta_{\text{therm}}$




Figure C-2-6

SYSTEM EFFICIENCY $\eta_s = \eta_{cycle} \times \eta_{coll.}$




FIGURE C2-7

SYSTEM EFFICIENCY $\eta_s = \eta_{cyc} \times \eta_{coll}$




Figure C-2-8




Figure C.2-9

SYSTEM EFFICIENCY $\eta_s = \eta_{\text{cycle}} \times \eta_{\text{coll.}}$




FIGURE C-2-10




FIGURE C-2-11

APPENDIX B8

BACKUP COST ESTIMATES
(Ref. Section 3.7)

JOB STES #2 CAPITAL COST FOR 1ST UNIT

ESTIMATE

1/7

ORDER NO. C-19650		CUSTOMER ERDA /ALO			LOCATION SHENANDOAH, GEO			BY	DATE 9/15/77	
AREA AND ACCOUNT		DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY		HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)
1101		<u>COLLECTORS</u>								
		COLLECTOR MODULES	M ²	9683			194.0	733.6	-	927.6
		COLLECTOR FOUND MATERIAL					-	-	41.8	41.8
		TOTAL COLLECTORS					194.0	733.6	41.8	969.4
1102		<u>PIPING</u>								
		2.5" φ					1.9	2.6	-	4.5
		3.5" φ					1.5	1.7	-	3.2
		4.0" φ					2.3	2.5	-	4.8
		4.5" φ					1.0	1.0	-	2.0
		PIPING INSULATION					-	-	41.2	41.2
		MANUAL VALVE					2.6	45.1	-	47.7
		HANGERS & SUPPORTS					8.0	138.0	-	146.0
		FLUID					-	401.6	-	401.6
		MISS. FITTINGS					14.3	1.5	-	15.8
		TOTAL PIPING					31.6	594.0	41.2	666.8
1103		<u>SITE CONST. MATERIALS</u>								
		SITE GRADING	CY	26000			45.6	-	-	45.6
		PAVING COLLECTOR AREA	SY	23300			21.0	64.2	-	85.2
		CHAINLINK FENCING	L.F.	1900			-	-	13.6	13.6
		CONC. (MODULE FOUND)	CY	575			63.0	21.0	-	84.0
		MODULE SUPPORTS (PIPE, 3")	EA	1400			19.0	110.0	-	129.0
		MISS. PIPING & GRADING	-	-			2.5	2.4	-	4.9
							151.1	197.6	13.6	362.3

JOB **STES #2** CAPITAL COST, 1ST UNIT

ESTIMATE

ORDER NO. C-19650		CUSTOMER			LOCATION			BY	DATE 9/15/77
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)	
1104	PACKING, SHIPPING & INSPECT				—	75.2	75.2	75.2	
	TOTAL PACK, SHIP, EST					75.2	75.2	75.2	
	TOTAL ITEMS 1101 THRU 1104				376.7	1602.4	96.6	2073.7	
ENERGY PLANT									
1201	TURBINE GENERATOR SYSTEM								
	Fossil Fuel Heater	BTU/Hr	10x10 ⁶		11.3	75.0	—	86.3	
	Toluene Vapor Turbine, incl								
	ALL FOLLOWING EQUIP.:								
	Speed Reducer								
	Generator (600KVA, 480V)								
	Vaporizer								
	127/225 Stage Regenerator								
	1" 1" " Condenser/Reboiler								
	1" 3" " Vapor Feed Pumps	GPM	55						
	Receiver	Gal	370						
	Hot well tank	Gal	415		90.0	600.0		690.0	
	CONDENSATE FEED PUMP	GPM	5		0.2	0.7		0.9	
	DEAERATING FEED H ₂ O HEATER	Gal	50		0.2	1.0		1.2	
	TOTAL TURBINE GEN. SYS.				101.7	676.7	—	778.4	

3/7

JOB STES #2 CAPITAL COST, 1ST UNIT

ESTIMATE

ORDER NO. C-19650		CUSTOMER					LOCATION			BY	DATE 9/15/77	
AREA AND ACCOUNT		DESCRIPTION			TYPE UNIT	WEIGHT OR QUANTITY		HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)
1202		PIPING & MISC. EQUIP										
		ABSORP. CHILLER			TON	220			2.0	8.0		10.0
		CHILLER HOT H ₂ O CIRC. PUMP			GPM	550			0.9	9.0		9.9
		CHILLER COOLING TOWER							2.0	20.0		22.0
		CHILLER COOLING H ₂ O PUMPS (3)			GPM	800			0.9	7.1		8.0
		CHILLER H ₂ O CIRC. PUMPS (2)			GPM	440			0.8	5.4		6.2
		CHILLER H ₂ O EXP. TANK			Ea	1			0.5	1.5		2.0
		" " CHEM FEED (18 gal)			Ea	1			0.1	0.3		0.4
		BLOG. HEAT PUMPS (10 GPM)			Ea	2			0.4	1.6		2.0
		DOM. H ₂ O HEATER PUM (5 GPM)			Ea	1			0.2	0.6		0.8
		DOM. H ₂ O HEATER (40 GAL)			Ea	1			0.8	2.2		3.0
		HOT H ₂ O CIRC. PUMPS (180 GPM)			Ea	2			0.4	2.1		2.5
		H ₂ O EXPAN. TANK (AIR H ₂ O)			Ea	1			0.8	2.2		3.0
		HEAT EXCH. TANK			Ea	1			0.5	1.5		2.0
		AIR COOL HEAT EXCHGR			Ea	1			1.5	7.5		9.0
		ANTI-FREEZE / CHEM FEEDER							0.5	2.5		3.0
		CO ₂ FIRE PROTECT. SYS.							5.0	3.0		8.0
		HYDROCARBON LEAK DETECTOR			Ea	1			0.2	0.8		1.0
		AIR COMPRESSOR (INSTRUMENT)			Ea	1			0.4	3.2		3.8
		" " (SERVICE)			Ea	1			0.6	9.3		9.9
		CRANE-STON BRIDGE, ELEC.			Ea	1			2.5	10.0		12.5
		CONDENSATE STOR. TANK (500 GAL)			Ea	1			1.5	3.5		5.0
		FUEL OIL STOR. TANK (1500 GAL)			Ea	1			5.0	12.0		17.0
		" " TRANS. PUMP			Ea	1			0.2	0.4		0.6
		SODIUM ION EXCH. UNIT (100 GAL)			Ea	1			0.1	0.6		0.7

BS-4

4/7

JCB STES CAPITAL COST, 1ST UNIT

ESTIMATE

ORDER NO. C-19650		CUSTOMER				LOCATION			BY	DATE 9/15/77
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY		HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)	
1202 (CONT'D)										
	COOLING TOWER FEED UNITS	EQ	2			0.4	1.8		2.2	
	CHEM. FEED UNITS	EQ	3			2.0	10.0		12.0	
	PIPING, VALVES & FITTINGS	L.S.				35.4	53.1		88.5	
	TOTAL PIPING & MISS. EQUIP					65.6	179.2	-0-	244.8	
1203 THERMAL STORAGE										
	PUMPS					1.0	3.6		4.6	
	FILTER					0.4	12.0		12.4	
	COMB. HEATER					0.3	2.5		2.8	
	REGULATOR					0.5	1.3		1.8	
	THERMAL STORAGE TANK							358.0	358.0	
	" " RESERVOIR							97.0	97.0	
	BLENDING TANK							60.0	60.0	
	TOTAL THERMAL STORAGE					2.2	19.4	515.0	536.6	
1204 T.S. PIPING & MISS. EQUIP.										
	PIPING, FITTINGS & MISS. EQUIP					8.0	24.0	9.8	41.8	
	TOTAL PIPING & MISS. EQUIP.					8.0	24.0	9.8	41.8	

5/7

JOB STES #2 CAPITAL COST - 1ST UNIT

ESTIMATE

ORDER NO. C-19650		CUSTOMER ERDA			LOCATION			BY	DATE 9/15/77
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)	
1205	BUILDINGS & MISC.								
	EXCAV. FOR BLDG. FND'N	CY	900		1.2	-	-	1.2	
	REIN. CONC. BLDG. FND'N	CY	70		8.0	7.7		15.7	
	STRUCT. CONC. FLOOR SLAB	CY	260		17.2	23.4	-	40.6	
	96'X72' BLOCK & BRICK FACE BLDG. INCL. ALL FINISHED PARTITIONS & INTERIOR	L.S.			79.8	89.9		169.7	
	BLDG. PLUMBING & ELEC	L.S.			2.0	43.8		45.8	
	TOTAL BLDGS & MISC.				108.2	164.8		273.0	
1206	YARD WORK								
	ROADWAY PAVING	SY	1100		2.6	5.7		8.3	
	PARKING AREA PAVING	SY	100		0.3	0.5		0.8	
	MACHINE EXC. & TRENCHING	CY	3800		8.3			8.3	
	EROSION CONTROL	L.S.			6.0			6.0	
	LANDSCAPING	L.S.					10.0	10.0	
	SAN. SEWER MANHOLES	Ea	2		0.4	0.8		1.2	
	8" H ₂ O MAIN	L.F.	5000				55.0	55.0	
	8" GATE VALVE	Ea	1				0.7	0.7	
	8" DRAIN LINE	L.F.	200		0.3	1.7		2.0	
	FIRE HYDRANTS	Ea	2		0.4	0.8		1.2	
	TRENCHING BACKFILL	CY	3000		15.9			15.9	
	TOTAL YARD WORK				34.2	9.5	65.7	109.4	

6/7

JOB STES #2 CAPITAL COST - 1ST UNIT

ESTIMATE

ORDER NO. C-19650		CUSTOMER ERDA			LOCATION			BY	DATE 9/15/77
AREA AND ACCOUNT		DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)
1207		PACKING, SHIPPING & INSPECTION				-0-	50.0	-0-	50.0
		TOTAL					50.0		50.0
		TOTAL - ITEMS 1201 THRU 1207				319.9	1,123.6	590.5	2,034.0
INTERFACE EQUIP., CONTROL & DISPLAY SYSTEMS									
1301		ELECTRICAL EQUIP. & SYSTEMS							
		POWER & CONTROL CABLEING	Lot			25.0	270.5	-0-	295.5
		CONDUIT, RGS	Lot			43.8	122.8	-0-	166.6
		CONTROL BLDG, ELEC. (INCLUDES SUB STATION)	L.S.			35.2	24.3	-0-	59.5
		480V. POWER CKT. BREAKER	Ea	5		2.4	22.0	-0-	24.4
		LOAD CENTER	Ea	1		1.0	11.3	-0-	12.3
		MOTOR CONTROL CTL.	Ea	1		1.2	8.4	-0-	9.6
		DISTRIBUTION TRANSFORMER	Ea	1		0.5	1.7	-0-	2.2
		750 KVA TRANS.	Ea	1		1.3	13.3	-0-	14.6
		480 V. BUS	Ea	1		0.8	10.1	-0-	10.9
		BATTERIES, BATT. CHARGER & 30KW DC/AC CONVERTER	Lot	1		4.2	38.7	-0-	42.9
		TOTAL ELEC. EQUIP & SYSTEMS				115.4	523.1	-0-	638.5

BB-7

JOB STES #2 CAPITAL COST - 1st UNIT

ESTIMATE

ORDER NO. <u>C-19650</u>		CUSTOMER <u>ERDA</u>			LOCATION			BY	DATE <u>9/15/77</u>
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)	
<u>1302</u>	<u>INSTRUMENTATION & CONTROLS</u>								
	<u>MINI COMDER</u>				<u>10.0</u>	<u>65.0</u>		<u>75.0</u>	
	<u>MISC. INST. & CONTROLS</u>				<u>80.0</u>	<u>145.0</u>		<u>225.0</u>	
	<u>TOTAL INSTRU. & CONTROLS</u>				<u>90.0</u>	<u>210.0</u>		<u>300.0</u>	
	<u>TOTAL ITEMS 1301 & 1302</u>				<u>205.4</u>	<u>133.1</u>		<u>938.5</u>	

JOB STES #2 CAPITAL COST - 100TH UNIT

ESTIMATE

ORDER NO. C-19650		CUSTOMER ERAN/ALO			LOCATION			BY	DATE 9/15/77	
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY		HOURS	LABOR (\$000)	MATERIAL (\$000)	OTHER (\$000)	TOTAL (\$000)	
<u>COLLECTOR FIELD</u>										
1101	MODULES									
	COLLECTORS					194.0	643.4	--	837.4	
	COLLECTOR FND'N MAT'L					--	--	41.8	41.8	
	TOTAL MODULES					194.0	643.4	41.8	879.2	
1102	PIPING (same as 1 st unit except reduction in pipe & valves)					31.6	570.2	41.2	643.0	
1103	SITE CONST'N MAT'L. (same as 1 st unit).					151.1	197.6	13.6	362.3	
1104	PACKING & SHIPPING (same as 1 st unit).					--	75.2	--	75.2	
	TOTAL ITEMS 1101 THRU 1104					376.7	1486.4	96.6	1959.7	
<u>ENERGY PLANT</u>										
1201	TURBINE GENERATOR									
	FOSSIL FUEL HEATER					11.3	73.8	--	85.1	
	TOLUENE TURBINE & MISC. EQUIP. (SEE 1 st UNIT LIST)					90.0	567.7	--	657.7	
	CONDENSATE FEED PUMP					0.2	0.7	--	0.9	
	DEAERATING					0.2	1.0	--	1.2	
	TOTAL TURBINE GENERATOR					101.7	643.2		744.9	

83-9

JOB STES #2 CAPITAL COST - 100TH UNIT

ESTIMATE

ORDER NO. <u>C-19650</u>		CUSTOMER <u>ERDA/ALO</u>				LOCATION			BY	DATE <u>9/15/77</u>	
AREA AND ACCOUNT	DESCRIPTION				TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR	MATERIAL	OTHER	TOTAL
1202	<u>PIPING & MISC EQUIP.</u> (same as 1 ST unit except slight reduction on major equip. items)							65.6	172.8	-0-	238.4
1203	<u>THERMAL STORAGE (T.S.)</u>										
	PUMPS							1.0	3.6	-0-	4.6
	FILTER							0.4	12.0	-0-	12.4
	COMB. HEATER							0.3	2.5	-0-	2.8
	REGULATOR							0.5	1.3	-0-	1.8
	THERMAL STORAGE TANK							-0-	-0-	304.3	304.3
	" " RESERVOIR							-0-	-0-	82.4	82.4
	BLENDING TANK							-0-	-0-	51.0	51.0
	TOTAL THERMAL STORAGE							2.2	19.4	437.7	459.3
1204	<u>T.S. PIPING & MISC. EQUIP.</u>							8.0	21.6	9.1	38.7
1205	<u>BLDGs & MISC.</u> (same as 1 ST unit)							108.2	164.8	-0-	273.0
1206	<u>YARDWORK</u> (same as 1 ST unit)							34.2	9.5	65.7	109.4

JOB STES #2 CAPITAL COST - 100th UNIT

ESTIMATE

ORDER NO. C-19650		CUSTOMER ERDA/ALD				LOCATION			BY	DATE 9/15/77	
AREA AND ACCOUNT		DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR	MATERIAL	OTHER	TOTAL		
1207	PACK. SHIP. & INSPECT. (same as 1 st unit)					-0-	50.0	-0-	50.0		
TOTAL ITEMS 1201 THRU 1207						319.9	1081.3	512.7	1913.7		
<u>INTERFACE EQUIP. CONTROL & DISPLAY SYSTEMS</u>											
1301	ELEC. EQUIP. (same as 10 th unit)					115.4	523.1	-0-	638.5		
1302	INSTRU. & CONTROL (same as 10 th unit)					90.0	206.2	-0-	296.2		
TOTAL ITEMS 1301 & 1302						205.4	729.3	-0-	934.7		

BB-11

JOB STES #2 CAPITAL COST - 10th UNIT

ESTIMATE

ORDER NO.	CUSTOMER	LOCATION			BY	DATE		
19650	ERDA /ALC					9/15/77		
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR	MATERIAL	OTHER	TOTAL
<u>COLLECTOR FIELD</u>								
1101	COLLECTORS (same as 1 st unit)				194.0	733.6	41.8	969.4
1102	PIPING (same as 1 st except reduction in pipe & valves)				31.6	583.4	41.2	656.3
1103	SITE CONST'N MAT'L (same as 1 st)				151.1	197.6	13.6	362.3
1104	PACKING & SHIPPING (same as 1 st)				-0-	75.2	-0-	75.2
TOTAL ITEM 1101 THRU 1104					376.8	1589.8	96.6	2063.2
<u>ENERGY PLANT</u>								
1201	TURBINE GENERATOR							
	FOSSIL FUEL HEATER				11.3	74.3	-0-	85.6
	TOLUENE TURBINE & MISC. EQUIP. (see 1 st unit list)				90.0	581.4	-0-	671.4
	CONDENSATE FEED PUMP				0.2	0.7	-0-	0.9
	DEAERATING				0.2	1.0	-0-	1.2
TOTAL, TURBINE GEN. SYSTEM					101.7	657.4	-0-	759.1
1202	PIPING & MISC. EQUIP. (same as 1 st unit, except a slight reduction on major items of equip.)				65.6	176.7	-0-	242.3

88-12

JOB CAPITAL COST 10th unit

ESTIMATE

ORDER NO. C-19650		CUSTOMER ERDA/AGO			LOCATION			BY	DATE 9/15/77
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR	MATERIAL	OTHER	TOTAL	
1203	<u>THERMAL STORAGE</u>								
	PUMPS				1.0	3.6	-0-	4.6	
	FILTERS				0.4	12.0	-0-	12.4	
	COMP. HEATER				0.3	2.5	-0-	2.8	
	REGULATOR				0.5	1.3	-0-	1.8	
	THERMAL STORAGE TANK				-0-	-0-	340.1	340.1	
	" " RESERVOIR				-0-	-0-	92.2	92.2	
	BLENDING TANK				-0-	-0-	57.0	57.0	
	<u>TOTAL THERMAL STORAGE</u>				2.2	19.4	489.3	510.9	
1204	<u>T.S. PIPING & MISC. EQUIP.</u>				8.0	21.8	9.1	38.9	
1205	<u>BLDG & MISC. (same as 12th Unit)</u>				108.2	164.8	-0-	273.0	
1206	<u>YARDWORK (same as 12th Unit)</u>				34.2	9.5	65.7	109.4	
1207	<u>PAVE. SHED & INSPECT. (same as 12th Unit)</u>				-0-	50.0	-0-	50.0	
	<u>TOTAL ITEMS 1201 THRU 1207</u>				319.9	1099.6	549.1	1968.6	

JOB STES #2 CAPITAL COST -10th Unit

ESTIMATE

ORDER NO. C-19650		CUSTOMER ERDA / ALO			LOCATION			BY	DATE 9/15/77
AREA AND ACCOUNT	DESCRIPTION	TYPE UNIT	WEIGHT OR QUANTITY	HOURS	LABOR	MATERIAL	OTHER	TOTAL	
<u>INTERFACE EQUIP. CONTROL & DISPLAY SYS.</u>									
1301	ELEC. EQUIP & SYS. (same as for 1 unit).				115.4	523.1	-0-	638.5	
1302	<u>INSTRU. & CONTROLS</u>								
	Mini COMPUTER				10.0	61.2		71.2	
	MISC. INST. & CONTROLS				80.0	145.0		225.0	
	TOTAL INSTRU. & CONTROLS				90.0	206.2	-0-	296.2	
TOTAL ITEMS 1301 & 1302					205.4	729.3	-0-	934.7	

BB-14

