

DO NOT MICROFILM
COVER

**PRELIMINARY DESIGN OF
THE CARRISA PLAINS
SOLAR CENTRAL RECEIVER POWER PLANT
VOLUME III, BOOK 3 — APPENDICES
PART 1**

*Prepared for the Department of Energy,
San Francisco Operations Office,
under Contract DE-FC03-82SF11674*



Rockwell International
Energy Systems Group



ARCO Solar Industries

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

DO NOT MICROFILM
COVER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

NOTICE
PORTIONS OF THIS REPORT ARE ILLEGIBLE.
It has been reproduced from the best available copy to permit the broadest possible availability.

DOE/SF/11674--1-Vol.3-Bk.3-Pt.1

DE84 005780

**PRELIMINARY DESIGN OF
THE CARRISA PLAINS
SOLAR CENTRAL RECEIVER POWER PLANT
VOLUME III, BOOK 3 — APPENDICES
PART 1**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.



Rockwell International

Energy Systems Group



ARCO Solar Industries

CONTRACT: DE-FC03-82SF11674

ISSUED: 31 DECEMBER 1983

ED

This report, Preliminary Design of the Carrisa Plains Solar Central Receiver Power Plant, ESG-DOE-13404, consists of three volumes, one of which is further subdivided. These are:

Volume I. Executive Summary

Volume II. Plant Specifications

Volume III. Plant Design

Book 1. Design Description

Book 2. Design Drawings

Book 3. Appendices

Books 1, 2, and 3 in Volume III, Plant Design, are a single document, separated for reasons of format and readability. Book 1, Design Description, contains narrative material, tables, and figures suited to an 8½-in. by 11-in. format. Book 2, Design Drawings, is a 17-in. by 22-in. volume containing material whose readability is benefitted by a larger format. Graphic material cited in Book 1 is referenced as a figure if it appears in Book 1, or as a drawing if it appears in Book 2. Material appearing in Books 2 and 3 is assigned a number in accordance with the section of Book 1 in which it is referenced. Consequently, the numbering in Books 2 and 3 may appear to leave gaps.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

INDEX

| <u>Appendix Number</u> | <u>Document Number</u> | <u>Title</u> |
|----------------------------|----------------------------|--|
| PART 1 | | |
| III-2.1 | 079TI000002 | Thermal Analysis of Central Receiver for Preliminary Design Phase |
| III-2.2 | 079TI000001 | Preliminary Design Structural Analysis-Carrizo Plains Solar Receiver Subsystem |
| III-4.1 | 079TI000007 | Sodium Safety Plan |
| III-4.2 | 079TI000004 | Materials of Construction, Carrizo Plains SCRPP |
| III-4.3 | 079TI000008 | Preliminary Piping Stress Report. Carrisa Plains Unit 1 Solar Power Plant |
| PART 2 | | |
| III-4.4 | 079TI000005 | Sodium Auxiliaries Subsystem Design Report |
| III-5.1 | | Carrizo Plains 30 MW Solar Power Plant Steam Generator Assembly. Manufacturing Plan |
| III-5.2 | 079TI000006 | Thermal/Hydraulic Analysis for the Carrizo Plains Solar Power Plant Steam Generator |
| III-5.3 | 079TI000009 | Carrisa Plains Steam Generator. TAP Model of the Lower Tubesheet and Component Support |
| III-5.4 | 079TI000003 | Steam Generator Module Stress Report. Carrizo Plains Solar Thermal Power Plant |
| III-6.1 | 079000052 | Carrisa Plains Solar Plant Instrument Index |
| IV.1 | | Start-up and Shutdown Procedures |
| IV-2 | D23-30E,-30M | Plant Electrical Equipment and Power Conversion System Data Sheets |
| IV.3 | | Calculations for Selection of Cooling System Design Parameters |
| VI.1 | D23-28 | Preliminary Electrical Load List |



| | | | | | |
|-----------------|------------------|------------------|--------------------|--|-----------------------|
| GO NO. 09479 | S/A NO. 13120 | PAGE 1 OF 203 | TOTAL PAGES 204 | REV LTR/CHG NO SEE SUMMARY OF CHG A | NUMBER 079TI000002 |
|-----------------|------------------|------------------|--------------------|--|-----------------------|

PROGRAM TITLE
Carrizo Plains 30 Mwt Solar Power Plant

DOCUMENT TITLE
Thermal Analysis of Central Receiver for Preliminary Design Phase

DOCUMENT TYPE
Technical Information

SYNOPSIS
Solar Central Receiver, Thermal Analysis

ORIGINAL ISSUE DATE

REL. DATE
6-9-83 RK

APPROVALS
J. G. Rico

DATE
3-16-83

PREPARED BY/DATE
Edward M. Mouradian

DEPT
731

MAIL ADDR
LB-30

IR&D PROGRAM? YES NO
IF YES, ENTER TPA NO.

DISTRIBUTION

| * | NAME | MAIL ADDR |
|---|------|-----------|
|---|------|-----------|

| | | |
|----|-----------------|------|
| * | W R Castle | LB30 |
| * | L E Glasgow | LA19 |
| | J K Ives | LA19 |
| ** | T L Johnson | LA19 |
| * | B Katz | LA19 |
| | J A Miller | LA19 |
| ** | E M Mouradian | LB30 |
| * | L G Rico | LB30 |
| * | T H Springer | LA24 |
| * | A Z Ullman | LA19 |
| | W Veljovich | LB30 |
| * | C K Wahnsiedler | LB30 |
| | J H Walter | LB07 |

ABSTRACT

Thermal analyses for the preliminary design phase of the Receiver of the Carrizo Plains Solar Power Plant are presented. The sodium reference operating conditions ($T_{in} = 610^{\circ}\text{F}$, $T_{out} = 1050^{\circ}\text{F}$) have been considered. Included are:

- Nominal flux distribution on receiver panel
- Energy input to tubes
- Axial temperature distribution; sodium and tubes
- Sodium flow distribution,
- Sodium pressure drop, orifice calculations
- Temperature distribution in tube cut ($R-\theta$)
- Backface structure
- Nonuniform sodium outlet temperature.

Transient conditions and panel front face heat losses are not considered. These are to be addressed in a subsequent design phase. Also to be considered later are the design conditions as variations from the nominal reference (operating) condition.

An addendum, designated Appendix C, has been included describing panel heat losses, panel temperature distribution, and tube-manifold joint thermal model.

RESERVED FOR PROPRIETARY/LEGAL NOTICES

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE DOE OFFICE OF PATENT COUNSEL

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

** Complete Document

* Title Page/Summary of Change and Addendum (Pg 66 - 203) Only

NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY

| REV | SUMMARY OF CHANGE | APPROVALS AND DATE |
|-----|--|---|
| A | 1) Added sentence to Abstract; cover page. 2) Added to Table of Contents; page 2. 3) Addendum included, Appendix C; pgs. 66 - 203. | June 9, 1983 <i>E.M. Mouradian</i> <i>J.R. Rio</i> <i>Ed. Date 6-9-83 J.R.</i> |
| | | |



CONTENTS

| | Page |
|--|------|
| I. Introduction..... | 3 |
| II. Analysis and Results..... | 4 |
| A. Heat Flux Distribution on Panel - Sodium Temperature Distribution Tube (Z)..... | 5 |
| B. Energy Input to Tube - Sodium Flow Parameters..... | 11 |
| C. Orifice Calculations..... | 19 |
| D. Temperature Distribution in Tubes; R, θ ; Radial and Circumferential..... | 28 |
| E. Temperature Distribution in Tubes; Z; Axial..... | 38 |
| F. Back Face Structure..... | 49 |
| G. Panel with Nonuniform Sodium Discharge Temperature..... | 54 |
| III. References..... | 57 |

APPENDICES

| | |
|--|-----|
| Appendix A Determine ΔT_1 and ΔT_2 | 60 |
| Appendix B Tap Model Listing..... | 64 |
| Appendix C Addendum of June 1983 | 66 |
| 1) Panel Heat Loss | 67 |
| 2) Panel Temperature Distribution .. | 86 |
| 3) Tube-Manifold TAP Model | 199 |

I. INTRODUCTION

The Carrizo Plains Plant, Unit 1 is a 30-Mwt Central Solar Receiver Power Plant currently under design. In this report, presentation is made of the thermal and hydraulic analyses of the Receiver Subsystem for the Preliminary Design Phase (as laid out in IL 640-82-53, Reference 1). The design specifications are N10046 and N10048, References 2a and 2b.

The nominal operating condition is for receiver sodium inlet and outlet temperatures of 610°F and 1050°F, respectively. This is considered the "reference condition." In later analysis, deviations from this reference condition (e.g., design limits) will be investigated.

The receiver design calls for a panel (in plane form, facing north) consisting of eight subpanels. The vertical length of an individual tube is 50 ft (manifold-to-manifold) with a 40-ft active length (exposed to solar flux). Each subpanel consists of 102 tubes; 3/4-in. OD, 0.049-in. wall, 316 stainless steel. Each subpanel has a nominal width of 77.51 in. (including a 10-mil thermal expansion clearance between tubes). The overall width of the panel is approximately 52 ft. See the receiver drawings, Reference 4.

Calculations in this report are based on each tube intercepting a 0.75-in. width of the solar flux field. It has been assumed that all solar energy intercepted by the tube is absorbed by the internal sodium flow. Heat loss from the tube surface (by reflection, reradiation, and convection) has been neglected. This means that the results are conservative from a stress analysis viewpoint, but would overestimate the overall energy performance of the receiver. This is considered acceptable as these results are intended as support for the stress analysis effort. Heat loss calculations are planned for a later analysis.

The analyses presented in this report are based on the nominal solar flux distribution on the panel as shown in the receiver design specification (Reference 2b, Pages 13 and 14). In the following sections, the calculations made are presented and explained. All calculations performed are for steady-state conditions.



II. ANALYSIS AND RESULTS



A. HEAT FLUX DISTRIBUTION ON PANEL - SODIUM TEMPERATURE DISTRIBUTION TUBE (Z)

Figures A-1 and A-2 show the nominal solar flux distribution on the receiver from the Receiver Design Specification (Reference 2b).

Figure A-1 shows the vertical flux distribution for tubes in the central region of the receiver. The shape of the curve is taken to be a "normal" distribution, with a standard deviation of 10 ft. Thus, the 40-ft-high tube sees a normal distribution from -2 to +2 standard deviations, with a peak flux at mid-height of 1.20 MW/m^2 .

Figure A-2 shows the lateral flux distribution on the panel at mid-height. The central subpanels (3, 4, 5, and 6) show mid-height flux of 1.20 MW/m^2 across the entire subpanel. Subpanels 2 and 7 show a partial tapering of incident flux at the outer edges of these subpanels. But the outermost subpanels (1 and 8) show a severe variation of solar flux across the subpanel width; from 0.97 MW/m^2 to 0.225 MW/m^2 .

In those tubes which have a mid-height flux less than 1.20 MW/m^2 , it is still assumed that the vertical flux distribution is "normal," as shown in Figure A-1 with a reduction in magnitude proportionate to that of the mid-height flux.

Table A-I shows characteristics of a normal distribution curve; $-2 \leq \sigma \leq +2$. As indicated, the axially averaged flux is 0.59814 of the peak mid-height flux.

$$\left(\frac{\bar{Q}}{A}\right) = 0.59814 \left(\frac{Q}{A}\right)_c$$

axial
average

PREPARED BY: *Emm*
 CHECKED BY:
 DATE: *12/82*



PAGE NO. *6* OF
 REPORT NO. *079TI000002*
 MODEL NO.




FIGURE A-1

VERTICAL FLUX DISTRIBUTION (From Ref. 2b)

FOR "FULL THERMAL LOAD" TUBES; (Q/A) = 1.20 MW/m²

NORMAL DISTRIBUTION { LENGTH = 40 FT.
 STD. DEV. = σ = 10 FT.

For tubes with lower peak flux, (Q/A) < 1.20 MW/m², the normal distribution curve applies with proportionally lower amplitudes.







FIGURE A-2
LATERAL FLUX DISTRIBUTION
AT PANEL MID-HEIGHT, Z = 20 FT.
From Ref. 2b

$(Q/A)_t = 1.20 \text{ MW/m}^2$ FULL THERMAL LOAD TUBE
 $(Q/A)_t = 0.97 \text{ MW/m}^2$ INBOARD TUBE, PANEL 1
 $(Q/A)_t = 0.225 \text{ MW/m}^2$ OUTBOARD TUBE, PANEL 1

TABLE A-I
 "NORMAL DISTRIBUTION" VERTICAL FLUX DISTRIBUTION



NORMALIZED:
 1.0
 $.5981440943 = \frac{(26)}{4(29)}$
 $.1353352832$

$$\left\{ \text{AVERAGE HEIGHT IN BAND: } (-2\sigma \rightarrow +2\sigma) \right\} = \frac{\text{SHADED}}{\text{TOTAL RECT}} = \frac{1.0 - 2(\text{TAILS})}{(.398942 \times 4\sigma)} = \frac{(26)}{4 \times (29)}$$

$$\left\{ \text{AVERAGE HEIGHT} \right\} = 0.5981440943 \quad (24)$$

FOR AXIALLY AVERAGED POWER ALONG ONE TUBE:
 $\left(\frac{\bar{Q}}{A} \right) = 0.5981440943 \times \left(\frac{Q}{A} \right)_{\phi}$
 AXIAL AVERAGE (MID-HEIGHT)

| STORAGE TI-58C | | |
|----------------|-------------|--|
| (29) | .3989422804 | ϕ HEIGHT |
| (28) | .0539909665 | $\sigma=2$ HEIGHT |
| (27) | .022750062 | AREA, ONE TAIL ($\sigma=2$) |
| (26) | .954499876 | AREA ($\sigma=-2 \rightarrow \sigma=+2$) 1 - 2 * TAIL |
| (25) | .1353352832 | NORMALIZED HEIGHT @ $\sigma=2$ |
| (24) | .5981440943 | NORMALIZED AVERAGE HEIGHT, BETWEEN $\sigma=-2 \rightarrow \sigma=+2$ |



In Table A-II, calculations are made for energy deposition distribution on the panel, and sodium temperature in the tube. It is assumed that no heat losses occur from the panel. This means that all incident energy goes to the sodium (without the bias of higher heat loss from the upper, higher temperature, portion of the panel). The inlet and outlet temperatures of the sodium are taken at the nominal operating temperatures of 610°F and 1050°F, respectively. (This presumes the appropriate sodium flow rate.) The fraction of the total energy which is incident on the tube up to a given point is determined, and the corresponding sodium temperature calculated assuming constant sodium specific heat.

In Table A-II, Column a is z, the axial location on the tube, measured from the bottom of the 40-ft active zone, and Column b is the axial location, x, measured in standard deviations from the mid-height ($-2 \leq x \leq +2$ std. div.) Columns c and d are the height of the normal distribution curve; raw and normalized, respectively. Columns e and f are the areas under the normal distribution curves from $x = -\infty$ and $x = -2$, respectively. Column g is the ratio of the normal distribution curve area from $x = -2$ to x to the total area from $x = -2$ to $x = +2$. Thus, the value in Column g represents the fraction of the total energy incident on the tube which strikes in the region from $x = -2$ (tube bottom) to x (the point in question). For instance, 83.1% of the total energy is intercepted by the tube in the lower 29 ft of the tube. Thus, it is taken that 83.1% of the sodium temperature rise has occurred in the first 29 ft. Hence, the sodium temperature at $Z = 29$ ft is:


$$T(z = 29 \text{ ft}) = 610 + 0.831 (1050 - 610) = 975.64^\circ\text{F}.$$

This sodium temperature distribution is shown in Column h, as well as Figures E1a, b, and c.

TABLE A-II NORMAL DISTRIBUTION CURVE

FOR VERTICAL FLUX DISTRIBUTION

8 mm
12/82



$Q(x)$ = ALTITUDE
 $P(x)$ = AREA (TOTAL AREA = 1.0)
 PROGRAM 14
 TEXAS INSTRUMENTS
 TI-58C
 NOTE: $\left(\frac{dQ(x)}{dx}\right)_{MAX}$ at $\sigma = \pm 1.0$ is 0.24197075 c/c
 (29) .3989422804 $Q(x=0)$; Q ALTITUDE
 (28) .0539909665 $Q(x=\pm 2\sigma)$ EDGE ALTITUDES
 (27) .0227500620 $P(\sigma=2 \rightarrow \infty)$ AREA; ONE TAIL
 (26) .9544998760 $P(\sigma=2 \rightarrow \sigma=+2)$ NON TAIL AREA
 (25) .1353352832 NORMALIZED HEIGHT; $\sigma = \pm 2$
 (24) .5981440943 NORMALIZED MEAN HEIGHT BETWEEN $\sigma = -2 \rightarrow \sigma = +2$.

| (a) Z LOCATION FROM BOTTOM OF PANEL | (b) X LOCATION IN STANDARD DEVIATIONS FROM C $\sigma = 10$ $X = \frac{20-Z}{10}$ | (c) Q(x) ALTITUDE OF NORMAL DISTR. CURVE PRGM 14 (A) TI-58C | (d) $\frac{Q(x)}{Q(x=0)} = \frac{Q(x)}{.3989}$ NORMALIZED ALTITUDE OF NORMAL DISTR. CURVE $\Phi(z)$ | (e) P(x) AREA OF CURVE: FROM: $(\sigma - \sigma)$ TO: X PRGM 14 (B) TI-58C | (f) P(x) - P(x=2) TAIL AREA OF CURVE: FROM: $(\sigma = -2)$ TO: X (c) - (27) .022750 | (g) FRACTION OF EFFECTIVE ENERGY FROM: Z TO: Z FROM: $(\sigma = -2)$ TO: (X) ENERGY ($Z=0 \rightarrow Z$) ENERGY ($Z=0 \rightarrow Z=2$) $\frac{P(x) - \text{TAIL}}{1.0 - 2 \times \text{TAIL}} = \frac{(f)}{(26)}$ 5981440943 \rightarrow (24) | (h) SODIUM TEMP FOR: $610 \rightarrow 1050$ T_{Na} °F 610 + 440 * FRAC 610 + 440 (g) (Constant C_p) No Losses |
|---|--|---|--|---|---|--|--|
| 0. | 2.0 | .053991 | .135335 | .022750 | 0.0 | 0.0 | 610 |
| 1. | 1.9 | .065616 | .164474 | .028716 | .005966 | .006251 | 612.75 |
| 2. | 1.8 | .078950 | .197899 | .035930 | .013180 | .013808 | 616.08 |
| 3. | 1.7 | .094049 | .235744 | .044565 | .021815 | .022852 | 620.06 |
| 4. | 1.6 | .110921 | .278037 | .054799 | .032049 | .033577 | 624.77 |
| 5. | 1.5 | .129518 | .324652 | .066807 | .044057 | .046157 | 630.31 |
| 6. | 1.4 | .149727 | .375311 | .080757 | .058007 | .060772 | 636.74 |
| 7. | 1.3 | .171369 | .429557 | .096801 | .074050 | .077580 | 644.14 |
| 8. | 1.2 | .194186 | .486752 | .115070 | .092320 | .096720 | 652.56 |
| 9. | 1.1 | .217852 | .546074 | .135666 | .112916 | .118299 | 662.05 |
| 10. | 1.0 | .241971 | .606531 | .158655 | .135905 | .142384 | 672.65 |
| 11. | .9 | .266085 | .666977 | .184060 | .161310 | .169000 | 684.36 |
| 12. | .8 | .289692 | .726149 | .211855 | .189105 | .198120 | 697.17 |
| 13. | .7 | .312254 | .782705 | .241964 | .219214 | .229663 | 711.05 |
| 14. | .6 | .333225 | .835270 | .274253 | .251503 | .263492 | 725.94 |
| 15. | .5 | .352065 | .882497 | .308538 | .285787 | .299411 | 741.74 |
| 16. | .4 | .368270 | .923116 | .344578 | .321828 | .337169 | 758.35 |
| 17. | .3 | .381388 | .955997 | .382089 | .359339 | .376468 | 775.65 |
| 18. | .2 | .391043 | .980199 | .420740 | .397990 | .416962 | 793.46 |
| 19. | 0.1 | .396953 | .995012 | .460172 | .437422 | .458274 | 811.64 |
| 20. | 0 | .398942 | 1.000 | .500000 | .477250 | .500000 | 830.00 |
| 21. | -.1 | .396953 | .995012 | .539828 | .517078 | .541726 | 848.36 |
| 22. | -.2 | .391043 | .980199 | .579260 | .556510 | .583038 | 866.54 |
| 23. | -.3 | .381388 | .955997 | .617911 | .595161 | .623532 | 884.35 |
| 24. | -.4 | .368270 | .923116 | .655422 | .632672 | .662831 | 901.65 |
| 25. | -.5 | .352065 | .882497 | .691462 | .668712 | .700589 | 918.26 |
| 26. | -.6 | .333225 | .835270 | .725797 | .702997 | .736508 | 934.06 |
| 27. | -.7 | .312254 | .782705 | .758036 | .735286 | .770337 | 948.95 |
| 28. | -.8 | .289692 | .726149 | .788145 | .765395 | .801880 | 962.83 |
| 29. | -.9 | .266085 | .666977 | .815940 | .793190 | .831000 | 975.64 |
| 30. | -1.0 | .241971 | .606531 | .841345 | .818595 | .857616 | 987.35 |
| 31. | -1.1 | .217852 | .546074 | .864334 | .841584 | .881701 | 997.95 |
| 32. | -1.2 | .194186 | .486752 | .884930 | .862180 | .903280 | 1007.44 |
| 33. | -1.3 | .171369 | .429557 | .903199 | .880449 | .922420 | 1015.86 |
| 34. | -1.4 | .149727 | .375311 | .919243 | .896493 | .939228 | 1023.26 |
| 35. | -1.5 | .129518 | .324652 | .933193 | .910443 | .953843 | 1029.69 |
| 36. | -1.6 | .110921 | .278037 | .945201 | .922451 | .966423 | 1035.23 |
| 37. | -1.7 | .094049 | .235746 | .955435 | .932685 | .977145 | 1039.94 |
| 38. | -1.8 | .078950 | .197899 | .964070 | .941320 | .986192 | 1043.92 |
| 39. | -1.9 | .065616 | .164474 | .971283 | .948533 | .993749 | 1047.25 |
| 40. | -2.0 | .053991 | .135335 | .977250 | .954500 | 1.0 | 1050.0 |

Max $\frac{dQ}{dx} = 1.53 \frac{c}{in}$ (24) $\frac{dQ}{dx}$ Max @ $Z = 10M$ 30ft
 @ $Z = 20H$



B. ENERGY INPUT TO TUBE - SODIUM FLOW PARAMETERS

In Table B-I, the total energy input to an individual tube is calculated based on the mid-height solar heat flux and the properties of the axial normal distribution function. Three representative tubes are considered: full thermal load tube, inboard tube of Panel 1, and outboard tube of Panel 1. These have mid-height solar heat fluxes of 1.20 MW/m^2 , 0.97 MW/m^2 , and 0.225 MW/m^2 , respectively (see Figures A-1 and A-2).

It is assumed that all energy incident on the tube is absorbed by the internal sodium. That is, no heat losses occur from the tube. This assumption is conservative from a stress analysis standpoint, as it maximizes (mathematically) the temperature gradients and differentials in the tube metal. However, the no-loss assumption is not conservative from a performance (energy delivery) standpoint. Heat losses are to be investigated in a later phase of this work. The primary emphasis in this report is support of stress analysis.

The energy input to a tube is calculated on the basis of the projected area of 0.75-in. width * 40-ft length. The 0.01 gap between tubes (or the thermally expanded tube diameter) is not taken into account.

The energy input is used to determine the sodium flow rate within individual tubes required to maintain the sodium temperature increase from 610°F to 1050°F . Table B-II shows sodium property values (from References 5a and 5b). Table B-III is a calculation sheet for the evaluation of the sodium heat transfer coefficient within the tube. Among the parameters determined are: axially averaged heat flux, total heat input to one tube, sodium flow rate \dot{w} , Reynolds number Re , Peclet number Pe , Nusselt number Nu , and heat transfer coefficient h . Notice that of the "high" and "low" sodium heat transfer coefficients calculated, the lower one is chosen for conservatism. In the calculations that follow, the lower h value yields higher tube wall temperature differentials; hence, higher thermal stresses. (A lower h value results in a larger metal surface to liquid sodium temperature drop. Since the heat flux




is set, the result is a higher metal temperature on the front half of the tube; hence, a greater front-to-back temperature differential across the tube diameter.)

Table B-IV shows the calculation of sodium flow velocity and related parameters, some of which are used in subsequent calculations. These include gpm flow rate, transit time, velocity head, and Reynolds number. Where appropriate, these parameters are determined for: tube entrance (bottom), lower quarter, middle half, upper quarter, and exit (top).

Table B-V shows the calculation of the sodium flow pressure drop in the tubes. The calculation for each tube is in five segments, as shown. For each segment, the parameters determined are: Reynolds number Re , friction factor f , loss coefficient K , velocity head H , and pressure loss ΔP . For each segment, sodium property values are based on the local mean sodium temperature. The segmental pressure drops are summed to determine the total pressure drop in the tube, from lower manifold to upper manifold. The three tubes considered are: full thermal load, inboard panel 1, and outboard panel 1. These calculations are based on the assumption that each tube has exactly the flow rate required to maintain the 1050°F outlet sodium temperature (for inlet of 610°F) for the idealized nominal solar flux of Figures A-1 and A-2. How to bring about this proper sodium flow distribution is investigated in following calculations.

Figure B-1 is the friction factor versus Reynolds number plot (based on data from Reference 9a). For this analysis, a roughness factor of $\epsilon/D = .0001$ (based on Reference 9b) as indicated in Table B-V.

TABLE B-I
ENERGY INCIDENT ON TUBE



PROJECTED AREA
OF ONE TUBE:

$$A_{\text{PROJ}} = L \times D_o = (40 \times 12) \times (.75) = 360 \text{ in}^2 \quad (2.5 \text{ ft}^2)$$

FLOW AREA
OF ONE TUBE:

$$A_{\text{FLOW}} = \frac{\pi}{4} D_i^2 = \frac{\pi}{4} \left(\frac{.652}{12} \right)^2 = .0023186 \text{ ft}^2$$

$$1.0 \frac{\text{MW}}{\text{m}^2} = 1.0 \frac{\text{MW}}{\text{m}^2} \times 3413000 \frac{\text{BTU}}{\text{hr MW}} \times \frac{\text{hr}}{3600 \text{ sec}} \times \left(\frac{2.54}{100} \right)^2 \left(\frac{\text{cm}}{\text{in}} \frac{\text{m}}{\text{cm}} \right)^2$$

$$1.0 \frac{\text{MW}}{\text{m}^2} = \begin{cases} 0.61165 \frac{\text{BTU}}{\text{sec in}^2} \\ 317078 \frac{\text{BTU}}{\text{hr ft}^2} \end{cases}$$

$$\left(\frac{\bar{Q}}{A} \right)_{\text{AXIAL AVERAGE}} = .598144 \times \left(\frac{Q}{A} \right)_{\text{PEAK}} ; Q_{\text{ONE TUBE}} = \left(\frac{\bar{Q}}{A} \right) \times A \quad \leftarrow 360 \text{ in}^2$$

| TUBE | $\left(\frac{Q}{A} \right)_{\text{PEAK}}$ MW/m ² (BTU/in ² sec) | $\left(\frac{\bar{Q}}{A} \right) = .59814 \left(\frac{Q}{A} \right)_{\text{Pk}}$ AXIAL AVG MW/m ² (BTU/in ² sec) | Q (ONE TUBE) $Q = A \times \left(\frac{Q}{A} \right) = 360 \frac{Q}{A}$ BTU/sec |
|----------------------|--|---|--|
| FULL THERMAL LOAD | 1.20 (.73398) | 0.71777 (.43903) | - 158.049 BTU/SEC |
| INBOARD: PANEL 1 | 0.97 (.59330) | 0.58020 (.35488) | - 127.757 BTU/SEC |
| OUTBOARD: PANEL 1 | 0.225 (.13762) | 0.13458 (.08232) | - 29.634 BTU/SEC |


| | | |
|---------------------------|---|-------------------------------|
| PREPARED BY: <u>E m m</u> |  | PAGE NO. <u>14</u> OF |
| CHECKED BY: | | REPORT NO. <u>079TI000002</u> |
| DATE: <u>12/82</u> | | MODEL NO. |

TABLE B-II
SODIUM PROPERTIES

GOLDEN & TOKAR
REF. 5a

SPECIFIC HEAT:

| | | | |
|------------------------|---------------------|---------------------|--|
| T_{OF} | C_p BTU/lbm °F | h BTU/lbm | $\bar{C}_p = \frac{\Delta h}{\Delta T} = \frac{133.77}{440} = 0.30402$ |
| 1050 | 0.3001 | 471.88 | |
| (830) | (0.3034) | (405.54) | |
| <u>610</u> | <u>0.3100</u> | <u>338.11</u> | |
| $\Delta T = 440^\circ$ | | $\Delta h = 133.77$ | |

| T_{OF} TEMP | k $\frac{BTU}{hr\ ft\ ^\circ F}$ THERMAL CONDUCT | ρ $\frac{lbm}{ft^3}$ DENSITY | μ $\frac{lbm}{ft\ hr}$ VISCOSITY | C_p $\frac{BTU}{lbm\ ^\circ F}$ SPECIFIC HEAT | $Pr = \frac{\mu C_p}{k}$ PRANDTL NO. |
|-----------------------------------|---|--------------------------------------|---|--|---|
| 1050 | 36.89 | 50.971 | .5221 | .3001 | .004247 |
| 940 | 38.50 | 51.889 | .5683 | .3013 | .004499 |
| 830 | 40.15 | 52.804 | .6256 | .3034 | .004727 |
| 720 | 41.86 | 53.715 | .6984 | .3063 | .005110 |
| 610 | 43.62 | 54.623 | .7937 | .3100 | .005641 |
| AVERAGE VALUES: FULL LENGTH | 40.1913 \bar{k} | 52.8013 $\bar{\rho}$ | 0.63755 $\bar{\mu}$ | .30402 \bar{C}_p | .004823 \bar{Pr} |

- 1) $\bar{k} = \frac{1}{4} \left(\frac{k}{2} + k + k + \frac{k}{2} \right)$
- 2) $\bar{C}_p = \frac{\Delta h}{\Delta T}$
- 3) $\bar{Pr} = \frac{\bar{\mu} \bar{C}_p}{\bar{k}}$
- 4) TOP $\frac{1}{4}$ Tube:
 $\rho = \frac{1}{2} \rho + \frac{1}{2} \rho$
 $\mu = \frac{1}{2} \mu + \frac{1}{2} \mu$
- 5) Mid $\frac{1}{2}$ Tube
 $\rho = \frac{1}{2} \left(\frac{1}{2} \rho + \rho + \frac{1}{2} \rho \right)$
- 6) BOTTOM $\frac{1}{4}$ Tube
 $\rho = \frac{1}{2} \rho + \frac{1}{2} \rho$

TABLE B-III
SODIUM HEAT TRANSFER COEFFICIENT, h_{Na}

| TUBE: | FULL THERMAL LOAD | INBOARD, PANEL 1 | OUTBOARD, PANEL 1 |
|--|--------------------|-------------------|-------------------|
| PEAK FLUX @ MID-HEIGHT $(Q/A)_{\frac{1}{2}}$ MW/m ² | 1.20 | 0.97 | 0.225 |
| AXIALLY AVERAGED FLUX $(\frac{Q}{A}) = 0.598144 * (\frac{Q}{A})_{\frac{1}{2}}$ MW/m ² | .717773 | .580200 | .134582 |
| TOTAL HEAT; ONE TUBE (APPROX) $Q_{ONE TUBE} = (\frac{Q}{A})_{MW/m^2} * .61165 * 360_{BTU/sec in^2} * 360_{in^2}$ BTU/sec | 158.049 | 127.757 | 29.634 |
| SODIUM FLOW RATE; ONE TUBE $\dot{W} = \frac{Q_{BTU/sec}}{C_p \Delta T} = \frac{Q_{BTU/sec}}{(.30402)(440)}$ lbm/sec | 1.18151 | 0.95505 | 0.22153 |
| AVERAGE REYNOLDS NUMBER $\bar{Re} = \frac{4 W}{\pi D \mu}$ $D = .652/12$ ft $\mu = .63755/3600$ lbm/sec ft $Re = \frac{W * 4 * 12 * 3600}{\pi * .652 * .63755}$ $Re = 132322 W$ | 156344 | 126375 | 29314 |
| AVERAGE PECLET NUMBER $\bar{Pe} = \bar{Re} \bar{Pr}$ $\bar{Pe} = .004823 \bar{Re}$ | 754.05 | 609.50 | 141.38 |
| $\frac{1}{40} (\bar{Pe})^{0.8}$ | 5.0102 | 4.2259 | 1.3130 |
| AVERAGE NUSSLETT NUMBER: LOW: $\bar{Nu} = 5 + \frac{1}{40} \bar{Pe}^{0.8}$ HIGH: $\bar{Nu} = 7 + \frac{1}{40} \bar{Pe}^{0.8}$ (Reference 8a) | 10.0102 12.0102 | 9.2259 11.2259 | 6.3130 8.3130 |
| AVERAGE SODIUM HEAT TRANSFER COEFFICIENT $\bar{h} = \bar{Nu} \frac{k}{D} = \bar{Nu} \frac{40.1913}{.652/12} = 739.7172 \bar{Nu}$ | 7407.7 8884.2 | 6824.6 8304.0 | 4669.8 6149.2 |
| SODIUM HEAT TRANSFER COEFFICIENT $\frac{BTU}{hr ft^2 OF}$ | 7400 | 6800 | 4700 |
| FOR USE IN CALCULATIONS | | | |


| | | |
|-------------------------|---|------------------------|
| PREPARED BY: <i>EMM</i> |  Rockwell International Energy Systems Group | PAGE NO. 16 OF |
| CHECKED BY: | | REPORT NO. 079TI000002 |
| DATE: 12/82 | | MODEL NO. |

TABLE B-IV
SODIUM FLOW VELOCITIES

| TUBE: | FULL THERMAL LOAD | INBOARD, PANEL 1 | OUTBOARD, PANEL 1 | |
|--|--|---|---|---|
| PEAK FLUX @ MID-HEIGHT $(Q/A)_E$ MW/m ² | 1.20 | 0.97 | 0.225 | |
| SODIUM FLOW RATE; ONE TUBE, \dot{W} lbm/sec | 1.18151 | 0.95505 | 0.22153 | |
| SODIUM FLOW VELOCITY: $V = \frac{W}{\rho A}$, ft/sec | $\rho(\text{EXIT}) = 50.971$ $\bar{\rho}(\text{TOP } 1/4) = 51.430$ $\bar{\rho}(\text{MID } 1/2) = 52.803$ $\rho(\text{BOT } 1/4) = 54.169$ $\rho(\text{ENTR}) = 54.623$ | 10.00 9.91 9.65 9.41 9.33 | 8.08 8.01 7.80 7.60 7.54 | 1.87 1.86 1.81 1.76 1.75 |
| SODIUM FLOW, GPM $\text{GPM} = \frac{W}{\rho} \frac{1728}{231} 60$ gal./min | EXIT TOP 1/4 MID 1/2 BOT 1/4 ENTR | 10.40 10.31 10.04 9.79 9.71 | 8.41 8.33 8.12 7.91 7.85 | 1.95 1.93 1.88 1.83 1.82 |
| TRANSIT TIME (SECONDS) $L = 40 \text{ FT}; \tau = \left\{ \frac{10}{V_{\text{BOT } 1/4}} + \frac{20}{V_{\text{MID } 1/2}} + \frac{10}{V_{\text{TOP } 1/4}} \right\}$ $L = 50 \text{ FT}; \tau = \left\{ \frac{15}{V_{\text{BOT } 1/4}} + \frac{20}{V_{\text{MID } 1/2}} + \frac{15}{V_{\text{TOP } 1/4}} \right\}$ (600") | | 4.14 5.18 | 5.13 6.41 | 22.11 27.64 |
| VELOCITY HEAD; H (psi) $H = \frac{\rho V^2}{2g_c} = \frac{1}{2g_c} \frac{1}{\rho} \frac{W^2}{A^2}$ $H = \frac{1}{(2)(32.1739)} \frac{1}{\rho} \frac{W^2}{\left(\frac{\pi}{4}\right)\left(\frac{.652}{12}\right)^2} \frac{1}{144}$ $H_{\text{psi}} = 20.075143 \frac{W^2}{\rho}$ | EXIT TOP 1/4 MID 1/2 BOT 1/4 ENTR | 0.5498 0.5449 0.5307 0.5173 0.5130 | 0.3592 0.3560 0.3468 0.3380 0.3352 | 0.01933 0.01916 0.01865 0.01819 0.01804 |
| REYNOLDS NUMBER; RE $Re = \frac{4}{\pi D} \frac{W}{\rho} = \frac{4(12)3600}{\pi (.652)} \frac{W}{\rho}$ $Re = 84361.9 \frac{W}{\rho}$ | $\rho(\text{EXIT}) .5221$ $\bar{\rho}(\text{TOP } 1/4) .5452$ $\bar{\rho}(\text{MID } 1/2) .6295$ $\rho(\text{BOT } 1/4) .7461$ $\bar{\rho}(\text{ENTR}) .7937$ | 1.909×10^5 1.828×10^5 1.583×10^5 1.336×10^5 1.256×10^5 | 1.543×10^5 1.478×10^5 1.280×10^5 1.080×10^5 1.015×10^5 | 3.580×10^4 3.428×10^4 2.969×10^4 2.505×10^4 2.355×10^4 |

0022185876
00


448,331168Y

20.0751428

84361.83A

TABLE B-VI
PRESSURE DROP:

FULL THERMAL LOAD TUBES
 INBOARD TUBE; PANEL 1
 OUTBOARD TUBE; PANEL 1



DRAWN TUBING $E = .000005$ FT (Reference 8b)
 Page A.23

$$\frac{E}{D} = \frac{.000005}{.652} = .000092 \rightarrow .0001 = \frac{E}{D}$$

$$\sum K = K_{EXIT} + f \left(\frac{L}{D} \right)$$

$$H = \frac{\rho v^2}{2g_c} = \frac{1}{2g_c \rho} \left(\frac{W}{A} \right)^2$$

$$\Delta P = \sum K * H \text{ psi}$$

| TUBE | FULL THERMAL LOAD: $(Q/A)_{\Delta} = 1.20$ | INBOARD $(Q/A)_{\Delta} = 0.97$ | OUTBOARD $(Q/A)_{\Delta} = 0.225$ |
|---|---|---|---|
| EXIT: UPPER 5 FT T=1050 $K_{EXIT} = 1.0$ $\frac{L}{D} = \frac{5(12) + .7}{.652} = 93$ | $Re = 1.91 \times 10^5$ $f = .0165$ $\sum K = 1 + .0165(93) = 2.5345$ $H = .5498$ psi $\Delta P = 1.3935$ psi | $Re = 1.54 \times 10^5$ $f = .0171$ $\sum K = 1 + .0171(93) = 2.5903$ $H = .3592$ $\Delta P = 0.9304$ psi | $Re = 3.58 \times 10^4$ $f = .0222$ $\sum K = 1 + .0222(93) = 3.0646$ $H = .01933$ $\Delta P = .0592$ |
| UPPER 1/4: 10 FT $\frac{L}{D} = \frac{10(12)}{.652} = 184$ T=940 → 1050 | $Re = 1.83 \times 10^5$ $f = .0166$ $\sum K = .0166(184) = 3.0544$ $H = .5449$ psi $\Delta P = 1.6643$ psi | $Re = 1.48 \times 10^5$ $f = .0172$ $\sum K = .0172(184) = 3.1648$ $H = .3560$ $\Delta P = 1.1267$ | $Re = 3.43 \times 10^4$ $f = .0225$ $\sum K = .0225(184) = 4.14$ $H = .01916$ $\Delta P = .0793$ |
| MID 1/2: 20 FT $\frac{L}{D} = \frac{20(12)}{.652} = 368$ T=720 → 940 | $Re = 1.58 \times 10^5$ $f = .0170$ $\sum K = f \frac{L}{D} = .0170(368) = 6.256$ $H = .5307$ $\Delta P = 3.3201$ | $Re = 1.28 \times 10^5$ $f = .0178$ $\sum K = .0178(368) = 6.5504$ $H = .3968$ $\Delta P = 2.2717$ | $Re = 2.97 \times 10^4$ $f = .0235$ $\sum K = .0235(368) = 8.648$ $H = .01865$ $\Delta P = .1613$ |
| LOWER 1/4: 10 FT $\frac{L}{D} = \frac{10(12)}{.652} = 184$ T=610 → 720 | $Re = 1.34 \times 10^5$ $f = .0175$ $\sum K = .0175(184) = 3.22$ $H = .5173$ $\Delta P = 1.6657$ | $Re = 1.08 \times 10^5$ $f = .0182$ $\sum K = .0182(184) = 3.3488$ $H = .3380$ $\Delta P = 1.1319$ | $Re = 2.51 \times 10^4$ $f = .0243$ $\sum K = .0243(184) = 4.4712$ $H = .01849$ $\Delta P = .0813$ |
| ENTRANCE: LOWEST 5 FT $K_{ENTR} = 0.25$ $\frac{L}{D} = \frac{5(12) + .7}{.652} = 93$ T=610 | $Re = 1.26 \times 10^5$ $f = .0179$ $\sum K = .25 + .0179(93) = 1.9147$ $H = .5130$ $\Delta P = 0.9822$ | $Re = 1.02 \times 10^5$ $f = .0190$ $\sum K = .25 + .0190(93) = 2.017$ $H = .3352$ $\Delta P = 0.6761$ | $Re = 2.36 \times 10^4$ $f = .0247$ $\sum K = .25 + (.0247)(93) = 2.5471$ $H = .01804$ $\Delta P = .0459$ |
| TOTAL: PSI | $\sum \Delta P = 9.0258$ | $\sum \Delta P = 6.1368$ | $\sum \Delta P = 0.4270$ |

$$\Delta(\sum \Delta P) = 6.1368 - 0.4270 = 5.7098 \text{ psi}$$




FIGURE B-1 Reynolds number $N_R = \frac{DV}{\nu}$ $\Delta p = f \frac{L}{D} \frac{\rho V^2}{2g_c}$
 FRICTION FACTOR FOR PIPES



C. ORIFICE CALCULATIONS

In the preceding calculations, it has been assumed that sodium enters the tubes (at the bottom) at 610°F and exits (at the top) at 1050°F. This requires that the sodium flow rate to each subpanel must be maintained at just the proper amount to match the heat input to that subpanel. Each of the eight subpanels has an independently controlled valve for this purpose.

Having a flow control valve may be satisfactory for those subpanels with uniform heat flux laterally (identical heat load to each tube). However, as shown in Figure A-2, the end subpanels are expected to have a substantial lateral variation of solar heat flux. Thus, some control of flow to the individual tubes in the subpanel is necessary so that the sodium flow in each tube can match the heat load on the tube. Otherwise, there would be a substantial variation of tube outlet temperatures across the subpanel.

In order to minimize the variation of sodium outlet temperatures (and hence, lateral variation of tube temperatures), it is proposed that orifices (or similar devices) be incorporated in the tube inlets of the end subpanels. These orifices would be designed such as to distribute the sodium flow among the tubes of the two end subpanels to match the nominal solar flux distribution of Figure A-2.

Table C-I is based on the pressure drop data of Table B-V of Section II-B. Notice that the extreme tubes (inboard and outboard) of the end panels have a nominal mid-height heat flux of 0.97 MW/m^2 and 0.225 MW/m^2 . Assume that the sodium flow rate is somehow adjusted so that both tubes have inlet-to-outlet temperatures of 610°F to 1050°F. The required sodium flow rates result in tube pressure drops of 6.137 psi and 0.427 psi, respectively. Thus, the difference in pressure drop (5.710 psi, Table B-V) must be created in the outboard tube to match pressure drops for the desired flow distribution.



In Table C-II, the equations used to calculate the orifice flow pressure drops are shown. (Table C-III is the calculational listing for the TI58C calculator.) The method shown is expected to give reasonably close results. However, some adjustment may be necessary in the velocity-of-approach factor and the sharp-edged orifice factor.

Table C-IV shows an estimate of the required orifice sizes in the outboard tube with one orifice, or with multiple orifices in series. The series calculation is presented only as a rough estimate since the calculational method is, rigorously, not valid for multiple orifices in series unless they are separated by sufficient distance to make them independent of one another. (The flow pattern must be able to recover to its original "far upstream" condition, so that each successive orifice is independent of its predecessor.)


It is recommended that the methods shown here be used to establish approximate orifice sizes, to be followed by a water test to establish the final design.

The above discussed calculation is for the orifice of the outboard tube, with no orifice in the inboard tube. The intermediate tubes of the subpanel will also require orifices; but each one somewhat larger in diameter than that of the outboard tube since a smaller orifice pressure drop is required. In Tables C-V, C-VI, and C-VII, calculations and results are shown for orifices for tubes at intermediate locations in the end subpanels.

TABLE C-I ORIFICE CALCULATIONS

Consider orifices (or similar flow restrictor) to match sodium flow to solar heat flux in tubes of end panels.

$$\beta = \frac{d}{D}$$



$$D$$

$$A = \frac{\pi}{4} D^2$$

$$V$$

$$H = \frac{\rho V^2}{2g_c}$$

$$Re = VD \frac{\rho}{\mu}$$



$$d = \beta D$$

$$a = \frac{\pi}{4} d^2 = \frac{\pi}{4} D^2 \beta^2 = A \beta^2$$

$$v = v \frac{A}{a} = v \left(\frac{D}{d}\right)^2 = v \beta^2$$

$$h = \frac{\rho v^2}{2g_c} = \frac{\rho V^2}{2g_c \beta^4} = \frac{H}{\beta^4}$$

$$re = v d \frac{\rho}{\mu} = \frac{V}{\beta^2} \rho D \frac{\rho}{\mu} = \frac{Re}{\beta}$$



$$\Delta P (\text{INBOARD No Orifice}) = 6.1368$$

$$\Delta P (\text{OUTBOARD No Orifice}) = 0.4270$$

$$\Delta P (\text{Required Orifice}) = 5.7098 \text{ psi}$$

Orifice Drop is required in outboard tube to make total pressure drop equal to pressure drop in inboard tube.


| | | |
|-------------------------|---|-------------------------------|
| PREPARED BY: <u>EMM</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>22</u> OF |
| CHECKED BY: | | REPORT NO. <u>079TI000002</u> |
| DATE: <u>2/1983</u> | | MODEL NO.: |

TABLE C-II ORIFICE LOSS COEFFICIENT

FOR OUTBOARD TUBE:

$$\Delta P_{\text{ORIFICE LOSS}} = K(\beta) \frac{\rho V^2}{2g_c} = K(\beta) \frac{\rho V^2}{2g_c} \left(\frac{D}{d}\right)^4 = K(\beta) \frac{H}{\beta^4}$$

$$H = \frac{\rho V^2}{2g_c} \quad \begin{matrix} \text{(Main Stream Flow)} \\ \text{Velocity Head} \end{matrix}$$

$$K = \left(\frac{\pi+2}{\pi}\right)^2 \underbrace{\left[(1-\beta^4)(1-\beta^2)\right]}_{\text{Velocity of Approach Correction}} = 2.6785 \left[(1-\beta^4)(1-\beta^2)\right]$$

$\left(\frac{1}{c'}\right)^2$ For Sharptedge Orifice

References
6a & 6b

$$d_{\text{ORIFICE I.D.}} = \beta D_{\text{TUBE I.D.}}$$

FOR OUTBOARD TUBE (COMPARED TO INBOARD TUBE)

$$H = \frac{\rho V^2}{2g_c} = 0.01804 \text{ psi}$$

$$\Delta P_{\text{REQUIRED ORIFICE}} = 5.7098 \text{ psi}$$

$$D = 0.652 \text{ inch}$$

Find β (and $d = \beta D$)

by Trial & Error.

(See Program for TI-58C)

PREPARED BY:

EMM



Rockwell International
Energy Systems Group

PAGE NO. 23 OF

079TI000002

CHECKED BY:

REPORT NO.

DATE:

2/83

MODEL NO.

SOLAR

TABLE C-III

PROGRAM FOR TI58C
ORIFICE DIAMETER

PRIOR TO RUN:

STORE:

29 $(\frac{1}{c})^2 = (\frac{\pi+2}{\pi})^2 = 2.67852428$

28 $H(\text{FREE STREAM}) = \frac{PV^2}{2g_c}$ psi

27 N (NUMBER OF ORIFICES IN SERIES)

26 $\sum \Delta P$ (TOTAL REQUIRED ORIFICE DROP) psi

DURING RUN:

STORAGE:

00 $\beta = d/D$

01 $(1-\beta^4)$

02 $(1-\beta^2)$

03 $K = 2.6785(1-\beta^4)(1-\beta^2)$
29 * 01 * 02

04 $\Delta P_{\text{CALC}} = \frac{KH}{\beta^4} = \frac{03 * 28}{(00)^4}$

05 $\frac{\Delta P(\text{CALC})}{\Delta P(\text{TARGET})} \stackrel{?}{=} 1.0 = \frac{04}{06}$

06 $\Delta P_{\text{TARGET}} = \frac{\sum \Delta P}{N}$

101 76 Lbl } B
102 12 B }
103 91 R/S INPUT β
104 42 ST ϕ } β
105 00 00 }
106 33 χ^2 β^2
107 33 χ^2 β^4
108 94 +/- $-\beta^4$
109 85 +
110 01 1.0
111 95 = } $1-\beta^4$
112 42 STO } $(1-\beta^4)$
113 01 01 }
114 43 RCL } β
115 00 00 }
116 33 χ^2 β^2
117 94 +/- $-\beta^2$
118 85 +
119 01 1.0
120 95 = } $1-\beta^2$
121 42 ST ϕ } $(1-\beta^2)$
122 02 02 }
123 65 *
124 43 RCL } $(1-\beta^4)$
125 01 01 }
126 65 *
127 43 RCL } $(\frac{1}{c})^2$
128 29 29 }
129 95 = } $K = (\frac{1}{c})^2 (1-\beta^4)(1-\beta^2)$
130 42 STO } K
131 03 03 }
132 65 *
133 43 RCL } H
134 28 28 }
135 95 = KH
136 55 \div
137 53 (

138 43 RCL } β
139 00 00 }
140 33 χ^2
141 33 χ^2
142 54)
143 95 = } $\Delta P_{\text{CALC}} = \frac{KH}{\beta^4}$
144 42 ST ϕ } ΔP
145 04 04 } CALC
146 43 RCL } $\sum \Delta P$
147 26 26 }
148 55 \div
149 43 RCL } N
150 27 27 }
151 95 = } $\frac{\sum \Delta P}{N} = \Delta P_{\text{TARGET}}$
152 42 ST ϕ } ΔP_{TARGET}
153 06 06 } ONE ORIFICE
154 55 \div
155 43 RCL } ΔP_{CALC}
156 04 04 }
157 95 =
158 35 $1/X$
159 42 STO } $\frac{\Delta P_{\text{CALC}}}{\Delta P_{\text{TARGET}}} \stackrel{?}{=} 1.0$
160 05 05 }
161 91 END.

- 1) INPUT TRIAL VALUE OF β
- 2) RUN: CALCULATE ΔP_{CALC} .
- 3) RCL 05: $\frac{\Delta P_{\text{CALC}}}{\Delta P_{\text{TARGET}}}$
- 4) IF 05 = 1.0; β = Correct
If 05 \neq 1.0;
Modify β and Try Again
 $\beta' \approx \beta_0$ (RCL 05)
USE THIS FOR NEXT TRY
- 5) WHEN 05 = 1.0,
 $\Delta P_{\text{CALC}} = \Delta P_{\text{TARGET}}$.
Then: $d = \beta D$


| | | |
|------------------|--|------------------------|
| PREPARED BY: Emm |  Rockwell International Energy Systems Group | PAGE NO. 24 OF |
| CHECKED BY: | | REPORT NO. 079TI000002 |
| DATE: 2/83 | | MODEL NO. |

TABLE C-IV

FOR OUT-BOARD TUBE

ORIFICE DIAMETER:

OUTBOARD TUBE

- 29 $(\frac{1}{2})^2 = 2.67852$
- 28 $0.01804 = H$
- 27 $N=1, 2, 3, \text{etc (ORIFICE IN SERIES)}$
- 26 $5.7098 = \Delta P \text{ REQUIRED}$

.192905234

| N (27) | β | d INCH | ΔP psi CALC | $\Delta P = \frac{\Sigma \Delta P}{N}$ TARGET |
|--------|---------|--------|------------------------|--|
| 1 | .295867 | 0.1929 | 5.7098 | 5.7098 |
| 2 * | .347953 | 0.2269 | 2.8549 | 2.8549 |
| 3 * | .381708 | 0.2489 | 1.903267 | 1.903267 |
| 4 * | .407095 | 0.2654 | 1.42745 | 1.42745 |
| 5 * | .427572 | 0.2788 | 1.14196 | 1.14196 |
| 6 * | .444782 | 0.2900 | 0.95163 | 0.95163 |

* Assumes same coefficient applies for orifices in series.

ONE ORIFICE AT ENTRANCE
OF OUTBOARD TUBE:

$d = 0.1929''$ SHARP-EDGED

$D = 0.652''$





TABLE C-V
END SUB-PANEL



$$\frac{X}{X} = \frac{(\text{TUBE NO.} - 1)}{(\text{TOTAL TUBES} - 1)} = \left(\frac{\text{TUBE NO.} - 1}{101} \right)$$

$$(Q/A)_i = 0.225 + (.970 - .225) \left(\frac{X}{X} \right); \quad \frac{(Q/A)_i}{(Q/A)_{\text{INBOARD}}} = \frac{.225 + (.970 - .225) \left(\frac{X}{X} \right)}{.97}$$

$$\frac{\dot{w}_i}{\dot{w}_{\text{INBOARD}}} = \frac{(Q/A)_i}{(Q/A)_{\text{INBOARD}}}; \quad \dot{w}_i = 0.95505 \left\{ \frac{.225 + .745 \left(\frac{X}{X} \right)}{.97} \right\} \text{ lbm/sec}$$

$$\frac{H_i}{H_{\text{INBOARD}}} = \left(\frac{\dot{w}_i}{\dot{w}_{\text{INBOARD}}} \right)^2 = \left\{ \frac{.225 + .745 \left(\frac{X}{X} \right)}{.970} \right\}^2 = \left\{ \frac{(Q/A)_i}{(Q/A)_{\text{INBOARD}}} \right\}^2$$

$$H_i = H_{\text{MID-INBOARD}} \left(\frac{\dot{w}_i}{\dot{w}_{\text{INBOARD}}} \right)^2 = (.3468) \left(\frac{\dot{w}_i}{\dot{w}_{\text{INBOARD}}} \right)^2; \quad H_i = H_{\text{ENTER INBOARD}} \left(\frac{\dot{w}_i}{\dot{w}_{\text{INBOARD}}} \right)^2 = (.3352) \left(\frac{\dot{w}_i}{\dot{w}_{\text{INBOARD}}} \right)^2$$

SEE CALCULATIONS ON NEXT SHEET FOR TUBES AT
OUTBOARD EDGE, 1/4 WIDTH, MID-WIDTH, 3/4 WIDTH
AT INBOARD EDGE OF END PANEL.

SIMILAR CALCULATIONS CAN BE MADE
FOR EACH INDIVIDUAL TUBE OF END PANEL
TO DETERMINE ORIFICE REQUIREMENT.

TABLE C-VI
INTERMEDIATE FLOW PARAMETERS

| | 0 | 0.25 | 0.50 | 0.75 | 1.0 |
|--|----------|----------|----------|----------|----------|
| $(z/X)_i$ | 0 | 0.25 | 0.50 | 0.75 | 1.0 |
| $(Q/A)_i = .225 + .745(z/X)_i$ | .225 | .41125 | .5975 | .78375 | 0.970 |
| $\frac{\dot{w}_i}{\dot{w}_{INBRD}} = \frac{(Q/A)_i}{0.970}$ | .23196 | .42397 | .61598 | .80800 | 1.00 |
| $\dot{w}_i = 0.95505 \left(\frac{\dot{w}_i}{\dot{w}_{INBRD}} \right) \frac{lb_m}{sec}$ | .22153 | .40491 | .58829 | .77167 | .95505 |
| $\frac{H}{H_{INBRD}} = \left(\frac{\dot{w}_i}{\dot{w}_{IN}} \right)^2$ | .053805 | .17975 | .37943 | .65285 | 1.00 |
| $H_{MID HEIGHT i} = .3468 \left(\frac{\dot{w}_i}{\dot{w}_{IN}} \right)^2 \text{ psi}$ | .01866 | .06233 | .13158 | .22639 | .3468 |
| $H_{ENTER i} = .3352 \left(\frac{\dot{w}_i}{\dot{w}_{IN}} \right)^2 \text{ psi}$ | .01804 | .06026 | .12719 | .21885 | .3352 |
| $\Delta p \text{ (CALC) psi}$ | 0.4270 | - | - | - | 6.1368 |
| $\bar{f}_{EFFECTIVE} = \frac{\Delta p}{H_{MID} \left(\frac{L}{D} \right)^{.922}}$ Based on Mid Height Properties | 0.024819 | - | - | - | 0.019193 |
| $\bar{f}_{EFF} = \bar{f} + (f - \bar{f}) \frac{z}{X}$ $\frac{z}{X}=0 \quad \frac{z}{X}=1 \quad \frac{z}{X}=0$ | 0.024819 | 0.023413 | 0.022006 | 0.020600 | 0.019193 |
| $\Delta p = \bar{f}_{EFF} \left(\frac{L}{D} \right) H_{MID} \text{ psi}$ | 0.4270 | 1.3456 | 2.6697 | 4.2999 | 6.1368 |
| $\Delta p \text{ (ORIFICE REQUIRED) psi}$ $(6.1368 - \Delta p)$ | 5.7098 | 4.7912 | 3.4671 | 1.8369 | 0.00 |
| $H_i \text{ ENTER psi}$ | 0.01804 | 0.06026 | .12719 | .21885 | .3352 |

FOR ORIFICE PROGRAM,

* STØ 26

** STØ 28


| | | |
|-------------------------|---|-------------------------------|
| PREPARED BY: <u>Emm</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>27</u> OF _____ |
| CHECKED BY: | | REPORT NO. <u>079TI000002</u> |
| DATE: <u>2/83</u> | | MODEL NO. _____ |

TABLE C-VII
ORIFICE DIAMETERS: INTERMEDIATE TUBES

For the indicated values of ΔP_A (TOTAL REQUIRED ORIFICE LOSS) and H_2 (MAIN STREAM HEAD, ENTRANCE), $\beta = \frac{d}{D}$ and d (ORIFICE) values are obtained using program on TI58C. $N=1$ is for one orifice only in each tube. Calculations also have been made for $N=2$ and $N=3$ (orifices in series, assuming no hydraulic effect of successive orifices on one another).

| N SUCCESSIVE ORIFICES IN EACH TUBE | TUBE LOCATION | OUTBOARD | 1/4 WIDTH | MID-WIDTH | 3/4 WIDTH | INBOARD |
|---|---|----------|-----------|-----------|-----------|---------------------|
| | $(X/X) \rightarrow$ | 0 | 0.25 | 0.50 | 0.75 | 1.0 |
| | ΔP REQUIRED ORIFICE LOSS (26) psi | 5.7098 | 4.7912 | 3.4671 | 1.8369 | 0.00 |
| | H_i psi (28) ENTER | 0.01804 | 0.06026 | 0.12719 | 0.21885 | 0.3352 |
| 1 (27) | $\beta = \frac{d}{D}$ | .295867 | .406661 | .510201 | .632997 | 1.0 |
| | d inch ORIFICE | .1929" | .2651" | .3327" | .4127" | .652" NO ORIFICE |
| 2 | β | .347953 | .472267 | .582285 | .702893 | - |
| | d ORIFICE | .2269" | .3079" | .3796" | .4583" | - |
| 3 | β | .381708 | .513078 | .624751 | .741016 | - |
| | d ORIFICE | .2489 | .3345 | .4073 | .4831 | - |

$D = 0.625"$ $d = \beta \times D$



D. TEMPERATURE DISTRIBUTION IN TUBES: R, θ ; RADIAL AND CIRCUMFERENTIAL

The tubes of the receiver panel experience an unusual thermal environment. A very intense solar heat flux impinges on one side of the tube. For the analysis of this report, this heat flux is as high as 1.20 MW/m^2 (almost 1000 times the sun's normal intensity). The heat is carried away by the sodium coolant flowing within the tube. A severe temperature gradient is set up in the tube wall. Thermal stresses are induced including both T_1 and T_2 type stresses; that is, both bowing moment producing and surface peaking (see Appendix A).

The two-dimensional (radial-circumferential) temperature distributions in tube cuts have been calculated by means of the "TAP" computer program (Reference 7) nodal model shown in Figure D-1. Additional details of the model used are in Reference 3, and a listing in Appendix B. The calculation is carried out at tube mid-height, which represents the highest heat flux location. Thus, this is where the highest temperature gradients and differentials (though not the highest temperatures) occur. The sodium temperature is set at 830°F (the average of the inlet and outlet temperatures). The incident solar heat fluxes are taken as 1.20 MW/m^2 , 0.97 MW/m^2 , and 0.225 MW/m^2 , representing the full thermal load tubes, inboard tube of an end panel, and the outboard tube of an end panel (see Figure A-2). The sodium side heat transfer coefficient is calculated and tabulated in Table B-III. The incident heat flux is assumed to have a cosine distribution (which results in a slightly more front loaded condition than the actual solar flux distribution coming from a mirror field). No heat losses are taken into consideration; not reflection, radiation, or convection. This assumption yields results that are conservative from a stress viewpoint since the neglect of losses means that all the heat is to be transferred through the tube wall, giving slightly exaggerated temperature gradients and differentials. On the other hand, the neglect of heat losses will yield somewhat higher than actual thermal power performance values. The matter of heat losses and panel thermal performance will be investigated in subsequent analyses.



Figures D-2a, D-2b, and D-2c show the results of the temperature distribution calculations for the three cases indicated. Tables D-Ia, D-Ib, and D-Ic show the numerical results from the computer printout. The terms ΔT_1 and ΔT_2 are defined and explained in Appendix A.

Table D-II summarizes parameters of interest from the results of these three cases.

FIGURE D-1
THERMAL NODAL MAP

See 004TI000002, Pg. 4 & 5
Reference 3





FIGURE D-2a
TEMPERATURE DISTRIBUTION MAP

CASE: FULL THERMAL LOAD

TUBE MID-HEIGHT (Z = 20 FT)



$$(Q/A)_0 = 1.20 \frac{\text{MW}}{\text{m}^2} \text{ (COSINE-LOADING)}$$

$$h(Na) = 7400 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$$

$$T(Na) = 830 \text{ } ^\circ\text{F}$$

$$T_{\text{PEAK}} = 1022.5 \text{ } ^\circ$$

$$\bar{T}_{\text{MET}} = 871.74 \text{ } ^\circ$$

$$\Delta T_1 = 139.66 \text{ } ^\circ$$

$$\Delta T_2 = 80.98 \text{ } ^\circ$$

$$T_{\text{PK}} - \bar{T}_{\text{MET}} = \frac{\Delta T_1}{2} + \Delta T_2 = 150.81 \text{ } ^\circ$$

$$T_{\text{PK}} - T_{\text{Na}} = 192.5 \text{ } ^\circ$$

$$T_{\text{"FRONT"}} = \bar{T} + \frac{\Delta T_1}{2} = 941.57 \text{ } ^\circ$$

$$T_{\text{"BACK"}} = \bar{T} - \frac{\Delta T_2}{2} = 801.91 \text{ } ^\circ$$

$$T_{\text{Na}} = 830 \text{ } ^\circ\text{F}$$

$$h_{\text{Na}} = 7400 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$$

$$S_1 = \frac{E \alpha \Delta T_1}{2} = 18,575 \text{ PSI}$$

$$S_2 = E \alpha \Delta T_2 = 21,541 \text{ PSI}$$

$$S_{\text{TOT}} = S_1 + S_2 = 40,116 \text{ PSI}$$

$$D_0 = \frac{3}{4} \text{ " SS: 316}$$

$$t_{\text{WALL}} = 0.049 \text{ " } E \alpha = 266 \frac{\text{PSI}}{\text{ } ^\circ\text{F}}$$




FIGURE D-2b

TEMPERATURE DISTRIBUTION MAP

CASE: INBOARD; PANEL 1

TUBE MID-HEIGHT (Z = 20 FT)



$$(Q/A)_0 = 0.97 \frac{MW}{m^2} \text{ (COSINE LOADING)}$$

$$h(Na) = 6800 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$$

$$T(Na) = 830^\circ\text{F}$$

$$T_{PEAK} = 990.50^\circ$$

$$\bar{T}_{MET} = 865.16^\circ$$

$$\Delta T_1 = 117.57^\circ$$

$$\Delta T_2 = 66.56^\circ$$

$$T_{PK} - \bar{T}_{MET} = \frac{\Delta T_1}{2} + \Delta T_2 = 125.34^\circ$$

$$T_{PK} - T_{Na} = 160.50^\circ$$

$$T_{"FRONT"} = \bar{T} + \frac{\Delta T_1}{2} = 923.95^\circ$$

$$T_{"BACK"} = \bar{T} - \frac{\Delta T_1}{2} = 806.38^\circ$$

$$S_1 = \frac{E \alpha \Delta T_1}{2} = 15,637 \text{ PSI}$$

$$S_2 = E \alpha \Delta T_2 = 17705 \text{ PSI}$$

$$S_{TOT} = S_1 + S_2 = 33,342 \text{ PSI}$$

$$D_o = \frac{3}{4}'' \quad SS:316$$

$$t_{WALL} = 0.049'' \quad E \alpha = 266 \frac{PSI}{^\circ\text{F}}$$

PREPARED BY: EMM
 CHECKED BY:
 DATE: 12/82



Rockwell International
 Energy Systems Group


PAGE NO. 33 OF
 REPORT NO. 079TI000002
 MODEL NO.

FIGURE D-2c

TEMPERATURE DISTRIBUTION MAP

CASE: OUTBOARD; PANEL 1

TUBE MID-HEIGHT (Z = 20 FT)



$$(Q/A)_0 = 0.225 \frac{MW}{m^2} \text{ (COSINE LOADING)}$$

$$h(Na) = 4700 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$$

$$T(Na) = 830^\circ\text{F}$$

$$T_{PEAK} = 873.17^\circ$$

$$\bar{T}_{MET} = 839.94^\circ$$

$$\Delta T_1 = 33.13^\circ$$

$$\Delta T_2 = 16.66^\circ$$

$$T_{PK} - \bar{T}_{MET} = \frac{\Delta T_1}{2} + \Delta T_2 = 33.23^\circ$$

$$T_{PK} - T_{Na} = 43.17^\circ$$

$$T_{"FRONT"} = \bar{T} + \frac{\Delta T_1}{2} = 856.51^\circ$$

$$T_{"BACK"} = \bar{T} - \frac{\Delta T_1}{2} = 823.37^\circ$$

$$S_1 = \frac{E \alpha \Delta T_1}{2} = 4406 \text{ PSI}$$

$$S_2 = E \alpha \Delta T_2 = 4432 \text{ PSI}$$

$$S_{TOT} = S_1 + S_2 = 8838 \text{ PSI}$$

$$D_o = \frac{3}{4}'' \quad SS:316$$

$$t_{WALL} = 0.049'' \quad E \alpha = 266 \frac{PSI}{^\circ\text{F}}$$

$$T_{Na} = 830^\circ\text{F}$$

$$h_{Na} = 4700 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$$

830.0

TABLE D-Ia

TUBE CROSS-SECTION TEMPERATURE DISTRIBUTION AT TUBE MID-HEIGHT

(See Plot: Figure D2a)
(See Nodal Map: Figure D1)

FULL THERMAL LOAD TUBE

(Q/A)0 = 1.20 MW/m^2

DEL R = 49 MILS O.D. = 0.75 INCH T:NA=830F CCSINE LOADING FULL THERMAL LOAD
Q/A = 1.20 MW/M2 H:KA=7400 SS:316 MODEL 2

Table with columns: ITER NO., 240., GREATEST TEMPERATURE CHANGE PER ITERATION = 2.4414E-04, CRITICAL NODE = 313. Rows contain temperature data for nodes 101-136, 201-336, 401-435, 501-535, 601-635.

TABLE D-I b

TUBE CROSS-SECTION TEMPERATURE
DISTRIBUTION AT TUBE MID-HEIGHT

(See Plot: Figure D2b)
(See Nodal Map: Figure D1)

INBOARD TUBE; PANEL 1

$$(Q/A)_O = 0.97 \text{ MW/m}^2$$

DEL R = 49 MILS O.D. = 0.75 INCH T:NA=830F COSINE LOADING
Q/A = 0.97 MW/M2 H:NA=6800 SST316

INBOARD: PANEL 1

ITER NO. 191. GREATEST TEMPERATURE CHANGE PER ITERATION = 2.4614E-04 CRITICAL NODE = 101

| | | | | |
|--------------------|-----------------------|--------------------|-------------------|--------------------|
| DT(1) = 117.57 | DT(2) = 66.558 | T:PK-BAR = 125.34 | T:PEAK = 990.50 | T:BAR = 865.16 |
| DT:FT WL = 109.44 | DT:TUBE = 169.52 | T:NA = 830.00 | T:SINK = 60.000 | MODEL 2 = 2.0000 |
| I IN4 = 6.6632E-03 | AREA IN2 = .10791 | R:GUTER = .37500 | R:INNER = .32600 | DEL R = 4.9000E-02 |
| (Q/A)O = .97000 | ALPHA = 1.0000 | EMISS = 1.0000E-07 | H:NA = 6800.0 | K:STL |
| HT TO NA = .44362 | HT TO SK = 1.3880E-09 | HI OUT = .44362 | HT IN = .44381 | CT/IN=1? = .95956 |
| STRESS 1 = 15637. | STRESS 2 = 17704. | STRS TOT = 33341. | STRS TOT = 33341. | E+A = 266.00 |
| T 101 = 990.50 | T 102 = 988.13 | T 103 = 981.07 | T 104 = 969.50 | T 105 = 953.75 |
| T 106 = 934.23 | T 107 = 911.53 | T 108 = 886.47 | T 109 = 860.48 | T 110 = 837.20 |
| T 111 = 831.94 | T 112 = 830.52 | T 113 = 830.13 | T 114 = 820.03 | T 115 = 820.00 |
| T 116 = 829.99 | T 117 = 829.99 | T 118 = 829.99 | T 119 = 829.99 | T 120 = 829.99 |
| T 121 = 829.99 | T 122 = 829.99 | T 123 = 830.00 | T 124 = 830.03 | T 125 = 830.13 |
| T 126 = 830.52 | T 127 = 831.94 | T 128 = 837.20 | T 129 = 860.48 | T 130 = 886.47 |
| T 131 = 911.53 | T 132 = 934.23 | T 133 = 953.75 | T 134 = 969.50 | T 135 = 981.07 |
| T 136 = 988.13 | | | | |
| T 201 = 969.97 | T 202 = 967.89 | T 203 = 961.71 | T 204 = 951.59 | T 205 = 937.82 |
| T 206 = 920.77 | T 207 = 908.97 | T 208 = 879.17 | T 209 = 856.70 | T 210 = 837.00 |
| T 211 = 831.90 | T 212 = 830.51 | T 213 = 830.13 | T 214 = 830.03 | T 215 = 830.00 |
| T 216 = 829.99 | T 217 = 829.99 | T 218 = 829.99 | T 219 = 829.99 | T 220 = 829.99 |
| T 221 = 829.99 | T 222 = 829.99 | T 223 = 830.00 | T 224 = 830.03 | T 225 = 830.13 |
| T 226 = 830.51 | T 227 = 831.90 | T 228 = 837.00 | T 229 = 856.70 | T 230 = 879.17 |
| T 231 = 908.97 | T 232 = 920.77 | T 233 = 937.82 | T 234 = 951.59 | T 235 = 961.71 |
| T 236 = 967.89 | | | | |
| T 301 = 948.82 | T 302 = 947.05 | T 303 = 941.78 | T 304 = 933.16 | T 305 = 921.43 |
| T 306 = 906.94 | T 307 = 890.13 | T 308 = 871.66 | T 309 = 852.74 | T 310 = 836.43 |
| T 311 = 831.76 | T 312 = 830.48 | T 313 = 830.12 | T 314 = 830.02 | T 315 = 830.00 |
| T 316 = 829.99 | T 317 = 829.99 | T 318 = 829.99 | T 319 = 829.99 | T 320 = 829.99 |
| T 321 = 829.99 | T 322 = 829.99 | T 323 = 830.00 | T 324 = 830.02 | T 325 = 830.12 |
| T 326 = 830.48 | T 327 = 831.76 | T 328 = 836.43 | T 329 = 852.74 | T 330 = 871.66 |
| T 331 = 890.13 | T 332 = 906.94 | T 333 = 921.43 | T 334 = 933.16 | T 335 = 941.78 |
| T 336 = 947.05 | | | | |
| T 401 = 926.99 | T 402 = 925.54 | T 403 = 921.22 | T 404 = 914.16 | T 405 = 904.56 |
| T 406 = 892.70 | T 407 = 878.97 | T 408 = 863.93 | T 409 = 848.60 | T 410 = 825.56 |
| T 411 = 831.54 | T 412 = 830.42 | T 413 = 830.11 | T 414 = 830.02 | T 415 = 830.00 |
| T 416 = 829.99 | T 417 = 829.99 | T 418 = 829.99 | T 419 = 829.99 | T 420 = 829.99 |
| T 421 = 829.99 | T 422 = 829.99 | T 423 = 830.00 | T 424 = 830.02 | T 425 = 830.11 |
| T 426 = 830.42 | T 427 = 831.54 | T 428 = 835.56 | T 429 = 848.60 | T 430 = 863.93 |
| T 431 = 878.97 | T 432 = 892.70 | T 433 = 904.56 | T 434 = 914.16 | T 435 = 921.22 |
| T 436 = 925.54 | | | | |
| T 501 = 904.43 | T 502 = 903.31 | T 503 = 899.98 | T 504 = 894.54 | T 505 = 887.14 |
| T 506 = 878.02 | T 507 = 867.47 | T 508 = 855.95 | T 509 = 844.26 | T 510 = 834.42 |
| T 511 = 831.23 | T 512 = 830.33 | T 513 = 830.09 | T 514 = 830.02 | T 515 = 830.00 |
| T 516 = 829.99 | T 517 = 829.99 | T 518 = 829.99 | T 519 = 829.99 | T 520 = 829.99 |
| T 521 = 829.99 | T 522 = 829.99 | T 523 = 830.00 | T 524 = 830.02 | T 525 = 830.06 |
| T 526 = 830.33 | T 527 = 831.23 | T 528 = 834.42 | T 529 = 844.26 | T 530 = 855.95 |
| T 531 = 867.47 | T 532 = 878.02 | T 533 = 887.14 | T 534 = 894.54 | T 535 = 899.98 |
| T 536 = 903.31 | | | | |
| T 601 = 881.06 | T 602 = 880.28 | T 603 = 877.98 | T 604 = 874.22 | T 605 = 869.12 |
| T 606 = 862.84 | T 607 = 855.60 | T 608 = 847.71 | T 609 = 839.73 | T 610 = 833.05 |
| T 611 = 830.86 | T 612 = 830.23 | T 613 = 830.06 | T 614 = 830.01 | T 615 = 830.00 |
| T 616 = 829.99 | T 617 = 829.99 | T 618 = 829.99 | T 619 = 829.99 | T 620 = 829.99 |
| T 621 = 829.99 | T 622 = 829.99 | T 623 = 830.00 | T 624 = 830.01 | T 625 = 830.06 |
| T 626 = 830.23 | T 627 = 830.86 | T 628 = 833.05 | T 629 = 839.73 | T 630 = 847.71 |
| T 631 = 855.60 | T 632 = 862.84 | T 633 = 869.12 | T 634 = 874.22 | T 635 = 877.98 |
| T 636 = 880.28 | | | | |

TABLE D-1c

TUBE CROSS-SECTION TEMPERATURE DISTRIBUTION AT TUBE MID-HEIGHT

(See Plot: Figure D2c)
(See Nodal Map: Figure D1)

OUTBOARD TUBE; PANEL 1

$$(Q/A)_0 = 0.225 \text{ MW/m}^2$$

DEL R = 49 MILS O.D. = 0.75 INCH T:NA=830F COSINE LOADING
Q/A = 0.225 MW/M2 H:NA=4700 SS:216

OUT BOARD: PANEL 1

| ITER NO. 269. | | GREATEST TEMPERATURE CHANGE PER ITERATION = 2.4414E-04 | | | | CRITICAL NODE = 231 | |
|--------------------|-----------------------|--|-------------------|--------------------|--|---------------------|--|
| DT(1) = 33.133 | DT(2) = 16.662 | T:PK-BAR = 33.229 | T:PEAK = 873.17 | T:BAR = 839.94 | | | |
| DT:FT ML = 26.105 | DT:TUBE = 43.187 | T:NA = 830.00 | T:SINK = 60.000 | MODEL 2 = 2.0000 | | | |
| I IN4 = 6.6632E-03 | AREA IN2 = .1C791 | R:OUTER = .37500 | R:INNER = .32600 | DEL R = 4.9000E-02 | | | |
| (Q/A)0 = .22500 | ALPHA = 1.0000 | EMISS = 1.0000E-07 | H:NA = 4700.0 | K:STL = | | | |
| HT TO NA = .10275 | HT TO SK = 1.0861E-09 | HT CUT = .10275 | HT IN = .10295 | CT/IN=17 = .99808 | | | |
| STRESS 1 = 4406.7 | STRESS 2 = 4432.2 | STRS TOT = 8838.9 | STRS TOT = 8838.9 | E*A = 266.00 | | | |
| T 101 = 873.17 | T 102 = 872.52 | T 103 = 870.58 | T 104 = 867.42 | T 105 = 863.13 | | | |
| T 106 = 857.84 | T 107 = 851.72 | T 108 = 845.04 | T 109 = 838.20 | T 110 = 832.19 | | | |
| T 111 = 830.66 | T 112 = 830.19 | T 113 = 830.05 | T 114 = 830.01 | T 115 = 829.99 | | | |
| T 116 = 829.98 | T 117 = 829.98 | T 118 = 829.98 | T 119 = 829.98 | T 120 = 829.98 | | | |
| T 121 = 829.98 | T 122 = 829.98 | T 123 = 829.98 | T 124 = 830.00 | T 125 = 830.05 | | | |
| T 126 = 830.19 | T 127 = 830.66 | T 128 = 832.19 | T 129 = 838.20 | T 130 = 845.04 | | | |
| T 131 = 851.73 | T 132 = 857.84 | T 133 = 863.13 | T 134 = 867.42 | T 135 = 870.58 | | | |
| T 136 = 872.52 | | | | | | | |
| T 201 = 868.20 | T 202 = 867.63 | T 203 = 865.91 | T 204 = 863.11 | T 205 = 859.31 | | | |
| T 206 = 854.63 | T 207 = 849.22 | T 208 = 843.32 | T 209 = 837.32 | T 210 = 832.14 | | | |
| T 211 = 830.64 | T 212 = 830.19 | T 213 = 830.05 | T 214 = 830.00 | T 215 = 829.99 | | | |
| T 216 = 829.98 | T 217 = 829.98 | T 218 = 829.98 | T 219 = 829.98 | T 220 = 829.98 | | | |
| T 221 = 829.98 | T 222 = 829.98 | T 223 = 829.99 | T 224 = 830.00 | T 225 = 830.05 | | | |
| T 226 = 830.19 | T 227 = 830.64 | T 228 = 832.14 | T 229 = 837.32 | T 230 = 843.32 | | | |
| T 231 = 849.22 | T 232 = 854.63 | T 233 = 859.31 | T 234 = 863.12 | T 235 = 865.91 | | | |
| T 236 = 867.63 | | | | | | | |
| T 301 = 863.12 | T 302 = 862.62 | T 303 = 861.13 | T 304 = 858.70 | T 305 = 855.41 | | | |
| T 306 = 851.34 | T 307 = 846.66 | T 308 = 841.55 | T 309 = 836.39 | T 310 = 832.00 | | | |
| T 311 = 830.61 | T 312 = 830.18 | T 313 = 830.04 | T 314 = 830.00 | T 315 = 829.99 | | | |
| T 316 = 829.98 | T 317 = 829.98 | T 318 = 829.98 | T 319 = 829.98 | T 320 = 829.98 | | | |
| T 321 = 829.98 | T 322 = 829.98 | T 323 = 829.99 | T 324 = 830.00 | T 325 = 830.04 | | | |
| T 326 = 830.18 | T 327 = 830.61 | T 328 = 832.00 | T 329 = 836.39 | T 330 = 841.55 | | | |
| T 331 = 846.66 | T 332 = 851.34 | T 333 = 855.41 | T 334 = 858.71 | T 335 = 861.13 | | | |
| T 336 = 862.62 | | | | | | | |
| T 401 = 857.91 | T 402 = 857.49 | T 403 = 856.23 | T 404 = 854.18 | T 405 = 851.40 | | | |
| T 406 = 847.98 | T 407 = 844.03 | T 408 = 839.74 | T 409 = 835.41 | T 410 = 831.78 | | | |
| T 411 = 830.55 | T 412 = 830.16 | T 413 = 830.04 | T 414 = 830.00 | T 415 = 829.99 | | | |
| T 416 = 829.99 | T 417 = 829.99 | T 418 = 829.99 | T 419 = 829.99 | T 420 = 829.99 | | | |
| T 421 = 829.99 | T 422 = 829.99 | T 423 = 829.99 | T 424 = 830.00 | T 425 = 830.04 | | | |
| T 426 = 830.16 | T 427 = 830.55 | T 428 = 831.78 | T 429 = 835.41 | T 430 = 829.74 | | | |
| T 431 = 844.03 | T 432 = 847.98 | T 433 = 851.40 | T 434 = 854.19 | T 435 = 856.23 | | | |
| T 436 = 857.49 | | | | | | | |
| T 501 = 852.56 | T 502 = 852.22 | T 503 = 851.20 | T 504 = 849.55 | T 505 = 847.29 | | | |
| T 506 = 844.53 | T 507 = 841.33 | T 508 = 837.87 | T 509 = 834.39 | T 510 = 831.49 | | | |
| T 511 = 830.46 | T 512 = 830.14 | T 513 = 830.03 | T 514 = 830.00 | T 515 = 829.99 | | | |
| T 516 = 829.99 | T 517 = 829.99 | T 518 = 829.99 | T 519 = 829.99 | T 520 = 829.99 | | | |
| T 521 = 829.99 | T 522 = 829.99 | T 523 = 829.99 | T 524 = 830.00 | T 525 = 830.03 | | | |
| T 526 = 830.13 | T 527 = 830.46 | T 528 = 831.49 | T 529 = 834.39 | T 530 = 837.87 | | | |
| T 531 = 841.33 | T 532 = 844.53 | T 533 = 847.30 | T 534 = 849.55 | T 535 = 851.20 | | | |
| T 536 = 852.22 | | | | | | | |
| T 601 = 847.06 | T 602 = 846.80 | T 603 = 846.03 | T 604 = 844.78 | T 605 = 843.07 | | | |
| T 606 = 840.98 | T 607 = 838.56 | T 608 = 835.94 | T 609 = 833.32 | T 610 = 831.14 | | | |
| T 611 = 830.35 | T 612 = 830.10 | T 613 = 830.03 | T 614 = 830.00 | T 615 = 829.99 | | | |
| T 616 = 829.99 | T 617 = 829.99 | T 618 = 829.99 | T 619 = 829.99 | T 620 = 829.99 | | | |
| T 621 = 829.99 | T 622 = 829.99 | T 623 = 829.99 | T 624 = 830.00 | T 625 = 830.02 | | | |
| T 626 = 830.10 | T 627 = 830.35 | T 628 = 831.14 | T 629 = 833.32 | T 630 = 835.94 | | | |
| T 631 = 838.56 | T 632 = 840.98 | T 633 = 843.07 | T 634 = 844.78 | T 635 = 846.03 | | | |
| T 636 = 846.80 | | | | | | | |


| | | |
|-------------------------|---|------------------------|
| PREPARED BY: <u>EMM</u> |  Rockwell International Energy Systems Group | PAGE NO. 37 OF |
| CHECKED BY: | | REPORT NO. 079TI000002 |
| DATE: 12/82 | | MODEL NO. |

TABLE D-II
TUBE TEMPERATURE PARAMETERS
 TUBE MID-HEIGHT (Φ)

SS: 316
 OD = 3/4"
 tw = 0.049"
 RUN 6903-07

| | |
|--|---|
| <u>MID-HEIGHT (Φ)</u> $(Q/A)_o = 1.20 \text{ MW/m}^2$ $h(Na) = 7400 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$ $T_{Na} = 830.0$ $\bar{T}_{MET} = 871.74$ $T_{PEAK} = 1022.5$ $\Delta T_1 = 139.66$ $\Delta T_2 = 80.98$ | <u>CASE: "FULL THERMAL LOAD"</u> $\textcircled{21} (\bar{T}_{MET} - T_{Na})_{\Phi} = (871.74 - 830.0) = 41.74$ $\textcircled{22} (\Delta T_1)_{\Phi} = 139.66$ $\textcircled{23} (T_{PK} - T_{Na})_{\Phi} = (1022.5 - 830)_{\Phi} = 192.5$ $\textcircled{24} (T_{PK} - \bar{T}_{MET})_{\Phi} = (1022.5 - 871.74)_{\Phi} = 150.76$ $\textcircled{25} (\Delta T_2)_{\Phi} = 80.98$ |
|--|---|

| | |
|---|--|
| <u>MID-HEIGHT (Φ)</u> $(Q/A)_o = 0.97 \text{ MW/m}^2$ $h(Na) = 6800 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$ $T_{Na} = 830.0$ $\bar{T}_{MET} = 865.16$ $T_{PEAK} = 990.50$ $\Delta T_1 = 117.57$ $\Delta T_2 = 66.558$ | <u>CASE: INBOARD, PANEL 1</u> $\textcircled{21} (\bar{T}_{MET} - T_{Na})_{\Phi} = (865.16 - 830.0) = 35.16$ $\textcircled{22} (\Delta T_1)_{\Phi} = 117.57$ $\textcircled{23} (T_{PK} - T_{Na})_{\Phi} = (990.50 - 830)_{\Phi} = 160.50$ $\textcircled{24} (T_{PK} - \bar{T}_{MET})_{\Phi} = (990.50 - 865.16)_{\Phi} = 125.34$ $\textcircled{25} (\Delta T_2)_{\Phi} = 66.558$ |
|---|--|

| | |
|--|--|
| <u>MID-HEIGHT (Φ)</u> $(Q/A)_o = 0.225 \text{ MW/m}^2$ $h(Na) = 4700 \text{ BTU/hr ft}^2 \text{ } ^\circ\text{F}$ $T_{Na} = 830.0$ $\bar{T}_{MET} = 839.94$ $T_{PEAK} = 873.17$ $\Delta T_1 = 33.133$ $\Delta T_2 = 16.662$ | <u>CASE: OUTBOARD, PANEL 1</u> $\textcircled{21} (\bar{T}_{MET} - T_{Na})_{\Phi} = (839.94 - 830) = 9.94$ $\textcircled{22} (\Delta T_1)_{\Phi} = 33.133$ $\textcircled{23} (T_{PK} - T_{Na})_{\Phi} = (873.17 - 830)_{\Phi} = 43.17$ $\textcircled{24} (T_{PK} - \bar{T}_{MET})_{\Phi} = (873.17 - 839.94)_{\Phi} = 33.23$ $\textcircled{25} (\Delta T_2)_{\Phi} = 16.662$ |
|--|--|

E. TEMPERATURE DISTRIBUTION IN TUBES; Z; AXIAL

The axial variation of sodium temperature in the tubes has been determined in Section II-A, and shown in Table A-II (as well as being shown in Figures E-1a, b, and c). The temperature differentials and gradients that occur in a tube (in a cut normal to the tube axis) due to the heat flux at tube mid-height (peak flux location) have been determined in Section II-D, and shown in Tables D-1a, b, and c and Figures D-2a, b, and c.

The temperature distributions for cuts of the tubes other than at mid-height (peak flux) have not been separately calculated by the methods of Section II-D. Instead, it has been assumed that the local temperature distribution (R, θ) is similar to that at mid-height, and proportional to the local heat flux. The local heat flux is taken to vary according to the "normal" distribution curve of Section II-A, on Figure A-1 and Tables A-I and A-II.

Thus, at any axial tube location, the temperature distribution (r, θ) is taken to be the local sodium temperature PLUS the proportionate amount of the peak flux location temperature differentials.

$$T_i(z) = T_{Na}(z) + \phi(z) * \frac{T_i(z=20)}{\phi}$$

These calculations are laid out on Table E-I, and presented in Tables E-IIa, b, and c for the three cases of interest: "Full Thermal Load Tube," "Inboard Tube, Subpanel 1," and "Outboard Tube, Subpanel 1." Table E-III shows the computational program used with the TI58C calculator.

The axial temperature profiles thus determined are shown in Figures E-1a, b, and c. Each of these figures show five temperature curves. $T(Na)$ is the sodium temperature from Section II-A, Table A-II. $T(\text{peak})$ is the highest temperature of the tube metal, occurring on the front-center of the tube outer surface. $\bar{T}(\text{met})$ is the mean metal temperature at the entire 360° cut at location z .



T(front) and T(back) are the fictitious temperatures that create the appropriate "Moment Generating Equivalent Linear Temperature Difference," ΔT_1 , as discussed in Appendix A. That is, if it is assumed that the tube, acting as a beam, has a linear temperature profile across a diameter (front-to-back) with the magnitude of the differential ΔT_1 , then the beam would have the same tendency to bow or generate internal moments as the tube with the actual complex temperature distribution.

$$\begin{aligned} T(\text{front}) &= \bar{T}(\text{met}) + \Delta T_1/2 \\ T(\text{back}) &= \bar{T}(\text{met}) - \Delta T_1/2 \end{aligned}$$

The values of T(front) and T(back) are useful as input data for the tube thermal stress-deflection analysis.

The net axial thermal expansion of the tube is based on the axially averaged temperature. This calculation and results are shown in Table E-IV. Notice that the axially averaged metal temperature is close to, but somewhat greater than, the mean sodium temperature.

The temperature distributions (including the appropriate temperature differentials) at tube mid-height are shown in Figures D-2a, b, and c and Tables D-Ia, b, and c. These are based on the peak solar heat flux at the three reference tubes. At axial locations between Z = 0 (bottom) to Z = 40 ft (top), the increment of temperature above the local sodium temperature is assumed to vary as $\phi(Z)$; (the normalized altitude of the normal distribution curve, Column d of Table A-III).

The calculations shown in the following Tables E-IIa, b, and c are made by the equations shown in Table E-I, of the form:

$$T_i(z) = \underset{\text{Na}}{T(z)} + \phi(z) * \underset{\phi}{\Delta T_i(z=z_0)}$$

See Table A-II See Table A-II See Table D-II
Col. h Col. d


| | | |
|-------------------------|---|-------------------------------|
| PREPARED BY: <u>EMM</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>40</u> OF |
| CHECKED BY: | | REPORT NO. <u>079TI000002</u> |
| DATE: <u>11/82</u> | | MODEL NO. |

TABLE E-I

AXIAL TEMPERATURE VARIATION

FOR CALCULATIONS OF TABLES E-II_{a, b, c}
FROM DATA OF TABLES A-II & D-II

COLUMN


- 0 Z (ft) Location from bottom of panel ($0 \leq Z \leq 40$)
- 1 $T_{Na}(Z)$, Sodium Temperature; See Table A-II, Col. h ($610 \leq T_{Na} \leq 1050$)
- 2 $\phi(Z) = \frac{Q(x)}{Q_{\xi}}$; Normalized Altitude of Curve, See Table A-II, Col. d
($.1353 \leq \phi \leq 1$)
- 
- 3 $\bar{T}_{MET}(Z) = T_{Na}(Z) + (\phi) * (\bar{T}_{MET} - T_{Na})_{\xi}$; Mean Metal Temperature.
① ② Table D-II
- 4 $\Delta T_1(Z) = (\Delta T_1)_{\xi} * (\phi)$; Equivalent Moment Generating ΔT
Table D-II ②
- 5 $\frac{\Delta T_1(Z)}{2} = \frac{[\Delta T_1(Z)]}{2}$ ④
- 6 $T_{"FRONT"}(Z) = \bar{T}_{MET}(Z) + \left(\frac{\Delta T_1(Z)}{2}\right)$ $T_{"FRONT"}$ FOR STRESS MODEL
③ ④
- 7 $T_{"BACK"}(Z) = \bar{T}_{MET}(Z) - \left(\frac{\Delta T_1(Z)}{2}\right)$ $T_{"BACK"}$ FOR STRESS MODEL
③ ④
- 8 $T_{PEAK}(Z) = T_{Na}(Z) + (\phi) * [T_{PK} - T_{Na}]_{\xi}$ PEAK METAL TEMPERATURE AT Z
① ② Table D-II
- 9 $(T_{PEAK} - \bar{T}_{MET})(Z) = (\phi) * [T_{PK} - \bar{T}_{MET}]_{\xi}$ $T_{MAX} - \bar{T} = \frac{\Delta T_1}{2} + \Delta T_2$
② Table D-II
- 10 $\Delta T_2(Z) = (\phi) * (\Delta T_2)_{\xi}$
② Table D-II

TABLE E-IIa
AXIAL TEMPERATURE DISTRIBUTION

CASE: "FULL LOAD" TUBE
(Q/A) = 1.20 MW/m²

- ① $(\bar{T}_{MET} - T_{Na})_z = 41.74$
- ② $(\Delta T_1)_z = 139.66$
- ③ $(T_{PK} - T_{Na})_z = 192.50$
- ④ $(T_{PK} - \bar{T}_{MET})_z = 150.76$
- ⑤ $(\Delta T_2)_z = 80.98$

| ② Z LOCATION (FT) | ① T _{Na} (z) SODIUM | ② φ(z) NORMALIZED ALTITUDE OF CURVE | ③ T _{MET} (z) MEAN METAL TEMP | ④ ΔT ₁ (z) | ⑤ ΔT ₁ / 2 | ⑥ T _{FRONT} (z) | ⑦ T _{BACK} (z) | ⑧ T _{PEAK} (z) | ⑨ (T _{PK} - T _{MET}) (z) | ⑩ ΔT ₂ (z) |
|----------------------------|------------------------------------|---|--|--------------------------|-----------------------------|-----------------------------|----------------------------|----------------------------|---|--------------------------|
| 0 | 610.00 | .135335 | 615.65 | 18.90 | 9.45 | 625.10 | 606.20 | 636.05 | 20.40 | 10.96 |
| 1 | 612.75 | .164474 | 619.62 | 22.97 | 11.49 | 631.10 | 608.13 | 644.41 | 24.80 | 13.32 |
| 2 | 616.08 | .197899 | 624.34 | 27.64 | 13.82 | 638.16 | 610.52 | 654.18 | 29.84 | 16.03 |
| 3 | 620.06 | .235746 | 629.40 | 32.92 | 16.46 | 646.36 | 613.44 | 665.44 | 35.55 | 19.09 |
| 4 | 624.77 | .278037 | 636.38 | 38.83 | 19.42 | 655.79 | 616.96 | 678.29 | 41.93 | 22.52 |
| 5 | 630.31 | .324652 | 643.86 | 45.34 | 22.67 | 666.53 | 621.19 | 692.81 | 48.96 | 26.29 |
| 6 | 636.74 | .375311 | 652.41 | 52.42 | 26.21 | 678.61 | 626.20 | 708.99 | 56.60 | 30.39 |
| 7 | 644.14 | .429557 | 662.07 | 59.99 | 30.00 | 692.07 | 632.07 | 726.83 | 64.78 | 34.79 |
| 8 | 652.56 | .486752 | 672.88 | 67.98 | 33.99 | 706.87 | 638.89 | 746.26 | 73.40 | 39.42 |
| 9 | 662.05 | .546074 | 684.84 | 76.26 | 38.13 | 722.98 | 646.71 | 767.17 | 82.35 | 44.22 |
| 10 | 672.65 | .606531 | 697.97 | 84.71 | 42.35 | 740.32 | 655.61 | 789.91 | 91.46 | 49.12 |
| 11 | 684.36 | .666977 | 712.20 | 93.15 | 46.58 | 758.77 | 665.62 | 812.75 | 100.58 | 54.01 |
| 12 | 697.17 | .726149 | 727.48 | 101.41 | 50.71 | 778.19 | 676.77 | 836.95 | 109.50 | 58.80 |
| 13 | 711.05 | .782705 | 743.72 | 109.31 | 54.66 | 798.38 | 689.06 | 861.72 | 118.03 | 63.38 |
| 14 | 725.94 | .835270 | 760.80 | 116.65 | 58.33 | 819.13 | 702.48 | 886.73 | 125.96 | 67.64 |
| 15 | 741.74 | .882497 | 778.57 | 123.25 | 61.62 | 840.20 | 716.95 | 911.62 | 133.08 | 71.46 |
| 16 | 758.35 | .923116 | 796.88 | 128.92 | 64.46 | 861.34 | 732.42 | 936.05 | 139.21 | 74.75 |
| 17 | 775.65 | .955997 | 815.55 | 133.51 | 66.76 | 882.31 | 748.80 | 959.68 | 144.16 | 77.42 |
| 18 | 793.46 | .980199 | 834.37 | 136.89 | 68.45 | 902.82 | 765.93 | 982.15 | 147.81 | 79.38 |
| 19 | 811.64 | .995012 | 853.17 | 138.96 | 69.48 | 922.65 | 783.69 | 1003.18 | 150.05 | 80.58 |
| 20 | 830.00 | 1.00 | 871.74 | 139.66 | 69.83 | 941.57 | 801.91 | 1022.50 | 150.76 | 80.98 |
| 21 | 848.36 | .995012 | 889.89 | 138.96 | 69.48 | 959.37 | 820.41 | 1039.90 | 150.05 | 80.58 |
| 22 | 866.54 | .980199 | 907.45 | 136.89 | 68.45 | 975.90 | 839.01 | 1055.23 | 147.81 | 79.38 |
| 23 | 884.35 | .955997 | 924.25 | 133.51 | 66.76 | 991.01 | 857.50 | 1068.38 | 144.16 | 77.42 |
| 24 | 901.65 | .923116 | 940.18 | 128.92 | 64.46 | 1004.64 | 875.72 | 1079.35 | 139.21 | 74.75 |
| 25 | 918.26 | .882497 | 955.10 | 123.25 | 61.62 | 1016.72 | 893.47 | 1088.14 | 133.08 | 71.46 |
| 26 | 934.06 | .835270 | 968.92 | 116.65 | 58.33 | 1027.25 | 910.60 | 1094.85 | 125.96 | 67.64 |
| 27 | 948.95 | .782705 | 981.62 | 109.31 | 54.66 | 1036.28 | 926.96 | 1099.62 | 118.03 | 63.38 |
| 28 | 962.83 | .726149 | 993.14 | 101.41 | 50.71 | 1043.85 | 942.93 | 1102.61 | 109.50 | 58.80 |
| 29 | 975.64 | .666977 | 1003.48 | 93.15 | 46.58 | 1050.05 | 956.90 | 1104.03 | 100.58 | 54.01 |
| 30 | 987.35 | .606531 | 1012.67 | 84.71 | 42.35 | 1055.02 | 970.31 | 1109.11 | 91.46 | 49.12 |
| 31 | 997.95 | .546074 | 1020.74 | 76.26 | 38.13 | 1058.88 | 982.61 | 1103.07 | 82.35 | 44.22 |
| 32 | 1007.44 | .486752 | 1027.76 | 67.98 | 33.99 | 1061.75 | 993.77 | 1101.14 | 73.40 | 39.42 |
| 33 | 1015.86 | .429557 | 1033.79 | 59.99 | 30.00 | 1063.79 | 1003.79 | 1098.55 | 64.78 | 34.79 |
| 34 | 1023.26 | .375311 | 1038.93 | 52.42 | 26.21 | 1065.13 | 1012.72 | 1095.51 | 56.60 | 30.39 |
| 35 | 1029.69 | .324652 | 1043.24 | 45.34 | 22.67 | 1065.91 | 1020.57 | 1092.19 | 48.96 | 26.29 |
| 36 | 1035.23 | .278037 | 1046.84 | 38.83 | 19.42 | 1066.25 | 1027.42 | 1088.75 | 41.93 | 22.52 |
| 37 | 1039.94 | .235746 | 1049.78 | 32.92 | 16.46 | 1066.24 | 1033.32 | 1085.32 | 35.55 | 19.09 |
| 38 | 1043.92 | .197899 | 1052.18 | 27.64 | 13.82 | 1066.00 | 1038.36 | 1082.02 | 29.84 | 16.03 |
| 39 | 1047.25 | .164474 | 1054.12 | 22.97 | 11.49 | 1065.60 | 1042.63 | 1078.91 | 24.80 | 13.32 |
| 40 | 1050.00 | .135335 | 1055.65 | 18.90 | 9.45 | 1065.10 | 1046.20 | 1076.05 | 20.40 | 10.96 |

TABLE E-IIb
AXIAL TEMPERATURE DISTRIBUTION

CASE: INBOARD; PANEL 1

$$\left(\frac{Q}{A}\right)_0 = 0.97 \text{ MW/m}^2$$

$$\textcircled{21} (\bar{T}_{\text{MET}} - T_{\text{Na}})_d = 35.16^\circ$$

$$\textcircled{22} (\Delta T_1)_d = 117.57^\circ$$

$$\textcircled{23} (T_{\text{PK}} - T_{\text{Na}})_d = 160.50^\circ$$

$$\textcircled{24} (T_{\text{PK}} - \bar{T}_{\text{MET}})_d = 125.34^\circ$$

$$\textcircled{25} (\Delta T_2)_d = 66.558^\circ$$

| ① z | ② $T_{\text{Na}}(z)$ SODIUM | ③ $\phi(z)$ | ④ $\bar{T}_{\text{MET}}(z)$ | ⑤ $\Delta T_1(z)$ | ⑥ $\frac{\Delta T_1}{2}$ | ⑦ T(z) "FRONT" | ⑧ T(z) "BACK" | ⑨ T(z) PEAK | ⑩ $(T_{\text{PK}} - \bar{T}_{\text{MET}})$ | ⑪ $\Delta T_2(z)$ |
|--------|-----------------------------------|----------------|--------------------------------|----------------------|-----------------------------|----------------------|---------------------|-------------------|---|----------------------|
| 0 | 610.0 | .135335 | 614.76 | 15.91 | 7.96 | 622.71 | 606.80 | 631.72 | 16.96 | 9.01 |
| 1 | 612.75 | .164474 | 618.53 | 19.34 | 9.67 | 628.20 | 608.86 | 639.15 | 20.62 | 10.95 |
| 2 | 616.08 | .197899 | 623.04 | 23.27 | 11.63 | 634.67 | 611.40 | 647.84 | 24.80 | 13.17 |
| 3 | 620.06 | .235746 | 628.35 | 27.72 | 13.86 | 642.21 | 614.49 | 657.90 | 29.55 | 15.69 |
| 4 | 624.77 | .278037 | 634.55 | 32.69 | 16.34 | 650.89 | 618.20 | 669.39 | 34.85 | 18.51 |
| 5 | 630.31 | .324652 | 641.72 | 38.17 | 19.08 | 660.81 | 622.64 | 682.42 | 40.69 | 21.61 |
| 6 | 636.74 | .375311 | 649.94 | 44.13 | 22.06 | 672.00 | 627.87 | 696.98 | 47.04 | 24.98 |
| 7 | 644.14 | .429557 | 659.24 | 50.50 | 25.25 | 684.49 | 633.99 | 713.08 | 53.84 | 28.59 |
| 8 | 652.56 | .486752 | 669.67 | 57.23 | 28.61 | 698.29 | 641.06 | 730.68 | 61.01 | 32.40 |
| 9 | 662.05 | .546074 | 681.25 | 64.20 | 32.10 | 713.35 | 649.15 | 749.69 | 68.44 | 36.35 |
| 10 | 672.65 | .606531 | 693.98 | 71.31 | 35.65 | 729.63 | 658.32 | 770.00 | 76.02 | 40.37 |
| 11 | 684.36 | .666977 | 707.81 | 78.42 | 39.21 | 747.02 | 668.60 | 791.41 | 83.60 | 44.39 |
| 12 | 697.17 | .726149 | 722.71 | 85.37 | 42.69 | 765.40 | 680.02 | 813.73 | 91.02 | 48.33 |
| 13 | 711.05 | .782705 | 738.57 | 92.02 | 46.01 | 784.58 | 692.56 | 836.67 | 98.10 | 52.10 |
| 14 | 725.94 | .835270 | 755.31 | 98.20 | 49.10 | 804.41 | 706.21 | 860.00 | 104.69 | 55.59 |
| 15 | 741.74 | .882497 | 772.77 | 103.76 | 51.88 | 824.65 | 720.89 | 883.38 | 110.61 | 58.74 |
| 16 | 758.35 | .923116 | 790.81 | 108.53 | 54.27 | 845.07 | 736.54 | 906.51 | 115.70 | 61.44 |
| 17 | 775.65 | .955997 | 809.26 | 112.40 | 56.20 | 865.46 | 753.06 | 929.09 | 119.82 | 63.63 |
| 18 | 793.46 | .980199 | 827.92 | 115.24 | 57.62 | 885.54 | 770.30 | 950.78 | 122.86 | 65.24 |
| 19 | 811.64 | .995012 | 846.62 | 116.98 | 58.49 | 905.12 | 788.13 | 971.34 | 124.71 | 66.23 |
| 20 | 830.00 | 1.00 | 865.16 | 117.57 | 58.79 | 923.95 | 806.38 | 990.50 | 125.34 | 66.56 |
| 21 | 848.36 | .995012 | 883.34 | 116.98 | 58.49 | 941.84 | 824.85 | 1008.06 | 124.71 | 66.23 |
| 22 | 866.54 | .980199 | 901.00 | 115.24 | 57.62 | 958.62 | 843.38 | 1023.86 | 122.86 | 65.24 |
| 23 | 884.35 | .955997 | 917.96 | 112.40 | 56.20 | 974.16 | 861.76 | 1037.79 | 119.82 | 63.63 |
| 24 | 901.65 | .923116 | 934.11 | 108.53 | 54.27 | 988.37 | 879.84 | 1049.81 | 115.70 | 61.44 |
| 25 | 918.26 | .882497 | 949.29 | 103.76 | 51.88 | 1001.17 | 897.41 | 1059.90 | 110.61 | 58.74 |
| 26 | 934.06 | .835270 | 963.43 | 98.20 | 49.10 | 1012.53 | 914.33 | 1068.12 | 104.69 | 55.59 |
| 27 | 948.95 | .782705 | 976.47 | 92.02 | 46.01 | 1022.48 | 930.46 | 1074.57 | 98.10 | 52.10 |
| 28 | 962.83 | .726149 | 988.36 | 85.37 | 42.69 | 1031.05 | 945.67 | 1079.38 | 91.02 | 48.33 |
| 29 | 975.64 | .666977 | 999.09 | 78.42 | 39.21 | 1038.30 | 959.88 | 1082.69 | 83.60 | 44.39 |
| 30 | 987.35 | .606531 | 1008.68 | 71.31 | 35.65 | 1044.33 | 973.02 | 1084.70 | 76.02 | 40.37 |
| 31 | 997.95 | .546074 | 1017.15 | 64.20 | 32.10 | 1049.25 | 985.05 | 1085.59 | 68.44 | 36.35 |
| 32 | 1007.44 | .486752 | 1024.55 | 57.23 | 28.61 | 1053.17 | 995.94 | 1085.56 | 61.01 | 32.40 |
| 33 | 1015.86 | .429557 | 1030.96 | 50.50 | 25.25 | 1056.21 | 1005.71 | 1084.80 | 53.84 | 28.59 |
| 34 | 1023.26 | .375311 | 1036.46 | 44.13 | 22.06 | 1058.52 | 1014.39 | 1083.50 | 47.04 | 24.98 |
| 35 | 1029.69 | .324652 | 1041.10 | 38.17 | 19.08 | 1060.19 | 1022.02 | 1081.80 | 40.69 | 21.61 |
| 36 | 1035.23 | .278037 | 1045.00 | 32.69 | 16.34 | 1061.35 | 1028.66 | 1079.85 | 34.85 | 18.51 |
| 37 | 1039.94 | .235746 | 1048.23 | 27.72 | 13.86 | 1062.09 | 1034.37 | 1077.78 | 29.55 | 15.69 |
| 38 | 1043.92 | .197899 | 1050.88 | 23.27 | 11.63 | 1062.51 | 1039.24 | 1075.68 | 24.80 | 13.17 |
| 39 | 1047.25 | .164474 | 1053.03 | 19.34 | 9.67 | 1062.70 | 1043.36 | 1073.65 | 20.62 | 10.95 |
| 40 | 1050.00 | .135335 | 1054.76 | 15.91 | 7.96 | 1062.71 | 1046.80 | 1071.72 | 16.96 | 9.01 |

TABLE E-IIc
AXIAL TEMPERATURE DISTRIBUTION

CASE: OUTBOARD PANEL 1

$(Q/A)_0 = 0.225 \frac{MW}{m^2}$

- ① $(\bar{T}_{MET} - T_{Na})_0 = 9.94^\circ$
- ② $(\Delta T_1)_0 = 33.133^\circ$
- ③ $(T_{PH} - T_{Na})_0 = 43.17^\circ$
- ④ $(T_{PH} - \bar{T}_{MET})_0 = 33.23^\circ$
- ⑤ $(\Delta T_2)_0 = 16.662^\circ$

| ⑥ | ① | ② | ③ | ④ | ⑤ | ⑥ | ⑦ | ⑧ | ⑨ | ⑩ |
|----|-----------------------|-----------|--------------------|-----------------|------------------------|-----------------|----------------|---------------|----------------------------------|-----------------|
| Z | $T_{Na}(Z)$ SODIUM | $\Phi(Z)$ | $\bar{T}_{MET}(Z)$ | $\Delta T_1(Z)$ | $\frac{\Delta T_1}{Z}$ | T(Z) "FRONT" | T(Z) "BACK" | $T_{PEAK}(Z)$ | $(T_{PH} - \bar{T}_{MET})_{(Z)}$ | $\Delta T_2(Z)$ |
| 0 | 610.00 | .135335 | 611.35 | 4.48 | 2.24 | 613.59 | 609.10 | 615.84 | 4.50 | 2.25 |
| 1 | 612.75 | .164474 | 614.38 | 5.45 | 2.72 | 617.11 | 611.66 | 619.85 | 5.47 | 2.74 |
| 2 | 616.08 | .197899 | 618.05 | 6.56 | 3.28 | 621.33 | 614.77 | 624.62 | 6.58 | 3.30 |
| 3 | 620.06 | .235746 | 622.40 | 7.81 | 3.91 | 626.31 | 618.50 | 630.24 | 7.83 | 3.93 |
| 4 | 624.77 | .278037 | 627.53 | 9.21 | 4.61 | 632.14 | 622.93 | 636.77 | 9.24 | 4.63 |
| 5 | 630.31 | .324652 | 633.54 | 10.76 | 5.38 | 638.92 | 628.16 | 644.33 | 10.79 | 5.41 |
| 6 | 636.74 | .375311 | 640.47 | 12.44 | 6.22 | 646.69 | 634.25 | 652.94 | 12.47 | 6.25 |
| 7 | 644.14 | .429557 | 648.41 | 14.23 | 7.12 | 655.53 | 641.29 | 662.68 | 14.27 | 7.16 |
| 8 | 652.56 | .486752 | 657.40 | 16.13 | 8.06 | 665.46 | 649.33 | 673.57 | 16.17 | 8.11 |
| 9 | 662.05 | .546074 | 667.48 | 18.09 | 9.05 | 676.52 | 658.43 | 685.62 | 18.15 | 9.10 |
| 10 | 672.65 | .606531 | 678.68 | 20.10 | 10.05 | 688.73 | 668.63 | 698.83 | 20.16 | 10.11 |
| 11 | 684.36 | .666977 | 690.99 | 22.10 | 11.05 | 702.04 | 679.94 | 713.15 | 22.16 | 11.11 |
| 12 | 697.17 | .726149 | 704.39 | 24.06 | 12.03 | 716.92 | 692.36 | 728.52 | 24.13 | 12.10 |
| 13 | 711.05 | .782705 | 718.83 | 25.93 | 12.97 | 731.80 | 705.86 | 744.84 | 26.01 | 13.04 |
| 14 | 725.94 | .835270 | 734.24 | 27.68 | 13.84 | 748.08 | 720.41 | 762.00 | 27.76 | 13.92 |
| 15 | 741.74 | .882497 | 750.51 | 29.24 | 14.62 | 765.13 | 735.89 | 779.84 | 29.33 | 14.70 |
| 16 | 758.35 | .923116 | 767.53 | 30.59 | 15.29 | 782.82 | 752.23 | 798.20 | 30.68 | 15.38 |
| 17 | 775.65 | .955997 | 785.15 | 31.68 | 15.84 | 800.99 | 769.32 | 816.92 | 31.77 | 15.93 |
| 18 | 793.46 | .980199 | 803.20 | 32.48 | 16.24 | 819.44 | 786.96 | 835.78 | 32.57 | 16.33 |
| 19 | 811.64 | .995012 | 821.53 | 32.97 | 16.48 | 838.01 | 805.05 | 854.59 | 33.06 | 16.58 |
| 20 | 830.00 | 1.00 | 839.94 | 33.13 | 16.57 | 856.51 | 823.37 | 873.17 | 33.23 | 16.66 |
| 21 | 848.36 | .995012 | 858.27 | 32.97 | 16.48 | 874.75 | 841.79 | 891.93 | 33.06 | 16.58 |
| 22 | 866.54 | .980199 | 876.28 | 32.48 | 16.24 | 892.52 | 860.04 | 908.86 | 32.57 | 16.33 |
| 23 | 884.35 | .955997 | 893.85 | 31.68 | 15.84 | 909.69 | 878.02 | 925.62 | 31.77 | 15.93 |
| 24 | 901.65 | .923116 | 910.83 | 30.59 | 15.29 | 926.12 | 895.53 | 941.50 | 30.68 | 15.38 |
| 25 | 918.26 | .882497 | 927.03 | 29.24 | 14.62 | 941.65 | 912.41 | 956.36 | 29.33 | 14.70 |
| 26 | 934.06 | .835270 | 942.36 | 27.68 | 13.84 | 956.20 | 928.53 | 970.12 | 27.76 | 13.92 |
| 27 | 948.95 | .782705 | 956.73 | 25.93 | 12.97 | 969.70 | 943.76 | 982.74 | 26.01 | 13.04 |
| 28 | 962.83 | .726149 | 970.05 | 24.06 | 12.03 | 982.08 | 958.02 | 994.18 | 24.13 | 12.10 |
| 29 | 975.64 | .666977 | 982.27 | 22.10 | 11.05 | 993.32 | 971.22 | 1004.43 | 22.16 | 11.11 |
| 30 | 987.35 | .606531 | 993.38 | 20.10 | 10.05 | 1003.43 | 983.33 | 1013.53 | 20.16 | 10.11 |
| 31 | 997.95 | .546074 | 1003.38 | 18.09 | 9.05 | 1012.42 | 994.33 | 1021.52 | 18.15 | 9.10 |
| 32 | 1007.44 | .486752 | 1012.28 | 16.13 | 8.06 | 1020.34 | 1004.21 | 1028.45 | 16.17 | 8.11 |
| 33 | 1015.86 | .429557 | 1020.13 | 14.23 | 7.12 | 1027.25 | 1013.01 | 1034.40 | 14.27 | 7.16 |
| 34 | 1023.26 | .375311 | 1026.94 | 12.44 | 6.22 | 1033.21 | 1020.77 | 1039.46 | 12.47 | 6.25 |
| 35 | 1029.69 | .324652 | 1032.92 | 10.76 | 5.38 | 1038.30 | 1027.54 | 1043.71 | 10.79 | 5.41 |
| 36 | 1035.23 | .278037 | 1037.99 | 9.21 | 4.61 | 1042.60 | 1033.39 | 1047.23 | 9.24 | 4.63 |
| 37 | 1039.94 | .235746 | 1042.28 | 7.81 | 3.91 | 1046.19 | 1038.38 | 1050.12 | 7.83 | 3.93 |
| 38 | 1043.92 | .197899 | 1045.89 | 6.56 | 3.28 | 1049.17 | 1042.61 | 1052.46 | 6.58 | 3.30 |
| 39 | 1047.25 | .164474 | 1048.88 | 5.45 | 2.72 | 1051.61 | 1046.16 | 1054.35 | 5.47 | 2.74 |
| 40 | 1050.00 | .135335 | 1051.35 | 4.48 | 2.24 | 1053.59 | 1049.10 | 1055.84 | 4.50 | 2.25 |

SOLAR

TABLE E-III

PROGRAM FOR TI58C

PRIOR TO RUN:

STORE:

21 $(\bar{T}_{MET} - T_{Na}) \epsilon$

22 $(\Delta T_1) \epsilon$

23 $(T_{PK} - T_{Na}) \epsilon$

24 $(T_{PK} - \bar{T}_{MET}) \epsilon$

25 $(\Delta T_2) \epsilon$

DURING RUN:

STORAGE:

01 $T_{Na} (z)$

02 $\phi (z)$

03 $\bar{T}_{MET} (z)$

04 $\Delta T_1 (z)$

05 $\Delta T_1 / 2 (z)$

06 $T_{FRONT} (z)$

07 $T_{BACK} (z)$

08 $T_{PEAK} (z)$

09 $(T_{PK} - \bar{T}_{MET}) (z)$

10 $\Delta T_2 (z)$

RUN (LBL C)

76 Lbl } C

13 C } C

91 R/S INPUT $T_{Na}(z)$

42 ST ϕ } T_{Na}

01 01 } T_{Na}

91 R/S INPUT $\phi(z)$

42 ST ϕ } ϕ

02 02 } ϕ

43 RCL } ϕ

02 02 } ϕ

65 *

43 RCL } $(\bar{T}_{MET} - T_{Na}) \epsilon$

21 21 } $(\bar{T}_{MET} - T_{Na}) \epsilon$

95 = $\phi(\bar{T}_{MET} - T_{Na}) \epsilon$

85 +

43 RCL } T_{Na}

01 01 } T_{Na}

95 = } $\bar{T}_{MET} (z)$

42 ST ϕ } $\bar{T}_{MET} (z)$

03 03 } $\bar{T}_{MET} (z)$

43 RCL } ϕ

02 02 } ϕ

65 *

43 RCL } $\Delta T_1 \epsilon$

22 22 } $\Delta T_1 \epsilon$

95 = } $\Delta T_1 (z)$

42 ST ϕ } $\Delta T_1 (z)$

04 04 } $\Delta T_1 (z)$

55 \div

02 2. } $\Delta T_1 (z)$

95 = } $\frac{\Delta T_1 (z)}{2}$

42 ST ϕ } $\frac{\Delta T_1 (z)}{2}$

05 05 } $\frac{\Delta T_1 (z)}{2}$

43 RCL } $\bar{T}_{MET} (z)$

03 03 } $\bar{T}_{MET} (z)$

85 +

43 RCL } $\frac{\Delta T_1 (z)}{2}$

05 05 } $\frac{\Delta T_1 (z)}{2}$

95 = } $T (z)$

42 ST ϕ } $T (z)$

06 06 } $T (z)$

43 RCL } $\bar{T}_{MET} (z)$

03 03 } $\bar{T}_{MET} (z)$

75 -

43 RCL } $\frac{\Delta T_1}{2} (z)$

05 05 } $\frac{\Delta T_1}{2} (z)$

95 = } $T (z)$

42 ST ϕ } $T (z)$

07 07 } $T (z)$

43 RCL } ϕ

02 02 } ϕ

65 *

43 RCL } $(T - T_{Na}) \epsilon$

23 23 } $(T - T_{Na}) \epsilon$

95 = } $\phi(T_{PK} - T_{Na}) \epsilon$

85 +

43 RCL } $T_{Na} (z)$

01 01 } $T_{Na} (z)$

95 = } $T_{PEAK} (z)$

42 ST ϕ } $T_{PEAK} (z)$

08 08 } $T_{PEAK} (z)$

43 RCL } ϕ

02 02 } ϕ

65 *

43 RCL } $(T_{PK} - \bar{T}_{MET}) \epsilon$

24 24 } $(T_{PK} - \bar{T}_{MET}) \epsilon$

95 = } $(T_{PK} - \bar{T}_{MET}) (z)$

42 ST ϕ } $(T_{PK} - \bar{T}_{MET}) (z)$

09 09 } $(T_{PK} - \bar{T}_{MET}) (z)$

43 RCL } ϕ

02 02 } ϕ

65 *

43 RCL } $\Delta T_2 \epsilon$


25 25 } $\Delta T_2 \epsilon$


95 = } $\Delta T_2 (z)$

42 ST ϕ } $\Delta T_2 (z)$

10 10 } $\Delta T_2 (z)$

91 END








TABLE E - IV

AXIALLY AVERAGED METAL TEMPERATURE, $\bar{\bar{T}}_{MET}$

The value $\bar{\bar{T}}_{MET}$ is the average metal temperature at a particular cross-section (θ, r average). The value of $(\bar{T}_{MET} - T_{Na})_{\phi}$ is the maximum differential between local average metal temperature and local sodium temperature. The axially averaged value of $(\bar{\bar{T}}_{MET} - T_{Na})_{\phi} = .59814 * (\bar{T}_{MET} - T_{Na})_{\phi}$ based on the Normal Distribution Curve of Table A-I. The axially averaged sodium temperature is $830^{\circ}F$, based on the symmetry of the axial sodium temperature profile. Thus, the axially averaged metal temperature (actually averaged in z, θ and r) is given by:

$$\begin{aligned}
 \bar{\bar{T}}_{MET} &= \bar{T}_{Na} + (\bar{T}_{MET} - T_{Na})_{\phi} * .598144 \\
 \text{AXIAL AVERAGE} & \quad \text{AXIAL AVERAGE} \quad \text{CROSS-SECTION AVERAGE} \quad \text{AVERAGE HEIGHT; NORMAL DISTRIBUTION} \\
 (830^{\circ}F) & \quad \text{Table D-II} \quad \text{Table A-I}
 \end{aligned}$$

| TUBE | (Q/A) _φ MW/m ² | (T̄ _{MET} - T _{Na}) _φ z=0 TUBE MID-HEIGHT Table D-II | .598144 * (T̄ _{MET} - T _{Na}) _φ = (T̄ _{MET} - T̄ _{Na}) AXIAL AVG | T̄ _{MET} AXIAL AVERAGE (use for Thermal Expansion) |
|-------------------|---|---|---|---|
| FULL THERMAL LOAD | 1.20 | 41.74 | 24.967 | <u>854.97°</u> |
| INBOARD; PANEL 1 | 0.97 | 35.16 | 21.031 | <u>851.03°</u> |
| OUTBOARD PANEL 1 | 0.225 | 9.94 | 5.946 | <u>835.95°</u> |

ALTERNATIVE: To determine $\bar{\bar{T}}_{MET}$: Go to Tables E-II, Column 3:

$$\bar{\bar{T}}_{MET} = \frac{1}{40} \left[\frac{T(z=0) + T(z=40)}{2} + \sum_{z=1}^{39} T(z) \right]$$




F. BACK FACE STRUCTURE

Calculations have been made to determine temperatures on the back face structure of the receiver panel: "hat bands," "tangs," and the panel back face.



The calculations indicate panel back face temperatures of approximately 220°F at the top ($T_{Na} = 1050^{\circ}\text{F}$) and 190°F at the bottom ($T_{Na} = 610^{\circ}\text{F}$) for an ambient temperature of 150°F. The calculations show hat band temperatures of approximately 230°F and 195°F at the panel top and bottom, respectively.

Overall heat loss from the back face of the panel is equal to or less than 0.6 KW/m_2 , which is considerably less than the 3.0 KW/m^2 maximum allowable by the Receiver Specification (Reference 2b, Section 3.3.2.8).

The tang configuration has not been established yet. The calculations take into account both tang configurations under consideration, and the calculated results reflect the behavior of the configuration with the more adverse thermal effect.


| | | |
|-------------------------|--|------------------------|
| PREPARED BY: <i>Emm</i> |  | PAGE NO. 50 OF |
| CHECKED BY: | | REPORT NO. 079TI000002 |
| DATE: 2/83 | | MODEL NO. |

CALCULATION SHEET F-1
HAT-BAND, TANGS & PANEL BACK FACE




GEOMETRIC PARAMETERS ASSUMED FOR THERMAL CALCULATIONS.


- (INSULATION THICKNESS) = 4 INCH (or more) CERAFELT
- (HAT BAND WIDTH (ONE TUBE WIDTH)) = 0.75"
- (CELL HEIGHT (C.C. HAT BANDS)) = 48"
- (INSULATION AREA (UNIT CELL; ONE TANGSET)) = (.75)(48) = 36 in²
- (GROSS EXPOSED HAT-BAND AREA (ONE TANG SET)) = (6)(.75) = 4.5 in²
- (EFFECTIVE EXPOSED HAT-BAND SURFACE AREA (ONE TANG SET)) ≈ 4.0 in²
- (TANG CROSS-SECTION AREA (ONE TANG SET (2)))
 - a) TWO STRIPS: 2(.035)(.375) = .02625 in²
 - b) TWO PINS: 2($\frac{\pi}{4}$)(.104)² = .0170 in²



OR:



TUBE & TANGS: STAINLESS STEEL


| | | |
|------------------|---|------------------------|
| PREPARED BY: Emm |  Rockwell International Energy Systems Group | PAGE NO. 51 OF |
| CHECKED BY: | | REPORT NO. 079TI000002 |
| DATE: 2/83 | | MODEL NO. |

CALC SHEET F-2

How MUCH HEAT IS LOST THROUGH BACK OF PANEL?
(Through insulation and tangs.)

$$\dot{q} = kA \frac{\Delta T}{\Delta x}$$

Consider one "cell" near top of panel, (Max heat loss location).



$$\Delta T \cong T_{HOT} - T_{AMB} = 1050 - 150 = 900^\circ F$$

$$\Delta x \cong 4 \text{ INCH}$$

$$\left\{ \begin{array}{l} k_{INSUL} \text{ (CERAFELT)} \cong 0.75 \frac{\text{BTU in}}{\text{ft}^2 \text{ of hr}} \rightarrow 0.0625 \frac{\text{BTU}}{\text{hr ft}^2 \text{ of}} \\ \text{(Johns-Manville Bulletin) Ref. 10a} \end{array} \right.$$

$$\left\{ \begin{array}{l} A_{INSUL} = 36 \text{ in}^2 \end{array} \right.$$

$$\left\{ \begin{array}{l} k_{TANGS} \text{ (SS)} \cong 11.0 \frac{\text{BTU}}{\text{hr ft}^2 \text{ of}} \quad \text{Ref. 10b} \end{array} \right.$$

$$\left\{ \begin{array}{l} a_{TANGS} = \begin{cases} .02625 \text{ in}^2 \\ .0170 \text{ in}^2 \end{cases} \quad \text{Use Larger Value} \end{array} \right.$$

$$Q_{LOSS} = kA \frac{\Delta T}{\Delta x} + k a \frac{\Delta T}{\Delta x} = A \frac{\Delta T}{\Delta x} \left(k_{INSUL} + \frac{k_{SS} a}{A} \right)$$


$$\frac{Q}{A} \leq \frac{\Delta T}{\Delta x} \left(k_{INSUL} + \frac{k_{SS} a}{A} \right) = \frac{900}{\frac{4}{12}} \left(.0625 + 11.0 \left(\frac{.02625}{36} \right) \right)$$

.008021

$$\frac{Q}{A} = 190.4 \frac{\text{BTU}}{\text{hr ft}^2}$$


$$190.4 \frac{\text{BTU}}{\text{hr ft}^2} \times \frac{1 \text{ hr kw}}{3413 \text{ BTU}} \times \frac{1 \text{ ft}^2}{(.3048)^2 \text{ m}^2} = 0.60 \frac{\text{kw}}{\text{m}^2}$$

$\left(\frac{Q}{A} \right) \leq 190 \frac{\text{BTU}}{\text{hr ft}^2} \cong 0.60 \frac{\text{kw}}{\text{m}^2}$
 HEAT LOSS FROM BACK OF PANEL
 THIS IS SUBSTANTIALLY LESS THAN THE $3.0 \frac{\text{kw}}{\text{m}^2}$ WHICH IS THE MAXIMUM ALLOWABLE $\Phi 3.3.2.8$ OF SPECIFICATION

| | | |
|-------------------------|--|------------------------|
| PREPARED BY: <i>Emm</i> |  Rockwell International Energy Systems Group | PAGE NO. 52 OF |
| CHECKED BY: | | REPORT NO. 079TI000002 |
| DATE: 2/83 | | MODEL NO. |

CALC SHEET F-3

$T_3 = 150^\circ\text{F}$ DETERMINE TEMPERATURE AT BACK FACE OF PANEL



$$Q_1 = Q_2 + Q_3$$

IN COND OUT CONV OUT RAD

$(A = 1.0 \text{ ft}^2)$

$$Q_1 = kA \frac{\Delta T}{\Delta x} = .0625 \frac{\text{BTU}}{\text{hr ft}^\circ\text{F}} \frac{1.0 \text{ ft}^2 (T_1 - T_2)^\circ\text{F}}{\frac{4}{12} \text{ ft}}; \quad Q_1 = .1875 (T_1 - T_2) \overset{1050}{\text{or } 610}$$

$$Q_2 = Ah \Delta T = 1.0 \text{ ft}^2 \cdot 0.2 \Delta T^{1/3} \Delta T = 0.2 (T_2 - T_3)^{4/3}; \quad Q_2 = 0.2 (T_2 - 150)^{4/3}$$

$$Q_3 = A \epsilon \sigma \bar{T}_R^3 \Delta T = (1)(.75)(1.713)(4) \left(\frac{\bar{T}_R}{1000} \right)^3 \Delta T; \quad Q_3 = 5.14 \left(\frac{\bar{T}_R}{1000} \right)^3 (T_2 - 150)$$

$\epsilon = 0.75$
 $\sigma = 1.713 \times 10^{-9}$
 $A = 1 \text{ ft}^2$

$\bar{T}_R = \left(\frac{T_2 + T_3}{2} + 460 \right)$

SOLVE FOR T_2 BY TRIAL & ERROR: $Q_1 = Q_2 + Q_3$

FOR $T_1 = 1050^\circ\text{F}$
TRY $T_2 = 221^\circ\text{F}$

$$T_2 - T_3 = 221 - 150 = 71$$

$$\bar{T}_R = \frac{221 + 150}{2} + 460 = 645.5$$

$$Q_1 = .1875 (1050 - 221) = 155.44_{\text{IN}}$$

$$Q_2 = .2 (71)^{4/3} = 58.80_{\text{OUT}}$$

$$Q_3 = 5.14 \left(\frac{645.5}{1000} \right)^3 (71) = 98.15_{\text{OUT}}$$

} 156.95

IN = OUT, $155.44 \approx 156.95$

$T_2 = 221^\circ\text{F}$
FOR $T_1 = 1050^\circ\text{F}$

FOR $T_1 = 610^\circ\text{F}$
SIMILAR CALCULATION
GIVES $T_2 = 190^\circ\text{F}$

BACK FACE OF PANEL

AT TOP; $T_2 = 221^\circ\text{F}$ ($T_{\text{TUBE}} = 1050^\circ\text{F}$)

AT BOTTOM; $T_2 = 190^\circ\text{F}$ ($T_{\text{TUBE}} = 610^\circ\text{F}$)


(EXCLUSIVE OF HAT BANDS)

FOR $T_{\text{AMB}} = 150^\circ\text{F}$

CALC SHEET F-4

DETERMINE HAT BAND TEMPERATURE

$T_3 = 150^\circ\text{F}$



$$Q_1 = Q_2 + Q_3$$

IN COND OUT CONV OUT RAD

$$Q_1 = kA \frac{\Delta T}{\Delta X} = 11 \frac{\text{BTU}}{\text{hr ft}^\circ\text{F}} \left(\begin{array}{c} \text{STRIP} \\ .02625 \text{ in}^2 \\ \text{OR} \\ .0170 \text{ in}^2 \\ \text{PIN} \end{array} \right) \frac{1 \text{ ft}^2}{144 \text{ in}^2} \frac{(T_1 - T_2)}{\frac{4}{12} \text{ ft}}$$

$$Q_1 = \begin{cases} .0060 (T_1 - T_2) & \text{STRIP} \\ .0039 (T_1 - T_2) & \text{PIN} \end{cases}$$

$$Q_2 = Ah\Delta T = \frac{4}{144} \text{ ft}^2 (.2) (T_2 - 150)^{4/3}$$

$$Q_2 = .0056 (T_2 - 150)^{4/3}$$

$$Q_3 = A\epsilon\sigma 4(\bar{T}_R)^3 \Delta T = \frac{4}{144} \text{ ft}^2 (.75)(1.713)(4) \left(\frac{\bar{T}_R}{1000} \right)^3 \Delta T: Q_3 = .143 \left(\frac{\bar{T}_R}{1000} \right)^3 (T_2 - 150)$$

$\epsilon = .75$

SOLVE BY TRIAL & ERROR PREVIOUS PAGE:

STRIP TANGS:

$$A = .02625 \text{ in}^2$$

PIN TANGS

$$A = .0170 \text{ in}^2$$

FOR $T_1 = 1050^\circ\text{F}$ $T_2 = 230^\circ\text{F}$

FOR $T_1 = 1050^\circ\text{F}$ $T_2 = 206^\circ\text{F}$

FOR $T_1 = 610^\circ\text{F}$ $T_2 = 195^\circ\text{F}$

FOR $T_1 = 610^\circ\text{F}$ $T_2 = 182^\circ\text{F}$

HAT BAND TEMPERATURES:

AT TOP OF PANEL $T \approx 230^\circ\text{F}$ ($T_{\text{TUBE}} = 1050^\circ\text{F}$)

AT BOTTOM OF PANEL $T \approx 195^\circ\text{F}$ ($T_{\text{TUBE}} = 610^\circ\text{F}$)

$T_{\text{AMBIENT}} = 150^\circ\text{F}$



G. PANEL WITH NONUNIFORM SODIUM DISCHARGE TEMPERATURE

In the preceding sections of this report, calculations have been made for three tubes of the subpanel (full thermal load tube, inboard tube of Panel 1, and outboard tube of Panel 1) for the idealized nominal solar heat flux distribution. Sodium flow has been assumed to be appropriately distributed among the tubes to result in a uniform discharge temperature ($T_{out} = 1050^{\circ}\text{F}$).


However, the Receiver Specification (Reference 2b, Section 3.3.2.2) indicates a maximum allowable "tube-to-tube outlet temperature variation" not to exceed 2°F . This means a possible 200°F variation of tube outlet temperature across a subpanel.

Tables G-Ia, and b show a method of estimating the tube temperature distribution factors for the three tubes for the indicated outlet temperature maldistribution as a modification of the calculated temperatures for the nominal cases.

In Tables G-Ia and b, the o subscripted terms indicate the nominal idealized conditions; the primed terms indicate the maldistribution case conditions.

TABLE G-Ia
NON-UNIFORM DISCHARGE
TEMPERATURE

$(T_{OUT})'_{MAL\ DIST} = 900F \quad 1100F \quad 900F \quad 1100F$
 $(T_{OUT})_0_{NOMINAL} = 1050F \quad 1050F \quad 1050F \quad 1050F$




| | | | | |
|--|---------------------------|-----------------------------|---------------------------|-----------------------------|
| $(T_{IN})_0 =$ | 610F | 610F | 610F | 610F |
| $(T_{IN})' =$ | 610F | 610F | 610F | 610F |
| $(\Delta T)_{OUT-IN}_0 =$ | 440F | 440F | 440F | 440F |
| $(\Delta T)_{OUT-IN}' =$ | 290F | 490F | 290F | 490F |
| $\mathcal{F} = \frac{\Delta T'}{\Delta T_0}$ | $\frac{290}{440} = .6591$ | $\frac{490}{440} = 1.11364$ | $\frac{290}{440} = .6591$ | $\frac{490}{440} = 1.11364$ |
| (APPLY TO PLOT:) | PANEL 1 "OUTBOARD" | PANEL 1 "INBOARD" | FULL THERMAL LOAD | FULL THERMAL LOAD |
| $(Q/A)_{NoM}_0$ | 0.225 | 0.97 | 1.20 | 1.20 |
| $(Q/A)' = \mathcal{F} (Q/A)_0$ | 0.1483 | 1.0802 | 0.7909 | 1.3364 |

MODIFICATION FORMULA

$$T_i'(z) = [T_{i0}(z) - 610^\circ] * (\mathcal{F}) + 610^\circ$$

TABLE G-1b
NON-UNIFORM DISCHARGE
TEMPERATURE

| | | | | |
|--------------------------|---------|-------|-------|-------|
| $(T_{OUT})'_{MAL\ DIST}$ | = 1100F | 900F | 1100F | 900F |
| $(T_{OUT})_0_{NOMINAL}$ | = 1050F | 1050F | 1050F | 1050F |



| | | | | |
|---|-----------------------------|----------------------------|-----------------------------|----------------------------|
| $(T_{IN})_0$ | = 610F | 610F | 610F | 610F |
| $(T_{IN})'$ | = 610F | 610F | 610F | 610F |
| $(\Delta T)_{OUT-IN}_0$ | = 440F | 440F | 440F | 440F |
| $(\Delta T)_{OUT-IN}'$ | = 490F | 290F | 490F | 290F |
| $\mathcal{F} = \frac{\Delta T'}{\Delta T_0}$ | $\frac{490}{440} = 1.11364$ | $\frac{290}{440} = 0.6591$ | $\frac{490}{440} = 1.11364$ | $\frac{290}{440} = 0.6591$ |
| (APPLY TO PLOT:) | PANEL 1 "OUTBOARD" | PANEL 1 "INBOARD" | FULL THERMAL LOAD | FULL THERMAL LOAD |
| $(Q/A)_{NOM}_0$ | 0.225 | 0.97 | 1.20 | 1.20 |
| $(\frac{Q}{A})' = \mathcal{F}(\frac{Q}{A})_0$ | 0.2506 | 0.6393 | 1.3364 | 0.7909 |

MODIFICATION FORMULA

$$T'_i(z) = [T_{i0}(z) - 610^\circ] * (\mathcal{F}) + 610^\circ$$



III. REFERENCES

1. E. M. Mouradian, "Proposed Thermal Analysis for Receiver of 30 MW Solar Power Plant," I. to G. H. Skopp, IL: 640-82-53, Energy Systems Group, Rockwell International, October 19, 1982
2. Design Specifications: Solar Central Power Plant, Unit 1, Energy Systems Group, Rockwell International:
 - 2a. Overall Specification N10046, Rev. D-1, January 6, 1983
 - 2b. Receiver Subsystem Specification N10048, October 22, 1983
3. E. M. Mouradian, "Solar Receiver Panel: Tube Wall Temperature Distribution," 004TI000002, Energy Systems Group, Rockwell International, April 1980
4. Solar Receiver Panel; Drawings: Energy System Group, Rockwell International, December 1982 and January 1983


Drawing Numbers: 079R000001 (2 sheets)
079R000002
079R000003
079R000005
079R000021
079R000025
5. Sodium Properties:
 - 5a. G. H. Golden and J. V. Tokar, "Thermophysical Properties of Sodium," ANL-7323, Argonne National Laboratory, August 1967
 - 5b. Nuclear Systems Materials Handbook - Design Data, Volume 1, Book 5, TID-26666, Hanford Engineering Development Laboratory
6. Orifice Pressure Loss Characteristics:
 - 6a. E. M. Mouradian, Personal Notes
 - 6b. H. Rouse, Elementary Mechanics of Fluids, John Wiley, Inc., 1962, Pages 56-60
 - 6c. R. H. Perry and C. H. Chilton, Chemical Engineers' Handbook, 5th Edition, McGraw-Hill, 1973, Pages 5.10, 5.11, 5.34
 - 6d. Fluid Meters - Their Theory and Application, 5th Edition, American Society of Mechanical Engineers



7. A. V. von Arx, "Thermal Analyzer Program (TAP-4S) Description and User's Manual," N036CPM620006, Energy Systems Group, Rockwell International, January 1979
8. Sodium Heat Transfer Coefficient
 - 8a. J. G. Knudsen and D. L. Katz, Fluid Dynamics and Heat Transfer, McGraw-Hill, 1958, Page 463
 - 8b. O. E. Dwyer, "Manuscript for Chapter 5 of the 1970 Edition of the Sodium and NaK Supplement to the Liquid Metals Handbook," BNL-11936, Brookhaven National Laboratory, January 1969, Page 4
9. Pipe Flow Friction:
 - 9a. L. F. Moody, "Friction Factors for Pipe Flow," Transactions of the American Society of Mechanical Engineers, Volume 66, November 1944, Pages 671-678
 - 9b. Flow of Fluids, Crane Technical Paper No. 410, Crane Co. 1965, Pages A.23 and A.24
10. Insulative Conductivities:
 - 10a. Cerafelt - Refractory Fiber Insulation, Johns-Manville Bulletin
 - 10b. Stainless Steel (316) - ASME Boiler and Pressure Vessel Code, 1980 Section III, Division 1, Appendix I, Page 88
11. W. R. Castle, "Preliminary Design Structural Analysis - Carrizo Plains Solar Receiver Subsystem," 079TI000001, Rockwell International, Energy Systems Group, March 1983



APPENDICES

| | | |
|-------------------------|--|------------------------|
| PREPARED BY: <i>EMM</i> |  Rockwell International Energy Systems Group | PAGE NO. 60 OF |
| CHECKED BY: | | REPORT NO. 079TI000002 |
| DATE: <i>1/83</i> | | MODEL NO. |

Appendix App - A

DETERMINE ΔT_1 and ΔT_2

For this analysis, ΔT_1 and ΔT_2 are used in a different (though conceptually similar) manner than in the ASME B&PV Code.

The ASME definitions are based on a slab of a given thickness, assuming it acts as the wall of a thin-walled tube with only radial temperature variation (no circumferential variation).


For the analysis of this report, ΔT_1 and ΔT_2 are defined on the basis of a tube acting as a beam.

In both cases:

ΔT_1 = Moment Generating Equivalent Linear Temperature Difference,
 ΔT_2 = Peaking (non-linear portion) component.

The difference between the two methods of defining ΔT_1 and ΔT_2 is somewhat analogous to the difference between polar moment of inertia $J = \int r^2 dA$, and regular moment of inertia $I = \int x^2 dA$.

The derivation of ΔT_1 and ΔT_2 as used in this analysis is shown on the following two pages. These expressions have been incorporated into the TAP program for determination of tube wall temperature distribution. The TAP program listing is included in the Appendix. Also see Reference 3, 004TI000002.



DETERMINE INTERNAL MOMENT GENERATED BY T(x).

$$dF = \sigma dA$$

$$\sigma = E\alpha (T(x) - \bar{T})$$


$$dF = E\alpha T(x) dA - (E\alpha \bar{T} dA)$$

$$dM = dF * X = E\alpha T(x) x dA - E\alpha \bar{T} x dA$$

$$M = \int_A E\alpha T(x) x dA - \int_A E\alpha \bar{T} x dA$$

$$M = \int_A E\alpha T(x) x dA \cong E\alpha \sum T_i x_i A_i \quad \text{MOMENT DUE TO } T(x) \quad \text{(A-1)}$$

DETERMINE MOMENT GENERATED BY LINEAR PROFILE OF MAGNITUDE ΔT_1 .



$$T(x) = \frac{\Delta T_1}{2} \left(\frac{x}{R_0} \right)$$

$$M = \int_A E\alpha \frac{\Delta T_1}{2} \frac{x}{R_0} x dA$$

$$M = \frac{E\alpha \Delta T_1}{2 R_0} \int_A x^2 dA \cong \frac{E\alpha \Delta T_1}{2 R_0} \sum x_i^2 A_i \quad \text{MOMENT DUE TO LINEAR PROFILE} \quad \text{(A-2)}$$

NOTE: $I_{(BEAM)} = \int_A x^2 dA \cong \sum x_i^2 A_i$

PREPARED BY: *Emm*
 CHECKED BY:
 DATE: *1/83*



PAGE NO. 62 OF
 REPORT NO. 079TI000002
 MODEL NO.

WHAT IS ΔT_1 ?

Equate (A-1) & (A-2):

$$E\alpha \int_A T(x) x dA = \frac{E\alpha \Delta T_1}{2R_0} \int x^2 dA$$

$$\Delta T_1 = \frac{2R_0 \int_A T(x) x dA}{\int_A x^2 dA} \cong \frac{2R_0 \sum T_i X_i A_i}{\sum X_i^2 A_i}$$

$$\Delta T_1 = \frac{2R_0 \sum T_i X_i A_i}{\sum X_i^2 A_i}$$

$$\Delta T_2 = (T_{SURF} - \bar{T}) - \frac{1}{2} \Delta T_1$$


(A-3)

$$S_{1\text{ MAX}} = E\alpha \frac{\Delta T_1}{2}$$

$$S_{2\text{ MAX}} = E\alpha \Delta T_2$$

$$S_{TOT\text{ MAX}} = (S_{1\text{ MAX}} + S_{2\text{ MAX}}) = E\alpha (T_{MAX} - \bar{T})$$

(A-4)



Two-dimensional (r,φ) steady-state thermal analysis
 of a single tube. (See Section II-D.)

00001

*** STAR 001 - TITLES & STORED COMMENTS

E M MOURADIAN EXT 3320 LB-30
 678901234567890

TAP-45 SUPER TAP
 6903-(AB) (500K)

MODEL 2 (TUNE TUBE, 360 DEG.)

ONE TUBE MODEL

QUANTITIES:

- A0101-A0636 = ANGULAR COORDINATE (DEGREES)
- B0101-B0636 = NUDE CROSS-SECTIONAL AREA (IN²)
- B0999 = TOTAL METAL AREA, ONE TUBE (IN²)
- C0101-C0636 = CAPACITANCE OF NODES, BTU/F
- D0101-D0890 = Y/K = A/ΔX (INCHI) FOR CONDUCTION PATHS
- D0101-D0636 = CIRCUMFERENTIAL
- D0711-D0890 = RADIAL
- E0101-E0136 = 1/A FLUX FACTOR (E.G., E(1)=SIN(ANGLE).)
- F0101-F0636 = (1/X)*A FOR EACH NODE
- G0101-G0636 = (AREA)/(X**2) FOR EACH NODE IN4
- H0001 = MIN(A) BTU/HR FT² F
- I0001 = SUM(A**X**2) = MOMENT OF INERTIA, ONE TUBE IN4
- I0005 = T-BAR, TUBE
- I0006 = DEL T ACROSS FRONT PART OF TUBE WALL
- I0007 = DEL T ACROSS TUBE DIAMETER
- I0010 = ALPHA (ABSORPTIVITY)
- I0011 = EMISSIVITY
- I0004 = DEL T(1) = 2*RO*SUM(TO*X**4)/SUM(X**4) (F)
- I0021 = T(PEAK) - T(BAR) F
- I0022 = (1/2)*DEL T(1) F
- I0023 = DEL T(2) = I21-I22 = (T(1)*R-T(BAR))-(L.5 DT(1))
- I0031 = MODEL NUMBER (2)

- J0101 = STRESS 1 = (1/2)*EA*DT(1) PSI
- J0102 = STRESS 2 = EA*DT(2) PSI
- J0103 = TOT STRS = (1/2)*EA*DT(1) + EA*DT(2) PSI
- J0104 = TOT STRS = (T(PEAK)-T(BAR))*EA PSI
- J0005 = SMALL NUMBER = 1.0 E-10
- J0010 = Q/A1 EXTERNAL HEAT FLUX, MW/M²
- J0011 = Q/A1 EXTERNAL HEAT FLUX, BTU/SEC IN2
- J0012 = Q/A1 NET = Q/A1ALPHA BTU/SEC IN2
- J0020 = E/A (ELAS MOD * THERM EXPAN COEFF) 266.0 PSI/F
- J0021 = E/A/HU = 371.43
- J0031 = KISS304 BTU/HR FT F
- J0032 = KISS304 BTU/SEC IN F
- J0041 = RHO*CP BTU/FT³ F
- J0042 = HHO*CP BTU/IN³ F
- P0101-P0636 = T(LOCAL)-T(BAR) = T(OABC) - (E0005)
- Q0101-Q0136 = HEAT INPUT (SOLAR) ON SURFACE BTU/SEC
- R0001 = R(OUTER) INCH
- R0002 = DEL R = WALL THICKNESS, INCH
- R0101-R0636 = RADIAL COORDINATE FOR EACH NODE (INCHI)
- S0101-S0136 = EXTERNAL SURFACE AREA (IN²) FOR Q/A & RAD.
- S0601-S0636 = INTERNAL SURFACE AREA (IN²) FOR NA CONV.
- T0000 = DUMMY FOR USE IN CARD PUNCHING
- T0101-T0636 = STEEL NODE TEMPERATURES
- T0901 = SODIUM TEMP
- T0902 = SINK TEMP
- U0001 = TOTAL HEAT TO NA BTU/SEC
- U0002 = TOTAL HEAT RADIATED TO SINK BTU/SEC
- U0003 = TOTAL HEAT OUT (U1+U2) BTU/SEC
- U0004 = TOTAL HEAT IN (U0101 TO Q0136) BTU/SEC
- U0005 = HEAT OUT/HEAT IN = 1.07 BTU/SEC
- U0901-U0936 = HEAT FLOW TO NA (BTU/SEC)
- U0951-U0986 = HEAT FLOW TO SINK (BTU/SEC)
- V0101-V0636 = MODAL VOLUMES (L=1.0) (IN3)
- W0101-W0636 = T(1)-T(BAR) = (1/2)*DT(1)*X(1)/R0
- X0101-X0636 = X COORDINATE. X = M-S N=0, S=
- Z0101-Z0636 = Z COORDINATE. Z = E-W

NODES:

- T0101-T0636 = STEEL NODES-
- T0101-T0136 = RING 1 OUTER
- T0201-T0236 = RING 2
- T0301-T0336 = RING 3
- T0401-T0436 = RING 4
- T0901-T0936 = RING 5

00010000

00010020

00209511

00300000

T0601-T0636 = RING 6 INNER
 T0901 = SODIUM
 T0902 = SINK

CAPACITANCES: BTU/F
 MODAL VOLUMES: VOL = (2PI/36*PI(1))*(LOR.2*DEL R)*PI(LT) (IN3)
 C = (RHO*CP)*VOL(UIME)

CONDUCTANCES:
 CONDUCTANCES: BTU/SEC F
 Y0101-Y0636 = CIRCUMFERENTIAL CONDUCTION
 Y/K = (L/2PI*(LOR.2)*DEL R)/(2PI/36*PI(1)) INCH
 Y0101-Y0236 = RING 1 (OUTER)
 Y0301-Y0336 = RING 2
 Y0401-Y0436 = RING 3
 Y0501-Y0536 = RING 4
 Y0601-Y0636 = RING 5 (INNER)
 Y0711-Y0890 = RADIAL CONDUCTION
 Y/K = (L/2PI/36*PI(1)*DEL R) INCH
 Y0711-Y0715 = Δ ANGLE = +90 DEG
 Y0716-Y0720 = Δ ANGLE = +80 DEG
 Y0886-Y0890 = Δ ANGLE = +100 DEG
 Y0901-Y0936 = SODIUM CONVECTION (Y=HA)
 Y0951-Y0986 = RADIATION TO SINK

TABLES:
 1: K STEEL BTU/SEC IN F VS TEMP
 2: RHO*CP STEEL BTU/IN³ F RHO(T) LOOP * CP(T) ACTUAL

MATERIAL PROPERTIES:
 FOR CONSTANT STEEL PROPERTIES:
 THERMAL CONDUCTIVITY:
 T-BAR (F) K(B/HR FT F) K(B/SEC IN F)
 SS-316 ASME B6PVC 1980
 0.0 7.4 0.0001713
 70.0 7.7 0.0001782
 100.0 7.9 0.0001829
 200.0 8.45 0.0001956
 300.0 9.0 0.0002083
 400.0 9.5 0.0002199
 500.0 10.0 0.0002315
 600.0 10.5 0.0002431
 700.0 11.0 0.0002546
 800.0 11.5 0.0002662
 900.0 12.0 0.0002778
 1000.0 12.45 0.0002882
 1100.0 12.9 0.0002986
 1200.0 13.35 0.0003090
 1300.0 13.8 0.0003194
 1400.0 14.2 0.0003287
 1500.0 14.6 0.0003380

RHO CP (RHO T=1000) * CP T=LOCAL
 J0041=BTU/FT³ F J0042=BTU/IN³ F

UNITS:
 LENGTHS, RADII = INCH
 UNIT LENGTH, (AXIAL) = 1.0 INCH
 AREA = IN²
 I = MOMENT OF INERTIAL IN4
 TIME = SECONDS
 TEMP & DEL T = DEG F
 HI INPUT VALUE) = BTU/HR FT² F
 1.0 BTU/HR FT² F = 1.929 E-06 BTU/SEC IN² F
 K = THERMAL CONDUCTIVITY (STEEL) = BTU/SEC IN F
 RHO CP (STEEL) = BTU/IN³ F
 Y = CONDUCTANCE = BTU/SEC F
 C = CAPACITANCE = BTU/F
 HEAT FLOW = BTU/SEC
 Q/A = SOLAR HEAT FLUX = MW/M² & BTU/SEC IN2
 1.0 MW/M² = 0.61160451 BTU/SEC IN2
 STEPHAN-BOLTZMANN = 3.3044 E-15 BTU/IN² SEC R4
 EA = ELASTIC MOD * THERM EXPAN COEFF PSI/F
 STRESS = PSI

BOUNDARY CONDITIONS:
 HEAT FLUX DISTRIBUTION = COSINE
 ALPHA = 1.0
 EMISS = 0.9
 T(SINK) = 60F
 T(NA) = 900F
 EQ/A30 = 1.20 MW/M² (J0010)
 EA = (ELAS MOD)*THERM EXPAN COEFF) = 266.0 PSI/F

SPECIAL OPERATIONS:
 CRT PLOTS:
 ISOTHERM PLOT FOR TUBE CROSS-SECTION

3

4

00300160
 00300901
 00300902
 00339999
 00340000
 00340100
 00340110
 00340501
 00349999
 00350000
 00350001
 00351004
 00351005
 00351310
 00351020
 00351030
 00351240
 00351050
 00351060
 00352001
 00352003
 00352010
 00352220
 00352360
 00353010
 00354010
 00379999
 00580000
 00580100
 00580200
 00600000
 00600001
 00600305
 00601001
 00601010
 00601020
 00602001
 00602007
 00602010
 00602020
 00602030
 00602040
 00602050
 00602060
 00602070
 00602280
 00602090
 00602100
 00602110
 00602120
 00602130
 00602140
 00602150
 00603001
 00603002
 00799998
 00800000
 00800110
 00800120
 00800130
 00800200
 00800300
 00800400
 00800500
 00800505
 00800620
 00800640
 00800720
 00800740
 00800800
 00800900
 00800904
 00801400
 00801410
 00801620
 00849999
 00850000
 00850100
 00850210
 00850220
 00850310
 00850320
 00850340
 00850300
 00859999
 00860000
 00861000
 00861100

PROBLEM CASE:
STEADY STATE.

DEL R = 49 MILS Q.D. = 0.75 INCH TANA=830F COSTNE LOADING
Q/A = 1.20 MW/M2 HANA=7400 SS1316 MODEL 2

00990000
00990001
00990100
00990310
00990020
00999999
01000000

(5)

*** STAR 010 - STATIC NETWORK DESCRIPTION

Table with columns for node IDs (Y 101, Y 201, etc.), values (0, .0, 1, etc.), and node coordinates (T 101 T 102, etc.). Includes a circled '6' at the bottom right.

*** STAR 020 - INITIALIZATION & CONSTANT DATA

Table with columns for node IDs (I 31, J 1, etc.), values (0, 2.0000E-10, etc.), and initialization/constant data (MODEL #2, SMALL NUMBER, etc.).

*** STAR 030 - FUNCTION STATEMENTS

Table with columns for node IDs (1 J 42, 2 J 11, etc.), values (0, .0, 1.0000, etc.), and function statements (RHOCP1 BTU/INS, Q/A BTU/SEC IN2, etc.).

(7)

(8)

| | | | |
|------------------------|---------|-------------------|----------------------|
| 86 E 101 E 136 120 .0 | 1.0000 | A 101 0 1 0 1 | 03350010 |
| 87 Q 101 J 110 152 .0 | 1.0000 | J 12 S 101 0 1 1 | 03350110 |
| 88 Q 101 Q 110 152 .0 | 1.0000 | Q 101 E 101 1 1 1 | 03350120 |
| 89 Q 120 J 136 152 .0 | 1.0000 | J 12 S 120 0 1 1 | 03350210 |
| 90 U 120 Q 136 152 .0 | 1.0000 | Q 120 E 120 1 1 1 | 03350220 |
| 91 U 901 U 936 40 .0 | 1.0000 | Y 901 0 1 0 1 | 03600010 |
| 92 U 951 U 986 40 .0 | 1.0000 | Y 951 0 1 0 1 | 03600320 |
| 93 U 1 0 61 .0 | 1.0000 | U 901 U 936 1 0 1 | HT TO WA |
| 94 U 2 0 61 .0 | 1.0000 | U 951 U 986 1 0 1 | HT TO AMBIENT |
| 95 U 3 0 60 .0 | 1.0000 | U 1 U 2 0 0 1 | HT OUT |
| 96 U 4 0 51 .0 | 1.0000 | Q 101 Q 136 1 0 1 | HT IN |
| 97 U 4 0 50 .0 | 1.0000 | U 4 J 5 0 0 1 | U4+EPS 2 |
| 98 U 5 0 53 .0 | 1.0000 | U 3 U 4 0 0 1 | HT OUT/HT IN |
| 99 I 5 0 59 .0 | 1.0000 | T 101 T 636 0 0 1 | T:BAR |
| 100 I 6 0 51 .0 | 1.0000 | T 101 T 601 0 0 1 | DT:FRONT WALL |
| 101 I 7 0 51 .0 | 1.0000 | T 101 T 119 0 0 1 | DT:TUBE |
| 102 G 101 G 636 103 .0 | 1.0000 | X 101 0 1 0 1 | X**2 |
| 103 G 101 G 636 152 .0 | 1.0000 | G 101 G 101 1 1 1 | [**2]**A |
| 104 I 1 0 161 .0 | 1.0000 | G 101 G 636 0 0 1 | [SUMIAX**X] |
| 105 F 101 F 636 52 .0 | 1.0000 | T 101 X 101 1 1 1 | T**X |
| 106 F 101 F 636 52 .0 | 1.0000 | F 101 B 101 1 1 1 | T**XA |
| 107 I 2 0 61 .0 | 1.0000 | F 101 F 636 1 0 1 | SUMIT**X**Y |
| 108 I 3 0 52 .0 | 2.0000 | I 2 R 1 0 0 0 | 2**RO**SUMI(T**X**A) |
| 109 I 4 0 53 .0 | 1.0000 | I 3 I 1 0 0 0 | DEL T(1) |
| 110 I 21 0 51 .0 | 1.0000 | T 101 I 5 0 0 0 | T:PEAK - T:BAR |
| 111 I 21 0 7 .0 | 1.0000 | I 21 0 0 0 0 | 1 |
| 112 J 22 0 7 .0 | -5.0000 | I 4 0 0 0 0 | [(1/2)DEL T(1)] |
| 113 I 22 0 7 .0 | 1.0000 | I 22 0 0 0 0 | 1 |
| 114 I 23 0 51 .0 | 1.0000 | I 21 I 22 0 0 1 | DEL T(2) |
| 115 M 101 M 136 152 .0 | -5.0000 | I 4 X 101 0 1 1 | -.5*DT1**X(1) |
| 116 M 201 M 236 152 .0 | -5.0000 | I 4 X 201 0 1 1 | 2 |
| 117 M 301 M 336 152 .0 | -5.0000 | I 4 X 301 0 1 1 | 2 |
| 118 M 401 M 436 152 .0 | -5.0000 | I 4 X 401 0 1 1 | 2 |
| 119 M 501 M 536 152 .0 | -5.0000 | I 4 X 501 0 1 1 | 2 |
| 120 M 601 M 636 152 .0 | -5.0000 | I 4 X 601 0 1 1 | 2 |
| 121 M 101 M 136 153 .0 | 1.0000 | M 101 R 1 1 0 1 | -5.0001**X/R |
| 122 M 201 M 236 153 .0 | 1.0000 | M 201 R 1 1 0 1 | 2 |
| 123 M 301 M 336 153 .0 | 1.0000 | M 301 R 1 1 0 1 | 2 |
| 124 M 401 M 436 153 .0 | 1.0000 | M 401 R 1 1 0 1 | 2 |
| 125 M 501 M 536 153 .0 | 1.0000 | M 501 R 1 1 0 1 | 2 |
| 126 M 601 M 636 153 .0 | 1.0000 | M 601 R 1 1 0 1 | 2 |
| 127 M 101 M 136 150 .0 | 1.0000 | M 101 T 101 1 1 1 | 2 |
| 128 M 201 M 236 150 .0 | 1.0000 | M 201 T 201 1 1 1 | 2 |
| 129 M 301 M 336 150 .0 | 1.0000 | M 301 T 301 1 1 1 | 2 |
| 130 M 401 M 436 150 .0 | 1.0000 | M 401 T 401 1 1 1 | 2 |
| 131 M 501 M 536 150 .0 | 1.0000 | M 501 T 501 1 1 1 | 2 |
| 132 M 601 M 636 150 .0 | 1.0000 | M 601 T 601 1 1 1 | 2 |
| 133 M 101 M 136 151 .0 | 1.0000 | M 101 T 5 1 0 1 | 2 |
| 134 M 201 M 236 151 .0 | 1.0000 | M 201 T 5 1 0 1 | 2 |
| 135 M 301 M 336 151 .0 | 1.0000 | M 301 T 5 1 0 1 | 2 |
| 136 M 401 M 436 151 .0 | 1.0000 | M 401 T 5 1 0 1 | 2 |
| 137 M 501 M 536 151 .0 | 1.0000 | M 501 T 5 1 0 1 | 2 |
| 138 M 601 M 636 151 .0 | 1.0000 | M 601 T 5 1 0 1 | 2 |
| 139 T 101 0 152 .0 | -5.0000 | J 20 T 4 0 0 0 | 1.5**DT1**PSI |
| 140 I 102 0 152 .0 | 1.0000 | J 20 T 23 0 0 0 | 1.5**DT2**PSI |
| 141 I 103 0 150 .0 | 1.0000 | I 101 I 102 0 0 1 | 1.5**DT3**PSI |
| 142 I 104 0 152 .0 | 1.0000 | J 20 T 21 0 0 0 | 1.5**DT4**PSI |
| 143 P 101 P 136 151 .0 | 1.0000 | T 101 I 5 1 0 1 | T(1)-T:BAR |
| 144 P 201 P 236 151 .0 | 1.0000 | T 201 I 5 1 0 1 | 1 |
| 145 P 301 P 336 151 .0 | 1.0000 | T 301 I 5 1 0 1 | 1 |
| 146 P 401 P 436 151 .0 | 1.0000 | T 401 I 5 1 0 1 | 1 |
| 147 P 501 P 536 151 .0 | 1.0000 | T 501 I 5 1 0 1 | 1 |
| 148 P 601 P 636 151 .0 | 1.0000 | T 601 I 5 1 0 1 | 1 |
| 149 Y 101 Y 890 89 .0 | 1.0000 | X 101 Z 101 0 0 1 | 1 |

*** STAR 040 - TABULAR DATA

| | | | | |
|--------------|------------|---------|-----------------|----------|
| 1 0 0 .0 | 1.7130E-04 | 0 0 0 0 | 1 TABLE 1 | 04100000 |
| 0 0 0 70.000 | 1.7820E-04 | 0 0 0 0 | 1 KISS316 | 04100070 |
| 0 0 0 100.00 | 1.8290E-04 | 0 0 0 0 | 1 DTU/SEC IN P | 04100100 |
| 0 0 0 300.00 | 2.0833E-04 | 0 0 0 0 | 1 | 04100300 |
| 0 0 0 900.00 | 2.7778E-04 | 0 0 0 0 | 1 | 04100900 |
| 0 0 0 1300.0 | 3.1944E-04 | 0 0 0 0 | 1 | 04101300 |
| 0 0 0 1500.0 | 3.3795E-04 | 0 0 0 0 | 1 | 04101500 |
| 0 0 0 1800.0 | 3.3800E-04 | 0 0 0 0 | 1 1 1 1 1 1 1 1 | 04110000 |
| 0005 | | | | 04000000 |

*** STAR 045 - CONTOUR PLOT CRT DATA

| | |
|--------------------------------------|----------|
| CURVE NO. 1 PLOTS THE 725.0 ISOTHERM | 06500010 |
| CURVE NO. 2 PLOTS THE 750.0 ISOTHERM | 06500020 |
| CURVE NO. 3 PLOTS THE 775.0 ISOTHERM | 06500030 |
| CURVE NO. 4 PLOTS THE 800.0 ISOTHERM | 06500040 |
| CURVE NO. 5 PLOTS THE 825.0 ISOTHERM | 06500050 |
| CURVE NO. 6 PLOTS THE 850.0 ISOTHERM | 06500060 |

| | |
|--|----------|
| CURVE NO. 7 PLOTS THE 875.0 ISOTHERM | 06500070 |
| CURVE NO. 8 PLOTS THE 900.0 ISOTHERM | 06500080 |
| CURVE NO. 9 PLOTS THE 925.0 ISOTHERM | 06500090 |
| PLOT 1, Y AXIS LABEL IS MURPHY-SOUTH WITH LIMITS OF -0.40 0.50 | 06500100 |
| CURVE NO. 10 PLOTS THE 950.0 ISOTHERM | 06500100 |
| CURVE NO. 11 PLOTS THE 975.0 ISOTHERM | 06500110 |
| CURVE NO. 12 PLOTS THE 1000.0 ISOTHERM | 06500120 |
| CURVE NO. 13 PLOTS THE 1025.0 ISOTHERM | 06500130 |
| CURVE NO. 14 PLOTS THE 1050.0 ISOTHERM | 06500140 |
| CURVE NO. 15 PLOTS THE 1075.0 ISOTHERM | 06500150 |
| CURVE NO. 16 PLOTS THE 1100.0 ISOTHERM | 06500160 |
| CURVE NO. 17 PLOTS THE 1125.0 ISOTHERM | 06500170 |
| CURVE NO. 18 PLOTS THE 1150.0 ISOTHERM | 06500180 |
| CURVE NO. 19 PLOTS THE 1175.0 ISOTHERM | 06500190 |
| PLOT 1, X AXIS LABEL IS WEST-EAST WITH LIMITS OF -0.40 0.50 | 06500200 |
| CURVE NO. 20 PLOTS THE 1200.0 ISOTHERM | 06500200 |

*** STAR 070 - SPECIAL CONTROL CONSTANTS

| | | | |
|------|------------|---|----------|
| 4 | 2.5000E-04 | CONVERGENCE TEST ON RATE OF TEMPERATURE CHANGE | 07000040 |
| 5 | 1.0000 | 0. - TRANSIENTS 11. - STEADY STATE | 07000050 |
| 6 | 1.0000 | +1= DUMP Y,T,G,C,Q, E DUMMIES AT END OF CASE | 07000060 |
| 9 | 3.3044E-19 | STEFAN-BOLTZMANN CONSTANT | 07000090 |
| 13 | 5.0000 | TIME STEP ON ITERS BETWEEN CALLING ARITH | 07000130 |
| 14 | 1.0000 | +1.0 PREVENTS KICKOFF ON EXCEEDING TABLE LIMITS | 07000140 |
| 15 | 1.0000 | +1.0 FOR 100 SERIES EVAL. AT END OF RUNS | 07000150 |
| 19 | 1.0000 | +1.0 - TAPOUT ENTRIES ON SEPARATE TITLED PAGE | 07000190 |
| 0000 | | | 08000000 |

*** STAR 080 - PRINTOUT SPECIFICATIONS

| | | | | |
|--------------|----|---------|------------|----------|
| I 4 0 1 .0 | .0 | 0 0 0 0 | 1 DT:11 | 08101010 |
| I 23 0 1 .0 | .0 | 0 0 0 0 | 1 DT:2) | 08101020 |
| I 21 0 1 .0 | .0 | 0 0 0 0 | 1 T:PK-BAR | 08101030 |
| T 101 0 1 .0 | .0 | 0 0 0 0 | 1 T:PEAK | 08101040 |
| I 5 0 1 .0 | .0 | 0 0 0 0 | 1 T:BAR | 08101050 |
| I 6 0 1 .0 | .0 | 0 0 0 0 | 1 DT:FT ML | 08102010 |
| I 7 0 1 .0 | .0 | 0 0 0 0 | 1 DT:TUBE | 08102020 |
| I 901 0 1 .0 | .0 | 0 0 0 0 | 1 T:WA | 08102030 |
| T 902 0 1 .0 | .0 | 0 0 0 0 | 1 T:SIANK | 08102040 |
| I 31 0 1 .0 | .0 | 0 0 0 0 | 1 MODEL 2 | 08102051 |
| I 1 0 1 .0 | .0 | 0 0 0 0 | 1 I IN4 | 08103010 |

| | | | | |
|------------------|----|---------|------------|----------|
| R 999 0 1 .0 | .0 | 0 0 0 0 | 1 AREA IN2 | 08103020 |
| R 1 0 1 .0 | .0 | 0 0 0 0 | 1 R:OUTER | 08103030 |
| R 601 0 1 .0 | .0 | 0 0 0 0 | 1 R:INNER | 08103040 |
| R 2 0 1 .0 | .0 | 0 0 0 0 | 1 DEL R | 08103050 |
| J 10 0 1 .0 | .0 | 0 0 0 0 | 1 TQ/AYO | 08104010 |
| I 10 0 1 .0 | .0 | 0 0 0 0 | 1 ALPHA | 08104020 |
| I 11 0 1 .0 | .0 | 0 0 0 0 | 1 ENISS | 08104030 |
| H 1 0 1 .0 | .0 | 0 0 0 0 | 1 H:HA | 08104040 |
| J 31 0 1 .0 | .0 | 0 0 0 0 | 1 K:STL | 08104051 |
| U 1 0 1 .0 | .0 | 0 0 0 0 | 1 HT TO WA | 08150210 |
| U 2 0 1 .0 | .0 | 0 0 0 0 | 1 HT TO SK | 08150220 |
| U 3 0 1 .0 | .0 | 0 0 0 0 | 1 HT OUT | 08150230 |
| U 4 0 1 .0 | .0 | 0 0 0 0 | 1 HT IN | 08150240 |
| U 5 0 1 .0 | .0 | 0 0 0 0 | 1 DT/IN=17 | 08150250 |
| I 101 0 1 .0 | .0 | 0 0 0 0 | 1 STRESS 1 | 08150310 |
| I 102 0 1 .0 | .0 | 0 0 0 0 | 1 STRESS 2 | 08150320 |
| I 103 0 1 .0 | .0 | 0 0 0 0 | 1 STRS TOT | 08150330 |
| I 104 0 1 .0 | .0 | 0 0 0 0 | 1 STRS TOT | 08150340 |
| J 20 0 1 .0 | .0 | 0 0 0 0 | 1 E**A | 08150350 |
| T 1 T 5 1 .0 | .0 | 0 0 0 0 | 1 | 08200005 |
| T 101 T 136 0 .0 | .0 | 0 0 0 0 | 1 | 08200100 |
| I 137 T 145 1 .0 | .0 | 0 0 0 0 | 1 | 08200101 |
| F 201 T 236 0 .0 | .0 | 0 0 0 0 | 1 | 08200200 |
| T 237 T 245 1 .0 | .0 | 0 0 0 0 | 1 | 08200201 |
| T 301 T 336 0 .0 | .0 | 0 0 0 0 | 1 | 08200300 |
| T 337 T 345 1 .0 | .0 | 0 0 0 0 | 1 | 08200301 |
| T 401 T 436 0 .0 | .0 | 0 0 0 0 | 1 | 08200400 |
| T 437 T 445 1 .0 | .0 | 0 0 0 0 | 1 | 08200401 |
| T 501 T 536 0 .0 | .0 | 0 0 0 0 | 1 | 08200500 |
| T 537 T 545 1 .0 | .0 | 0 0 0 0 | 1 | 08200501 |
| T 601 T 636 0 .0 | .0 | 0 0 0 0 | 1 | 08200600 |
| T 637 T 645 1 .0 | .0 | 0 0 0 0 | 1 | 08200601 |
| 0090 | | | | 09000000 |

*** STAR 090 - PRINTOUT & STOP TIMES

| | | | |
|-------------|--------|-----------|----------|
| 0 0 0 .0 | 200.00 | 0 0 0 0 1 | 09000001 |
| 0 0 0 606.0 | .0 | 0 0 0 0 1 | 09000002 |
| 0099 | | | 09099999 |



APPENDIX C

ADDENDUM OF JUNE 1983

Thermal analysis of the central receiver of the Carrisa Plains 30-MWt solar power plant continued after the publication of 079TI000002 in March 1983. The continuing analysis, to date, is summarized in the addendum.

The subjects presented are:

| | <u>Page</u> |
|--|-------------|
| 1) Panel Heat Loss | 67 |
| 2) Panel Temperature Distribution | 86 |
| 3) Tube-Manifold TAP Thermal Model Setup | 199 |

5370F/sjh

ADD-1 PANEL HEAT LOSS

In order to determine the heat loss from the panel, the "effective" mean temperature is calculated for both convection and radiation. These are defined as:

$$\bar{T}_{\text{CONV}} = \frac{\int^A T dA}{\int^A dA} \quad \bar{T}_{\text{RAD}} = \left[\frac{\int^A T^4 dA}{\int^A dA} \right]^{1/4}$$

The integration proceeds in three steps: circumferential around the periphery of the individual tube surface, ϕ , axially along the tube (panel) height, z ; and laterally across the panel width, x .

The heat loss from the panel is then calculated based on these "effective" mean temperatures (as if the panel were isothermal). The reflection heat loss is taken to be 5% of the solar flux energy incident on the panel, ($\alpha = 0.95$). The radiation heat loss is based on an effective emissivity of 0.88. The convection heat loss is based on a combination of natural convection and forced (wind) convection. The receiver is approximated by a 43-ft-diameter cylinder.

The circumferential temperature distributions on panel tubes at panel mid-height are shown on Pages 30 through 36 (of 079TI000002, March 1983) for the "Reference" Solar Flux Distribution of Figure A-2, Page 7 of 079TI000002. The surface temperature varies approximately as the cosine expression shown in Table Add-I-1, and as verified in the table. In Table Add-I-2, the circumferentially averaged mean temperature (for convection) is determined for an individual tube. In Table A-I-3, the circumferentially averaged mean temperature (for radiation) is determined for an individual tube.

The second integration is carried out by assuming that the ΔT (Peak-Na) varies axially according to the normal distribution curve indicated on Pages 6, 8, and 10 (of 079TI000002, March 1983).

Table Add-I-4 lists the computer program used to carry out the first two steps of the integration. Step 1 evaluates the circumferential mean temperatures at tube mid-height based on the equations of Tables Add-I-2 and Add-I-3. Step 2 evaluates the axial mean temperatures based on the normal distribution factors of Page 10, Table A-II, Column d. The calculations are made for 1/8-in.-wide strips of the less-than-peak portion of Subpanel 2.

The computer output is summarized in Table Add-I-5 (circumferential and axially averaged temperatures).

The third step of the integration is the lateral integration. In Table Add-I-6, the lateral averaging across Subpanels 1 and 2 are shown. In Table Add-I-7, the lateral averaging across all eight subpanels is carried out. The final "overall" mean temperatures for the panel are:

Radiation: 1396.40°R (936.71°F)

Convection: 894.19°F

With these values, the heat loss calculations can be carried out. On Table Add-I-8a, the panel area and total incident thermal power is determined. On Table Add-I-8b, the reflection heat loss and radiation heat loss are calculated. On Table Add-I-8c, the natural convection heat loss is determined based on the assumption of still air. In order to account for the effect of wind, the rectangular cross section of the receiver structure is approximated by a cylinder 43 ft in diameter. The forced convection heat transfer correlation employed (Figure Add-I-1) was previously shown in 272TI000004, Page 38, of April 1978. Table Add-I-9 shows the forced convection heat transfer calculation, as well as the combined effect of forced and natural convection.

Table Add-I-10 summarizes the total heat losses from the panel under conditions of the "REFERENCE" solar flux distribution with sodium inlet/outlet temperatures of 610/1050°F.

TABLE Add-I-1

$$\text{VERIFY: } T(\theta)_{\text{SURFACE}} = T_{Na} + (T_{\text{PEAK}} - T_{Na}) \cos \theta$$

See: 079TI000002
Pages: 30-36

| $(Q/A)_{\theta}$ MW/m ² | θ ANGULAR LOCATION | T(θ) SURFACE | $\Delta T = T_{\text{SURF}} - T_{Na}$ (830) | $\frac{(T_s - T_{Na})_{\theta}}{(T_s - T_{Na})_{\theta=0}}$ | $\cos \theta$ | $\frac{(T_s - T_{Na})_{\theta}}{(T_s - T_{Na})_{\theta=0}} \stackrel{?}{=} 1$ $\frac{1}{\cos \theta}$ |
|---------------------------------------|---------------------------------|--------------------------|--|---|---------------|--|
| 1.20 | 0 | 1022.5 | 192.50 | 1.0 | 1.0 | 1.0 |
| | 10 | 1019.7 | 189.7 | 0.98545 | 0.98481 | 1.000657 |
| | 20 | 1011.3 | 181.3 | 0.94182 | 0.93969 | 1.00226 |
| | 30 | 997.48 | 167.48 | 0.87003 | 0.86603 | 1.00462 |
| | 40 | 978.64 | 148.64 | 0.77216 | 0.76604 | 1.00798 |
| | 50 | 955.27 | 125.27 | 0.65075 | 0.64279 | 1.01239 |
| | 60 | 928.04 | 98.04 | 0.50930 | 0.50000 | 1.01860 |
| | 70 | 897.93 | 67.93 | 0.35288 | 0.34202 | 1.03176 |
| | 80 | 866.61 | 36.61 | 0.19018 | 0.17365 | 1.09521 |
| | 90 | 838.43 | 8.43 | 0.04379 | 0.00 | — |
| 0.97 | 0 | 990.50 | 160.50 | 1.0 | 1.0 | 1.0 |
| | 10 | 988.13 | 158.13 | 0.98523 | 0.98481 | 1.000433 |
| | 20 | 981.07 | 151.07 | 0.94125 | 0.93969 | 1.00165 |
| | 30 | 969.50 | 139.50 | 0.86916 | 0.86603 | 1.00362 |
| | 40 | 953.75 | 123.75 | 0.77103 | 0.76604 | 1.00651 |
| | 50 | 934.23 | 104.23 | 0.64941 | 0.64279 | 1.01030 |
| | 60 | 911.53 | 81.53 | 0.50798 | 0.50000 | 1.01595 |
| | 70 | 886.47 | 56.47 | 0.35184 | 0.34202 | 1.02871 |
| | 80 | 860.50 | 30.50 | 0.19003 | 0.17365 | 1.09435 |
| | 90 | 837.20 | 7.20 | 0.04486 | 0.0 | — |
| 0.225 | 0 | 873.17 | 43.17 | 1.0 | 1.0 | 1.0 |
| | 10 | 872.52 | 42.52 | 0.98494 | 0.98481 | 1.000138 |
| | 20 | 870.58 | 40.58 | 0.94000 | 0.93969 | 1.000332 |
| | 30 | 867.42 | 37.42 | 0.86681 | 0.86603 | 1.000901 |
| | 40 | 863.13 | 33.13 | 0.76743 | 0.76604 | 1.00181 |
| | 50 | 857.84 | 27.84 | 0.64489 | 0.64279 | 1.00327 |
| | 60 | 851.72 | 21.72 | 0.50313 | 0.50000 | 1.00625 |
| | 70 | 845.04 | 15.04 | 0.34839 | 0.34202 | 1.01862 |
| | 80 | 838.20 | 8.20 | 0.18995 | 0.17365 | 1.09386 |
| | 90 | 832.19 | 2.19 | 0.05073 | 0.0 | — |


| | | |
|-------------------------|---|--|
| PREPARED BY: <i>EMM</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>70</i> OF |
| CHECKED BY: | | Addendum to 07911000002 REPORT NO. |
| DATE: | | MODEL NO. |

TABLE Add-I-2

CIRCUMFERENTIALLY AVERAGED TEMPERATURE:

FOR CONVECTION:

$$T(\theta) = T_{Na} + \Delta T_{PN}(z) \cos \theta = a + b \cos \theta = a + B$$

$$a = T_{Na}(z)$$

$$b = \Delta T_{PN}(z) = (T_{P_{out}} - T_{Na})$$

$$B = b \cos \theta$$

$$\bar{T}_{conv} = \frac{\int_0^{\pi/2} T d\theta}{\int_0^{\pi/2} d\theta} = \frac{\int_0^{\pi/2} (a + b \cos \theta) d\theta}{\pi/2}$$

$$\bar{T}_{conv} = T_{Na} + \frac{2}{\pi} b \int_0^{\pi/2} \cos \theta d\theta$$

$$\int_0^{\pi/2} \cos \theta d\theta = \left[\sin \theta \right]_0^{\pi/2} = \sin \frac{\pi}{2} = 1$$

$$\bar{T}_{conv} = T_{Na}(z) + \frac{2}{\pi} \Delta T_{PN}(z)$$

$$\bar{T}_{conv} = T_{Na}(z) + \left(\frac{2}{\pi}\right) \Delta T_{PN}(z)$$

$$\frac{2}{\pi} = 0.636620 = G_{conv}$$


$$\bar{T}_{conv} = T_{Na}(z) + \left(\frac{2}{\pi}\right) \Delta T(z)_{(P_{out}-Na)}$$

CIRCUMFERENTIAL AVERAGE AROUND
INDIVIDUAL TUBE PERIPHERY.

CONVECTION.



TABLE Add-I-3 (a)

CIRCUMFERENTIALLY AVERAGED TEMPERATURE:FOR RADIATION:

$$T(\theta) = T_{Na} + \Delta T_{P-N} \cos \theta$$

$$\Delta T_{P-N} = (T_{PEAK} - T_{Na})(z)$$

$$T(\theta) = A + B$$

$$\left\{ \begin{array}{l} a = T_{Na}(z) \\ B = \Delta T_{P-N}(z) \cos \theta = b \cos \theta \end{array} \right.$$

$$dA = [\cos \theta d\theta] 2\pi RL$$

$$\overline{T^4} = \frac{\int_0^{\pi/2} T^4 dA}{\int_0^{\pi/2} dA} = \frac{2\pi RL \int_0^{\pi/2} T^4 \cos \theta d\theta}{2\pi RL \int_0^{\pi/2} \cos \theta d\theta} = \frac{\int_0^{\pi/2} T^4 \cos \theta d\theta}{\int_0^{\pi/2} \cos \theta d\theta}$$

$$T^4 = (a+B)^4 = a^4 + 4a^3B + 6a^2B^2 + 4aB^3 + B^4$$

$$a = T_{Na}$$

$$B = \Delta T_{P-N} \cos \theta = b \cos \theta$$

$$b = \Delta T_{P-N}(z)$$

$$T^4 = a^4 + 4a^3b \cos \theta + 6a^2b^2 \cos^2 \theta + 4ab^3 \cos^3 \theta + b^4 \cos^4 \theta$$

$$T^4 = a^4 \cos \theta + 4a^3b \cos^2 \theta + 6a^2b^2 \cos^3 \theta + 4ab^3 \cos^4 \theta + b^4 \cos^5 \theta$$

$$\overline{T^4} = \frac{\int_0^{\pi/2} T^4 \cos \theta d\theta}{\int_0^{\pi/2} \cos \theta d\theta}$$

TABLE
 Add-I-3(b) $\int_0^{\pi/2} \cos^n \theta d\theta = ? \quad n = 1 \rightarrow 5$

| | |
|---|---|
| $\sin 0 = 0$ $\sin \frac{\pi}{2} = +1$ $\sin 2(\frac{\pi}{2}) = 0$ $\sin 3(\frac{\pi}{2}) = -1$ $\sin 4(\frac{\pi}{2}) = 0$ $\sin 5(\frac{\pi}{2}) = +1$ | $\int_0^{\pi/2} \cos \theta d\theta = \left[\sin \theta \right]_0^{\pi/2} = \sin \frac{\pi}{2} - \sin 0 = 1 - 0 = 1.0$ $\int_0^{\pi/2} \cos^2 \theta d\theta = \left[\frac{\theta}{2} + \frac{1}{4} \sin 2\theta \right]_0^{\pi/2} = \left(\frac{\pi}{4} - 0 \right) - (0 - 0) = \frac{\pi}{4}$ $\int_0^{\pi/2} \cos^3 \theta d\theta = \left[\frac{3}{4} \sin \theta + \frac{1}{12} \sin 3\theta \right]_0^{\pi/2} = \left[\frac{3}{4}(1) + \frac{1}{12}(-1) - 0 - 0 \right] = \frac{2}{3}$ |
|---|---|

$$\int_0^{\pi/2} \cos^4 \theta d\theta = \left[\frac{3\theta}{8} + \frac{1}{4} \sin 2\theta + \frac{1}{32} \sin 4\theta \right]_0^{\pi/2} = \left[\frac{3}{8}(\frac{\pi}{2}) + 0 + 0 - (0 + 0 + 0) \right] = \frac{3\pi}{16}$$

$$\int_0^{\pi/2} \cos^5 \theta d\theta = \left[\frac{5}{8} \sin \theta + \frac{5}{48} \sin 3\theta + \frac{1}{80} \sin 5\theta \right]_0^{\pi/2} = \left[\frac{5}{8}(1) + \frac{5}{48}(-1) + \frac{1}{80}(1) - (0 + 0 + 0) \right] = \frac{8}{15}$$

SEE: W. MEYER ZUR CAPELLEN, INTEGRALTAFELN, 1950
 Pg. 160; (# 2.2.1.1. → 2.2.4)

| | | |
|--|-----------------------------|-------|
| $\int_0^{\pi/2} \cos^n \theta d\theta =$ | $1.0 = 1.0$ | $n=1$ |
| | $\frac{\pi}{4} = .785398$ | $n=2$ |
| | $\frac{2}{3} = .666667$ | $n=3$ |
| | $\frac{3\pi}{16} = .589049$ | $n=4$ |
| | $\frac{8}{15} = .533333$ | $n=5$ |

$$\overline{T^4} = a^4(1) + 4a^3b\left(\frac{\pi}{4}\right) + 6a^2b^2\left(\frac{2}{3}\right) + 4ab^3\left(\frac{3\pi}{16}\right) + b^4\left(\frac{8}{15}\right)$$

| | |
|---|-------------------------|
| $\overline{(T^4)} = a^4 \left\{ 1 + \pi \left(\frac{b}{a}\right) + 4 \left(\frac{b}{a}\right)^2 + \frac{3\pi}{4} \left(\frac{b}{a}\right)^3 + \frac{8}{15} \left(\frac{b}{a}\right)^4 \right\}$ | SEE TI58C LISTING |
| $\overline{(T^4)} = a^4 \left\{ G \right\}_{RAD} = \left(T_{Na} \right)_{OR}^4 \left\{ G \right\}_{RAD}; \quad \overline{T}_{OR} = T_{Na} \left\{ G \right\}_{RAD}^{1/4}$ | |

CIRCUMFERENTIAL AVERAGE AROUND INDIVIDUAL TUBE PERIPHERY.
 RADIATION

TABLE
 Add-I-3(c) T158C LISTING TO CALCULATE $\left\{ \frac{G}{RAD} \right\}^{1/4}$

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|----|--|--------|---|----|--|---|----|----------------|---|----|--|---|----|-----|---|----|----------------|---|----|--|---|----|--------------|---|----|--|---|----|---|----|----|----------------|----|----|--|----|----|---|----|----|-----------------|----|----|--|----|----|----------------|----|----|--|----|----|----------------|----|----|---|----|----|---|----|----|----------------|----|----|--|----|----|-----------------------|----|----|------------------------------|----|----|--|---|----|----|----------------|----|----|--|----|----|-----------------------------------|----|----|---|----|----|----------------|----|----|--|----|----|----------------------|----|----|---|----|----|-----------------|----|----|--|----|----|---|----|----|-----------------------------------|----|----|--|----|----|----------------|----|----|--|----|----|----------------|----|----|-----------------------------------|----|----|---|----|----|-----------------|----|----|--|----|----|----------------------------|----|----|----------|----|----|--|--|----|----|---|----|----|----------|----|----|--|----|----|---|----|----|----------|----|----|--|----|----|---|----|----|----------|----|----|--|----|----|---|----|----|------------------|----|----|-----------------------|----|----|---|----|----|-------------------------------|----|----|--|----|----|----|----|----|----|----|----|--|----|----|--|----|----|---------|
| <table style="width:100%; border-collapse: collapse;"> <tr><td>0</td><td>76</td><td>{ LBIA</td></tr> <tr><td>1</td><td>11</td><td></td></tr> <tr><td>2</td><td>42</td><td>} STO 00 (b/a)</td></tr> <tr><td>3</td><td>00</td><td></td></tr> <tr><td>4</td><td>01</td><td>1.0</td></tr> <tr><td>5</td><td>42</td><td>} STO 10 (1.0)</td></tr> <tr><td>6</td><td>10</td><td></td></tr> <tr><td>7</td><td>43</td><td>} RCL 01 (π)</td></tr> <tr><td>8</td><td>01</td><td></td></tr> <tr><td>9</td><td>65</td><td>*</td></tr> <tr><td>10</td><td>43</td><td>} RCL 00 (b/a)</td></tr> <tr><td>11</td><td>00</td><td></td></tr> <tr><td>12</td><td>95</td><td>=</td></tr> <tr><td>13</td><td>42</td><td>} STO 11 π(b/a)</td></tr> <tr><td>14</td><td>11</td><td></td></tr> <tr><td>15</td><td>43</td><td>} RCL 00 (b/a)</td></tr> <tr><td>16</td><td>00</td><td></td></tr> <tr><td>17</td><td>33</td><td>X²</td></tr> <tr><td>18</td><td>95</td><td>=</td></tr> <tr><td>19</td><td>65</td><td>*</td></tr> <tr><td>20</td><td>43</td><td>} RCL 02 (4.0)</td></tr> <tr><td>21</td><td>02</td><td></td></tr> <tr><td>22</td><td>95</td><td>= 4(b/a)²</td></tr> <tr><td>23</td><td>42</td><td>} STO 12 4(b/a)²</td></tr> <tr><td>24</td><td>12</td><td></td></tr> </table> | 0 | 76 | { LBIA | 1 | 11 | | 2 | 42 | } STO 00 (b/a) | 3 | 00 | | 4 | 01 | 1.0 | 5 | 42 | } STO 10 (1.0) | 6 | 10 | | 7 | 43 | } RCL 01 (π) | 8 | 01 | | 9 | 65 | * | 10 | 43 | } RCL 00 (b/a) | 11 | 00 | | 12 | 95 | = | 13 | 42 | } STO 11 π(b/a) | 14 | 11 | | 15 | 43 | } RCL 00 (b/a) | 16 | 00 | | 17 | 33 | X ² | 18 | 95 | = | 19 | 65 | * | 20 | 43 | } RCL 02 (4.0) | 21 | 02 | | 22 | 95 | = 4(b/a) ² | 23 | 42 | } STO 12 4(b/a) ² | 24 | 12 | | <table style="width:100%; border-collapse: collapse;"> <tr><td>25</td><td>43</td><td>} RCL 00 (b/a)</td></tr> <tr><td>26</td><td>00</td><td></td></tr> <tr><td>27</td><td>33</td><td>X² (b/a)²</td></tr> <tr><td>28</td><td>65</td><td>*</td></tr> <tr><td>29</td><td>43</td><td>} RCL 00 (b/a)</td></tr> <tr><td>30</td><td>00</td><td></td></tr> <tr><td>31</td><td>95</td><td>= (b/a)³</td></tr> <tr><td>32</td><td>65</td><td>*</td></tr> <tr><td>33</td><td>43</td><td>} RCL 03 (3π/4)</td></tr> <tr><td>34</td><td>03</td><td></td></tr> <tr><td>35</td><td>95</td><td>=</td></tr> <tr><td>36</td><td>42</td><td>} STO 13 (3π/4)(b/a)³</td></tr> <tr><td>37</td><td>13</td><td></td></tr> <tr><td>38</td><td>43</td><td>} RCL 00 (b/a)</td></tr> <tr><td>39</td><td>00</td><td></td></tr> <tr><td>40</td><td>33</td><td>X²</td></tr> <tr><td>41</td><td>33</td><td>X² (b/a)⁴</td></tr> <tr><td>42</td><td>65</td><td>*</td></tr> <tr><td>43</td><td>43</td><td>} RCL 04 (8/15)</td></tr> <tr><td>44</td><td>04</td><td></td></tr> <tr><td>45</td><td>95</td><td>= (8/15)(b/a)⁴</td></tr> <tr><td>46</td><td>42</td><td>} STO 14</td></tr> <tr><td>47</td><td>14</td><td></td></tr> </table> | 25 | 43 | } RCL 00 (b/a) | 26 | 00 | | 27 | 33 | X ² (b/a) ² | 28 | 65 | * | 29 | 43 | } RCL 00 (b/a) | 30 | 00 | | 31 | 95 | = (b/a) ³ | 32 | 65 | * | 33 | 43 | } RCL 03 (3π/4) | 34 | 03 | | 35 | 95 | = | 36 | 42 | } STO 13 (3π/4)(b/a) ³ | 37 | 13 | | 38 | 43 | } RCL 00 (b/a) | 39 | 00 | | 40 | 33 | X ² | 41 | 33 | X ² (b/a) ⁴ | 42 | 65 | * | 43 | 43 | } RCL 04 (8/15) | 44 | 04 | | 45 | 95 | = (8/15)(b/a) ⁴ | 46 | 42 | } STO 14 | 47 | 14 | | <table style="width:100%; border-collapse: collapse;"> <tr><td>48</td><td>85</td><td>+</td></tr> <tr><td>49</td><td>43</td><td>} RCL 13</td></tr> <tr><td>50</td><td>13</td><td></td></tr> <tr><td>51</td><td>85</td><td>+</td></tr> <tr><td>52</td><td>43</td><td>} RCL 12</td></tr> <tr><td>53</td><td>12</td><td></td></tr> <tr><td>54</td><td>85</td><td>+</td></tr> <tr><td>55</td><td>43</td><td>} RCL 11</td></tr> <tr><td>56</td><td>11</td><td></td></tr> <tr><td>57</td><td>85</td><td>+</td></tr> <tr><td>58</td><td>43</td><td>} 10+11+12+13+14</td></tr> <tr><td>59</td><td>10</td><td>{ G_{GRAD}}</td></tr> <tr><td>60</td><td>95</td><td>=</td></tr> <tr><td>61</td><td>42</td><td>} STO 15 {G_{GRAD}}</td></tr> <tr><td>62</td><td>15</td><td></td></tr> <tr><td>63</td><td>34</td><td>√x</td></tr> <tr><td>64</td><td>34</td><td>√x</td></tr> <tr><td>65</td><td>42</td><td>} STO 16 {G_{GRAD}}^{1/4}</td></tr> <tr><td>66</td><td>16</td><td></td></tr> <tr><td>67</td><td>91</td><td>R/S END</td></tr> </table> | 48 | 85 | + | 49 | 43 | } RCL 13 | 50 | 13 | | 51 | 85 | + | 52 | 43 | } RCL 12 | 53 | 12 | | 54 | 85 | + | 55 | 43 | } RCL 11 | 56 | 11 | | 57 | 85 | + | 58 | 43 | } 10+11+12+13+14 | 59 | 10 | { G _{GRAD} } | 60 | 95 | = | 61 | 42 | } STO 15 {G _{GRAD} } | 62 | 15 | | 63 | 34 | √x | 64 | 34 | √x | 65 | 42 | } STO 16 {G _{GRAD} } ^{1/4} | 66 | 16 | | 67 | 91 | R/S END |
| 0 | 76 | { LBIA | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | 42 | } STO 00 (b/a) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | 00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | 01 | 1.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | 42 | } STO 10 (1.0) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | 43 | } RCL 01 (π) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | 01 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | 65 | * | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | 43 | } RCL 00 (b/a) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | 00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | 95 | = | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 13 | 42 | } STO 11 π(b/a) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 14 | 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 15 | 43 | } RCL 00 (b/a) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 16 | 00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 17 | 33 | X ² | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 18 | 95 | = | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 19 | 65 | * | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 20 | 43 | } RCL 02 (4.0) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 21 | 02 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 22 | 95 | = 4(b/a) ² | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 23 | 42 | } STO 12 4(b/a) ² | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 24 | 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 25 | 43 | } RCL 00 (b/a) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 26 | 00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 27 | 33 | X ² (b/a) ² | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 28 | 65 | * | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 29 | 43 | } RCL 00 (b/a) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 30 | 00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 31 | 95 | = (b/a) ³ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | 65 | * | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | 43 | } RCL 03 (3π/4) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | 03 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | 95 | = | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | 42 | } STO 13 (3π/4)(b/a) ³ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 37 | 13 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 38 | 43 | } RCL 00 (b/a) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 39 | 00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 40 | 33 | X ² | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 41 | 33 | X ² (b/a) ⁴ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 42 | 65 | * | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 43 | 43 | } RCL 04 (8/15) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 44 | 04 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 45 | 95 | = (8/15)(b/a) ⁴ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 46 | 42 | } STO 14 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 47 | 14 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 48 | 85 | + | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 49 | 43 | } RCL 13 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 50 | 13 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 51 | 85 | + | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 52 | 43 | } RCL 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 53 | 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 54 | 85 | + | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 55 | 43 | } RCL 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 56 | 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 57 | 85 | + | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 58 | 43 | } 10+11+12+13+14 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 59 | 10 | { G _{GRAD} } | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 60 | 95 | = | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 61 | 42 | } STO 15 {G _{GRAD} } | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 62 | 15 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 63 | 34 | √x | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 64 | 34 | √x | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 65 | 42 | } STO 16 {G _{GRAD} } ^{1/4} | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 66 | 16 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 67 | 91 | R/S END | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

STORE BEFORE RUN:

- | | | | |
|----|-----------------|----|-------------------------------------|
| 00 | (b/a) | 00 | (b/a) |
| 01 | π = 3.14159 | 10 | 1.0 |
| 02 | 4.0 | 11 | π (b/a) |
| 03 | 3π/4 = 2.356195 | 12 | 4 (b/a) ² |
| 04 | 8/15 = .5333 | 13 | 3π/4 (b/a) ³ |
| | | 14 | (8/15)(b/a) ⁴ |
| | | 15 | G _{GRAD} |
| | | 16 | {G _{GRAD} } ^{1/4} |

$$\frac{b}{a} = \frac{\Delta T(z)}{T_{Na}^{(R)}}$$

$$\overline{T}_{RAD} = T_{Na} * \left\{ \frac{G}{RAD} \right\}^{1/4}$$

OR

| (b/a) | {G _{RAD} } | {G _{RAD} } ^{1/4} | b/a | {G _{RAD} } | {G _{RAD} } ^{1/4} |
|-------|---------------------|------------------------------------|-----|---------------------|------------------------------------|
| 0 | 1.0 | 1.0 | .11 | 1.397189 | 1.087211 |
| 0.01 | 1.031818 | 1.007861 | .12 | 1.438773 | 1.095212 |
| .02 | 1.064451 | 1.015737 | .13 | 1.481336 | 1.103223 |
| .03 | 1.097912 | 1.023627 | .14 | 1.524893 | 1.111245 |
| .04 | 1.132216 | 1.031531 | .15 | 1.569461 | 1.119277 |
| .05 | 1.167377 | 1.039448 | .16 | 1.615055 | 1.127319 |
| .06 | 1.203411 | 1.047378 | .17 | 1.661692 | 1.135371 |
| .07 | 1.240332 | 1.055321 | .18 | 1.709388 | 1.143432 |
| .08 | 1.278156 | 1.063276 | .19 | 1.758159 | 1.151501 |
| .09 | 1.316896 | 1.071243 | .20 | 1.808021 | 1.159580 |
| .10 | 1.356569 | 1.079221 | .25 | 2.074297 | 1.200101 |
| | | | .30 | 2.370415 | 1.240812 |
| | | | .40 | 3.061087 | 1.322723 |
| | | | .50 | 3.898654 | 1.405169 |

| NO | NAME | UNIT | VALUE | NO | NAME | UNIT | VALUE | NO | NAME | UNIT | VALUE |
|-------|--|------|-------|-------|----------|---------|------------------|----------|----------|------|-------|
| 77 | REGION=500K, TIME=1 | | | 80304 | 624.77 | | | 82100304 | | | |
| 78 | ENRG TAP# | | | 80305 | 630.31 | TNA(F) | | 82100305 | | | |
| 79 | CG.SYSIN DD * | | | 80306 | 636.74 | TNA(F) | | 82100306 | | | |
| 80001 | E R MOURADIAN ENT 3320 LB90 | | | 80307 | 644.14 | TNA(F) | | 82100307 | | | |
| | 678901234567890 | | | 80308 | 652.56 | TNA(F) | | 82100308 | | | |
| | TAP=45 SUPER TAP | | | 80309 | 662.03 | TNA(F) | | 82100309 | | | |
| | 6903-1AB1 (500K) | | | 80310 | 672.43 | TNA(F) | | 82100310 | | | |
| | EFFECTIVE MEAN TEMPERATURE OF TUBE (FOR CONVECTION & RADIATION) | | | 80311 | 684.36 | TNA(F) | | 82100311 | | | |
| | INTEGRATED WITH THETA & Z | | | 80312 | 697.17 | TNA(F) | | 82100312 | | | |
| | DUMMIES: | | | 80313 | 711.05 | TNA(F) | | 82100313 | | | |
| | D0001 = DELTA T (CL) (T1PEAK - T0NA) @ MID-HEIGHT | | | 80314 | 725.44 | TNA(F) | | 82100314 | | | |
| | D0300 = D0340 = T1NA TPT | | | 80315 | 741.74 | TNA(F) | | 82100315 | | | |
| | D0400 = D0440 = T1RA (R) | | | 80316 | 758.35 | TNA(F) | | 82100316 | | | |
| | D0500 = D0540 = DELTA T1 (Z) (T1PH-T1NA)(Z) | | | 80317 | 775.45 | TNA(F) | | 82100317 | | | |
| | D0600 = D0640 = (DEL T1/T1NA IN) * R/A | | | 80318 | 792.46 | TNA(F) | | 82100318 | | | |
| | D0700 = D0740 = T1BAR (RADIATION) PER NODE (THETA AVG) | | | 80319 | 811.44 | TNA(F) | | 82100319 | | | |
| | D0800 = D0840 = (T1Z-RAD)*** | | | 80320 | 830.00 | TNA(F) | | 82100320 | | | |
| | D0900 = D0940 = (AIZ)/A(T1Z)*** | | | 80321 | 848.34 | TNA(F) | | 82100321 | | | |
| | E0100 = E0140 = (Z/P1)(DT) EXTRA INCREMENT, CONV | | | 80322 | 864.54 | TNA(F) | | 82100322 | | | |
| | E0200 = E0240 = (C**1/4)RAD T1BR(RAD)=T1NA*(G) (R) | | | 80323 | 884.35 | TNA(F) | | 82100323 | | | |
| | F0100 = F0140 = HEAT FLOW (REJECTION) CONVECTION | | | 80324 | 901.45 | TNA(F) | | 82100324 | | | |
| | F0150 = TOTAL HEAT FLOW OUT - CONVECTION | | | 80325 | 918.26 | TNA(F) | | 82100325 | | | |
| | F0200 = F0240 = HEAT FLOW (REJECTION) RADIATION | | | 80326 | 934.06 | TNA(F) | | 82100326 | | | |
| | F0250 = TOTAL HEAT FLOW OUT - RADIATION | | | 80327 | 948.93 | TNA(F) | | 82100327 | | | |
| | F0260 = SUM (AIZ)/A(T1Z)*** = RAD HEAT OUT | | | 80328 | 962.83 | TNA(F) | | 82100328 | | | |
| | H0011 = T1BRN CNV CVERALL MEAN TEMP (O & Z INTEGRATION) (F) | | | 80329 | 975.44 | TNA(F) | | 82100329 | | | |
| | H0021 = T1BRN RAD CVERALL MEAN TEMP (O & Z INTEGRATION) (F) | | | 80330 | 987.85 | TNA(F) | | 82100330 | | | |
| | H0022 = T1BRN RAD CVERALL MEAN TEMP (O & Z INTEGRATION) (R) | | | 80331 | 997.85 | TNA(F) | | 82100331 | | | |
| | H0025 = T1BRN RAD CVERALL MEAN TEMP (O & Z INTEGRATION) (R) | | | 80332 | 1007.44 | TNA(F) | | 82100332 | | | |
| | SHOULD BE SAME AS H0021 | | | 80333 | 1015.84 | TNA(F) | | 82100333 | | | |
| | H0026 = T1BRN RAD CVERALL MEAN TEMP (O & Z INTEGRATION) (F) | | | 80334 | 1023.26 | TNA(F) | | 82100334 | | | |
| | SHOULD BE SAME AS H0022 | | | 80335 | 1029.49 | TNA(F) | | 82100335 | | | |
| | H001 = 0.25 = 1/4 | | | 80336 | 1035.23 | TNA(F) | | 82100336 | | | |
| | H002 = 459.49 | | | 80337 | 1039.96 | TNA(F) | | 82100337 | | | |
| | H003 = 0.434620 = 2/P1 | | | 80338 | 1043.92 | TNA(F) | | 82100338 | | | |
| | H004 = 4.0 | | | 80339 | 1047.25 | TNA(F) | | 82100339 | | | |
| | H0100 = H0140 = NORMAL DISTRIBUTION (OIZ) | | | 80340 | 1050.00 | TNA(F) | | 82100340 | | | |
| | MODES: | | | 80001 | -1 | 0.0 | CONV SINK | 0.0F | 82110101 | | |
| | T0001 = CONVECTIVE SINK: T = 0 F | | | 80002 | -1 | 1000.0 | DUPNY STRING | | 82110102 | | |
| | T0002 = RADIATIVE SINK: T = -459.49F = 0 R | | | 80003 | -1 | -459.49 | DUPNY STRING | | 82110103 | | |
| | T0100 = T0140 = "CONVECTIVE" TEMP MODES | | | 80004 | -1 | 0.01 | DUPNY STRING | | 82110104 | | |
| | T0200 = T0240 = "RADIATIVE" TEMP ACDEES | | | 80005 | -1 | 0.01 | RAD SINK | 0.0R | 82110105 | | |
| | T0301 = T0302 = DUMMY MODES (CNV) | | | 80006 | -1 | 25.0 | INT T | | 82110106 | | |
| | T0401 = T0402 = DUMMY ACDES (RAD) | | | 80007 | -1 | 25.0 | DUPNY STRING | | 82110107 | | |
| | LENGTH OF MODES: | | | 80008 | -1 | 1000.0 | DUPNY STRING | | 82110108 | | |
| | T0100 & T0140 L = 1/80 = 0.0125 | | | 80009 | 0.0125 | | CONV HA=1/80 | | 82400110 | | |
| | T0101 & T0139 L = 1/50 = 0.0200 | | | 80010 | 0.0125 | | CONV HA=1/50 | | 82400120 | | |
| | T0200 & T0240 L = 1/80 = 0.0125 | | | 80011 | 0.0125 | | CONV HA=1/80 | | 82400130 | | |
| | T0301 & T0319 L = 1/40 = 0.0250 | | | 80012 | 0.4 | | DUPNY Y | | 82400140 | | |
| | T0401 & T0419 L = 1/40 = 0.0250 | | | 80013 | 0.4 | | GENERAL | | 82450000 | | |
| | CONDUCTANCES: | | | 80014 | 0.14474 | | 3RD DISTRIBUTION | | 82450020 | | |
| | Y0100 = Y0140 = CONVECTION QUT | | | 80015 | 0.235746 | | 3RD ACCTRS: | | 82450030 | | |
| | Y = NA; HA=1/80 FOR 1 & 40; HA=1/40 FOR 2 THRU 39 | | | 80016 | 0.278037 | | 32 (OZ) | | 82450040 | | |
| | Y0200 = Y0240 = RADIATION QUT | | | 80017 | 0.324452 | | 30 (OZ) | | 82450050 | | |
| | GAIN = 1/80 FOR 1 & 40; 1/40 FOR 2 THRU 39 | | | 80018 | 0.375311 | | 20 (OZ) | | 82450060 | | |
| | Y0301 = Y0302 = DUMMY CONDUCTANCES | | | 80019 | 0.429557 | | 26 (OZ) | | 82450070 | | |
| | Y0401 = Y0402 = DUMMY CONDUCTANCES | | | 80020 | 0.484752 | | 24 (OZ) | | 82450080 | | |
| | TABLES: | | | 80021 | 0.534874 | | 22 (OZ) | | 82450090 | | |
| | TABLE 2: FOR RADIATION: | | | 80022 | 0.580531 | | 20 (OZ) | | 82450100 | | |
| | (G**1/4) VS (R/A) | | | 80023 | 0.644727 | | 18 (OZ) | | 82450110 | | |
| | R/A = DEL T/T1NA R | | | 80024 | 0.724149 | | 16 (OZ) | | 82450120 | | |
| | (G**1/4) = T1BR RAD(O) = (T1NA R)**(0.25) | | | 80025 | 0.782705 | | 14 (OZ) | | 82450130 | | |
| | SPECIAL CONDITION: | | | 80026 | 0.835270 | | 12 (OZ) | | 82450140 | | |
| | SIGMA = 1.0 BTU/HR FT ² R4 (MATHEMATICAL CONTRIVANCE) | | | 80027 | 0.882497 | | 10 (OZ) | | 82450150 | | |
| | PROBLEM CASE: | | | 80028 | 0.923116 | | 8 (OZ) | | 82450160 | | |
| | T1NA = 610F - 1050F | | | 80029 | 0.955997 | | 6 (OZ) | | 82450170 | | |
| | (Q/A)CL = 1.20 MW/M ² (T1PR-T1NA)EL = 192.50F | | | 80030 | 0.980199 | | 4 (OZ) | | 82450180 | | |
| | | | | 80031 | 0.995912 | | 2 (OZ) | | 82450190 | | |
| | | | | 80032 | 1.0 | | | | 82450200 | | |
| | | | | 80033 | 459.49 | | | | 82450210 | | |
| | | | | 80034 | 459.49 | | | | 82450220 | | |
| | | | | 80035 | 2/P1 | | | | 82450230 | | |
| | | | | 80036 | 4.0 | | | | 82450240 | | |
| | | | | 80037 | 0.000000 | | | | 82450250 | | |
| | | | | 80038 | 0.000000 | | | | 82450260 | | |
| | | | | 80039 | 0.000000 | | | | 82450270 | | |
| | | | | 80040 | 0.000000 | | | | 82450280 | | |
| | | | | 80041 | 0.000000 | | | | 82450290 | | |
| | | | | 80042 | 0.000000 | | | | 82450300 | | |
| | | | | 80043 | 0.000000 | | | | 82450310 | | |
| | | | | 80044 | 0.000000 | | | | 82450320 | | |
| | | | | 80045 | 0.000000 | | | | 82450330 | | |
| | | | | 80046 | 0.000000 | | | | 82450340 | | |
| | | | | 80047 | 0.000000 | | | | 82450350 | | |
| | | | | 80048 | 0.000000 | | | | 82450360 | | |
| | | | | 80049 | 0.000000 | | | | 82450370 | | |
| | | | | 80050 | 0.000000 | | | | 82450380 | | |
| | | | | 80051 | 0.000000 | | | | 82450390 | | |
| | | | | 80052 | 0.000000 | | | | 82450400 | | |
| | | | | 80053 | 0.000000 | | | | 82450410 | | |
| | | | | 80054 | 0.000000 | | | | 82450420 | | |
| | | | | 80055 | 0.000000 | | | | 82450430 | | |
| | | | | 80056 | 0.000000 | | | | 82450440 | | |
| | | | | 80057 | 0.000000 | | | | 82450450 | | |
| | | | | 80058 | 0.000000 | | | | 82450460 | | |
| | | | | 80059 | 0.000000 | | | | 82450470 | | |
| | | | | 80060 | 0.000000 | | | | 82450480 | | |
| | | | | 80061 | 0.000000 | | | | 82450490 | | |
| | | | | 80062 | 0.000000 | | | | 82450500 | | |
| | | | | 80063 | 0.000000 | | | | 82450510 | | |
| | | | | 80064 | 0.000000 | | | | 82450520 | | |
| | | | | 80065 | 0.000000 | | | | 82450530 | | |
| | | | | 80066 | 0.000000 | | | | 82450540 | | |
| | | | | 80067 | 0.000000 | | | | 82450550 | | |
| | | | | 80068 | 0.000000 | | | | 82450560 | | |
| | | | | 80069 | 0.000000 | | | | 82450570 | | |
| | | | | 80070 | 0.000000 | | | | 82450580 | | |
| | | | | 80071 | 0.000000 | | | | 82450590 | | |
| | | | | 80072 | 0.000000 | | | | 82450600 | | |
| | | | | 80073 | 0.000000 | | | | 82450610 | | |
| | | | | 80074 | 0.000000 | | | | 82450620 | | |
| | | | | 80075 | 0.000000 | | | | 82450630 | | |
| | | | | 80076 | 0.000000 | | | | 82450640 | | |
| | | | | 80077 | 0.000000 | | | | 82450650 | | |
| | | | | 80078 | 0.000000 | | | | 82450660 | | |
| | | | | 80079 | 0.000000 | | | | 82450670 | | |
| | | | | 80080 | 0.000000 | | | | 82450680 | | |
| | | | | 80081 | 0.000000 | | | | 82450690 | | |
| | | | | 80082 | 0.000000 | | | | 8245070 | | |

| | | | | | | | | | | | |
|------------|-----|--------|------------|---|------------------|----------|-------|----|--------------------------|----------------------------------|----------|
| F0200F0240 | 40 | 1.0 | F0200 | 1 | HT PLU RAD | 03630200 | 00001 | 2 | (Q/A)CL = 0.97 MW/P2 | (T)PK-T)NA)CL = 160.50F | 20000010 |
| F0190 | 41 | 1.0 | F0100F0140 | | TOT G CWV | 03640100 | 00001 | 2 | 160.50 | (DT) Q/A=0.97 | 20001022 |
| F0290 | 01 | 1.0 | F0200F0240 | | TOT G RAD | 03640200 | 00070 | 11 | 1.0 | | 22000100 |
| H0011 | 1 | 1.0 | F0190 | | T)BRM CWV F | 03650100 | 00096 | 2 | | | 27000000 |
| H0022 | 40 | 1.0 | F0290H0001 | | T)BRM RAD R | 03650200 | 00096 | 2 | | | 27000110 |
| H0021 | 51 | 1.0 | H0022H0002 | | T)BRM RAD F | 03650300 | 00096 | 2 | | | 29600000 |
| C0000D0440 | 140 | 1.0 | D0700H0004 | 1 | 1**4 | 03750100 | 00001 | 2 | (Q/A)CL = 0.225 MW/P2 | (T)PK-T)NA)CL = 43.17F | 30000010 |
| C0900 | 1 | 0.0125 | D0800 | | (1/40)T**4 | 03750210 | 00001 | 2 | 43.17 | (DT) Q/A=0.225 | 30001022 |
| C0901D0939 | 1 | 0.025 | D0801 | 1 | (1/40)T**4 | 03750220 | 00001 | 2 | | | 32000000 |
| C0940 | 1 | 0.0125 | D0840 | | (1/80)T**4 | 03750230 | 00001 | 2 | | | 32000100 |
| F0240 | 41 | 1.0 | D0900D0940 | | SUM(A/A)T**4 | 03750400 | 00001 | 2 | (Q/A)CL = 0.310125 MW/P2 | (T)PK-T)NA)CL = 57.03625F (1/8) | 32000000 |
| H0026 | 40 | 1.0 | F0200H0001 | | SUM(T**4)**1/4 | 03750500 | 00001 | 2 | | | 41000001 |
| H0025 | 51 | 1.0 | H0026H0002 | | T)BR (F) | 03750600 | 00020 | 2 | 57.03625 | | 41020000 |
| H0040 | 2 | 0.0 | | | 04000000 | 00096 | 2 | | | | 41020100 |
| | | 0.01 | 1.007801 | | TABLE 2 2 2 2 2 | 04200001 | 00001 | 2 | | | 41096000 |
| | | 0.02 | 1.015737 | | IC**1/4) RAD | 04200010 | 00001 | 2 | (Q/A)CL = 0.411255 MW/P2 | (T)PK-T)NA)CL = 72.5025 F (1/4) | 42000001 |
| | | 0.03 | 1.023627 | | FACTOR FOR | 04200020 | 00001 | 2 | 72.5025 | | 42000020 |
| | | 0.04 | 1.031531 | | MEAN TEMPERATURE | 04200030 | 00001 | 2 | | | 42020100 |
| | | 0.05 | 1.039448 | | FOR RADIATION | 04200040 | 00001 | 2 | | | 42020200 |
| | | 0.06 | 1.047379 | | | 04200050 | 00001 | 2 | | | 42096000 |
| | | 0.07 | 1.055321 | | | 04200060 | 00001 | 2 | (Q/A)CL = 0.504375 MW/P2 | (T)PK-T)NA)CL = 87.16075F (3/8) | 43000001 |
| | | 0.08 | 1.063276 | | | 04200070 | 00001 | 2 | 87.16075 | | 43000020 |
| | | 0.09 | 1.071243 | | | 04200080 | 00001 | 2 | | | 43020100 |
| | | 0.10 | 1.079221 | | | 04200090 | 00001 | 2 | | | 43096000 |
| | | 0.11 | 1.087211 | | | 04200100 | 00001 | 2 | (Q/A)CL = 0.5975 MW/P2 | (T)PK-T)NA)CL = 101.835 F (1/2) | 44000001 |
| | | 0.12 | 1.095212 | | | 04200110 | 00001 | 2 | 101.835 | | 44000020 |
| | | 0.13 | 1.103223 | | | 04200120 | 00020 | 2 | | | 44020000 |
| | | 0.14 | 1.111245 | | | 04200130 | 00001 | 2 | | | 44020100 |
| | | 0.15 | 1.119277 | | | 04200140 | 00096 | 2 | | | 44096000 |
| | | 0.16 | 1.127315 | | | 04200150 | 00001 | 2 | (Q/A)CL = 0.690625 MW/P2 | (T)PK-T)NA)CL = 116.50125F (5/8) | 45000001 |
| | | 0.17 | 1.135371 | | | 04200160 | 00001 | 2 | 116.50125 | | 45000020 |
| | | 0.18 | 1.143432 | | | 04200170 | 00001 | 2 | | | 45020000 |
| | | 0.19 | 1.151501 | | | 04200180 | 00001 | 2 | | | 45020100 |
| | | 0.20 | 1.159580 | | | 04200190 | 00096 | 2 | | | 45096000 |
| | | 0.25 | 1.200101 | | | 04200200 | 00001 | 2 | (Q/A)CL = 0.78375 MW/P2 | (T)PK-T)NA)CL = 131.1675 F (3/4) | 46000001 |
| | | 0.30 | 1.240812 | | | 04200250 | 00001 | 2 | 131.1675 | | 46000020 |
| | | 0.50 | 1.405105 | | | 04200300 | 00020 | 2 | | | 46020000 |
| | | | | | | 07000000 | 00001 | 2 | | | 46020100 |
| | | | | | | 07000190 | 00096 | 2 | | | 46096000 |
| | | | | | | 07000400 | 00001 | 2 | (Q/A)CL = 0.876875 MW/P2 | (T)PK-T)NA)CL = 145.83375F (7/8) | 47000001 |
| | | | | | | 07000500 | 00001 | 2 | 145.83375 | | 47000020 |
| | | | | | | 07000600 | 00020 | 2 | | | 47020000 |
| | | | | | | 07000700 | 00001 | 2 | | | 47020100 |
| | | | | | | 07000800 | 00096 | 2 | | | 47096000 |
| | | | | | | 07001400 | 00001 | 2 | (Q/A)CL = 0.99875 MW/P2 | (T)PK-T)NA)CL = 164.50 F (1/8) | 51000001 |
| | | | | | | 08000000 | 00001 | 2 | 164.50 | | 51000020 |
| | | | | | | 08220110 | 00001 | 2 | | | 51020100 |
| | | | | | | 08220120 | 00096 | 2 | | | 51096000 |
| | | | | | | 08220140 | 00001 | 2 | (Q/A)CL = 1.0275 MW/P2 | (T)PK-T)NA)CL = 168.50 F (1/4) | 52000001 |
| | | | | | | 08220150 | 00001 | 2 | 168.50 | | 52000020 |
| | | | | | | 08220210 | 00001 | 2 | | | 52020000 |
| | | | | | | 08220220 | 00020 | 2 | | | 52020100 |
| | | | | | | 08220230 | 00001 | 2 | | | 52096000 |
| | | | | | | 08220240 | 00001 | 2 | (Q/A)CL = 1.05625 MW/P2 | (T)PK-T)NA)CL = 172.50 F (3/8) | 53000001 |
| | | | | | | 08220250 | 00001 | 2 | 172.50 | | 53000020 |
| | | | | | | 08220310 | 00020 | 2 | | | 53020000 |
| | | | | | | 08220320 | 00001 | 2 | | | 53020100 |
| | | | | | | 08220330 | 00096 | 2 | | | 53096000 |
| | | | | | | 08220340 | 00001 | 2 | (Q/A)CL = 1.085 MW/P2 | (T)PK-T)NA)CL = 176.50 F (1/2) | 54000001 |
| | | | | | | 08220350 | 00001 | 2 | 176.50 | | 54000020 |
| | | | | | | 08230001 | 00001 | 2 | | | 54020000 |
| | | | | | | 08240110 | 00001 | 2 | | | 54020100 |
| | | | | | | 08240140 | 00001 | 2 | (Q/A)CL = 1.11375 MW/P2 | (T)PK-T)NA)CL = 180.50 F (5/8) | 54096000 |
| | | | | | | 08240150 | 00001 | 2 | 180.50 | | 55000001 |
| | | | | | | 08240210 | 00096 | 2 | | | 55000020 |
| | | | | | | 08240240 | 00001 | 2 | | | 55020000 |
| | | | | | | 08240250 | 00001 | 2 | | | 55020100 |
| | | | | | | 08240310 | 00096 | 2 | | | 55096000 |
| | | | | | | 08240340 | 00001 | 2 | (Q/A)CL = 1.1425 MW/P2 | (T)PK-T)NA)CL = 184.50 F (3/4) | 56000001 |
| | | | | | | 08240350 | 00001 | 2 | 184.50 | | 56000020 |
| | | | | | | 08250001 | 00001 | 2 | | | 56020000 |
| | | | | | | 08500100 | 00001 | 2 | | | 56020100 |
| | | | | | | 08500200 | 00096 | 2 | | | 56096000 |
| | | | | | | 08500300 | 00001 | 2 | (Q/A)CL = 1.17125 MW/P2 | (T)PK-T)NA)CL = 188.50 F (7/8) | 57000001 |
| | | | | | | 08500400 | 00001 | 2 | 188.50 | | 57000020 |
| | | | | | | 08500500 | 00001 | 2 | | | 57020000 |
| | | | | | | 09000000 | 00001 | 2 | | | 57020100 |
| | | | | | | 09000100 | 00020 | 2 | | | 57096000 |
| | | | | | | 09000202 | 00001 | 2 | | | |
| | | | | | | 09600000 | 00096 | 2 | | | |

TABLE Add-I - 4 (b)

6903-14

3/29/83

BU = 1.2732

T_{INA} 610° → 1050°F $\bar{T}_{NC} = 830^\circ$ EFFECTIVE MEAN TEMPERATURE (Z & θ AVERAGING)

6903

| LOCATION | (Q/A) & MW/m ² | ΔT & Pk-Na | COMPUTER OR INTERVAL | CONV | | RADIATION | |
|------------------|------------------------------|-----------------------|----------------------------|------------------------|--|-----------------------|-----------------------|
| | | | | \bar{T}_{CONV} °F | | \bar{T}_{RAD} °F | \bar{T}_{RAD} °R |
| FULL LOAD TUBE | 1.20 | 192.50 | TAP | 903.29 | | 947.70 | 1407.4 |
| INBOARD | 0.97 | 160.50 | TAP | 891.10 | | 932.24 | 1391.9 |
| OUTBOARD | 0.225 | 43.17 | TAP | 846.43 | | 876.95 | 1336.6 |
| PANEL 1 | 0 | 43.17 | TAP | 846.43 | | 876.95 | 1336.64 |
| | 1/8 | 57.83625 | Inter | 852.02 | | 883.74 | 1343.43 |
| | 1/4 | 72.5025 | Inter | 857.60 | | 890.57 | 1350.26 |
| | 3/8 | 87.16875 | Inter | 863.18 | | 897.42 | 1357.11 |
| | 1/2 | 101.835 | Inter | 868.77 | | 904.32 | 1364.01 |
| | 5/8 | 116.50125 | Inter | 874.35 | | 911.25 | 1370.94 |
| | 3/4 | 131.1675 | Inter | 879.93 | | 918.21 | 1377.90 |
| | 7/8 | 145.83375 | Inter | 885.52 | | 925.21 | 1384.90 |
| | 1 | 160.50 | TAP | 891.10 | | 932.24 | 1391.93 |
| PORTION; PANEL 2 | 0 | 160.50 | TAP | 891.10 | | 932.24 | 1391.93 |
| | 1/8 | 164.50 | Inter | 892.62 | | 934.16 | 1393.85 |
| | 1/4 | 168.50 | Inter | 894.15 | | 936.09 | 1395.78 |
| | 3/8 | 172.50 | Inter | 895.67 | | 938.02 | 1397.71 |
| | 1/2 | 176.50 | Inter | 897.19 | | 939.95 | 1399.64 |
| | 5/8 | 180.50 | Inter | 898.72 | | 941.88 | 1401.57 |
| | 3/4 | 184.50 | Inter | 900.24 | | 943.82 | 1403.51 |
| | 7/8 | 188.50 | Inter | 901.76 | | 945.75 | 1405.44 |
| | 1 | 192.50 | TAP | 903.29 | | 947.70 | 1407.39 |

TO DETERMINE
"EFFECTIVE MEAN"
TEMPERATURE
(For Heat Loss Calculation).

TABLE ADD-I-5
COMPUTER OUTPUT:
MEAN TEMPERATURES;
Averaged Circumferentially, θ ,
and Axially, Z.

NO 000

NO
PAGE 76Addendum to
079TT000002

TABLE Add-I-6
 TEMPERATURES AVERAGED ACROSS PANEL.

SUB-PANEL 1

θ, z mean

| FRACTION | LOCATION | (Q/A) ε | \bar{T}_{RAD} OR | $\left(\frac{\bar{T}_{RAD} \text{ OR}}{1000}\right)^4$ | $\left(\frac{\bar{T}_{RAD} \text{ (OR)}}{1000}\right)^4 \times \text{FRAC}$ | \bar{T}_{CONV} OF | $\bar{T}_{CONV} \times \text{FRAC}$ OF |
|--------------|----------|------------|-----------------------|--|---|---------------------------------------|---|
| .0625 = 1/16 | 0 | .225 | 1336.64 | 3.191963 | 0.199498 | 846.43 | 52.901875 |
| .125 = 1/8 | 1/8 | ↓ | 1343.43 | 3.257381 | 0.407165 | 852.02 | 106.5025 |
| .125 | 1/4 | ↓ | 1350.26 | 3.324066 | 0.415508 | 857.60 | 107.2000 |
| .125 | 3/8 | ↓ | 1357.11 | 3.392034 | 0.424004 | 863.18 | 107.8975 |
| .125 | 1/2 | ↓ | 1364.01 | 3.461547 | 0.432693 | 868.77 | 108.59625 |
| .125 | 5/8 | ↓ | 1370.94 | 3.532432 | 0.441554 | 874.35 | 109.29375 |
| .125 | 3/4 | ↓ | 1377.90 | 3.604714 | 0.450589 | 879.93 | 109.99125 |
| .125 = 1/8 | 7/8 | ↓ | 1384.90 | 3.678525 | 0.459816 | 885.52 | 110.69000 |
| .0625 = 1/16 | 1 | .970 | 1391.93 | 3.753787 | 0.234612 | 891.10 | 55.69375 |
| | | | | | $\Sigma = 3.465439$ | | |
| | | | | | $1000 \times (3.465439)^{1/4} = 1364.393^\circ R$ | | |
| | | | | | | $\Sigma = 868.766875$ (868.765) °F | |

SUB-PANEL 2

| FRACTION | (Q/A) ε | \bar{T}_{RAD} OR | $\left(\frac{\bar{T}_{RAD} \text{ OR}}{1000}\right)^4$ | $\left(\frac{\bar{T}_{RAD} \text{ (OR)}}{1000}\right)^4 \times \text{FRAC}$ | \bar{T}_{CONV} OF | $\bar{T}_{CONV} \times \text{FRAC}$ OF | |
|---|------------|-----------------------|--|---|---|---|--|
| $\frac{1}{16} \times \left(\frac{230}{745}\right) = .0192953$ | .970 | 1391.93 | 3.753787 | 0.072430 | 891.10 | 17.194044 | |
| $\frac{1}{8} \times \left(\frac{230}{745}\right) = .0385906$ | ↓ | 1393.85 | 3.774541 | 0.145662 | 892.62 | 34.446745 | |
| $\frac{1}{8} \times \left(\frac{230}{745}\right) = .0385906$ | ↓ | 1395.78 | 3.795490 | 0.146470 | 894.15 | 34.505789 | |
| $\frac{1}{8} \times \left(\frac{230}{745}\right) = .0385906$ | ↓ | 1397.71 | 3.816527 | 0.147282 | 895.67 | 34.564446 | |
| $\frac{1}{8} \times \left(\frac{230}{745}\right) = .0385906$ | ↓ | 1399.64 | 3.837650 | 0.148097 | 897.19 | 34.623104 | |
| $\frac{1}{8} \times \left(\frac{230}{745}\right) = .0385906$ | ↓ | 1401.57 | 3.858861 | 0.148916 | 898.72 | 34.682148 | |
| $\frac{1}{8} \times \left(\frac{230}{745}\right) = .0385906$ | ↓ | 1403.51 | 3.880271 | 0.149742 | 900.24 | 34.740805 | |
| $\frac{1}{8} \times \left(\frac{230}{745}\right) = .0385906$ | ↓ | 1405.44 | 3.901658 | 0.150567 | 901.76 | 34.799463 | |
| $\frac{1}{16} \times \left(\frac{230}{745}\right) = .0192953$ | 1.20 | 1407.39 | 3.923357 | 0.075702 | 903.29 | 17.429253 | |
| $\left(1 - \frac{230}{745}\right) = .6912752$ | 1.20 | 1407.39 | 3.923357 | 2.712119 | 903.29 | 624.421946 | |
| | | | | | $\Sigma = 3.896987$ | | |
| | | | | | $1000 \times (3.896987)^{1/4} = 1405.019^\circ R$ | | |
| | | | | | | $\Sigma = 901.406952$ °F | |

TABLE Add-I-7

OVERALL EFFECTIVE TEMPERATURES

(θ, z, x INTEGRATION)

RADIATION:

| SUB-PANEL NUMBER | $\bar{T}_{\text{AVG RAD}}^{\circ\text{R}}$ | $\left(\frac{\bar{T}}{1000}\right)^4 \times \text{FRAC} =$ |
|------------------|--|--|
| 1, 8 | 1364.393 | $3.465436 \times \left(\frac{2}{8}\right) = 0.8663590952^{01}$ |
| 2, 7 | 1405.019 | $3.896985 \times \left(\frac{2}{8}\right) = 0.9742463728^{02}$ |
| 3, 6 4, 5 | 1407.39 | $3.923357 \times \left(\frac{4}{8}\right) = 1.9616785707^{03}$ |
| | | <u>3.8022840387⁰⁰</u> |
| | | $1000 \times (3.802284)^{1/4} = 1396.404^{\circ\text{R}}$ $(936.714^{\circ\text{F}})$ |
| | | $\left. \begin{array}{l} \\ \\ \end{array} \right\} = T_{\text{EFF MEAN OVERALL RADIATION}}$ |

CONVECTION:

$$T_{\text{EFF MEAN CONV}} = \frac{1}{4}(868.766875) + \frac{1}{4}(901.406952) + \frac{1}{2}(903.29) = 894.188^{\circ\text{F}}$$

$$= 894.188^{\circ\text{F}}$$

EFFECTIVE MEAN TEMPERATURES:

REFERENCE SOLAR FLUX, $\left\{ \begin{array}{l} T_{\text{Na-IN}} = 610^{\circ\text{F}} \\ T_{\text{Na-OUT}} = 1050^{\circ\text{F}} \end{array} \right.$
 3/4" OD, 0.049" wall Tubes.

INTEGRATION: $\left\{ \begin{array}{l} \theta \text{ (CIRCUMFERENTIAL AROUND TUBE)} \\ z \text{ (AXIAL - VERTICAL)} \\ x \text{ (LATERAL - ACROSS PANEL)} \end{array} \right.$

$$\bar{T}_{\text{OVERALL RADIATION}} = 1396.40^{\circ\text{R}}$$

$$(936.71^{\circ\text{F}})$$

$$\bar{T}_{\text{OVERALL CONVECTION}} = 894.19^{\circ\text{F}}$$

TABLE
 Add-I-8 (a) HEAT LOSS CALCULATIONS:

BASED ON REFERENCE SOLAR FLUX
 (079TI000002 Pg.7)

SIZE OF ACTIVE PANEL:

HEIGHT: 40 feet

WIDTH: 8 * [(102 * .75 inch) + (101 + .010 inch)] = 620.08 inch
Sub Panels Tubes OD/Tube Gaps Gap width (51.6733 ft)

Projected Area: 40 ft * 51.6733 ft = 2066.933 ft²

2066.933 (.3048)² = 192.024 m²

"PROJECTED AREA" OF ACTIVE PANEL = { 2066.93 ft²
 192.024 m² }

ENERGY INCIDENT ON PANEL?

a) Determine $(\frac{Q}{A})_{\text{Mean}}$ by averaging laterally.

REFERENCE SOLAR FLUX
 See 079TI000002 Pg.7

b) Determine overall mean by averaging vertically:

c) $Q = A * (\frac{Q}{A})_{\text{Mean}} = .5981441 * (\frac{Q}{A})_{\text{Mean}}$

See 079TI000002 Pg.8

a) (i) 2 Panels: $(\frac{Q}{A})_{\text{L}} = \frac{1}{2} (.225 + .970) = .5975$

(ii) 2 Panels: $(\frac{230}{745}) [\frac{1}{2} (.970 + 1.20)] + (1 - \frac{230}{745}) (1.20) = 1.1645$

(iii) 4 Panels: 1.20

$(\frac{Q}{A})_{\text{L}} = \frac{1}{4} \{ .5975 + 1.1645 + 2(1.20) \} = 1.0405 \text{ MW/m}^2$

$(\frac{Q}{A})_{\text{L}} = 1.0405$ LATERALLY AVERAGED MID-HEIGHT FLUXES

b) $(\frac{Q}{A})_{\text{OVERALL MEAN}} = .598144 * (\frac{Q}{A})_{\text{L}} = .598144 * 1.0405$

$(\frac{Q}{A})_{\text{OVERALL MEAN}} = 0.622368 \frac{\text{MW}}{\text{m}^2}$

c) $Q_{\text{TOTAL INCIDENT}} = (\frac{Q}{A})_{\text{OVERALL MEAN}} * A = 0.622368 \frac{\text{MW}}{\text{m}^2} * 192.024 \text{ m}^2 = 119.51 \text{ MW}$

$Q_{\text{PANEL INCIDENT}} = 119.51 \text{ MW}$


| | | |
|---------------------------|---|--|
| PREPARED BY: <u>E M M</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>80</u> OF |
| CHECKED BY: | | Addendum to <u>079TI0000002</u> REPORT NO. |
| DATE: | | MODEL NO. |

TABLE
Add-I-B (b)

REFLECTION HEAT LOSS:

Assume: $\alpha_{\text{SOLAR}} = 0.95$

This means: Reflectivity = $0.05 = 5\%$

$$Q_{\text{LOSS REFLEC}} = 0.05 \times Q_{\text{INCID}} = 0.05 \times 119.51 \text{ MW} = 5.9755 \text{ MW}_t$$

$Q_{\text{LOSS REFLECTION}} = 5.98 \text{ MW}$

RADIATION HEAT LOSS:

{ EMISSIVITY } \approx { 0.85 } "Effective" emissivity (based on projected area)
 { OF COATING } \approx { 0.88 } is slightly higher than that of coating.

Let's say: $\epsilon_{\text{EFF}} = 0.88$; $f = \epsilon = 0.88$

$T_{\text{COLD}} = 60^\circ\text{F} = 519.69^\circ\text{R}$

$A = 2066.93 \text{ ft}^2$

$\sigma = 0.1713 \times 10^{-8} \frac{\text{BTU}}{\text{ft}^2 \text{ hr } ^\circ\text{R}^4}$

$T_{\text{HOT}} = 1396.4^\circ\text{R}$
EFFECTIVE
MEAN PANEL TEMP
FOR RADIATION.

$$Q_{\text{LOSS RAD}} = f A \sigma (T_{\text{HOT}}^4 - T_{\text{COLD}}^4)$$

$$= (0.88)(2066.93 \text{ ft}^2)(.1713 \times 10^{-8} \frac{\text{BTU}}{\text{ft}^2 \text{ hr } ^\circ\text{R}^4}) \{ 1396.4^4 - 519.69^4 \}$$

$$= 1.162 \times 10^7 \frac{\text{BTU}}{\text{hr}}$$

$$= 3.405 \text{ MW}$$

$Q_{\text{LOSS RADIATION}} = 3.41 \text{ MW}$

$$\frac{3.40453}{119.51} \Rightarrow 2.85\%$$

TABLE
Add -I-8 (c)

CONVECTION HEAT LOSS:

- a) Natural Convection
- b) Forced Convection due to Wind
- c) Combined effect of h_{NAT} & h_{FORCED} .

Effective Mean Temperature of Convection Heat Loss } = 894.19 °F = T_{HOT}

Air Temperature = 60 °F = T_{COLD}

} ΔT = (T_H - T_C) = 894.19 - 60

ΔT = 834.19 °F

FOR NATURAL CONVECTION:


$$h_{NAT AIR} = \eta \Delta T^{1/3} \approx 0.15 \Delta T^{1/3}$$

ΔT = 834.19

η ≈ 0.15 @ T̄ ≈ 500 °F

h = 0.15 (834.19)^{1/3} = 1.412

$h_{NAT CONV AIR} \approx 1.412 \frac{BTU}{hr ft^2 OF}$



TREAT RECTANGULAR CROSS-SECTION AS A CYLINDER:

$\sqrt{35 \times 52} = 42.661$

$\frac{35 + 52}{2} = 43.5'$

} → Say D_o ≈ 43 ft.

USE FORCED CONVECTION
CORRELATION FOR CYLINDRICAL
GEOMETRY WITH EFFECTIVE
DIAMETER = 43 ft

FIGURE Add-I-1

See: 272TI000004
 Page 38

FORCED CONVECTION HEAT
 TRANSFER CORRELATION
 Nu_f versus Re_f
 Flow normal to cylinder axis

From: Achenbach,
 Wagner





TABLE Add-I-9 (a)

AIR VELOCITY:

V_0 = GROUND LEVEL VELOCITY

V_{alt} = VELOCITY AT ELEVATION

$H(\text{Tower}) = 125 \text{ meter} = 410 \text{ ft.}$

$V_{alt} = V_0 \left(\frac{H(\text{meter})}{10 \text{ meter}} \right)^{0.15} = V_0 \left(\frac{125}{10} \right)^{0.15} = 1.4606 V_0$

| | | |
|--------------------|---------------|--------------|
| GROUND VELOCITY | At 410 ft. | At 410 ft |
|--------------------|---------------|--------------|

MEAN: 7mph 10.224mph 14.996 FPS = 15 ft/sec = V_{MEAN}

MAXIMUM: 30mph 43.819mph 64.267 = 64 ft/sec = V_{MAX}

| VELOCITIES @ 410ft ALTITUDE: | |
|------------------------------|-------------|
| MEAN: Typical Day | = 15 ft/sec |
| MAXIMUM Operation | = 64 ft/sec |

EVALUATE REYNOLDS NUMBER:

AIR PROPERTIES @ 500°F (Film Temp.)

$\rho = 0.041325 \text{ lbm/ft}^3$

$k = 0.02310 \text{ BTU/hr ft}^\circ\text{F}$

$C_p = 0.2470 \text{ BTU/lbm}^\circ\text{F}$

$\mu = 0.06804 \text{ lbm/ft hr}$

$\nu = 1.64647 \text{ ft}^2/\text{hr}$

$Pr = 0.72752$

REYNOLDS $Re = \frac{V \frac{\text{ft}}{\text{sec}} D_0 \text{ ft} 3600 \frac{\text{sec}}{\text{hr}}}{\nu \text{ ft}^2/\text{hr}} = \frac{V \frac{\text{ft}}{\text{sec}} 43 \text{ ft} 3600 \frac{\text{sec}}{\text{hr}}}{1.64647 \text{ ft}^2/\text{hr}} = 94020 V_{FPS}$

NUSSLETT $Nu = \frac{h D}{k}$ $h = \frac{Nu k \frac{\text{BTU}}{\text{hr ft}^\circ\text{F}}}{D_{FT}} = \frac{.02310}{43} Nu = .000537 Nu$

Use upper roughness curve to account for effect of corners;

See plot of Nu vs. Re.

TABLE Add - I - 9 (b)

| V _{FPS} | Re = 94020V | Nu FROM PLOT (UPPER CLAU) | $h = .000537 Nu$ BTU/hr ft ² °F FORCED | $h = \sqrt{h_{FRCD}^2 + h_{NAT}^2}$ BTU/hr ft ² °F COMB |
|------------------|--------------------|---------------------------------|---|--|
| 15 | 1.41×10^6 | 4400 | 2.363 | 2.753 |
| 64 | 6.02×10^6 | 12000 | 6.444 | 6.597 |

$$h = \sqrt{h_{FRCD}^2 + 1.412^2}$$

$$h_{air(15 FPS)}^{COMBINED} = 2.76 \text{ BTU/hr ft}^2 \text{ °F}$$

$$h_{air(64 FPS)}^{COMBINED} = 6.60 \text{ BTU/hr ft}^2 \text{ °F}$$

$$Q_{LOSS CONV} = h A \Delta T$$

$$\Delta T = 894.19 - 60 = 834.19 \text{ °F}$$

$$A = 2066.93 \text{ ft}^2$$

$$Q_{\frac{BTU}{hr}} = \begin{pmatrix} 2.76 \\ 6.60 \end{pmatrix} (2066.93)(834.19) = \begin{matrix} 4,758,830 \text{ BTU/hr} \\ 11,379,800 \end{matrix} = \begin{cases} 1.394 \text{ MW} \\ 3.334 \text{ MW} \end{cases}$$

| Q CONVECTIVE LOSS | | | | |
|---------------------------------|--------------|-----------------|------------------------------|-------|
| For "MEAN" Typical Day Velocity | 7mph Ground | 15 FPS Altitude | $Q_{LOSS} = 1.39 \text{ MW}$ | 1.17% |
| For "MAX" WIND | 30mph Ground | 64 FPS Altitude | $Q_{LOSS} = 3.34 \text{ MW}$ | 2.79% |


| | | |
|--------------------------|--|--|
| PREPARED BY: <u>EMMM</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>85</u> OF |
| CHECKED BY: | | Addendum to <u>079TI0000002</u> REPORT NO. |
| DATE: | | MODEL NO. |

TABLE Add - I - 10
PANEL HEAT LOSSES:

FOR "REFERENCE" SOLAR FLUX DISTRIBUTION:

$$\text{SODIUM TEMP: } \begin{cases} T_{\text{Na (IN)}} = 610^{\circ}\text{F} \\ T_{\text{Na (OUT)}} = 1050^{\circ}\text{F} \end{cases}$$

TUBES: 0.75" x 0.049" wall : Stainless Steel.

$$Q_{\text{(INCIDENT ON PANEL)}} = 119.51 \text{ MW}$$

$$Q_{\text{LOSS (REFLECTION)}} = 5.98 \text{ MW} \quad 5\% \text{ (Percent of Full Load)}$$

$$Q_{\text{LOSS (RADIATION)}} = 3.41 \text{ MW} \quad 2.85\%$$

$$Q_{\text{LOSS (COMBINED CONV)}} = 1.39 \text{ MW} \quad 1.17\%$$

(Typical Day)



ADD-2 PANEL TEMPERATURE DISTRIBUTION

The temperature distribution is determined for a variety of solar flux and tube orificing conditions. Figure Add-II-1 shows the "reference" solar flux distribution (also see Page 7 of 079TI000002 of March 1983). Figure Add-II-2 shows the "Off-Normal" solar flux distribution. These two patterns are used in the calculations of this section. Furthermore, two orifice conditions have been assumed. No orifices at all, and orifices in Subpanels 1 and 2 such as to cause the sodium flow rate to be distributed in exactly the same proportion as the reference case flux distribution. The orifices are assumed to be such as to result in all tubes discharging the same temperature sodium for the "reference" case and a nonuniform pattern for the "off-normal" case.

Tables Add-II-1 and Add-II-2 deal with the lateral variation of solar flux on the panels for both flux distribution conditions. The "reference" condition distribution is taken as a linear Q/A variation up to the peak Q/A. The "Off-Normal" condition has a parabolic curve fit for the Q/A variation. The Q/L loading is converted to Q/A by assuming the normal distribution curve discussed previously (bell curve, 2 SD upward and downward from mid-height peak). Table Add-II-3 shows the expressions for interpolating the tube wall mid-height ΔT_s for varying Q/A values.

Tables Add-II-4 and Add-II-5 show the $(Q/A)_0$ and tube wall ΔT_s for Subpanels 1 and 2 for both solar flux distributions. Table Add-II-6 shows the set of four cases considered based on flux distribution and orificing. Also shown in Table Add-II-6 is flux and temperature information for Case 1 (reference Flux, Orifices).

In Tables Add-II-7, Add-II-8, and Add-II-9, flux variation and sodium outlet temperatures are shown for Case 2 (reference Flux, No Orifices), Case 3 (Off-Normal Flux, Orifices), and Case 4 (Off-Normal Flux, No Orifices). Figure Add-II-3 shows the sodium outlet temperatures across the panel for the four cases.



Table Add-II-10 shows the TAP program listing for the calculation of the axial distribution of temperature in a particular tube of the panel. The tube wall ΔT s are input, and the two standard deviation normal distribution curve is assumed.

Table Add-II-11 explains the computer data sheets that follow it. The four cases are shown. The solar flux distribution and orifice conditions are indicated.

5370F/sjh

1 x.

PANEL SIZE 1.964m X 12.2m

6.44ft X 40ft

FIGURE "REFERENCE"
Add - II - 1
SOLAR FLUX
DISTRIBUTION

POWER = 119.36 MW INCIDENT





FIGURE
Add-II-2

"OFF-NORMAL" SOLAR FLUX DISTRIBUTION



POWER DISTRIBUTION

ARCO 12 PT. AIM, STRATEGY #3 (11/5/82)

PREPARED BY: EMM
 CHECKED BY:
 DATE:



Rockwell International
 Energy Systems Group


PAGE NO. 90 OF
 Addendum to
 079T1000002
 REPORT NO.

MODEL NO.

TABLE Add - II - 1

REFERENCE SOLAR FLUX

SUB-PANEL 1




$$\left(\frac{Q}{A}\right)_x = .225 + .745 \left(\frac{x}{L}\right) \quad \frac{MW}{m^2}$$

MEAN:

$$\left(\frac{\bar{Q}}{A}\right) = \frac{1}{2} (.225 + .970) = .5975$$

$$\left(\frac{\bar{Q}}{A}\right)_{MEAN} = 0.5975 \frac{MW}{m^2}$$

SUB-PANEL 2



$$\begin{cases} \left(\frac{Q}{A}\right)_x = .97 + .745 \left(\frac{x}{L}\right) & 0 \leq \frac{x}{L} \leq .3087 \\ \left(\frac{Q}{A}\right)_x = 1.20 & \frac{x}{L} \geq .3087 \end{cases} \quad \frac{MW}{m^2}$$

MEAN:

$$\left(\frac{\bar{Q}}{A}\right) = \left(\frac{.230}{.745}\right) \left[\frac{1}{2} (.97 + 1.20)\right] + \left(1 - \frac{.230}{.745}\right) (1.20)$$


$$\left(\frac{\bar{Q}}{A}\right)_x = 1.164496 \frac{MW}{m^2}$$

PREPARED BY: *EMM*
 CHECKED BY:
 DATE:



PAGE NO. 91 OF
 Addendum to
 REPORT NO. 079T10000002
 MODEL NO.

TABLE Add-II-2 (a)
 OFF-NORMAL SOLAR FLUX



LINEAR PORTION:
 $y = 0.20 + (2.32 - 0.20) \frac{x}{L} = 0.20 + 2.12 \left(\frac{x}{L}\right)$


PARABOLIC PORTION:

 $\Delta y = .12 - \left[\left(\frac{x}{L} - .5\right)^2 \left(\frac{.12}{(.5)^2}\right)\right]$
 $\Delta y = .48 \left(.25 - \left(\frac{x}{L} - .5\right)^2\right) = .48 \frac{x}{L} - .48 \left(\frac{x}{L}\right)^2$

COMBINED CURVE:
 $y = \left(\frac{Q}{L}\right) \frac{MW}{ft} = 0.20 + 2.60 \frac{x}{L} - .48 \left(\frac{x}{L}\right)^2$

MEAN: AREA UNDER CURVE:
 (1) $\left[\frac{0.20 + 2.32}{2} \right] + (1) \frac{2}{3} (.12) = 1.26 + .08 = 1.34$
 TRAPEZOID PARABOLA
 OR:
 $\int_0^1 \frac{Q}{L} dx = (1) \int_0^1 \left[.2x + 2.60 \frac{x^2}{2} - .48 \frac{x^3}{3} \right] dx$
 $= .2 + 2.60 \left(\frac{1}{3}\right) - .48 \left(\frac{1}{3}\right) = .2 + 1.30 - .16 = 1.34$

$\left(\frac{\bar{Q}}{L}\right) = 1.34 \frac{MW}{ft \text{ width}}$
 SUBPANEL 1



LINEAR PORTION:
 $y = 2.32 + (2.90 - 2.32) \frac{x}{L} = 2.32 + 1.16 \left(\frac{x}{L}\right)$
 $(0 \leq \frac{x}{L} \leq .5)$

PARABOLIC PORTION:

 $\Delta y = .11 - \left[\left(\frac{x}{L} - .25\right)^2 \left(\frac{.11}{(.25)^2}\right)\right] = .88 \frac{x}{L} - 1.76 \left(\frac{x}{L}\right)^2$
 $(0 \leq \frac{x}{L} \leq .5)$

COMBINED CURVE:
 $y = \left(\frac{Q}{L}\right) \frac{MW}{ft} = 2.32 + 2.04 \frac{x}{L} - 1.76 \left(\frac{x}{L}\right)^2$ $(0 \leq \frac{x}{L} \leq .5)$
 $y = \left(\frac{Q}{L}\right) \frac{MW}{ft} = 2.90$ $(.5 \leq \frac{x}{L} \leq 1.0)$

MEAN: AREA UNDER CURVE:
 $.5(2.90) + .5 \left(\frac{2.32 + 2.90}{2} \right) + .5 \left(\frac{2}{3} \right) (.11)$
 RECTANGLE TRAPEZOID PARABOLA
 1.45 + 1.305 + .036666

$\left(\frac{\bar{Q}}{L}\right) = 2.791667 \frac{MW}{m^2}$
 $\int_0^1 \frac{Q}{L} dx = \int_0^{.5} \left[2.32x + 2.04 \frac{x^2}{2} - 1.76 \frac{x^3}{3} \right] dx + \frac{2.9}{2}$
 $= [1.16 + .255 - .07333] + 1.45$

$\left(\frac{\bar{Q}}{L}\right) = 2.791667 \frac{MW}{ft \text{ width}}$
 SUBPANEL 2

TABLE Add-II-2(b)

$$\frac{Q}{L} \frac{MW}{ft \text{ width}} = \left(\frac{Q}{A}\right)_{\epsilon} \cdot \left(\frac{(Q/A)_{MEAN}}{(Q/A)_{PEAK} \epsilon}\right) \cdot \frac{MW}{m^2} \times .3048^2 \frac{m^2}{ft^2} * 40 \text{ ft}$$

↑
↑

(Q/A)_{MEAN}
Active Height

(Q/A)_{PEAK} ε

$$\left(\frac{Q}{L}\right) \frac{MW}{ft \text{ width}} = \left(\frac{Q}{A}\right)_{\epsilon} (.5981441) (.3048)^2 (40) = 2.2227762 = \frac{1}{.44988785}$$


$$\left(\frac{Q}{A}\right)_{\epsilon} \frac{MW}{m^2} = 0.449888 \left(\frac{Q}{L}\right) \frac{MW}{ft}$$

THUS: TO ESTIMATE $\left(\frac{Q}{A}\right)_{\epsilon} \frac{MW}{m^2}$ FOR THESE CASES BASED ON $\left(\frac{Q}{L}\right) \frac{MW}{ft \text{ width}}$,

USE THE FORMULA :

$$\left(\frac{Q}{A}\right)_{\epsilon} \frac{MW}{m^2} = 0.44989 \left(\frac{Q}{L}\right) \frac{MW}{ft \text{ width}}$$

| SUB. PANEL 1 | | | SUB. PANEL 2 | | |
|--------------|---|--|--------------|---|--|
| X/L | $\frac{Q}{L} \frac{MW}{ft}$ $.20 + 2.6 \frac{X}{L} - .48 \left(\frac{X}{L}\right)^2$ | $\left(\frac{Q}{A}\right)_{\epsilon} \frac{MW}{m^2}$.44989 (Q/L) | X/L | $\frac{Q}{L} \frac{MW}{ft}$ $\begin{cases} 2.32 + 2.04 \frac{X}{L} - 1.76 \left(\frac{X}{L}\right)^2 \\ 0 \leq \frac{X}{L} \leq 0.5 \\ 2.90 \text{ for } \frac{X}{L} > .5 \end{cases}$ | $\left(\frac{Q}{A}\right)_{\epsilon} \frac{MW}{m^2}$.44989 (Q/L) |
| 0.05 | .3288 | .147923 | .05 | 2.4176 | 1.087649 |
| 0.15 | .5792 | .260575 | .15 | 2.5864 | 1.163590 |
| 0.25 | .8200 | .368903 | .25 | 2.7200 | 1.223695 |
| 0.35 | 1.0512 | .472922 | .35 | 2.8184 | 1.267964 |
| 0.45 | 1.2728 | .572617 | .45 | 2.8816 | 1.296397 |
| 0.55 | 1.4848 | .667993 | .50+ | 2.90 | 1.304675 |
| 0.65 | 1.6872 | .759051 | .75 | | |
| 0.75 | 1.8800 | .845789 | 1.0 | | |
| 0.85 | 2.0632 | .928209 | | | |
| 0.95 | 2.2368 | 1.006309 | | | |
| 0.0 | .20 | 0.089976 | 0 | 2.32 | 1.043740 |
| 0.25 | .82 | 0.368908 | .125 | 2.5472 | 1.145954 |
| 0.50 | 1.38 | 0.620845 | .25 | 2.72 | 1.223695 |
| 0.75 | 1.88 | 0.845789 | .375 | 2.8375 | 1.276557 |
| 1.0 | 2.32 | 1.043740 | .50 | 2.90 | 1.304675 |
| | | | 1.0 | 2.90 | 1.304675 |



| TABLE Add - II - 3 INTERPOLATION OF TUBE WALL MID-HEIGHT ΔT 's: | | | | |
|---|--------------------------------------|--|--|--|
| $\frac{Q}{A} \rightarrow \delta$: RANGE: $\Delta T \downarrow$ | $0 \rightarrow 0.225 \frac{MW}{m^2}$ | $0.225 \rightarrow 0.970 \frac{MW}{m^2}$ | $0.970 \rightarrow 1.20$ AND ABOVE $\frac{MW}{m^2}$ | |
| A0021 $(T_{MET} - T_{No}) \downarrow$ | A21 = 9.94 $\frac{Q}{.225}$ | A21 = 9.94 + (35.16 - 9.94) $\left(\frac{Q - .225}{.745}\right)$ (25.22) (.970 - .225) | A21 = 35.16 + (41.74 - 35.16) $\left(\frac{Q - .97}{.23}\right)$ (1.20 - .97) | |
| A0022 $(\Delta T_1) \downarrow$ | A22 = 33.133 $\frac{Q}{.225}$ | A22 = 33.133 + (117.57 - 33.133) $\left(\frac{Q - .225}{.745}\right)$ (84.437) | A22 = 117.57 + (139.66 - 117.57) $\left(\frac{Q - .97}{.23}\right)$ | |
| A0023 $(T_{PEAK} - T_{No}) \downarrow$ | A23 = 43.17 $\frac{Q}{.225}$ | A23 = 43.17 + (160.50 - 43.17) $\left(\frac{Q - .225}{.745}\right)$ (117.33) | A23 = 160.50 + (192.50 - 160.50) $\left(\frac{Q - .97}{.23}\right)$ | |
| A0024 $(T_{PEAK} - T_{MET}) \downarrow$ | A24 = 33.23 $\frac{Q}{.225}$ | A24 = 33.23 + (125.34 - 33.23) $\left(\frac{Q - .225}{.745}\right)$ (92.11) | A24 = 125.34 + (150.76 - 125.34) $\left(\frac{Q - .97}{.23}\right)$ | |
| A0025 $(\Delta T_2) \downarrow$ | A25 = 16.662 $\frac{Q}{.225}$ | A25 = 16.662 + (66.558 - 16.662) $\left(\frac{Q - .225}{.745}\right)$ (49.896) | A25 = 66.558 + (80.96 - 66.558) $\left(\frac{Q - .97}{.23}\right)$ | |

BASED ON INTERPOLATION OF TUBE WALL ΔT 's
 OF 079TI000002, Page 37


| | | |
|-------------------------|--|---|
| PREPARED BY: <u>EMM</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>94</u> OF |
| CHECKED BY: | | Addendum to 079T10000002 REPORT NO. |
| DATE: | | MODEL NO. |

TABLE Add-II-4

REFERENCE FLUX DISTRIBUTION:

(Q/A) & ΔT TUBE WALL ΔT 's

REFERENCE FLUX DISTRIBUTION

| MAP STATION | LOCATION | | (Q/A) | A0021 | A0022 | A0023 | A0024 | A0025 |
|----------------|----------|---------------------|--------------|---------------------------------|--------------|--------------------------------|--------------------------------|--------------|
| | PANEL | %L | | $(T_{MET} - T_{WA}) \Delta T_1$ | ΔT_1 | $(T_{PH} - T_{WA}) \Delta T_2$ | $(T_{PH} - T_{MT}) \Delta T_2$ | ΔT_2 |
| | 1 | 0 | <u>0.225</u> | 9.94 | 33.133 | 43.17 | 33.23 | 16.662 |
| * | 1 | .05 | .26225 | 11.201 | 37.35485 | 49.0365 | 37.8355 | 19.1568 |
| * | 1 | .15 | .33675 | 13.723 | 45.79855 | 60.7695 | 47.0465 | 24.1464 |
| * | 1 | .25 | .41125 | 16.245 | 54.24225 | 72.5025 | 56.2575 | 29.136 |
| * | 1 | .35 | .48575 | 18.767 | 62.68595 | 84.2355 | 65.4685 | 34.1256 |
| * | 1 | .45 | .56025 | 21.289 | 71.12965 | 95.9685 | 74.6795 | 39.1152 |
| * | 1 | .55 | .63475 | 23.811 | 79.57335 | 107.7015 | 83.8905 | 44.1048 |
| * | 1 | .65 | .70925 | 26.333 | 88.01705 | 119.4345 | 93.1015 | 49.0944 |
| * | 1 | .75 | .78375 | 28.855 | 96.46075 | 131.1675 | 102.3125 | 54.084 |
| * | 1 | .85 | .85825 | 31.377 | 104.90445 | 142.9005 | 111.5235 | 59.0736 |
| * | 1 | .95 | .93275 | 33.899 | 113.34815 | 154.6335 | 120.7345 | 64.0632 |
| | 1 | 1.00 | <u>0.970</u> | 35.16 | 117.57 | 160.50 | 125.34 | 66.558 |
| | 2 | 0 | <u>0.970</u> | 35.16 | 117.57 | 160.50 | 125.34 | 66.558 |
| * | 2 | .05 | 1.00725 | 36.22567 | 121.14762 | 165.68261 | 129.45693 | 68.89050 |
| * | 2 | .15 | 1.08175 | 38.35702 | 128.30286 | 176.04783 | 137.69080 | 73.55549 |
| * | 2 | .25 | 1.15625 | 40.48837 | 135.45810 | 186.413 | 145.92467 | 78.22050 |
| * | 2 | $\frac{.33}{.25} +$ | <u>1.20</u> | 41.74 | 139.66 | 192.50 | 150.76 | 80.96 |


| | | |
|--------------------------|---|---|
| PREPARED BY: <u>EMMM</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>95</u> OF |
| CHECKED BY: | | Addendum to <u>079TI000002</u> REPORT NO. |
| DATE: | | MODEL NO. |

TABLE Add -II-5
OFF-NORMAL DISTRIBUTION:
 $(Q/A)_{\epsilon}$ & ϵ TUBE WALL ΔT 'S.

$$\left(\frac{Q}{A}\right)_{\epsilon} \frac{MW}{m^2} = 0.449888 \left(\frac{Q}{F}\right) \frac{MW}{ft \text{ width}}$$

"OFF NORMAL FLUX DISTRIBUTION"

| S M A P | LOCATION | (Q/L) | (Q/A) ₀ | A0021 | A0022 | A0023 | A0024 | A0025 |
|------------------|-------------|------------------------|--------------------|---------------------------------------|-------------------------|--------------------------------|--------------------------------------|-------------------------|
| | PANEL x/L | MW/ft _{width} | MW/m ² | $(\bar{T}_{MET} - T_{MO})_{\epsilon}$ | ΔT_1_{ϵ} | $(T_{PH} - T_{MO})_{\epsilon}$ | $(T_{PH} - \bar{T}_{M1})_{\epsilon}$ | ΔT_2_{ϵ} |
| | 1 0 | 0.20 | 0.089976 | 3.9749 | 13.250 | 17.263 | 13.288 | 6.6630 |
| * | 1 .05 | 0.3288 | .147923 | 6.5349 | 21.783 | 28.381 | 21.897 | 10.954 |
| * | 1 .15 | 0.5792 | .260575 | 11.1443 | 37.1650 | 48.7727 | 37.6284 | 19.0446 |
| * | 1 .25 | 0.8200 | .368908 | 14.8116 | 49.4433 | 65.8341 | 51.0224 | 26.3002 |
| * | 1 .35 | 1.0512 | .472922 | 18.3327 | 61.2321 | 82.2152 | 63.8825 | 33.26646 |
| * | 1 .45 | 1.2728 | .572617 | 21.7076 | 72.5313 | 97.9162 | 76.2086 | 39.94349 |
| * | 1 .55 | 1.4848 | .667993 | 24.9364 | 83.3411 | 112.937 | 88.0006 | 46.3313 |
| * | 1 .65 | 1.6872 | .759051 | 28.0189 | 93.6614 | 127.278 | 99.2587 | 52.4298 |
| * | 1 .75 | 1.8800 | .845789 | 30.9552 | 103.492 | 140.938 | 109.983 | 58.2390 |
| * | 1 .85 | 2.0632 | .928209 | 33.7453 | 112.833 | 153.918 | 120.173 | 63.7590 |
| * | 1 .95 | 2.2368 | 1.006309 | 36.1988 | 121.057 | 165.552 | 129.353 | 68.8316 |
| | 1 1.00 | 2.32 | 1.043740 | 37.2696 | 124.652 | 170.759 | 133.490 | 71.1754 |
| | 2 0 | 2.32 | 1.043740 | 37.2696 | 124.652 | 170.759 | 133.490 | 71.1754 |
| * | 2 .05 | 2.4176 | 1.087649 | 38.5258 | 128.8694 | 176.869 | 138.343 | 73.9249 |
| * | 2 .15 | 2.5864 | 1.163590 | 40.69836 | 136.163 | 187.434 | 146.736 | 78.6801 |
| * | 2 .25 | 2.7200 | 1.223695 | 42.4179 | 141.936 | 195.7967 | 153.379 | 82.4437 |
| * | 2 .35 | 2.8184 | 1.267964 | 43.6844 | 146.187 | 201.9558 | 158.271 | 85.2157 |
| * | 2 .45 | 2.8816 | 1.296397 | 44.4978 | 148.918 | 205.912 | 161.414 | 86.9961 |
| * | 2 .55+ | 2.90 | 1.304675 | 44.7346 | 149.713 | 207.063 | 162.329 | 87.51446 |

TABLE Add - II - 6

CASES TO CONSIDER:

$$T_{Na, IN} = 610^{\circ}F$$

| | ORIFICIED TUBES (FOR REFERENCE FLUX DIST) | NO ORIFICES |
|-----------------------------------|--|---|
| REFERENCE SOLAR FLUX DISTRIBUTION | <u>CASE 1</u> ① REF (Q/A); ORIFICIED $T_{Na, OUT} = 1050^{\circ}F$ | <u>CASE 2</u> ② REF (Q/A); NO ORIFICES $T_{Na, OUT} (Max) = 1100^{\circ}F$ |
| OFF-NORMAL FLUX DISTRIBUTION | <u>CASE 3</u> ③ OFF NORMAL Q/A ORIFICIED (FOR REF FLUX) $T_{Na, OUT} = 1050^{\circ}F$ | <u>CASE 4</u> ④ OFF NORMAL Q/A NO ORIFICES $T_{Na, OUT} (Max) = 1100^{\circ}F$ |

CASE 1 REFERENCE SOLAR FLUX DISTRIBUTION
ORIFICIED FOR $T_{Na, OUT} = 1050^{\circ}F$.

$$ALL TUBES: \begin{cases} T_{IN, Na} = 610^{\circ}F \\ T_{OUT, Na} = 1050^{\circ}F \end{cases}$$

ORIFICES TO BE DESIGNED SUCH THAT FOR REFERENCE SOLAR FLUX, ALL TUBES DISCHARGE AT $T_{Na} = 1050^{\circ}F$. THUS, SODIUM FLOW RATE IN EACH INDIVIDUAL TUBE OF A SUB-PANEL IS PROPORTIONAL TO TOTAL SOLAR ENERGY INCIDENT ON TUBE (hence $(\frac{Q}{A})_E$).

SUB-PANEL 1

$$\left(\frac{Q}{A}\right)_E = 0.225 + (.970 - .225)\left(\frac{x}{L}\right)$$

$$\left\{ \left(\frac{Q}{A}\right)_E = 0.225 + 0.745\left(\frac{x}{L}\right) \right. \quad \frac{MW}{m^2}$$


SUB-PANEL 2

$$\left(\frac{Q}{A}\right)_E = 0.97 + (1.20 - .97) \frac{\left(\frac{x}{L}\right)}{\frac{1.20 - .97}{.97 - .225}} =$$

$$\left\{ \left(\frac{Q}{A}\right)_E = 0.97 + 0.745\left(\frac{x}{L}\right) : \quad For \quad 0 \leq \frac{x}{L} \leq \frac{.230}{.745} = .3087 \right.$$

$$\left. \left(\frac{Q}{A}\right)_E = 1.20 \quad For \quad \frac{x}{L} \geq \frac{.230}{.745} = .3087 \right.$$


PREPARED BY: Emm
 CHECKED BY:
 DATE:



PAGE NO. 97 OF
 Addendum to
079T1000002
 REPORT NO.
 MODEL NO.


CASE 2 TABLE Add -II-7
REFERENCE SOLAR FLUX DISTRIBUTION
NO ORIFICES:

$T_{IN} = 610^{\circ}F$ $T_{OUT} (MAX) = 1100^{\circ}F$
 N_a N_a



$T_{Na, OUT} \left(\frac{X}{L} \right) = 610 + (1100 - 610) \left(\frac{Q/A}{.970} \right)$
 BUT $\frac{Q}{A} = .225 + .745 \left(\frac{X}{L} \right)$

$T_{Na, OUT} \left(\frac{X}{L} \right) = 610 + \frac{490}{.970} \left(.225 + .745 \frac{X}{L} \right)$



$T_{Na, OUT} = 610 + 490 \left(\frac{Q/A}{1.20} \right)$
 BUT $\begin{cases} Q/A = .97 + .745 \left(\frac{X}{L} \right) & \text{for } \frac{X}{L} \leq .3087 \\ Q/A = 1.20 & \text{for } \frac{X}{L} \geq .3087 \end{cases}$
 $\begin{cases} T_{Na, OUT} = 610 + 490 \left(\frac{.97 + .745 \frac{X}{L}}{1.20} \right) & \text{for } \frac{X}{L} \leq .3087 \\ T_{Na, OUT} = 1100^{\circ}F & \text{for } \frac{X}{L} \geq .3087 \end{cases}$

SUB-PANEL 1

| $\left(\frac{X}{L} \right)$ | $T_{Na, OUT}$ |
|------------------------------|---------------|
| 0 | 723.660 |
| .05 | 742.48 |
| .15 | 780.11 |
| .25 | 817.74 |
| .35 | 855.38 |
| .45 | 893.01 |
| .55 | 930.65 |
| .65 | 968.28 |
| .75 | 1005.91 |
| .85 | 1043.55 |
| .95 | 1081.18 |
| 1.0 | 1100.0 |

SUB-PANEL 2

| $\frac{X}{L}$ | $T_{Na, OUT}$ |
|-----------------------------|---------------|
| 0 | 1006.08 |
| .05 | 1021.29 |
| .15 | 1051.71 |
| .25 | 1082.14 |
| $\frac{.230}{.745} = .3087$ | 1100.0 |
| AND MORE | ↓ |
| 1.0 | 1100.0 |

TABLE Add-II-8 (a)
CASE 3 OFF NORMAL SOLAR FLUX DISTRIBUTION
ORIFICES AS DESIGNED FOR REFERENCE FLUX CASE

$T_{IN} = 610^{\circ}F$ $\bar{T}_{OUT} = 1050^{\circ}F$ $\bar{ST} = 440^{\circ}$
 N_a N_a N_a
 MEAN MEAN

SUB-PANEL 1

$$T_{OUT} \left(\frac{x}{L} \right) = 610 + 440 \left(\frac{\frac{(Q/L)(x/L)}{(Q/L)_{MEAN}} \left(\frac{Q/A}{(Q/A)_{MEAN}} \right)}{\frac{(Q/A)(x/L)}{(Q/A)_{MEAN}}} \right)$$

NOTE: $(Q/A)_d$ is proportional to flow.
REF

$$\frac{Q}{L} \left(\frac{x}{L} \right) = 0.20 + 2.6 \left(\frac{x}{L} \right) - .48 \left(\frac{x}{L} \right)^2 \quad \text{MW/FT} \quad \text{OFF-NORMAL}$$

$$\frac{Q}{L} (\text{MEAN}) = 1.34 \quad \text{MW/FT} \quad \text{OFF-NORMAL}$$

$$\frac{Q}{A} \left(\frac{x}{L} \right) = .225 + .745 \left(\frac{x}{L} \right) \quad \text{MW/m}^2 \quad \text{REF}$$

$$\frac{Q}{A} (\text{MEAN}) = .5975 \quad \text{MW/m}^2 \quad \text{REF}$$

$$T_{OUT} \left(\frac{x}{L} \right) = 610 + 440 \left(\frac{\frac{.20 + 2.6 \left(\frac{x}{L} \right) - .48 \left(\frac{x}{L} \right)^2}{1.34}}{\frac{.225 + .745 \left(\frac{x}{L} \right)}{.5975}} \right) = 610 + 440 \left(\frac{.5975}{1.34} \right) \left(\frac{.20 + 2.6 \left(\frac{x}{L} \right) - .48 \left(\frac{x}{L} \right)}{.225 + .745 \left(\frac{x}{L} \right)} \right)$$

SUB-PANEL 1

| $\frac{x}{L}$ | $T_{Na, OUT}$ | $\frac{Q/A}{\text{(Proportional to } \dot{w})}$ | $\dot{w} T$ $(Q/A * T_{Na, OUT})$ |
|---------------|---------------|---|--------------------------------------|
| 0 | 784.39 | --- | --- |
| .05 | 855.98 | .26225 | 224.4811 |
| .15 | 947.45 | .33675 | 319.0531 |
| .25 | 1001.20 | .41125 | 411.7416 |
| .35 | 1034.58 | .48575 | 502.5467 |
| .45 | 1055.72 | .56025 | 591.4683 |
| .55 | 1068.93 | .63475 | 678.5064 |
| .65 | 1076.72 | .70925 | 763.6611 |
| .75 | 1080.62 | .78375 | 846.9322 |
| .85 | 1081.64 | .85825 | 928.3200 |
| .95 | 1080.49 | .93275 | 1007.8243 |
| 1.0 | 1079.25 | --- | --- |
| | | $\Sigma = 5.975$ | $\Sigma = 6274.5348$ |

$$\bar{T} = \frac{\sum \dot{w} T}{\sum \dot{w}}$$

$$\bar{T}_{Na, OUT} = \frac{6274.5348}{5.975} = 1050.131^{\circ}$$

(Should be 1050°F)

TABLE Acd - II-8 (b)
CASE 3 CON'T OFF NORMAL SOLAR FLUX DISTRIBUTION
 ORIFICES AS DESIGNED FOR REF FLUX CASE

SUB-PANEL 2

$T_{Na IN} = 610^\circ$ $T_{Na OUT MEAN} = 1050^\circ$

$$T_{OUT Na} \left(\frac{x}{L} \right) = 610 + 440 \left(\frac{\frac{(Q/L)(x/L)}{(Q/L)_{MEAN}} \left(\frac{Q}{A} \right)_{REF}}{\frac{(Q/A)(x/L)}{(Q/A)_{MEAN}} \left(\frac{Q}{A} \right)_{REF}} \right)$$


NOTE: $\left(\frac{Q/A}{REF} \right)_x$ is proportional to flow

$$\left\{ \begin{array}{l} \frac{Q}{L} \left(\frac{x}{L} \right) = 2.32 + 2.04 \left(\frac{x}{L} \right) - 1.76 \left(\frac{x}{L} \right)^2 \quad 0 \leq \frac{x}{L} \leq 0.5 \\ \frac{Q}{L} \left(\frac{x}{L} \right) = 2.90 \quad \frac{x}{L} \geq 0.5 \end{array} \right\} \text{OFF-NORMAL}$$

$$\left\{ \begin{array}{l} \frac{Q}{L} (\text{MEAN}) = 2.791667 \end{array} \right\} \text{OFF-NORMAL}$$

$$\left\{ \begin{array}{l} \frac{Q}{A} \left(\frac{x}{L} \right) = .97 + .745 \frac{x}{L} \quad 0 \leq \frac{x}{L} \leq 0.3087 = \frac{.230}{.745} \\ \frac{Q}{A} \left(\frac{x}{L} \right) = 1.20 \quad \frac{x}{L} \geq .3087 \end{array} \right\} \text{REFERENCE}$$

$$\left\{ \begin{array}{l} \frac{Q}{A} (\text{MEAN}) = 1.1644966 \quad \text{REF} \end{array} \right.$$



$$\frac{.230}{.745} \left(\frac{.97 + 1.20}{2} \right) + \left(1 - \frac{.230}{.745} \right) (1.20) = 1.16449664 = \frac{Q}{A} (\text{MEAN})$$

$$T_{OUT Na} \left(\frac{x}{L} \right) = 610 + 440 \left(\frac{\frac{Q/L(x/L)}{2.791667}}{\frac{Q/A(x/L)}{1.1644966}} \right) = \dots$$

$$T_{OUT Na} = 610 + 440 \left(\frac{1.1644966}{2.791667} \right) \left(\frac{Q/L(x/L)}{Q/A(x/L)} \right) = \dots$$

SUB-PANEL 2


| X/L | Q/L | Q/A REF Proportional to \dot{w} | T _{Na} OUT | $\dot{w} T$ (Q/A * T _{Na} OUT) |
|---------|------------|---|------------------------|---|
| (0) | (2.32) | (0.97) | (1048.98) | |
| .05 | 2.4176 | 1.00725 | 1050.529 | 1058.145 |
| .15 | 2.5864 | 1.08175 | 1048.830 | 1134.572 |
| .25 | 2.7200 | 1.15625 | 1041.762 | 1204.537 |
| (.3087) | (2.782051) | (1.20) | (1035.5114) | |
| .35 | 2.8184 | 1.20 | 1041.071 | 1249.285 |
| (.50) | (2.8816) | (1.20) | (1050.737) | (1260.885) |
| .55 | (2.90) | (1.20) | (1053.552) | (1264.262) |
| .65 | 2.90 | 1.20 | " | " |
| .75 | 2.90 | 1.20 | " | " |
| .85 | 2.90 | 1.20 | " | " |
| .95 | 2.90 | 1.20 | " | " |
| 1.0 | (2.90) | (1.20) | 1053.552 | |
| | | $\Sigma = 11.64525$ Exclude () | | $\Sigma = 12228.734$ Exclude () |

$$\bar{T} = \frac{\Sigma \dot{w} T}{\Sigma \dot{w}}$$


$$T_{Na OUT} = \frac{12228.734}{11.64525} = 1050.105^\circ$$

(Should be 1050°F)

| CASE 3, CON'T | | | | SUB-PANEL 2 | | | | TABLE Add - II - 8 (C) | | | |
|---------------|---------------|---------------|----------------|--------------------|---------------|---------------|------------------|------------------------|---------------|---------------|----------------|
| $\frac{X}{L}$ | $\frac{Q}{L}$ | $\frac{Q}{A}$ | $T_{Na_{OUT}}$ | $\frac{X}{L}$ | $\frac{Q}{L}$ | $\frac{Q}{A}$ | $T_{Na_{OUT}}$ | $\frac{X}{L}$ | $\frac{Q}{L}$ | $\frac{Q}{A}$ | $T_{Na_{OUT}}$ |
| 0 | 2.32 | 0.97 | 1048.98 | .19 | 2.64406 | 1.11155 | 1046.59 | .37 | 2.83386 | 1.20 | 1043.44 |
| .01 | 2.34022 | .97745 | 1049.43 | .20 | 2.6576 | 1.119 | 1045.90 | .38 | 2.84106 | " | 1044.54 |
| .02 | 2.36010 | .9849 | 1049.81 | .21 | 2.67078 | 1.12645 | 1045.17 | .39 | 2.84790 | " | 1045.58 |
| .03 | 2.37962 | .99235 | 1050.12 | .22 | 2.68362 | 1.1339 | 1044.38 | .40 | 2.8544 | " | 1046.58 |
| .04 | 2.39878 | .9998 | 1050.36 | .23 | 2.69610 | 1.14135 | 1043.56 | .41 | 2.86054 | " | 1047.52 |
| .05 | 2.4176 | 1.00725 | 1050.53 | .24 | 2.708224 | 1.1488 | 1042.68 | .42 | 2.86634 | " | 1048.40 |
| .06 | 2.43606 | 1.0147 | 1050.63 | .25 | 2.72 | 1.15625 | 1041.76 | .43 | 2.871776 | " | 1049.24 |
| .07 | 2.45418 | 1.02215 | 1050.675 | .26 | 2.7342 | 1.1637 | 1040.80 | .44 | 2.87686 | " | 1050.01 |
| .08 | 2.47194 | 1.0296 | 1050.65 | .27 | 2.7425 | 1.17115 | 1039.79 | .45 | 2.8816 | " | 1050.74 |
| .09 | 2.48939 | 1.03705 | 1050.57 | .28 | 2.75322 | 1.1787 | 1038.75 | .46 | 2.88598 | " | 1051.41 |
| .10 | 2.5064 | 1.0445 | 1050.42 | .29 | 2.7636 | 1.1861 | 1037.66 | .47 | 2.89002 | " | 1052.03 |
| .11 | | | | .30 | 2.7736 | 1.1935 | 1036.53 | .48 | 2.89370 | " | 1052.59 |
| .12 | 2.53946 | 1.0594 | 1049.96 | $\frac{.30}{.745}$ | 2.78205 | 1.20 | 1035.51 (Min) | .49 | 2.89702 | " | 1053.11 |
| .13 | | | | .31 | 2.78326 | 1.20 | 1035.70 | .50 | 2.90 | " | 1053.55 |
| .14 | 2.571104 | 1.0743 | 1049.26 | .32 | 2.79258 | " | 1037.12 | ↓ | ↓ | ↓ | ↓ |
| .15 | 2.5804 | 1.08175 | 1048.83 | .33 | 2.80154 | " | 1038.49 | ↓ | ↓ | ↓ | ↓ |
| .16 | 2.60139 | 1.0892 | 1048.35 | .34 | 2.81014 | " | 1039.81 | ↓ | ↓ | ↓ | ↓ |
| .17 | 2.61594 | 1.09665 | 1047.81 | .35 | 2.8184 | " | 1041.07 | 1.0 | 2.90 | 1.20 | 1053.552 |
| .18 | 2.63018 | 1.1041 | 1047.22 | .36 | 2.8263 | " | 1042.28 | | | | |



PREPARED BY: EMM
 CHECKED BY:
 DATE:



PAGE NO. 101 OF
 Addendum to
079I10000002
 REPORT NO.
 MODEL NO.

CASE 4 TABLE Add - II-9
OFF NORMAL SOLAR FLUX DISTRIBUTION
NO ORIFICES

$T_{IN} = 610^{\circ}F$ $T_{OUT} = 1100^{\circ}F$
 Na Na
 Max

SUB-PANEL 1

SUB-PANEL 2

$Q/L = 0.20 + 2.60\left(\frac{x}{L}\right) - .48\left(\frac{x}{L}\right)^2$
 $T_{Na_{OUT}} = 610 + 490\left(\frac{Q/L}{2.32}\right)$
 $T_{Na_{OUT}} = 610 + \frac{490}{2.32} \left(.20 + 2.6\frac{x}{L} - .48\left(\frac{x}{L}\right)^2 \right)$

$Q/L = 2.32 + 2.04\frac{x}{L} - 1.76\left(\frac{x}{L}\right)^2$
 For $0 \leq \frac{x}{L} \leq .5$
 $Q/L = 2.90$ For $\frac{x}{L} \geq .5$
 $T_{Na_{OUT}} = 610 + \frac{490}{2.90} \left(\frac{Q}{L}\right)$

| $\frac{x}{L}$ | $T_{Na_{OUT}}$ |
|---------------|----------------|
| 0 | 652.24 |
| .05 | 679.44 |
| .15 | 732.33 |
| .25 | 783.19 |
| .35 | 832.02 |
| .45 | 878.82 |
| .55 | 923.60 |
| .65 | 966.35 |
| .75 | 1007.07 |
| .85 | 1045.76 |
| .95 | 1082.43 |
| 1.0 | 1100.0 |

| $\frac{x}{L}$ | $T_{Na_{OUT}}$ |
|---------------|----------------|
| 0 | 1002.00 |
| .05 | 1018.49 |
| .15 | 1047.01 |
| .25 | 1069.59 |
| .35 | 1080.07 |
| .35 | 1086.21 |
| .45 | 1096.89 |
| .50+ | 1100.00 |
| ↓ | ↓ |
| 1.0 | 1100.00 |

FIGURE
Acd-II-3

SODIUM OUTLET TEMPERATURE

$$T_{IN}^{Na} = 610^{\circ}F$$







TABLE Add-II-10(a) PANEL TEMP DISTRIB LISTING

00000010

*** STAR 001 - TITLES & STORED COMMENTS

E M MOURACIAN EXT 3320 LB30
 678901234567890

TAP-4S SUPER TAP
 6903-(AB) (500K)

1

TO DETERMINE TEMPERATURE DISTRIBUTION ON PANEL, BASED ON:
 NORMAL DISTRIBUTION AXIALLY: (S.D.=+2).

SODIUM INLET & OUTLET TEMPERATURES ACC01 & A0002
 MID HEIGHT VALUES OF:
 (T:BAR MET - T:NA) A0021
 (DT 1) A0022
 (T:PEAK - T:NA) A0023
 (T:PEAK - T:BAR MET) A0024
 (DT 2) A0025

INPUT VALUES ARE:

A0001 = T(NA:INLET)
 A0002 = T(NA:OUTLET)
 A0021 = ((T:BAR METAL) - (T:NA)) CL (AZ=20FT)
 A0022 = (DELTA T 1) CL (AZ=20FT)
 A0023 = ((T:PEAK) - (T:NA)) CL (AZ=20FT)
 A0024 = ((T:PEAK) - (T:BAR METAL)) CL (AZ=20FT)
 A0025 = (DELTA T 2) CL (AZ=20FT)

DETERMINE SODIUM TEMPERATURE RISE:

ACC01 = DT:NA = T:NA(OUT) - T:NA(IN) = A0002 - A0001

DETERMINE T:NA(Z):

T:NA(Z) = T:NA(IN) + FRAC(Z)*DT:NA
 N(Z) = ACC01 + F(Z)*A0011

DETERMINE T:NA(AXIAL MEAN)

T:NA(BAR) = (1/80)*(N0+N40) + (1/40)*(SUM N1 THRU N39)
 N1C1 = (1/2)*(N0000 + A0040)
 N1C2 = (SUM N0001 THRU N0039)
 N1C0 = (.025)*(N0101+N0102)

DETERMINE T:METAL(BAR)(Z) . . . MEAN METAL TEMPERATURE (Z)
 (CIRCUMFERENTIAL & RADIAL MEAN)

T:MET(BAR)(Z) = T:NA(Z) + (NORM FACTOR)*(T:BR:M - T:NA)CL
 M(Z) = N(Z) + C(Z)*A0021

DETERMINE AXIALLY AVERAGED METAL TEMPERATURE:

(CIRCUM & RADIAL & AXIAL MEAN)

T:METAL(BAR, BAR) = T:NA(BAR) + .59814*(T:BR:M - T:NA)CL
 M0100 = N0100 + .59814*A0021

T:METAL(BAR, BAR) = (1/80)*(M0+M40) + (1/40)*(SUM M1 THRU M39)
 M201 = (1/2)*(M0 + M40)
 M202 = (SUM M1 THRU M39)

M200 = (.025)*(M201+M202)

DETERMINE DELTA T 1 (Z)

DT1(Z) = (NORM FACTOR)*(DT1)CL
 D(Z) = C(Z)*A0022

DETERMINE DELTA T 2 (Z)

DT2(Z) = (NORM FACTOR)*(DT2)CL
 E(Z) = C(Z)*A0025

DETERMINE T:FRONT(Z) & T:BACK(Z)

(1/2)*DT1(Z) = D0100 THRU D0140
 T:FRONT(Z) = T:MET + (1/2)DT1
 G(Z) = M(Z) + D(100+Z)
 T:BACK(Z) = T:MET - (1/2)DT1
 H(Z) = M(Z) - D(100+Z)

DETERMINE PEAK METAL TEMP (Z)

T:PEAK(Z) = T:NA(Z) + (NORM FACT)*(T:PK-T:NA)CL
 P(Z) = N(Z) + C(Z)*A0023

DETERMINE: (T:PK(Z) - T:MET(Z)) (Z)

(T:P-T:M)(Z) = (NORM FACT) * (DT:PK-MET)CL
 R(Z) = C(Z) * ACC24
 (T:P-T:M)(Z) = (1/2)DT1(Z) + DT2(Z)
 R(100+Z) = D(100+Z) + E(Z)
 (T:P-T:M)(Z) = T:PK(Z) - T:M(Z)
 R(200+Z) = P(Z) - M(Z)

DUMMIES:

A0001 = T:NA INLET
 A0002 = T:NA OUTLET
 A0011 = DT:NA (OUT-IN) = A2 - A1
 A0021 = (T:BR METAL - T:NA) CL
 A0022 = (DT:1) CL
 A0023 = (T:PEAK - T:NA) CL
 A0024 = (T:PEAK - T:BR METAL) CL
 A0025 = (DT:2) CL
 C0000 - C0040 = DT(1) (Z)

00001000
 00001010
 00001050
 00001100
 00001120
 00001150
 00012001
 C0012501
 00013001
 C0014201
 00014210
 00014220
 00014230
 00014240
 00014250
 00029999
 00030000
 00030010
 00030020
 00030210
 00030220
 00030230
 00030240
 00030250
 00031000
 00031010
 00031110
 00031120
 00031130
 00031210
 00031220
 00031230
 00031240
 00031250
 00032000
 C0032010
 00032020
 00032030
 00032110
 00032120
 00032130
 00032140
 00032150
 00032160
 00032170
 00032180
 00033000
 00033010
 00033020
 00034000
 00034010
 00034020
 00035000
 00035010
 00035020
 00035030
 00035040
 00035050
 00036000
 00036010
 00036020
 00037000
 00037110
 00037120
 00037210
 00037220
 00037310
 00037320
 00199999
 00200000
 00210010
 00210020
 00210110
 00210210
 00210220
 00210230
 00210240
 00210250
 00240010

TABLE Add - II - 10(b)

| | | |
|---|--------|----------|
| 00100 - 00140 = DT(1)/2 | (Z) | 00240100 |
| E0000 - E0040 = GT(2) | (Z) | 00250010 |
| F0000 - F0040 = FRACTION OF EFFECTIVE ENERGY ABSORBED | | 00260011 |
| FRGM 2=0 TO Z. | (Z) | 00260012 |
| T:NA(Z) = T:NA(IN) + (DT:NA)*FRAC | | 00260020 |
| G0000 - G0040 = T(FRONT) | (Z) | 00270010 |
| T(FRT) = T:BR MET + DT(1)/2 | | 00270020 |
| H0000 - H0040 = T(BACK) | (Z) | 00280010 |
| T(BCK) = T:BR MET - DT(1)/2 | | 00280020 |
| M0000 - M0040 = T:BR MET(Z). MEAN TEMP OF METAL | (Z) | 00330010 |
| M0100 = AXIAL AVERAGED METAL TEMPERATURE | | 00330100 |
| M0200 = AXIAL AVERAGED METAL TEMPERATURE | | 00330200 |
| (AVERAGED BY O, R, & Z). | | 00330300 |
| N0000 - N0040 = T:NA (Z). SODIUM TEMPERATURE | (Z) | 00340010 |
| N0100 = AXIAL AVERAGED SODIUM TEMPERATURE | | 00340100 |
| O0000 - O0040 = G(Z). NORMALIZED ALTITUDE OF | | 00350011 |
| NORMAL DISTRIBUTION CURVE. | | 00350012 |
| P0000 - P0040 = T:PEAK METAL | (Z) | 00360010 |
| R0000 - R0040 = T:PK - T:BR MET | (Z) | 00380010 |
| O*(DT:PK-MET) | | 00380011 |
| R0100 - R0140 = T:PK - T:BR MET | (Z) | 00380100 |
| DT(1)/2 + DT(2) | | 00380101 |
| R0200 - R0240 = T:PK - T:BR MET | (Z) | 00380200 |
| T:PK - T:BR MET | | 00380202 |
| Z0000 - Z0040 = NODAL ALTITUDE (Z) | (FEET) | 00460010 |
| | | 00899999 |
| | | 00900000 |

2

PROBLEM CASE:

1 *** (Q/A)CL=1.20Mh/M2 T:NA(IN)=610F T:NA(OUT)=1050F *****
 2 *** A21=41.74 A22=139.66 A23=152.5 A24=150.76 A25=80.98 *****
 *0010 01000000

*** STAR 010 - STATIC NETWORK DESCRIPTION

| | | | | | | | | | | |
|-------|---|---|--------|----|-----|-----|---|---|---|----------|
| Y 1 | 0 | 0 | 1.0000 | .0 | T 1 | T 2 | 0 | 0 | 1 | 01000100 |
| Y 2 | 0 | 0 | 9.0000 | .0 | T 2 | T 3 | 0 | 0 | 1 | 01000200 |
| *0020 | | | | | | | | | | 02000000 |

*** STAR 020 - INITIALIZATION & CONSTANT DATA

| | | | | | | | | | | | |
|----------|---|---|------------|--------|---|---|---|---|---|------------------|----------|
| A 1 | G | 0 | 610.00 | .0 | 0 | 0 | 0 | C | 1 | T(NA-IN) | 02100010 |
| A 2 | 0 | 0 | 1050.0 | .0 | 0 | 0 | 0 | C | 1 | T(NA-OUT) | 02100020 |
| A 21 | 0 | 0 | 41.740 | .0 | 0 | 0 | 0 | 0 | 1 | DT:(MET-BR)-(NA) | 02100210 |
| A 22 | 0 | 0 | 139.66 | .0 | 0 | 0 | 0 | 0 | 1 | DT1 CL | 02100220 |
| A 23 | 0 | 0 | 192.50 | .0 | 0 | 0 | 0 | 0 | 1 | DT:(PK)-(NA) CL | 02100230 |
| A 24 | 0 | 0 | 150.76 | .0 | 0 | 0 | 0 | 0 | 1 | DT:(PK)-(MET-BR) | 02100240 |
| A 25 | 0 | 0 | 80.980 | .0 | 0 | 0 | 0 | 0 | 1 | DT2 CL | 02100250 |
| Z 0 Z 40 | 0 | 0 | .0 | 1.0000 | 0 | 0 | 0 | 0 | 1 | | 02740000 |
| F 0 | 0 | 0 | .0 | .0 | 0 | 0 | 0 | C | 1 | | 02750000 |
| F 1 | 0 | 0 | 6.2510E-C3 | .0 | 0 | 0 | 0 | C | 1 | | 02750010 |
| F 2 | 0 | 0 | 1.3808E-C2 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750020 |
| F 3 | 0 | 0 | 2.2855E-C2 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750030 |
| F 4 | 0 | 0 | 3.3577E-C2 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750040 |
| F 5 | 0 | 0 | 4.6157E-C2 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750050 |
| F 6 | 0 | 0 | 6.0772E-C2 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750060 |
| F 7 | 0 | 0 | 7.7580E-C2 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750070 |
| F 8 | 0 | 0 | 9.6720E-C2 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750080 |
| F 9 | 0 | 0 | .11830 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750090 |
| F 10 | 0 | 0 | .14238 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750100 |
| F 11 | 0 | 0 | .16900 | .0 | 0 | 0 | 0 | C | 1 | | 02750110 |
| F 12 | 0 | 0 | .19812 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750120 |
| F 13 | 0 | 0 | .22946 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750130 |
| F 14 | 0 | 0 | .26349 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750140 |
| F 15 | 0 | 0 | .29941 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750150 |
| F 16 | 0 | 0 | .33717 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750160 |
| F 17 | 0 | 0 | .37647 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750170 |
| F 18 | 0 | 0 | .41696 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750180 |
| F 19 | 0 | 0 | .45827 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750190 |
| F 20 | 0 | 0 | .50000 | .0 | 0 | 0 | 0 | C | 1 | | 02750200 |
| F 21 | 0 | 0 | .54173 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750210 |
| F 22 | 0 | 0 | .58304 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750220 |
| F 23 | 0 | 0 | .62353 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750230 |
| F 24 | 0 | 0 | .66283 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750240 |
| F 25 | 0 | 0 | .70059 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750250 |
| F 26 | 0 | 0 | .73651 | .0 | 0 | 0 | 0 | C | 1 | | 02750260 |
| F 27 | 0 | 0 | .77034 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750270 |
| F 28 | 0 | 0 | .80188 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750280 |
| F 29 | 0 | 0 | .83100 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750290 |
| F 30 | 0 | 0 | .85762 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750300 |
| F 31 | 0 | 0 | .88170 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750310 |
| F 32 | 0 | 0 | .90328 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750320 |
| F 33 | 0 | 0 | .92242 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750330 |
| F 34 | 0 | 0 | .93923 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750340 |
| F 35 | 0 | 0 | .95384 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750350 |
| F 36 | 0 | 0 | .96542 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750360 |
| F 37 | 0 | 0 | .97715 | .0 | 0 | 0 | 0 | C | 1 | | 02750370 |
| F 38 | 0 | 0 | .98619 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750380 |
| F 39 | 0 | 0 | .99375 | .0 | 0 | 0 | 0 | 0 | 1 | | 02750390 |
| F 40 | 0 | 0 | 1.0000 | .0 | 0 | 0 | 0 | C | 1 | | 02750400 |

TABLE Add-II-10 (c)

| | | | | | | | | | | | | |
|-------|----|---|----|---|---------|----|---|---|---|---|----|----------|
| 0 | 0 | 0 | 40 | 0 | .13534 | .0 | 0 | 0 | 0 | C | 40 | 02760000 |
| 0 | 1 | 0 | 39 | 0 | .16447 | .0 | 0 | 0 | 0 | C | 38 | 02760010 |
| 0 | 2 | 0 | 38 | 0 | .19790 | .0 | 0 | 0 | 0 | C | 36 | 02760020 |
| 0 | 3 | 0 | 37 | 0 | .23575 | .0 | 0 | 0 | 0 | C | 34 | 02760030 |
| 0 | 4 | 0 | 36 | 0 | .27804 | .0 | 0 | 0 | 0 | C | 32 | 02760040 |
| 0 | 5 | 0 | 35 | 0 | .32465 | .0 | 0 | 0 | 0 | C | 30 | 02760050 |
| 0 | 6 | 0 | 34 | 0 | .37531 | .0 | 0 | 0 | 0 | C | 28 | 02760060 |
| 0 | 7 | 0 | 33 | 0 | .42556 | .0 | 0 | 0 | C | C | 26 | 02760070 |
| 0 | 8 | 0 | 32 | 0 | .48675 | .0 | 0 | 0 | 0 | C | 24 | 02760080 |
| 0 | 9 | 0 | 31 | 0 | .54607 | .0 | 0 | C | 0 | C | 22 | 02760090 |
| 0 | 10 | 0 | 30 | 0 | .60653 | .0 | 0 | 0 | 0 | C | 20 | 02760100 |
| 0 | 11 | 0 | 29 | 0 | .66698 | .0 | 0 | 0 | 0 | C | 18 | 02760110 |
| 0 | 12 | 0 | 28 | 0 | .72615 | .0 | 0 | 0 | 0 | C | 16 | 02760120 |
| 0 | 13 | 0 | 27 | 0 | .78271 | .0 | C | 0 | 0 | C | 14 | 02760130 |
| 0 | 14 | 0 | 26 | 0 | .83527 | .0 | 0 | 0 | 0 | C | 12 | 02760140 |
| 0 | 15 | 0 | 25 | 0 | .88250 | .0 | 0 | 0 | 0 | C | 10 | 02760150 |
| 0 | 16 | 0 | 24 | 0 | .92312 | .0 | 0 | 0 | 0 | C | 8 | 02760160 |
| 0 | 17 | 0 | 23 | 0 | .95600 | .0 | 0 | 0 | 0 | C | 6 | 02760170 |
| 0 | 18 | 0 | 22 | 0 | .98020 | .0 | 0 | 0 | 0 | C | 4 | 02760180 |
| 0 | 19 | 0 | 21 | 0 | .99501 | .0 | 0 | C | 0 | C | 2 | 02760190 |
| C | 20 | 0 | 0 | 0 | 1.00000 | .0 | 0 | 0 | 0 | C | 1 | 02760200 |
| T | 1 | 0 | -1 | 0 | .0 | .0 | 0 | 0 | 0 | C | 1 | 02950010 |
| T | 2 | 0 | 0 | 0 | 500.00 | .0 | 0 | 0 | 0 | C | 1 | 02950020 |
| T | 3 | 0 | -1 | 0 | 100C.0 | .0 | 0 | 0 | 0 | C | 1 | 02950030 |
| *0030 | | | | | | | | | | | | |

3

*** STAR 030 - FUNCTION STATEMENTS

| | | | | | | | | | | | | | | | | |
|-------|---|-----|---|-----|-----|------------|--------|-----|-----|-----|-----|---|---|--------------|----------------|----------|
| 1 | A | 11 | 0 | 151 | .0 | 1.0000 | A | 2 | A | 1 | 0 | 0 | 1 | T:NA(OUT-IN) | 03100100 | |
| 2 | N | 0 | N | 40 | 152 | .0 | 1.0000 | F | 0 | A | 11 | 1 | C | 1 | 03120110 | |
| 3 | N | 0 | N | 40 | 150 | .0 | 1.0000 | N | 0 | A | 1 | 1 | 0 | 1 | T:NA(Z) | 03120120 |
| 4 | N | 101 | 0 | 150 | .0 | .50000 | N | C | N | 40 | 0 | C | 1 | 1 | 03120310 | |
| 5 | N | 102 | 0 | 161 | .0 | 1.0000 | N | 1 | N | 39 | 0 | C | 1 | 1 | 03120320 | |
| 6 | N | 100 | 0 | 150 | .0 | 2.5000E-02 | N | 101 | N | 102 | 0 | 0 | 1 | T:NA BAR | 03120330 | |
| 7 | M | 0 | M | 40 | 152 | .0 | 1.0000 | 0 | 0 | A | 21 | 1 | 0 | 1 | 03150110 | |
| 8 | M | 0 | M | 40 | 150 | .0 | 1.0000 | M | 0 | N | 0 | 1 | 1 | 1 | T:BR MET (Z) | 03150120 |
| 9 | M | 100 | 0 | 101 | .0 | .59814 | A | 21 | 0 | 0 | 0 | C | 1 | 1 | 03150310 | |
| 10 | M | 100 | 0 | 150 | .0 | 1.0000 | M | 100 | N | 100 | 0 | 0 | 1 | T:BR BR MET | 03150320 | |
| 11 | M | 201 | 0 | 150 | .0 | .50000 | M | 0 | M | 40 | 0 | 0 | 1 | 1 | 03160110 | |
| 12 | M | 202 | 0 | 161 | .0 | 1.0000 | M | 1 | M | 39 | 0 | 0 | 1 | 1 | 03160120 | |
| 13 | M | 200 | 0 | 150 | .0 | 2.5000E-02 | M | 201 | M | 202 | 0 | 0 | 1 | T:BR BR MET | 03160130 | |
| 14 | D | 0 | D | 40 | 152 | .0 | 1.0000 | 0 | 0 | A | 22 | 1 | 0 | 1 | DT1 (Z) | 03180110 |
| 15 | D | 100 | D | 140 | 101 | .0 | .50000 | 0 | 0 | 0 | 0 | 1 | 0 | 1 | DT1/2 (Z) | 03180120 |
| 16 | E | 0 | E | 40 | 152 | .0 | 1.0000 | 0 | 0 | A | 25 | 1 | 0 | 1 | DT2 (Z) | 03180210 |
| 17 | G | 0 | G | 40 | 150 | .0 | 1.0000 | M | 0 | D | 100 | 1 | 1 | 1 | T(FRONT) (Z) | 03210100 |
| 18 | H | 0 | H | 40 | 151 | .0 | 1.0000 | M | 0 | D | 100 | 1 | 1 | 1 | T(BACK) (Z) | 03210200 |
| 19 | P | 0 | P | 40 | 152 | .0 | 1.0000 | C | 0 | A | 23 | 1 | 0 | 1 | 1 | 03250110 |
| 20 | P | 0 | P | 40 | 150 | .0 | 1.0000 | P | 0 | N | 0 | 1 | 1 | 1 | T(PEAK) (Z) | 03250120 |
| 21 | R | 0 | R | 40 | 152 | .0 | 1.0000 | 0 | 0 | A | 24 | 1 | C | 1 | T:PK - T:MET Z | 03280100 |
| 22 | K | 100 | R | 140 | 150 | .0 | 1.0000 | D | 100 | E | 0 | 1 | 1 | 1 | T:PK - T:MET Z | 03280200 |
| 23 | R | 200 | R | 240 | 151 | .0 | 1.0000 | P | 0 | M | 0 | 1 | 1 | 1 | T:PK - T:MET Z | 03280300 |
| *0070 | | | | | | | | | | | | | | | | |

*** STAR 070 - SPECIAL CONTROL CONSTANTS

| | | | |
|-------|--------|---|----------|
| 5 | 1.0000 | 0. = TRANSIENT; +1. = STEADY STATE | 07000050 |
| 6 | 1.0000 | +1= DUMP Y,T,C,Q, & DUMMIES AT END OF CASE | 07000060 |
| 19 | 1.0000 | +1.0 - TAPOLT ENTRIES ON SEPARATE TITLED PAGE | 07000190 |
| *0080 | | | 08000000 |

*** STAR 080 - PRINTOUT SPECIFICATIONS

| | | | | | | | | | | | | |
|-------|-----|---|----|----|----|----|---|---|---|---|----------|----------|
| A | 1 | 0 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | T:NA IN | 08101010 |
| A | 2 | 0 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | T:NA CUT | 08101020 |
| A | 11 | 0 | 1 | .0 | .0 | C | 0 | 0 | 0 | 1 | DT: NA | 08101030 |
| N | 100 | 0 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | T:BR NA | 08101040 |
| M | 100 | 0 | 1 | .0 | .0 | 0 | 0 | C | 0 | 1 | T:BR M | 08101050 |
| A | 21 | 0 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | DT M-N | 08102010 |
| A | 22 | 0 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | DT1 | 08102020 |
| A | 23 | 0 | 1 | .0 | .0 | C | 0 | 0 | 0 | 1 | DT P-N | 08102030 |
| A | 24 | 0 | 1 | .0 | .0 | 0 | 0 | 0 | C | 1 | DT P-M | 08102040 |
| A | 25 | 0 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | DT2 | 08102050 |
| B | 1 | B | 5 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | 08300101 |
| N | 0 | N | 40 | 0 | .0 | .0 | 0 | C | 0 | C | 1 | 08300200 |
| B | 1 | B | 9 | 1 | .0 | .0 | 0 | 0 | 0 | C | 1 | 08300210 |
| M | 0 | M | 40 | 0 | .0 | .0 | 0 | 0 | 0 | C | 1 | 08300300 |
| B | 1 | B | 9 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | 08300310 |
| P | 0 | P | 40 | 0 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | 08300400 |
| B | 1 | B | 9 | 1 | .0 | .0 | 8 | 0 | 0 | C | 1 | 08300410 |
| G | 0 | G | 40 | 0 | .0 | .0 | 0 | 0 | 0 | C | 1 | 08300500 |
| B | 1 | B | 9 | 1 | .0 | .0 | 0 | 0 | 0 | 0 | 1 | 08300510 |
| H | 1 | H | 40 | 0 | .0 | .0 | 0 | 0 | 0 | C | 1 | 08300600 |
| B | 1 | B | 4 | 1 | .0 | .0 | 0 | 0 | 0 | C | 1 | 08300610 |
| *0090 | | | | | | | | | | | | |

*** STAR 090 - PRINTOUT & STOP TIMES

| | | | | | | | | | | | |
|--------|---|---|--------|--------|---|---|---|---|---|----------|----------|
| 0 | 0 | 0 | .0 | 2.0000 | C | 0 | 0 | C | 1 | 09000100 | |
| 0 | 0 | 0 | 2.0000 | .0 | 0 | 0 | 0 | C | 1 | 09000200 | |
| *0096. | | | | | | | | | | | 09600000 |

TABLE Add-II-(10d)

*0001 10200001
 *** STAR 001 - TITLES & STCRED COMMENTS
 1 *** (Q/A)CL=0.97Mw/M2 T:NA(IN)=610F T:NA(OUT)=1050F *****
 2 *** A21=35.16 A22=117.57 A23=160.5 A24=125.34 A25=66.558 *****
 *0020 10200010
 10200020
 10202000

*** STAR 020 - INITIALIZATION & CONSTANT DATA

4

| | | | | | | | | | | | |
|---|----|---|---|--------|----|---|---|---|---|---|----------|
| A | 1 | 0 | 0 | 610.00 | .0 | 0 | 0 | 0 | 0 | 1 | 10202010 |
| A | 2 | 0 | 0 | 1050.0 | .0 | 0 | 0 | 0 | 0 | 1 | 10202020 |
| A | 21 | 0 | 0 | 35.160 | .0 | 0 | 0 | 0 | 0 | 1 | 10202210 |
| A | 22 | 0 | 0 | 117.57 | .0 | 0 | 0 | 0 | 0 | 1 | 10202220 |
| A | 23 | 0 | 0 | 160.50 | .0 | 0 | 0 | 0 | 0 | 1 | 10202230 |
| A | 24 | 0 | 0 | 125.34 | .0 | 0 | 0 | 0 | 0 | 1 | 10202240 |
| A | 25 | 0 | 0 | 66.558 | .0 | 0 | 0 | 0 | 0 | 1 | 10202250 |

*0070 10207000

*** STAR 070 - SPECIAL CONTROL CONSTANTS

11 1.0000 NODE SUMMARY: +1.0=NO PRINT:- 1.0= NO COMPILE 10207011
 *0056 10209600

*0001 10300001

*** STAR 001 - TITLES & STCRED COMMENTS

1 *** (Q/A)CL=0.225Mw/M2 T:NA(IN)=610F T:NA(OUT)=1050F *****
 2 *** A21=9.94 A22=33.133 A23=43.17 A24=33.23 A25=16.662 *****
 *0020 10300010
 10300020
 10302000

*** STAR 020 - INITIALIZATION & CONSTANT DATA

| | | | | | | | | | | | |
|---|----|---|---|--------|----|---|---|---|---|---|----------|
| A | 1 | 0 | 0 | 610.00 | .0 | 0 | 0 | 0 | 0 | 1 | 10302010 |
| A | 2 | 0 | 0 | 1050.0 | .0 | 0 | 0 | 0 | 0 | 1 | 10302020 |
| A | 21 | 0 | 0 | 9.9400 | .0 | 0 | 0 | 0 | 0 | 1 | 10302210 |
| A | 22 | 0 | 0 | 33.133 | .0 | 0 | 0 | 0 | 0 | 1 | 10302220 |
| A | 23 | 0 | 0 | 43.170 | .0 | 0 | 0 | 0 | 0 | 1 | 10302230 |
| A | 24 | 0 | 0 | 33.230 | .0 | 0 | 0 | 0 | 0 | 1 | 10302240 |
| A | 25 | 0 | 0 | 16.662 | .0 | 0 | 0 | 0 | 0 | 1 | 10302250 |

*0056 10309600

TABLE Add - II - 11
 PANEL TEMPERATURE DISTRIBUTION

| | | | | |
|---|--|--|---|---|
| T:NA IN Sodium Inlet Temp (A0001) | T:NA OUT Sodium Outlet Temp (A0002) | DT:NA $(T_{N_{OUT}} - T_{N_{IN}})$ (A0011) | \bar{T} :B NA Axially Averaged Sodium Temp (N0100) | \bar{T} :B M Overall Averaged Metal Temp (z, θ , R) (M0100) |
| DT M-N $(\bar{T}_{MET} - T_{NA}) \pm$ (A0021) | DT1 $\Delta T_1 \pm$ (A0022) | DT P-N $(T_{Peak} - T_{NA}) \pm$ (A0023) | DT P-M $(T_{Peak} - \bar{T}_{ME}) \pm$ (A0024) | DT2 $\Delta T_2 \pm$ (A0025) |

- N Sodium Temperature (at elevation Z)
- M Mean Metal Temp (Circum & Radial) (at elevation Z)
- P Peak Metal Temperature (at elevation Z)
- G "Front" Temperature = $T(\text{mean}) + (\Delta T_1/2)$ (at elev Z)
- H "Back" Temperature = $T(\text{mean}) - (\Delta T_1/2)$ (at elev Z)

Number (Z): Elevation on active panel (feet).
 Example: M0027 = Mean Metal Temp, 27 feet above the bottom of active panel.



PANEL TEMPERATURE DISTRIBUTION

CASE 1

SET 1 Subpanel 1

Solar Flux Distribution: REFERENCE

Orifices: Yes: Orificed to match tube flow rates to
reference flux distribution

Sodium Temperatures: T (Na-Inlet) = 610°F
T (Na-Outlet) = 1050°F (all tubes)

5370F/sjh

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0.05

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 1 LOC=05 T:NA(IN)=610F T:NA(OUT)=1050F
 A21=11.201 A22= 37.355 A23= 49.037 A24= 37.836 A25=19.157

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL MODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 836.70 |
| DT M-N = 11.201 | DT1 = 37.355 | DT P-N = 49.037 | DT P-M = 37.836 | DT2 = 19.157 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.66 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 611.52 | M 1 = 614.59 | M 2 = 618.29 | M 3 = 622.70 | M 4 = 627.89 |
| M 5 = 633.95 | M 6 = 640.94 | M 7 = 648.95 | M 8 = 658.01 | M 9 = 668.17 |
| M 10 = 679.44 | M 11 = 691.83 | M 12 = 705.31 | M 13 = 719.82 | M 14 = 735.29 |
| M 15 = 751.63 | M 16 = 768.69 | M 17 = 786.35 | M 18 = 804.64 | M 19 = 822.79 |
| M 20 = 841.20 | M 21 = 859.50 | M 22 = 877.52 | M 23 = 895.06 | M 24 = 911.99 |
| M 25 = 928.14 | M 26 = 943.42 | M 27 = 957.72 | M 28 = 970.96 | M 29 = 983.11 |
| M 30 = 994.14 | M 31 = 1004.1 | M 32 = 1012.9 | M 33 = 1020.7 | M 34 = 1027.5 |
| M 35 = 1033.3 | M 36 = 1038.3 | M 37 = 1042.6 | M 38 = 1046.1 | M 39 = 1049.1 |
| M 40 = 1051.5 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| = 616.64 | P 1 = 620.82 | P 2 = 625.78 | P 3 = 631.62 | P 4 = 638.41 |
| 5 = 646.23 | P 6 = 655.14 | P 7 = 665.20 | P 8 = 676.43 | P 9 = 688.83 |
| 10 = 702.39 | P 11 = 717.07 | P 12 = 732.78 | P 13 = 749.43 | P 14 = 766.90 |
| P 15 = 785.02 | P 16 = 803.62 | P 17 = 822.52 | P 18 = 841.53 | P 19 = 860.43 |
| P 20 = 879.04 | P 21 = 897.15 | P 22 = 914.60 | P 23 = 931.23 | P 24 = 949.91 |
| P 25 = 961.53 | P 26 = 975.02 | P 27 = 987.33 | P 28 = 998.44 | P 29 = 1008.3 |
| P 30 = 1017.1 | P 31 = 1024.7 | P 32 = 1031.3 | P 33 = 1036.9 | P 34 = 1041.7 |
| P 35 = 1045.6 | P 36 = 1048.9 | P 37 = 1051.5 | P 38 = 1053.6 | P 39 = 1055.3 |
| P 40 = 1056.6 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 614.04 | G 1 = 617.66 | G 2 = 621.99 | G 3 = 627.10 | G 4 = 633.08 |
| G 5 = 640.01 | G 6 = 647.95 | G 7 = 656.97 | G 8 = 667.10 | G 9 = 678.37 |
| G 10 = 690.77 | G 11 = 704.29 | G 12 = 718.87 | G 13 = 734.44 | G 14 = 750.89 |
| G 15 = 768.11 | G 16 = 785.94 | G 17 = 804.21 | G 18 = 822.75 | G 19 = 841.37 |
| G 20 = 859.88 | G 21 = 878.09 | G 22 = 895.82 | G 23 = 912.92 | G 24 = 929.23 |
| G 25 = 944.63 | G 26 = 959.02 | G 27 = 972.33 | G 28 = 984.52 | G 29 = 995.57 |
| G 30 = 1005.5 | G 31 = 1014.3 | G 32 = 1022.0 | G 33 = 1028.7 | G 34 = 1034.5 |
| G 35 = 1039.4 | G 36 = 1043.5 | G 37 = 1047.0 | G 38 = 1049.8 | G 39 = 1052.2 |
| G 40 = 1054.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 611.52 | H 2 = 614.60 | H 3 = 618.29 | H 4 = 622.69 | H 5 = 627.88 |
| H 6 = 633.93 | H 7 = 640.92 | H 8 = 648.92 | H 9 = 657.97 | H 10 = 668.11 |
| H 11 = 679.37 | H 12 = 691.74 | H 13 = 705.20 | H 14 = 719.69 | H 15 = 735.14 |
| H 16 = 751.45 | H 17 = 768.50 | H 18 = 786.13 | H 19 = 804.20 | H 20 = 822.52 |
| H 21 = 840.92 | H 22 = 859.21 | H 23 = 877.21 | H 24 = 894.74 | H 25 = 911.66 |
| H 26 = 927.82 | H 27 = 943.10 | H 28 = 957.60 | H 29 = 970.65 | H 30 = 982.82 |
| H 31 = 993.87 | H 32 = 1003.8 | H 33 = 1012.7 | H 34 = 1020.5 | H 35 = 1027.3 |
| H 36 = 1033.1 | H 37 = 1038.2 | H 38 = 1042.4 | H 39 = 1046.0 | H 40 = 1049.0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0.15

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 1 LOC=0.15 T:NA(IN)=610F T:NA(OUT)=1050F
 A21=13.723 A22= 45.799 A23= 60.770 A24= 47.047 A25=24.146

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 838.21 |
| DT M-N = 13.723 | DTI = 45.799 | DT P-N = 60.770 | DT P-M = 47.047 | DT2 = 24.146 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 611.86 | M 1 = 615.01 | M 2 = 618.79 | M 3 = 623.29 | M 4 = 628.59 |
| M 5 = 634.76 | M 6 = 641.89 | M 7 = 650.03 | M 8 = 659.24 | M 9 = 669.55 |
| M 10 = 680.97 | M 11 = 693.51 | M 12 = 707.14 | M 13 = 721.79 | M 14 = 737.40 |
| M 15 = 753.85 | M 16 = 771.02 | M 17 = 788.76 | M 18 = 806.91 | M 19 = 825.29 |
| M 20 = 843.72 | M 21 = 862.01 | M 22 = 879.99 | M 23 = 897.47 | M 24 = 914.31 |
| M 25 = 930.37 | M 26 = 945.53 | M 27 = 959.69 | M 28 = 972.79 | M 29 = 984.79 |
| M 30 = 995.67 | M 31 = 1005.4 | M 32 = 1014.1 | M 33 = 1021.8 | M 34 = 1028.4 |
| M 35 = 1034.1 | M 36 = 1039.0 | M 37 = 1043.2 | M 38 = 1046.6 | M 39 = 1049.5 |
| M 40 = 1051.9 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 618.22 | P 1 = 622.75 | P 2 = 628.10 | P 3 = 634.38 | P 4 = 641.67 |
| P 5 = 650.04 | P 6 = 659.55 | P 7 = 670.24 | P 8 = 682.14 | P 9 = 695.24 |
| P 10 = 709.51 | P 11 = 724.89 | P 12 = 741.30 | P 13 = 758.62 | P 14 = 776.70 |
| P 15 = 795.37 | P 16 = 814.45 | P 17 = 833.74 | P 18 = 853.03 | P 19 = 872.11 |
| P 20 = 890.77 | P 21 = 908.83 | P 22 = 926.10 | P 23 = 942.45 | P 24 = 957.74 |
| P 25 = 971.89 | P 26 = 984.82 | P 27 = 996.51 | P 28 = 1007.0 | P 29 = 1016.2 |
| P 30 = 1024.2 | P 31 = 1031.1 | P 32 = 1037.0 | P 33 = 1042.0 | P 34 = 1046.1 |
| P 35 = 1049.4 | P 36 = 1052.1 | P 37 = 1056.3 | P 38 = 1056.0 | P 39 = 1057.2 |
| P 40 = 1058.2 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 614.96 | G 1 = 618.77 | G 2 = 623.32 | G 3 = 628.69 | G 4 = 634.96 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 642.20 | G 6 = 650.48 | G 7 = 659.87 | G 8 = 670.38 | G 9 = 682.05 |
| G 10 = 694.86 | G 11 = 708.79 | G 12 = 723.77 | G 13 = 739.72 | G 14 = 756.53 |
| G 15 = 774.06 | G 16 = 792.16 | G 17 = 810.66 | G 18 = 829.36 | G 19 = 848.08 |
| G 20 = 866.62 | G 21 = 884.80 | G 22 = 902.43 | G 23 = 919.36 | G 24 = 935.45 |
| G 25 = 950.58 | G 26 = 964.65 | G 27 = 977.61 | G 28 = 989.42 | G 29 = 1000.1 |
| G 30 = 1009.6 | G 31 = 1017.9 | G 32 = 1025.3 | G 33 = 1031.6 | G 34 = 1037.0 |
| G 35 = 1041.6 | G 36 = 1045.4 | G 37 = 1048.6 | G 38 = 1051.2 | G 39 = 1053.3 |
| G 40 = 1055.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 611.24 | H 2 = 614.26 | H 3 = 617.89 | H 4 = 622.22 | H 5 = 627.33 |
| H 6 = 633.30 | H 7 = 640.19 | H 8 = 648.09 | H 9 = 657.04 | H 10 = 667.08 |
| H 11 = 678.24 | H 12 = 690.51 | H 13 = 703.87 | H 14 = 718.27 | H 15 = 733.64 |
| H 16 = 749.88 | H 17 = 766.87 | H 18 = 784.47 | H 19 = 802.51 | H 20 = 820.82 |
| H 21 = 839.23 | H 22 = 857.54 | H 23 = 875.58 | H 24 = 893.17 | H 25 = 910.16 |
| H 26 = 926.40 | H 27 = 941.77 | H 28 = 956.16 | H 29 = 969.52 | H 30 = 981.78 |
| H 31 = 992.94 | H 32 = 1003.0 | H 33 = 1011.9 | H 34 = 1019.8 | H 35 = 1026.7 |
| H 36 = 1032.7 | H 37 = 1037.8 | H 38 = 1042.1 | H 39 = 1045.7 | H 40 = 1048.8 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: .25

T(Na-inlet) = 610 F

T(Na-outlet) : 1050 F

PANEL 1 LOC=.25 I:NA(IN)=610F I:NA(OUT)=1050F
A21=16.245 A22= 54.242 A23= 72.503 A24= 56.258 A25=29.136

ITEM NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 839.71 |
| DT M-N = 16.245 | DT1 = 54.242 | DT P-N = 72.503 | DT P-M = 56.258 | DT2 = 29.136 |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 |
| N 5 = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 6 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | N = .0 | N = .0 | N = .0 | N = .0 |
| M = 612.20 | M 1 = 615.42 | M 2 = 619.29 | M 3 = 623.89 | M 4 = 629.29 |
| M 5 = 635.58 | M 6 = 642.84 | M 7 = 651.11 | M 8 = 660.46 | M 9 = 670.92 |
| M 10 = 682.50 | M 11 = 695.19 | M 12 = 708.97 | M 13 = 723.77 | M 14 = 739.51 |
| M 15 = 756.08 | M 16 = 773.35 | M 17 = 791.18 | M 18 = 809.39 | M 19 = 827.80 |
| M 20 = 846.24 | M 21 = 864.52 | M 22 = 882.46 | M 23 = 899.88 | M 24 = 916.64 |
| M 25 = 932.59 | M 26 = 947.63 | M 27 = 961.66 | M 28 = 974.62 | M 29 = 986.47 |
| M 30 = 997.20 | M 31 = 1006.8 | M 32 = 1015.4 | M 33 = 1022.8 | M 34 = 1029.4 |
| M 35 = 1035.0 | M 36 = 1039.7 | M 37 = 1043.8 | M 38 = 1047.1 | M 39 = 1049.9 |
| M 40 = 1052.2 | M = .0 | M = .0 | M = .0 | M = .0 |
| P = 619.81 | P 1 = 624.68 | P 2 = 630.42 | P 3 = 637.15 | P 4 = 644.93 |
| P 5 = 653.85 | P 6 = 663.95 | P 7 = 675.28 | P 8 = 687.85 | P 9 = 701.64 |
| P 10 = 716.62 | P 11 = 732.72 | P 12 = 749.82 | P 13 = 767.80 | P 14 = 786.50 |
| P 15 = 805.72 | P 16 = 825.28 | P 17 = 844.96 | P 18 = 864.53 | P 19 = 883.78 |
| P 20 = 902.50 | P 21 = 920.50 | P 22 = 937.60 | P 23 = 953.67 | P 24 = 968.57 |
| P 25 = 982.24 | P 26 = 994.42 | P 27 = 1005.7 | P 28 = 1015.5 | P 29 = 1024.0 |
| P 30 = 1031.3 | P 31 = 1037.5 | P 32 = 1042.7 | P 33 = 1047.0 | P 34 = 1050.5 |
| P 35 = 1053.2 | P 36 = 1055.4 | P 37 = 1057.0 | P 38 = 1058.3 | P 39 = 1059.2 |
| P 40 = 1059.8 | P = .0 | P = .0 | P = .0 | P = .0 |
| G = 615.87 | G 1 = 619.88 | G 2 = 624.66 | G 3 = 630.28 | G 4 = 636.83 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 644.39 | G 6 = 653.02 | G 7 = 662.76 | G 8 = 673.67 | G 9 = 685.73 |
| G 10 = 698.95 | G 11 = 713.28 | G 12 = 728.66 | G 13 = 744.99 | G 14 = 762.16 |
| G 15 = 780.01 | G 16 = 798.39 | G 17 = 817.10 | G 18 = 835.97 | G 19 = 854.79 |
| G 20 = 873.37 | G 21 = 891.51 | G 22 = 909.04 | G 23 = 925.81 | G 24 = 941.68 |
| G 25 = 956.53 | G 26 = 970.29 | G 27 = 982.89 | G 28 = 994.32 | G 29 = 1004.6 |
| G 30 = 1013.7 | G 31 = 1021.6 | G 32 = 1028.6 | G 33 = 1034.5 | G 34 = 1039.5 |
| G 35 = 1043.8 | G 36 = 1047.3 | G 37 = 1050.2 | G 38 = 1052.5 | G 39 = 1054.4 |
| G 40 = 1055.9 | G = .0 | G = .0 | G = .0 | G = .0 |
| H 1 = 610.96 | H 2 = 613.92 | H 3 = 617.49 | H 4 = 621.75 | H 5 = 626.78 |
| H 6 = 632.66 | H 7 = 639.46 | H 8 = 647.26 | H 9 = 656.11 | H 10 = 666.05 |
| H 11 = 677.11 | H 12 = 689.27 | H 13 = 702.54 | H 14 = 716.85 | H 15 = 732.14 |
| H 16 = 748.31 | H 17 = 765.25 | H 18 = 782.80 | H 19 = 800.82 | H 20 = 819.12 |
| H 21 = 837.54 | H 22 = 855.88 | H 23 = 873.96 | H 24 = 891.61 | H 25 = 908.66 |
| H 26 = 924.98 | H 27 = 940.44 | H 28 = 954.93 | H 29 = 968.39 | H 30 = 980.75 |
| H 31 = 992.01 | H 32 = 1002.1 | H 33 = 1011.2 | H 34 = 1019.2 | H 35 = 1026.2 |
| H 36 = 1032.2 | H 37 = 1037.4 | H 38 = 1041.8 | H 39 = 1045.5 | H 40 = 1048.5 |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0.35

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 1 LOC=35 T:NA(IN)=610F T:NA(OUT)=1050F
A21=18.767 A22= 62.686 A23= 84.236 A24= 65.469 A25=34.126

ITER-NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = 0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 841.22 |
| JT M-N = 18.767 | DT1 = 62.686 | DT P-N = 84.236 | DT P-M = 65.469 | DT2 = 34.126 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 646.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | | | | |
| M = 612.54 | M 1 = 615.84 | M 2 = 619.79 | M 3 = 624.48 | M 4 = 629.99 |
| M 5 = 636.40 | M 6 = 643.78 | M 7 = 652.20 | M 8 = 661.69 | M 9 = 672.30 |
| M 10 = 684.03 | M 11 = 696.88 | M 12 = 710.80 | M 13 = 725.74 | M 14 = 741.61 |
| M 15 = 758.30 | M 16 = 775.68 | M 17 = 793.59 | M 18 = 811.86 | M 19 = 830.31 |
| M 20 = 848.77 | M 21 = 867.03 | M 22 = 884.93 | M 23 = 902.30 | M 24 = 918.97 |
| M 25 = 934.82 | M 26 = 949.74 | M 27 = 963.64 | M 28 = 976.45 | M 29 = 988.16 |
| M 30 = 998.73 | M 31 = 1008.2 | M 32 = 1016.6 | M 33 = 1023.9 | M 34 = 1030.3 |
| M 35 = 1032.8 | M 36 = 1040.4 | M 37 = 1044.4 | M 38 = 1047.6 | M 39 = 1050.3 |
| M 40 = 1052.5 | | | | |
| P = 621.40 | P 1 = 626.60 | P 2 = 632.75 | P 3 = 639.91 | P 4 = 648.19 |
| P 5 = 657.66 | P 6 = 668.35 | P 7 = 680.32 | P 8 = 693.56 | P 9 = 708.05 |
| P 10 = 723.74 | P 11 = 740.54 | P 12 = 758.34 | P 13 = 776.98 | P 14 = 796.30 |
| P 15 = 816.08 | P 16 = 836.11 | P 17 = 856.18 | P 18 = 876.03 | P 19 = 895.46 |
| P 20 = 914.24 | P 21 = 932.18 | P 22 = 949.10 | P 23 = 964.88 | P 24 = 979.41 |
| P 25 = 992.60 | P 26 = 1006.4 | P 27 = 1016.9 | P 28 = 1024.0 | P 29 = 1031.8 |
| P 30 = 1038.4 | P 31 = 1043.9 | P 32 = 1048.4 | P 33 = 1052.0 | P 34 = 1054.9 |
| P 35 = 1057.0 | P 36 = 1058.6 | P 37 = 1059.8 | P 38 = 1060.6 | P 39 = 1061.1 |
| P 40 = 1061.4 | | | | |
| G = 616.78 | G 1 = 620.99 | G 2 = 625.99 | G 3 = 631.87 | G 4 = 638.71 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 646.58 | G 6 = 655.55 | G 7 = 665.66 | G 8 = 676.95 | G 9 = 689.42 |
| G 10 = 703.04 | G 11 = 717.78 | G 12 = 733.56 | G 13 = 750.27 | G 14 = 767.79 |
| G 15 = 785.96 | G 16 = 804.61 | G 17 = 823.55 | G 18 = 842.58 | G 19 = 861.50 |
| G 20 = 880.11 | G 21 = 898.22 | G 22 = 915.65 | G 23 = 932.26 | G 24 = 947.90 |
| G 25 = 962.48 | G 26 = 975.92 | G 27 = 988.17 | G 28 = 999.21 | G 29 = 1009.1 |
| G 30 = 1017.7 | G 31 = 1025.3 | G 32 = 1031.8 | G 33 = 1037.4 | G 34 = 1042.1 |
| G 35 = 1046.0 | G 36 = 1049.2 | G 37 = 1051.8 | G 38 = 1053.8 | G 39 = 1055.5 |
| G 40 = 1056.8 | | | | |
| H 1 = 610.68 | H 2 = 613.59 | H 3 = 617.09 | H 4 = 621.28 | H 5 = 626.23 |
| H 6 = 632.02 | H 7 = 638.73 | H 8 = 646.44 | H 9 = 655.18 | H 10 = 665.02 |
| H 11 = 675.97 | H 12 = 688.04 | H 13 = 701.21 | H 14 = 715.43 | H 15 = 730.64 |
| H 16 = 746.74 | H 17 = 763.62 | H 18 = 781.14 | H 19 = 799.13 | H 20 = 817.42 |
| H 21 = 835.85 | H 22 = 854.21 | H 23 = 872.33 | H 24 = 890.04 | H 25 = 907.16 |
| H 26 = 924.56 | H 27 = 939.10 | H 28 = 953.69 | H 29 = 967.25 | H 30 = 979.72 |
| H 31 = 991.08 | H 32 = 1001.3 | H 33 = 1010.5 | H 34 = 1018.5 | H 35 = 1025.6 |
| H 36 = 1031.7 | H 37 = 1037.0 | H 38 = 1041.4 | H 39 = 1045.2 | H 40 = 1048.3 |

CASE # 1

Solar Flux: REFERENCE
 Orifices: YES
 Sub-Panel: 1
 Location x/L: 0.45
 T(Na-inlet) = 610 F
 T(Na-outlet) : Mean = 1050F

PANEL 1 LOC=0.45 T:NA(IN)=610F T:NA(OUT)=1050F
 A21=21.289 A22= 71.130 A23= 95.969 A24= 74.680 A25=39.115

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL MODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 842.73 |
| DT M-N = 21.289 | DT1 = 71.130 | DT P-N = 95.969 | DT P-M = 74.680 | DT2 = 39.115 |
| N = .0 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.76 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | N = .0 | N = .0 | N = .0 | N = .0 |
| M = .0 | M 1 = 616.25 | M 2 = 620.29 | M 3 = 625.07 | M 4 = 630.69 |
| M 5 = 637.22 | M 6 = 644.73 | M 7 = 653.28 | M 8 = 662.92 | M 9 = 673.68 |
| M 10 = 685.56 | M 11 = 698.56 | M 12 = 712.63 | M 13 = 727.71 | M 14 = 743.72 |
| M 15 = 760.53 | M 16 = 778.01 | M 17 = 796.00 | M 18 = 814.33 | M 19 = 832.82 |
| M 20 = 851.29 | M 21 = 869.54 | M 22 = 887.40 | M 23 = 904.71 | M 24 = 921.30 |
| M 25 = 937.05 | M 26 = 951.85 | M 27 = 965.61 | M 28 = 978.29 | M 29 = 989.84 |
| M 30 = 1000.3 | M 31 = 1009.6 | M 32 = 1017.8 | M 33 = 1025.0 | M 34 = 1031.3 |
| M 35 = 1036.6 | M 36 = 1041.1 | M 37 = 1045.0 | M 38 = 1048.1 | M 39 = 1050.8 |
| M 40 = 1052.9 | M = .0 | M = .0 | M = .0 | M = .0 |
| P = .0 | P 1 = 628.53 | P 2 = 635.07 | P 3 = 642.68 | P 4 = 651.46 |
| P 5 = 661.47 | P 6 = 672.76 | P 7 = 685.36 | P 8 = 699.27 | P 9 = 714.46 |
| P 10 = 730.86 | P 11 = 748.37 | P 12 = 766.86 | P 13 = 786.17 | P 14 = 806.10 |
| P 15 = 826.43 | P 16 = 846.94 | P 17 = 867.39 | P 18 = 887.53 | P 19 = 907.13 |
| P 20 = 925.97 | P 21 = 943.85 | P 22 = 960.61 | P 23 = 976.10 | P 24 = 990.24 |
| P 25 = 1002.0 | P 26 = 1014.2 | P 27 = 1024.1 | P 28 = 1032.5 | P 29 = 1039.6 |
| P 30 = 1045.6 | P 31 = 1050.4 | P 32 = 1054.2 | P 33 = 1057.1 | P 34 = 1059.3 |
| P 35 = 1060.8 | P 36 = 1061.9 | P 37 = 1062.6 | P 38 = 1062.9 | P 39 = 1063.0 |
| P 40 = 1063.0 | P = .0 | P = .0 | P = .0 | P = .0 |
| G = .0 | G 1 = 622.10 | G 2 = 627.33 | G 3 = 633.46 | G 4 = 640.58 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 648.77 | G 6 = 658.08 | G 7 = 668.56 | G 8 = 680.23 | G 9 = 693.10 |
| G 10 = 707.13 | G 11 = 722.28 | G 12 = 738.46 | G 13 = 755.55 | G 14 = 773.42 |
| G 15 = 791.91 | G 16 = 810.84 | G 17 = 830.00 | G 18 = 849.19 | G 19 = 868.21 |
| G 20 = 886.85 | G 21 = 904.93 | G 22 = 922.26 | G 23 = 938.71 | G 24 = 954.13 |
| G 25 = 968.43 | G 26 = 981.55 | G 27 = 993.45 | G 28 = 1004.1 | G 29 = 1013.6 |
| G 30 = 1021.8 | G 31 = 1029.0 | G 32 = 1035.1 | G 33 = 1040.3 | G 34 = 1044.6 |
| G 35 = 1048.1 | G 36 = 1051.0 | G 37 = 1053.3 | G 38 = 1055.2 | G 39 = 1056.6 |
| G 40 = 1057.7 | G = .0 | G = .0 | G = .0 | G = .0 |
| H 1 = 610.40 | H 2 = 613.25 | H 3 = 616.69 | H 4 = 620.80 | H 5 = 625.67 |
| H 6 = 631.38 | H 7 = 638.00 | H 8 = 645.61 | H 9 = 654.26 | H 10 = 663.99 |
| H 11 = 674.84 | H 12 = 686.81 | H 13 = 699.88 | H 14 = 714.01 | H 15 = 729.14 |
| H 16 = 745.18 | H 17 = 762.00 | H 18 = 779.47 | H 19 = 797.44 | H 20 = 815.72 |
| H 21 = 834.15 | H 22 = 852.54 | H 23 = 870.71 | H 24 = 888.47 | H 25 = 905.66 |
| H 26 = 922.14 | H 27 = 937.77 | H 28 = 952.46 | H 29 = 966.12 | H 30 = 978.69 |
| H 31 = 990.15 | H 32 = 1000.5 | H 33 = 1009.7 | H 34 = 1017.9 | H 35 = 1025.1 |
| H 36 = 1031.3 | H 37 = 1036.6 | H 38 = 1041.1 | H 39 = 1044.9 | H 40 = 1048.1 |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0.55

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 1 LOC=55 T:NA(IN)=610F T:NA(OUT)=1050F
A21=23.811 A22= 79.573 A23=107.70 A24= 83.891 A25=44.105

ITER NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = 0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 844.24 |
| DT M-N = 23.811 | DT1 = 79.573 | DT P-N = 107.70 | DT P-M = 83.891 | DT2 = 44.105 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 613.22 | M 1 = 616.67 | M 2 = 620.79 | M 3 = 625.67 | M 4 = 631.39 |
| M 5 = 638.04 | M 6 = 645.68 | M 7 = 654.36 | M 8 = 664.15 | M 9 = 675.05 |
| M 10 = 687.09 | M 11 = 700.24 | M 12 = 714.46 | M 13 = 729.69 | M 14 = 745.82 |
| M 15 = 762.75 | M 16 = 780.33 | M 17 = 798.61 | M 18 = 816.80 | M 19 = 835.33 |
| M 20 = 853.81 | M 21 = 872.05 | M 22 = 889.88 | M 23 = 907.12 | M 24 = 923.63 |
| M 25 = 939.27 | M 26 = 953.95 | M 27 = 967.59 | M 28 = 980.12 | M 29 = 991.52 |
| M 30 = 1001.8 | M 31 = 1011.0 | M 32 = 1019.0 | M 33 = 1026.1 | M 34 = 1032.2 |
| M 35 = 1037.4 | M 36 = 1041.8 | M 37 = 1045.6 | M 38 = 1048.6 | M 39 = 1051.2 |
| M 40 = 1053.2 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 624.58 | P 1 = 630.46 | P 2 = 637.39 | P 3 = 645.45 | P 4 = 654.72 |
| P 5 = 665.27 | P 6 = 677.16 | P 7 = 690.40 | P 8 = 704.98 | P 9 = 720.86 |
| P 10 = 737.97 | P 11 = 756.19 | P 12 = 775.38 | P 13 = 795.35 | P 14 = 815.89 |
| P 15 = 836.79 | P 16 = 857.77 | P 17 = 878.61 | P 18 = 899.03 | P 19 = 918.80 |
| P 20 = 937.70 | P 21 = 955.52 | P 22 = 972.10 | P 23 = 987.31 | P 24 = 1001.1 |
| P 25 = 1013.3 | P 26 = 1024.0 | P 27 = 1033.2 | P 28 = 1041.0 | P 29 = 1047.5 |
| P 30 = 1052.7 | P 31 = 1056.8 | P 32 = 1059.9 | P 33 = 1062.1 | P 34 = 1063.7 |
| P 35 = 1064.7 | P 36 = 1065.2 | P 37 = 1065.3 | P 38 = 1065.2 | P 39 = 1065.0 |
| P 40 = 1064.6 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 618.61 | G 1 = 623.21 | G 2 = 628.66 | G 3 = 635.05 | G 4 = 642.46 |
| | | | | |
| G 5 = 650.96 | G 6 = 660.61 | G 7 = 671.45 | G 8 = 683.51 | G 9 = 696.78 |
| G 10 = 711.22 | G 11 = 726.78 | G 12 = 743.35 | G 13 = 760.83 | G 14 = 779.06 |
| G 15 = 797.86 | G 16 = 817.06 | G 17 = 836.44 | G 18 = 855.80 | G 19 = 874.92 |
| G 20 = 893.60 | G 21 = 911.64 | G 22 = 928.87 | G 23 = 945.15 | G 24 = 960.35 |
| G 25 = 974.38 | G 26 = 987.18 | G 27 = 998.73 | G 28 = 1009.0 | G 29 = 1018.1 |
| G 30 = 1025.9 | G 31 = 1032.7 | G 32 = 1038.4 | G 33 = 1043.2 | G 34 = 1047.1 |
| G 35 = 1050.3 | G 36 = 1052.9 | G 37 = 1054.9 | G 38 = 1056.5 | G 39 = 1057.7 |
| G 40 = 1058.6 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 610.12 | H 2 = 612.91 | H 3 = 616.29 | H 4 = 620.33 | H 5 = 625.12 |
| H 6 = 630.74 | H 7 = 637.27 | H 8 = 644.78 | H 9 = 653.33 | H 10 = 662.96 |
| H 11 = 673.70 | H 12 = 685.57 | H 13 = 698.55 | H 14 = 712.59 | H 15 = 727.64 |
| H 16 = 743.61 | H 17 = 760.37 | H 18 = 777.80 | H 19 = 795.74 | H 20 = 814.02 |
| H 21 = 832.46 | H 22 = 850.88 | H 23 = 869.08 | H 24 = 886.90 | H 25 = 904.16 |
| H 26 = 920.72 | H 27 = 936.44 | H 28 = 951.23 | H 29 = 964.98 | H 30 = 977.64 |
| H 31 = 989.22 | H 32 = 995.67 | H 33 = 1009.0 | H 34 = 1017.3 | H 35 = 1024.5 |
| H 36 = 1030.8 | H 37 = 1036.2 | H 38 = 1040.8 | H 39 = 1044.6 | H 40 = 1047.8 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0.65

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 1 LOC=65 T:NA(IN)=610F T:NA(OUT)=1050F
A21=26.333 A22= 88.017 A23=119.43 A24= 93.102 A25=49.094

ITER NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|-------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT = 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 845.75 |
| JT M-N = 26.333 | DT1 = 88.017 | DT P-N = 119.43 | DT P-M = 93.102 | DT2 = 49.094 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 613.56 | M 1 = 617.08 | M 2 = 621.29 | M 3 = 626.26 | M 4 = 632.10 |
| M 5 = 638.86 | M 6 = 646.62 | M 7 = 655.45 | M 8 = 665.37 | M 9 = 676.43 |
| M 10 = 688.62 | M 11 = 701.92 | M 12 = 716.29 | M 13 = 731.66 | M 14 = 747.93 |
| M 15 = 764.98 | M 16 = 782.66 | M 17 = 800.82 | M 18 = 819.27 | M 19 = 837.84 |
| M 20 = 856.33 | M 21 = 874.56 | M 22 = 892.35 | M 23 = 909.53 | M 24 = 925.95 |
| M 25 = 941.50 | M 26 = 956.06 | M 27 = 969.56 | M 28 = 981.95 | M 29 = 993.20 |
| M 30 = 1003.3 | M 31 = 1012.3 | M 32 = 1020.3 | M 33 = 1027.2 | M 34 = 1033.1 |
| M 35 = 1038.2 | M 36 = 1042.5 | M 37 = 1046.2 | M 38 = 1049.1 | M 39 = 1051.6 |
| M 40 = 1053.6 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| = 626.16 | P 1 = 632.39 | P 2 = 639.71 | P 3 = 648.21 | P 4 = 657.98 |
| = 669.08 | P 6 = 681.56 | P 7 = 695.44 | P 8 = 710.69 | P 9 = 727.27 |
| P 10 = 745.09 | P 11 = 764.02 | P 12 = 783.90 | P 13 = 804.53 | P 14 = 825.69 |
| P 15 = 847.14 | P 16 = 868.60 | P 17 = 889.82 | P 18 = 910.53 | P 19 = 930.47 |
| P 20 = 949.43 | P 21 = 967.19 | P 22 = 983.60 | P 23 = 998.53 | P 24 = 1011.9 |
| P 25 = 1023.7 | P 26 = 1033.8 | P 27 = 1042.4 | P 28 = 1049.6 | P 29 = 1055.3 |
| P 30 = 1059.8 | P 31 = 1063.2 | P 32 = 1065.6 | P 33 = 1067.2 | P 34 = 1068.1 |
| P 35 = 1068.5 | P 36 = 1068.4 | P 37 = 1068.1 | P 38 = 1067.6 | P 39 = 1066.9 |
| P 40 = 1066.2 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 619.52 | G 1 = 624.32 | G 2 = 630.00 | G 3 = 636.64 | G 4 = 644.33 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 653.15 | G 6 = 663.14 | G 7 = 674.35 | G 8 = 686.80 | G 9 = 700.46 |
| G 10 = 715.31 | G 11 = 731.28 | G 12 = 748.25 | G 13 = 766.11 | G 14 = 784.69 |
| G 15 = 803.82 | G 16 = 823.24 | G 17 = 842.89 | G 18 = 862.61 | G 19 = 881.63 |
| G 20 = 900.34 | G 21 = 918.35 | G 22 = 935.49 | G 23 = 951.60 | G 24 = 966.58 |
| G 25 = 980.33 | G 26 = 992.82 | G 27 = 1004.0 | G 28 = 1013.9 | G 29 = 1022.6 |
| G 30 = 1030.0 | G 31 = 1036.4 | G 32 = 1041.7 | G 33 = 1046.1 | G 34 = 1049.7 |
| G 35 = 1052.5 | G 36 = 1054.8 | G 37 = 1056.5 | G 38 = 1057.8 | G 39 = 1058.8 |
| G 40 = 1059.5 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 609.84 | H 2 = 612.58 | H 3 = 615.89 | H 4 = 619.86 | H 5 = 624.57 |
| H 6 = 630.11 | H 7 = 636.54 | H 8 = 643.95 | H 9 = 652.40 | H 10 = 661.93 |
| H 11 = 672.57 | H 12 = 684.34 | H 13 = 697.22 | H 14 = 711.17 | H 15 = 726.14 |
| H 16 = 742.04 | H 17 = 758.75 | H 18 = 776.14 | H 19 = 794.05 | H 20 = 812.32 |
| H 21 = 830.77 | H 22 = 849.21 | H 23 = 867.46 | H 24 = 885.33 | H 25 = 902.66 |
| H 26 = 919.30 | H 27 = 935.11 | H 28 = 949.99 | H 29 = 963.85 | H 30 = 976.63 |
| H 31 = 988.30 | H 32 = 998.84 | H 33 = 1008.3 | H 34 = 1016.6 | H 35 = 1024.0 |
| H 36 = 1030.3 | H 37 = 1035.8 | H 38 = 1040.4 | H 39 = 1044.3 | H 40 = 1047.6 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0.75

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 1 LOC=0.75 T:NA(IN)=610F T:NA(OUT)=1050F
A21=28.855 A22= 96.461 A23=131.17 A24=102.31 A25=54.084

ITER NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = 0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 847.26 |
| DT M-N = 28.855 | DT1 = 96.461 | DT P-N = 131.17 | DT P-M = 102.31 | DT2 = 54.084 |
| N = 0 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | N = 0 | N = 0 | N = 0 | N = 0 |
| M = 0 | M 1 = 617.50 | M 2 = 621.79 | M 3 = 626.86 | M 4 = 632.80 |
| M 5 = 639.68 | M 6 = 647.57 | M 7 = 656.53 | M 8 = 666.60 | M 9 = 677.81 |
| M 10 = 690.15 | M 11 = 703.61 | M 12 = 718.13 | M 13 = 733.64 | M 14 = 750.04 |
| M 15 = 767.21 | M 16 = 784.99 | M 17 = 803.23 | M 18 = 821.75 | M 19 = 840.35 |
| M 20 = 858.85 | M 21 = 877.07 | M 22 = 894.82 | M 23 = 911.94 | M 24 = 928.28 |
| M 25 = 943.72 | M 26 = 958.17 | M 27 = 971.53 | M 28 = 983.78 | M 29 = 994.89 |
| M 30 = 1006.9 | M 31 = 1013.7 | M 32 = 1021.5 | M 33 = 1028.3 | M 34 = 1034.1 |
| M 35 = 1039.1 | M 36 = 1043.2 | M 37 = 1046.7 | M 38 = 1049.6 | M 39 = 1052.0 |
| M 40 = 1053.9 | M = 0 | M = 0 | M = 0 | M = 0 |
| P = 0 | P 1 = 634.32 | P 2 = 642.03 | P 3 = 650.98 | P 4 = 661.24 |
| P 5 = 672.89 | P 6 = 685.97 | P 7 = 700.48 | P 8 = 716.40 | P 9 = 733.68 |
| P 10 = 752.21 | P 11 = 771.85 | P 12 = 792.42 | P 13 = 813.72 | P 14 = 835.50 |
| P 15 = 857.50 | P 16 = 879.44 | P 17 = 901.04 | P 18 = 922.04 | P 19 = 942.16 |
| P 20 = 961.17 | P 21 = 978.87 | P 22 = 995.11 | P 23 = 1009.8 | P 24 = 1022.7 |
| P 25 = 1034.0 | P 26 = 1043.6 | P 27 = 1051.6 | P 28 = 1058.1 | P 29 = 1063.1 |
| P 30 = 1066.9 | P 31 = 1069.6 | P 32 = 1071.3 | P 33 = 1072.2 | P 34 = 1072.5 |
| P 35 = 1072.3 | P 36 = 1071.7 | P 37 = 1070.9 | P 38 = 1069.9 | P 39 = 1068.8 |
| P 40 = 1067.8 | P = 0 | P = 0 | P = 0 | P = 0 |
| G = 0 | G 1 = 625.43 | G 2 = 631.33 | G 3 = 638.23 | G 4 = 646.21 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 655.33 | G 6 = 665.67 | G 7 = 677.25 | G 8 = 690.08 | G 9 = 704.15 |
| G 10 = 719.40 | G 11 = 735.77 | G 12 = 753.15 | G 13 = 771.39 | G 14 = 790.32 |
| G 15 = 809.77 | G 16 = 829.51 | G 17 = 849.34 | G 18 = 869.02 | G 19 = 888.34 |
| G 20 = 907.09 | G 21 = 925.06 | G 22 = 942.10 | G 23 = 958.05 | G 24 = 972.80 |
| G 25 = 986.29 | G 26 = 998.45 | G 27 = 1009.3 | G 28 = 1018.8 | G 29 = 1027.1 |
| G 30 = 1034.1 | G 31 = 1040.0 | G 32 = 1045.0 | G 33 = 1049.0 | G 34 = 1052.2 |
| G 35 = 1054.7 | G 36 = 1056.7 | G 37 = 1058.1 | G 38 = 1059.2 | G 39 = 1059.9 |
| G 40 = 1060.4 | G = 0 | G = 0 | G = 0 | G = 0 |
| H 1 = 609.56 | H 2 = 612.24 | H 3 = 615.49 | H 4 = 619.39 | H 5 = 624.02 |
| H 6 = 629.47 | H 7 = 635.81 | H 8 = 643.13 | H 9 = 651.47 | H 10 = 660.90 |
| H 11 = 671.44 | H 12 = 683.10 | H 13 = 695.89 | H 14 = 709.75 | H 15 = 724.64 |
| H 16 = 740.47 | H 17 = 757.12 | H 18 = 774.47 | H 19 = 792.36 | H 20 = 810.62 |
| H 21 = 829.08 | H 22 = 847.54 | H 23 = 865.83 | H 24 = 883.76 | H 25 = 901.16 |
| H 26 = 917.88 | H 27 = 933.78 | H 28 = 948.76 | H 29 = 962.72 | H 30 = 975.60 |
| H 31 = 987.37 | H 32 = 998.01 | H 33 = 1007.5 | H 34 = 1016.0 | H 35 = 1023.4 |
| H 36 = 1029.8 | H 37 = 1035.4 | H 38 = 1040.1 | H 39 = 1044.1 | H 40 = 1047.4 |
| H = 0 | H = 0 | H = 0 | H = 0 | H = 0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: .85

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 1 LOC=.85 T:NA(IN)=610F T:NA(OUT)=1050F
 A21=31.377 A22=104.90 A23=142.90 A24=111.52 A25=59.074

ITER NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 848.77 |
| DT: M-N = 31.377 | DT1 = 104.90 | DT P-N = 142.90 | DT P-M = 111.52 | DT2 = 59.074 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 614.25 | M 1 = 617.91 | M 2 = 622.28 | M 3 = 627.45 | M 4 = 633.50 |
| M 5 = 640.50 | M 6 = 648.52 | M 7 = 657.61 | M 8 = 667.83 | M 9 = 679.19 |
| M 10 = 691.68 | M 11 = 705.29 | M 12 = 719.96 | M 13 = 735.61 | M 14 = 752.14 |
| M 15 = 769.43 | M 16 = 787.32 | M 17 = 805.64 | M 18 = 824.22 | M 19 = 842.86 |
| M 20 = 861.38 | M 21 = 879.58 | M 22 = 897.29 | M 23 = 914.35 | M 24 = 930.61 |
| M 25 = 945.95 | M 26 = 960.27 | M 27 = 973.51 | M 28 = 985.61 | M 29 = 996.57 |
| M 30 = 1006.4 | M 31 = 1015.1 | M 32 = 1022.7 | M 33 = 1029.3 | M 34 = 1035.0 |
| M 35 = 1039.9 | M 36 = 1043.9 | M 37 = 1047.3 | M 38 = 1050.1 | M 39 = 1052.4 |
| M 40 = 1054.2 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 629.34 | P 1 = 636.25 | P 2 = 644.35 | P 3 = 653.74 | P 4 = 664.51 |
| P 5 = 676.70 | P 6 = 690.37 | P 7 = 705.52 | P 8 = 722.11 | P 9 = 740.09 |
| P 10 = 759.32 | P 11 = 775.67 | P 12 = 800.94 | P 13 = 822.90 | P 14 = 845.30 |
| P 15 = 867.85 | P 16 = 890.27 | P 17 = 912.26 | P 18 = 933.53 | P 19 = 953.83 |
| P 20 = 972.90 | P 21 = 990.55 | P 22 = 1006.6 | P 23 = 1021.0 | P 24 = 1033.6 |
| P 25 = 1044.4 | P 26 = 1053.4 | P 27 = 1060.8 | P 28 = 1066.6 | P 29 = 1071.0 |
| P 30 = 1074.0 | P 31 = 1076.0 | P 32 = 1077.0 | P 33 = 1077.2 | P 34 = 1076.9 |
| P 35 = 1076.1 | P 36 = 1075.0 | P 37 = 1073.6 | P 38 = 1072.2 | P 39 = 1070.8 |
| P 40 = 1069.3 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 621.34 | G 1 = 626.54 | G 2 = 632.66 | G 3 = 639.82 | G 4 = 648.08 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 657.52 | G 6 = 668.20 | G 7 = 680.14 | G 8 = 693.36 | G 9 = 707.83 |
| G 10 = 723.49 | G 11 = 740.27 | G 12 = 758.04 | G 13 = 776.66 | G 14 = 795.95 |
| G 15 = 815.72 | G 16 = 835.74 | G 17 = 855.78 | G 18 = 875.63 | G 19 = 895.05 |
| G 20 = 913.83 | G 21 = 931.77 | G 22 = 948.70 | G 23 = 964.49 | G 24 = 979.03 |
| G 25 = 992.24 | G 26 = 1004.1 | G 27 = 1014.6 | G 28 = 1023.7 | G 29 = 1031.6 |
| G 30 = 1038.2 | G 31 = 1043.7 | G 32 = 1048.2 | G 33 = 1051.9 | G 34 = 1054.7 |
| G 35 = 1056.9 | G 36 = 1058.5 | G 37 = 1059.7 | G 38 = 1060.5 | G 39 = 1061.0 |
| G 40 = 1061.3 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 609.28 | H 2 = 611.91 | H 3 = 615.09 | H 4 = 618.91 | H 5 = 623.47 |
| H 6 = 628.83 | H 7 = 635.08 | H 8 = 642.30 | H 9 = 650.54 | H 10 = 659.87 |
| H 11 = 670.30 | H 12 = 681.87 | H 13 = 694.56 | H 14 = 708.33 | H 15 = 723.14 |
| H 16 = 738.90 | H 17 = 755.50 | H 18 = 772.81 | H 19 = 790.67 | H 20 = 808.93 |
| H 21 = 827.39 | H 22 = 845.88 | H 23 = 864.21 | H 24 = 882.19 | H 25 = 899.66 |
| H 26 = 916.46 | H 27 = 932.45 | H 28 = 947.52 | H 29 = 961.58 | H 30 = 974.57 |
| H 31 = 986.44 | H 32 = 997.19 | H 33 = 1006.8 | H 34 = 1015.4 | H 35 = 1022.8 |
| H 36 = 1029.4 | H 37 = 1035.0 | H 38 = 1039.8 | H 39 = 1043.8 | H 40 = 1047.1 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 1

Solar Flux: REFERENCE
Orifices: YES
Sub-Panel: 1
Location x/L: 0.95
T(Na-inlet) = 610 F
T(Na-outlet) : 1050F

PANEL 1 LOC=0.95 T:NA(IN)=610F T:NA(OUT)=1050F
A21=33.899 A22=113.35 A23=154.63 A24=120.73 A25=64.063

| ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | CRITICAL NODE = 2 | | |
|--|------------------|-------------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 850.27 |
| DT M-N = 33.899 | DT1 = 113.35 | DT P-N = 154.63 | DT P-M = 120.73 | DT2 = 64.063 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 614.59 | M 1 = 618.33 | M 2 = 622.78 | M 3 = 628.05 | M 4 = 636.20 |
| M 5 = 641.31 | M 6 = 649.46 | M 7 = 658.70 | M 8 = 669.06 | M 9 = 680.56 |
| M 10 = 693.21 | M 11 = 706.97 | M 12 = 721.79 | M 13 = 737.58 | M 14 = 754.25 |
| M 15 = 771.66 | M 16 = 789.65 | M 17 = 808.05 | M 18 = 826.69 | M 19 = 845.37 |
| M 20 = 863.90 | M 21 = 882.09 | M 22 = 899.76 | M 23 = 916.76 | M 24 = 932.94 |
| M 25 = 948.17 | M 26 = 962.38 | M 27 = 975.48 | M 28 = 987.44 | M 29 = 998.25 |
| M 30 = 1007.9 | M 31 = 1016.5 | M 32 = 1023.9 | M 33 = 1030.4 | M 34 = 1036.0 |
| M 35 = 1040.7 | M 36 = 1044.7 | M 37 = 1047.9 | M 38 = 1050.6 | M 39 = 1052.8 |
| M 40 = 1054.6 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 630.93 | P 1 = 638.18 | P 2 = 646.68 | P 3 = 656.51 | P 4 = 667.77 |
| P 5 = 680.51 | P 6 = 694.77 | P 7 = 710.56 | P 8 = 727.82 | P 9 = 746.49 |
| P 10 = 766.44 | P 11 = 787.49 | P 12 = 809.46 | P 13 = 832.08 | P 14 = 855.09 |
| P 15 = 878.20 | P 16 = 901.10 | P 17 = 923.47 | P 18 = 945.03 | P 19 = 965.50 |
| P 20 = 984.63 | P 21 = 1002.2 | P 22 = 1018.1 | P 23 = 1032.2 | P 24 = 1044.4 |
| P 25 = 1054.7 | P 26 = 1063.2 | P 27 = 1070.0 | P 28 = 1075.1 | P 29 = 1078.8 |
| P 30 = 1081.1 | P 31 = 1082.4 | P 32 = 1082.7 | P 33 = 1082.3 | P 34 = 1081.3 |
| P 35 = 1079.9 | P 36 = 1078.2 | P 37 = 1076.4 | P 38 = 1074.5 | P 39 = 1072.7 |
| P 40 = 1070.9 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 622.26 | G 1 = 627.65 | G 2 = 634.00 | G 3 = 641.41 | G 4 = 649.96 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 659.71 | G 6 = 670.73 | G 7 = 683.04 | G 8 = 696.64 | G 9 = 711.51 |
| G 10 = 727.58 | G 11 = 744.77 | G 12 = 762.94 | G 13 = 781.94 | G 14 = 801.59 |
| G 15 = 821.67 | G 16 = 841.96 | G 17 = 862.23 | G 18 = 882.24 | G 19 = 901.74 |
| G 20 = 920.57 | G 21 = 938.48 | G 22 = 955.32 | G 23 = 970.94 | G 24 = 985.26 |
| G 25 = 998.19 | G 26 = 1009.7 | G 27 = 1019.8 | G 28 = 1028.6 | G 29 = 1036.1 |
| G 30 = 1042.3 | G 31 = 1047.4 | G 32 = 1051.5 | G 33 = 1054.8 | G 34 = 1057.3 |
| G 35 = 1059.1 | G 36 = 1060.4 | G 37 = 1061.3 | G 38 = 1061.8 | G 39 = 1062.1 |
| G 40 = 1062.3 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 609.00 | H 2 = 611.57 | H 3 = 614.69 | H 4 = 618.44 | H 5 = 622.91 |
| H 6 = 628.19 | H 7 = 634.35 | H 8 = 641.47 | H 9 = 649.61 | H 10 = 658.83 |
| H 11 = 669.17 | H 12 = 680.63 | H 13 = 693.22 | H 14 = 706.91 | H 15 = 721.64 |
| H 16 = 737.33 | H 17 = 753.87 | H 18 = 771.14 | H 19 = 788.98 | H 20 = 807.22 |
| H 21 = 825.70 | H 22 = 844.21 | H 23 = 862.58 | H 24 = 880.62 | H 25 = 898.16 |
| H 26 = 915.04 | H 27 = 931.12 | H 28 = 946.29 | H 29 = 960.45 | H 30 = 973.54 |
| H 31 = 985.51 | H 32 = 996.36 | H 33 = 1006.1 | H 34 = 1014.7 | H 35 = 1022.3 |
| H 36 = 1028.9 | H 37 = 1034.6 | H 38 = 1039.4 | H 39 = 1043.5 | H 40 = 1046.9 |
| = .0 | = .0 | = .0 | = .0 | = .0 |



PANEL TEMPERATURE DISTRIBUTION

CASE 1

SET 2 Subpanel 2

Solar Flux Distribution: REFERENCE

Orifices: Yes: Orificed so as to match tube flow rates to
reference flux distribution

Sodium Temperatures: T (Na-Inlet) = 610°F
T (Na-Outlet) = 1050°F (all tubes)

5370F/sjh

CASE # 1

Solar Flux: REFERENCE
 Orifices: YES
 Sub-Panel: 2
 Location x/L: 0.05
 T(Na-inlet) = 610 F
 T(Na-outlet) : 1050F

PANEL 2 LOC=05 T:NA(IN)=610F T:NA(OUT)=1050F
 A21=36.226 A22=121.15 A23=165.68 A24=129.46 A25=68.890

ITER NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 851.67 |
| DT M-N = 36.226 | DT1 = 121.15 | DT P-N = 165.68 | DT P-M = 129.46 | DT2 = 68.891 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | | | | |
| M = 614.90 | M 1 = 618.71 | M 2 = 623.24 | M 3 = 628.60 | M 4 = 634.85 |
| M 5 = 642.07 | M 6 = 650.34 | M 7 = 659.70 | M 8 = 670.19 | M 9 = 681.83 |
| M 10 = 694.62 | M 11 = 708.52 | M 12 = 723.48 | M 13 = 739.41 | M 14 = 756.19 |
| M 15 = 773.71 | M 16 = 791.79 | M 17 = 810.28 | M 18 = 828.97 | M 19 = 847.69 |
| M 20 = 866.23 | M 21 = 884.40 | M 22 = 902.05 | M 23 = 918.99 | M 24 = 935.09 |
| M 25 = 950.23 | M 26 = 964.32 | M 27 = 977.30 | M 28 = 989.13 | M 29 = 999.80 |
| M 30 = 1009.3 | M 31 = 1017.7 | M 32 = 1025.1 | M 33 = 1031.4 | M 34 = 1036.9 |
| M 35 = 1041.5 | M 36 = 1045.3 | M 37 = 1048.5 | M 38 = 1051.1 | M 39 = 1053.2 |
| M 40 = 1054.9 | | | | |
| P = 632.42 | P 1 = 640.00 | P 2 = 648.86 | P 3 = 659.11 | P 4 = 670.84 |
| P 5 = 684.10 | P 6 = 698.92 | P 7 = 715.30 | P 8 = 733.20 | P 9 = 752.52 |
| P 10 = 773.14 | P 11 = 794.86 | P 12 = 817.48 | P 13 = 840.73 | P 14 = 864.32 |
| P 15 = 887.95 | P 16 = 911.30 | P 17 = 934.04 | P 18 = 955.86 | P 19 = 976.49 |
| P 20 = 995.68 | P 21 = 1013.2 | P 22 = 1028.9 | P 23 = 1042.7 | P 24 = 1054.6 |
| P 25 = 1064.5 | P 26 = 1072.5 | P 27 = 1078.6 | P 28 = 1083.1 | P 29 = 1086.1 |
| P 30 = 1087.8 | P 31 = 1088.4 | P 32 = 1088.1 | P 33 = 1087.0 | P 34 = 1085.4 |
| P 35 = 1083.5 | P 36 = 1081.3 | P 37 = 1079.0 | P 38 = 1076.7 | P 39 = 1074.5 |
| P 40 = 1072.4 | | | | |
| G = 623.10 | G 1 = 628.67 | G 2 = 635.23 | G 3 = 642.88 | G 4 = 651.69 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 661.74 | G 6 = 673.07 | G 7 = 685.72 | G 8 = 699.67 | G 9 = 714.91 |
| G 10 = 731.36 | G 11 = 748.92 | G 12 = 767.46 | G 13 = 786.82 | G 14 = 806.79 |
| G 15 = 827.17 | G 16 = 847.71 | G 17 = 868.19 | G 18 = 888.35 | G 19 = 907.96 |
| G 20 = 926.80 | G 21 = 944.68 | G 22 = 961.42 | G 23 = 976.90 | G 24 = 991.00 |
| G 25 = 1003.7 | G 26 = 1014.9 | G 27 = 1024.7 | G 28 = 1033.1 | G 29 = 1040.2 |
| G 30 = 1046.1 | G 31 = 1050.8 | G 32 = 1054.6 | G 33 = 1057.4 | G 34 = 1059.6 |
| G 35 = 1061.1 | G 36 = 1062.1 | G 37 = 1062.8 | G 38 = 1063.1 | G 39 = 1063.2 |
| G 40 = 1063.1 | | | | |
| H 1 = 608.75 | H 2 = 611.26 | H 3 = 614.32 | H 4 = 618.00 | H 5 = 622.40 |
| H 6 = 627.60 | H 7 = 633.68 | H 8 = 640.70 | H 9 = 648.75 | H 10 = 657.88 |
| H 11 = 668.12 | H 12 = 679.49 | H 13 = 691.99 | H 14 = 705.60 | H 15 = 720.25 |
| H 16 = 735.88 | H 17 = 752.37 | H 18 = 769.60 | H 19 = 787.41 | H 20 = 805.65 |
| H 21 = 824.13 | H 22 = 842.67 | H 23 = 861.08 | H 24 = 879.17 | H 25 = 896.77 |
| H 26 = 913.73 | H 27 = 929.89 | H 28 = 945.15 | H 29 = 959.60 | H 30 = 972.58 |
| H 31 = 984.65 | H 32 = 995.59 | H 33 = 1005.4 | H 34 = 1014.1 | H 35 = 1021.8 |
| H 36 = 1028.5 | H 37 = 1034.2 | H 38 = 1039.1 | H 39 = 1043.2 | H 40 = 1046.7 |
| H 40 = .0 | | | | |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 2

Location x/L: 0.15

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 2 LOC = .15 T:NA(IN)=610F T:NA(OUT)=1050F
A21=38.357 A22=128.30 A23=176.05 A24=137.69 A25=73.555

| ITER NO. 2 | | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|-------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT = 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 852.94 | | | | | |
| DT M-N = 38.357 | DT1 = 128.30 | DT P-N = 176.05 | DT P-M = 137.69 | DT2 = 72.555 | | | | | |
| N = .0 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 | | | | | |
| N 5 = 610.00 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 | | | | | |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 | | | | | |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 | | | | | |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 | | | | | |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 | | | | | |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 | | | | | |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 | | | | | |
| N 40 = 1050.0 | N = .0 | N = .0 | N = .0 | N = .0 | | | | | |
| M = 615.19 | M 1 = 619.06 | M 2 = 623.67 | M 3 = 629.10 | M 4 = 635.44 | | | | | |
| M 5 = 642.76 | M 6 = 651.14 | M 7 = 660.61 | M 8 = 671.23 | M 9 = 683.00 | | | | | |
| M 10 = 695.91 | M 11 = 709.94 | M 12 = 725.03 | M 13 = 741.07 | M 14 = 757.97 | | | | | |
| M 15 = 775.59 | M 16 = 793.76 | M 17 = 812.31 | M 18 = 831.06 | M 19 = 849.81 | | | | | |
| M 20 = 868.36 | M 21 = 886.52 | M 22 = 904.13 | M 23 = 921.02 | M 24 = 937.05 | | | | | |
| M 25 = 952.11 | M 26 = 966.10 | M 27 = 978.97 | M 28 = 990.68 | M 29 = 1001.2 | | | | | |
| M 30 = 1010.6 | M 31 = 1018.9 | M 32 = 1026.1 | M 33 = 1032.3 | M 34 = 1037.7 | | | | | |
| M 35 = 1042.1 | M 36 = 1045.9 | M 37 = 1049.0 | M 38 = 1051.5 | M 39 = 1053.6 | | | | | |
| M 40 = 1055.2 | M = .0 | M = .0 | M = .0 | M = .0 | | | | | |
| P = 633.83 | P 1 = 641.71 | P 2 = 650.92 | P 3 = 661.56 | P 4 = 673.72 | | | | | |
| P 5 = 687.46 | P 6 = 702.81 | P 7 = 719.76 | P 8 = 738.25 | P 9 = 758.19 | | | | | |
| P 10 = 729.43 | P 11 = 801.78 | P 12 = 825.01 | P 13 = 848.85 | P 14 = 872.99 | | | | | |
| P 15 = 897.10 | P 16 = 920.87 | P 17 = 943.95 | P 18 = 966.03 | P 19 = 986.81 | | | | | |
| P 20 = 1006.0 | P 21 = 1023.5 | P 22 = 1039.1 | P 23 = 1052.7 | P 24 = 1064.2 | | | | | |
| P 25 = 1073.6 | P 26 = 1081.1 | P 27 = 1086.7 | P 28 = 1090.7 | P 29 = 1093.1 | | | | | |
| P 30 = 1094.1 | P 31 = 1094.1 | P 32 = 1093.1 | P 33 = 1091.5 | P 34 = 1089.3 | | | | | |
| P 35 = 1086.8 | P 36 = 1084.2 | P 37 = 1081.4 | P 38 = 1078.8 | P 39 = 1076.2 | | | | | |
| P 40 = 1073.8 | P = .0 | P = .0 | P = .0 | P = .0 | | | | | |
| G = 623.87 | G 1 = 629.61 | G 2 = 636.36 | G 3 = 644.22 | G 4 = 653.27 | | | | | |
| G 5 = 663.59 | G 6 = 675.21 | G 7 = 688.17 | G 8 = 702.45 | G 9 = 718.03 | | | | | |
| G 10 = 734.82 | G 11 = 752.73 | G 12 = 771.61 | G 13 = 791.28 | G 14 = 811.56 | | | | | |
| G 15 = 832.20 | G 16 = 852.98 | G 17 = 873.64 | G 18 = 893.96 | G 19 = 913.64 | | | | | |
| G 20 = 932.51 | G 21 = 950.35 | G 22 = 967.01 | G 23 = 982.35 | G 24 = 996.27 | | | | | |
| G 25 = 1008.7 | G 26 = 1019.7 | G 27 = 1029.2 | G 28 = 1037.3 | G 29 = 1044.0 | | | | | |
| G 30 = 1049.5 | G 31 = 1053.9 | G 32 = 1057.3 | G 33 = 1059.9 | G 34 = 1061.7 | | | | | |
| G 35 = 1063.0 | G 36 = 1063.7 | G 37 = 1064.1 | G 38 = 1064.2 | G 39 = 1064.1 | | | | | |
| G 40 = 1063.9 | G = .0 | G = .0 | G = .0 | G = .0 | | | | | |
| H 1 = 608.51 | H 2 = 610.97 | H 3 = 613.98 | H 4 = 617.60 | H 5 = 621.94 | | | | | |
| H 6 = 627.06 | H 7 = 633.06 | H 8 = 640.00 | H 9 = 647.97 | H 10 = 657.00 | | | | | |
| H 11 = 667.16 | H 12 = 678.44 | H 13 = 690.86 | H 14 = 704.39 | H 15 = 718.98 | | | | | |
| H 16 = 734.54 | H 17 = 750.99 | H 18 = 768.18 | H 19 = 785.98 | H 20 = 804.21 | | | | | |
| H 21 = 822.69 | H 22 = 841.25 | H 23 = 859.70 | H 24 = 877.84 | H 25 = 895.50 | | | | | |
| H 26 = 912.52 | H 27 = 928.76 | H 28 = 944.10 | H 29 = 958.44 | H 30 = 971.71 | | | | | |
| H 31 = 983.86 | H 32 = 994.89 | H 33 = 1004.8 | H 34 = 1013.6 | H 35 = 1021.3 | | | | | |
| H 36 = 1028.1 | H 37 = 1033.9 | H 38 = 1038.8 | H 39 = 1043.0 | H 40 = 1046.5 | | | | | |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 | | | | | |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 2

Location x/L: .25

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 2 LOC=.25 T:NA(IN)=610F T:NA(OUT)=1050F
A21=40.488 A22=135.46 A23=186.41 A24=145.92 A25=78.221

ITER. NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 854.22 |
| DT M-N = 40.488 | DT1 = 135.46 | DT P-N = 186.41 | DT P-M = 145.92 | DT2 = 78.221 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | N 40 = 1050.0 | N 40 = 1050.0 | N 40 = 1050.0 | N 40 = 1050.0 |
| M = 615.48 | M 1 = 619.41 | M 2 = 624.09 | M 3 = 629.60 | M 4 = 636.03 |
| M 5 = 643.45 | M 6 = 651.94 | M 7 = 661.53 | M 8 = 672.26 | M 9 = 684.16 |
| M 10 = 697.21 | M 11 = 711.36 | M 12 = 726.57 | M 13 = 742.74 | M 14 = 759.75 |
| M 15 = 777.47 | M 16 = 795.73 | M 17 = 816.35 | M 18 = 833.15 | M 19 = 851.93 |
| M 20 = 870.49 | M 21 = 888.65 | M 22 = 906.22 | M 23 = 923.06 | M 24 = 939.02 |
| M 25 = 953.99 | M 26 = 967.88 | M 27 = 980.64 | M 28 = 992.23 | M 29 = 1002.6 |
| M 30 = 1011.9 | M 31 = 1020.1 | M 32 = 1027.2 | M 33 = 1033.3 | M 34 = 1038.5 |
| M 35 = 1042.8 | M 36 = 1046.5 | M 37 = 1049.5 | M 38 = 1051.9 | M 39 = 1053.9 |
| M 40 = 1055.5 | M 40 = 1055.5 | M 40 = 1055.5 | M 40 = 1055.5 | M 40 = 1055.5 |
| P = 635.23 | P 1 = 643.41 | P 2 = 652.97 | P 3 = 664.00 | P 4 = 676.60 |
| P 5 = 690.83 | P 6 = 706.70 | P 7 = 724.21 | P 8 = 743.29 | P 9 = 763.84 |
| P 10 = 785.71 | P 11 = 808.69 | P 12 = 832.53 | P 13 = 856.96 | P 14 = 881.64 |
| P 15 = 906.25 | P 16 = 930.43 | P 17 = 953.85 | P 18 = 976.18 | P 19 = 997.12 |
| P 20 = 1016.4 | P 21 = 1033.8 | P 22 = 1049.3 | P 23 = 1062.6 | P 24 = 1073.7 |
| P 25 = 1082.8 | P 26 = 1089.8 | P 27 = 1094.9 | P 28 = 1098.2 | P 29 = 1100.0 |
| P 30 = 1100.4 | P 31 = 1099.7 | P 32 = 1098.2 | P 33 = 1095.9 | P 34 = 1093.2 |
| P 35 = 1090.2 | P 36 = 1087.1 | P 37 = 1083.9 | P 38 = 1080.8 | P 39 = 1077.9 |
| P 40 = 1075.2 | P 40 = 1075.2 | P 40 = 1075.2 | P 40 = 1075.2 | P 40 = 1075.2 |
| G = 624.65 | G 1 = 630.55 | G 2 = 637.49 | G 3 = 645.57 | G 4 = 654.86 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 665.44 | G 6 = 677.35 | G 7 = 690.62 | G 8 = 705.23 | G 9 = 721.15 |
| G 10 = 738.29 | G 11 = 756.54 | G 12 = 775.75 | G 13 = 795.75 | G 14 = 816.33 |
| G 15 = 837.24 | G 16 = 858.25 | G 17 = 879.10 | G 18 = 899.56 | G 19 = 919.32 |
| G 20 = 938.22 | G 21 = 956.04 | G 22 = 972.61 | G 23 = 987.81 | G 24 = 1001.5 |
| G 25 = 1013.8 | G 26 = 1024.5 | G 27 = 1033.7 | G 28 = 1041.4 | G 29 = 1047.8 |
| G 30 = 1053.0 | G 31 = 1057.0 | G 32 = 1060.1 | G 33 = 1062.4 | G 34 = 1063.9 |
| G 35 = 1064.8 | G 36 = 1065.3 | G 37 = 1065.5 | G 38 = 1065.3 | G 39 = 1065.0 |
| G 40 = 1064.6 | G 40 = 1064.6 | G 40 = 1064.6 | G 40 = 1064.6 | G 40 = 1064.6 |
| H 1 = 608.27 | H 2 = 610.68 | H 3 = 613.63 | H 4 = 617.20 | H 5 = 621.46 |
| H 6 = 626.52 | H 7 = 632.43 | H 8 = 639.30 | H 9 = 647.18 | H 10 = 656.13 |
| H 11 = 666.19 | H 12 = 677.39 | H 13 = 689.73 | H 14 = 703.18 | H 15 = 717.70 |
| H 16 = 733.21 | H 17 = 749.60 | H 18 = 766.76 | H 19 = 784.53 | H 20 = 802.76 |
| H 21 = 821.25 | H 22 = 839.83 | H 23 = 858.31 | H 24 = 876.50 | H 25 = 894.22 |
| H 26 = 911.31 | H 27 = 927.63 | H 28 = 943.05 | H 29 = 957.47 | H 30 = 970.83 |
| H 31 = 983.07 | H 32 = 994.18 | H 33 = 1004.2 | H 34 = 1013.0 | H 35 = 1020.8 |
| H 36 = 1027.7 | H 37 = 1033.5 | H 38 = 1038.5 | H 39 = 1042.8 | H 40 = 1046.3 |
| H 40 = 1046.3 | H 40 = 1046.3 | H 40 = 1046.3 | H 40 = 1046.3 | H 40 = 1046.3 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 2

Location x/L: FULL

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

PANEL 2 LOC=FULL T:NA(IN)=610F T:NA(OUT)=1050F
A21=41.740 A22=139.66 A23=192.50 A24=150.76 A25=80.960

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 854.96 |
| DT M-N = 41.740 | DT1 = 139.66 | DT P-N = 192.50 | DT P-M = 150.76 | DT2 = 80.960 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | N = .0 | N = .0 | N = .0 | N = .0 |
| M = 615.65 | M 1 = 619.62 | M 2 = 624.34 | M 3 = 629.90 | M 4 = 636.38 |
| M 5 = 643.86 | M 6 = 652.40 | M 7 = 662.06 | M 8 = 672.87 | M 9 = 684.84 |
| M 10 = 697.97 | M 11 = 712.20 | M 12 = 727.48 | M 13 = 743.72 | M 14 = 760.80 |
| M 15 = 778.58 | M 16 = 796.89 | M 17 = 815.55 | M 18 = 834.38 | M 19 = 853.17 |
| M 20 = 871.74 | M 21 = 889.89 | M 22 = 907.45 | M 23 = 924.26 | M 24 = 940.18 |
| M 25 = 955.09 | M 26 = 968.93 | M 27 = 981.62 | M 28 = 993.14 | M 29 = 1003.5 |
| M 30 = 1012.7 | M 31 = 1020.7 | M 32 = 1027.8 | M 33 = 1033.8 | M 34 = 1038.9 |
| M 35 = 1043.2 | M 36 = 1046.8 | M 37 = 1049.8 | M 38 = 1052.2 | M 39 = 1054.1 |
| M 40 = 1055.6 | M = .0 | M = .0 | M = .0 | M = .0 |
| P = 636.05 | P 1 = 644.41 | P 2 = 654.17 | P 3 = 665.44 | P 4 = 678.30 |
| P 5 = 692.80 | P 6 = 708.99 | P 7 = 726.82 | P 8 = 746.26 | P 9 = 767.17 |
| P 10 = 789.41 | P 11 = 812.75 | P 12 = 836.96 | P 13 = 861.72 | P 14 = 886.73 |
| P 15 = 911.62 | P 16 = 936.05 | P 17 = 959.68 | P 18 = 982.15 | P 19 = 1003.2 |
| P 20 = 1022.5 | P 21 = 1039.9 | P 22 = 1055.2 | P 23 = 1068.4 | P 24 = 1079.3 |
| P 25 = 1088.1 | P 26 = 1094.9 | P 27 = 1099.6 | P 28 = 1102.6 | P 29 = 1104.0 |
| P 30 = 1104.1 | P 31 = 1103.1 | P 32 = 1101.1 | P 33 = 1098.6 | P 34 = 1095.5 |
| P 35 = 1092.2 | P 36 = 1088.7 | P 37 = 1085.3 | P 38 = 1082.0 | P 39 = 1078.9 |
| P 40 = 1076.1 | P = .0 | P = .0 | P = .0 | P = .0 |
| G = 625.10 | G 1 = 631.10 | G 2 = 638.15 | G 3 = 646.36 | G 4 = 655.79 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 666.53 | G 6 = 678.61 | G 7 = 692.06 | G 8 = 706.86 | G 9 = 722.98 |
| G 10 = 740.32 | G 11 = 758.77 | G 12 = 778.19 | G 13 = 798.38 | G 14 = 819.13 |
| G 15 = 840.20 | G 16 = 861.35 | G 17 = 882.31 | G 18 = 902.82 | G 19 = 922.45 |
| G 20 = 941.57 | G 21 = 959.37 | G 22 = 975.90 | G 23 = 991.01 | G 24 = 1004.6 |
| G 25 = 1016.7 | G 26 = 1027.3 | G 27 = 1036.3 | G 28 = 1043.8 | G 29 = 1050.1 |
| G 30 = 1055.0 | G 31 = 1058.9 | G 32 = 1061.7 | G 33 = 1063.8 | G 34 = 1065.1 |
| G 35 = 1065.9 | G 36 = 1066.2 | G 37 = 1066.2 | G 38 = 1066.0 | G 39 = 1065.6 |
| G 40 = 1065.1 | G = .0 | G = .0 | G = .0 | G = .0 |
| H 1 = 608.13 | H 2 = 610.52 | H 3 = 613.43 | H 4 = 616.96 | H 5 = 621.19 |
| H 6 = 626.20 | H 7 = 632.07 | H 8 = 638.88 | H 9 = 646.71 | H 10 = 655.61 |
| H 11 = 665.62 | H 12 = 676.77 | H 13 = 689.06 | H 14 = 702.47 | H 15 = 716.95 |
| H 16 = 732.42 | H 17 = 748.79 | H 18 = 765.93 | H 19 = 783.69 | H 20 = 801.91 |
| H 21 = 820.41 | H 22 = 839.00 | H 23 = 857.50 | H 24 = 875.72 | H 25 = 893.47 |
| H 26 = 910.60 | H 27 = 926.96 | H 28 = 942.43 | H 29 = 956.90 | H 30 = 970.31 |
| H 31 = 982.61 | H 32 = 993.77 | H 33 = 1003.8 | H 34 = 1012.7 | H 35 = 1020.6 |
| H 36 = 1027.4 | H 37 = 1033.3 | H 38 = 1038.4 | H 39 = 1042.6 | H 40 = 1046.2 |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

(Q/A)CL = 0.225 MW/M2 T:NA(IN) = 610F T:NA(OUT) = 1050F
A21= 9.94 A22= 33.133 A23= 43.17 A24= 33.23 A25= 16.662

ITER NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = 0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 835.94 |
| DT M-N = 9.9400 | DTI = 33.133 | DT P-N = 43.170 | DT P-M = 33.230 | DT2 = 16.662 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.66 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | N = 0 | N = 0 | N = 0 | N = 0 |
| M = 611.35 | M 1 = 614.39 | M 2 = 618.04 | M 3 = 622.40 | M 4 = 627.54 |
| M 5 = 633.54 | M 6 = 640.47 | M 7 = 648.40 | M 8 = 657.39 | M 9 = 667.48 |
| M 10 = 678.68 | M 11 = 690.99 | M 12 = 704.39 | M 13 = 718.83 | M 14 = 734.24 |
| M 15 = 750.51 | M 16 = 767.53 | M 17 = 785.15 | M 18 = 803.21 | M 19 = 821.53 |
| M 20 = 839.94 | M 21 = 858.25 | M 22 = 876.28 | M 23 = 893.86 | M 24 = 910.82 |
| M 25 = 927.03 | M 26 = 942.37 | M 27 = 956.73 | M 28 = 970.04 | M 29 = 982.27 |
| M 30 = 993.38 | M 31 = 1003.4 | M 32 = 1012.3 | M 33 = 1020.1 | M 34 = 1027.0 |
| M 35 = 1032.9 | M 36 = 1038.0 | M 37 = 1042.3 | M 38 = 1045.9 | M 39 = 1048.9 |
| M 40 = 1051.3 | M = 0 | M = 0 | M = 0 | M = 0 |
| P = 615.84 | P 1 = 619.85 | P 2 = 624.62 | P 3 = 630.23 | P 4 = 636.78 |
| P 5 = 644.32 | P 6 = 652.94 | P 7 = 662.68 | P 8 = 673.57 | P 9 = 685.63 |
| P 10 = 698.83 | P 11 = 713.15 | P 12 = 728.52 | P 13 = 744.84 | P 14 = 761.99 |
| P 15 = 779.84 | P 16 = 798.21 | P 17 = 816.92 | P 18 = 835.78 | P 19 = 854.59 |
| P 20 = 873.17 | P 21 = 891.31 | P 22 = 908.85 | P 23 = 925.62 | P 24 = 941.50 |
| P 25 = 956.36 | P 26 = 970.12 | P 27 = 982.74 | P 28 = 994.17 | P 29 = 1004.4 |
| P 30 = 1013.5 | P 31 = 1021.5 | P 32 = 1028.5 | P 33 = 1034.4 | P 34 = 1039.5 |
| P 35 = 1043.7 | P 36 = 1047.2 | P 37 = 1050.1 | P 38 = 1052.5 | P 39 = 1054.3 |
| P 40 = 1055.8 | P = 0 | P = 0 | P = 0 | P = 0 |
| G = 613.59 | G 1 = 617.11 | G 2 = 621.32 | G 3 = 626.30 | G 4 = 632.14 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 638.91 | G 6 = 646.69 | G 7 = 655.52 | G 8 = 665.46 | G 9 = 676.53 |
| G 10 = 688.73 | G 11 = 702.04 | G 12 = 716.42 | G 13 = 731.80 | G 14 = 748.08 |
| G 15 = 765.13 | G 16 = 782.82 | G 17 = 800.99 | G 18 = 819.44 | G 19 = 838.01 |
| G 20 = 856.51 | G 21 = 874.73 | G 22 = 892.52 | G 23 = 909.69 | G 24 = 926.11 |
| G 25 = 941.65 | G 26 = 956.20 | G 27 = 969.69 | G 28 = 982.07 | G 29 = 993.32 |
| G 30 = 1003.4 | G 31 = 1012.4 | G 32 = 1020.3 | G 33 = 1027.3 | G 34 = 1033.2 |
| G 35 = 1038.3 | G 36 = 1042.6 | G 37 = 1046.2 | G 38 = 1049.2 | G 39 = 1051.6 |
| G 40 = 1053.6 | G = 0 | G = 0 | G = 0 | G = 0 |
| H 1 = 611.66 | H 2 = 614.76 | H 3 = 618.49 | H 4 = 622.93 | H 5 = 628.16 |
| H 6 = 634.25 | H 7 = 641.29 | H 8 = 649.33 | H 9 = 658.43 | H 10 = 668.63 |
| H 11 = 679.94 | H 12 = 692.36 | H 13 = 705.86 | H 14 = 720.40 | H 15 = 735.89 |
| H 16 = 752.24 | H 17 = 769.31 | H 18 = 786.97 | H 19 = 805.05 | H 20 = 823.37 |
| H 21 = 841.77 | H 22 = 860.04 | H 23 = 878.02 | H 24 = 895.53 | H 25 = 912.41 |
| H 26 = 928.53 | H 27 = 943.76 | H 28 = 958.02 | H 29 = 971.22 | H 30 = 983.33 |
| H 31 = 994.33 | H 32 = 1004.2 | H 33 = 1013.0 | H 34 = 1020.8 | H 35 = 1027.5 |
| H 36 = 1033.4 | H 37 = 1038.4 | H 38 = 1042.6 | H 39 = 1046.2 | H 40 = 1049.1 |
| H = 0 | H = 0 | H = 0 | H = 0 | H = 0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1 2

Location x/L: 1.0 0

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

~~(Q/A)CL = 0.97 MW/M2 T:NA(IN) = 610F T:NA(OUT) = 1050F
A21= 35.16 A22=117.57 A23=160.50 A24=125.34 A25= 66.558~~

ITER-NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = 0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 851.03 |
| DT M-N = 35.160 | DT1 = 117.57 | DT P-N = 160.50 | DT P-M = 125.34 | DT2 = 66.558 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 614.76 | M 1 = 618.53 | M 2 = 623.03 | M 3 = 628.34 | M 4 = 634.55 |
| M 5 = 641.72 | M 6 = 649.94 | M 7 = 659.24 | M 8 = 669.67 | M 9 = 681.25 |
| M 10 = 693.97 | M 11 = 707.81 | M 12 = 722.70 | M 13 = 738.57 | M 14 = 755.30 |
| M 15 = 772.77 | M 16 = 790.81 | M 17 = 809.26 | M 18 = 827.93 | M 19 = 846.62 |
| M 20 = 865.16 | M 21 = 883.34 | M 22 = 901.00 | M 23 = 917.97 | M 24 = 934.10 |
| M 25 = 949.29 | M 26 = 963.43 | M 27 = 976.47 | M 28 = 988.36 | M 29 = 999.09 |
| M 30 = 1008.7 | M 31 = 1017.1 | M 32 = 1024.6 | M 33 = 1031.0 | M 34 = 1036.5 |
| M 35 = 1041.1 | M 36 = 1045.0 | M 37 = 1048.2 | M 38 = 1050.9 | M 39 = 1053.0 |
| M 40 = 1054.8 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 631.72 | P 1 = 639.15 | P 2 = 647.84 | P 3 = 657.89 | P 4 = 669.40 |
| P 5 = 682.42 | P 6 = 696.98 | P 7 = 713.08 | P 8 = 730.68 | P 9 = 749.70 |
| P 10 = 770.00 | P 11 = 791.41 | P 12 = 813.72 | P 13 = 836.68 | P 14 = 860.00 |
| P 15 = 883.38 | P 16 = 906.51 | P 17 = 929.08 | P 18 = 950.78 | P 19 = 971.34 |
| P 20 = 990.50 | P 21 = 1008.1 | P 22 = 1023.9 | P 23 = 1037.8 | P 24 = 1049.8 |
| P 25 = 1059.9 | P 26 = 1068.1 | P 27 = 1074.6 | P 28 = 1079.4 | P 29 = 1082.7 |
| P 30 = 1084.7 | P 31 = 1085.6 | P 32 = 1085.6 | P 33 = 1084.8 | P 34 = 1083.5 |
| P 35 = 1081.8 | P 36 = 1079.9 | P 37 = 1077.8 | P 38 = 1075.7 | P 39 = 1073.6 |
| P 40 = 1071.7 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 622.71 | G 1 = 628.20 | G 2 = 634.67 | G 3 = 642.20 | G 4 = 650.89 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 660.81 | G 6 = 672.00 | G 7 = 684.49 | G 8 = 698.28 | G 9 = 713.35 |
| G 10 = 729.63 | G 11 = 747.02 | G 12 = 765.39 | G 13 = 784.58 | G 14 = 804.41 |
| G 15 = 824.65 | G 16 = 845.08 | G 17 = 865.46 | G 18 = 885.55 | G 19 = 905.12 |
| G 20 = 923.94 | G 21 = 941.84 | G 22 = 958.62 | G 23 = 974.17 | G 24 = 988.37 |
| G 25 = 1001.2 | G 26 = 1012.5 | G 27 = 1022.5 | G 28 = 1031.0 | G 29 = 1038.3 |
| G 30 = 1044.3 | G 31 = 1049.2 | G 32 = 1053.2 | G 33 = 1056.2 | G 34 = 1058.5 |
| G 35 = 1060.2 | G 36 = 1061.3 | G 37 = 1062.1 | G 38 = 1062.5 | G 39 = 1062.7 |
| G 40 = 1062.7 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 608.86 | H 2 = 611.40 | H 3 = 614.49 | H 4 = 618.20 | H 5 = 622.64 |
| H 6 = 627.87 | H 7 = 633.99 | H 8 = 641.06 | H 9 = 649.15 | H 10 = 658.32 |
| H 11 = 668.60 | H 12 = 680.02 | H 13 = 692.56 | H 14 = 706.20 | H 15 = 720.89 |
| H 16 = 736.55 | H 17 = 753.06 | H 18 = 770.31 | H 19 = 788.13 | H 20 = 806.37 |
| H 21 = 824.85 | H 22 = 843.38 | H 23 = 861.77 | H 24 = 879.84 | H 25 = 897.41 |
| H 26 = 914.33 | H 27 = 930.46 | H 28 = 945.67 | H 29 = 959.88 | H 30 = 973.02 |
| H 31 = 985.05 | H 32 = 995.94 | H 33 = 1005.7 | H 34 = 1014.4 | H 35 = 1022.0 |
| H 36 = 1028.7 | H 37 = 1034.4 | H 38 = 1039.2 | H 39 = 1043.4 | H 40 = 1046.8 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 2

Location x/L: 1.0

T(Na-inlet) = 610 F

T(Na-outlet) : 1050F

(Q/A)CL = 1.20 MW/M2 T:NA(IN) = 610F T:NA(OUT) = 1050F
A21= 41.74 A22=139.66 A23=192.50 A24=150.76 A25= 80.98

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.0 | DT: NA = 440.00 | T:B NA = 830.00 | T:B M = 854.96 |
| DT M-N = 41.740 | DT1 = 139.66 | DT P-N = 192.50 | DT P-M = 150.76 | DT2 = 80.980 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.06 | N 4 = 624.77 |
| N 5 = 630.31 | N 6 = 636.74 | N 7 = 644.14 | N 8 = 652.56 | N 9 = 662.05 |
| N 10 = 672.65 | N 11 = 684.36 | N 12 = 697.17 | N 13 = 711.05 | N 14 = 725.94 |
| N 15 = 741.74 | N 16 = 758.35 | N 17 = 775.65 | N 18 = 793.46 | N 19 = 811.64 |
| N 20 = 830.00 | N 21 = 848.36 | N 22 = 866.54 | N 23 = 884.35 | N 24 = 901.65 |
| N 25 = 918.26 | N 26 = 934.06 | N 27 = 948.95 | N 28 = 962.83 | N 29 = 975.64 |
| N 30 = 987.35 | N 31 = 997.95 | N 32 = 1007.4 | N 33 = 1015.9 | N 34 = 1023.3 |
| N 35 = 1029.7 | N 36 = 1035.2 | N 37 = 1039.9 | N 38 = 1043.9 | N 39 = 1047.2 |
| N 40 = 1050.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 615.65 | M 1 = 619.62 | M 2 = 624.34 | M 3 = 629.90 | M 4 = 636.38 |
| M 5 = 643.86 | M 6 = 652.40 | M 7 = 662.06 | M 8 = 672.87 | M 9 = 684.84 |
| M 10 = 697.97 | M 11 = 712.20 | M 12 = 727.48 | M 13 = 743.72 | M 14 = 760.80 |
| M 15 = 778.58 | M 16 = 796.89 | M 17 = 815.55 | M 18 = 834.38 | M 19 = 853.17 |
| M 20 = 871.74 | M 21 = 889.89 | M 22 = 907.45 | M 23 = 924.26 | M 24 = 940.18 |
| M 25 = 955.09 | M 26 = 968.93 | M 27 = 981.62 | M 28 = 993.14 | M 29 = 1003.5 |
| M 30 = 1012.7 | M 31 = 1020.7 | M 32 = 1027.8 | M 33 = 1033.8 | M 34 = 1038.9 |
| M 35 = 1043.2 | M 36 = 1046.8 | M 37 = 1049.8 | M 38 = 1052.2 | M 39 = 1054.1 |
| M 40 = 1055.6 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 636.05 | P 1 = 644.41 | P 2 = 654.17 | P 3 = 665.44 | P 4 = 678.30 |
| P 5 = 692.80 | P 6 = 708.99 | P 7 = 726.82 | P 8 = 746.26 | P 9 = 767.17 |
| P 10 = 789.41 | P 11 = 812.75 | P 12 = 836.96 | P 13 = 861.72 | P 14 = 886.73 |
| P 15 = 911.62 | P 16 = 936.05 | P 17 = 959.68 | P 18 = 982.15 | P 19 = 1003.2 |
| P 20 = 1022.5 | P 21 = 1039.9 | P 22 = 1055.2 | P 23 = 1068.4 | P 24 = 1079.3 |
| P 25 = 1088.1 | P 26 = 1094.9 | P 27 = 1099.6 | P 28 = 1102.6 | P 29 = 1104.0 |
| P 30 = 1104.1 | P 31 = 1103.1 | P 32 = 1101.1 | P 33 = 1098.6 | P 34 = 1095.5 |
| P 35 = 1092.2 | P 36 = 1088.7 | P 37 = 1085.3 | P 38 = 1082.0 | P 39 = 1078.9 |
| P 40 = 1076.1 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 625.10 | G 1 = 631.10 | G 2 = 638.15 | G 3 = 646.36 | G 4 = 655.79 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 666.53 | G 6 = 678.61 | G 7 = 692.06 | G 8 = 706.86 | G 9 = 722.98 |
| G 10 = 740.32 | G 11 = 758.77 | G 12 = 778.19 | G 13 = 798.38 | G 14 = 819.13 |
| G 15 = 840.20 | G 16 = 861.35 | G 17 = 882.31 | G 18 = 902.82 | G 19 = 922.65 |
| G 20 = 941.57 | G 21 = 959.37 | G 22 = 975.90 | G 23 = 991.01 | G 24 = 1004.6 |
| G 25 = 1016.7 | G 26 = 1027.3 | G 27 = 1036.3 | G 28 = 1043.8 | G 29 = 1050.1 |
| G 30 = 1055.0 | G 31 = 1058.9 | G 32 = 1061.7 | G 33 = 1063.8 | G 34 = 1065.1 |
| G 35 = 1065.9 | G 36 = 1066.2 | G 37 = 1066.2 | G 38 = 1066.0 | G 39 = 1065.6 |
| G 40 = 1065.1 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 608.13 | H 2 = 610.52 | H 3 = 613.43 | H 4 = 616.96 | H 5 = 621.19 |
| H 6 = 626.20 | H 7 = 632.07 | H 8 = 638.88 | H 9 = 646.71 | H 10 = 655.61 |
| H 11 = 665.62 | H 12 = 676.77 | H 13 = 689.06 | H 14 = 702.47 | H 15 = 716.95 |
| H 16 = 732.42 | H 17 = 748.79 | H 18 = 765.93 | H 19 = 783.69 | H 20 = 801.91 |
| H 21 = 820.41 | H 22 = 839.00 | H 23 = 857.50 | H 24 = 875.72 | H 25 = 893.47 |
| H 26 = 910.60 | H 27 = 926.96 | H 28 = 942.63 | H 29 = 956.90 | H 30 = 970.31 |
| H 31 = 982.61 | H 32 = 993.77 | H 33 = 1003.8 | H 34 = 1012.7 | H 35 = 1020.6 |
| H 36 = 1027.4 | H 37 = 1033.3 | H 38 = 1038.4 | H 39 = 1042.6 | H 40 = 1046.2 |
| = .0 | = .0 | = .0 | = .0 | = .0 |



PANEL TEMPERATURE DISTRIBUTION

CASE 1

SET 4 Subpanel Boundaries

Solar Flux Distribution: REFERENCE

Orifices: Yes: Orificed so as to match tube flow rates to
reference flux distribution

Sodium Temperatures: T (Na-Inlet) = 610°F
 T (Na-Outlet) = 1050°F (all tubes)

5370F/sjh

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1

Location x/L: 0

T(Na-inlet) = 600 F

T(Na-outlet) : 1100 F

$Q/AICL = 0.225 \text{ MW/M}^2$ $T:NA(IN) = 600F$ $T:NA(OUT) = 1100F$
A21= 9.94 A22= 33.133 A23= 43.17 A24= 33.23 A25= 16.662

ITER NO. 2 GREATEST TEMPERATURE CHANGE PER ITERATION = 0 CRITICAL NODE = 2

| | | | | |
|------------------|-------------------|-----------------|-----------------|----------------|
| T:NA IN = 600.00 | T:NA OUT = 1100.0 | DT: NA = 500.00 | T:B NA = 850.00 | T:B M = 855.94 |
| DT M-N = 9.9400 | DT1 = 33.133 | DT P-N = 43.170 | DT P-M = 33.230 | DT2 = 16.662 |
| N = 600.00 | N 1 = 603.13 | N 2 = 606.90 | N 3 = 611.43 | N 4 = 616.79 |
| N 5 = 623.08 | N 6 = 630.39 | N 7 = 638.79 | N 8 = 648.36 | N 9 = 659.15 |
| N 10 = 671.19 | N 11 = 684.50 | N 12 = 699.06 | N 13 = 714.83 | N 14 = 731.75 |
| N 15 = 749.71 | N 16 = 768.58 | N 17 = 788.23 | N 18 = 808.48 | N 19 = 829.14 |
| N 20 = 850.00 | N 21 = 874.86 | N 22 = 891.52 | N 23 = 911.77 | N 24 = 931.42 |
| N 25 = 950.29 | N 26 = 968.25 | N 27 = 985.17 | N 28 = 1000.9 | N 29 = 1015.5 |
| N 30 = 1028.8 | N 31 = 1040.9 | N 32 = 1051.6 | N 33 = 1061.2 | N 34 = 1069.6 |
| N 35 = 1076.9 | N 36 = 1083.2 | N 37 = 1088.6 | N 38 = 1093.1 | N 39 = 1096.9 |
| N 40 = 1100.0 | | | | |
| M = 601.35 | M 1 = 604.76 | M 2 = 608.87 | M 3 = 613.77 | M 4 = 619.55 |
| M 5 = 626.31 | M 6 = 634.12 | M 7 = 643.06 | M 8 = 653.20 | M 9 = 664.58 |
| M 10 = 677.22 | M 11 = 691.13 | M 12 = 706.28 | M 13 = 722.61 | M 14 = 740.05 |
| M 15 = 758.48 | M 16 = 777.76 | M 17 = 797.74 | M 18 = 818.22 | M 19 = 839.03 |
| M 20 = 859.94 | M 21 = 880.75 | M 22 = 901.26 | M 23 = 921.27 | M 24 = 940.59 |
| M 25 = 959.07 | M 26 = 976.56 | M 27 = 992.95 | M 28 = 1008.2 | M 29 = 1022.1 |
| M 30 = 1034.8 | M 31 = 1046.3 | M 32 = 1056.5 | M 33 = 1065.5 | M 34 = 1073.3 |
| M 35 = 1080.1 | M 36 = 1086.0 | M 37 = 1090.9 | M 38 = 1095.1 | M 39 = 1098.5 |
| M 40 = 1101.3 | | | | |
| P = 605.84 | P 1 = 610.23 | P 2 = 615.45 | P 3 = 621.60 | P 4 = 628.79 |
| P 5 = 637.09 | P 6 = 646.59 | P 7 = 657.33 | P 8 = 669.37 | P 9 = 682.72 |
| P 10 = 697.38 | P 11 = 713.29 | P 12 = 730.41 | P 13 = 748.62 | P 14 = 767.80 |
| P 15 = 787.80 | P 16 = 808.44 | P 17 = 829.50 | P 18 = 850.80 | P 19 = 872.09 |
| P 20 = 893.17 | P 21 = 913.82 | P 22 = 933.83 | P 23 = 953.04 | P 24 = 971.27 |
| P 25 = 984.39 | P 26 = 1004.3 | P 27 = 1019.0 | P 28 = 1032.3 | P 29 = 1044.3 |
| P 30 = 1055.0 | P 31 = 1064.4 | P 32 = 1072.7 | P 33 = 1079.8 | P 34 = 1085.8 |
| P 35 = 1090.9 | P 36 = 1095.2 | P 37 = 1098.7 | P 38 = 1101.6 | P 39 = 1104.0 |
| P 40 = 1105.8 | | | | |
| G = 603.59 | G 1 = 607.48 | G 2 = 612.15 | G 3 = 617.68 | G 4 = 624.16 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 631.68 | G 6 = 640.33 | G 7 = 650.18 | G 8 = 661.26 | G 9 = 673.62 |
| G 10 = 687.27 | G 11 = 702.18 | G 12 = 718.31 | G 13 = 735.58 | G 14 = 753.89 |
| G 15 = 773.10 | G 16 = 793.05 | G 17 = 813.57 | G 18 = 834.46 | G 19 = 855.51 |
| G 20 = 876.51 | G 21 = 897.24 | G 22 = 917.50 | G 23 = 937.11 | G 24 = 955.88 |
| G 25 = 973.69 | G 26 = 990.39 | G 27 = 1005.9 | G 28 = 1020.2 | G 29 = 1033.2 |
| G 30 = 1044.9 | G 31 = 1055.3 | G 32 = 1064.5 | G 33 = 1072.6 | G 34 = 1079.6 |
| G 35 = 1085.5 | G 36 = 1090.6 | G 37 = 1094.8 | G 38 = 1098.3 | G 39 = 1101.2 |
| G 40 = 1103.6 | | | | |
| H 1 = 602.04 | H 2 = 605.59 | H 3 = 609.87 | H 4 = 614.95 | H 5 = 620.93 |
| H 6 = 627.90 | H 7 = 635.94 | H 8 = 645.13 | H 9 = 655.53 | H 10 = 667.17 |
| H 11 = 680.08 | H 12 = 694.25 | H 13 = 709.64 | H 14 = 726.21 | H 15 = 743.86 |
| H 16 = 762.47 | H 17 = 781.90 | H 18 = 801.99 | H 19 = 822.54 | H 20 = 843.37 |
| H 21 = 864.27 | H 22 = 885.02 | H 23 = 905.43 | H 24 = 925.30 | H 25 = 944.45 |
| H 26 = 962.72 | H 27 = 979.98 | H 28 = 996.13 | H 29 = 1011.1 | H 30 = 1024.8 |
| H 31 = 1037.2 | H 32 = 1048.4 | H 33 = 1058.4 | H 34 = 1067.1 | H 35 = 1074.8 |
| H 36 = 1081.4 | H 37 = 1087.0 | H 38 = 1091.8 | H 39 = 1095.8 | H 40 = 1099.1 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 1 2

Location x/L: 1.0 0.0

T(Na-inlet) = 600 F

T(Na-outlet) : 1100 F

1100F

(Q/A)CL = 0.97 MW/M2 T:NA(IN) = 600F T:NA(OUT) = 1100F
A21= 35.16 A22=117.57 A23=160.50 A24=125.34 A25= 66.558

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = 0.0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 600.00 | T:NA OUT= 1100.0 | DT: NA = 500.00 | T:B NA = 850.00 | T:B M = 871.03 |
| JT M-N = 35.160 | DT1 = 117.57 | DT P-N = 160.50 | DT P-M = 125.34 | DT2 = 66.558 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N 5 = 600.00 | N 1 = 603.13 | N 2 = 606.90 | N 3 = 611.43 | N 4 = 616.79 |
| N 10 = 623.08 | N 6 = 630.39 | N 7 = 638.79 | N 8 = 648.36 | N 9 = 659.15 |
| N 15 = 671.19 | N 11 = 684.50 | N 12 = 699.06 | N 13 = 714.83 | N 14 = 731.75 |
| N 20 = 749.71 | N 16 = 768.58 | N 17 = 788.23 | N 18 = 808.48 | N 19 = 829.14 |
| N 25 = 850.00 | N 21 = 870.86 | N 22 = 891.52 | N 23 = 911.77 | N 24 = 931.42 |
| N 30 = 950.29 | N 26 = 968.25 | N 27 = 985.17 | N 28 = 1000.9 | N 29 = 1015.5 |
| N 35 = 1028.8 | N 31 = 1040.9 | N 32 = 1051.6 | N 33 = 1061.2 | N 34 = 1069.6 |
| N 40 = 1076.9 | N 36 = 1083.2 | N 37 = 1088.6 | N 38 = 1093.1 | N 39 = 1096.9 |
| = 1100.0 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M 5 = 604.76 | M 1 = 608.91 | M 2 = 613.86 | M 3 = 619.72 | M 4 = 626.56 |
| M 10 = 634.49 | M 6 = 643.58 | M 7 = 653.89 | M 8 = 665.47 | M 9 = 678.35 |
| M 15 = 692.52 | M 11 = 707.95 | M 12 = 724.59 | M 13 = 742.35 | M 14 = 761.11 |
| M 20 = 780.73 | M 16 = 801.04 | M 17 = 821.85 | M 18 = 842.94 | M 19 = 866.12 |
| M 25 = 885.16 | M 21 = 905.85 | M 22 = 925.98 | M 23 = 945.38 | M 24 = 963.87 |
| M 30 = 981.32 | M 26 = 997.62 | M 27 = 1012.7 | M 28 = 1026.5 | M 29 = 1039.0 |
| M 35 = 1050.1 | M 31 = 1060.1 | M 32 = 1068.8 | M 33 = 1076.3 | M 34 = 1082.8 |
| M 40 = 1088.3 | M 36 = 1093.0 | M 37 = 1096.9 | M 38 = 1100.1 | M 39 = 1102.7 |
| M 40 = 1104.8 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P 5 = 621.72 | P 1 = 629.52 | P 2 = 638.67 | P 3 = 649.26 | P 4 = 661.41 |
| P 10 = 675.18 | P 6 = 690.62 | P 7 = 707.73 | P 8 = 726.48 | P 9 = 746.79 |
| P 15 = 768.54 | P 11 = 791.55 | P 12 = 815.61 | P 13 = 840.46 | P 14 = 865.81 |
| P 20 = 891.35 | P 16 = 916.74 | P 17 = 941.67 | P 18 = 965.80 | P 19 = 988.84 |
| P 25 = 1010.5 | P 21 = 1030.6 | P 22 = 1048.8 | P 23 = 1065.2 | P 24 = 1079.6 |
| P 30 = 1091.9 | P 26 = 1102.3 | P 27 = 1110.8 | P 28 = 1117.5 | P 29 = 1122.5 |
| P 35 = 1126.2 | P 31 = 1128.5 | P 32 = 1129.8 | P 33 = 1130.2 | P 34 = 1129.9 |
| P 40 = 1129.0 | P 36 = 1127.8 | P 37 = 1126.4 | P 38 = 1124.9 | P 39 = 1123.3 |
| = 1121.7 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G 5 = 612.71 | G 1 = 618.58 | G 2 = 625.50 | G 3 = 633.57 | G 4 = 642.91 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 653.58 | G 6 = 665.64 | G 7 = 679.14 | G 8 = 694.09 | G 9 = 710.45 |
| G 10 = 728.17 | G 11 = 747.16 | G 12 = 767.28 | G 13 = 788.36 | G 14 = 810.22 |
| G 15 = 832.61 | G 16 = 855.31 | G 17 = 878.04 | G 18 = 900.57 | G 19 = 922.61 |
| G 20 = 943.94 | G 21 = 964.34 | G 22 = 983.60 | G 23 = 1001.6 | G 24 = 1018.1 |
| G 25 = 1033.2 | G 26 = 1046.7 | G 27 = 1058.7 | G 28 = 1069.2 | G 29 = 1078.2 |
| G 30 = 1085.8 | G 31 = 1092.2 | G 32 = 1097.4 | G 33 = 1101.6 | G 34 = 1104.9 |
| G 35 = 1107.4 | G 36 = 1109.3 | G 37 = 1110.7 | G 38 = 1111.7 | G 39 = 1112.3 |
| G 40 = 1112.7 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 599.24 | H 2 = 602.23 | H 3 = 605.86 | H 4 = 610.22 | H 5 = 615.41 |
| H 6 = 621.52 | H 7 = 628.64 | H 8 = 636.86 | H 9 = 646.25 | H 10 = 656.86 |
| H 11 = 668.74 | H 12 = 681.90 | H 13 = 696.34 | H 14 = 712.01 | H 15 = 728.86 |
| H 16 = 746.78 | H 17 = 765.65 | H 18 = 785.32 | H 19 = 805.63 | H 20 = 826.37 |
| H 21 = 847.36 | H 22 = 868.36 | H 23 = 889.18 | H 24 = 909.61 | H 25 = 929.45 |
| H 26 = 948.52 | H 27 = 966.68 | H 28 = 983.78 | H 29 = 999.74 | H 30 = 1014.5 |
| H 31 = 1027.9 | H 32 = 1040.1 | H 33 = 1051.1 | H 34 = 1060.7 | H 35 = 1069.3 |
| H 36 = 1076.6 | H 37 = 1083.0 | H 38 = 1088.4 | H 39 = 1093.0 | H 40 = 1096.8 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 1

Solar Flux: REFERENCE

Orifices: YES

Sub-Panel: 2

Location x/L: 1.0

T(Na-inlet) = 600 F

T(Na-outlet) : 1100 F

1100 F

Q/AIC1 = 1.20 MW/M2 T:NA(I) = 600F T:NA(OUT) = 1100F
A21= 41.74 A22=139.66 A23=192.50 A24=150.76 A25= 80.98

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|-------------------|-----------------|-----------------|----------------|
| T:NA IN = 600.00 | T:NA OUT = 1100.0 | DT: NA = 500.00 | T:B NA = 850.00 | T:B M = 874.96 |
| DT M-N = 41.740 | DT1 = 139.66 | DT P-M = 192.50 | DT P-M = 150.76 | DT2 = 80.980 |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 |
| N 5 = 600.00 | N 1 = 603.13 | N 2 = 606.90 | N 3 = 611.43 | N 4 = 616.79 |
| N 5 = 623.08 | N 6 = 630.39 | N 7 = 638.79 | N 8 = 648.36 | N 9 = 659.15 |
| N 10 = 671.19 | N 11 = 684.50 | N 12 = 699.06 | N 13 = 714.83 | N 14 = 731.75 |
| N 15 = 749.71 | N 16 = 768.58 | N 17 = 788.23 | N 18 = 808.48 | N 19 = 829.14 |
| N 20 = 850.00 | N 21 = 870.86 | N 22 = 891.52 | N 23 = 911.77 | N 24 = 931.42 |
| N 25 = 950.29 | N 26 = 968.25 | N 27 = 985.17 | N 28 = 1000.9 | N 29 = 1015.5 |
| N 30 = 1028.8 | N 31 = 1040.9 | N 32 = 1051.6 | N 33 = 1061.2 | N 34 = 1069.6 |
| N 35 = 1076.9 | N 36 = 1083.2 | N 37 = 1088.6 | N 38 = 1093.1 | N 39 = 1096.9 |
| N 40 = 1100.0 | N = .0 | N = .0 | N = .0 | N = .0 |
| M = 605.65 | M 1 = 609.99 | M 2 = 615.16 | M 3 = 621.27 | M 4 = 628.39 |
| M 5 = 636.63 | M 6 = 646.05 | M 7 = 656.72 | M 8 = 668.68 | M 9 = 681.94 |
| M 10 = 696.51 | M 11 = 712.34 | M 12 = 729.37 | M 13 = 747.50 | M 14 = 766.61 |
| M 15 = 786.54 | M 16 = 807.12 | M 17 = 828.14 | M 18 = 849.39 | M 19 = 870.67 |
| M 20 = 891.74 | M 21 = 912.39 | M 22 = 932.43 | M 23 = 951.67 | M 24 = 969.95 |
| M 25 = 987.13 | M 26 = 1003.1 | M 27 = 1017.8 | M 28 = 1031.2 | M 29 = 1043.3 |
| M 30 = 1054.1 | M 31 = 1063.6 | M 32 = 1072.0 | M 33 = 1079.1 | M 34 = 1085.3 |
| M 35 = 1090.5 | M 36 = 1094.8 | M 37 = 1098.4 | M 38 = 1101.4 | M 39 = 1103.7 |
| M 40 = 1105.6 | M = .0 | M = .0 | M = .0 | M = .0 |
| P = 626.05 | P 1 = 634.79 | P 2 = 645.00 | P 3 = 656.81 | P 4 = 670.31 |
| P 5 = 685.57 | P 6 = 702.63 | P 7 = 721.48 | P 8 = 742.06 | P 9 = 764.27 |
| P 10 = 787.95 | P 11 = 812.89 | P 12 = 838.84 | P 13 = 865.50 | P 14 = 892.54 |
| P 15 = 919.59 | P 16 = 946.28 | P 17 = 972.26 | P 18 = 997.17 | P 19 = 1020.7 |
| P 20 = 1042.5 | P 21 = 1062.4 | P 22 = 1080.2 | P 23 = 1095.8 | P 24 = 1109.1 |
| P 25 = 1120.2 | P 26 = 1129.0 | P 27 = 1135.8 | P 28 = 1140.7 | P 29 = 1143.9 |
| P 30 = 1145.6 | P 31 = 1146.0 | P 32 = 1145.3 | P 33 = 1143.9 | P 34 = 1141.9 |
| P 35 = 1139.4 | P 36 = 1136.7 | P 37 = 1134.0 | P 38 = 1131.2 | P 39 = 1126.5 |
| P 40 = 1126.1 | P = .0 | P = .0 | P = .0 | P = .0 |
| G = 615.10 | G 1 = 621.48 | G 2 = 628.98 | G 3 = 637.73 | G 4 = 647.81 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 659.30 | G 6 = 672.26 | G 7 = 686.72 | G 8 = 702.67 | G 9 = 720.07 |
| G 10 = 738.86 | G 11 = 758.91 | G 12 = 780.08 | G 13 = 802.16 | G 14 = 824.94 |
| G 15 = 848.17 | G 16 = 871.58 | G 17 = 894.89 | G 18 = 917.84 | G 19 = 940.15 |
| G 20 = 961.57 | G 21 = 981.88 | G 22 = 1000.9 | G 23 = 1018.4 | G 24 = 1034.4 |
| G 25 = 1048.8 | G 26 = 1061.4 | G 27 = 1072.5 | G 28 = 1082.0 | G 29 = 1089.9 |
| G 30 = 1096.5 | G 31 = 1101.8 | G 32 = 1105.9 | G 33 = 1109.1 | G 34 = 1111.5 |
| G 35 = 1113.1 | G 36 = 1114.2 | G 37 = 1114.9 | G 38 = 1115.2 | G 39 = 1115.2 |
| G 40 = 1115.1 | G = .0 | G = .0 | G = .0 | G = .0 |
| H 1 = 598.51 | H 2 = 601.34 | H 3 = 604.81 | H 4 = 608.98 | H 5 = 613.96 |
| H 6 = 619.84 | H 7 = 626.72 | H 8 = 634.69 | H 9 = 643.81 | H 10 = 654.15 |
| H 11 = 665.76 | H 12 = 678.66 | H 13 = 692.84 | H 14 = 708.28 | H 15 = 724.92 |
| H 16 = 742.65 | H 17 = 761.38 | H 18 = 780.95 | H 19 = 801.19 | H 20 = 821.91 |
| H 21 = 842.91 | H 22 = 863.98 | H 23 = 884.91 | H 24 = 905.48 | H 25 = 925.50 |
| H 26 = 944.79 | H 27 = 963.18 | H 28 = 980.54 | H 29 = 996.76 | H 30 = 1011.8 |
| H 31 = 1025.5 | H 32 = 1038.0 | H 33 = 1049.1 | H 34 = 1059.1 | H 35 = 1067.8 |
| H 36 = 1075.4 | H 37 = 1081.9 | H 38 = 1087.5 | H 39 = 1092.3 | H 40 = 1096.2 |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 |



PANEL TEMPERATURE DISTRIBUTION

CASE 2

SET 1 Subpanel 1

Solar Flux Distribution: REFERENCE

Orifices: None

Sodium Temperatures: T (Na-Inlet) = 610°F
T (Na-Outlet) = 1100°F maximum
(723.66 to 1100F)

5370F/sjh

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.05

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LOC=.05 T:NA(IN)=610F T:NA(CUT)=742.48
A21=11.201 A22= 37.355 A23= 49.037 A24= 37.836 A25=19.1

2

| ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | CRITICAL NODE = 2 | | |
|--|------------------|-------------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA CUT= 742.48 | DT: NA = 132.42 | T:8 NA = 676.24 | T:8 M = 682.94 |
| DT M-N = 11.201 | DT1 = 37.355 | DT P-N = 49.037 | DT P-M = 37.836 | DT2 = 19.157 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N 5 = 610.00 | N 1 = 610.83 | N 2 = 611.83 | N 3 = 613.03 | N 4 = 614.45 |
| N 10 = 616.11 | N 6 = 618.05 | N 7 = 620.28 | N 8 = 622.81 | N 9 = 625.67 |
| N 15 = 628.86 | N 11 = 632.39 | N 12 = 636.25 | N 13 = 640.43 | N 14 = 644.91 |
| N 20 = 649.67 | N 16 = 654.67 | N 17 = 659.87 | N 18 = 665.24 | N 19 = 670.71 |
| N 25 = 676.24 | N 21 = 681.77 | N 22 = 687.24 | N 23 = 692.61 | N 24 = 697.81 |
| N 30 = 702.81 | N 26 = 707.57 | N 27 = 712.05 | N 28 = 716.23 | N 29 = 720.09 |
| N 35 = 723.62 | N 31 = 726.81 | N 32 = 729.67 | N 33 = 732.20 | N 34 = 734.43 |
| N 40 = 736.36 | N 36 = 738.03 | N 37 = 739.45 | N 38 = 740.65 | N 39 = 741.65 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M 5 = 611.52 | M 1 = 612.67 | M 2 = 614.05 | M 3 = 615.67 | M 4 = 617.56 |
| M 10 = 619.75 | M 6 = 622.25 | M 7 = 625.09 | M 8 = 628.27 | M 9 = 631.79 |
| M 15 = 635.66 | M 11 = 639.86 | M 12 = 644.38 | M 13 = 649.19 | M 14 = 654.26 |
| M 20 = 659.55 | M 16 = 665.01 | M 17 = 670.58 | M 18 = 676.22 | M 19 = 681.86 |
| M 25 = 687.44 | M 21 = 692.91 | M 22 = 698.22 | M 23 = 703.31 | M 24 = 708.15 |
| M 30 = 712.70 | M 26 = 716.93 | M 27 = 720.82 | M 28 = 724.37 | M 29 = 727.56 |
| M 35 = 730.41 | M 31 = 732.92 | M 32 = 735.12 | M 33 = 737.01 | M 34 = 738.63 |
| M 40 = 740.00 | M 36 = 741.15 | M 37 = 742.09 | M 38 = 742.87 | M 39 = 743.49 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P 5 = 616.64 | P 1 = 618.89 | P 2 = 621.53 | P 3 = 624.59 | P 4 = 628.08 |
| P 10 = 632.03 | P 6 = 636.46 | P 7 = 641.34 | P 8 = 646.68 | P 9 = 652.45 |
| P 15 = 658.61 | P 11 = 665.10 | P 12 = 671.85 | P 13 = 678.81 | P 14 = 685.87 |
| P 20 = 692.94 | P 16 = 695.93 | P 17 = 706.75 | P 18 = 713.30 | P 19 = 719.50 |
| P 25 = 725.28 | P 21 = 730.56 | P 22 = 735.31 | P 23 = 739.48 | P 24 = 743.08 |
| P 30 = 746.09 | P 26 = 746.53 | P 27 = 750.44 | P 28 = 751.84 | P 29 = 752.80 |
| P 35 = 753.36 | P 31 = 753.59 | P 32 = 753.54 | P 33 = 753.27 | P 34 = 752.83 |
| P 40 = 752.28 | P 36 = 751.67 | P 37 = 751.01 | P 38 = 750.35 | P 39 = 749.72 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G 5 = 614.04 | G 1 = 615.74 | G 2 = 617.74 | G 3 = 620.07 | G 4 = 622.76 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 625.81 | G 6 = 625.26 | G 7 = 633.11 | G 8 = 637.36 | G 9 = 641.99 |
| G 10 = 646.98 | G 11 = 652.32 | G 12 = 657.94 | G 13 = 663.81 | G 14 = 669.86 |
| G 15 = 676.03 | G 16 = 682.25 | G 17 = 688.44 | G 18 = 694.53 | G 19 = 700.44 |
| G 20 = 706.12 | G 21 = 711.50 | G 22 = 716.53 | G 23 = 721.17 | G 24 = 725.39 |
| G 25 = 729.18 | G 26 = 732.53 | G 27 = 735.44 | G 28 = 737.93 | G 29 = 740.02 |
| G 30 = 741.74 | G 31 = 743.12 | G 32 = 744.21 | G 33 = 745.04 | G 34 = 745.64 |
| G 35 = 746.06 | G 36 = 746.34 | G 37 = 746.50 | G 38 = 746.56 | G 39 = 746.57 |
| G 40 = 746.52 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 609.60 | H 2 = 610.35 | H 3 = 611.26 | H 4 = 612.37 | H 5 = 613.69 |
| H 6 = 615.24 | H 7 = 617.07 | H 8 = 619.17 | H 9 = 621.59 | H 10 = 624.33 |
| H 11 = 627.40 | H 12 = 630.82 | H 13 = 634.57 | H 14 = 638.66 | H 15 = 643.07 |
| H 16 = 647.77 | H 17 = 652.73 | H 18 = 657.91 | H 19 = 663.27 | H 20 = 668.76 |
| H 21 = 674.33 | H 22 = 679.91 | H 23 = 685.46 | H 24 = 690.91 | H 25 = 696.22 |
| H 26 = 701.33 | H 27 = 706.20 | H 28 = 710.80 | H 29 = 715.10 | H 30 = 719.08 |
| H 31 = 722.72 | H 32 = 726.03 | H 33 = 728.99 | H 34 = 731.62 | H 35 = 733.94 |
| H 36 = 735.95 | H 37 = 737.69 | H 38 = 739.17 | H 39 = 740.42 | H 40 = 741.47 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.15

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LOC=.15 T:NA(IN)=610F T:NA(CUT)=780.11
A21=13.723 A22= 45.799 A23= 60.770 A24= 47.047 A25=24.146

2

| ITER NO. 2. | | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA CUT= 780.11 | DT: NA = 170.11 | T:B NA = 695.05 | T:B M = 703.26 | | | | | |
| DT M-N = 13.723 | DT1 = 45.799 | DT P-N = 60.770 | DT P-M = 47.047 | DT2 = 24.146 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| N = 610.00 | N 1 = 611.06 | N 2 = 612.35 | N 3 = 613.89 | N 4 = 615.71 | | | | | |
| N 5 = 617.85 | N 6 = 620.34 | N 7 = 623.20 | N 8 = 626.45 | N 9 = 630.12 | | | | | |
| N 10 = 634.22 | N 11 = 638.75 | N 12 = 643.70 | N 13 = 649.07 | N 14 = 654.82 | | | | | |
| N 15 = 660.93 | N 16 = 667.36 | N 17 = 674.04 | N 18 = 680.93 | N 19 = 687.96 | | | | | |
| N 20 = 695.05 | N 21 = 702.15 | N 22 = 709.18 | N 23 = 716.07 | N 24 = 722.75 | | | | | |
| N 25 = 729.18 | N 26 = 735.29 | N 27 = 741.04 | N 28 = 746.41 | N 29 = 751.36 | | | | | |
| N 30 = 755.89 | N 31 = 755.99 | N 32 = 763.66 | N 33 = 766.91 | N 34 = 769.77 | | | | | |
| N 35 = 772.20 | N 36 = 774.40 | N 37 = 776.22 | N 38 = 777.76 | N 39 = 779.05 | | | | | |
| N 40 = 780.11 | = .0 | = .0 | = .0 | = .0 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| M = 611.86 | M 1 = 613.32 | M 2 = 615.06 | M 3 = 617.12 | M 4 = 619.53 | | | | | |
| M 5 = 622.31 | M 6 = 625.49 | M 7 = 629.09 | M 8 = 633.13 | M 9 = 637.62 | | | | | |
| M 10 = 642.54 | M 11 = 647.90 | M 12 = 653.67 | M 13 = 659.81 | M 14 = 666.28 | | | | | |
| M 15 = 673.04 | M 16 = 680.02 | M 17 = 687.16 | M 18 = 694.38 | M 19 = 701.61 | | | | | |
| M 20 = 708.78 | M 21 = 715.81 | M 22 = 722.63 | M 23 = 729.19 | M 24 = 735.42 | | | | | |
| M 25 = 741.29 | M 26 = 746.75 | M 27 = 751.78 | M 28 = 756.37 | M 29 = 760.51 | | | | | |
| M 30 = 764.21 | M 31 = 767.48 | M 32 = 770.34 | M 33 = 772.81 | M 34 = 774.92 | | | | | |
| M 35 = 776.71 | M 36 = 778.21 | M 37 = 779.46 | M 38 = 780.48 | M 39 = 781.30 | | | | | |
| M 40 = 781.97 | = .0 | = .0 | = .0 | = .0 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| P = 618.22 | P 1 = 621.06 | P 2 = 624.37 | P 3 = 628.21 | P 4 = 632.61 | | | | | |
| P 5 = 637.58 | P 6 = 643.15 | P 7 = 649.30 | P 8 = 656.03 | P 9 = 663.31 | | | | | |
| P 10 = 671.08 | P 11 = 675.28 | P 12 = 687.83 | P 13 = 696.63 | P 14 = 705.58 | | | | | |
| P 15 = 714.56 | P 16 = 723.45 | P 17 = 732.14 | P 18 = 740.50 | P 19 = 748.42 | | | | | |
| P 20 = 755.82 | P 21 = 762.62 | P 22 = 768.75 | P 23 = 774.16 | P 24 = 778.85 | | | | | |
| P 25 = 782.81 | P 26 = 786.05 | P 27 = 788.61 | P 28 = 790.54 | P 29 = 791.89 | | | | | |
| P 30 = 792.75 | P 31 = 793.17 | P 32 = 793.24 | P 33 = 793.02 | P 34 = 792.58 | | | | | |
| P 35 = 791.99 | P 36 = 791.29 | P 37 = 790.55 | P 38 = 789.79 | P 39 = 789.04 | | | | | |
| P 40 = 788.33 | = .0 | = .0 | = .0 | = .0 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| G = 614.96 | G 1 = 617.09 | G 2 = 619.60 | G 3 = 622.52 | G 4 = 625.89 | | | | | |
| G 5 = 629.74 | G 6 = 634.08 | G 7 = 638.93 | G 8 = 644.28 | G 9 = 650.12 | | | | | |
| G 10 = 656.43 | G 11 = 663.17 | G 12 = 670.30 | G 13 = 677.73 | G 14 = 685.41 | | | | | |
| G 15 = 693.25 | G 16 = 701.16 | G 17 = 709.05 | G 18 = 716.83 | G 19 = 724.40 | | | | | |
| G 20 = 731.68 | G 21 = 738.59 | G 22 = 745.08 | G 23 = 751.08 | G 24 = 756.56 | | | | | |
| G 25 = 761.50 | G 26 = 765.88 | G 27 = 769.71 | G 28 = 773.00 | G 29 = 775.79 | | | | | |
| G 30 = 778.10 | G 31 = 779.98 | G 32 = 781.48 | G 33 = 782.64 | G 34 = 783.52 | | | | | |
| G 35 = 784.15 | G 36 = 784.58 | G 37 = 784.86 | G 38 = 785.01 | G 39 = 785.07 | | | | | |
| G 40 = 785.07 | = .0 | = .0 | = .0 | = .0 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| H 1 = 609.55 | H 2 = 610.53 | H 3 = 611.72 | H 4 = 613.16 | H 5 = 614.87 | | | | | |
| H 6 = 616.89 | H 7 = 619.26 | H 8 = 621.99 | H 9 = 625.11 | H 10 = 628.65 | | | | | |
| H 11 = 632.63 | H 12 = 637.04 | H 13 = 641.89 | H 14 = 647.16 | H 15 = 652.83 | | | | | |
| H 16 = 658.88 | H 17 = 665.27 | H 18 = 671.93 | H 19 = 678.83 | H 20 = 685.88 | | | | | |
| H 21 = 693.02 | H 22 = 700.19 | H 23 = 707.30 | H 24 = 714.28 | H 25 = 721.00 | | | | | |
| H 26 = 727.62 | H 27 = 733.86 | H 28 = 739.74 | H 29 = 745.24 | H 30 = 750.32 | | | | | |
| H 31 = 754.97 | H 32 = 759.19 | H 33 = 762.97 | H 34 = 766.33 | H 35 = 769.28 | | | | | |
| H 36 = 771.85 | H 37 = 774.06 | H 38 = 775.94 | H 39 = 777.54 | H 40 = 778.87 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.25

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LOC=.25 T:NA(IN)=610F T:NA(CUT)=817.74
A21=16.245 A22= 54.242 A23= 72.503 A24= 56.258 A25=29.136

2

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| ITER | NA IN | DT M-N | DT1 | DT2 | DT P-N | DT P-M | DT2 |
|------|--------|--------|--------|--------|--------|--------|--------|
| 1 | 610.00 | 16.245 | 54.242 | 72.503 | 713.87 | 56.258 | 29.136 |
| 5 | 619.59 | | | | | | |
| 10 | 639.58 | | | | | | |
| 15 | 672.20 | | | | | | |
| 20 | 713.87 | | | | | | |
| 25 | 755.54 | | | | | | |
| 30 | 788.16 | | | | | | |
| 35 | 808.15 | | | | | | |
| 40 | 817.74 | | | | | | |
| M 1 | 613.97 | | | | | | |
| M 5 | 624.86 | | | | | | |
| M 10 | 649.43 | | | | | | |
| M 15 | 686.54 | | | | | | |
| M 20 | 730.11 | | | | | | |
| M 25 | 769.88 | | | | | | |
| M 30 | 798.01 | | | | | | |
| M 35 | 813.43 | | | | | | |
| M 40 | 819.94 | | | | | | |
| P 1 | 619.81 | | | | | | |
| P 5 | 643.13 | | | | | | |
| P 10 | 683.55 | | | | | | |
| P 15 | 736.18 | | | | | | |
| P 20 | 786.37 | | | | | | |
| P 25 | 819.52 | | | | | | |
| P 30 | 832.14 | | | | | | |
| P 35 | 831.69 | | | | | | |
| P 40 | 827.55 | | | | | | |
| G 1 | 618.43 | | | | | | |
| G 2 | 621.45 | | | | | | |
| G 3 | 624.97 | | | | | | |
| G 4 | 629.03 | | | | | | |

| | | | | | | | | | |
|------|--------|------|--------|------|--------|------|--------|------|--------|
| G 5 | 633.67 | G 6 | 638.90 | G 7 | 644.74 | G 8 | 651.20 | G 9 | 658.26 |
| G 10 | 665.88 | G 11 | 674.03 | G 12 | 682.65 | G 13 | 691.65 | G 14 | 700.96 |
| G 15 | 710.47 | G 16 | 720.07 | G 17 | 729.66 | G 18 | 739.13 | G 19 | 748.35 |
| G 20 | 757.24 | G 21 | 765.69 | G 22 | 773.63 | G 23 | 780.99 | G 24 | 787.73 |
| G 25 | 793.81 | G 26 | 795.22 | G 27 | 803.97 | G 28 | 808.07 | G 29 | 811.56 |
| G 30 | 814.46 | G 31 | 816.85 | G 32 | 818.76 | G 33 | 820.25 | G 34 | 821.39 |
| G 35 | 822.23 | G 36 | 822.82 | G 37 | 823.22 | G 38 | 823.45 | G 39 | 823.57 |
| G 40 | 823.61 | | | | | | | | |
| H 1 | 604.51 | H 2 | 610.72 | H 3 | 612.18 | H 4 | 613.95 | H 5 | 616.06 |
| H 6 | 618.54 | H 7 | 621.44 | H 8 | 624.80 | H 9 | 628.64 | H 10 | 632.98 |
| H 11 | 637.85 | H 12 | 643.26 | H 13 | 649.20 | H 14 | 655.65 | H 15 | 662.60 |
| H 16 | 670.00 | H 17 | 677.81 | H 18 | 685.96 | H 19 | 694.38 | H 20 | 702.99 |
| H 21 | 711.72 | H 22 | 720.46 | H 23 | 729.13 | H 24 | 737.66 | H 25 | 745.94 |
| H 26 | 753.92 | H 27 | 761.52 | H 28 | 768.68 | H 29 | 775.38 | H 30 | 781.56 |
| H 31 | 787.23 | H 32 | 792.35 | H 33 | 796.95 | H 34 | 801.03 | H 35 | 804.62 |
| H 36 | 807.74 | H 37 | 810.43 | H 38 | 812.72 | H 39 | 814.65 | H 40 | 816.27 |
| | .0 | | .0 | | .0 | | .0 | | .0 |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

PANEL 1 LOC=0.35 T:NA(IN)=610F T:NA(CUT)=855.38

A21=18.767 A22= 62.686 A23= 64.236 A24= 65.469 A25=34.126 Location x/L: 0.35

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

2

| ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | CRITICAL NODE | | |
|--|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 855.38 | DT: NA = 245.38 | T:B NA = 732.69 | T:B M = 743.91 |
| DT M-N = 18.767 | DT1 = 62.686 | DT F-N = 84.236 | DT P-M = 65.469 | DT2 = 34.126 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N 5 = 610.00 | N 1 = 611.53 | N 2 = 613.39 | N 3 = 615.61 | N 4 = 618.24 |
| N 10 = 621.33 | N 6 = 624.91 | N 7 = 629.04 | N 8 = 633.73 | N 9 = 639.03 |
| N 15 = 644.94 | N 11 = 651.47 | N 12 = 658.61 | N 13 = 666.35 | N 14 = 674.66 |
| N 20 = 683.47 | N 16 = 692.73 | N 17 = 702.38 | N 18 = 712.31 | N 19 = 722.45 |
| N 25 = 732.69 | N 21 = 742.93 | N 22 = 753.07 | N 23 = 763.00 | N 24 = 772.65 |
| N 30 = 781.91 | N 26 = 790.72 | N 27 = 799.03 | N 28 = 806.77 | N 29 = 813.91 |
| N 35 = 820.44 | N 31 = 826.35 | N 32 = 831.65 | N 33 = 836.34 | N 34 = 840.47 |
| N 40 = 844.05 | N 36 = 847.14 | N 37 = 849.77 | N 38 = 851.99 | N 39 = 853.85 |
| M 5 = 612.54 | M 1 = 614.62 | M 2 = 617.10 | M 3 = 620.03 | M 4 = 623.46 |
| M 10 = 627.42 | M 6 = 631.96 | M 7 = 637.10 | M 8 = 642.87 | M 9 = 649.28 |
| M 15 = 656.32 | M 11 = 663.99 | M 12 = 672.24 | M 13 = 681.04 | M 14 = 690.33 |
| M 20 = 700.03 | M 16 = 710.06 | M 17 = 720.32 | M 18 = 730.71 | M 19 = 741.12 |
| M 25 = 751.46 | M 21 = 761.60 | M 22 = 771.46 | M 23 = 780.94 | M 24 = 789.97 |
| M 30 = 758.47 | M 26 = 806.40 | M 27 = 813.71 | M 28 = 820.39 | M 29 = 826.43 |
| M 35 = 831.82 | M 31 = 836.60 | M 32 = 840.78 | M 33 = 844.40 | M 34 = 847.51 |
| M 40 = 850.15 | M 36 = 852.36 | M 37 = 854.20 | M 38 = 855.71 | M 39 = 856.93 |
| P 5 = 621.40 | P 1 = 625.39 | P 2 = 630.06 | P 3 = 635.47 | P 4 = 641.66 |
| P 10 = 648.67 | P 6 = 656.53 | P 7 = 665.22 | P 8 = 674.73 | P 9 = 685.03 |
| P 15 = 696.03 | P 11 = 707.65 | P 12 = 719.78 | P 13 = 732.29 | P 14 = 745.02 |
| P 20 = 757.81 | P 16 = 770.49 | P 17 = 782.91 | P 18 = 794.88 | P 19 = 806.27 |
| P 25 = 816.93 | P 21 = 826.74 | P 22 = 835.63 | P 23 = 843.53 | P 24 = 850.40 |
| P 30 = 856.25 | P 26 = 861.08 | P 27 = 864.96 | P 28 = 867.93 | P 29 = 870.09 |
| P 35 = 871.53 | P 31 = 872.35 | P 32 = 872.65 | P 33 = 872.53 | P 34 = 872.08 |
| P 40 = 871.40 | P 36 = 870.56 | P 37 = 869.63 | P 38 = 868.66 | P 39 = 867.70 |
| G 5 = 616.78 | G 1 = 619.78 | G 2 = 623.30 | G 3 = 627.42 | G 4 = 632.17 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 637.59 | G 6 = 643.72 | G 7 = 650.56 | G 8 = 658.12 | G 9 = 666.35 |
| G 10 = 675.33 | G 11 = 684.89 | G 12 = 695.00 | G 13 = 705.58 | G 14 = 716.51 |
| G 15 = 727.69 | G 16 = 738.99 | G 17 = 750.28 | G 18 = 761.43 | G 19 = 772.31 |
| G 20 = 782.80 | G 21 = 792.79 | G 22 = 802.18 | G 23 = 810.91 | G 24 = 818.90 |
| G 25 = 826.13 | G 26 = 832.58 | G 27 = 838.25 | G 28 = 843.15 | G 29 = 847.33 |
| G 30 = 850.83 | G 31 = 853.72 | G 32 = 856.04 | G 33 = 857.87 | G 34 = 859.27 |
| G 35 = 860.32 | G 36 = 861.07 | G 37 = 861.58 | G 38 = 861.91 | G 39 = 862.09 |
| H 1 = 609.47 | H 2 = 610.90 | H 3 = 612.64 | H 4 = 614.74 | H 5 = 617.24 |
| H 6 = 620.19 | H 7 = 623.63 | H 8 = 627.61 | H 9 = 632.16 | H 10 = 637.31 |
| H 11 = 643.08 | H 12 = 649.48 | H 13 = 656.51 | H 14 = 664.15 | H 15 = 672.37 |
| H 16 = 681.12 | H 17 = 690.35 | H 18 = 699.99 | H 19 = 709.94 | H 20 = 720.11 |
| H 21 = 730.42 | H 22 = 740.74 | H 23 = 750.98 | H 24 = 761.04 | H 25 = 770.81 |
| H 26 = 780.22 | H 27 = 785.18 | H 28 = 797.63 | H 29 = 805.52 | H 30 = 812.81 |
| H 31 = 819.48 | H 32 = 825.53 | H 33 = 830.94 | H 34 = 835.75 | H 35 = 839.97 |
| H 36 = 843.64 | H 37 = 846.81 | H 38 = 849.50 | H 39 = 851.78 | H 40 = 853.68 |

CASE # . 2

Solar Flux: REFERENCE
 Orifices: NO
 Sub-Panel: 1
 Location x/L: 0.45
 T(Na-inlet) = 610 F
 T(Na-outlet) : Max = 1100F

PANEL 1 LOC=-.45 T:NA(IN)=610F T:NA(OUT)=893.01
 A21=21.289 A22= 71.130 A23= 55.969 A24= 74.680 A25=39.115

2

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = Z

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 893.01 | DT: NA = 283.01 | T:B NA = 751.50 | T:B M = 764.24 |
| DT M-N = 21.289 | DT1 = 71.130 | DT P-N = 95.969 | DT P-M = 74.680 | DT2 = 39.115 |
| = -0 | = -0 | = -0 | = -0 | = -0 |
| N 5 = 610.00 | N 1 = 611.77 | N 2 = 613.91 | N 3 = 616.47 | N 4 = 619.50 |
| N 6 = 623.06 | N 6 = 627.20 | N 7 = 631.96 | N 8 = 637.37 | N 9 = 643.48 |
| N 10 = 650.30 | N 11 = 657.83 | N 12 = 666.07 | N 13 = 675.00 | N 14 = 684.57 |
| N 15 = 694.74 | N 16 = 705.42 | N 17 = 716.54 | N 18 = 728.00 | N 19 = 739.70 |
| N 20 = 751.50 | N 21 = 763.31 | N 22 = 775.01 | N 23 = 786.47 | N 24 = 797.59 |
| N 25 = 808.27 | N 26 = 816.44 | N 27 = 828.01 | N 28 = 836.94 | N 29 = 845.18 |
| N 30 = 852.71 | N 31 = 855.53 | N 32 = 865.64 | N 33 = 871.05 | N 34 = 875.81 |
| N 35 = 879.95 | N 36 = 883.51 | N 37 = 886.54 | N 38 = 889.10 | N 39 = 891.24 |
| N 40 = 893.01 | = -0 | = -0 | = -0 | = -0 |
| M 5 = 612.88 | M 1 = 615.27 | M 2 = 618.12 | M 3 = 621.49 | M 4 = 625.42 |
| M 6 = 629.97 | M 6 = 635.19 | M 7 = 641.10 | M 8 = 647.73 | M 9 = 655.10 |
| M 10 = 663.21 | M 11 = 672.03 | M 12 = 681.53 | M 13 = 691.66 | M 14 = 702.35 |
| M 15 = 713.52 | M 16 = 725.07 | M 17 = 736.90 | M 18 = 748.87 | M 19 = 760.88 |
| M 20 = 772.79 | M 21 = 784.50 | M 22 = 795.87 | M 23 = 806.82 | M 24 = 817.24 |
| M 25 = 827.06 | M 26 = 836.22 | M 27 = 844.68 | M 28 = 852.40 | M 29 = 859.38 |
| M 30 = 865.63 | M 31 = 871.16 | M 32 = 876.00 | M 33 = 880.20 | M 34 = 883.80 |
| M 35 = 886.86 | M 36 = 889.43 | M 37 = 891.56 | M 38 = 893.31 | M 39 = 894.74 |
| M 40 = 895.89 | = -0 | = -0 | = -0 | = -0 |
| P 5 = 622.99 | P 1 = 627.55 | P 2 = 632.90 | P 3 = 639.09 | P 4 = 646.19 |
| P 6 = 654.22 | P 6 = 663.22 | P 7 = 673.18 | P 8 = 684.09 | P 9 = 695.89 |
| P 10 = 708.50 | P 11 = 721.84 | P 12 = 735.76 | P 13 = 750.11 | P 14 = 764.73 |
| P 15 = 779.43 | P 16 = 794.01 | P 17 = 808.29 | P 18 = 822.07 | P 19 = 835.19 |
| P 20 = 847.47 | P 21 = 858.80 | P 22 = 869.07 | P 23 = 878.21 | P 24 = 886.18 |
| P 25 = 892.97 | P 26 = 898.60 | P 27 = 903.13 | P 28 = 906.63 | P 29 = 909.19 |
| P 30 = 910.92 | P 31 = 911.94 | P 32 = 912.35 | P 33 = 912.28 | P 34 = 911.83 |
| P 35 = 911.10 | P 36 = 910.19 | P 37 = 909.17 | P 38 = 908.09 | P 39 = 907.02 |
| P 40 = 906.00 | = -0 | = -0 | = -0 | = -0 |
| G 5 = 617.69 | G 1 = 621.12 | G 2 = 625.16 | G 3 = 629.87 | G 4 = 635.31 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 641.52 | G 6 = 648.54 | G 7 = 656.38 | G 8 = 665.05 | G 9 = 674.53 |
| G 10 = 684.78 | G 11 = 695.75 | G 12 = 707.35 | G 13 = 719.50 | G 14 = 732.06 |
| G 15 = 744.91 | G 16 = 757.90 | G 17 = 770.90 | G 18 = 783.73 | G 19 = 796.27 |
| G 20 = 808.36 | G 21 = 815.88 | G 22 = 830.72 | G 23 = 840.82 | G 24 = 850.07 |
| G 25 = 858.45 | G 26 = 865.93 | G 27 = 872.51 | G 28 = 878.22 | G 29 = 883.10 |
| G 30 = 887.20 | G 31 = 890.58 | G 32 = 893.31 | G 33 = 895.48 | G 34 = 897.15 |
| G 35 = 898.40 | G 36 = 895.31 | G 37 = 899.94 | G 38 = 900.35 | G 39 = 900.59 |
| G 40 = 900.70 | = -0 | = -0 | = -0 | = -0 |
| H 1 = 609.42 | H 2 = 611.08 | H 3 = 613.10 | H 4 = 615.53 | H 5 = 618.43 |
| H 6 = 621.84 | H 7 = 625.82 | H 8 = 630.42 | H 9 = 635.68 | H 10 = 641.64 |
| H 11 = 648.31 | H 12 = 655.70 | H 13 = 663.82 | H 14 = 672.65 | H 15 = 682.14 |
| H 16 = 692.24 | H 17 = 702.90 | H 18 = 714.01 | H 19 = 725.49 | H 20 = 737.23 |
| H 21 = 749.11 | H 22 = 761.01 | H 23 = 772.82 | H 24 = 784.41 | H 25 = 795.67 |
| H 26 = 806.51 | H 27 = 816.84 | H 28 = 826.57 | H 29 = 835.66 | H 30 = 844.05 |
| H 31 = 851.73 | H 32 = 858.69 | H 33 = 864.92 | H 34 = 870.45 | H 35 = 875.31 |
| H 36 = 879.54 | H 37 = 883.18 | H 38 = 886.28 | H 39 = 888.89 | H 40 = 891.08 |
| = -0 | = -0 | = -0 | = -0 | = -0 |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.55

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LGC=.55 T:NA(IN)=610F T:NA(OUT)=930.65
A21=23.811 A22= 79.573 A23=107.70 A24= 83.891 A25=44.105

2

| ITER NC. | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|----------|----------|---|----------|--------|----------|-------------------|----------|-------|----------|
| T:NA IN | = 610.00 | T:NA OUT | = 930.65 | DT: NA | = 320.65 | T:B NA | = 770.32 | T:B M | = 784.57 |
| DT M-N | = 23.811 | DT1 | = 79.573 | DT P-N | = 107.70 | DT P-M | = 83.891 | DT2 | = 44.105 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| N | = 610.00 | N 1 | = 612.00 | N 2 | = 614.43 | N 3 | = 617.33 | N 4 | = 620.77 |
| N 5 | = 624.80 | N 6 | = 629.49 | N 7 | = 634.82 | N 8 | = 641.01 | N 9 | = 647.93 |
| N 10 | = 655.66 | N 11 | = 664.19 | N 12 | = 673.53 | N 13 | = 683.64 | N 14 | = 694.49 |
| N 15 | = 706.01 | N 16 | = 718.11 | N 17 | = 730.71 | N 18 | = 743.70 | N 19 | = 756.95 |
| N 20 | = 770.32 | N 21 | = 783.70 | N 22 | = 796.95 | N 23 | = 809.94 | N 24 | = 822.54 |
| N 25 | = 834.64 | N 26 | = 846.16 | N 27 | = 857.01 | N 28 | = 867.12 | N 29 | = 876.46 |
| N 30 | = 884.99 | N 31 | = 892.72 | N 32 | = 899.64 | N 33 | = 905.77 | N 34 | = 911.16 |
| N 35 | = 915.85 | N 36 | = 919.88 | N 37 | = 923.32 | N 38 | = 926.22 | N 39 | = 928.65 |
| N 40 | = 930.65 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| M | = 613.22 | M 1 | = 615.92 | M 2 | = 619.14 | M 3 | = 622.94 | M 4 | = 627.39 |
| M 5 | = 632.53 | M 6 | = 638.42 | M 7 | = 645.10 | M 8 | = 652.60 | M 9 | = 660.93 |
| M 10 | = 670.10 | M 11 | = 680.07 | M 12 | = 690.82 | M 13 | = 702.28 | M 14 | = 714.38 |
| M 15 | = 727.02 | M 16 | = 740.09 | M 17 | = 753.48 | M 18 | = 767.04 | M 19 | = 780.64 |
| M 20 | = 794.14 | M 21 | = 807.40 | M 22 | = 820.29 | M 23 | = 832.70 | M 24 | = 844.52 |
| M 25 | = 855.66 | M 26 | = 866.05 | M 27 | = 875.65 | M 28 | = 884.41 | M 29 | = 892.34 |
| M 30 | = 899.44 | M 31 | = 905.72 | M 32 | = 911.23 | M 33 | = 916.00 | M 34 | = 920.10 |
| M 35 | = 923.58 | M 36 | = 926.50 | M 37 | = 928.93 | M 38 | = 930.93 | M 39 | = 932.56 |
| M 40 | = 933.87 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| P | = 624.58 | P 1 | = 629.72 | P 2 | = 635.74 | P 3 | = 642.72 | P 4 | = 650.71 |
| P 5 | = 659.76 | P 6 | = 665.91 | P 7 | = 681.14 | P 8 | = 693.44 | P 9 | = 706.74 |
| P 10 | = 720.98 | P 11 | = 736.02 | P 12 | = 751.73 | P 13 | = 767.94 | P 14 | = 784.45 |
| P 15 | = 801.05 | P 16 | = 817.53 | P 17 | = 833.68 | P 18 | = 849.27 | P 19 | = 864.11 |
| P 20 | = 878.02 | P 21 | = 890.87 | P 22 | = 902.52 | P 23 | = 912.90 | P 24 | = 921.96 |
| P 25 | = 929.69 | P 26 | = 936.12 | P 27 | = 941.31 | P 28 | = 945.33 | P 29 | = 948.29 |
| P 30 | = 950.32 | P 31 | = 951.53 | P 32 | = 952.06 | P 33 | = 952.04 | P 34 | = 951.58 |
| P 35 | = 950.81 | P 36 | = 945.83 | P 37 | = 948.71 | P 38 | = 947.54 | P 39 | = 946.36 |
| P 40 | = 945.23 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| G | = 618.61 | G 1 | = 622.46 | G 2 | = 627.01 | G 3 | = 632.32 | G 4 | = 638.45 |
| G 5 | = 645.45 | G 6 | = 653.35 | G 7 | = 662.19 | G 8 | = 671.97 | G 9 | = 682.66 |
| G 10 | = 694.23 | G 11 | = 706.61 | G 12 | = 719.71 | G 13 | = 733.42 | G 14 | = 747.61 |
| G 15 | = 762.13 | G 16 | = 776.82 | G 17 | = 791.51 | G 18 | = 806.04 | G 19 | = 820.23 |
| G 20 | = 833.92 | G 21 | = 846.98 | G 22 | = 859.29 | G 23 | = 870.73 | G 24 | = 881.24 |
| G 25 | = 890.77 | G 26 | = 899.28 | G 27 | = 906.79 | G 28 | = 913.30 | G 29 | = 918.88 |
| G 30 | = 923.57 | G 31 | = 927.45 | G 32 | = 930.59 | G 33 | = 933.09 | G 34 | = 935.03 |
| G 35 | = 936.50 | G 36 | = 937.57 | G 37 | = 938.31 | G 38 | = 938.81 | G 39 | = 939.11 |
| G 40 | = 939.26 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| H | = 609.38 | H 2 | = 611.27 | H 3 | = 613.56 | H 4 | = 616.32 | H 5 | = 619.61 |
| H 6 | = 623.49 | H 7 | = 628.01 | H 8 | = 633.24 | H 9 | = 639.21 | H 10 | = 645.97 |
| H 11 | = 653.53 | H 12 | = 661.93 | H 13 | = 671.14 | H 14 | = 681.14 | H 15 | = 691.91 |
| H 16 | = 703.37 | H 17 | = 715.44 | H 18 | = 728.04 | H 19 | = 741.05 | H 20 | = 754.35 |
| H 21 | = 767.81 | H 22 | = 781.29 | H 23 | = 794.66 | H 24 | = 807.79 | H 25 | = 820.54 |
| H 26 | = 832.82 | H 27 | = 844.50 | H 28 | = 855.52 | H 29 | = 865.80 | H 30 | = 875.30 |
| H 31 | = 883.99 | H 32 | = 891.86 | H 33 | = 898.91 | H 34 | = 905.17 | H 35 | = 910.66 |
| H 36 | = 915.44 | H 37 | = 915.55 | H 38 | = 923.06 | H 39 | = 926.02 | H 40 | = 928.49 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.65

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LOC=0.65 T:NA(IN)=610F T:NA(CUT)=968.28
A21=26.333 A22= 88.017 A23=119.43 A24= 93.102 A25=49.094

2

| ITER NO. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = -0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA CUT= 968.28 | DT: NA = 358.28 | T:8 NA = 789.14 | T:8 M = 804.89 | | | | |
| DT M-N = 26.333 | DT1 = 88.017 | DT P-N = 119.43 | DT P-M = 93.102 | DT2 = 49.094 | | | | |
| N = 610.00 | N 1 = 612.24 | N 2 = 614.95 | N 3 = 618.19 | N 4 = 622.03 | | | | |
| N 5 = 626.54 | N 6 = 631.77 | N 7 = 637.80 | N 8 = 644.65 | N 9 = 652.38 | | | | |
| N 10 = 661.01 | N 11 = 670.55 | N 12 = 680.92 | N 13 = 692.28 | N 14 = 704.40 | | | | |
| N 15 = 717.27 | N 16 = 730.80 | N 17 = 744.88 | N 18 = 759.39 | N 19 = 774.19 | | | | |
| N 20 = 789.14 | N 21 = 804.09 | N 22 = 818.89 | N 23 = 833.40 | N 24 = 847.48 | | | | |
| N 25 = 861.01 | N 26 = 873.88 | N 27 = 886.00 | N 28 = 897.30 | N 29 = 907.73 | | | | |
| N 30 = 917.27 | N 31 = 925.90 | N 32 = 933.63 | N 33 = 940.48 | N 34 = 946.51 | | | | |
| N 35 = 951.74 | N 36 = 956.25 | N 37 = 960.09 | N 38 = 963.33 | N 39 = 966.04 | | | | |
| N 40 = 968.28 | | | | | | | | |
| M = 613.56 | M 1 = 616.57 | M 2 = 620.16 | M 3 = 624.40 | M 4 = 629.35 | | | | |
| M 5 = 635.09 | M 6 = 641.68 | M 7 = 649.11 | M 8 = 657.47 | M 9 = 666.76 | | | | |
| M 10 = 676.98 | M 11 = 688.11 | M 12 = 700.10 | M 13 = 712.89 | M 14 = 726.40 | | | | |
| M 15 = 740.51 | M 16 = 755.11 | M 17 = 770.05 | M 18 = 785.20 | M 19 = 800.39 | | | | |
| M 20 = 815.47 | M 21 = 830.29 | M 22 = 844.70 | M 23 = 858.57 | M 24 = 871.79 | | | | |
| M 25 = 884.25 | M 26 = 895.87 | M 27 = 906.61 | M 28 = 916.42 | M 29 = 925.29 | | | | |
| M 30 = 933.24 | M 31 = 940.28 | M 32 = 946.44 | M 33 = 951.80 | M 34 = 956.39 | | | | |
| M 35 = 960.29 | M 36 = 963.57 | M 37 = 966.30 | M 38 = 968.54 | M 39 = 970.37 | | | | |
| M 40 = 971.84 | | | | | | | | |
| P = 626.16 | P 1 = 631.88 | P 2 = 638.58 | P 3 = 646.34 | P 4 = 655.24 | | | | |
| P 5 = 665.31 | P 6 = 676.60 | P 7 = 689.10 | P 8 = 702.79 | P 9 = 717.60 | | | | |
| P 10 = 733.45 | P 11 = 750.21 | P 12 = 767.71 | P 13 = 785.76 | P 14 = 804.16 | | | | |
| P 15 = 822.67 | P 16 = 841.05 | P 17 = 859.06 | P 18 = 876.45 | P 19 = 893.02 | | | | |
| P 20 = 908.57 | P 21 = 922.92 | P 22 = 935.96 | P 23 = 947.57 | P 24 = 957.73 | | | | |
| P 25 = 966.40 | P 26 = 973.63 | P 27 = 979.47 | P 28 = 984.02 | P 29 = 987.39 | | | | |
| P 30 = 989.70 | P 31 = 991.11 | P 32 = 991.76 | P 33 = 991.79 | P 34 = 991.33 | | | | |
| P 35 = 990.52 | P 36 = 989.46 | P 37 = 988.25 | P 38 = 986.97 | P 39 = 985.68 | | | | |
| P 40 = 984.44 | | | | | | | | |
| G = 619.52 | G 1 = 623.81 | G 2 = 628.87 | G 3 = 634.77 | G 4 = 641.59 | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 649.37 | G 6 = 658.17 | G 7 = 668.01 | G 8 = 678.89 | G 9 = 690.80 |
| G 10 = 703.68 | G 11 = 717.47 | G 12 = 732.06 | G 13 = 747.34 | G 14 = 763.16 |
| G 15 = 779.35 | G 16 = 795.73 | G 17 = 812.13 | G 18 = 828.34 | G 19 = 844.18 |
| G 20 = 859.48 | G 21 = 874.08 | G 22 = 887.84 | G 23 = 900.64 | G 24 = 912.41 |
| G 25 = 923.08 | G 26 = 932.63 | G 27 = 941.05 | G 28 = 948.38 | G 29 = 954.65 |
| G 30 = 959.93 | G 31 = 964.31 | G 32 = 967.87 | G 33 = 970.70 | G 34 = 972.91 |
| G 35 = 974.58 | G 36 = 975.81 | G 37 = 976.67 | G 38 = 977.25 | G 39 = 977.61 |
| G 40 = 977.80 | | | | |
| H 1 = 609.33 | H 2 = 611.45 | H 3 = 614.02 | H 4 = 617.12 | H 5 = 620.80 |
| H 6 = 625.14 | H 7 = 630.20 | H 8 = 636.05 | H 9 = 642.73 | H 10 = 650.29 |
| H 11 = 658.76 | H 12 = 668.15 | H 13 = 678.45 | H 14 = 689.64 | H 15 = 701.67 |
| H 16 = 714.48 | H 17 = 727.98 | H 18 = 742.06 | H 19 = 756.60 | H 20 = 771.46 |
| H 21 = 786.50 | H 22 = 801.56 | H 23 = 816.50 | H 24 = 831.16 | H 25 = 845.41 |
| H 26 = 859.11 | H 27 = 872.16 | H 28 = 884.46 | H 29 = 895.94 | H 30 = 906.55 |
| H 31 = 916.24 | H 32 = 925.02 | H 33 = 932.89 | H 34 = 939.87 | H 35 = 946.00 |
| H 36 = 951.34 | H 37 = 955.92 | H 38 = 959.83 | H 39 = 963.13 | H 40 = 965.89 |
| | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.75

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LOC=0.75 T:NA(IN)=610F T:NA(CUT)=1005.91
A21=28.855 A22=96.461 A23=131.17 A24=102.31 A25=54.084

2

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = Z

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA CUT= 1005.9 | DT: NA = 395.91 | T:B NA = 807.95 | T:B M = 825.21 |
| DT M-N = 28.855 | DT1 = 96.461 | DT F-N = 131.17 | DT P-M = 102.31 | DT2 = 54.084 |
| N = .0 | N 1 = .0 | N 2 = .0 | N 3 = .0 | N 4 = .0 |
| N 5 = 610.00 | N 6 = 612.47 | N 7 = 615.47 | N 8 = 619.05 | N 9 = 623.29 |
| N 10 = 628.27 | N 11 = 634.06 | N 12 = 640.71 | N 13 = 648.29 | N 14 = 656.84 |
| N 15 = 666.37 | N 16 = 676.91 | N 17 = 688.44 | N 18 = 700.93 | N 19 = 714.32 |
| N 20 = 728.54 | N 21 = 743.49 | N 22 = 759.05 | N 23 = 775.08 | N 24 = 791.44 |
| N 25 = 807.95 | N 26 = 824.47 | N 27 = 840.83 | N 28 = 856.86 | N 29 = 872.42 |
| N 30 = 887.37 | N 31 = 901.59 | N 32 = 914.98 | N 33 = 927.47 | N 34 = 939.00 |
| N 35 = 949.54 | N 36 = 955.07 | N 37 = 967.62 | N 38 = 975.20 | N 39 = 981.85 |
| N 40 = 987.64 | N 36 = 992.62 | N 37 = 996.86 | N 38 = 1000.4 | N 39 = 1003.4 |
| M = 1005.9 | M 1 = .0 | M 2 = .0 | M 3 = .0 | M 4 = .0 |
| M 5 = 613.91 | M 6 = 617.22 | M 7 = 621.18 | M 8 = 625.85 | M 9 = 631.32 |
| M 10 = 637.64 | M 11 = 644.89 | M 12 = 653.11 | M 13 = 662.34 | M 14 = 672.59 |
| M 15 = 683.87 | M 16 = 696.15 | M 17 = 709.39 | M 18 = 723.51 | M 19 = 738.42 |
| M 20 = 754.00 | M 21 = 770.12 | M 22 = 786.63 | M 23 = 803.36 | M 24 = 820.15 |
| M 25 = 836.81 | M 26 = 853.19 | M 27 = 869.11 | M 28 = 884.45 | M 29 = 899.06 |
| M 30 = 912.83 | M 31 = 925.69 | M 32 = 937.57 | M 33 = 948.43 | M 34 = 958.25 |
| M 35 = 967.04 | M 36 = 974.83 | M 37 = 981.66 | M 38 = 987.59 | M 39 = 992.68 |
| M 40 = 997.00 | M 36 = 1000.6 | M 37 = 1003.7 | M 38 = 1006.2 | M 39 = 1008.2 |
| P = 1009.8 | P 1 = .0 | P 2 = .0 | P 3 = .0 | P 4 = .0 |
| P 5 = 627.75 | P 6 = 634.05 | P 7 = 641.42 | P 8 = 649.97 | P 9 = 659.76 |
| P 10 = 670.86 | P 11 = 683.29 | P 12 = 697.06 | P 13 = 712.14 | P 14 = 728.46 |
| P 15 = 745.93 | P 16 = 764.40 | P 17 = 783.69 | P 18 = 803.59 | P 19 = 823.88 |
| P 20 = 844.30 | P 21 = 864.57 | P 22 = 884.45 | P 23 = 903.65 | P 24 = 921.95 |
| P 25 = 939.12 | P 26 = 954.99 | P 27 = 969.40 | P 28 = 982.26 | P 29 = 993.51 |
| P 30 = 1003.1 | P 31 = 1011.2 | P 32 = 1017.7 | P 33 = 1022.7 | P 34 = 1026.5 |
| P 35 = 1029.1 | P 36 = 1030.7 | P 37 = 1031.5 | P 38 = 1031.5 | P 39 = 1031.1 |
| P 40 = 1030.2 | P 36 = 1029.1 | P 37 = 1027.8 | P 38 = 1026.4 | P 39 = 1025.0 |
| G = 1023.7 | G 1 = .0 | G 2 = .0 | G 3 = .0 | G 4 = .0 |
| G 5 = 620.43 | G 6 = 625.15 | G 7 = 630.72 | G 8 = 637.22 | G 9 = 644.73 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 653.30 | G 6 = 662.99 | G 7 = 673.83 | G 8 = 685.81 | G 9 = 698.93 |
| G 10 = 713.13 | G 11 = 728.32 | G 12 = 744.41 | G 13 = 761.26 | G 14 = 778.71 |
| G 15 = 796.57 | G 16 = 814.65 | G 17 = 832.74 | G 18 = 850.64 | G 19 = 868.14 |
| G 20 = 885.04 | G 21 = 901.18 | G 22 = 916.39 | G 23 = 930.56 | G 24 = 943.58 |
| G 25 = 955.40 | G 26 = 965.98 | G 27 = 975.32 | G 28 = 983.45 | G 29 = 990.42 |
| G 30 = 996.29 | G 31 = 1001.2 | G 32 = 1005.1 | G 33 = 1008.3 | G 34 = 1010.8 |
| G 35 = 1012.7 | G 36 = 1014.0 | G 37 = 1015.0 | G 38 = 1015.7 | G 39 = 1016.1 |
| G 40 = 1016.3 | G 36 = .0 | G 37 = .0 | G 38 = .0 | G 39 = .0 |
| H 1 = 609.29 | H 2 = 611.63 | H 3 = 614.48 | H 4 = 617.91 | H 5 = 621.98 |
| H 6 = 626.79 | H 7 = 632.39 | H 8 = 638.86 | H 9 = 646.25 | H 10 = 654.62 |
| H 11 = 663.99 | H 12 = 674.37 | H 13 = 685.76 | H 14 = 698.13 | H 15 = 711.44 |
| H 16 = 725.60 | H 17 = 740.52 | H 18 = 756.09 | H 19 = 772.16 | H 20 = 788.58 |
| H 21 = 805.20 | H 22 = 821.84 | H 23 = 838.34 | H 24 = 854.54 | H 25 = 870.27 |
| H 26 = 885.41 | H 27 = 895.82 | H 28 = 913.40 | H 29 = 926.08 | H 30 = 937.79 |
| H 31 = 948.49 | H 32 = 958.19 | H 33 = 966.87 | H 34 = 974.58 | H 35 = 981.35 |
| H 36 = 987.23 | H 37 = 992.29 | H 38 = 996.61 | H 39 = 1000.2 | H 40 = 1003.3 |
| H 40 = .0 | H 37 = .0 | H 38 = .0 | H 39 = .0 | H 40 = .0 |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.85

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LOC=0.85 T:NA(IN)=610F T:NA(CUT)=1043.55
 A21=31.377 A22=104.90 A23=142.90 A24=111.52 A25=59.074

2

| ITER NO- | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|---|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1043.6 | DT: NA = 433.55 | T:B NA = 826.77 | T:B M = 845.54 | | | | | |
| DT M-N = 31.377 | DTI = 104.90 | DT P-N = 142.90 | DT P-M = 111.52 | DT2 = 59.074 | | | | | |
| N = 610.00 | N 1 = 612.71 | N 2 = 615.99 | N 3 = 619.91 | N 4 = 624.56 | | | | | |
| N 5 = 630.01 | N 6 = 634.35 | N 7 = 643.63 | N 8 = 651.93 | N 9 = 661.29 | | | | | |
| N 10 = 671.73 | N 11 = 683.27 | N 12 = 695.89 | N 13 = 709.57 | N 14 = 724.24 | | | | | |
| N 15 = 739.81 | N 16 = 756.18 | N 17 = 773.22 | N 18 = 790.77 | N 19 = 808.68 | | | | | |
| N 20 = 826.77 | N 21 = 844.87 | N 22 = 862.78 | N 23 = 880.33 | N 24 = 897.37 | | | | | |
| N 25 = 913.74 | N 26 = 929.31 | N 27 = 943.98 | N 28 = 957.66 | N 29 = 970.28 | | | | | |
| N 30 = 981.82 | N 31 = 992.26 | N 32 = 1001.6 | N 33 = 1009.9 | N 34 = 1017.2 | | | | | |
| N 35 = 1023.5 | N 36 = 1029.0 | N 37 = 1033.6 | N 38 = 1037.6 | N 39 = 1040.8 | | | | | |
| N 40 = 1043.6 | | | | | | | | | |
| M = 614.25 | M 1 = 617.87 | M 2 = 622.20 | M 3 = 627.31 | M 4 = 633.28 | | | | | |
| M 5 = 640.20 | M 6 = 646.12 | M 7 = 657.11 | M 8 = 667.21 | M 9 = 678.42 | | | | | |
| M 10 = 690.76 | M 11 = 704.20 | M 12 = 718.68 | M 13 = 734.13 | M 14 = 750.45 | | | | | |
| M 15 = 767.50 | M 16 = 785.14 | M 17 = 803.21 | M 18 = 821.53 | M 19 = 839.91 | | | | | |
| M 20 = 858.15 | M 21 = 876.09 | M 22 = 893.53 | M 23 = 910.33 | M 24 = 926.33 | | | | | |
| M 25 = 941.43 | M 26 = 955.52 | M 27 = 968.54 | M 28 = 980.44 | M 29 = 991.21 | | | | | |
| M 30 = 1000.9 | M 31 = 1009.4 | M 32 = 1016.9 | M 33 = 1023.4 | M 34 = 1029.0 | | | | | |
| M 35 = 1033.7 | M 36 = 1037.7 | M 37 = 1041.0 | M 38 = 1043.8 | M 39 = 1046.0 | | | | | |
| M 40 = 1047.8 | | | | | | | | | |
| P = 629.34 | P 1 = 636.21 | P 2 = 644.27 | P 3 = 653.60 | P 4 = 664.29 | | | | | |
| P 5 = 676.40 | P 6 = 685.98 | P 7 = 705.02 | P 8 = 721.49 | P 9 = 739.32 | | | | | |
| P 10 = 758.40 | P 11 = 778.58 | P 12 = 799.66 | P 13 = 821.42 | P 14 = 843.60 | | | | | |
| P 15 = 865.92 | P 16 = 888.09 | P 17 = 909.83 | P 18 = 930.84 | P 19 = 950.87 | | | | | |
| P 20 = 969.67 | P 21 = 987.05 | P 22 = 1002.8 | P 23 = 1016.9 | P 24 = 1029.3 | | | | | |
| P 25 = 1039.8 | P 26 = 1048.7 | P 27 = 1055.8 | P 28 = 1061.4 | P 29 = 1065.6 | | | | | |
| P 30 = 1068.5 | P 31 = 1070.3 | P 32 = 1071.2 | P 33 = 1071.3 | P 34 = 1070.8 | | | | | |
| P 35 = 1069.9 | P 36 = 1068.7 | P 37 = 1067.3 | P 38 = 1065.8 | P 39 = 1064.3 | | | | | |
| P 40 = 1062.9 | | | | | | | | | |
| G = 621.34 | G 1 = 626.50 | G 2 = 632.58 | G 3 = 639.67 | G 4 = 647.86 | | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 657.23 | G 6 = 667.81 | G 7 = 679.64 | G 8 = 692.74 | G 9 = 707.06 |
| G 10 = 722.57 | G 11 = 735.18 | G 12 = 756.77 | G 13 = 775.18 | G 14 = 794.25 |
| G 15 = 813.79 | G 16 = 833.56 | G 17 = 853.36 | G 18 = 872.94 | G 19 = 892.09 |
| G 20 = 910.60 | G 21 = 928.27 | G 22 = 944.94 | G 23 = 960.47 | G 24 = 974.75 |
| G 25 = 987.72 | G 26 = 995.33 | G 27 = 1009.6 | G 28 = 1018.5 | G 29 = 1026.2 |
| G 30 = 1032.7 | G 31 = 1038.0 | G 32 = 1042.4 | G 33 = 1045.9 | G 34 = 1048.7 |
| G 35 = 1050.8 | G 36 = 1052.3 | G 37 = 1053.4 | G 38 = 1054.2 | G 39 = 1054.6 |
| G 40 = 1054.9 | | | | |
| H 1 = 609.24 | H 2 = 611.82 | H 3 = 614.94 | H 4 = 618.70 | H 5 = 623.17 |
| H 6 = 628.44 | H 7 = 634.58 | H 8 = 641.68 | H 9 = 649.78 | H 10 = 658.95 |
| H 11 = 669.21 | H 12 = 680.59 | H 13 = 693.08 | H 14 = 706.64 | H 15 = 721.21 |
| H 16 = 736.73 | H 17 = 753.07 | H 18 = 770.12 | H 19 = 787.72 | H 20 = 805.70 |
| H 21 = 823.90 | H 22 = 842.12 | H 23 = 860.15 | H 24 = 877.92 | H 25 = 895.14 |
| H 26 = 911.71 | H 27 = 927.49 | H 28 = 942.35 | H 29 = 956.22 | H 30 = 969.04 |
| H 31 = 980.75 | H 32 = 991.36 | H 33 = 1000.9 | H 34 = 1009.3 | H 35 = 1016.7 |
| H 36 = 1023.1 | H 37 = 1028.7 | H 38 = 1033.4 | H 39 = 1037.4 | H 40 = 1040.7 |
| | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: 0.95

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 1 LOC=.95 T:NA(IN)=610F T:NA(CUT)=1081.18
A21=33.899 A22=113.35 A23=154.63 A24=120.73 A25=64.063

2

| ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | CRITICAL NODE = 2 | | |
|--|------------------|-------------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1081.2 | DT: NA = 471.18 | T:B NA = 845.59 | T:B M = 865.86 |
| DT M-N = 33.899 | DT1 = 113.35 | DT P-N = 154.63 | DT P-M = 120.73 | DT2 = 64.063 |
| N = 610.00 | N 1 = 612.95 | N 2 = 616.51 | N 3 = 620.77 | N 4 = 625.82 |
| N 5 = 631.75 | N 6 = 638.63 | N 7 = 646.55 | N 8 = 655.57 | N 9 = 665.74 |
| N 10 = 677.09 | N 11 = 689.63 | N 12 = 703.35 | N 13 = 718.21 | N 14 = 734.15 |
| N 15 = 751.08 | N 16 = 768.87 | N 17 = 787.38 | N 18 = 806.46 | N 19 = 825.93 |
| N 20 = 845.59 | N 21 = 865.25 | N 22 = 884.72 | N 23 = 903.80 | N 24 = 922.31 |
| N 25 = 940.10 | N 26 = 957.03 | N 27 = 972.97 | N 28 = 987.83 | N 29 = 1001.6 |
| N 30 = 1014.1 | N 31 = 1025.4 | N 32 = 1035.6 | N 33 = 1044.6 | N 34 = 1052.5 |
| N 35 = 1059.4 | N 36 = 1065.4 | N 37 = 1070.4 | N 38 = 1074.7 | N 39 = 1078.2 |
| N 40 = 1081.2 | | | | |
| M = 614.59 | M 1 = 618.52 | M 2 = 623.21 | M 3 = 628.76 | M 4 = 635.25 |
| M 5 = 642.75 | M 6 = 651.36 | M 7 = 661.12 | M 8 = 672.07 | M 9 = 684.25 |
| M 10 = 697.65 | M 11 = 712.24 | M 12 = 727.97 | M 13 = 744.75 | M 14 = 762.47 |
| M 15 = 780.99 | M 16 = 800.16 | M 17 = 819.79 | M 18 = 839.69 | M 19 = 859.66 |
| M 20 = 879.49 | M 21 = 898.98 | M 22 = 917.94 | M 23 = 936.20 | M 24 = 953.60 |
| M 25 = 970.02 | M 26 = 985.34 | M 27 = 999.50 | M 28 = 1012.4 | M 29 = 1024.2 |
| M 30 = 1034.7 | M 31 = 1044.0 | M 32 = 1052.1 | M 33 = 1059.2 | M 34 = 1065.3 |
| M 35 = 1070.4 | M 36 = 1074.8 | M 37 = 1078.4 | M 38 = 1081.4 | M 39 = 1083.8 |
| M 40 = 1085.8 | | | | |
| P = 630.93 | P 1 = 638.38 | P 2 = 647.11 | P 3 = 657.22 | P 4 = 668.81 |
| P 5 = 681.95 | P 6 = 696.67 | P 7 = 712.98 | P 8 = 730.84 | P 9 = 750.18 |
| P 10 = 770.88 | P 11 = 792.76 | P 12 = 815.63 | P 13 = 839.24 | P 14 = 863.31 |
| P 15 = 887.54 | P 16 = 911.61 | P 17 = 935.21 | P 18 = 958.03 | P 19 = 979.79 |
| P 20 = 1000.2 | P 21 = 1019.1 | P 22 = 1036.3 | P 23 = 1051.6 | P 24 = 1065.1 |
| P 25 = 1076.6 | P 26 = 1086.2 | P 27 = 1094.0 | P 28 = 1100.1 | P 29 = 1104.7 |
| P 30 = 1107.9 | P 31 = 1109.9 | P 32 = 1110.9 | P 33 = 1111.0 | P 34 = 1110.6 |
| P 35 = 1109.6 | P 36 = 1108.4 | P 37 = 1106.9 | P 38 = 1105.3 | P 39 = 1103.7 |
| P 40 = 1102.1 | | | | |
| G = 622.26 | G 1 = 627.84 | G 2 = 634.43 | G 3 = 642.12 | G 4 = 651.00 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 661.15 | G 6 = 672.63 | G 7 = 685.46 | G 8 = 699.66 | G 9 = 715.20 |
| G 10 = 732.02 | G 11 = 750.04 | G 12 = 769.12 | G 13 = 789.10 | G 14 = 809.81 |
| G 15 = 831.01 | G 16 = 852.48 | G 17 = 873.97 | G 18 = 895.24 | G 19 = 916.05 |
| G 20 = 936.16 | G 21 = 955.37 | G 22 = 973.50 | G 23 = 990.38 | G 24 = 1005.9 |
| G 25 = 1020.0 | G 26 = 1032.7 | G 27 = 1043.9 | G 28 = 1053.6 | G 29 = 1062.0 |
| G 30 = 1069.0 | G 31 = 1074.9 | G 32 = 1079.7 | G 33 = 1083.5 | G 34 = 1086.5 |
| G 35 = 1088.8 | G 36 = 1090.5 | G 37 = 1091.8 | G 38 = 1092.6 | G 39 = 1093.1 |
| G 40 = 1093.4 | | | | |
| H 1 = 609.20 | H 2 = 612.00 | H 3 = 615.40 | H 4 = 619.49 | H 5 = 624.35 |
| H 6 = 630.09 | H 7 = 636.77 | H 8 = 644.49 | H 9 = 653.30 | H 10 = 663.27 |
| H 11 = 674.44 | H 12 = 686.81 | H 13 = 700.39 | H 14 = 715.13 | H 15 = 730.98 |
| H 16 = 747.84 | H 17 = 765.61 | H 18 = 784.14 | H 19 = 803.27 | H 20 = 822.81 |
| H 21 = 842.59 | H 22 = 862.39 | H 23 = 882.02 | H 24 = 901.29 | H 25 = 920.00 |
| H 26 = 938.00 | H 27 = 955.14 | H 28 = 971.25 | H 29 = 986.36 | H 30 = 1000.3 |
| H 31 = 1013.0 | H 32 = 1024.5 | H 33 = 1034.8 | H 34 = 1044.0 | H 35 = 1052.0 |
| H 36 = 1059.0 | H 37 = 1065.0 | H 38 = 1070.2 | H 39 = 1074.5 | H 40 = 1078.1 |
| H 40 = .0 | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 2

Location x/L: 0.05

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 2 LDC=.05 T:NA(IN)=610F T:NA(CUT)=1021.29
A21=36.226 A22=121.15 A23=165.68 A24=129.46 A25=68.890

2

ITER NG. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA CUT= 1021.3 | DT: NA = 411.29 | T:B NA = 815.64 | T:B M = 837.31 |
| DT M-N = 36.226 | DT1 = 121.15 | DT F-N = 165.68 | DT P-M = 129.46 | DT2 = 68.891 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N 1 = 610.00 | N 1 = 612.57 | N 2 = 615.68 | N 3 = 619.40 | N 4 = 623.81 |
| N 5 = 628.98 | N 6 = 634.99 | N 7 = 641.91 | N 8 = 649.78 | N 9 = 658.66 |
| N 10 = 668.56 | N 11 = 675.51 | N 12 = 691.48 | N 13 = 704.46 | N 14 = 718.37 |
| N 15 = 733.14 | N 16 = 746.67 | N 17 = 764.84 | N 18 = 781.49 | N 19 = 798.48 |
| N 20 = 815.65 | N 21 = 832.81 | N 22 = 849.80 | N 23 = 866.45 | N 24 = 882.62 |
| N 25 = 898.15 | N 26 = 912.92 | N 27 = 926.83 | N 28 = 939.81 | N 29 = 951.78 |
| N 30 = 962.73 | N 31 = 972.63 | N 32 = 981.51 | N 33 = 989.38 | N 34 = 996.29 |
| N 35 = 1002.3 | N 36 = 1007.5 | N 37 = 1011.9 | N 38 = 1015.6 | N 39 = 1018.7 |
| N 40 = 1021.3 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M 1 = 614.90 | M 1 = 618.53 | M 2 = 622.85 | M 3 = 627.94 | M 4 = 633.86 |
| M 5 = 640.74 | M 6 = 648.59 | M 7 = 657.47 | M 8 = 667.41 | M 9 = 678.44 |
| M 10 = 690.53 | M 11 = 703.67 | M 12 = 717.79 | M 13 = 732.81 | M 14 = 748.63 |
| M 15 = 765.11 | M 16 = 782.11 | M 17 = 799.47 | M 18 = 817.00 | M 19 = 834.53 |
| M 20 = 851.87 | M 21 = 866.85 | M 22 = 885.31 | M 23 = 901.08 | M 24 = 916.06 |
| M 25 = 930.11 | M 26 = 943.18 | M 27 = 955.19 | M 28 = 966.11 | M 29 = 975.94 |
| M 30 = 984.70 | M 31 = 992.42 | M 32 = 999.14 | M 33 = 1004.9 | M 34 = 1009.9 |
| M 35 = 1014.1 | M 36 = 1017.6 | M 37 = 1020.4 | M 38 = 1022.8 | M 39 = 1024.7 |
| M 40 = 1026.2 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P 1 = 632.42 | P 1 = 635.82 | P 2 = 648.47 | P 3 = 658.46 | P 4 = 669.87 |
| P 5 = 682.77 | P 6 = 697.18 | P 7 = 713.08 | P 8 = 730.42 | P 9 = 749.13 |
| P 10 = 769.05 | P 11 = 790.01 | P 12 = 811.79 | P 13 = 834.14 | P 14 = 856.76 |
| P 15 = 879.36 | P 16 = 901.62 | P 17 = 923.23 | P 18 = 943.89 | P 19 = 963.34 |
| P 20 = 981.32 | P 21 = 997.66 | P 22 = 1012.2 | P 23 = 1024.8 | P 24 = 1035.6 |
| P 25 = 1044.4 | P 26 = 1051.3 | P 27 = 1056.5 | P 28 = 1060.1 | P 29 = 1062.3 |
| P 30 = 1063.2 | P 31 = 1063.1 | P 32 = 1062.2 | P 33 = 1060.6 | P 34 = 1058.5 |
| P 35 = 1056.1 | P 36 = 1053.5 | P 37 = 1050.9 | P 38 = 1048.4 | P 39 = 1046.0 |
| P 40 = 1043.7 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G 1 = 623.10 | G 1 = 628.49 | G 2 = 634.84 | G 3 = 642.22 | G 4 = 650.72 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 660.41 | G 6 = 671.33 | G 7 = 683.49 | G 8 = 696.90 | G 9 = 711.52 |
| G 10 = 727.27 | G 11 = 744.07 | G 12 = 761.78 | G 13 = 780.22 | G 14 = 799.23 |
| G 15 = 818.57 | G 16 = 836.03 | G 17 = 857.38 | G 18 = 876.38 | G 19 = 894.80 |
| G 20 = 912.45 | G 21 = 929.12 | G 22 = 944.68 | G 23 = 958.99 | G 24 = 971.97 |
| G 25 = 983.57 | G 26 = 993.77 | G 27 = 1002.6 | G 28 = 1010.1 | G 29 = 1016.3 |
| G 30 = 1021.4 | G 31 = 1025.5 | G 32 = 1028.6 | G 33 = 1031.0 | G 34 = 1032.6 |
| G 35 = 1033.7 | G 36 = 1034.4 | G 37 = 1034.7 | G 38 = 1034.8 | G 39 = 1034.6 |
| G 40 = 1034.4 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 608.57 | H 2 = 610.86 | H 3 = 613.66 | H 4 = 617.04 | H 5 = 621.08 |
| H 6 = 625.86 | H 7 = 631.45 | H 8 = 637.93 | H 9 = 645.36 | H 10 = 653.79 |
| H 11 = 663.27 | H 12 = 673.80 | H 13 = 685.40 | H 14 = 698.03 | H 15 = 711.66 |
| H 16 = 726.20 | H 17 = 741.56 | H 18 = 757.62 | H 19 = 774.26 | H 20 = 791.30 |
| H 21 = 808.58 | H 22 = 825.93 | H 23 = 843.17 | H 24 = 860.14 | H 25 = 876.66 |
| H 26 = 892.58 | H 27 = 907.77 | H 28 = 922.12 | H 29 = 935.54 | H 30 = 947.96 |
| H 31 = 959.34 | H 32 = 965.66 | H 33 = 978.92 | H 34 = 987.16 | H 35 = 994.40 |
| H 36 = 1000.7 | H 37 = 1006.1 | H 38 = 1010.8 | H 39 = 1014.7 | H 40 = 1018.0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 2

Location x/L: 0.15

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 2 LOC=0.15 T:NA(IN)=610F T:NA(CUT)=1051.71
A21=38.357 A22=128.30 A23=176.05 A24=137.69 A25=73.555

2

| ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | CRITICAL NODE = 2 | | |
|--|------------------|-------------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1051.7 | DT: NA = 441.71 | T:B NA = 830.85 | T:B M = 853.80 |
| DT M-N = 38.357 | DTI = 126.30 | DT F-N = 176.05 | DT P-M = 137.69 | DT2 = 73.555 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.76 | N 2 = 616.10 | N 3 = 620.10 | N 4 = 624.83 |
| N 5 = 630.39 | N 6 = 636.84 | N 7 = 644.27 | N 8 = 652.72 | N 9 = 662.25 |
| N 10 = 672.89 | N 11 = 684.65 | N 12 = 697.51 | N 13 = 711.44 | N 14 = 726.39 |
| N 15 = 742.25 | N 16 = 758.93 | N 17 = 776.29 | N 18 = 794.18 | N 19 = 812.42 |
| N 20 = 830.85 | N 21 = 845.29 | N 22 = 867.53 | N 23 = 885.42 | N 24 = 902.78 |
| N 25 = 919.46 | N 26 = 935.32 | N 27 = 950.27 | N 28 = 964.20 | N 29 = 977.06 |
| N 30 = 988.82 | N 31 = 995.46 | N 32 = 1009.0 | N 33 = 1017.4 | N 34 = 1024.9 |
| N 35 = 1031.3 | N 36 = 1036.9 | N 37 = 1041.6 | N 38 = 1045.6 | N 39 = 1048.9 |
| N 40 = 1051.7 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 615.19 | M 1 = 615.07 | M 2 = 623.69 | M 3 = 629.14 | M 4 = 635.50 |
| M 5 = 642.84 | M 6 = 651.24 | M 7 = 660.74 | M 8 = 671.39 | M 9 = 683.20 |
| M 10 = 696.16 | M 11 = 710.23 | M 12 = 725.36 | M 13 = 741.47 | M 14 = 758.43 |
| M 15 = 776.10 | M 16 = 794.34 | M 17 = 812.96 | M 18 = 831.77 | M 19 = 850.59 |
| M 20 = 869.21 | M 21 = 887.45 | M 22 = 905.13 | M 23 = 922.09 | M 24 = 938.19 |
| M 25 = 953.31 | M 26 = 967.36 | M 27 = 980.29 | M 28 = 992.05 | M 29 = 1002.6 |
| M 30 = 1012.1 | M 31 = 1020.4 | M 32 = 1027.7 | M 33 = 1033.9 | M 34 = 1039.3 |
| M 35 = 1043.8 | M 36 = 1047.5 | M 37 = 1050.7 | M 38 = 1053.2 | M 39 = 1055.3 |
| M 40 = 1056.9 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 631.83 | P 1 = 641.72 | P 2 = 650.94 | P 3 = 661.60 | P 4 = 673.78 |
| P 5 = 687.54 | P 6 = 702.92 | P 7 = 719.89 | P 8 = 738.41 | P 9 = 758.39 |
| P 10 = 779.67 | P 11 = 802.07 | P 12 = 825.35 | P 13 = 849.24 | P 14 = 873.44 |
| P 15 = 897.62 | P 16 = 921.45 | P 17 = 944.59 | P 18 = 966.74 | P 19 = 987.60 |
| P 20 = 1006.9 | P 21 = 1024.5 | P 22 = 1040.1 | P 23 = 1053.7 | P 24 = 1065.3 |
| P 25 = 1074.8 | P 26 = 1082.4 | P 27 = 1088.1 | P 28 = 1092.0 | P 29 = 1094.5 |
| P 30 = 1095.6 | P 31 = 1095.6 | P 32 = 1094.7 | P 33 = 1093.1 | P 34 = 1090.9 |
| P 35 = 1088.5 | P 36 = 1085.8 | P 37 = 1083.1 | P 38 = 1080.5 | P 39 = 1077.9 |
| P 40 = 1075.5 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 623.87 | G 1 = 625.62 | G 2 = 636.38 | G 3 = 644.26 | G 4 = 653.33 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 663.67 | G 6 = 675.32 | G 7 = 688.30 | G 8 = 702.62 | G 9 = 718.23 |
| G 10 = 735.07 | G 11 = 753.02 | G 12 = 771.95 | G 13 = 791.68 | G 14 = 812.01 |
| G 15 = 832.71 | G 16 = 853.56 | G 17 = 874.29 | G 18 = 894.65 | G 19 = 914.42 |
| G 20 = 933.36 | G 21 = 951.28 | G 22 = 968.01 | G 23 = 983.42 | G 24 = 997.40 |
| G 25 = 1009.9 | G 26 = 1020.9 | G 27 = 1030.5 | G 28 = 1038.6 | G 29 = 1045.4 |
| G 30 = 1051.0 | G 31 = 1055.4 | G 32 = 1058.9 | G 33 = 1061.5 | G 34 = 1063.3 |
| G 35 = 1064.6 | G 36 = 1065.4 | G 37 = 1065.8 | G 38 = 1065.9 | G 39 = 1065.8 |
| G 40 = 1065.6 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 608.52 | H 2 = 610.99 | H 3 = 614.01 | H 4 = 617.66 | H 5 = 622.01 |
| H 6 = 621.16 | H 7 = 633.19 | H 8 = 640.17 | H 9 = 648.17 | H 10 = 657.25 |
| H 11 = 667.45 | H 12 = 676.78 | H 13 = 691.26 | H 14 = 704.84 | H 15 = 719.49 |
| H 16 = 735.12 | H 17 = 751.63 | H 18 = 768.89 | H 19 = 786.76 | H 20 = 805.06 |
| H 21 = 823.62 | H 22 = 842.25 | H 23 = 860.76 | H 24 = 878.97 | H 25 = 896.69 |
| H 26 = 913.78 | H 27 = 930.08 | H 28 = 945.47 | H 29 = 959.86 | H 30 = 973.17 |
| H 31 = 985.37 | H 32 = 996.43 | H 33 = 1006.4 | H 34 = 1015.2 | H 35 = 1022.9 |
| H 36 = 1029.7 | H 37 = 1035.5 | H 38 = 1040.5 | H 39 = 1044.7 | H 40 = 1048.2 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 2

Solar Flux: REFERENCE
Orifices: NO
Sub-Panel: 2
Location x/L: 0.25
T(Na-inlet) = 610 F
T(Na-outlet) : Max = 1100F

PANEL 2 LOC=.25 T:NA(IN)=610F T:NA(CUT)=1082-14
A21=40.488 A22=135.46 A23=186.41 A24=145.92 A25=78.221

2

| ITER NO. | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|---|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA CUT= 1082.1 | DT: NA = 472.14 | T:8 NA = 846.07 | T:8 M = 870.29 | | | | | |
| DT M-N = 40.488 | DT1 = 135.46 | DT P-N = 186.41 | DT P-M = 145.92 | DT2 = 78.221 | | | | | |
| N = 610.00 | N 1 = 612.95 | N 2 = 616.52 | N 3 = 620.79 | N 4 = 625.85 | | | | | |
| N 5 = 631.79 | N 6 = 638.69 | N 7 = 646.63 | N 8 = 655.67 | N 9 = 665.85 | | | | | |
| N 10 = 677.23 | N 11 = 685.79 | N 12 = 703.54 | N 13 = 718.43 | N 14 = 734.41 | | | | | |
| N 15 = 751.36 | N 16 = 765.19 | N 17 = 787.75 | N 18 = 806.86 | N 19 = 826.37 | | | | | |
| N 20 = 846.07 | N 21 = 865.77 | N 22 = 885.28 | N 23 = 904.39 | N 24 = 922.95 | | | | | |
| N 25 = 940.78 | N 26 = 957.73 | N 27 = 973.71 | N 28 = 988.60 | N 29 = 1002.3 | | | | | |
| N 30 = 1014.9 | N 31 = 1026.3 | N 32 = 1036.5 | N 33 = 1045.5 | N 34 = 1053.4 | | | | | |
| N 35 = 1060.3 | N 36 = 1066.3 | N 37 = 1071.3 | N 38 = 1075.6 | N 39 = 1079.2 | | | | | |
| N 40 = 1082.1 | | | | | | | | | |
| M = 615.48 | M 1 = 615.61 | M 2 = 624.53 | M 3 = 630.34 | M 4 = 637.11 | | | | | |
| M 5 = 644.94 | M 6 = 653.89 | M 7 = 664.02 | M 8 = 675.37 | M 9 = 687.96 | | | | | |
| M 10 = 701.78 | M 11 = 716.80 | M 12 = 732.94 | M 13 = 750.12 | M 14 = 768.22 | | | | | |
| M 15 = 787.09 | M 16 = 806.57 | M 17 = 826.45 | M 18 = 846.55 | M 19 = 866.66 | | | | | |
| M 20 = 886.56 | M 21 = 906.06 | M 22 = 924.96 | M 23 = 943.10 | M 24 = 960.32 | | | | | |
| M 25 = 976.51 | M 26 = 991.55 | M 27 = 1005.4 | M 28 = 1018.0 | M 29 = 1029.4 | | | | | |
| M 30 = 1039.5 | M 31 = 1048.4 | M 32 = 1056.2 | M 33 = 1062.9 | M 34 = 1068.6 | | | | | |
| M 35 = 1073.5 | M 36 = 1077.5 | M 37 = 1086.5 | M 38 = 1083.6 | M 39 = 1085.8 | | | | | |
| M 40 = 1087.6 | | | | | | | | | |
| P = 635.23 | P 1 = 643.61 | P 2 = 653.41 | P 3 = 664.74 | P 4 = 677.68 | | | | | |
| P 5 = 692.31 | P 6 = 706.65 | P 7 = 726.70 | P 8 = 746.40 | P 9 = 767.65 | | | | | |
| P 10 = 790.29 | P 11 = 814.12 | P 12 = 838.90 | P 13 = 864.34 | P 14 = 890.11 | | | | | |
| P 15 = 915.87 | P 16 = 941.27 | P 17 = 965.55 | P 18 = 989.58 | P 19 = 1011.8 | | | | | |
| P 20 = 1032.5 | P 21 = 1051.3 | P 22 = 1068.0 | P 23 = 1082.6 | P 24 = 1095.0 | | | | | |
| P 25 = 1105.3 | P 26 = 1113.4 | P 27 = 1119.6 | P 28 = 1124.0 | P 29 = 1126.7 | | | | | |
| P 30 = 1128.0 | P 31 = 1128.1 | P 32 = 1127.2 | P 33 = 1125.6 | P 34 = 1123.4 | | | | | |
| P 35 = 1120.9 | P 36 = 1118.1 | P 37 = 1115.3 | P 38 = 1112.5 | P 39 = 1109.8 | | | | | |
| P 40 = 1107.4 | | | | | | | | | |
| G = 624.65 | G 1 = 630.75 | G 2 = 637.94 | G 3 = 646.30 | G 4 = 655.94 | | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 666.93 | G 6 = 675.31 | G 7 = 693.11 | G 8 = 708.34 | G 9 = 724.95 |
| G 10 = 742.86 | G 11 = 761.97 | G 12 = 782.12 | G 13 = 803.14 | G 14 = 824.80 |
| G 15 = 846.87 | G 16 = 865.09 | G 17 = 851.20 | G 18 = 912.94 | G 19 = 934.05 |
| G 20 = 954.29 | G 21 = 973.45 | G 22 = 991.35 | G 23 = 1007.9 | G 24 = 1022.8 |
| G 25 = 1036.3 | G 26 = 1048.1 | G 27 = 1058.4 | G 28 = 1067.2 | G 29 = 1074.5 |
| G 30 = 1080.6 | G 31 = 1085.4 | G 32 = 1085.1 | G 33 = 1092.0 | G 34 = 1094.1 |
| G 35 = 1095.5 | G 36 = 1096.4 | G 37 = 1096.9 | G 38 = 1097.0 | G 39 = 1097.0 |
| G 40 = 1096.8 | | | | |
| H 1 = 608.47 | H 2 = 611.13 | H 3 = 614.37 | H 4 = 618.28 | H 5 = 622.95 |
| H 6 = 628.47 | H 7 = 634.93 | H 8 = 642.41 | H 9 = 650.98 | H 10 = 660.70 |
| H 11 = 671.62 | H 12 = 683.76 | H 13 = 697.11 | H 14 = 711.65 | H 15 = 727.32 |
| H 16 = 744.04 | H 17 = 761.70 | H 18 = 780.16 | H 19 = 799.26 | H 20 = 818.83 |
| H 21 = 838.66 | H 22 = 858.57 | H 23 = 878.35 | H 24 = 897.80 | H 25 = 916.73 |
| H 26 = 934.98 | H 27 = 952.38 | H 28 = 968.82 | H 29 = 984.18 | H 30 = 998.39 |
| H 31 = 1011.4 | H 32 = 1023.2 | H 33 = 1033.8 | H 34 = 1043.2 | H 35 = 1051.5 |
| H 36 = 1058.7 | H 37 = 1064.9 | H 38 = 1070.2 | H 39 = 1074.7 | H 40 = 1078.5 |
| | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 2

Location x/L: FULL

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PANEL 2 LOC=FULL T:NA(IN)=610F T:NA(OUT)=1100.00
A21=41.740 A22=139.66 A23=192.50 A24=150.76 A25=80.960

2

| ITER NO. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|--|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT = 1100.0 | DT: NA = 490.00 | T:B NA = 855.00 | T:B M = 879.96 | | | | |
| DT M-N = 41.740 | DT1 = 139.66 | DT F-N = 192.50 | DT P-M = 150.76 | DT2 = 80.960 | | | | |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 | | | | |
| N 5 = 610.00 | N 1 = 613.06 | N 2 = 616.77 | N 3 = 621.20 | N 4 = 626.45 | | | | |
| N 10 = 632.62 | N 6 = 639.78 | N 7 = 648.01 | N 8 = 657.39 | N 9 = 667.97 | | | | |
| N 15 = 679.77 | N 11 = 692.81 | N 12 = 707.08 | N 13 = 722.53 | N 14 = 739.11 | | | | |
| N 20 = 756.71 | N 16 = 775.21 | N 17 = 794.47 | N 18 = 814.31 | N 19 = 834.55 | | | | |
| N 25 = 855.00 | N 21 = 875.45 | N 22 = 895.69 | N 23 = 915.53 | N 24 = 934.79 | | | | |
| N 30 = 953.29 | N 26 = 970.89 | N 27 = 987.47 | N 28 = 1002.9 | N 29 = 1017.2 | | | | |
| N 35 = 1030.2 | N 31 = 1042.0 | N 32 = 1052.6 | N 33 = 1062.0 | N 34 = 1070.2 | | | | |
| N 40 = 1077.4 | N 36 = 1063.5 | N 37 = 1088.8 | N 38 = 1093.2 | N 39 = 1096.9 | | | | |
| M = 1100.0 | M = .0 | M = .0 | M = .0 | M = .0 | | | | |
| M 5 = 615.65 | M 1 = 619.93 | M 2 = 625.03 | M 3 = 631.04 | M 4 = 638.06 | | | | |
| M 10 = 646.17 | M 6 = 655.44 | M 7 = 665.94 | M 8 = 677.71 | M 9 = 690.76 | | | | |
| M 15 = 705.08 | M 11 = 720.65 | M 12 = 737.39 | M 13 = 755.20 | M 14 = 773.97 | | | | |
| M 20 = 793.55 | M 16 = 813.74 | M 17 = 834.37 | M 18 = 855.22 | M 19 = 876.09 | | | | |
| M 25 = 896.74 | M 21 = 916.98 | M 22 = 936.60 | M 23 = 955.43 | M 24 = 973.32 | | | | |
| M 30 = 990.12 | M 26 = 1005.8 | M 27 = 1020.1 | M 28 = 1033.2 | M 29 = 1045.0 | | | | |
| M 35 = 1055.5 | M 31 = 1064.8 | M 32 = 1072.9 | M 33 = 1079.9 | M 34 = 1085.9 | | | | |
| M 40 = 1090.9 | M 36 = 1095.2 | M 37 = 1098.6 | M 38 = 1101.5 | M 39 = 1103.8 | | | | |
| P = 1105.6 | P = .0 | P = .0 | P = .0 | P = .0 | | | | |
| P 5 = 636.05 | P 1 = 644.72 | P 2 = 654.86 | P 3 = 666.58 | P 4 = 679.97 | | | | |
| P 10 = 695.11 | P 6 = 712.03 | P 7 = 730.70 | P 8 = 751.09 | P 9 = 773.09 | | | | |
| P 15 = 796.53 | P 11 = 821.20 | P 12 = 846.86 | P 13 = 873.21 | P 14 = 899.90 | | | | |
| P 20 = 926.59 | P 16 = 952.91 | P 17 = 978.50 | P 18 = 1003.0 | P 19 = 1026.1 | | | | |
| P 25 = 1047.5 | P 21 = 1067.0 | P 22 = 1084.4 | P 23 = 1099.6 | P 24 = 1112.5 | | | | |
| P 30 = 1123.2 | P 26 = 1131.7 | P 27 = 1138.1 | P 28 = 1142.7 | P 29 = 1145.6 | | | | |
| P 35 = 1147.0 | P 31 = 1147.2 | P 32 = 1146.3 | P 33 = 1144.7 | P 34 = 1142.5 | | | | |
| P 40 = 1139.9 | P 36 = 1137.1 | P 37 = 1134.2 | P 38 = 1131.3 | P 39 = 1128.6 | | | | |
| G = 1126.1 | G = .0 | G = .0 | G = .0 | G = .0 | | | | |
| G 5 = 625.10 | G 1 = 631.41 | G 2 = 638.85 | G 3 = 647.50 | G 4 = 657.47 | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 668.84 | G 6 = 681.65 | G 7 = 695.94 | G 8 = 711.70 | G 9 = 728.89 |
| G 10 = 747.44 | G 11 = 767.22 | G 12 = 788.09 | G 13 = 809.86 | G 14 = 832.30 |
| G 15 = 855.17 | G 16 = 878.20 | G 17 = 901.13 | G 18 = 923.67 | G 19 = 945.57 |
| G 20 = 966.57 | G 21 = 986.46 | G 22 = 1005.0 | G 23 = 1022.2 | G 24 = 1037.8 |
| G 25 = 1051.7 | G 26 = 1064.1 | G 27 = 1074.8 | G 28 = 1083.9 | G 29 = 1091.6 |
| G 30 = 1097.9 | G 31 = 1103.0 | G 32 = 1106.9 | G 33 = 1109.9 | G 34 = 1112.1 |
| G 35 = 1113.6 | G 36 = 1114.6 | G 37 = 1115.1 | G 38 = 1115.3 | G 39 = 1115.3 |
| G 40 = 1115.1 | G = .0 | G = .0 | G = .0 | G = .0 |
| H 1 = 608.44 | H 2 = 611.21 | H 3 = 614.58 | H 4 = 618.64 | H 5 = 623.50 |
| H 6 = 629.24 | H 7 = 635.95 | H 8 = 643.72 | H 9 = 652.63 | H 10 = 662.73 |
| H 11 = 674.07 | H 12 = 684.68 | H 13 = 700.55 | H 14 = 715.65 | H 15 = 731.92 |
| H 16 = 749.28 | H 17 = 767.61 | H 18 = 786.78 | H 19 = 806.60 | H 20 = 826.91 |
| H 21 = 847.50 | H 22 = 868.15 | H 23 = 888.68 | H 24 = 908.86 | H 25 = 928.50 |
| H 26 = 947.43 | H 27 = 965.48 | H 28 = 982.52 | H 29 = 998.45 | H 30 = 1013.2 |
| H 31 = 1026.7 | H 32 = 1038.9 | H 33 = 1049.9 | H 34 = 1059.7 | H 35 = 1068.3 |
| H 36 = 1075.7 | H 37 = 1082.2 | H 38 = 1087.7 | H 39 = 1092.3 | H 40 = 1096.2 |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 |



PANEL TEMPERATURE DISTRIBUTION

CASE 2

SET 3 Subpanel Boundaries

Solar Flux Distribution: REFERENCE

Orifices: None

Sodium Temperatures: T (Na-Inlet) = 610°F
 T (Na-Outlet) = 1100°F maximum
 (723.66 to 1100°F)

5370F/sjh

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

(Q/A)=0.225MW/M2 T:NA(IN)=610F T:NA(OUT)=723.66 PL 1,OUT Sub-Panel: 1
A21=9.94 A22=33.133 A23=43.17 A24=33.23 A25=16.662

Location x/L: OUT (0.0)

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

2

| ITER NO. | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = -0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|---|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 723.66 | DT: NA = 113.66 | T:B NA = 666.83 | T:B M = 672.77 | | | | | |
| DT M-N = 9.9400 | DT1 = 33.133 | DT P-N = 43.170 | DT P-M = 33.230 | DT2 = 16.662 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| N 5 = 610.00 | N 1 = 610.71 | N 2 = 611.57 | N 3 = 612.60 | N 4 = 613.82 | | | | | |
| N 6 = 615.25 | N 6 = 616.91 | N 7 = 618.82 | N 8 = 620.99 | N 9 = 623.45 | | | | | |
| N 10 = 626.18 | N 11 = 625.21 | N 12 = 632.52 | N 13 = 636.10 | N 14 = 639.95 | | | | | |
| N 15 = 644.03 | N 16 = 648.32 | N 17 = 652.79 | N 18 = 657.39 | N 19 = 662.09 | | | | | |
| N 20 = 666.83 | N 21 = 671.57 | N 22 = 676.27 | N 23 = 680.87 | N 24 = 685.34 | | | | | |
| N 25 = 689.63 | N 26 = 693.71 | N 27 = 697.56 | N 28 = 701.14 | N 29 = 704.45 | | | | | |
| N 30 = 707.48 | N 31 = 710.21 | N 32 = 712.67 | N 33 = 714.84 | N 34 = 716.75 | | | | | |
| N 35 = 718.41 | N 36 = 715.84 | N 37 = 721.06 | N 38 = 722.09 | N 39 = 722.95 | | | | | |
| N 40 = 723.66 | = .0 | = .0 | = .0 | = .0 | | | | | |
| M 5 = 611.35 | M 1 = 612.35 | M 2 = 613.54 | M 3 = 614.94 | M 4 = 616.58 | | | | | |
| M 6 = 618.47 | M 6 = 620.64 | M 7 = 623.09 | M 8 = 625.83 | M 9 = 628.87 | | | | | |
| M 10 = 632.21 | M 11 = 635.84 | M 12 = 639.74 | M 13 = 643.88 | M 14 = 648.25 | | | | | |
| M 15 = 652.80 | M 16 = 657.50 | M 17 = 662.29 | M 18 = 667.14 | M 19 = 671.98 | | | | | |
| M 20 = 676.77 | M 21 = 681.46 | M 22 = 686.01 | M 23 = 690.37 | M 24 = 694.51 | | | | | |
| M 25 = 698.40 | M 26 = 702.01 | M 27 = 705.34 | M 28 = 708.36 | M 29 = 711.08 | | | | | |
| M 30 = 713.51 | M 31 = 715.64 | M 32 = 717.50 | M 33 = 719.11 | M 34 = 720.48 | | | | | |
| M 35 = 721.64 | M 36 = 722.61 | M 37 = 723.41 | M 38 = 724.06 | M 39 = 724.58 | | | | | |
| M 40 = 725.01 | = .0 | = .0 | = .0 | = .0 | | | | | |
| P 5 = 615.84 | P 1 = 617.81 | P 2 = 620.11 | P 3 = 622.77 | P 4 = 625.82 | | | | | |
| P 6 = 629.26 | P 6 = 633.11 | P 7 = 637.36 | P 8 = 642.01 | P 9 = 647.02 | | | | | |
| P 10 = 652.37 | P 11 = 658.00 | P 12 = 663.87 | P 13 = 669.89 | P 14 = 676.01 | | | | | |
| P 15 = 682.13 | P 16 = 688.17 | P 17 = 694.06 | P 18 = 699.71 | P 19 = 705.04 | | | | | |
| P 20 = 710.00 | P 21 = 714.53 | P 22 = 718.58 | P 23 = 722.14 | P 24 = 725.19 | | | | | |
| P 25 = 727.73 | P 26 = 725.77 | P 27 = 731.35 | P 28 = 732.49 | P 29 = 733.24 | | | | | |
| P 30 = 733.66 | P 31 = 733.79 | P 32 = 733.68 | P 33 = 733.39 | P 34 = 732.95 | | | | | |
| P 35 = 732.43 | P 36 = 731.85 | P 37 = 731.24 | P 38 = 730.63 | P 39 = 730.05 | | | | | |
| P 40 = 729.50 | = .0 | = .0 | = .0 | = .0 | | | | | |
| G 5 = 613.59 | G 1 = 615.07 | G 2 = 616.81 | G 3 = 618.85 | G 4 = 621.19 | | | | | |
| G 5 = 623.85 | G 6 = 626.86 | G 7 = 630.20 | G 8 = 633.90 | G 9 = 637.92 | | | | | |
| G 10 = 642.26 | G 11 = 646.89 | G 12 = 651.77 | G 13 = 656.85 | G 14 = 662.09 | | | | | |
| G 15 = 667.42 | G 16 = 672.79 | G 17 = 678.13 | G 18 = 683.37 | G 19 = 688.46 | | | | | |
| G 20 = 693.34 | G 21 = 697.95 | G 22 = 702.25 | G 23 = 706.21 | G 24 = 709.81 | | | | | |
| G 25 = 713.02 | G 26 = 715.85 | G 27 = 718.30 | G 28 = 720.39 | G 29 = 722.13 | | | | | |
| G 30 = 723.55 | G 31 = 724.69 | G 32 = 725.57 | G 33 = 726.23 | G 34 = 726.70 | | | | | |
| G 35 = 727.02 | G 36 = 727.21 | G 37 = 727.31 | G 38 = 727.34 | G 39 = 727.31 | | | | | |
| G 40 = 727.25 | = .0 | = .0 | = .0 | = .0 | | | | | |
| H 1 = 609.62 | H 2 = 610.26 | H 3 = 611.04 | H 4 = 611.97 | H 5 = 613.09 | | | | | |
| H 6 = 614.42 | H 7 = 615.97 | H 8 = 617.77 | H 9 = 619.83 | H 10 = 622.16 | | | | | |
| H 11 = 624.79 | H 12 = 627.71 | H 13 = 630.92 | H 14 = 634.41 | H 15 = 638.18 | | | | | |
| H 16 = 642.21 | H 17 = 646.45 | H 18 = 650.90 | H 19 = 655.49 | H 20 = 660.20 | | | | | |
| H 21 = 664.98 | H 22 = 665.77 | H 23 = 674.54 | H 24 = 679.22 | H 25 = 683.78 | | | | | |
| H 26 = 688.18 | H 27 = 692.37 | H 28 = 696.33 | H 29 = 700.03 | H 30 = 703.46 | | | | | |
| H 31 = 706.59 | H 32 = 705.44 | H 33 = 712.00 | H 34 = 714.27 | H 35 = 716.26 | | | | | |
| H 36 = 718.00 | H 37 = 715.50 | H 38 = 720.78 | H 39 = 721.86 | H 40 = 722.76 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 1

Location x/L: IN (1.0)

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

(Q/A)=0.970MW/M2 T:NA(IN)=610F T:NA(OUT)=1100.0 PL 1, IN
A21=35.16 A22=117.57 A23=140.5 A24=125.34 A25=66.558

2

| ITER NO. 2. | | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | |
|------------------|-------------------|--|-----------------|----------------|--|-------------------|--|
| T:NA IN = 610.00 | T:NA OUT = 1100.0 | DT: NA = 490.00 | T:B NA = 855.00 | T:B M = 876.03 | | | |
| DT M-N = 35.160 | DT1 = 117.57 | DT F-N = 160.50 | DT P-M = 125.34 | DT2 = 66.558 | | | |
| N = 610.00 | N 1 = 613.06 | N 2 = 616.77 | N 3 = 621.20 | N 4 = 626.45 | | | |
| N 5 = 632.62 | N 6 = 635.78 | N 7 = 648.01 | N 8 = 657.39 | N 9 = 667.97 | | | |
| N 10 = 679.77 | N 11 = 692.81 | N 12 = 707.08 | N 13 = 722.53 | N 14 = 739.11 | | | |
| N 15 = 756.71 | N 16 = 775.21 | N 17 = 794.47 | N 18 = 814.31 | N 19 = 834.55 | | | |
| N 20 = 855.00 | N 21 = 875.45 | N 22 = 895.69 | N 23 = 915.53 | N 24 = 934.79 | | | |
| N 25 = 953.29 | N 26 = 970.89 | N 27 = 987.47 | N 28 = 1002.9 | N 29 = 1017.2 | | | |
| N 30 = 1030.2 | N 31 = 1042.0 | N 32 = 1052.6 | N 33 = 1062.0 | N 34 = 1070.2 | | | |
| N 35 = 1077.4 | N 36 = 1083.5 | N 37 = 1088.8 | N 38 = 1093.2 | N 39 = 1096.9 | | | |
| N 40 = 1100.0 | | | | | | | |
| M = 614.70 | M 1 = 618.85 | M 2 = 623.72 | M 3 = 629.49 | M 4 = 636.23 | | | |
| M 5 = 644.03 | M 6 = 652.97 | M 7 = 663.12 | M 8 = 674.51 | M 9 = 687.17 | | | |
| M 10 = 701.09 | M 11 = 716.26 | M 12 = 732.61 | M 13 = 750.05 | M 14 = 768.48 | | | |
| M 15 = 787.74 | M 16 = 807.67 | M 17 = 828.08 | M 18 = 848.77 | M 19 = 869.54 | | | |
| M 20 = 890.16 | M 21 = 910.43 | M 22 = 930.15 | M 23 = 949.14 | M 24 = 967.24 | | | |
| M 25 = 984.32 | M 26 = 1000.3 | M 27 = 1015.0 | M 28 = 1028.5 | M 29 = 1040.6 | | | |
| M 30 = 1051.6 | M 31 = 1061.2 | M 32 = 1065.7 | M 33 = 1077.1 | M 34 = 1083.4 | | | |
| M 35 = 1088.8 | M 36 = 1093.3 | M 37 = 1097.1 | M 38 = 1100.2 | M 39 = 1102.7 | | | |
| M 40 = 1104.8 | | | | | | | |
| P = 631.72 | P 1 = 639.46 | P 2 = 648.53 | P 3 = 659.04 | P 4 = 671.08 | | | |
| P 5 = 684.72 | P 6 = 700.02 | P 7 = 716.96 | P 8 = 735.52 | P 9 = 755.61 | | | |
| P 10 = 777.12 | P 11 = 795.86 | P 12 = 823.63 | P 13 = 848.16 | P 14 = 873.17 | | | |
| P 15 = 898.35 | P 16 = 923.37 | P 17 = 947.91 | P 18 = 971.63 | P 19 = 994.25 | | | |
| P 20 = 1015.5 | P 21 = 1035.1 | P 22 = 1053.0 | P 23 = 1069.0 | P 24 = 1082.9 | | | |
| P 25 = 1094.9 | P 26 = 1104.9 | P 27 = 1113.1 | P 28 = 1119.5 | P 29 = 1124.2 | | | |
| P 30 = 1127.6 | P 31 = 1129.7 | P 32 = 1130.7 | P 33 = 1130.9 | P 34 = 1130.5 | | | |
| P 35 = 1129.5 | P 36 = 1128.2 | P 37 = 1126.6 | P 38 = 1125.0 | P 39 = 1123.3 | | | |
| P 40 = 1121.7 | | | | | | | |
| G = 622.71 | G 1 = 628.51 | G 2 = 635.36 | G 3 = 643.35 | G 4 = 652.57 | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 663.12 | G 6 = 675.04 | G 7 = 688.37 | G 8 = 703.12 | G 9 = 719.27 |
| G 10 = 736.75 | G 11 = 755.47 | G 12 = 775.30 | G 13 = 796.07 | G 14 = 817.58 |
| G 15 = 839.62 | G 16 = 861.93 | G 17 = 884.28 | G 18 = 906.40 | G 19 = 928.03 |
| G 20 = 948.94 | G 21 = 968.92 | G 22 = 987.77 | G 23 = 1005.3 | G 24 = 1021.5 |
| G 25 = 1036.2 | G 26 = 1049.4 | G 27 = 1061.0 | G 28 = 1071.1 | G 29 = 1079.8 |
| G 30 = 1087.2 | G 31 = 1093.3 | G 32 = 1098.3 | G 33 = 1102.3 | G 34 = 1105.5 |
| G 35 = 1107.9 | G 36 = 1109.7 | G 37 = 1110.9 | G 38 = 1111.8 | G 39 = 1112.4 |
| G 40 = 1112.7 | | | | |
| H 1 = 609.18 | H 2 = 612.09 | H 3 = 615.63 | H 4 = 619.88 | H 5 = 624.95 |
| H 6 = 630.91 | H 7 = 637.87 | H 8 = 645.89 | H 9 = 655.07 | H 10 = 665.44 |
| H 11 = 677.05 | H 12 = 685.92 | H 13 = 704.04 | H 14 = 719.38 | H 15 = 735.86 |
| H 16 = 753.40 | H 17 = 771.88 | H 18 = 791.15 | H 19 = 811.05 | H 20 = 831.37 |
| H 21 = 851.94 | H 22 = 872.53 | H 23 = 892.94 | H 24 = 912.98 | H 25 = 932.44 |
| H 26 = 951.16 | H 27 = 968.97 | H 28 = 985.77 | H 29 = 1001.4 | H 30 = 1015.9 |
| H 31 = 1029.1 | H 32 = 1041.1 | H 33 = 1051.8 | H 34 = 1061.4 | H 35 = 1069.7 |
| H 36 = 1077.0 | H 37 = 1083.2 | H 38 = 1088.6 | H 39 = 1093.1 | H 40 = 1096.8 |
| | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 2

Location x/L: OUT

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

(Q/A)=0.970Mh/M2 T:NA(IN)=610F T:NA(OUT)=1006.08 PL 2,OUT
 A21=35.16 A22=117.57 A23=160.5 A24=125.34 A25=66.558

2

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 |
|------------------|------------------|--|-----------------|----------------|--|-------------------|
| T:NA IN = 610.00 | T:NA CUT= 1006.1 | DT: NA = 396.08 | T:B NA = 808.04 | T:B M = 829.07 | | |
| DT M-N = 35.160 | DT1 = 117.57 | DT P-N = 160.50 | DT P-M = 125.34 | DT2 = 66.558 | | |
| N = 610.00 | N 1 = 612.48 | N 2 = 615.47 | N 3 = 619.05 | N 4 = 623.30 | | |
| N 5 = 628.28 | N 6 = 634.07 | N 7 = 640.73 | N 8 = 648.31 | N 9 = 656.86 | | |
| N 10 = 666.40 | N 11 = 676.94 | N 12 = 688.47 | N 13 = 700.96 | N 14 = 714.36 | | |
| N 15 = 728.59 | N 16 = 743.55 | N 17 = 759.11 | N 18 = 775.15 | N 19 = 791.51 | | |
| N 20 = 808.04 | N 21 = 824.57 | N 22 = 840.93 | N 23 = 856.97 | N 24 = 872.53 | | |
| N 25 = 887.49 | N 26 = 901.72 | N 27 = 915.11 | N 28 = 927.61 | N 29 = 939.14 | | |
| N 30 = 949.68 | N 31 = 959.22 | N 32 = 967.77 | N 33 = 975.35 | N 34 = 982.01 | | |
| N 35 = 987.80 | N 36 = 992.78 | N 37 = 997.03 | N 38 = 1000.6 | N 39 = 1003.6 | | |
| N 40 = 1006.1 | | | | | | |
| M = 614.76 | M 1 = 618.26 | M 2 = 622.43 | M 3 = 627.34 | M 4 = 633.07 | | |
| M 5 = 639.70 | M 6 = 647.27 | M 7 = 655.83 | M 8 = 665.42 | M 9 = 676.06 | | |
| M 10 = 687.72 | M 11 = 700.39 | M 12 = 714.00 | M 13 = 728.48 | M 14 = 743.73 | | |
| M 15 = 759.62 | M 16 = 776.00 | M 17 = 792.72 | M 18 = 809.61 | M 19 = 826.50 | | |
| M 20 = 843.20 | M 21 = 859.55 | M 22 = 875.39 | M 23 = 890.58 | M 24 = 904.99 | | |
| M 25 = 918.52 | M 26 = 931.08 | M 27 = 942.63 | M 28 = 953.14 | M 29 = 962.59 | | |
| M 30 = 971.01 | M 31 = 978.42 | M 32 = 984.89 | M 33 = 990.46 | M 34 = 995.21 | | |
| M 35 = 999.21 | M 36 = 1002.6 | M 37 = 1005.3 | M 38 = 1007.6 | M 39 = 1009.4 | | |
| M 40 = 1010.8 | | | | | | |
| P = 631.72 | P 1 = 638.87 | P 2 = 647.23 | P 3 = 656.89 | P 4 = 667.92 | | |
| P 5 = 680.39 | P 6 = 694.31 | P 7 = 709.67 | P 8 = 726.43 | P 9 = 744.50 | | |
| P 10 = 763.74 | P 11 = 783.99 | P 12 = 805.02 | P 13 = 826.59 | P 14 = 848.42 | | |
| P 15 = 870.23 | P 16 = 891.71 | P 17 = 912.55 | P 18 = 932.47 | P 19 = 951.21 | | |
| P 20 = 968.54 | P 21 = 984.27 | P 22 = 998.25 | P 23 = 1010.4 | P 24 = 1020.7 | | |
| P 25 = 1029.1 | P 26 = 1035.8 | P 27 = 1040.7 | P 28 = 1044.2 | P 29 = 1046.2 | | |
| P 30 = 1047.0 | P 31 = 1046.9 | P 32 = 1045.9 | P 33 = 1044.3 | P 34 = 1042.2 | | |
| P 35 = 1039.9 | P 36 = 1037.4 | P 37 = 1034.9 | P 38 = 1032.4 | P 39 = 1030.0 | | |
| P 40 = 1027.8 | | | | | | |
| G = 622.71 | G 1 = 627.93 | G 2 = 634.06 | G 3 = 641.20 | G 4 = 649.42 | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 658.78 | G 6 = 669.33 | G 7 = 681.08 | G 8 = 694.04 | G 9 = 708.16 |
| G 10 = 723.38 | G 11 = 735.60 | G 12 = 756.69 | G 13 = 774.50 | G 14 = 792.83 |
| G 15 = 811.50 | G 16 = 830.27 | G 17 = 848.92 | G 18 = 867.23 | G 19 = 884.99 |
| G 20 = 901.98 | G 21 = 918.04 | G 22 = 933.01 | G 23 = 946.78 | G 24 = 959.26 |
| G 25 = 970.40 | G 26 = 980.19 | G 27 = 988.65 | G 28 = 995.83 | G 29 = 1001.8 |
| G 30 = 1006.7 | G 31 = 1010.5 | G 32 = 1013.5 | G 33 = 1015.7 | G 34 = 1017.3 |
| G 35 = 1018.3 | G 36 = 1018.9 | G 37 = 1019.2 | G 38 = 1019.2 | G 39 = 1019.1 |
| G 40 = 1018.8 | | | | |
| H 1 = 608.59 | H 2 = 610.79 | H 3 = 613.48 | H 4 = 616.73 | H 5 = 620.61 |
| H 6 = 625.20 | H 7 = 630.58 | H 8 = 636.81 | H 9 = 643.95 | H 10 = 652.07 |
| H 11 = 661.18 | H 12 = 671.32 | H 13 = 682.47 | H 14 = 694.63 | H 15 = 707.74 |
| H 16 = 721.74 | H 17 = 736.53 | H 18 = 751.99 | H 19 = 768.01 | H 20 = 784.41 |
| H 21 = 801.06 | H 22 = 817.77 | H 23 = 834.38 | H 24 = 850.73 | H 25 = 866.64 |
| H 26 = 881.98 | H 27 = 896.62 | H 28 = 910.45 | H 29 = 923.38 | H 30 = 935.35 |
| H 31 = 946.32 | H 32 = 956.27 | H 33 = 965.20 | H 34 = 973.14 | H 35 = 980.13 |
| H 36 = 986.21 | H 37 = 991.46 | H 38 = 995.94 | H 39 = 999.72 | H 40 = 1002.9 |
| | | | | |

CASE # 2

Solar Flux: REFERENCE

Orifices: NO

Sub-Panel: 2

Location x/L: IN (1.0)

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

(Q/A)=1.20 Mw/M2 T:NA(IN)=610F T:NA(OUT)=1100.0 PL 2,IN
A21=41.74 A22=139.66 A23=152.5 A24=150.76 A25=80.96

2

| ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | CRITICAL NODE = 2 | |
|--|-------------------|-------------------|-----------------|
| T:NA IN = 610.00 | T:NA OUT = 1100.0 | DT: NA = 490.00 | T:B NA = 855.00 |
| DT M-N = 41.740 | DT1 = 139.66 | DT P-N = 192.50 | DT P-M = 150.76 |
| N = 610.00 | N 1 = 613.06 | N 2 = 616.77 | N 3 = 621.20 |
| N 5 = 632.62 | N 6 = 635.78 | N 7 = 648.01 | N 8 = 657.39 |
| N 10 = 679.77 | N 11 = 692.81 | N 12 = 707.08 | N 13 = 722.53 |
| N 15 = 756.71 | N 16 = 775.21 | N 17 = 794.47 | N 18 = 814.31 |
| N 20 = 855.00 | N 21 = 875.45 | N 22 = 895.69 | N 23 = 915.53 |
| N 25 = 953.29 | N 26 = 970.89 | N 27 = 987.47 | N 28 = 1002.9 |
| N 30 = 1030.2 | N 31 = 1042.0 | N 32 = 1052.6 | N 33 = 1062.0 |
| N 35 = 1077.4 | N 36 = 1083.5 | N 37 = 1088.8 | N 38 = 1093.2 |
| N 40 = 1100.0 | N 39 = 1096.9 | N 40 = 1100.0 | N 40 = 1100.0 |
| M = 615.65 | M 1 = 615.93 | M 2 = 625.03 | M 3 = 631.04 |
| M 5 = 640.17 | M 6 = 655.44 | M 7 = 665.94 | M 8 = 677.71 |
| M 10 = 705.08 | M 11 = 720.65 | M 12 = 737.39 | M 13 = 755.20 |
| M 15 = 792.55 | M 16 = 813.74 | M 17 = 834.37 | M 18 = 855.22 |
| M 20 = 896.74 | M 21 = 916.98 | M 22 = 936.60 | M 23 = 955.43 |
| M 25 = 990.12 | M 26 = 1005.8 | M 27 = 1020.1 | M 28 = 1033.2 |
| M 30 = 1055.5 | M 31 = 1064.8 | M 32 = 1072.9 | M 33 = 1079.9 |
| M 35 = 1090.9 | M 36 = 1055.2 | M 37 = 1098.6 | M 38 = 1101.5 |
| M 40 = 1105.0 | M 39 = 1103.8 | M 40 = 1105.0 | M 39 = 1103.8 |
| P = 636.05 | P 1 = 644.72 | P 2 = 654.86 | P 3 = 666.58 |
| P 5 = 695.11 | P 6 = 712.03 | P 7 = 730.70 | P 8 = 751.09 |
| P 10 = 796.53 | P 11 = 821.20 | P 12 = 846.86 | P 13 = 873.21 |
| P 15 = 926.59 | P 16 = 952.91 | P 17 = 978.50 | P 18 = 1003.0 |
| P 20 = 1047.5 | P 21 = 1067.0 | P 22 = 1084.4 | P 23 = 1099.6 |
| P 25 = 1123.2 | P 26 = 1131.7 | P 27 = 1138.1 | P 28 = 1142.7 |
| P 30 = 1147.0 | P 31 = 1147.2 | P 32 = 1146.3 | P 33 = 1144.7 |
| P 35 = 1139.9 | P 36 = 1137.1 | P 37 = 1134.2 | P 38 = 1131.3 |
| P 40 = 1126.1 | P 39 = 1128.6 | P 40 = 1126.1 | P 39 = 1128.6 |
| G = 625.10 | G 1 = 631.41 | G 2 = 638.85 | G 3 = 647.50 |
| G 4 = 657.47 | G 4 = 657.47 | G 4 = 657.47 | G 4 = 657.47 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 608.84 | G 6 = 681.65 | G 7 = 695.94 | G 8 = 711.70 | G 9 = 728.89 |
| G 10 = 747.44 | G 11 = 767.22 | G 12 = 788.09 | G 13 = 809.86 | G 14 = 832.30 |
| G 15 = 855.17 | G 16 = 878.20 | G 17 = 901.13 | G 18 = 923.67 | G 19 = 945.57 |
| G 20 = 966.57 | G 21 = 986.46 | G 22 = 1005.0 | G 23 = 1022.2 | G 24 = 1037.8 |
| G 25 = 1051.7 | G 26 = 1064.1 | G 27 = 1074.8 | G 28 = 1083.9 | G 29 = 1091.6 |
| G 30 = 1097.9 | G 31 = 1103.0 | G 32 = 1106.9 | G 33 = 1109.9 | G 34 = 1112.1 |
| G 35 = 1113.6 | G 36 = 1114.6 | G 37 = 1115.1 | G 38 = 1115.3 | G 39 = 1115.3 |
| G 40 = 1115.1 | G 40 = 1115.1 | G 40 = 1115.1 | G 40 = 1115.1 | G 40 = 1115.1 |
| H 1 = 608.44 | H 2 = 611.21 | H 3 = 614.58 | H 4 = 618.64 | H 5 = 623.50 |
| H 6 = 629.24 | H 7 = 635.95 | H 8 = 643.72 | H 9 = 652.63 | H 10 = 662.73 |
| H 11 = 674.07 | H 12 = 686.68 | H 13 = 700.55 | H 14 = 715.65 | H 15 = 731.92 |
| H 16 = 749.28 | H 17 = 767.61 | H 18 = 786.78 | H 19 = 806.60 | H 20 = 826.91 |
| H 21 = 847.50 | H 22 = 868.15 | H 23 = 888.68 | H 24 = 908.86 | H 25 = 928.50 |
| H 26 = 947.43 | H 27 = 965.48 | H 28 = 982.52 | H 29 = 998.45 | H 30 = 1013.2 |
| H 31 = 1026.7 | H 32 = 1038.9 | H 33 = 1049.9 | H 34 = 1059.7 | H 35 = 1068.3 |
| H 36 = 1075.7 | H 37 = 1082.2 | H 38 = 1087.7 | H 39 = 1092.3 | H 40 = 1096.2 |
| H 40 = 1075.7 | H 40 = 1075.7 | H 40 = 1075.7 | H 40 = 1075.7 | H 40 = 1075.7 |



PANEL TEMPERATURE DISTRIBUTION

CASE 3

SET 1 Subpanel 1

Solar Flux Distribution: OFF NORMAL

Orifices: Yes: Orificed so as to match tube flow rates to
reference flux distribution

Sodium Temperatures: T (Na-Inlet) = 610°F
T (Na-Outlet) = 1050°F (mean)
(784.4 to 1081.6)

5370F/sjh

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 1

Location x/L: 0.05

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 1 LOC=.05 T:IN=610F T:OUT=855.98 C/A=0.14792 MW/M2
 A21=6.535 A22=21.783 A23=28.381 A24=21.847 A25=10.954

3

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 855.98 | DT: NA = 245.98 | T:B NA = 732.99 | T:B M = 736.90 |
| DT M-N = 6.5350 | DT1 = 21.783 | DT F-N = 28.381 | DT P-M = 21.847 | DT2 = 10.954 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 611.54 | N 2 = 613.40 | N 3 = 615.62 | N 4 = 618.26 |
| N 5 = 621.35 | N 6 = 624.95 | N 7 = 629.08 | N 8 = 633.79 | N 9 = 639.10 |
| N 10 = 645.02 | N 11 = 651.57 | N 12 = 658.73 | N 13 = 666.49 | N 14 = 674.81 |
| N 15 = 683.65 | N 16 = 692.94 | N 17 = 702.60 | N 18 = 712.56 | N 19 = 722.73 |
| N 20 = 732.99 | N 21 = 743.25 | N 22 = 753.42 | N 23 = 763.36 | N 24 = 773.04 |
| N 25 = 782.33 | N 26 = 791.17 | N 27 = 799.49 | N 28 = 807.25 | N 29 = 814.41 |
| N 30 = 820.96 | N 31 = 826.88 | N 32 = 832.19 | N 33 = 836.90 | N 34 = 841.03 |
| N 35 = 846.63 | N 36 = 847.72 | N 37 = 850.36 | N 38 = 852.58 | N 39 = 854.44 |
| N 40 = 855.98 | = .0 | = .0 | = .0 | = .0 |
| M = 610.88 | M 1 = 612.61 | M 2 = 614.65 | M 3 = 617.16 | M 4 = 620.08 |
| M 5 = 623.48 | M 6 = 627.40 | M 7 = 631.89 | M 8 = 636.97 | M 9 = 642.67 |
| M 10 = 648.99 | M 11 = 655.93 | M 12 = 663.48 | M 13 = 671.61 | M 14 = 680.27 |
| M 15 = 689.42 | M 16 = 698.97 | M 17 = 708.85 | M 18 = 718.97 | M 19 = 729.23 |
| M 20 = 739.52 | M 21 = 749.76 | M 22 = 759.82 | M 23 = 769.62 | M 24 = 779.08 |
| M 25 = 788.10 | M 26 = 796.62 | M 27 = 804.60 | M 28 = 811.99 | M 29 = 818.77 |
| M 30 = 824.92 | M 31 = 830.45 | M 32 = 835.37 | M 33 = 839.70 | M 34 = 843.48 |
| M 35 = 846.75 | M 36 = 849.54 | M 37 = 851.90 | M 38 = 853.82 | M 39 = 855.52 |
| M 40 = 856.86 | = .0 | = .0 | = .0 | = .0 |
| P = 613.84 | P 1 = 616.21 | P 2 = 619.01 | P 3 = 622.31 | P 4 = 626.15 |
| P 5 = 630.57 | P 6 = 635.60 | P 7 = 641.27 | P 8 = 647.61 | P 9 = 654.60 |
| P 10 = 662.24 | P 11 = 670.50 | P 12 = 679.34 | P 13 = 688.71 | P 14 = 698.52 |
| P 15 = 708.70 | P 16 = 719.14 | P 17 = 729.74 | P 18 = 740.38 | P 19 = 750.97 |
| P 20 = 761.37 | P 21 = 772.49 | P 22 = 781.23 | P 23 = 790.51 | P 24 = 799.24 |
| P 25 = 807.38 | P 26 = 814.87 | P 27 = 821.70 | P 28 = 827.85 | P 29 = 833.24 |
| P 30 = 838.17 | P 31 = 842.38 | P 32 = 846.00 | P 33 = 849.09 | P 34 = 851.68 |
| P 35 = 853.84 | P 36 = 855.61 | P 37 = 857.05 | P 38 = 858.20 | P 39 = 859.11 |
| P 40 = 859.82 | = .0 | = .0 | = .0 | = .0 |
| G = 612.36 | G 1 = 614.40 | G 2 = 616.84 | G 3 = 619.73 | G 4 = 623.10 |
| G 5 = 627.01 | G 6 = 631.49 | G 7 = 636.57 | G 8 = 642.27 | G 9 = 648.61 |
| G 10 = 655.59 | G 11 = 663.19 | G 12 = 671.39 | G 13 = 680.13 | G 14 = 689.37 |
| G 15 = 699.03 | G 16 = 709.02 | G 17 = 719.26 | G 18 = 729.65 | G 19 = 740.07 |
| G 20 = 750.42 | G 21 = 760.59 | G 22 = 770.50 | G 23 = 780.04 | G 24 = 789.13 |
| G 25 = 797.71 | G 26 = 805.72 | G 27 = 813.13 | G 28 = 819.90 | G 29 = 826.03 |
| G 30 = 831.53 | G 31 = 836.40 | G 32 = 840.67 | G 33 = 844.38 | G 34 = 847.57 |
| G 35 = 850.28 | G 36 = 852.57 | G 37 = 854.47 | G 38 = 856.03 | G 39 = 857.31 |
| G 40 = 858.34 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 610.82 | H 2 = 612.53 | H 3 = 614.59 | H 4 = 617.05 | H 5 = 619.94 |
| H 6 = 623.31 | H 7 = 627.21 | H 8 = 631.67 | H 9 = 636.72 | H 10 = 642.38 |
| H 11 = 648.66 | H 12 = 655.57 | H 13 = 663.08 | H 14 = 671.17 | H 15 = 679.80 |
| H 16 = 688.92 | H 17 = 698.44 | H 18 = 708.29 | H 19 = 718.39 | H 20 = 728.63 |
| H 21 = 738.92 | H 22 = 749.15 | H 23 = 759.21 | H 24 = 769.02 | H 25 = 778.49 |
| H 26 = 787.53 | H 27 = 796.08 | H 28 = 804.08 | H 29 = 811.50 | H 30 = 818.31 |
| H 31 = 824.50 | H 32 = 830.07 | H 33 = 835.03 | H 34 = 839.40 | H 35 = 843.21 |
| H 36 = 846.51 | H 37 = 849.33 | H 38 = 851.72 | H 39 = 853.73 | H 40 = 855.39 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 1

Location x/L: 0.45

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 1 LOC=0.45 T:IN=610F T:OUT=1055.72 C/A=0.57262 MW/M2
A21=21.708 A22=72.531 A23=97.916 A24=76.205 A25=39.943

3

| ITER. NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 |
|------------------|-------------------|--|-----------------|----------------|--|-------------------|
| T:NA IN = 610.00 | T:NA OUT = 1055.7 | DT: NA = 445.72 | T:E NA = 832.86 | T:E M = 845.84 | | |
| DT M-N = 21.708 | DT1 = 72.531 | DT F-N = 97.916 | DT P-M = 76.209 | DT2 = 39.943 | | |
| N = .0 | N 1 = .0 | N 2 = .0 | N 3 = .0 | N 4 = .0 | | |
| N 5 = 610.00 | N 6 = 612.79 | N 7 = 616.15 | N 8 = 620.19 | N 9 = 624.97 | | |
| N 10 = 630.57 | N 11 = 637.09 | N 12 = 644.58 | N 13 = 653.11 | N 14 = 662.73 | | |
| N 15 = 673.46 | N 16 = 685.33 | N 17 = 698.31 | N 18 = 712.37 | N 19 = 727.44 | | |
| N 20 = 743.45 | N 21 = 760.28 | N 22 = 777.80 | N 23 = 795.85 | N 24 = 814.26 | | |
| N 25 = 832.86 | N 26 = 851.46 | N 27 = 869.87 | N 28 = 887.92 | N 29 = 905.44 | | |
| N 30 = 922.27 | N 31 = 938.28 | N 32 = 953.35 | N 33 = 967.41 | N 34 = 980.39 | | |
| N 35 = 992.26 | N 36 = 1003.0 | N 37 = 1012.6 | N 38 = 1021.1 | N 39 = 1028.6 | | |
| N 40 = 1035.1 | N 36 = 1040.6 | N 37 = 1045.5 | N 38 = 1049.6 | N 39 = 1052.9 | | |
| M = .0 | M 1 = .0 | M 2 = .0 | M 3 = .0 | M 4 = .0 | | |
| M 5 = 612.94 | M 6 = 616.36 | M 7 = 620.45 | M 8 = 625.30 | M 9 = 631.00 | | |
| M 10 = 637.62 | M 11 = 645.23 | M 12 = 653.90 | M 13 = 663.68 | M 14 = 674.58 | | |
| M 15 = 686.63 | M 16 = 695.81 | M 17 = 714.07 | M 18 = 729.36 | M 19 = 745.58 | | |
| M 20 = 762.61 | M 21 = 780.32 | M 22 = 798.55 | M 23 = 817.13 | M 24 = 835.86 | | |
| M 25 = 854.57 | M 26 = 873.06 | M 27 = 891.15 | M 28 = 908.67 | M 29 = 925.48 | | |
| M 30 = 941.42 | M 31 = 956.41 | M 32 = 970.35 | M 33 = 983.18 | M 34 = 994.37 | | |
| M 35 = 1005.4 | M 36 = 1014.8 | M 37 = 1023.2 | M 38 = 1030.5 | M 39 = 1036.8 | | |
| M 40 = 1042.2 | M 36 = 1046.8 | M 37 = 1050.7 | M 38 = 1053.9 | M 39 = 1056.5 | | |
| P = .0 | P 1 = .0 | P 2 = .0 | P 3 = .0 | P 4 = .0 | | |
| P 5 = 623.25 | P 6 = 628.89 | P 7 = 635.53 | P 8 = 643.27 | P 9 = 652.19 | | |
| P 10 = 662.36 | P 11 = 673.84 | P 12 = 686.64 | P 13 = 700.77 | P 14 = 716.20 | | |
| P 15 = 732.85 | P 16 = 750.63 | P 17 = 769.41 | P 18 = 789.00 | P 19 = 809.23 | | |
| P 20 = 829.86 | P 21 = 850.67 | P 22 = 871.41 | P 23 = 891.83 | P 24 = 911.69 | | |
| P 25 = 930.78 | P 26 = 948.89 | P 27 = 965.85 | P 28 = 981.53 | P 29 = 995.82 | | |
| P 30 = 1008.7 | P 31 = 1020.1 | P 32 = 1030.0 | P 33 = 1038.5 | P 34 = 1045.7 | | |
| P 35 = 1051.6 | P 36 = 1056.5 | P 37 = 1060.3 | P 38 = 1063.2 | P 39 = 1065.4 | | |
| P 40 = 1066.9 | P 36 = 1068.0 | P 37 = 1068.6 | P 38 = 1068.9 | P 39 = 1069.0 | | |
| G = .0 | G 1 = .0 | G 2 = .0 | G 3 = .0 | G 4 = .0 | | |
| G 5 = 617.85 | G 6 = 622.32 | G 7 = 627.63 | G 8 = 633.85 | G 9 = 641.08 | | |
| G 10 = 649.39 | G 6 = 658.85 | G 7 = 669.48 | G 8 = 681.33 | G 9 = 694.39 | | |
| G 10 = 708.63 | G 11 = 723.99 | G 12 = 740.40 | G 13 = 757.74 | G 14 = 775.87 | | |
| G 15 = 794.61 | G 16 = 813.80 | G 17 = 833.22 | G 18 = 852.67 | G 19 = 871.95 | | |
| G 20 = 890.83 | G 21 = 905.14 | G 22 = 926.70 | G 23 = 943.34 | G 24 = 956.95 | | |
| G 25 = 973.43 | G 26 = 986.70 | G 27 = 998.73 | G 28 = 1009.5 | G 29 = 1019.1 | | |
| G 30 = 1027.4 | G 31 = 1034.6 | G 32 = 1040.8 | G 33 = 1046.0 | G 34 = 1050.4 | | |
| G 35 = 1054.0 | G 36 = 1056.9 | G 37 = 1059.2 | G 38 = 1061.0 | G 39 = 1062.5 | | |
| G 40 = 1063.6 | G 36 = .0 | G 37 = .0 | G 38 = .0 | G 39 = .0 | | |
| H 1 = 610.39 | H 2 = 613.27 | H 3 = 616.75 | H 4 = 620.92 | H 5 = 625.85 | | |
| H 6 = 631.62 | H 7 = 636.33 | H 8 = 646.02 | H 9 = 654.78 | H 10 = 664.63 | | |
| H 11 = 675.62 | H 12 = 687.73 | H 13 = 700.97 | H 14 = 715.26 | H 15 = 730.61 | | |
| H 16 = 746.84 | H 17 = 763.88 | H 18 = 781.58 | H 19 = 799.78 | H 20 = 818.30 | | |
| H 21 = 836.97 | H 22 = 855.60 | H 23 = 874.00 | H 24 = 892.00 | H 25 = 909.42 | | |
| H 26 = 926.12 | H 27 = 941.96 | H 28 = 956.84 | H 29 = 970.68 | H 30 = 983.43 | | |
| H 31 = 995.04 | H 32 = 1005.5 | H 33 = 1014.5 | H 34 = 1023.2 | H 35 = 1030.4 | | |
| H 36 = 1036.7 | H 37 = 1042.1 | H 38 = 1046.7 | H 39 = 1050.5 | H 40 = 1053.7 | | |
| H 40 = .0 | H 37 = .0 | H 38 = .0 | H 39 = .0 | H 40 = .0 | | |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 1

Location x/L: 0.55

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 1 LOC=-55 I:IN=610F I:OUT=1068.93 C/A=C.66799 Mw/M2
A21=24.936 A22=83.341 A23=112.94 A24=88.001 A25=46.331

3

| ITER NO. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 |
|------------------|--|-----------------|-----------------|----------------|-------------------|
| T:NA IN = 610.00 | T:NA OUT= 1068.9 | DT: NA = 458.93 | T:B NA = 839.46 | T:B M = 854.38 | |
| DT M-N = 24.936 | DTI = 83.341 | DT P-N = 112.94 | DT P-M = 88.001 | DT2 = 46.331 | |
| N = 610.00 | N 1 = 612.87 | N 2 = 616.34 | N 3 = 620.49 | N 4 = 625.41 | |
| N 5 = 631.18 | N 6 = 637.89 | N 7 = 645.60 | N 8 = 654.39 | N 9 = 664.29 | |
| N 10 = 675.34 | N 11 = 687.56 | N 12 = 700.92 | N 13 = 715.40 | N 14 = 730.92 | |
| N 15 = 747.41 | N 16 = 764.74 | N 17 = 782.77 | N 18 = 801.36 | N 19 = 820.32 | |
| N 20 = 839.46 | N 21 = 858.61 | N 22 = 877.57 | N 23 = 896.16 | N 24 = 914.19 | |
| N 25 = 931.52 | N 26 = 948.01 | N 27 = 963.53 | N 28 = 978.01 | N 29 = 991.37 | |
| N 30 = 1003.6 | N 31 = 1014.6 | N 32 = 1024.5 | N 33 = 1033.3 | N 34 = 1041.0 | |
| N 35 = 1047.7 | N 36 = 1053.5 | N 37 = 1058.4 | N 38 = 1062.6 | N 39 = 1066.1 | |
| N 40 = 1068.9 | N = .0 | N = .0 | N = .0 | N = .0 | |
| M = 613.37 | M 1 = 616.97 | M 2 = 621.27 | M 3 = 626.37 | M 4 = 632.34 | |
| M 5 = 639.28 | M 6 = 647.25 | M 7 = 656.32 | M 8 = 666.52 | M 9 = 677.91 | |
| M 10 = 690.47 | M 11 = 704.19 | M 12 = 719.03 | M 13 = 734.92 | M 14 = 751.75 | |
| M 15 = 769.41 | M 16 = 787.76 | M 17 = 806.61 | M 18 = 825.80 | M 19 = 845.13 | |
| M 20 = 864.40 | M 21 = 883.43 | M 22 = 902.02 | M 23 = 920.00 | M 24 = 937.21 | |
| M 25 = 953.53 | M 26 = 968.83 | M 27 = 983.05 | M 28 = 996.11 | M 29 = 1008.0 | |
| M 30 = 1018.7 | M 31 = 1028.3 | M 32 = 1036.7 | M 33 = 1044.0 | M 34 = 1050.4 | |
| M 35 = 1055.8 | M 36 = 1060.5 | M 37 = 1064.3 | M 38 = 1067.5 | M 39 = 1070.2 | |
| M 40 = 1072.3 | M = .0 | M = .0 | M = .0 | M = .0 | |
| P = 625.28 | P 1 = 631.44 | P 2 = 638.65 | P 3 = 647.11 | P 4 = 656.81 | |
| P 5 = 667.85 | P 6 = 680.28 | P 7 = 694.12 | P 8 = 709.36 | P 9 = 725.96 | |
| P 10 = 743.85 | P 11 = 762.89 | P 12 = 782.93 | P 13 = 803.80 | P 14 = 825.26 | |
| P 15 = 847.08 | P 16 = 868.99 | P 17 = 890.74 | P 18 = 912.06 | P 19 = 932.69 | |
| P 20 = 952.40 | P 21 = 970.99 | P 22 = 988.28 | P 23 = 1004.1 | P 24 = 1018.4 | |
| P 25 = 1031.2 | P 26 = 1042.3 | P 27 = 1051.9 | P 28 = 1060.0 | P 29 = 1068.0 | |
| P 30 = 1072.1 | P 31 = 1076.3 | P 32 = 1079.5 | P 33 = 1081.6 | P 34 = 1083.4 | |
| P 35 = 1084.4 | P 36 = 1084.9 | P 37 = 1085.1 | P 38 = 1084.9 | P 39 = 1084.6 | |
| P 40 = 1084.2 | P = .0 | P = .0 | P = .0 | P = .0 | |
| G = 619.01 | G 1 = 623.82 | G 2 = 629.52 | G 3 = 636.19 | G 4 = 643.93 | |
| G 5 = 652.81 | G 6 = 662.89 | G 7 = 674.21 | G 8 = 686.81 | G 9 = 700.66 | |
| G 10 = 715.74 | G 11 = 731.98 | G 12 = 749.25 | G 13 = 767.53 | G 14 = 786.56 | |
| G 15 = 806.19 | G 16 = 826.22 | G 17 = 846.45 | G 18 = 866.84 | G 19 = 886.59 | |
| G 20 = 906.07 | G 21 = 924.89 | G 22 = 942.86 | G 23 = 959.83 | G 24 = 975.68 | |
| G 25 = 990.30 | G 26 = 1003.6 | G 27 = 1015.7 | G 28 = 1026.4 | G 29 = 1035.8 | |
| G 30 = 1044.0 | G 31 = 1051.0 | G 32 = 1057.0 | G 33 = 1061.9 | G 34 = 1066.0 | |
| G 35 = 1069.4 | G 36 = 1072.0 | G 37 = 1074.1 | G 38 = 1075.8 | G 39 = 1077.0 | |
| G 40 = 1077.9 | G = .0 | G = .0 | G = .0 | G = .0 | |
| H 1 = 610.12 | H 2 = 613.02 | H 3 = 616.54 | H 4 = 620.76 | H 5 = 625.75 | |
| H 6 = 631.61 | H 7 = 638.42 | H 8 = 646.24 | H 9 = 655.15 | H 10 = 665.19 | |
| H 11 = 676.40 | H 12 = 686.77 | H 13 = 702.30 | H 14 = 716.95 | H 15 = 732.64 | |
| H 16 = 749.29 | H 17 = 766.77 | H 18 = 784.95 | H 19 = 803.66 | H 20 = 822.73 | |
| H 21 = 841.96 | H 22 = 861.17 | H 23 = 880.16 | H 24 = 898.74 | H 25 = 916.75 | |
| H 26 = 934.03 | H 27 = 950.43 | H 28 = 965.85 | H 29 = 980.21 | H 30 = 993.44 | |
| H 31 = 1005.5 | H 32 = 1016.4 | H 33 = 1026.1 | H 34 = 1034.8 | H 35 = 1042.3 | |
| H 36 = 1048.9 | H 37 = 1054.5 | H 38 = 1059.3 | H 39 = 1063.3 | H 40 = 1066.7 | |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 | |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 1

Location x/L: 0.75

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 1 LOC=.75 T:IN=610F T:OUT=1080.62 C/A=0.84579 MW/M2
A21=30.955 A22=103.49 A23=140.94 A24=105.58 A25=56.239

3

| ITER NO. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1080.6 | DT: NA = 470.62 | T:E NA = 845.31 | T:B M = 863.82 | | | | |
| DT M-N = 30.955 | DT1 = 103.49 | DT P-N = 140.54 | DT P-M = 109.98 | DT2 = 58.237 | | | | |
| = -0 | = -0 | = -0 | = -0 | = -0 | | | | |
| N = 610.00 | N 1 = 612.94 | N 2 = 616.50 | N 3 = 620.76 | N 4 = 625.80 | | | | |
| N 5 = 631.72 | N 6 = 636.60 | N 7 = 646.51 | N 8 = 655.52 | N 9 = 665.67 | | | | |
| N 10 = 677.01 | N 11 = 685.53 | N 12 = 703.24 | N 13 = 718.08 | N 14 = 734.00 | | | | |
| N 15 = 750.91 | N 16 = 768.68 | N 17 = 787.17 | N 18 = 806.23 | N 19 = 825.67 | | | | |
| N 20 = 845.31 | N 21 = 864.95 | N 22 = 884.35 | N 23 = 903.45 | N 24 = 921.94 | | | | |
| N 25 = 939.71 | N 26 = 956.62 | N 27 = 972.54 | N 28 = 987.38 | N 29 = 1001.1 | | | | |
| N 30 = 1013.6 | N 31 = 1024.9 | N 32 = 1035.1 | N 33 = 1044.1 | N 34 = 1052.0 | | | | |
| N 35 = 1058.9 | N 36 = 1064.8 | N 37 = 1069.9 | N 38 = 1074.1 | N 39 = 1077.7 | | | | |
| N 40 = 1080.6 | = -0 | = -0 | = -0 | = -0 | | | | |
| M = 614.19 | M 1 = 616.03 | M 2 = 622.62 | M 3 = 628.05 | M 4 = 634.41 | | | | |
| M 5 = 641.77 | M 6 = 650.22 | M 7 = 659.81 | M 8 = 670.59 | M 9 = 682.58 | | | | |
| M 10 = 695.78 | M 11 = 710.18 | M 12 = 725.72 | M 13 = 742.31 | M 14 = 759.86 | | | | |
| M 15 = 778.23 | M 16 = 797.25 | M 17 = 816.77 | M 18 = 836.57 | M 19 = 856.47 | | | | |
| M 20 = 876.26 | M 21 = 895.75 | M 22 = 914.73 | M 23 = 933.04 | M 24 = 950.52 | | | | |
| M 25 = 967.03 | M 26 = 982.47 | M 27 = 996.76 | M 28 = 1009.9 | M 29 = 1021.7 | | | | |
| M 30 = 1032.4 | M 31 = 1041.8 | M 32 = 1050.2 | M 33 = 1057.4 | M 34 = 1063.6 | | | | |
| M 35 = 1068.9 | M 36 = 1073.4 | M 37 = 1077.2 | M 38 = 1080.2 | M 39 = 1082.6 | | | | |
| M 40 = 1084.8 | = -0 | = -0 | = -0 | = -0 | | | | |
| P = 629.07 | P 1 = 636.12 | P 2 = 644.39 | P 3 = 653.98 | P 4 = 664.99 | | | | |
| P 5 = 677.48 | P 6 = 691.50 | P 7 = 707.05 | P 8 = 724.12 | P 9 = 742.64 | | | | |
| P 10 = 762.49 | P 11 = 783.54 | P 12 = 805.58 | P 13 = 828.40 | P 14 = 851.73 | | | | |
| P 15 = 875.29 | P 16 = 896.78 | P 17 = 921.91 | P 18 = 944.38 | P 19 = 965.91 | | | | |
| P 20 = 986.25 | P 21 = 1005.2 | P 22 = 1022.5 | P 23 = 1038.2 | P 24 = 1052.6 | | | | |
| P 25 = 1064.1 | P 26 = 1074.3 | P 27 = 1082.9 | P 28 = 1089.7 | P 29 = 1095.1 | | | | |
| P 30 = 1099.1 | P 31 = 1101.9 | P 32 = 1103.7 | P 33 = 1104.7 | P 34 = 1104.9 | | | | |
| P 35 = 1104.7 | P 36 = 1104.0 | P 37 = 1103.1 | P 38 = 1102.0 | P 39 = 1100.9 | | | | |
| P 40 = 1099.7 | = -0 | = -0 | = -0 | = -0 | | | | |
| G = 621.19 | G 1 = 626.54 | G 2 = 632.86 | G 3 = 640.25 | G 4 = 648.60 | | | | |
| G 5 = 658.57 | G 6 = 665.64 | G 7 = 682.03 | G 8 = 695.77 | G 9 = 710.83 | | | | |
| G 10 = 727.17 | G 11 = 744.69 | G 12 = 763.25 | G 13 = 782.81 | G 14 = 803.08 | | | | |
| G 15 = 823.89 | G 16 = 845.02 | G 17 = 866.23 | G 18 = 887.29 | G 19 = 907.96 | | | | |
| G 20 = 928.01 | G 21 = 947.23 | G 22 = 965.45 | G 23 = 982.51 | G 24 = 998.28 | | | | |
| G 25 = 1012.7 | G 26 = 1025.7 | G 27 = 1037.3 | G 28 = 1047.4 | G 29 = 1056.2 | | | | |
| G 30 = 1063.8 | G 31 = 1070.1 | G 32 = 1075.4 | G 33 = 1079.6 | G 34 = 1083.1 | | | | |
| G 35 = 1085.7 | G 36 = 1087.8 | G 37 = 1089.4 | G 38 = 1090.5 | G 39 = 1091.3 | | | | |
| G 40 = 1091.8 | = -0 | = -0 | = -0 | = -0 | | | | |
| H 1 = 609.52 | H 2 = 612.38 | H 3 = 615.85 | H 4 = 620.02 | H 5 = 624.97 | | | | |
| H 6 = 630.80 | H 7 = 637.58 | H 8 = 645.40 | H 9 = 654.32 | H 10 = 664.40 | | | | |
| H 11 = 675.67 | H 12 = 688.14 | H 13 = 701.81 | H 14 = 716.64 | H 15 = 732.56 | | | | |
| H 16 = 749.49 | H 17 = 767.30 | H 18 = 785.85 | H 19 = 804.99 | H 20 = 824.52 | | | | |
| H 21 = 844.26 | H 22 = 864.01 | H 23 = 883.57 | H 24 = 902.75 | H 25 = 921.36 | | | | |
| H 26 = 939.25 | H 27 = 956.26 | H 28 = 972.28 | H 29 = 987.22 | H 30 = 1001.0 | | | | |
| H 31 = 1013.6 | H 32 = 1025.0 | H 33 = 1035.2 | H 34 = 1044.2 | H 35 = 1052.1 | | | | |
| H 36 = 1059.0 | H 37 = 1065.0 | H 38 = 1070.0 | H 39 = 1074.3 | H 40 = 1077.8 | | | | |
| = -0 | = -0 | = -0 | = -0 | = -0 | | | | |

CASE # 3

Solar Flux: OFF-NORMAL
 Orifices: YES
 Sub-Panel: 1
 Location x/L: 0.85
 T(Na-inlet) = 610 F
 T(Na-outlet) : Mean = 1050F

PNL 1 LOC=.85 T:IN=610F T:OUT=1081.64 Q/A=0.92821 MW/M2
 A21=33.745 A22=112.83 A23=153.92 A24=120.17 A25=63.759

3

| ITER NO. | 2- GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1081.6 | DT: NA = 471.64 | T:B NA = 845.82 | T:B M = 866.00 | | | | |
| DT M-N = 33.745 | DT1 = 112.83 | DT F-N = 153.92 | DT P-M = 120.17 | DT2 = 63.750 | | | | |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 | | | | |
| N 5 = 610.00 | N 1 = 612.95 | N 2 = 616.51 | N 3 = 620.78 | N 4 = 625.84 | | | | |
| N 10 = 631.77 | N 6 = 638.66 | N 7 = 646.55 | N 8 = 655.62 | N 9 = 665.75 | | | | |
| N 15 = 677.15 | N 11 = 689.71 | N 12 = 703.44 | N 13 = 718.32 | N 14 = 734.27 | | | | |
| N 20 = 751.21 | N 16 = 765.02 | N 17 = 787.56 | N 18 = 808.60 | N 19 = 826.14 | | | | |
| N 25 = 845.82 | N 21 = 865.50 | N 22 = 884.98 | N 23 = 904.08 | N 24 = 922.62 | | | | |
| N 30 = 940.43 | N 26 = 957.37 | N 27 = 973.32 | N 28 = 988.20 | N 29 = 1001.9 | | | | |
| N 35 = 1014.5 | N 31 = 1025.8 | N 32 = 1036.0 | N 33 = 1045.1 | N 34 = 1053.0 | | | | |
| N 40 = 1059.9 | N 36 = 1065.8 | N 37 = 1070.9 | N 38 = 1075.1 | N 39 = 1078.7 | | | | |
| M = 1081.6 | M = .0 | M = .0 | M = .0 | M = .0 | | | | |
| M 5 = 614.57 | M 1 = 616.50 | M 2 = 623.19 | M 3 = 628.73 | M 4 = 635.22 | | | | |
| M 10 = 642.72 | M 6 = 651.33 | M 7 = 661.08 | M 8 = 672.04 | M 9 = 684.22 | | | | |
| M 15 = 697.62 | M 11 = 712.21 | M 12 = 727.94 | M 13 = 744.73 | M 14 = 762.40 | | | | |
| M 20 = 780.99 | M 16 = 800.17 | M 17 = 819.82 | M 18 = 839.73 | M 15 = 859.72 | | | | |
| M 25 = 879.56 | M 21 = 895.08 | M 22 = 918.06 | M 23 = 936.34 | M 24 = 953.77 | | | | |
| M 30 = 970.21 | M 26 = 985.55 | M 27 = 999.73 | M 28 = 1012.7 | M 25 = 1024.4 | | | | |
| M 35 = 1035.0 | M 31 = 1044.3 | M 32 = 1052.4 | M 33 = 1059.5 | M 34 = 1065.6 | | | | |
| M 40 = 1070.8 | M 36 = 1075.2 | M 37 = 1078.8 | M 38 = 1081.8 | M 39 = 1084.2 | | | | |
| P = 1086.2 | P = .0 | P = .0 | P = .0 | P = .0 | | | | |
| P 5 = 630.83 | P 1 = 638.26 | P 2 = 646.97 | P 3 = 657.07 | P 4 = 668.03 | | | | |
| P 10 = 681.74 | P 6 = 696.43 | P 7 = 712.71 | P 8 = 730.54 | P 9 = 749.85 | | | | |
| P 15 = 770.51 | P 11 = 792.37 | P 12 = 815.21 | P 13 = 838.79 | P 14 = 862.84 | | | | |
| P 20 = 887.05 | P 16 = 911.11 | P 17 = 934.70 | P 18 = 957.53 | P 15 = 979.29 | | | | |
| P 25 = 999.74 | P 21 = 1018.7 | P 22 = 1035.9 | P 23 = 1051.2 | P 24 = 1064.7 | | | | |
| P 30 = 1076.3 | P 26 = 1085.9 | P 27 = 1093.8 | P 28 = 1100.0 | P 29 = 1104.0 | | | | |
| P 35 = 1107.8 | P 31 = 1109.9 | P 32 = 1110.9 | P 33 = 1111.2 | P 34 = 1110.7 | | | | |
| P 40 = 1109.8 | P 36 = 1108.6 | P 37 = 1107.1 | P 38 = 1105.6 | P 39 = 1104.0 | | | | |
| G = 1102.5 | G = .0 | G = .0 | G = .0 | G = .0 | | | | |
| G 5 = 622.20 | G 1 = 627.78 | G 2 = 634.35 | G 3 = 642.03 | G 4 = 650.90 | | | | |
| G 10 = 661.04 | G 6 = 672.50 | G 7 = 685.32 | G 8 = 699.50 | G 9 = 715.03 | | | | |
| G 15 = 731.84 | G 11 = 745.84 | G 12 = 768.91 | G 13 = 786.89 | G 14 = 805.56 | | | | |
| G 20 = 830.78 | G 16 = 852.25 | G 17 = 873.75 | G 18 = 895.03 | G 19 = 915.30 | | | | |
| G 25 = 935.98 | G 21 = 955.21 | G 22 = 973.36 | G 23 = 990.27 | G 24 = 1005.8 | | | | |
| G 30 = 1020.0 | G 26 = 1032.7 | G 27 = 1043.9 | G 28 = 1053.7 | G 25 = 1062.1 | | | | |
| G 35 = 1069.2 | G 31 = 1075.1 | G 32 = 1075.9 | G 33 = 1083.8 | G 34 = 1086.3 | | | | |
| G 40 = 1089.1 | G 36 = 1090.9 | G 37 = 1092.1 | G 38 = 1093.0 | G 39 = 1093.5 | | | | |
| H = 1093.8 | H = .0 | H = .0 | H = .0 | H = .0 | | | | |
| H 1 = 609.22 | H 2 = 612.03 | H 3 = 615.42 | H 4 = 619.53 | H 5 = 624.41 | | | | |
| H 6 = 630.15 | H 7 = 634.85 | H 8 = 644.52 | H 9 = 653.41 | H 10 = 663.40 | | | | |
| H 11 = 674.59 | H 12 = 686.98 | H 13 = 700.57 | H 14 = 715.34 | H 15 = 731.21 | | | | |
| H 16 = 748.09 | H 17 = 765.88 | H 18 = 784.43 | H 19 = 803.58 | H 20 = 823.15 | | | | |
| H 21 = 842.94 | H 22 = 862.76 | H 23 = 882.41 | H 24 = 901.69 | H 25 = 920.42 | | | | |
| H 26 = 938.43 | H 27 = 955.58 | H 28 = 971.74 | H 29 = 986.81 | H 30 = 1000.7 | | | | |
| H 31 = 1013.5 | H 32 = 1025.0 | H 33 = 1035.2 | H 34 = 1044.5 | H 35 = 1052.5 | | | | |
| H 36 = 1059.5 | H 37 = 1065.5 | H 38 = 1070.6 | H 39 = 1075.0 | H 40 = 1078.6 | | | | |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 | | | | |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 1

Location x/L: 0.95

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 1 LOC=.95 T:IN=610F T:OUT=1080.49 C/A=1.00631 MW/M2
A21=36.199 A22=121.06 A23=165.55 A24=125.35 A25=68.832

3

| ITER NO. 2. | | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1080.5 | DT: NA = 470.49 | T:B NA = 845.24 | T:B M = 866.90 | | | | | |
| DT M-N = 36.199 | DT1 = 121.06 | DT F-N = 165.55 | DT F-M = 124.35 | DT2 = 68.032 | | | | | |
| N = 610.00 | N 1 = 612.94 | N 2 = 616.50 | N 3 = 620.75 | N 4 = 625.80 | | | | | |
| N 5 = 631.72 | N 6 = 638.59 | N 7 = 646.50 | N 8 = 655.51 | N 9 = 665.66 | | | | | |
| N 10 = 676.95 | N 11 = 685.51 | N 12 = 703.21 | N 13 = 718.05 | N 14 = 733.97 | | | | | |
| N 15 = 750.87 | N 16 = 768.63 | N 17 = 787.12 | N 18 = 806.18 | N 19 = 825.61 | | | | | |
| N 20 = 845.24 | N 21 = 864.88 | N 22 = 884.31 | N 23 = 903.37 | N 24 = 921.86 | | | | | |
| N 25 = 939.62 | N 26 = 956.52 | N 27 = 972.44 | N 28 = 987.28 | N 29 = 1001.0 | | | | | |
| N 30 = 1013.5 | N 31 = 1024.8 | N 32 = 1035.0 | N 33 = 1044.0 | N 34 = 1051.9 | | | | | |
| N 35 = 1058.8 | N 36 = 1064.7 | N 37 = 1069.7 | N 38 = 1074.0 | N 39 = 1077.5 | | | | | |
| N 40 = 1080.5 | | | | | | | | | |
| M = 614.90 | M 1 = 618.89 | M 2 = 623.66 | M 3 = 629.29 | M 4 = 635.86 | | | | | |
| M 5 = 643.47 | M 6 = 652.18 | M 7 = 662.05 | M 8 = 673.13 | M 9 = 685.43 | | | | | |
| M 10 = 698.95 | M 11 = 713.66 | M 12 = 729.50 | M 13 = 746.39 | M 14 = 764.21 | | | | | |
| M 15 = 782.82 | M 16 = 802.05 | M 17 = 821.73 | M 18 = 841.66 | M 19 = 861.63 | | | | | |
| M 20 = 881.44 | M 21 = 900.89 | M 22 = 919.80 | M 23 = 937.97 | M 24 = 955.27 | | | | | |
| M 25 = 971.57 | M 26 = 986.76 | M 27 = 1000.8 | M 28 = 1013.6 | M 29 = 1025.1 | | | | | |
| M 30 = 1035.5 | M 31 = 1044.6 | M 32 = 1052.6 | M 33 = 1059.5 | M 34 = 1065.5 | | | | | |
| M 35 = 1070.5 | M 36 = 1074.8 | M 37 = 1078.3 | M 38 = 1081.2 | M 39 = 1083.5 | | | | | |
| M 40 = 1085.4 | | | | | | | | | |
| P = 632.40 | P 1 = 640.17 | P 2 = 645.26 | P 3 = 659.78 | P 4 = 671.83 | | | | | |
| P 5 = 685.46 | P 6 = 700.73 | P 7 = 717.61 | P 8 = 736.09 | P 9 = 756.06 | | | | | |
| P 10 = 777.40 | P 11 = 795.93 | P 12 = 823.43 | P 13 = 847.63 | P 14 = 872.25 | | | | | |
| P 15 = 896.97 | P 16 = 921.46 | P 17 = 945.35 | P 18 = 968.45 | P 19 = 990.34 | | | | | |
| P 20 = 1010.8 | P 21 = 1029.6 | P 22 = 1046.6 | P 23 = 1061.6 | P 24 = 1074.7 | | | | | |
| P 25 = 1085.7 | P 26 = 1094.8 | P 27 = 1102.0 | P 28 = 1107.5 | P 29 = 1111.4 | | | | | |
| P 30 = 1113.9 | P 31 = 1115.2 | P 32 = 1115.6 | P 33 = 1115.1 | P 34 = 1114.3 | | | | | |
| P 35 = 1112.5 | P 36 = 1110.7 | P 37 = 1108.8 | P 38 = 1106.8 | P 39 = 1104.8 | | | | | |
| P 40 = 1102.9 | | | | | | | | | |
| G = 623.09 | G 1 = 628.85 | G 2 = 635.64 | G 3 = 643.56 | G 4 = 652.69 | | | | | |
| G 5 = 663.12 | G 6 = 674.90 | G 7 = 688.05 | G 8 = 702.59 | G 9 = 718.48 | | | | | |
| G 10 = 735.66 | G 11 = 754.03 | G 12 = 773.45 | G 13 = 793.76 | G 14 = 814.70 | | | | | |
| G 15 = 836.23 | G 16 = 857.93 | G 17 = 879.60 | G 18 = 900.99 | G 19 = 921.86 | | | | | |
| G 20 = 941.97 | G 21 = 961.12 | G 22 = 979.13 | G 23 = 995.84 | G 24 = 1011.1 | | | | | |
| G 25 = 1025.0 | G 26 = 1037.3 | G 27 = 1048.1 | G 28 = 1057.5 | G 29 = 1065.5 | | | | | |
| G 30 = 1072.2 | G 31 = 1077.7 | G 32 = 1082.1 | G 33 = 1085.5 | G 34 = 1088.2 | | | | | |
| G 35 = 1090.2 | G 36 = 1091.6 | G 37 = 1092.5 | G 38 = 1093.1 | G 39 = 1093.5 | | | | | |
| G 40 = 1093.6 | | | | | | | | | |
| H 1 = 608.94 | H 2 = 611.68 | H 3 = 615.02 | H 4 = 619.03 | H 5 = 623.82 | | | | | |
| H 6 = 629.46 | H 7 = 636.05 | H 8 = 643.66 | H 9 = 652.37 | H 10 = 662.23 | | | | | |
| H 11 = 673.28 | H 12 = 685.55 | H 13 = 699.01 | H 14 = 713.65 | H 15 = 729.40 | | | | | |
| H 16 = 746.17 | H 17 = 763.86 | H 18 = 782.33 | H 19 = 801.40 | H 20 = 820.91 | | | | | |
| H 21 = 840.67 | H 22 = 860.46 | H 23 = 880.10 | H 24 = 899.39 | H 25 = 918.15 | | | | | |
| H 26 = 936.20 | H 27 = 953.39 | H 28 = 969.61 | H 29 = 984.75 | H 30 = 998.74 | | | | | |
| H 31 = 1011.5 | H 32 = 1023.1 | H 33 = 1033.5 | H 34 = 1042.8 | H 35 = 1050.9 | | | | | |
| H 36 = 1057.9 | H 37 = 1064.0 | H 38 = 1069.2 | H 39 = 1073.5 | H 40 = 1077.2 | | | | | |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 2

Location x/L: 0.05

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 2 LOC=.05 T:IN=610F T:OUT=1050.53 Q/A=1.08765 MW/M2
A21=38.526 A22=128.87 A23=176.87 A24=136.34 A25=73.925

3

| ITER NO. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA CUT= 1050.5 | DT: NA = 440.53 | T:B NA = 830.26 | T:B M = 853.31 | | | | |
| DT M-N = 38.526 | DT1 = 126.87 | DT P-N = 176.87 | DT P-M = 138.34 | DT2 = 73.925 | | | | |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 | | | | |
| N 5 = 610.00 | N 1 = 612.75 | N 2 = 616.08 | N 3 = 620.07 | N 4 = 624.79 | | | | |
| N 10 = 630.33 | N 6 = 636.77 | N 7 = 644.18 | N 8 = 652.61 | N 9 = 662.11 | | | | |
| N 15 = 672.72 | N 11 = 684.45 | N 12 = 697.28 | N 13 = 711.17 | N 14 = 726.08 | | | | |
| N 20 = 741.90 | N 16 = 756.53 | N 17 = 775.85 | N 18 = 793.68 | N 19 = 811.88 | | | | |
| N 25 = 830.26 | N 21 = 846.65 | N 22 = 866.85 | N 23 = 884.08 | N 24 = 902.00 | | | | |
| N 30 = 918.63 | N 26 = 934.45 | N 27 = 949.36 | N 28 = 963.25 | N 29 = 976.08 | | | | |
| N 35 = 987.81 | N 31 = 998.42 | N 32 = 1007.9 | N 33 = 1016.4 | N 34 = 1023.8 | | | | |
| N 40 = 1030.2 | N 36 = 1035.7 | N 37 = 1046.5 | N 38 = 1044.4 | N 39 = 1047.8 | | | | |
| M = .0 | M = .0 | M = .0 | M = .0 | M = .0 | | | | |
| M 5 = 615.21 | M 1 = 615.09 | M 2 = 623.71 | M 3 = 629.15 | M 4 = 635.50 | | | | |
| M 10 = 642.84 | M 6 = 651.23 | M 7 = 660.73 | M 8 = 671.36 | M 9 = 683.15 | | | | |
| M 15 = 696.09 | M 11 = 710.15 | M 12 = 725.25 | M 13 = 741.33 | M 14 = 758.26 | | | | |
| M 20 = 775.90 | M 16 = 794.10 | M 17 = 812.68 | M 18 = 831.45 | M 19 = 850.22 | | | | |
| M 25 = 868.79 | M 21 = 886.98 | M 22 = 904.61 | M 23 = 921.51 | M 24 = 937.56 | | | | |
| M 30 = 952.63 | M 26 = 966.63 | M 27 = 979.51 | M 28 = 991.23 | M 29 = 1001.3 | | | | |
| M 35 = 1011.2 | M 31 = 1019.5 | M 32 = 1026.7 | M 33 = 1032.9 | M 34 = 1038.2 | | | | |
| M 40 = 1042.7 | M 36 = 1046.4 | M 37 = 1049.5 | M 38 = 1052.1 | M 39 = 1054.1 | | | | |
| P = .0 | P = .0 | P = .0 | P = .0 | P = .0 | | | | |
| P 5 = 633.94 | P 1 = 641.84 | P 2 = 651.08 | P 3 = 661.76 | P 4 = 673.97 | | | | |
| P 10 = 687.75 | P 6 = 703.15 | P 7 = 720.15 | P 8 = 738.70 | P 9 = 758.70 | | | | |
| P 15 = 780.00 | P 11 = 802.42 | P 12 = 825.71 | P 13 = 849.61 | P 14 = 873.81 | | | | |
| P 20 = 897.99 | P 16 = 921.80 | P 17 = 944.93 | P 18 = 967.05 | P 19 = 987.87 | | | | |
| P 25 = 1007.1 | P 21 = 1024.6 | P 22 = 1040.2 | P 23 = 1053.8 | P 24 = 1065.3 | | | | |
| P 30 = 1074.7 | P 26 = 1082.2 | P 27 = 1087.8 | P 28 = 1091.7 | P 29 = 1094.0 | | | | |
| P 35 = 1095.1 | P 31 = 1095.0 | P 32 = 1094.0 | P 33 = 1092.3 | P 34 = 1090.1 | | | | |
| P 40 = 1087.6 | P 36 = 1084.9 | P 37 = 1082.2 | P 38 = 1079.4 | P 39 = 1076.9 | | | | |
| G = .0 | G = .0 | G = .0 | G = .0 | G = .0 | | | | |
| G 5 = 623.93 | G 1 = 625.69 | G 2 = 630.46 | G 3 = 644.34 | G 4 = 653.42 | | | | |
| G 10 = 663.76 | G 6 = 675.41 | G 7 = 688.40 | G 8 = 702.72 | G 9 = 718.34 | | | | |
| G 15 = 735.17 | G 11 = 753.12 | G 12 = 772.04 | G 13 = 791.76 | G 14 = 812.08 | | | | |
| G 20 = 832.76 | G 16 = 853.58 | G 17 = 874.28 | G 18 = 894.61 | G 19 = 914.33 | | | | |
| G 25 = 933.23 | G 21 = 951.09 | G 22 = 967.77 | G 23 = 983.11 | G 24 = 997.04 | | | | |
| G 30 = 1009.5 | G 26 = 1020.5 | G 27 = 1029.9 | G 28 = 1038.0 | G 29 = 1044.8 | | | | |
| G 35 = 1050.3 | G 31 = 1054.6 | G 32 = 1058.0 | G 33 = 1060.6 | G 34 = 1062.4 | | | | |
| G 40 = 1063.6 | G 36 = 1064.4 | G 37 = 1064.7 | G 38 = 1064.8 | G 39 = 1064.7 | | | | |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 | | | | |
| H 1 = 608.49 | H 2 = 610.96 | H 3 = 613.96 | H 4 = 617.59 | H 5 = 621.92 | | | | |
| H 6 = 627.05 | H 7 = 633.05 | H 8 = 640.00 | H 9 = 647.97 | H 10 = 657.01 | | | | |
| H 11 = 667.17 | H 12 = 676.46 | H 13 = 686.89 | H 14 = 704.43 | H 15 = 719.03 | | | | |
| H 16 = 734.62 | H 17 = 751.08 | H 18 = 768.29 | H 19 = 786.10 | H 20 = 804.36 | | | | |
| H 21 = 822.87 | H 22 = 841.45 | H 23 = 859.92 | H 24 = 878.08 | H 25 = 895.77 | | | | |
| H 26 = 912.81 | H 27 = 929.08 | H 28 = 944.44 | H 29 = 958.80 | H 30 = 972.09 | | | | |
| H 31 = 984.27 | H 32 = 995.31 | H 33 = 1005.2 | H 34 = 1014.0 | H 35 = 1021.8 | | | | |
| H 36 = 1028.5 | H 37 = 1034.4 | H 38 = 1039.3 | H 39 = 1043.5 | H 40 = 1047.0 | | | | |

CASE # 3

Solar Flux: OFF-NORMAL
Orifices: YES
Sub-Panel: 2
Location x/L: 0.25
T(Na-inlet) = 610 F
T(Na-outlet) : Mean = 1050F

PNL 2 LOC=-25 T:IN=610F T:OUT=1041.76 C/A=1.22369 Mb/M2
A21=42.418 A22=141.94 A23=195.80 A24=153.38 A25=82.444

3

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | CRITICAL NODE = 2 | |
|------------------|-------------------|--|-------------------|----------------|
| T:NA IN = 610.00 | T:NA OUT = 1041.8 | DT: NA = 431.76 | T:B NA = 825.88 | T:R M = 851.25 |
| DT M-N = 42.418 | DT1 = 141.94 | DT P-N = 195.80 | DT P-M = 153.38 | DT2 = 82.444 |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 |
| N 1 = 610.00 | N 1 = 612.70 | N 2 = 615.96 | N 3 = 619.87 | N 4 = 624.50 |
| N 5 = 629.93 | N 6 = 636.24 | N 7 = 643.50 | N 8 = 651.75 | N 9 = 661.08 |
| N 10 = 671.48 | N 11 = 682.97 | N 12 = 695.54 | N 13 = 709.16 | N 14 = 723.77 |
| N 15 = 739.27 | N 16 = 755.58 | N 17 = 772.54 | N 18 = 790.03 | N 19 = 807.86 |
| N 20 = 825.88 | N 21 = 843.90 | N 22 = 861.73 | N 23 = 879.22 | N 24 = 896.18 |
| N 25 = 912.49 | N 26 = 927.99 | N 27 = 942.60 | N 28 = 956.22 | N 29 = 968.79 |
| N 30 = 980.28 | N 31 = 996.68 | N 32 = 1000.00 | N 33 = 1008.3 | N 34 = 1015.5 |
| N 35 = 1021.8 | N 36 = 1027.3 | N 37 = 1031.5 | N 38 = 1035.8 | N 39 = 1039.1 |
| N 40 = 1041.8 | N = .0 | N = .0 | N = .0 | N = .0 |
| M = 615.74 | M 1 = 615.68 | M 2 = 624.36 | M 3 = 629.87 | M 4 = 636.29 |
| M 5 = 643.70 | M 6 = 652.16 | M 7 = 661.72 | M 8 = 672.41 | M 9 = 684.24 |
| M 10 = 697.20 | M 11 = 711.26 | M 12 = 726.34 | M 13 = 742.36 | M 14 = 759.20 |
| M 15 = 776.71 | M 16 = 794.73 | M 17 = 813.05 | M 18 = 831.61 | M 19 = 850.07 |
| M 20 = 868.30 | M 21 = 886.10 | M 22 = 903.31 | M 23 = 919.77 | M 24 = 935.34 |
| M 25 = 949.92 | M 26 = 963.43 | M 27 = 975.80 | M 28 = 987.02 | M 29 = 997.08 |
| M 30 = 1006.0 | M 31 = 1013.8 | M 32 = 1020.6 | M 33 = 1026.5 | M 34 = 1031.4 |
| M 35 = 1035.6 | M 36 = 1039.1 | M 37 = 1041.5 | M 38 = 1044.2 | M 39 = 1046.3 |
| M 40 = 1047.5 | M = .0 | M = .0 | M = .0 | M = .0 |
| P = 636.50 | P 1 = 644.90 | P 2 = 654.71 | P 3 = 666.03 | P 4 = 678.94 |
| P 5 = 693.50 | P 6 = 705.72 | P 7 = 727.60 | P 8 = 747.07 | P 9 = 768.00 |
| P 10 = 790.23 | P 11 = 813.56 | P 12 = 837.72 | P 13 = 862.41 | P 14 = 887.31 |
| P 15 = 912.07 | P 16 = 936.32 | P 17 = 959.73 | P 18 = 981.95 | P 19 = 1002.7 |
| P 20 = 1021.7 | P 21 = 1038.7 | P 22 = 1053.7 | P 23 = 1066.4 | P 24 = 1076.5 |
| P 25 = 1085.3 | P 26 = 1091.5 | P 27 = 1095.9 | P 28 = 1098.4 | P 29 = 1099.4 |
| P 30 = 1099.0 | P 31 = 1097.6 | P 32 = 1095.3 | P 33 = 1092.4 | P 34 = 1087.0 |
| P 35 = 1085.4 | P 36 = 1081.7 | P 37 = 1076.1 | P 38 = 1074.5 | P 39 = 1071.3 |
| P 40 = 1068.3 | P = .0 | P = .0 | P = .0 | P = .0 |
| G = 625.34 | G 1 = 631.35 | G 2 = 638.40 | G 3 = 646.60 | G 4 = 656.02 |
| G 5 = 666.74 | G 6 = 676.79 | G 7 = 692.20 | G 8 = 706.95 | G 9 = 722.95 |
| G 10 = 740.25 | G 11 = 756.59 | G 12 = 777.88 | G 13 = 797.91 | G 14 = 816.47 |
| G 15 = 839.34 | G 16 = 860.25 | G 17 = 880.94 | G 18 = 901.17 | G 19 = 920.69 |
| G 20 = 939.27 | G 21 = 956.72 | G 22 = 972.87 | G 23 = 987.61 | G 24 = 1000.9 |
| G 25 = 1012.6 | G 26 = 1022.7 | G 27 = 1031.3 | G 28 = 1038.6 | G 29 = 1044.4 |
| G 30 = 1049.1 | G 31 = 1052.6 | G 32 = 1055.2 | G 33 = 1057.0 | G 34 = 1058.1 |
| G 35 = 1058.6 | G 36 = 1058.8 | G 37 = 1058.6 | G 38 = 1058.2 | G 39 = 1057.7 |
| G 40 = 1057.1 | G = .0 | G = .0 | G = .0 | G = .0 |
| H 1 = 608.00 | H 2 = 616.31 | H 3 = 613.14 | H 4 = 616.56 | H 5 = 620.66 |
| H 6 = 625.52 | H 7 = 631.23 | H 8 = 637.86 | H 9 = 645.49 | H 10 = 654.16 |
| H 11 = 663.92 | H 12 = 674.81 | H 13 = 686.81 | H 14 = 699.92 | H 15 = 714.08 |
| H 16 = 729.22 | H 17 = 745.25 | H 18 = 762.04 | H 19 = 779.45 | H 20 = 797.33 |
| H 21 = 815.49 | H 22 = 833.75 | H 23 = 851.92 | H 24 = 869.83 | H 25 = 887.29 |
| H 26 = 904.15 | H 27 = 920.25 | H 28 = 935.45 | H 29 = 949.75 | H 30 = 962.97 |
| H 31 = 975.09 | H 32 = 986.10 | H 33 = 996.00 | H 34 = 1004.8 | H 35 = 1012.6 |
| H 36 = 1019.3 | H 37 = 1025.2 | H 38 = 1030.1 | H 39 = 1034.4 | H 40 = 1037.7 |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 2

Location x/L: 0.35

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050 F

PNL 2 LDC=.35 T:IN=610 F T:OUT=1041.07 Q/A=1.26796 MW/M2
A21=43.684 A22=146.19 A23=201.96 A24=158.27 A25=85.216

3

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|-----------|--------|--|--------|----------|--------|-------------------|--------|---------|--------|
| T:NA IN = | 610.00 | T:NA OUT= | 1041.1 | DT: NA = | 431.07 | T:8 NA = | 825.53 | T:8 M = | 851.00 |
| DT M-N = | 43.684 | DT1 = | 146.19 | DT P-N = | 201.96 | DT P-M = | 158.27 | DT2 = | 85.210 |
| N = | 610.00 | N 1 = | 612.69 | N 2 = | 615.95 | N 3 = | 619.85 | N 4 = | 624.47 |
| N 5 = | 629.90 | N 6 = | 636.20 | N 7 = | 643.44 | N 8 = | 651.65 | N 9 = | 661.00 |
| N 10 = | 671.38 | N 11 = | 682.85 | N 12 = | 695.40 | N 13 = | 709.00 | N 14 = | 723.59 |
| N 15 = | 739.07 | N 16 = | 755.34 | N 17 = | 772.28 | N 18 = | 789.74 | N 19 = | 807.55 |
| N 20 = | 825.53 | N 21 = | 843.52 | N 22 = | 861.33 | N 23 = | 878.79 | N 24 = | 895.73 |
| N 25 = | 912.00 | N 26 = | 927.49 | N 27 = | 942.07 | N 28 = | 955.67 | N 29 = | 968.22 |
| N 30 = | 979.69 | N 31 = | 990.07 | N 32 = | 999.38 | N 33 = | 1007.6 | N 34 = | 1014.9 |
| N 35 = | 1021.2 | N 36 = | 1026.6 | N 37 = | 1031.2 | N 38 = | 1035.1 | N 39 = | 1038.4 |
| N 40 = | 1041.1 | | | | | | | | |
| M = | 615.91 | M 1 = | 619.88 | M 2 = | 624.60 | M 3 = | 630.15 | M 4 = | 636.62 |
| M 5 = | 644.08 | M 6 = | 652.59 | M 7 = | 662.21 | M 8 = | 672.92 | M 9 = | 684.85 |
| M 10 = | 697.87 | M 11 = | 711.99 | M 12 = | 727.12 | M 13 = | 743.19 | M 14 = | 760.07 |
| M 15 = | 777.62 | M 16 = | 795.67 | M 17 = | 814.05 | M 18 = | 832.56 | M 19 = | 851.01 |
| M 20 = | 869.22 | M 21 = | 886.99 | M 22 = | 904.15 | M 23 = | 920.55 | M 24 = | 936.05 |
| M 25 = | 950.55 | M 26 = | 963.97 | M 27 = | 976.26 | M 28 = | 987.39 | M 29 = | 997.35 |
| M 30 = | 1006.2 | M 31 = | 1013.9 | M 32 = | 1020.6 | M 33 = | 1026.4 | M 34 = | 1031.3 |
| M 35 = | 1035.4 | M 36 = | 1038.7 | M 37 = | 1041.5 | M 38 = | 1043.8 | M 39 = | 1045.6 |
| M 40 = | 1047.0 | | | | | | | | |
| P = | 637.33 | P 1 = | 645.91 | P 2 = | 655.92 | P 3 = | 667.46 | P 4 = | 680.63 |
| P 5 = | 695.46 | P 6 = | 711.99 | P 7 = | 730.20 | P 8 = | 750.00 | P 9 = | 771.26 |
| P 10 = | 793.87 | P 11 = | 817.55 | P 12 = | 842.06 | P 13 = | 867.08 | P 14 = | 892.27 |
| P 15 = | 917.30 | P 16 = | 941.78 | P 17 = | 965.36 | P 18 = | 987.70 | P 19 = | 1008.5 |
| P 20 = | 1027.5 | P 21 = | 1044.5 | P 22 = | 1059.3 | P 23 = | 1071.9 | P 24 = | 1082.2 |
| P 25 = | 1090.2 | P 26 = | 1096.2 | P 27 = | 1100.1 | P 28 = | 1102.3 | P 29 = | 1102.9 |
| P 30 = | 1102.2 | P 31 = | 1100.4 | P 32 = | 1097.7 | P 33 = | 1094.4 | P 34 = | 1090.7 |
| P 35 = | 1086.7 | P 36 = | 1082.7 | P 37 = | 1078.8 | P 38 = | 1075.1 | P 39 = | 1071.6 |
| P 40 = | 1068.4 | | | | | | | | |
| G = | 625.80 | G 1 = | 631.90 | G 2 = | 639.06 | G 3 = | 647.38 | G 4 = | 656.94 |
| G 5 = | 667.81 | G 6 = | 680.03 | G 7 = | 693.61 | G 8 = | 708.54 | G 9 = | 724.76 |
| G 10 = | 742.21 | G 11 = | 760.74 | G 12 = | 780.20 | G 13 = | 800.40 | G 14 = | 821.13 |
| G 15 = | 842.12 | G 16 = | 863.14 | G 17 = | 883.92 | G 18 = | 904.21 | G 19 = | 923.74 |
| G 20 = | 942.31 | G 21 = | 955.72 | G 22 = | 975.80 | G 23 = | 990.43 | G 24 = | 1003.5 |
| G 25 = | 1015.1 | G 26 = | 1025.0 | G 27 = | 1033.5 | G 28 = | 1040.5 | G 29 = | 1046.1 |
| G 30 = | 1050.5 | G 31 = | 1053.8 | G 32 = | 1056.2 | G 33 = | 1057.8 | G 34 = | 1058.7 |
| G 35 = | 1059.1 | G 36 = | 1059.1 | G 37 = | 1058.7 | G 38 = | 1058.2 | G 39 = | 1057.6 |
| G 40 = | 1056.9 | | | | | | | | |
| H 1 = | 607.86 | H 2 = | 616.13 | H 3 = | 612.92 | H 4 = | 616.30 | H 5 = | 620.35 |
| H 6 = | 625.16 | H 7 = | 630.81 | H 8 = | 637.38 | H 9 = | 644.93 | H 10 = | 653.54 |
| H 11 = | 663.23 | H 12 = | 674.05 | H 13 = | 685.98 | H 14 = | 699.02 | H 15 = | 713.11 |
| H 16 = | 728.19 | H 17 = | 744.17 | H 18 = | 760.91 | H 19 = | 778.28 | H 20 = | 796.12 |
| H 21 = | 814.26 | H 22 = | 832.50 | H 23 = | 850.67 | H 24 = | 868.58 | H 25 = | 886.05 |
| H 26 = | 902.92 | H 27 = | 915.05 | H 28 = | 934.31 | H 29 = | 948.60 | H 30 = | 961.85 |
| H 31 = | 974.01 | H 32 = | 985.06 | H 33 = | 994.99 | H 34 = | 1003.8 | H 35 = | 1011.6 |
| H 36 = | 1018.4 | H 37 = | 1024.3 | H 38 = | 1029.2 | H 39 = | 1033.5 | H 40 = | 1037.1 |
| | .0 | | .0 | | .0 | | .0 | | .0 |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 2

Location x/L: 0.45

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 2 LOC=.45 I:IN=210F T:OUT=105C.74 Q/A=1.25640 MW/M2
A21=44.498 A22=148.92 A23=205.91 A24=161.41 A25=86.996

3

| ITER NO. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 |
|------------------|---|-----------------|-----------------|----------------|-------------------|
| T:NA IN = 610.00 | T:NA OUT= 1050.7 | DT: NA = 440.74 | T:B NA = 830.37 | T:B M = 856.08 | |
| DT M-N = 44.498 | DTI = 148.92 | DT P-N = 205.51 | DT P-M = 161.41 | DT2 = 86.996 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| N = 610.00 | N 1 = 612.75 | N 2 = 616.09 | N 3 = 620.07 | N 4 = 624.80 | |
| N 5 = 630.34 | N 6 = 636.78 | N 7 = 644.15 | N 8 = 652.63 | N 9 = 662.14 | |
| N 10 = 672.75 | N 11 = 684.48 | N 12 = 697.32 | N 13 = 711.22 | N 14 = 726.13 | |
| N 15 = 741.96 | N 16 = 756.60 | N 17 = 775.92 | N 18 = 793.77 | N 19 = 811.92 | |
| N 20 = 830.37 | N 21 = 848.76 | N 22 = 866.97 | N 23 = 884.82 | N 24 = 902.14 | |
| N 25 = 918.78 | N 26 = 934.61 | N 27 = 949.52 | N 28 = 963.42 | N 29 = 976.25 | |
| N 30 = 987.99 | N 31 = 998.60 | N 32 = 1008.1 | N 33 = 1016.5 | N 34 = 1024.0 | |
| N 35 = 1030.4 | N 36 = 1035.9 | N 37 = 1040.7 | N 38 = 1044.7 | N 39 = 1048.0 | |
| N 40 = 1056.7 | = .0 | = .0 | = .0 | = .0 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| M = 616.02 | M 1 = 626.07 | M 2 = 624.89 | M 3 = 630.56 | M 4 = 637.17 | |
| M 5 = 644.79 | M 6 = 653.48 | M 7 = 663.31 | M 8 = 674.29 | M 9 = 686.44 | |
| M 10 = 699.74 | M 11 = 714.16 | M 12 = 725.63 | M 13 = 740.05 | M 14 = 763.30 | |
| M 15 = 781.23 | M 16 = 795.68 | M 17 = 818.46 | M 18 = 837.39 | M 19 = 856.26 | |
| M 20 = 874.67 | M 21 = 893.04 | M 22 = 910.58 | M 23 = 927.36 | M 24 = 943.21 | |
| M 25 = 958.05 | M 26 = 971.78 | M 27 = 984.35 | M 28 = 995.73 | M 29 = 1005.9 | |
| M 30 = 1015.0 | M 31 = 1022.9 | M 32 = 1029.8 | M 33 = 1035.7 | M 34 = 1040.7 | |
| M 35 = 1044.8 | M 36 = 1048.3 | M 37 = 1051.2 | M 38 = 1053.5 | M 39 = 1055.3 | |
| M 40 = 1056.8 | = .0 | = .0 | = .0 | = .0 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| P = 637.87 | P 1 = 646.62 | P 2 = 656.83 | P 3 = 668.62 | P 4 = 682.05 | |
| P 5 = 697.19 | P 6 = 714.06 | P 7 = 732.64 | P 8 = 752.80 | P 9 = 774.58 | |
| P 10 = 797.64 | P 11 = 821.82 | P 12 = 846.84 | P 13 = 872.39 | P 14 = 898.12 | |
| P 15 = 923.68 | P 16 = 948.68 | P 17 = 972.77 | P 18 = 995.60 | P 19 = 1016.9 | |
| P 20 = 1036.3 | P 21 = 1053.6 | P 22 = 1068.8 | P 23 = 1081.7 | P 24 = 1092.2 | |
| P 25 = 1100.5 | P 26 = 1106.6 | P 27 = 1110.7 | P 28 = 1112.9 | P 29 = 1113.6 | |
| P 30 = 1112.9 | P 31 = 1111.0 | P 32 = 1108.3 | P 33 = 1105.0 | P 34 = 1101.2 | |
| P 35 = 1097.2 | P 36 = 1053.2 | P 37 = 1089.2 | P 38 = 1085.4 | P 39 = 1081.9 | |
| P 40 = 1078.6 | = .0 | = .0 | = .0 | = .0 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| G = 626.10 | G 1 = 632.32 | G 2 = 639.63 | G 3 = 648.12 | G 4 = 657.87 | |
| G 5 = 668.96 | G 6 = 681.43 | G 7 = 695.29 | G 8 = 710.53 | G 9 = 727.10 | |
| G 10 = 744.91 | G 11 = 763.83 | G 12 = 783.70 | G 13 = 804.33 | G 14 = 825.45 | |
| G 15 = 846.94 | G 16 = 868.42 | G 17 = 889.65 | G 18 = 910.37 | G 19 = 930.34 | |
| G 20 = 949.33 | G 21 = 967.12 | G 22 = 983.57 | G 23 = 998.54 | G 24 = 1011.9 | |
| G 25 = 1023.8 | G 26 = 1034.0 | G 27 = 1042.6 | G 28 = 1049.8 | G 29 = 1055.6 | |
| G 30 = 1060.1 | G 31 = 1063.6 | G 32 = 1066.0 | G 33 = 1067.6 | G 34 = 1068.6 | |
| G 35 = 1069.0 | G 36 = 1069.0 | G 37 = 1068.7 | G 38 = 1068.2 | G 39 = 1067.0 | |
| G 40 = 1066.8 | = .0 | = .0 | = .0 | = .0 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| H 1 = 607.83 | H 2 = 610.16 | H 3 = 613.01 | H 4 = 616.47 | H 5 = 620.62 | |
| H 6 = 625.54 | H 7 = 631.32 | H 8 = 638.04 | H 9 = 645.78 | H 10 = 654.58 | |
| H 11 = 664.50 | H 12 = 675.56 | H 13 = 687.77 | H 14 = 701.10 | H 15 = 715.52 | |
| H 16 = 730.95 | H 17 = 747.28 | H 18 = 764.40 | H 19 = 782.17 | H 20 = 800.41 | |
| H 21 = 818.95 | H 22 = 837.60 | H 23 = 856.17 | H 24 = 874.48 | H 25 = 892.34 | |
| H 26 = 909.58 | H 27 = 926.07 | H 28 = 941.66 | H 29 = 956.27 | H 30 = 969.81 | |
| H 31 = 982.24 | H 32 = 993.53 | H 33 = 1003.7 | H 34 = 1012.7 | H 35 = 1020.7 | |
| H 36 = 1027.6 | H 37 = 1033.6 | H 38 = 1038.7 | H 39 = 1043.1 | H 40 = 1046.7 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 2

Location x/L: FULL

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 2 LOC=FULL:IN=610F T:OUT=1053.55 Q/A=1.3046E MW/M2
A21=44.735 A22=149.71 A23=207.06 A24=162.33 A25=87.51

3

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1053.6 | DT: NA = 443.55 | T:B NA = 831.77 | T:B # = 858.53 | | | | | |
| DT M-N = 44.735 | DT1 = 149.71 | DT F-N = 207.06 | DT P-M = 162.33 | DT2 = 87.514 | | | | | |
| N = 610.00 | N 1 = 612.77 | N 2 = 616.12 | N 3 = 620.14 | N 4 = 624.89 | | | | | |
| N 5 = 630.47 | N 6 = 636.96 | N 7 = 644.41 | N 8 = 652.90 | N 9 = 662.47 | | | | | |
| N 10 = 673.15 | N 11 = 684.96 | N 12 = 697.88 | N 13 = 711.87 | N 14 = 726.87 | | | | | |
| N 15 = 742.80 | N 16 = 755.55 | N 17 = 776.98 | N 18 = 794.94 | N 19 = 813.27 | | | | | |
| N 20 = 831.77 | N 21 = 850.28 | N 22 = 868.61 | N 23 = 886.57 | N 24 = 904.00 | | | | | |
| N 25 = 920.75 | N 26 = 936.68 | N 27 = 951.68 | N 28 = 965.67 | N 29 = 978.59 | | | | | |
| N 30 = 990.40 | N 31 = 1001.1 | N 32 = 1010.6 | N 33 = 1019.1 | N 34 = 1026.6 | | | | | |
| N 35 = 1033.1 | N 36 = 1038.7 | N 37 = 1043.4 | N 38 = 1047.4 | N 39 = 1050.8 | | | | | |
| N 40 = 1053.6 | | | | | | | | | |
| M = 616.05 | M 1 = 620.13 | M 2 = 624.98 | M 3 = 630.68 | M 4 = 637.33 | | | | | |
| M 5 = 645.00 | M 6 = 653.74 | M 7 = 663.63 | M 8 = 674.67 | M 9 = 686.90 | | | | | |
| M 10 = 700.29 | M 11 = 714.80 | M 12 = 730.36 | M 13 = 746.88 | M 14 = 764.24 | | | | | |
| M 15 = 782.28 | M 16 = 800.85 | M 17 = 819.75 | M 18 = 838.79 | M 19 = 857.78 | | | | | |
| M 20 = 876.51 | M 21 = 894.79 | M 22 = 912.46 | M 23 = 929.33 | M 24 = 945.29 | | | | | |
| M 25 = 960.22 | M 26 = 974.04 | M 27 = 986.70 | M 28 = 998.16 | M 29 = 1008.4 | | | | | |
| M 30 = 1017.5 | M 31 = 1025.5 | M 32 = 1032.4 | M 33 = 1038.4 | M 34 = 1043.4 | | | | | |
| M 35 = 1047.6 | M 36 = 1051.1 | M 37 = 1054.0 | M 38 = 1056.3 | M 39 = 1058.1 | | | | | |
| M 40 = 1059.6 | | | | | | | | | |
| P = 638.02 | P 1 = 646.83 | P 2 = 657.10 | P 3 = 668.95 | P 4 = 682.40 | | | | | |
| P 5 = 697.70 | P 6 = 714.67 | P 7 = 733.35 | P 8 = 753.69 | P 9 = 775.54 | | | | | |
| P 10 = 798.74 | P 11 = 823.06 | P 12 = 848.23 | P 13 = 873.93 | P 14 = 899.82 | | | | | |
| P 15 = 925.53 | P 16 = 950.69 | P 17 = 974.93 | P 18 = 997.90 | P 19 = 1019.3 | | | | | |
| P 20 = 1038.8 | P 21 = 1056.3 | P 22 = 1071.6 | P 23 = 1084.5 | P 24 = 1095.1 | | | | | |
| P 25 = 1103.5 | P 26 = 1109.6 | P 27 = 1113.7 | P 28 = 1116.0 | P 29 = 1116.7 | | | | | |
| P 30 = 1116.0 | P 31 = 1114.1 | P 32 = 1111.4 | P 33 = 1108.1 | P 34 = 1104.3 | | | | | |
| P 35 = 1100.3 | P 36 = 1096.2 | P 37 = 1092.2 | P 38 = 1088.4 | P 39 = 1084.6 | | | | | |
| P 40 = 1081.6 | | | | | | | | | |
| G = 626.18 | G 1 = 632.44 | G 2 = 635.79 | G 3 = 648.33 | G 4 = 658.14 | | | | | |
| G 5 = 669.30 | G 6 = 681.84 | G 7 = 695.78 | G 8 = 711.11 | G 9 = 727.70 | | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 10 = 745.69 | G 11 = 764.72 | G 12 = 784.72 | G 13 = 805.47 | G 14 = 820.70 |
| G 15 = 848.34 | G 16 = 865.95 | G 17 = 891.31 | G 18 = 912.17 | G 19 = 932.26 |
| G 20 = 951.36 | G 21 = 965.28 | G 22 = 985.83 | G 23 = 1000.9 | G 24 = 1014.4 |
| G 25 = 1026.3 | G 26 = 1036.6 | G 27 = 1045.3 | G 28 = 1052.5 | G 29 = 1058.4 |
| G 30 = 1062.9 | G 31 = 1066.4 | G 32 = 1068.9 | G 33 = 1070.5 | G 34 = 1071.5 |
| G 35 = 1071.9 | G 36 = 1071.9 | G 37 = 1071.6 | G 38 = 1071.1 | G 39 = 1070.4 |
| G 40 = 1069.7 | | | | |
| H 1 = 607.82 | H 2 = 610.16 | H 3 = 613.04 | H 4 = 616.52 | H 5 = 620.09 |
| H 6 = 625.65 | H 7 = 631.47 | H 8 = 638.24 | H 9 = 646.02 | H 10 = 654.89 |
| H 11 = 664.87 | H 12 = 676.00 | H 13 = 688.29 | H 14 = 701.71 | H 15 = 716.22 |
| H 16 = 731.75 | H 17 = 746.19 | H 18 = 765.42 | H 19 = 783.30 | H 20 = 801.65 |
| H 21 = 820.31 | H 22 = 835.08 | H 23 = 857.77 | H 24 = 876.19 | H 25 = 894.17 |
| H 26 = 911.52 | H 27 = 928.11 | H 28 = 943.80 | H 29 = 958.50 | H 30 = 972.13 |
| H 31 = 984.63 | H 32 = 995.99 | H 33 = 1006.2 | H 34 = 1015.3 | H 35 = 1023.3 |
| H 36 = 1030.3 | H 37 = 1036.3 | H 38 = 1041.5 | H 39 = 1045.8 | H 40 = 1049.5 |
| | | | | |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 1

Location x/L: 0.0(OUT)

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 1 LOC=0 T:IN=610F T:OUT=784.39 C/A=0.08998 MM/M2
 A21=3.975 A22=13.250 A23=17.263 A24=13.288 A25=6.6630

3

| ITER NO. | GREATEST TEMPERATURE CHANGE PER ITERATION = | | | | CRITICAL NODE = |
|------------------|---|-----------------|-----------------|----------------|-----------------|
| | 2 | | | | 2 |
| T:NA IN = 610.00 | T:NA OUT= 784.39 | DT: NA = 174.39 | T:E NA = 697.19 | T:E M = 699.57 | |
| DT M-N = 3.9750 | DT1 = 13.250 | DT F-N = 17.263 | DT P-M = 13.288 | DT2 = 0.6630 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| N = 610.00 | N 1 = 611.09 | N 2 = 612.41 | N 3 = 613.99 | N 4 = 615.86 | |
| N 5 = 618.05 | N 6 = 626.60 | N 7 = 623.53 | N 8 = 626.87 | N 9 = 630.63 | |
| N 10 = 634.83 | N 11 = 635.47 | N 12 = 644.55 | N 13 = 650.05 | N 14 = 655.95 | |
| N 15 = 662.21 | N 16 = 668.80 | N 17 = 675.05 | N 18 = 682.71 | N 19 = 689.92 | |
| N 20 = 697.19 | N 21 = 704.47 | N 22 = 711.68 | N 23 = 718.74 | N 24 = 725.59 | |
| N 25 = 732.18 | N 26 = 738.44 | N 27 = 744.34 | N 28 = 745.84 | N 29 = 754.92 | |
| N 30 = 759.56 | N 31 = 763.76 | N 32 = 767.52 | N 33 = 770.85 | N 34 = 773.79 | |
| N 35 = 776.34 | N 36 = 776.53 | N 37 = 780.40 | N 38 = 781.98 | N 39 = 783.30 | |
| N 40 = 784.39 | = .0 | = .0 | = .0 | = .0 | |
| M = 610.54 | M 1 = 611.74 | M 2 = 613.19 | M 3 = 614.92 | M 4 = 616.90 | |
| M 5 = 619.34 | M 6 = 622.09 | M 7 = 625.24 | M 8 = 628.80 | M 9 = 632.80 | |
| M 10 = 637.24 | M 11 = 642.12 | M 12 = 647.44 | M 13 = 653.16 | M 14 = 659.27 | |
| M 15 = 665.72 | M 16 = 672.47 | M 17 = 679.45 | M 18 = 686.61 | M 19 = 693.87 | |
| M 20 = 701.17 | M 21 = 706.43 | M 22 = 715.57 | M 23 = 722.54 | M 24 = 729.26 | |
| M 25 = 735.68 | M 26 = 741.76 | M 27 = 747.45 | M 28 = 752.73 | M 29 = 757.57 | |
| M 30 = 761.97 | M 31 = 765.93 | M 32 = 769.44 | M 33 = 772.57 | M 34 = 775.28 | |
| M 35 = 777.63 | M 36 = 779.64 | M 37 = 781.34 | M 38 = 782.77 | M 39 = 783.95 | |
| M 40 = 784.93 | = .0 | = .0 | = .0 | = .0 | |
| P = 612.34 | P 1 = 613.93 | P 2 = 615.82 | P 3 = 618.06 | P 4 = 620.64 | |
| P 5 = 623.65 | P 6 = 627.08 | P 7 = 630.94 | P 8 = 635.27 | P 9 = 640.06 | |
| P 10 = 645.30 | P 11 = 656.99 | P 12 = 657.09 | P 13 = 663.56 | P 14 = 670.37 | |
| P 15 = 677.45 | P 16 = 684.73 | P 17 = 692.16 | P 18 = 699.64 | P 19 = 707.09 | |
| P 20 = 714.46 | P 21 = 721.65 | P 22 = 728.60 | P 23 = 735.24 | P 24 = 741.53 | |
| P 25 = 747.41 | P 26 = 752.86 | P 27 = 757.85 | P 28 = 762.37 | P 29 = 766.43 | |
| P 30 = 770.03 | P 31 = 773.19 | P 32 = 775.92 | P 33 = 778.28 | P 34 = 780.27 | |
| P 35 = 781.94 | P 36 = 783.33 | P 37 = 784.47 | P 38 = 785.40 | P 39 = 786.14 | |
| P 40 = 786.73 | = .0 | = .0 | = .0 | = .0 | |
| G = 611.43 | G 1 = 612.83 | G 2 = 614.51 | G 3 = 616.48 | G 4 = 618.80 | |
| G 5 = 621.49 | G 6 = 624.58 | G 7 = 628.08 | G 8 = 632.03 | G 9 = 636.42 | |
| G 10 = 641.26 | G 11 = 646.54 | G 12 = 652.25 | G 13 = 658.35 | G 14 = 664.80 | |
| G 15 = 671.57 | G 16 = 678.58 | G 17 = 685.79 | G 18 = 693.10 | G 19 = 700.47 | |
| G 20 = 707.79 | G 21 = 715.02 | G 22 = 722.07 | G 23 = 728.87 | G 24 = 735.38 | |
| G 25 = 741.53 | G 26 = 747.29 | G 27 = 752.64 | G 28 = 757.54 | G 29 = 761.99 | |
| G 30 = 765.99 | G 31 = 765.55 | G 32 = 772.68 | G 33 = 775.41 | G 34 = 777.77 | |
| G 35 = 779.78 | G 36 = 781.48 | G 37 = 782.90 | G 38 = 784.08 | G 39 = 785.04 | |
| G 40 = 785.82 | = .0 | = .0 | = .0 | = .0 | |
| H 1 = 610.65 | H 2 = 611.88 | H 3 = 613.36 | H 4 = 615.12 | H 5 = 617.19 | |
| H 6 = 619.60 | H 7 = 622.39 | H 8 = 625.58 | H 9 = 629.16 | H 10 = 633.22 | |
| H 11 = 637.70 | H 12 = 642.63 | H 13 = 647.98 | H 14 = 653.74 | H 15 = 659.86 | |
| H 16 = 666.35 | H 17 = 673.12 | H 18 = 680.12 | H 19 = 687.28 | H 20 = 694.54 | |
| H 21 = 701.83 | H 22 = 705.08 | H 23 = 716.20 | H 24 = 723.14 | H 25 = 729.84 | |
| H 26 = 736.23 | H 27 = 742.26 | H 28 = 747.92 | H 29 = 753.15 | H 30 = 757.95 | |
| H 31 = 762.31 | H 32 = 766.23 | H 33 = 769.72 | H 34 = 772.80 | H 35 = 775.48 | |
| H 36 = 777.80 | H 37 = 779.76 | H 38 = 781.46 | H 39 = 782.86 | H 40 = 784.03 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 1

PNL 1 LOC=1 T:IN=610F T:OUT=1075.25 C/A=1.04374 MW/M2
A21=37.270 A22=124.65 A23=170.76 A24=133.49 A25=71.175

Location x/L: 1.0 (IN)

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

3

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| | | | | |
|------------------|------------------|-----------------|-----------------|----------------|
| T:NA IN = 610.00 | T:NA OUT= 1079.2 | DT: NA = 469.25 | T:B NA = 846.62 | T:B M = 866.92 |
| DT M-N = 37.270 | DTI = 124.65 | DT F-N = 170.76 | DT P-M = 133.49 | DT2 = 71.175 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.93 | N 2 = 616.48 | N 3 = 620.72 | N 4 = 625.76 |
| N 5 = 631.66 | N 6 = 638.52 | N 7 = 646.40 | N 8 = 655.39 | N 9 = 665.51 |
| N 10 = 676.81 | N 11 = 685.30 | N 12 = 702.97 | N 13 = 717.77 | N 14 = 733.64 |
| N 15 = 750.50 | N 16 = 766.22 | N 17 = 786.66 | N 18 = 805.66 | N 19 = 825.04 |
| N 20 = 844.62 | N 21 = 864.20 | N 22 = 883.59 | N 23 = 902.59 | N 24 = 921.03 |
| N 25 = 938.75 | N 26 = 955.61 | N 27 = 971.46 | N 28 = 986.28 | N 29 = 999.95 |
| N 30 = 1012.4 | N 31 = 1023.7 | N 32 = 1033.9 | N 33 = 1042.8 | N 34 = 1050.7 |
| N 35 = 1057.6 | N 36 = 1063.5 | N 37 = 1068.5 | N 38 = 1072.8 | N 39 = 1076.3 |
| N 40 = 1079.2 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| M = 615.04 | M 1 = 615.06 | M 2 = 623.85 | M 3 = 629.51 | M 4 = 636.12 |
| M 5 = 643.76 | M 6 = 652.50 | M 7 = 662.41 | M 8 = 673.53 | M 9 = 685.86 |
| M 10 = 699.42 | M 11 = 714.16 | M 12 = 730.03 | M 13 = 746.94 | M 14 = 764.77 |
| M 15 = 783.39 | M 16 = 802.62 | M 17 = 822.25 | M 18 = 842.19 | M 19 = 862.13 |
| M 20 = 881.89 | M 21 = 901.29 | M 22 = 920.12 | M 23 = 938.22 | M 24 = 955.44 |
| M 25 = 971.64 | M 26 = 986.74 | M 27 = 1000.7 | M 28 = 1013.3 | M 29 = 1024.8 |
| M 30 = 1035.0 | M 31 = 1044.1 | M 32 = 1052.0 | M 33 = 1058.9 | M 34 = 1064.7 |
| M 35 = 1069.7 | M 36 = 1073.9 | M 37 = 1077.3 | M 38 = 1080.1 | M 39 = 1082.4 |
| M 40 = 1084.3 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| P = 633.11 | P 1 = 641.02 | P 2 = 650.27 | P 3 = 660.98 | P 4 = 673.23 |
| P 5 = 687.10 | P 6 = 702.60 | P 7 = 719.76 | P 8 = 738.50 | P 9 = 758.76 |
| P 10 = 780.38 | P 11 = 803.20 | P 12 = 826.96 | P 13 = 851.42 | P 14 = 876.27 |
| P 15 = 901.19 | P 16 = 925.85 | P 17 = 945.90 | P 18 = 973.04 | P 19 = 994.95 |
| P 20 = 1015.4 | P 21 = 1034.1 | P 22 = 1051.0 | P 23 = 1065.8 | P 24 = 1078.7 |
| P 25 = 1089.4 | P 26 = 1058.2 | P 27 = 1105.1 | P 28 = 1110.3 | P 29 = 1113.8 |
| P 30 = 1116.0 | P 31 = 1117.0 | P 32 = 1117.0 | P 33 = 1116.2 | P 34 = 1114.5 |
| P 35 = 1113.0 | P 36 = 1111.0 | P 37 = 1108.8 | P 38 = 1106.6 | P 39 = 1104.4 |
| P 40 = 1102.4 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| G = 623.48 | G 1 = 625.31 | G 2 = 636.19 | G 3 = 644.20 | G 4 = 652.45 |
| G 5 = 663.99 | G 6 = 675.90 | G 7 = 689.19 | G 8 = 703.86 | G 9 = 719.90 |
| G 10 = 737.22 | G 11 = 755.73 | G 12 = 775.29 | G 13 = 795.72 | G 14 = 816.83 |
| G 15 = 838.39 | G 16 = 860.15 | G 17 = 881.87 | G 18 = 903.28 | G 19 = 924.14 |
| G 20 = 944.22 | G 21 = 963.30 | G 22 = 981.21 | G 23 = 997.80 | G 24 = 1013.0 |
| G 25 = 1026.6 | G 26 = 1038.8 | G 27 = 1045.4 | G 28 = 1058.6 | G 29 = 1066.4 |
| G 30 = 1072.8 | G 31 = 1078.1 | G 32 = 1082.2 | G 33 = 1085.6 | G 34 = 1088.1 |
| G 35 = 1089.9 | G 36 = 1091.2 | G 37 = 1092.0 | G 38 = 1092.5 | G 39 = 1092.7 |
| G 40 = 1092.7 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 608.81 | H 2 = 611.52 | H 3 = 614.82 | H 4 = 618.79 | H 5 = 623.52 |
| H 6 = 629.11 | H 7 = 635.64 | H 8 = 643.15 | H 9 = 651.83 | H 10 = 661.62 |
| H 11 = 672.59 | H 12 = 684.77 | H 13 = 698.16 | H 14 = 712.72 | H 15 = 728.39 |
| H 16 = 745.09 | H 17 = 762.70 | H 18 = 781.10 | H 19 = 800.11 | H 20 = 819.57 |
| H 21 = 839.27 | H 22 = 855.03 | H 23 = 878.64 | H 24 = 897.90 | H 25 = 916.64 |
| H 26 = 934.68 | H 27 = 951.87 | H 28 = 968.09 | H 29 = 983.24 | H 30 = 997.24 |
| H 31 = 1010.1 | H 32 = 1021.7 | H 33 = 1032.1 | H 34 = 1041.3 | H 35 = 1049.5 |
| H 36 = 1056.5 | H 37 = 1062.6 | H 38 = 1067.8 | H 39 = 1072.2 | H 40 = 1075.9 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 2

Location x/L: 0.0 (out)

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 2 LOC=0 T:IN=610F T:OUT=1046.98 C/A=1.04374 MW/M2
A21=37.270 A22=124.65 A23=170.76 A24=133.45 A25=71.175

3

ITER NO. 2- GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| ITER NO. | 2- | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | CRITICAL NODE = 2 |
|------------------|------------------|--|-------------------|
| T:NA IN = 610.00 | T:NA OUT= 1049.0 | DT: NA = 436.98 | T:BN A = 829.49 |
| DT M-N = 37.270 | DT1 = 124.65 | DT P-N = 170.76 | DT P-M = 133.49 |
| = .0 | = .0 | = .0 | = .0 |
| N = 610.00 | N 1 = 612.74 | N 2 = 616.06 | N 3 = 620.03 |
| N 5 = 630.26 | N 6 = 636.68 | N 7 = 644.06 | N 8 = 652.46 |
| N 10 = 672.50 | N 11 = 684.19 | N 12 = 696.97 | N 13 = 710.82 |
| N 15 = 741.44 | N 16 = 758.01 | N 17 = 775.26 | N 18 = 793.04 |
| N 20 = 829.49 | N 21 = 847.81 | N 22 = 865.94 | N 23 = 883.72 |
| N 25 = 917.54 | N 26 = 933.31 | N 27 = 948.16 | N 28 = 962.01 |
| N 30 = 986.48 | N 31 = 997.05 | N 32 = 1006.5 | N 33 = 1014.9 |
| N 35 = 1028.7 | N 36 = 1034.2 | N 37 = 1038.9 | N 38 = 1042.9 |
| N 40 = 1049.0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 |
| M = 615.04 | M 1 = 616.87 | M 2 = 623.44 | M 3 = 628.82 |
| M 5 = 642.36 | M 6 = 650.67 | M 7 = 660.07 | M 8 = 670.60 |
| M 10 = 695.11 | M 11 = 705.05 | M 12 = 724.02 | M 13 = 739.99 |
| M 15 = 774.33 | M 16 = 792.41 | M 17 = 810.89 | M 18 = 824.57 |
| M 20 = 866.76 | M 21 = 884.89 | M 22 = 902.47 | M 23 = 919.35 |
| M 25 = 950.44 | M 26 = 964.44 | M 27 = 977.33 | M 28 = 989.07 |
| M 30 = 1009.1 | M 31 = 1017.4 | M 32 = 1024.7 | M 33 = 1030.9 |
| M 35 = 1040.8 | M 36 = 1044.6 | M 37 = 1047.7 | M 38 = 1050.3 |
| M 40 = 1054.0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 |
| P = 633.11 | P 1 = 640.83 | P 2 = 645.85 | P 3 = 660.29 |
| P 5 = 685.70 | P 6 = 700.77 | P 7 = 717.41 | P 8 = 735.58 |
| P 10 = 776.07 | P 11 = 798.08 | P 12 = 820.97 | P 13 = 844.47 |
| P 15 = 892.13 | P 16 = 915.64 | P 17 = 938.51 | P 18 = 960.42 |
| P 20 = 1000.2 | P 21 = 1017.7 | P 22 = 1033.3 | P 23 = 1047.0 |
| P 25 = 1068.2 | P 26 = 1075.9 | P 27 = 1081.6 | P 28 = 1086.0 |
| P 30 = 1090.0 | P 31 = 1090.3 | P 32 = 1089.6 | P 33 = 1088.3 |
| P 35 = 1084.2 | P 36 = 1081.7 | P 37 = 1079.2 | P 38 = 1076.7 |
| P 40 = 1072.1 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 |
| G = 623.48 | G 1 = 625.12 | G 2 = 635.77 | G 3 = 643.51 |
| G 5 = 662.60 | G 6 = 674.06 | G 7 = 686.84 | G 8 = 700.94 |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 10 = 732.91 | G 11 = 750.61 | G 12 = 769.29 | G 13 = 786.77 | G 14 = 808.80 |
| G 15 = 829.33 | G 16 = 845.95 | G 17 = 870.47 | G 18 = 890.00 | G 19 = 910.27 |
| G 20 = 929.08 | G 21 = 946.90 | G 22 = 963.56 | G 23 = 978.93 | G 24 = 992.91 |
| G 25 = 1005.4 | G 26 = 1016.5 | G 27 = 1026.1 | G 28 = 1034.3 | G 29 = 1041.2 |
| G 30 = 1046.9 | G 31 = 1051.4 | G 32 = 1055.0 | G 33 = 1057.7 | G 34 = 1059.7 |
| G 35 = 1061.1 | G 36 = 1061.9 | G 37 = 1062.4 | G 38 = 1062.6 | G 39 = 1062.6 |
| G 40 = 1062.5 | = .0 | = .0 | = .0 | = .0 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 608.62 | H 2 = 611.10 | H 3 = 614.13 | H 4 = 617.77 | H 5 = 622.13 |
| H 6 = 627.27 | H 7 = 633.29 | H 8 = 640.26 | H 9 = 648.25 | H 10 = 657.31 |
| H 11 = 667.48 | H 12 = 678.78 | H 13 = 691.21 | H 14 = 704.74 | H 15 = 719.32 |
| H 16 = 734.88 | H 17 = 751.31 | H 18 = 768.48 | H 19 = 786.24 | H 20 = 804.43 |
| H 21 = 822.88 | H 22 = 841.38 | H 23 = 859.77 | H 24 = 877.84 | H 25 = 895.43 |
| H 26 = 912.38 | H 27 = 926.55 | H 28 = 943.82 | H 29 = 958.08 | H 30 = 971.26 |
| H 31 = 983.37 | H 32 = 994.33 | H 33 = 1004.2 | H 34 = 1012.9 | H 35 = 1020.0 |
| H 36 = 1027.3 | H 37 = 1033.0 | H 38 = 1038.0 | H 39 = 1042.1 | H 40 = 1045.6 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 3

Solar Flux: OFF-NORMAL

Orifices: YES

Sub-Panel: 2

Location x/L: 1.0 (IN)

T(Na-inlet) = 610 F

T(Na-outlet) : Mean = 1050F

PNL 2 LOC=1 T:IN=610F T:OUT=1053.55 C/A=1.30468 MW/M2
A21=44.735 A22=149.71 A23=207.06 A24=162.33 A25=87.514

3

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NCDE = 2 |
|------------------|------------------|--|-----------------|----------------|--|-------------------|
| T:NA IN = 610.00 | T:NA OUT= 1053.6 | DT: NA = 443.55 | T:B NA = 631.77 | T:b M = 858.53 | | |
| DT M-N = 44.735 | DT1 = 145.71 | DT F-N = 207.06 | DT P-M = 162.33 | DT2 = 87.514 | | |
| N = 610.00 | N 1 = 612.77 | N 2 = 616.12 | N 3 = 620.14 | N 4 = 624.89 | | |
| N 5 = 630.47 | N 6 = 636.96 | N 7 = 644.41 | N 8 = 652.90 | N 9 = 662.47 | | |
| N 10 = 673.15 | N 11 = 684.96 | N 12 = 697.88 | N 13 = 711.87 | N 14 = 726.87 | | |
| N 15 = 742.80 | N 16 = 759.55 | N 17 = 776.98 | N 18 = 794.94 | N 19 = 813.27 | | |
| N 20 = 831.77 | N 21 = 850.28 | N 22 = 868.61 | N 23 = 886.57 | N 24 = 904.00 | | |
| N 25 = 920.75 | N 26 = 936.68 | N 27 = 951.68 | N 28 = 965.67 | N 29 = 978.59 | | |
| N 30 = 990.40 | N 31 = 1001.1 | N 32 = 1010.6 | N 33 = 1019.1 | N 34 = 1026.6 | | |
| N 35 = 1033.1 | N 36 = 1038.7 | N 37 = 1043.4 | N 38 = 1047.4 | N 39 = 1050.8 | | |
| N 40 = 1053.6 | | | | | | |
| M = 616.05 | M 1 = 620.13 | M 2 = 624.98 | M 3 = 630.68 | M 4 = 637.33 | | |
| M 5 = 645.00 | M 6 = 653.74 | M 7 = 663.63 | M 8 = 674.67 | M 9 = 686.90 | | |
| M 10 = 700.29 | M 11 = 714.80 | M 12 = 730.36 | M 13 = 746.88 | M 14 = 764.24 | | |
| M 15 = 782.28 | M 16 = 800.85 | M 17 = 819.75 | M 18 = 838.79 | M 19 = 857.78 | | |
| M 20 = 876.51 | M 21 = 894.79 | M 22 = 912.46 | M 23 = 929.33 | M 24 = 945.26 | | |
| M 25 = 960.22 | M 26 = 974.04 | M 27 = 986.70 | M 28 = 998.16 | M 29 = 1008.4 | | |
| M 30 = 1017.5 | M 31 = 1025.5 | M 32 = 1032.4 | M 33 = 1036.4 | M 34 = 1043.4 | | |
| M 35 = 1047.6 | M 36 = 1051.1 | M 37 = 1054.0 | M 38 = 1056.0 | M 39 = 1056.1 | | |
| M 40 = 1059.6 | | | | | | |
| P = 638.02 | P 1 = 646.83 | P 2 = 657.10 | P 3 = 668.95 | P 4 = 682.46 | | |
| P 5 = 697.70 | P 6 = 714.67 | P 7 = 733.35 | P 8 = 753.69 | P 9 = 775.54 | | |
| P 10 = 798.74 | P 11 = 823.06 | P 12 = 846.23 | P 13 = 873.93 | P 14 = 895.82 | | |
| P 15 = 925.53 | P 16 = 950.69 | P 17 = 974.93 | P 18 = 997.90 | P 19 = 1019.3 | | |
| P 20 = 1038.8 | P 21 = 1056.3 | P 22 = 1071.6 | P 23 = 1084.5 | P 24 = 1095.1 | | |
| P 25 = 1103.5 | P 26 = 1109.6 | P 27 = 1113.7 | P 28 = 1116.0 | P 29 = 1116.7 | | |
| P 30 = 1116.0 | P 31 = 1114.1 | P 32 = 1111.4 | P 33 = 1106.1 | P 34 = 1104.3 | | |
| P 35 = 1100.3 | P 36 = 1096.2 | P 37 = 1092.2 | P 38 = 1088.4 | P 39 = 1084.8 | | |
| P 40 = 1081.6 | | | | | | |
| G = 626.18 | G 1 = 632.44 | G 2 = 639.79 | G 3 = 648.33 | G 4 = 658.14 | | |
| G 5 = 669.30 | G 6 = 681.84 | G 7 = 695.78 | G 8 = 711.11 | G 9 = 727.76 | | |
| G 10 = 745.69 | G 11 = 764.72 | G 12 = 784.72 | G 13 = 805.47 | G 14 = 826.76 | | |
| G 15 = 848.34 | G 16 = 865.95 | G 17 = 891.31 | G 18 = 912.17 | G 19 = 932.26 | | |
| G 20 = 951.36 | G 21 = 969.28 | G 22 = 985.83 | G 23 = 1000.9 | G 24 = 1014.4 | | |
| G 25 = 1026.3 | G 26 = 1036.6 | G 27 = 1045.3 | G 28 = 1052.5 | G 29 = 1058.4 | | |
| G 30 = 1062.9 | G 31 = 1066.4 | G 32 = 1068.9 | G 33 = 1070.5 | G 34 = 1071.5 | | |
| G 35 = 1071.9 | G 36 = 1071.9 | G 37 = 1071.6 | G 38 = 1071.1 | G 39 = 1070.4 | | |
| G 40 = 1069.7 | | | | | | |
| H 1 = 607.82 | H 2 = 610.16 | H 3 = 613.04 | H 4 = 616.52 | H 5 = 620.69 | | |
| H 6 = 625.65 | H 7 = 631.47 | H 8 = 638.24 | H 9 = 646.02 | H 10 = 654.89 | | |
| H 11 = 664.87 | H 12 = 676.00 | H 13 = 688.29 | H 14 = 701.71 | H 15 = 716.22 | | |
| H 16 = 731.75 | H 17 = 748.19 | H 18 = 765.42 | H 19 = 783.30 | H 20 = 801.65 | | |
| H 21 = 820.31 | H 22 = 835.08 | H 23 = 857.77 | H 24 = 876.17 | H 25 = 894.17 | | |
| H 26 = 911.52 | H 27 = 928.11 | H 28 = 943.80 | H 29 = 958.50 | H 30 = 972.13 | | |
| H 31 = 984.63 | H 32 = 995.99 | H 33 = 1006.2 | H 34 = 1015.3 | H 35 = 1023.3 | | |
| H 36 = 1030.3 | H 37 = 1036.3 | H 38 = 1041.5 | H 39 = 1045.8 | H 40 = 1049.5 | | |
| H 40 = -0 | | | | | | |



PANEL TEMPERATURE DISTRIBUTION

CASE 4

SET 1 Subpanel 1

Solar Flux Distribution: OFF NORMAL

Orifices: None

Sodium Temperatures: T (Na-Inlet) = 610°F
 T (Na-Outlet) = 1100°F maximum
 (652.2 to 1100F)

5370F/sjh

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

Location x/L: 0.15

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 1 LOC=-15 T:IN=610F T:OUT=732.33 G/A=0.26058 Mb/M2
A21=11.144 A22=37.165 A23=48.773 A24=37.628 A25=19.045

4

| ITER NC. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 732.33 | DT: AA = 122.33 | T:B NA = 671.16 | T:B M = 677.83 | | | | |
| DT M-N = 11.144 | DT1 = 37.165 | DT P-N = 48.773 | DT P-M = 37.628 | DT2 = 19.045 | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | |
| N = 610.00 | N 1 = 610.76 | N 2 = 611.69 | N 3 = 612.80 | N 4 = 614.11 | | | | |
| N 5 = 615.65 | N 6 = 617.43 | N 7 = 619.49 | N 8 = 621.83 | N 9 = 624.47 | | | | |
| N 10 = 627.42 | N 11 = 630.67 | N 12 = 634.24 | N 13 = 638.09 | N 14 = 642.23 | | | | |
| N 15 = 646.63 | N 16 = 651.25 | N 17 = 656.05 | N 18 = 661.01 | N 19 = 666.06 | | | | |
| N 20 = 671.17 | N 21 = 676.27 | N 22 = 681.32 | N 23 = 686.28 | N 24 = 691.08 | | | | |
| N 25 = 695.70 | N 26 = 700.10 | N 27 = 704.24 | N 28 = 708.09 | N 29 = 711.66 | | | | |
| N 30 = 714.91 | N 31 = 717.86 | N 32 = 720.50 | N 33 = 722.84 | N 34 = 724.90 | | | | |
| N 35 = 726.68 | N 36 = 726.22 | N 37 = 725.53 | N 38 = 730.64 | N 39 = 731.57 | | | | |
| N 40 = 732.33 | = .0 | = .0 | = .0 | = .0 | | | | |
| M = 611.51 | M 1 = 612.60 | M 2 = 613.89 | M 3 = 615.42 | M 4 = 617.21 | | | | |
| M 5 = 619.26 | M 6 = 621.62 | M 7 = 624.28 | M 8 = 627.26 | M 9 = 630.56 | | | | |
| M 10 = 634.18 | M 11 = 636.11 | M 12 = 642.33 | M 13 = 646.82 | M 14 = 651.54 | | | | |
| M 15 = 656.46 | M 16 = 661.53 | M 17 = 666.71 | M 18 = 671.93 | M 19 = 677.15 | | | | |
| M 20 = 682.31 | M 21 = 687.36 | M 22 = 692.25 | M 23 = 696.93 | M 24 = 701.37 | | | | |
| M 25 = 705.54 | M 26 = 705.41 | M 27 = 712.96 | M 28 = 716.19 | M 29 = 719.09 | | | | |
| M 30 = 721.67 | M 31 = 723.94 | M 32 = 725.92 | M 33 = 727.63 | M 34 = 729.08 | | | | |
| M 35 = 730.30 | M 36 = 731.32 | M 37 = 732.16 | M 38 = 732.85 | M 39 = 733.40 | | | | |
| M 40 = 733.84 | = .0 | = .0 | = .0 | = .0 | | | | |
| P = 616.60 | P 1 = 618.79 | P 2 = 621.34 | P 3 = 624.29 | P 4 = 627.67 | | | | |
| P 5 = 631.48 | P 6 = 635.74 | P 7 = 640.44 | P 8 = 645.57 | P 9 = 651.10 | | | | |
| P 10 = 657.00 | P 11 = 663.20 | P 12 = 669.65 | P 13 = 676.27 | P 14 = 682.97 | | | | |
| P 15 = 689.67 | P 16 = 696.27 | P 17 = 702.68 | P 18 = 708.81 | P 19 = 714.59 | | | | |
| P 20 = 719.94 | P 21 = 724.80 | P 22 = 729.13 | P 23 = 732.90 | P 24 = 736.11 | | | | |
| P 25 = 738.74 | P 26 = 740.84 | P 27 = 742.41 | P 28 = 743.51 | P 29 = 744.19 | | | | |
| P 30 = 744.49 | P 31 = 744.49 | P 32 = 744.24 | P 33 = 743.79 | P 34 = 743.20 | | | | |
| P 35 = 742.52 | P 36 = 741.78 | P 37 = 741.03 | P 38 = 740.29 | P 39 = 739.59 | | | | |
| P 40 = 738.93 | = .0 | = .0 | = .0 | = .0 | | | | |
| G = 614.02 | G 1 = 615.65 | G 2 = 617.57 | G 3 = 619.80 | G 4 = 622.37 | | | | |
| G 5 = 625.30 | G 6 = 628.59 | G 7 = 632.26 | G 8 = 636.30 | G 9 = 640.70 | | | | |
| G 10 = 645.45 | G 11 = 650.50 | G 12 = 655.82 | G 13 = 661.36 | G 14 = 667.06 | | | | |
| G 15 = 672.86 | G 16 = 678.69 | G 17 = 684.47 | G 18 = 690.14 | G 19 = 695.64 | | | | |
| G 20 = 700.89 | G 21 = 705.85 | G 22 = 710.46 | G 23 = 714.69 | G 24 = 718.52 | | | | |
| G 25 = 721.94 | G 26 = 724.93 | G 27 = 727.50 | G 28 = 729.68 | G 29 = 731.48 | | | | |
| G 30 = 732.94 | G 31 = 734.09 | G 32 = 734.97 | G 33 = 735.61 | G 34 = 736.05 | | | | |
| G 35 = 736.33 | G 36 = 736.49 | G 37 = 736.54 | G 38 = 736.52 | G 39 = 736.45 | | | | |
| G 40 = 736.35 | = .0 | = .0 | = .0 | = .0 | | | | |
| H 1 = 609.54 | H 2 = 610.22 | H 3 = 611.04 | H 4 = 612.04 | H 5 = 613.23 | | | | |
| H 6 = 614.64 | H 7 = 616.29 | H 8 = 618.21 | H 9 = 620.41 | H 10 = 622.91 | | | | |
| H 11 = 625.71 | H 12 = 626.83 | H 13 = 632.27 | H 14 = 636.02 | H 15 = 640.06 | | | | |
| H 16 = 644.38 | H 17 = 646.94 | H 18 = 653.72 | H 19 = 658.66 | H 20 = 663.73 | | | | |
| H 21 = 668.87 | H 22 = 674.03 | H 23 = 679.17 | H 24 = 684.22 | H 25 = 689.14 | | | | |
| H 26 = 693.88 | H 27 = 698.41 | H 28 = 702.69 | H 29 = 706.69 | H 30 = 710.40 | | | | |
| H 31 = 713.80 | H 32 = 716.88 | H 33 = 719.64 | H 34 = 722.10 | H 35 = 724.27 | | | | |
| H 36 = 726.15 | H 37 = 727.78 | H 38 = 729.17 | H 39 = 730.34 | H 40 = 731.32 | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

Location x/L: 0.25

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PNL 1 LOC=25 T:IN=610F T:OUT=783.19 Q/A=0.36891 MM/M2
 A21=14.812 A22=49.443 A23=65.834 A24=51.022 A25=26.300

4

ITER NO. 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 CRITICAL NODE = 2

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|-----------|----------|--|--------|----------|--------|-------------------|--------|---------|--------|
| T:NA IN = | 610.00 | T:NA OUT= | 783.19 | DT: NA = | 173.19 | T:B NA = | 696.59 | T:B M = | 705.45 |
| DT M-N = | 14.812 | DT1 = | 49.443 | DT P-N = | 65.834 | DT P-M = | 51.022 | DT2 = | 26.300 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| N | = 610.00 | N 1 = | 611.08 | N 2 = | 612.39 | N 3 = | 613.96 | N 4 = | 615.82 |
| N 5 = | 617.99 | N 6 = | 620.52 | N 7 = | 623.44 | N 8 = | 626.75 | N 9 = | 630.49 |
| N 10 = | 634.66 | N 11 = | 635.27 | N 12 = | 644.31 | N 13 = | 649.78 | N 14 = | 655.63 |
| N 15 = | 661.85 | N 16 = | 668.39 | N 17 = | 675.20 | N 18 = | 682.21 | N 19 = | 689.37 |
| N 20 = | 696.59 | N 21 = | 703.82 | N 22 = | 710.98 | N 23 = | 717.99 | N 24 = | 724.80 |
| N 25 = | 731.33 | N 26 = | 737.56 | N 27 = | 743.41 | N 28 = | 748.88 | N 29 = | 753.92 |
| N 30 = | 758.53 | N 31 = | 762.70 | N 32 = | 766.44 | N 33 = | 769.75 | N 34 = | 772.66 |
| N 35 = | 775.20 | N 36 = | 777.37 | N 37 = | 779.23 | N 38 = | 780.80 | N 39 = | 782.11 |
| N 40 = | 783.19 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| M | = 612.00 | M 1 = | 613.52 | M 2 = | 615.32 | M 3 = | 617.45 | M 4 = | 619.93 |
| M 5 = | 622.80 | M 6 = | 626.08 | M 7 = | 629.80 | M 8 = | 633.96 | M 9 = | 638.58 |
| M 10 = | 643.04 | M 11 = | 645.15 | M 12 = | 655.07 | M 13 = | 661.37 | M 14 = | 668.01 |
| M 15 = | 674.93 | M 16 = | 682.07 | M 17 = | 689.36 | M 18 = | 696.73 | M 19 = | 704.11 |
| M 20 = | 711.41 | M 21 = | 718.56 | M 22 = | 725.49 | M 23 = | 732.15 | M 24 = | 738.47 |
| M 25 = | 744.41 | M 26 = | 749.93 | M 27 = | 755.01 | M 28 = | 759.63 | M 29 = | 763.80 |
| M 30 = | 767.51 | M 31 = | 770.79 | M 32 = | 773.65 | M 33 = | 776.12 | M 34 = | 778.22 |
| M 35 = | 780.00 | M 36 = | 781.45 | M 37 = | 782.72 | M 38 = | 783.73 | M 39 = | 784.54 |
| M 40 = | 785.19 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| P | = 618.91 | P 1 = | 621.91 | P 2 = | 625.42 | P 3 = | 629.48 | P 4 = | 634.12 |
| P 5 = | 639.37 | P 6 = | 645.23 | P 7 = | 651.72 | P 8 = | 658.80 | P 9 = | 666.44 |
| P 10 = | 674.59 | P 11 = | 683.18 | P 12 = | 692.12 | P 13 = | 701.30 | P 14 = | 710.62 |
| P 15 = | 719.95 | P 16 = | 725.17 | P 17 = | 738.14 | P 18 = | 746.74 | P 19 = | 754.87 |
| P 20 = | 762.43 | P 21 = | 765.33 | P 22 = | 775.51 | P 23 = | 780.93 | P 24 = | 785.57 |
| P 25 = | 784.43 | P 26 = | 792.54 | P 27 = | 794.94 | P 28 = | 796.68 | P 29 = | 797.83 |
| P 30 = | 798.46 | P 31 = | 798.65 | P 32 = | 798.48 | P 33 = | 798.03 | P 34 = | 797.37 |
| P 35 = | 796.57 | P 36 = | 795.68 | P 37 = | 794.75 | P 38 = | 793.83 | P 39 = | 792.94 |
| P 40 = | 792.10 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| G | = 615.35 | G 1 = | 617.58 | G 2 = | 620.21 | G 3 = | 623.28 | G 4 = | 626.81 |

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| G 5 = | 630.83 | G 6 = | 635.36 | G 7 = | 640.42 | G 8 = | 645.99 | G 9 = | 652.08 |
| G 10 = | 658.64 | G 11 = | 665.64 | G 12 = | 673.02 | G 13 = | 680.72 | G 14 = | 688.65 |
| G 15 = | 696.74 | G 16 = | 704.89 | G 17 = | 712.99 | G 18 = | 720.96 | G 19 = | 728.70 |
| G 20 = | 736.13 | G 21 = | 743.16 | G 22 = | 749.73 | G 23 = | 755.78 | G 24 = | 761.29 |
| G 25 = | 766.22 | G 26 = | 770.58 | G 27 = | 774.36 | G 28 = | 777.58 | G 29 = | 780.29 |
| G 30 = | 782.51 | G 31 = | 784.29 | G 32 = | 785.68 | G 33 = | 786.74 | G 34 = | 787.50 |
| G 35 = | 788.03 | G 36 = | 788.37 | G 37 = | 788.55 | G 38 = | 788.62 | G 39 = | 788.61 |
| G 40 = | 788.54 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| H 1 = | 609.45 | H 2 = | 610.43 | H 3 = | 611.62 | H 4 = | 613.06 | H 5 = | 614.78 |
| H 6 = | 616.81 | H 7 = | 619.18 | H 8 = | 621.93 | H 9 = | 625.08 | H 10 = | 628.65 |
| H 11 = | 632.66 | H 12 = | 637.12 | H 13 = | 642.02 | H 14 = | 647.36 | H 15 = | 653.11 |
| H 16 = | 659.25 | H 17 = | 665.73 | H 18 = | 672.50 | H 19 = | 679.51 | H 20 = | 686.69 |
| H 21 = | 693.96 | H 22 = | 701.26 | H 23 = | 708.52 | H 24 = | 715.65 | H 25 = | 722.59 |
| H 26 = | 729.28 | H 27 = | 735.66 | H 28 = | 741.68 | H 29 = | 747.31 | H 30 = | 752.52 |
| H 31 = | 757.29 | H 32 = | 761.62 | H 33 = | 765.50 | H 34 = | 768.95 | H 35 = | 771.98 |
| H 36 = | 774.62 | H 37 = | 776.90 | H 38 = | 778.84 | H 39 = | 780.48 | H 40 = | 781.85 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

PNL 1 LOC=.35 T:IN=610F T:OUT=832.02 Q/A=0.47292 MW/M2

A21=18.333 A22=61.232 A23=82.215 A24=63.883 A25=33.264

Location x/L: 0.35

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

4

| ITER NO. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|--|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 832.02 | DT: NA = 222.02 | T:B NA = 721.01 | T:B M = 731.97 | | | | |
| DT M-N = 18.333 | DT1 = 61.232 | DT P-N = 82.215 | DT P-M = 63.883 | DT2 = 33.266 | | | | |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 | | | | |
| N 5 = 610.00 | N 1 = 611.39 | N 2 = 613.07 | N 3 = 615.07 | N 4 = 617.45 | | | | |
| N 10 = 620.25 | N 6 = 623.49 | N 7 = 627.22 | N 8 = 631.47 | N 9 = 636.26 | | | | |
| N 15 = 641.61 | N 11 = 647.52 | N 12 = 653.99 | N 13 = 660.99 | N 14 = 668.50 | | | | |
| N 20 = 676.48 | N 16 = 684.86 | N 17 = 693.58 | N 18 = 702.57 | N 19 = 711.75 | | | | |
| N 25 = 721.01 | N 21 = 730.27 | N 22 = 739.45 | N 23 = 748.44 | N 24 = 757.16 | | | | |
| N 30 = 765.54 | N 26 = 773.52 | N 27 = 781.03 | N 28 = 788.03 | N 29 = 794.50 | | | | |
| N 35 = 800.41 | N 31 = 805.76 | N 32 = 810.55 | N 33 = 814.80 | N 34 = 818.53 | | | | |
| N 40 = 821.77 | N 36 = 824.57 | N 37 = 826.95 | N 38 = 828.95 | N 39 = 830.63 | | | | |
| M = .0 | M = .0 | M = .0 | M = .0 | M = .0 | | | | |
| M 5 = 612.48 | M 1 = 614.40 | M 2 = 616.69 | M 3 = 619.40 | M 4 = 622.55 | | | | |
| M 10 = 626.20 | M 6 = 630.37 | M 7 = 635.10 | M 8 = 640.40 | M 9 = 646.28 | | | | |
| M 15 = 652.73 | M 11 = 655.75 | M 12 = 667.30 | M 13 = 675.34 | M 14 = 683.81 | | | | |
| M 20 = 692.65 | M 16 = 701.78 | M 17 = 711.11 | M 18 = 720.54 | M 19 = 729.99 | | | | |
| M 25 = 739.34 | M 21 = 748.52 | M 22 = 757.42 | M 23 = 765.96 | M 24 = 774.08 | | | | |
| M 30 = 781.72 | M 26 = 788.83 | M 27 = 795.38 | M 28 = 801.35 | M 29 = 806.73 | | | | |
| M 35 = 811.53 | M 31 = 815.77 | M 32 = 819.47 | M 33 = 822.67 | M 34 = 825.41 | | | | |
| M 40 = 827.72 | M 36 = 825.66 | M 37 = 831.27 | M 38 = 832.58 | M 39 = 833.65 | | | | |
| P = .0 | P = .0 | P = .0 | P = .0 | P = .0 | | | | |
| P 5 = 621.13 | P 1 = 624.91 | P 2 = 629.34 | P 3 = 634.46 | P 4 = 640.31 | | | | |
| P 10 = 646.94 | P 6 = 654.35 | P 7 = 662.54 | P 8 = 671.49 | P 9 = 681.16 | | | | |
| P 15 = 691.48 | P 11 = 702.36 | P 12 = 713.69 | P 13 = 725.34 | P 14 = 737.17 | | | | |
| P 20 = 749.03 | P 16 = 760.75 | P 17 = 772.18 | P 18 = 783.16 | P 19 = 793.55 | | | | |
| P 25 = 803.22 | P 21 = 812.08 | P 22 = 820.03 | P 23 = 827.03 | P 24 = 833.06 | | | | |
| P 30 = 838.10 | P 26 = 842.15 | P 27 = 845.38 | P 28 = 847.73 | P 29 = 849.33 | | | | |
| P 35 = 850.27 | P 31 = 850.65 | P 32 = 850.56 | P 33 = 850.11 | P 34 = 849.38 | | | | |
| P 40 = 848.46 | P 36 = 847.42 | P 37 = 846.33 | P 38 = 845.22 | P 39 = 844.15 | | | | |
| G = .0 | G = .0 | G = .0 | G = .0 | G = .0 | | | | |
| G 5 = 616.62 | G 1 = 615.44 | G 2 = 622.75 | G 3 = 626.61 | G 4 = 631.06 | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 636.14 | G 6 = 641.86 | G 7 = 648.25 | G 8 = 655.30 | G 9 = 662.99 |
| G 10 = 671.30 | G 11 = 680.17 | G 12 = 689.53 | G 13 = 699.30 | G 14 = 709.39 |
| G 15 = 719.67 | G 16 = 730.04 | G 17 = 740.38 | G 18 = 750.55 | G 19 = 760.45 |
| G 20 = 769.96 | G 21 = 778.98 | G 22 = 787.43 | G 23 = 795.23 | G 24 = 802.35 |
| G 25 = 808.74 | G 26 = 814.40 | G 27 = 819.34 | G 28 = 823.58 | G 29 = 827.15 |
| G 30 = 830.10 | G 31 = 832.48 | G 32 = 834.37 | G 33 = 835.82 | G 34 = 836.90 |
| G 35 = 837.66 | G 36 = 838.17 | G 37 = 838.48 | G 38 = 838.64 | G 39 = 838.68 |
| G 40 = 838.64 | | | | |
| H 1 = 609.37 | H 2 = 610.63 | H 3 = 612.18 | H 4 = 614.04 | H 5 = 616.26 |
| H 6 = 618.88 | H 7 = 621.95 | H 8 = 625.49 | H 9 = 629.56 | H 10 = 634.16 |
| H 11 = 639.33 | H 12 = 645.07 | H 13 = 651.38 | H 14 = 658.24 | H 15 = 665.64 |
| H 16 = 673.52 | H 17 = 681.84 | H 18 = 690.53 | H 19 = 699.52 | H 20 = 708.73 |
| H 21 = 718.05 | H 22 = 727.41 | H 23 = 736.69 | H 24 = 745.82 | H 25 = 754.70 |
| H 26 = 763.26 | H 27 = 771.42 | H 28 = 779.11 | H 29 = 786.31 | H 30 = 792.96 |
| H 31 = 799.05 | H 32 = 804.57 | H 33 = 809.52 | H 34 = 813.92 | H 35 = 817.78 |
| H 36 = 821.15 | H 37 = 824.05 | H 38 = 826.52 | H 39 = 828.61 | H 40 = 830.36 |
| | | | | |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

Location x/L: 0.45

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 1 LOC=.45 T:IN=610F T:OUT=878.82 Q/A=0.57262 MW/M2
A21=21.708 A22=72.531 A23=97.916 A24=76.209 A25=39.943

A

| ITER NG. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 878.82 | DT: NA = 268.82 | T:B NA = 744.41 | T:B M = 757.39 | | | | |
| DT M-N = 21.708 | DT1 = 72.531 | DT P-N = 97.916 | DT P-M = 76.209 | DT2 = 39.943 | | | | |
| N = .0 | N = .0 | N = .0 | N = .0 | N = .0 | | | | |
| N 5 = 610.00 | N 1 = 611.68 | N 2 = 613.71 | N 3 = 616.14 | N 4 = 619.03 | | | | |
| N 10 = 622.41 | N 6 = 626.34 | N 7 = 630.85 | N 8 = 636.00 | N 9 = 641.80 | | | | |
| N 15 = 648.28 | N 11 = 655.43 | N 12 = 663.26 | N 13 = 671.74 | N 14 = 680.83 | | | | |
| N 20 = 690.49 | N 16 = 700.64 | N 17 = 711.20 | N 18 = 722.09 | N 19 = 733.19 | | | | |
| N 25 = 744.41 | N 21 = 755.63 | N 22 = 766.73 | N 23 = 777.62 | N 24 = 788.18 | | | | |
| N 30 = 798.33 | N 26 = 807.99 | N 27 = 817.08 | N 28 = 825.56 | N 29 = 833.39 | | | | |
| N 35 = 840.54 | N 31 = 847.02 | N 32 = 852.82 | N 33 = 857.96 | N 34 = 862.48 | | | | |
| N 40 = 866.41 | N 36 = 865.79 | N 37 = 872.68 | N 38 = 875.11 | N 39 = 877.14 | | | | |
| M = .0 | M = .0 | M = .0 | M = .0 | M = .0 | | | | |
| M 5 = 612.94 | M 1 = 615.25 | M 2 = 618.01 | M 3 = 621.26 | M 4 = 625.06 | | | | |
| M 10 = 629.46 | M 6 = 634.48 | M 7 = 640.18 | M 8 = 646.57 | M 9 = 653.66 | | | | |
| M 15 = 661.44 | M 11 = 669.91 | M 12 = 679.02 | M 13 = 688.73 | M 14 = 698.96 | | | | |
| M 20 = 709.64 | M 16 = 720.68 | M 17 = 731.95 | M 18 = 743.37 | M 19 = 754.79 | | | | |
| M 25 = 766.12 | M 21 = 777.23 | M 22 = 788.01 | M 23 = 798.37 | M 24 = 808.22 | | | | |
| M 30 = 817.49 | M 26 = 826.12 | M 27 = 834.07 | M 28 = 841.32 | M 29 = 847.87 | | | | |
| M 35 = 853.71 | M 31 = 858.87 | M 32 = 863.39 | M 33 = 867.29 | M 34 = 870.63 | | | | |
| M 40 = 873.46 | M 36 = 875.83 | M 37 = 877.79 | M 38 = 879.40 | M 39 = 880.71 | | | | |
| P = .0 | P = .0 | P = .0 | P = .0 | P = .0 | | | | |
| P 5 = 623.25 | P 1 = 627.78 | P 2 = 633.09 | P 3 = 639.23 | P 4 = 646.25 | | | | |
| P 10 = 654.20 | P 6 = 663.09 | P 7 = 672.92 | P 8 = 683.66 | P 9 = 695.27 | | | | |
| P 15 = 707.66 | P 11 = 720.74 | P 12 = 734.36 | P 13 = 748.38 | P 14 = 762.62 | | | | |
| P 20 = 776.90 | P 16 = 791.03 | P 17 = 804.81 | P 18 = 818.06 | P 19 = 830.62 | | | | |
| P 25 = 842.33 | P 21 = 853.05 | P 22 = 862.71 | P 23 = 871.22 | P 24 = 878.57 | | | | |
| P 30 = 884.74 | P 26 = 889.77 | P 27 = 893.72 | P 28 = 896.66 | P 29 = 898.70 | | | | |
| P 35 = 899.93 | P 31 = 900.49 | P 32 = 900.48 | P 33 = 900.03 | P 34 = 899.23 | | | | |
| P 40 = 898.20 | P 36 = 897.02 | P 37 = 895.76 | P 38 = 894.49 | P 39 = 893.24 | | | | |
| G = .0 | G = .0 | G = .0 | G = .0 | G = .0 | | | | |
| G 5 = 617.85 | G 1 = 621.22 | G 2 = 625.18 | G 3 = 629.81 | G 4 = 635.14 | | | | |
| G 5 = 641.23 | G 6 = 648.09 | G 7 = 655.76 | G 8 = 664.22 | G 9 = 673.46 | | | | |
| G 10 = 683.44 | G 11 = 694.10 | G 12 = 705.36 | G 13 = 717.11 | G 14 = 729.25 | | | | |
| G 15 = 741.65 | G 16 = 754.15 | G 17 = 766.62 | G 18 = 778.91 | G 19 = 790.88 | | | | |
| G 20 = 802.38 | G 21 = 813.31 | G 22 = 823.56 | G 23 = 833.04 | G 24 = 841.70 | | | | |
| G 25 = 849.49 | G 26 = 856.41 | G 27 = 862.46 | G 28 = 867.66 | G 29 = 872.06 | | | | |
| G 30 = 875.71 | G 31 = 878.68 | G 32 = 881.04 | G 33 = 882.87 | G 34 = 884.24 | | | | |
| G 35 = 885.23 | G 36 = 885.91 | G 37 = 886.34 | G 38 = 886.58 | G 39 = 886.67 | | | | |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 | | | | |
| H 1 = 609.29 | H 2 = 610.83 | H 3 = 612.71 | H 4 = 614.98 | H 5 = 617.68 | | | | |
| H 6 = 620.87 | H 7 = 624.60 | H 8 = 628.91 | H 9 = 633.85 | H 10 = 639.45 | | | | |
| H 11 = 645.72 | H 12 = 652.69 | H 13 = 660.34 | H 14 = 668.67 | H 15 = 677.64 | | | | |
| H 16 = 687.20 | H 17 = 697.28 | H 18 = 707.82 | H 19 = 718.71 | H 20 = 729.85 | | | | |
| H 21 = 741.14 | H 22 = 752.46 | H 23 = 763.70 | H 24 = 774.74 | H 25 = 785.49 | | | | |
| H 26 = 795.83 | H 27 = 805.69 | H 28 = 814.99 | H 29 = 823.68 | H 30 = 831.71 | | | | |
| H 31 = 839.07 | H 32 = 845.73 | H 33 = 851.71 | H 34 = 857.02 | H 35 = 861.69 | | | | |
| H 36 = 865.75 | H 37 = 865.24 | H 38 = 872.23 | H 39 = 874.75 | H 40 = 876.85 | | | | |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

Location x/L: 0.65

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 1 LOC=.65 T:IN=610F T:OUT=966.35 Q/A=0.75905 MW/M2
A21=28.019 A22=93.661 A23=127.28 A24=95.259 A25=52.430

4

| ITER NO. | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | |
|------------------|------------------|---|-----------------|----------------|--|-------------------|--|
| T:NA IN = 610.00 | T:NA CUT= 966.35 | DT: NA = 356.35 | T:B NA = 788.17 | T:B M = 804.93 | | | |
| DT M-N = 28.019 | DT1 = 93.661 | DT P-N = 127.28 | DT P-M = 99.259 | DT2 = 52.430 | | | |
| N = .0 | N 1 = 612.23 | N 2 = 614.92 | N 3 = 618.14 | N 4 = 621.97 | | | |
| N 5 = 626.45 | N 6 = 631.66 | N 7 = 637.65 | N 8 = 644.47 | N 9 = 652.16 | | | |
| N 10 = 660.74 | N 11 = 670.22 | N 12 = 680.60 | N 13 = 691.84 | N 14 = 703.90 | | | |
| N 15 = 716.70 | N 16 = 730.15 | N 17 = 744.15 | N 18 = 758.58 | N 19 = 773.31 | | | |
| N 20 = 788.18 | N 21 = 803.04 | N 22 = 817.77 | N 23 = 832.20 | N 24 = 846.20 | | | |
| N 25 = 859.65 | N 26 = 872.45 | N 27 = 884.51 | N 28 = 895.75 | N 29 = 906.13 | | | |
| N 30 = 915.61 | N 31 = 924.19 | N 32 = 931.88 | N 33 = 938.70 | N 34 = 944.69 | | | |
| N 35 = 949.90 | N 36 = 954.38 | N 37 = 958.21 | N 38 = 961.43 | N 39 = 964.12 | | | |
| N 40 = 966.35 | N = .0 | N = .0 | N = .0 | N = .0 | | | |
| M = 613.79 | M 1 = 616.84 | M 2 = 620.47 | M 3 = 624.75 | M 4 = 629.76 | | | |
| M 5 = 635.54 | M 6 = 642.17 | M 7 = 649.68 | M 8 = 658.10 | M 9 = 667.46 | | | |
| M 10 = 677.73 | M 11 = 686.91 | M 12 = 700.95 | M 13 = 713.77 | M 14 = 727.30 | | | |
| M 15 = 741.42 | M 16 = 756.01 | M 17 = 770.94 | M 18 = 786.05 | M 19 = 801.19 | | | |
| M 20 = 816.19 | M 21 = 830.92 | M 22 = 845.23 | M 23 = 858.98 | M 24 = 872.06 | | | |
| M 25 = 884.38 | M 26 = 895.86 | M 27 = 906.44 | M 28 = 916.10 | M 29 = 924.81 | | | |
| M 30 = 932.61 | M 31 = 935.49 | M 32 = 945.52 | M 33 = 950.74 | M 34 = 955.21 | | | |
| M 35 = 959.00 | M 36 = 962.18 | M 37 = 964.81 | M 38 = 966.97 | M 39 = 968.73 | | | |
| M 40 = 970.14 | M = .0 | M = .0 | M = .0 | M = .0 | | | |
| P = 627.23 | P 1 = 633.16 | P 2 = 640.11 | P 3 = 648.15 | P 4 = 657.35 | | | |
| P 5 = 667.77 | P 6 = 675.43 | P 7 = 692.32 | P 8 = 706.42 | P 9 = 721.66 | | | |
| P 10 = 737.94 | P 11 = 755.12 | P 12 = 773.02 | P 13 = 791.46 | P 14 = 810.21 | | | |
| P 15 = 829.02 | P 16 = 847.64 | P 17 = 865.83 | P 18 = 883.34 | P 19 = 899.95 | | | |
| P 20 = 915.45 | P 21 = 925.69 | P 22 = 942.53 | P 23 = 953.87 | P 24 = 963.69 | | | |
| P 25 = 971.98 | P 26 = 978.77 | P 27 = 984.13 | P 28 = 988.17 | P 29 = 991.02 | | | |
| P 30 = 992.81 | P 31 = 993.70 | P 32 = 993.84 | P 33 = 993.38 | P 34 = 992.46 | | | |
| P 35 = 991.22 | P 36 = 985.77 | P 37 = 988.21 | P 38 = 986.62 | P 39 = 985.06 | | | |
| P 40 = 983.58 | P = .0 | P = .0 | P = .0 | P = .0 | | | |
| G = 620.13 | G 1 = 624.54 | G 2 = 629.73 | G 3 = 635.79 | G 4 = 642.78 | | | |
| G 5 = 650.75 | G 6 = 655.75 | G 7 = 669.80 | G 8 = 680.90 | G 9 = 693.03 | | | |
| G 10 = 706.14 | G 11 = 720.15 | G 12 = 734.95 | G 13 = 750.43 | G 14 = 766.41 | | | |
| G 15 = 782.75 | G 16 = 799.24 | G 17 = 815.71 | G 18 = 831.95 | G 19 = 847.78 | | | |
| G 20 = 863.02 | G 21 = 877.52 | G 22 = 891.13 | G 23 = 903.75 | G 24 = 915.29 | | | |
| G 25 = 925.71 | G 26 = 934.97 | G 27 = 943.05 | G 28 = 950.10 | G 29 = 956.05 | | | |
| G 30 = 961.01 | G 31 = 965.07 | G 32 = 968.32 | G 33 = 970.86 | G 34 = 972.79 | | | |
| G 35 = 974.20 | G 36 = 975.20 | G 37 = 975.85 | G 38 = 976.24 | G 39 = 976.43 | | | |
| G 40 = 976.48 | G = .0 | G = .0 | G = .0 | G = .0 | | | |
| H 1 = 609.13 | H 2 = 611.20 | H 3 = 613.71 | H 4 = 616.73 | H 5 = 620.34 | | | |
| H 6 = 624.60 | H 7 = 625.56 | H 8 = 635.31 | H 9 = 641.88 | H 10 = 649.33 | | | |
| H 11 = 657.68 | H 12 = 666.94 | H 13 = 677.12 | H 14 = 688.18 | H 15 = 700.09 | | | |
| H 16 = 712.78 | H 17 = 726.17 | H 18 = 740.15 | H 19 = 754.59 | H 20 = 769.36 | | | |
| H 21 = 784.33 | H 22 = 799.33 | H 23 = 814.21 | H 24 = 828.83 | H 25 = 843.05 | | | |
| H 26 = 856.74 | H 27 = 865.79 | H 28 = 882.09 | H 29 = 893.58 | H 30 = 904.20 | | | |
| H 31 = 913.92 | H 32 = 922.73 | H 33 = 930.62 | H 34 = 937.63 | H 35 = 943.79 | | | |
| H 36 = 949.15 | H 37 = 953.77 | H 38 = 957.71 | H 39 = 961.03 | H 40 = 963.80 | | | |
| H = .0 | H = .0 | H = .0 | H = .0 | H = .0 | | | |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

Location x/L: 0.75

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PNL 1 LOC=.75 T:IN=610F T:OUT=1007.07 Q/A=0.84579 Mw/M2
 A21=30.955 A22=103.49 A23=140.94 A24=105.98 A25=58.239

4

| ITER NG. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA CUT= 1007.1 | DT: NA = 397.07 | T:B NA = 808.53 | T:B M = 827.05 | | | | | |
| DT M-N = 30.955 | DT1 = 103.49 | DT P-N = 140.94 | DT P-M = 109.98 | DT2 = 58.239 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| N 5 = 610.00 | N 1 = 612.48 | N 2 = 615.48 | N 3 = 619.07 | N 4 = 623.33 | | | | | |
| N 10 = 628.33 | N 6 = 634.13 | N 7 = 640.80 | N 8 = 648.40 | N 9 = 656.97 | | | | | |
| N 15 = 666.54 | N 11 = 677.10 | N 12 = 688.67 | N 13 = 701.19 | N 14 = 714.62 | | | | | |
| N 20 = 728.89 | N 16 = 743.88 | N 17 = 755.48 | N 18 = 775.56 | N 19 = 791.97 | | | | | |
| N 25 = 808.53 | N 21 = 825.10 | N 22 = 841.51 | N 23 = 857.59 | N 24 = 873.19 | | | | | |
| N 30 = 888.18 | N 26 = 902.45 | N 27 = 915.88 | N 28 = 928.40 | N 29 = 939.97 | | | | | |
| N 35 = 950.53 | N 31 = 960.10 | N 32 = 968.67 | N 33 = 976.27 | N 34 = 982.94 | | | | | |
| N 40 = 988.74 | N 36 = 993.74 | N 37 = 997.99 | N 38 = 1001.6 | N 39 = 1004.6 | | | | | |
| = 1007.1 | = .0 | = .0 | = .0 | = .0 | | | | | |
| M 5 = 614.19 | M 1 = 617.57 | M 2 = 621.61 | M 3 = 626.37 | M 4 = 631.94 | | | | | |
| M 10 = 638.38 | M 6 = 645.75 | M 7 = 654.10 | M 8 = 663.47 | M 9 = 673.88 | | | | | |
| M 15 = 685.31 | M 11 = 697.75 | M 12 = 711.15 | M 13 = 725.42 | M 14 = 740.48 | | | | | |
| M 20 = 756.20 | M 16 = 772.45 | M 17 = 789.08 | M 18 = 805.91 | M 19 = 822.77 | | | | | |
| M 25 = 839.49 | M 21 = 855.90 | M 22 = 871.85 | M 23 = 887.18 | M 24 = 901.77 | | | | | |
| M 30 = 915.50 | M 26 = 928.30 | M 27 = 940.11 | M 28 = 950.88 | M 29 = 960.61 | | | | | |
| M 35 = 969.31 | M 31 = 977.00 | M 32 = 983.73 | M 33 = 989.56 | M 34 = 994.56 | | | | | |
| M 40 = 998.79 | M 36 = 1002.3 | M 37 = 1005.3 | M 38 = 1007.7 | M 39 = 1009.7 | | | | | |
| = 1011.3 | = .0 | = .0 | = .0 | = .0 | | | | | |
| P 5 = 629.07 | P 1 = 635.66 | P 2 = 643.37 | P 3 = 652.30 | P 4 = 662.52 | | | | | |
| P 10 = 674.08 | P 6 = 687.03 | P 7 = 701.35 | P 8 = 717.01 | P 9 = 733.94 | | | | | |
| P 15 = 752.02 | P 11 = 771.11 | P 12 = 791.01 | P 13 = 811.51 | P 14 = 832.35 | | | | | |
| P 20 = 853.27 | P 16 = 873.98 | P 17 = 894.22 | P 18 = 913.71 | P 19 = 932.20 | | | | | |
| P 25 = 949.47 | P 21 = 965.34 | P 22 = 979.66 | P 23 = 992.32 | P 24 = 1003.3 | | | | | |
| P 30 = 1012.6 | P 26 = 1020.2 | P 27 = 1026.2 | P 28 = 1030.7 | P 29 = 1034.0 | | | | | |
| P 35 = 1036.0 | P 31 = 1037.1 | P 32 = 1037.3 | P 33 = 1036.8 | P 34 = 1035.8 | | | | | |
| P 40 = 1034.5 | P 36 = 1032.9 | P 37 = 1031.2 | P 38 = 1029.5 | P 39 = 1027.8 | | | | | |
| = 1026.1 | = .0 | = .0 | = .0 | = .0 | | | | | |
| G 5 = 621.19 | G 1 = 626.08 | G 2 = 631.85 | G 3 = 638.57 | G 4 = 646.33 | | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 655.18 | G 6 = 665.17 | G 7 = 676.33 | G 8 = 688.66 | G 9 = 702.13 |
| G 10 = 716.70 | G 11 = 732.26 | G 12 = 748.72 | G 13 = 765.92 | G 14 = 783.70 |
| G 15 = 801.87 | G 16 = 820.22 | G 17 = 838.54 | G 18 = 856.63 | G 19 = 874.25 |
| G 20 = 891.23 | G 21 = 907.39 | G 22 = 922.57 | G 23 = 936.65 | G 24 = 949.53 |
| G 25 = 961.17 | G 26 = 971.52 | G 27 = 980.61 | G 28 = 988.45 | G 29 = 995.12 |
| G 30 = 1000.7 | G 31 = 1005.3 | G 32 = 1008.9 | G 33 = 1011.8 | G 34 = 1014.0 |
| G 35 = 1015.6 | G 36 = 1016.7 | G 37 = 1017.5 | G 38 = 1018.0 | G 39 = 1018.2 |
| G 40 = 1018.3 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 609.06 | H 2 = 611.37 | H 3 = 614.17 | H 4 = 617.55 | H 5 = 621.58 |
| H 6 = 626.33 | H 7 = 631.87 | H 8 = 638.28 | H 9 = 645.62 | H 10 = 653.93 |
| H 11 = 663.24 | H 12 = 673.57 | H 13 = 684.92 | H 14 = 697.26 | H 15 = 710.54 |
| H 16 = 724.69 | H 17 = 735.61 | H 18 = 755.18 | H 19 = 771.28 | H 20 = 787.74 |
| H 21 = 804.42 | H 22 = 821.13 | H 23 = 837.71 | H 24 = 854.00 | H 25 = 869.84 |
| H 26 = 885.08 | H 27 = 895.60 | H 28 = 913.31 | H 29 = 926.10 | H 30 = 937.92 |
| H 31 = 948.74 | H 32 = 958.55 | H 33 = 967.33 | H 34 = 975.14 | H 35 = 981.99 |
| H 36 = 987.96 | H 37 = 993.09 | H 38 = 997.47 | H 39 = 1001.2 | H 40 = 1004.3 |
| = .0 | = .0 | = .0 | = .0 | = .0 |

CASE # 4

Solar Flux: OFF-NORMAL
Orifices: NO

PNL 1 LOC=.85 T:IN=610F T:OUT=1045.76 G/A=0.92821 MW/M2
A21=33.745 A22=112.83 A23=153.92 A24=120.17 A25=63.759

Sub-Panel: 1
Location x/L: 0.85
T(Na-inlet) = 610 F
T(Na-outlet) :

Max = 1100F

| ITEM NO. | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION | | CRITICAL POINT | | | | | |
|-----------|--------|--|--------|----------------|--------|----------|--------|---------|--------|
| T:NA IN = | 610.00 | T:NA OUT = | 1045.8 | DT: NA = | 435.76 | T:B NA = | 827.88 | T:B M = | 848.06 |
| DT M-N = | 33.745 | DT1 = | 112.83 | DT P-N = | 153.92 | DT P-M = | 120.17 | DT2 = | 63.759 |
| N = | 610.00 | N 1 = | 612.72 | N 2 = | 616.02 | N 3 = | 619.96 | N 4 = | 624.63 |
| N 5 = | 630.11 | N 6 = | 636.48 | N 7 = | 643.81 | N 8 = | 652.15 | N 9 = | 661.55 |
| N 10 = | 672.05 | N 11 = | 683.64 | N 12 = | 696.33 | N 13 = | 710.08 | N 14 = | 724.82 |
| N 15 = | 740.47 | N 16 = | 756.92 | N 17 = | 774.05 | N 18 = | 791.70 | N 19 = | 809.70 |
| N 20 = | 827.88 | N 21 = | 846.06 | N 22 = | 864.06 | N 23 = | 881.71 | N 24 = | 898.84 |
| N 25 = | 915.29 | N 26 = | 930.94 | N 27 = | 945.68 | N 28 = | 959.43 | N 29 = | 972.12 |
| N 30 = | 983.71 | N 31 = | 994.21 | N 32 = | 1003.6 | N 33 = | 1012.0 | N 34 = | 1019.3 |
| N 35 = | 1025.6 | N 36 = | 1031.1 | N 37 = | 1035.8 | N 38 = | 1039.7 | N 39 = | 1043.0 |
| N 40 = | 1045.8 | | .0 | | .0 | | .0 | | .0 |
| M = | 614.57 | M 1 = | 618.27 | M 2 = | 622.69 | M 3 = | 627.91 | M 4 = | 634.01 |
| M 5 = | 641.07 | M 6 = | 649.15 | M 7 = | 658.30 | M 8 = | 668.57 | M 9 = | 679.98 |
| M 10 = | 692.51 | M 11 = | 706.15 | M 12 = | 720.84 | M 13 = | 736.49 | M 14 = | 753.01 |
| M 15 = | 770.25 | M 16 = | 788.07 | M 17 = | 806.31 | M 18 = | 824.77 | M 19 = | 843.27 |
| M 20 = | 861.62 | M 21 = | 879.64 | M 22 = | 897.14 | M 23 = | 913.97 | M 24 = | 929.99 |
| M 25 = | 945.07 | M 26 = | 959.13 | M 27 = | 972.09 | M 28 = | 983.93 | M 29 = | 994.62 |
| M 30 = | 1004.2 | M 31 = | 1012.6 | M 32 = | 1020.0 | M 33 = | 1026.4 | M 34 = | 1031.9 |
| M 35 = | 1036.6 | M 36 = | 1040.5 | M 37 = | 1043.8 | M 38 = | 1046.4 | M 39 = | 1048.6 |
| M 40 = | 1050.3 | | .0 | | .0 | | .0 | | .0 |
| P = | 630.83 | P 1 = | 638.04 | P 2 = | 646.48 | P 3 = | 656.25 | P 4 = | 667.43 |
| P 5 = | 680.08 | P 6 = | 694.25 | P 7 = | 709.92 | P 8 = | 727.07 | P 9 = | 745.60 |
| P 10 = | 765.40 | P 11 = | 786.30 | P 12 = | 808.10 | P 13 = | 830.55 | P 14 = | 853.38 |
| P 15 = | 876.30 | P 16 = | 895.01 | P 17 = | 921.20 | P 18 = | 942.57 | P 19 = | 962.85 |
| P 20 = | 981.80 | P 21 = | 999.21 | P 22 = | 1014.9 | P 23 = | 1028.9 | P 24 = | 1040.9 |
| P 25 = | 1051.1 | P 26 = | 1059.5 | P 27 = | 1066.2 | P 28 = | 1071.2 | P 29 = | 1074.8 |
| P 30 = | 1077.1 | P 31 = | 1078.3 | P 32 = | 1078.5 | P 33 = | 1078.1 | P 34 = | 1077.0 |
| P 35 = | 1075.6 | P 36 = | 1073.9 | P 37 = | 1072.1 | P 38 = | 1070.2 | P 39 = | 1068.4 |
| P 40 = | 1066.6 | | .0 | | .0 | | .0 | | .0 |
| G = | 622.20 | G 1 = | 627.55 | G 2 = | 633.86 | G 3 = | 641.21 | G 4 = | 649.70 |
| G 5 = | 659.38 | G 6 = | 670.32 | G 7 = | 682.53 | G 8 = | 696.03 | G 9 = | 710.78 |
| G 10 = | 726.73 | G 11 = | 743.78 | G 12 = | 761.80 | G 13 = | 780.65 | G 14 = | 800.13 |
| G 15 = | 820.04 | G 16 = | 840.15 | G 17 = | 860.24 | G 18 = | 880.07 | G 19 = | 899.41 |
| G 20 = | 918.04 | G 21 = | 935.77 | G 22 = | 952.44 | G 23 = | 967.90 | G 24 = | 982.06 |
| G 25 = | 994.85 | G 26 = | 1006.2 | G 27 = | 1016.3 | G 28 = | 1024.9 | G 29 = | 1032.3 |
| G 30 = | 1038.4 | G 31 = | 1043.4 | G 32 = | 1047.5 | G 33 = | 1050.7 | G 34 = | 1053.1 |
| G 35 = | 1054.9 | G 36 = | 1056.2 | G 37 = | 1057.1 | G 38 = | 1057.6 | G 39 = | 1057.9 |
| G 40 = | 1058.0 | | .0 | | .0 | | .0 | | .0 |
| H 1 = | 609.00 | H 2 = | 611.53 | H 3 = | 614.61 | H 4 = | 618.33 | H 5 = | 622.75 |
| H 6 = | 627.97 | H 7 = | 634.07 | H 8 = | 641.11 | H 9 = | 649.17 | H 10 = | 658.29 |
| H 11 = | 668.52 | H 12 = | 675.87 | H 13 = | 682.33 | H 14 = | 705.88 | H 15 = | 720.46 |
| H 16 = | 736.00 | H 17 = | 752.38 | H 18 = | 769.47 | H 19 = | 787.14 | H 20 = | 805.21 |
| H 21 = | 823.51 | H 22 = | 841.84 | H 23 = | 860.04 | H 24 = | 877.91 | H 25 = | 895.28 |
| H 26 = | 912.00 | H 27 = | 927.94 | H 28 = | 942.96 | H 29 = | 957.00 | H 30 = | 969.96 |
| H 31 = | 981.83 | H 32 = | 992.58 | H 33 = | 1002.2 | H 34 = | 1010.8 | H 35 = | 1018.3 |
| H 36 = | 1024.8 | H 37 = | 1030.5 | H 38 = | 1035.3 | H 39 = | 1039.3 | H 40 = | 1042.7 |
| | .0 | | .0 | | .0 | | .0 | | .0 |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

PNL 1 LOC=.95 T:IN=610F T:OUT=1082.43 Q/A=1.00631 Mh/M2
A21=36.199 A22=121.06 A23=165.55 A24=129.35 A25=68.832

Location x/L: 0.95

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

A

| ITER NG. | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|----------|----------|---|----------|--------|----------|-------------------|----------|-------|----------|
| T:NA IN | = 610.00 | T:NA OUT | = 1082.4 | DT: NA | = 472.43 | T:B NA | = 846.21 | T:B M | = 867.87 |
| DT M-N | = 36.199 | DT1 | = 121.06 | DT P-N | = 165.55 | DT P-M | = 129.35 | DT2 | = 68.832 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| N | = 610.00 | N 1 | = 612.95 | N 2 | = 616.52 | N 3 | = 620.80 | N 4 | = 625.86 |
| N 5 | = 631.81 | N 6 | = 638.71 | N 7 | = 646.65 | N 8 | = 655.69 | N 9 | = 665.89 |
| N 10 | = 677.27 | N 11 | = 685.84 | N 12 | = 703.60 | N 13 | = 718.50 | N 14 | = 734.48 |
| N 15 | = 751.45 | N 16 | = 765.29 | N 17 | = 787.85 | N 18 | = 806.99 | N 19 | = 826.50 |
| N 20 | = 846.21 | N 21 | = 865.93 | N 22 | = 885.44 | N 23 | = 904.57 | N 24 | = 923.14 |
| N 25 | = 940.98 | N 26 | = 957.95 | N 27 | = 973.93 | N 28 | = 988.83 | N 29 | = 1002.6 |
| N 30 | = 1015.2 | N 31 | = 1026.5 | N 32 | = 1036.7 | N 33 | = 1045.8 | N 34 | = 1053.7 |
| N 35 | = 1060.6 | N 36 | = 1066.6 | N 37 | = 1071.6 | N 38 | = 1075.9 | N 39 | = 1079.5 |
| N 40 | = 1082.4 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| M | = 614.90 | M 1 | = 618.91 | M 2 | = 623.65 | M 3 | = 629.33 | M 4 | = 635.93 |
| M 5 | = 643.56 | M 6 | = 652.30 | M 7 | = 662.20 | M 8 | = 673.31 | M 9 | = 685.66 |
| M 10 | = 699.22 | M 11 | = 713.98 | M 12 | = 729.88 | M 13 | = 746.83 | M 14 | = 764.72 |
| M 15 | = 783.40 | M 16 | = 802.70 | M 17 | = 822.46 | M 18 | = 842.47 | M 19 | = 862.52 |
| M 20 | = 882.41 | M 21 | = 901.95 | M 22 | = 920.93 | M 23 | = 939.18 | M 24 | = 956.56 |
| M 25 | = 972.92 | M 26 | = 988.18 | M 27 | = 1002.3 | M 28 | = 1015.1 | M 29 | = 1026.7 |
| M 30 | = 1037.1 | M 31 | = 1046.3 | M 32 | = 1054.4 | M 33 | = 1061.3 | M 34 | = 1067.3 |
| M 35 | = 1072.4 | M 36 | = 1076.6 | M 37 | = 1080.2 | M 38 | = 1083.1 | M 39 | = 1085.4 |
| M 40 | = 1087.3 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| P | = 632.40 | P 1 | = 640.18 | P 2 | = 649.29 | P 3 | = 659.82 | P 4 | = 671.89 |
| P 5 | = 685.55 | P 6 | = 700.84 | P 7 | = 717.76 | P 8 | = 736.28 | P 9 | = 756.29 |
| P 10 | = 777.68 | P 11 | = 800.26 | P 12 | = 823.81 | P 13 | = 848.08 | P 14 | = 872.76 |
| P 15 | = 897.55 | P 16 | = 922.11 | P 17 | = 946.12 | P 18 | = 969.26 | P 19 | = 991.23 |
| P 20 | = 1011.8 | P 21 | = 1030.7 | P 22 | = 1047.7 | P 23 | = 1062.8 | P 24 | = 1076.0 |
| P 25 | = 1087.1 | P 26 | = 1096.2 | P 27 | = 1103.5 | P 28 | = 1109.0 | P 29 | = 1113.0 |
| P 30 | = 1115.6 | P 31 | = 1116.9 | P 32 | = 1117.2 | P 33 | = 1116.9 | P 34 | = 1115.9 |
| P 35 | = 1114.4 | P 36 | = 1112.6 | P 37 | = 1110.7 | P 38 | = 1108.7 | P 39 | = 1106.7 |
| P 40 | = 1104.8 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| G | = 623.09 | G 1 | = 626.86 | G 2 | = 635.67 | G 3 | = 643.60 | G 4 | = 652.76 |

| | | | | | | | | | |
|------|----------|------|----------|------|----------|------|----------|------|----------|
| G 5 | = 663.21 | G 6 | = 675.01 | G 7 | = 688.20 | G 8 | = 702.78 | G 9 | = 718.71 |
| G 10 | = 735.94 | G 11 | = 754.36 | G 12 | = 773.84 | G 13 | = 794.21 | G 14 | = 815.28 |
| G 15 | = 836.81 | G 16 | = 858.58 | G 17 | = 880.33 | G 18 | = 901.80 | G 19 | = 922.75 |
| G 20 | = 942.94 | G 21 | = 962.17 | G 22 | = 980.26 | G 23 | = 997.05 | G 24 | = 1012.4 |
| G 25 | = 1026.3 | G 26 | = 1038.7 | G 27 | = 1049.6 | G 28 | = 1059.1 | G 29 | = 1067.1 |
| G 30 | = 1073.8 | G 31 | = 1079.4 | G 32 | = 1083.8 | G 33 | = 1087.3 | G 34 | = 1090.0 |
| G 35 | = 1092.0 | G 36 | = 1093.5 | G 37 | = 1094.4 | G 38 | = 1095.0 | G 39 | = 1095.4 |
| G 40 | = 1095.5 | | = .0 | | = .0 | | = .0 | | = .0 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| H 1 | = 608.95 | H 2 | = 611.71 | H 3 | = 615.06 | H 4 | = 619.10 | H 5 | = 623.91 |
| H 6 | = 629.58 | H 7 | = 636.20 | H 8 | = 643.85 | H 9 | = 652.60 | H 10 | = 662.51 |
| H 11 | = 673.61 | H 12 | = 685.93 | H 13 | = 699.46 | H 14 | = 714.16 | H 15 | = 729.98 |
| H 16 | = 746.83 | H 17 | = 764.59 | H 18 | = 783.14 | H 19 | = 802.29 | H 20 | = 821.88 |
| H 21 | = 841.72 | H 22 | = 861.60 | H 23 | = 881.31 | H 24 | = 900.68 | H 25 | = 919.51 |
| H 26 | = 937.62 | H 27 | = 954.89 | H 28 | = 971.16 | H 29 | = 986.36 | H 30 | = 1000.4 |
| H 31 | = 1013.3 | H 32 | = 1024.9 | H 33 | = 1035.3 | H 34 | = 1044.6 | H 35 | = 1052.7 |
| H 36 | = 1059.8 | H 37 | = 1065.9 | H 38 | = 1071.1 | H 39 | = 1075.5 | H 40 | = 1079.1 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |



PANEL TEMPERATURE DISTRIBUTION

CASE 4

SET 2 Subpanel 2

Solar Flux Distribution: OFF NORMAL

Orifices: None

Sodium Temperatures: T (Na-Inlet) = 610°F

T (Na-Outlet) = 1100°F maximum
(1002.2 to 1100°F)

5370F/sjh

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: 0.05

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 2 LOC=.05 T:IN=610F T:OUT=1018.49 Q/A=1.08765 MW/M2
A21=38.526 A22=128.87 A23=176.87 A24=138.34 A25=73.525

4

| ITER NO. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1018.5 | DT: MA = 608.49 | T:B MA = 814.24 | T:B M = 837.29 | | | | |
| DT M-N = 38.526 | DT1 = 128.87 | DT P-N = 176.87 | DT P-M = 138.34 | DT2 = 73.925 | | | | |
| N = .0 | N 1 = .0 | N 2 = .0 | N 3 = .0 | N 4 = .0 | | | | |
| N 5 = 610.00 | N 6 = 612.55 | N 7 = 615.64 | N 8 = 619.34 | N 9 = 623.72 | | | | |
| N 10 = 628.85 | N 11 = 634.82 | N 12 = 641.69 | N 13 = 649.51 | N 14 = 658.32 | | | | |
| N 15 = 668.16 | N 16 = 679.03 | N 17 = 690.93 | N 18 = 703.81 | N 19 = 717.63 | | | | |
| N 20 = 732.31 | N 21 = 747.73 | N 22 = 763.78 | N 23 = 780.32 | N 24 = 797.20 | | | | |
| N 25 = 814.24 | N 26 = 831.29 | N 27 = 848.17 | N 28 = 864.71 | N 29 = 880.76 | | | | |
| N 30 = 896.18 | N 31 = 910.86 | N 32 = 924.67 | N 33 = 937.56 | N 34 = 949.46 | | | | |
| N 35 = 960.33 | N 36 = 970.17 | N 37 = 978.98 | N 38 = 986.80 | N 39 = 993.67 | | | | |
| N 40 = 999.64 | N 36 = 1004.8 | N 37 = 1009.2 | N 38 = 1012.8 | N 39 = 1015.9 | | | | |
| M = 1018.5 | M 1 = .0 | M 2 = .0 | M 3 = .0 | M 4 = .0 | | | | |
| M 5 = 615.21 | M 6 = 618.89 | M 7 = 623.26 | M 8 = 628.42 | M 9 = 634.43 | | | | |
| M 10 = 641.36 | M 11 = 645.28 | M 12 = 658.24 | M 13 = 668.26 | M 14 = 679.36 | | | | |
| M 15 = 691.53 | M 16 = 704.73 | M 17 = 718.91 | M 18 = 733.97 | M 19 = 749.81 | | | | |
| M 20 = 766.31 | M 21 = 783.29 | M 22 = 800.61 | M 23 = 818.09 | M 24 = 835.53 | | | | |
| M 25 = 852.77 | M 26 = 865.62 | M 27 = 885.93 | M 28 = 901.54 | M 29 = 916.32 | | | | |
| M 30 = 930.18 | M 31 = 943.04 | M 32 = 954.83 | M 33 = 965.54 | M 34 = 975.15 | | | | |
| M 35 = 983.69 | M 36 = 991.20 | M 37 = 997.73 | M 38 = 1003.3 | M 39 = 1008.1 | | | | |
| M 40 = 1012.1 | M 36 = 1015.5 | M 37 = 1018.2 | M 38 = 1020.5 | M 39 = 1022.3 | | | | |
| P = 1023.7 | P 1 = .0 | P 2 = .0 | P 3 = .0 | P 4 = .0 | | | | |
| P 5 = 633.94 | P 6 = 641.64 | P 7 = 650.64 | P 8 = 661.03 | P 9 = 672.89 | | | | |
| P 10 = 680.28 | P 11 = 701.21 | P 12 = 717.67 | P 13 = 735.60 | P 14 = 754.91 | | | | |
| P 15 = 775.44 | P 16 = 797.00 | P 17 = 819.36 | P 18 = 842.25 | P 19 = 865.37 | | | | |
| P 20 = 888.39 | P 21 = 911.00 | P 22 = 932.87 | P 23 = 953.69 | P 24 = 973.19 | | | | |
| P 25 = 991.11 | P 26 = 1007.3 | P 27 = 1021.5 | P 28 = 1033.8 | P 29 = 1044.0 | | | | |
| P 30 = 1052.3 | P 31 = 1058.6 | P 32 = 1063.1 | P 33 = 1066.0 | P 34 = 1067.4 | | | | |
| P 35 = 1067.6 | P 36 = 1066.7 | P 37 = 1065.1 | P 38 = 1062.8 | P 39 = 1060.0 | | | | |
| P 40 = 1057.1 | P 36 = 1054.0 | P 37 = 1050.9 | P 38 = 1047.9 | P 39 = 1045.0 | | | | |
| G = 1042.4 | G 1 = .0 | G 2 = .0 | G 3 = .0 | G 4 = .0 | | | | |
| G 5 = 623.93 | G 6 = 625.45 | G 7 = 636.02 | G 8 = 643.61 | G 9 = 652.34 | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 662.28 | G 6 = 673.47 | G 7 = 685.92 | G 8 = 699.63 | G 9 = 714.55 |
| G 10 = 730.61 | G 11 = 747.71 | G 12 = 765.69 | G 13 = 784.40 | G 14 = 803.63 |
| G 15 = 823.17 | G 16 = 842.77 | G 17 = 862.21 | G 18 = 881.25 | G 19 = 899.65 |
| G 20 = 917.21 | G 21 = 933.74 | G 22 = 945.05 | G 23 = 963.14 | G 24 = 975.80 |
| G 25 = 987.05 | G 26 = 994.86 | G 27 = 1005.3 | G 28 = 1012.3 | G 29 = 1018.1 |
| G 30 = 1022.8 | G 31 = 1026.4 | G 32 = 1029.1 | G 33 = 1031.0 | G 34 = 1032.3 |
| G 35 = 1033.1 | G 36 = 1033.4 | G 37 = 1033.4 | G 38 = 1033.2 | G 39 = 1032.9 |
| G 40 = 1032.4 | G 36 = .0 | G 37 = .0 | G 38 = .0 | G 39 = .0 |
| H 1 = 608.29 | H 2 = 610.51 | H 3 = 613.23 | H 4 = 616.51 | H 5 = 620.44 |
| H 6 = 625.10 | H 7 = 630.56 | H 8 = 636.90 | H 9 = 644.18 | H 10 = 652.45 |
| H 11 = 661.75 | H 12 = 672.12 | H 13 = 683.54 | H 14 = 695.99 | H 15 = 709.44 |
| H 16 = 723.81 | H 17 = 735.01 | H 18 = 754.93 | H 19 = 771.42 | H 20 = 788.34 |
| H 21 = 805.51 | H 22 = 822.77 | H 23 = 839.94 | H 24 = 856.84 | H 25 = 873.32 |
| H 26 = 889.21 | H 27 = 904.40 | H 28 = 918.75 | H 29 = 932.17 | H 30 = 944.61 |
| H 31 = 950.02 | H 32 = 966.37 | H 33 = 975.67 | H 34 = 983.94 | H 35 = 991.22 |
| H 36 = 997.57 | H 37 = 1003.0 | H 38 = 1007.7 | H 39 = 1011.7 | H 40 = 1015.0 |
| H 40 = .0 | H 37 = .0 | H 38 = .0 | H 39 = .0 | H 40 = .0 |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: 0.15

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 2 LOC=.15 T:IN=610F T:OUT=1047.01 C/A=1.16359 MW/M2
A21=40.698 A22=136.16 A23=187.43 A24=146.74 A25=78.680

4

| ITER NG. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|-----------|-------------|--|-------------|----------|-------------|-------------------|-------------|---------|-------------|
| T:NA IN = | 610.00 | T:NA OUT= | 1047.0 | DT: NA = | 437.01 | T:B NA = | 828.50 | T:B M = | 852.85 |
| DT M-N = | 40.698 | DT1 = | 136.16 | DT P-N = | 187.43 | DT P-M = | 146.74 | DT2 = | 78.68C |
| | = -0 | | = -0 | | = -0 | | = -0 | | = -0 |
| N | 1 = 610.00 | N | 1 = 612.73 | N | 2 = 616.03 | N | 3 = 619.99 | N | 4 = 624.67 |
| N | 5 = 630.17 | N | 6 = 636.56 | N | 7 = 643.90 | N | 8 = 652.27 | N | 9 = 661.70 |
| N | 10 = 672.22 | N | 11 = 683.85 | N | 12 = 696.58 | N | 13 = 710.36 | N | 14 = 725.15 |
| N | 15 = 740.85 | N | 16 = 757.35 | N | 17 = 774.52 | N | 18 = 792.22 | N | 19 = 810.27 |
| N | 20 = 828.50 | N | 21 = 846.74 | N | 22 = 864.79 | N | 23 = 882.49 | N | 24 = 899.66 |
| N | 25 = 916.16 | N | 26 = 931.86 | N | 27 = 946.64 | N | 28 = 960.43 | N | 29 = 973.16 |
| N | 30 = 984.79 | N | 31 = 995.31 | N | 32 = 1004.7 | N | 33 = 1013.1 | N | 34 = 1020.5 |
| N | 35 = 1026.8 | N | 36 = 1032.3 | N | 37 = 1037.0 | N | 38 = 1041.0 | N | 39 = 1044.3 |
| N | 40 = 1047.0 | | = -0 | | = -0 | | = -0 | | = -0 |
| M | 1 = 615.51 | M | 1 = 615.43 | M | 2 = 624.09 | M | 3 = 629.58 | M | 4 = 635.99 |
| M | 5 = 643.38 | M | 6 = 651.83 | M | 7 = 661.39 | M | 8 = 672.08 | M | 9 = 683.92 |
| M | 10 = 696.91 | M | 11 = 711.00 | M | 12 = 726.13 | M | 13 = 742.22 | M | 14 = 759.14 |
| M | 15 = 776.76 | M | 16 = 794.92 | M | 17 = 813.43 | M | 18 = 832.11 | M | 19 = 850.77 |
| M | 20 = 869.20 | M | 21 = 887.23 | M | 22 = 904.69 | M | 23 = 921.40 | M | 24 = 937.23 |
| M | 25 = 952.08 | M | 26 = 965.85 | M | 27 = 978.50 | M | 28 = 989.98 | M | 29 = 1000.3 |
| M | 30 = 1009.5 | M | 31 = 1017.5 | M | 32 = 1024.6 | M | 33 = 1030.6 | M | 34 = 1035.7 |
| M | 35 = 1040.1 | M | 36 = 1043.7 | M | 37 = 1046.6 | M | 38 = 1049.0 | M | 39 = 1051.0 |
| M | 40 = 1052.5 | | = -0 | | = -0 | | = -0 | | = -0 |
| P | 1 = 635.37 | P | 1 = 643.56 | P | 2 = 653.13 | P | 3 = 664.17 | P | 4 = 676.79 |
| P | 5 = 691.02 | P | 6 = 706.90 | P | 7 = 724.41 | P | 8 = 743.50 | P | 9 = 764.05 |
| P | 10 = 785.91 | P | 11 = 806.87 | P | 12 = 832.68 | P | 13 = 857.07 | P | 14 = 881.70 |
| P | 15 = 906.25 | P | 16 = 930.37 | P | 17 = 953.70 | P | 18 = 975.94 | P | 19 = 996.77 |
| P | 20 = 1015.9 | P | 21 = 1033.2 | P | 22 = 1048.5 | P | 23 = 1061.7 | P | 24 = 1072.7 |
| P | 25 = 1081.6 | P | 26 = 1088.4 | P | 27 = 1093.3 | P | 28 = 1096.5 | P | 29 = 1098.2 |
| P | 30 = 1098.5 | P | 31 = 1097.7 | P | 32 = 1096.0 | P | 33 = 1093.6 | P | 34 = 1090.8 |
| P | 35 = 1087.7 | P | 36 = 1084.4 | P | 37 = 1081.2 | P | 38 = 1078.1 | P | 39 = 1075.1 |
| P | 40 = 1072.4 | | = -0 | | = -0 | | = -0 | | = -0 |
| G | 1 = 624.72 | G | 1 = 630.62 | G | 2 = 637.56 | G | 3 = 645.63 | G | 4 = 654.92 |

| | | | | | | | | | |
|---|-------------|---|-------------|---|-------------|---|-------------|---|-------------|
| G | 5 = 665.49 | G | 6 = 677.38 | G | 7 = 690.63 | G | 8 = 705.22 | G | 9 = 721.10 |
| G | 10 = 738.20 | G | 11 = 756.41 | G | 12 = 775.57 | G | 13 = 795.51 | G | 14 = 816.01 |
| G | 15 = 836.84 | G | 16 = 857.76 | G | 17 = 878.51 | G | 18 = 898.84 | G | 19 = 918.51 |
| G | 20 = 937.28 | G | 21 = 954.97 | G | 22 = 971.42 | G | 23 = 986.48 | G | 24 = 1000.1 |
| G | 25 = 1012.2 | G | 26 = 1022.7 | G | 27 = 1031.8 | G | 28 = 1039.4 | G | 29 = 1045.7 |
| G | 30 = 1050.8 | G | 31 = 1054.7 | G | 32 = 1057.7 | G | 33 = 1059.8 | G | 34 = 1061.3 |
| G | 35 = 1062.2 | G | 36 = 1062.6 | G | 37 = 1062.7 | G | 38 = 1062.5 | G | 39 = 1062.2 |
| G | 40 = 1061.7 | | = -0 | | = -0 | | = -0 | | = -0 |
| H | 1 = 608.23 | H | 2 = 610.61 | H | 3 = 613.53 | H | 4 = 617.06 | H | 5 = 621.28 |
| H | 6 = 626.28 | H | 7 = 632.14 | H | 8 = 638.94 | H | 9 = 646.74 | H | 10 = 655.61 |
| H | 11 = 665.59 | H | 12 = 676.70 | H | 13 = 688.93 | H | 14 = 702.28 | H | 15 = 716.68 |
| H | 16 = 732.07 | H | 17 = 748.34 | H | 18 = 765.38 | H | 19 = 783.02 | H | 20 = 801.12 |
| H | 21 = 819.49 | H | 22 = 837.95 | H | 23 = 856.31 | H | 24 = 874.39 | H | 25 = 892.00 |
| H | 26 = 908.99 | H | 27 = 925.21 | H | 28 = 940.55 | H | 29 = 954.89 | H | 30 = 968.18 |
| H | 31 = 980.36 | H | 32 = 991.41 | H | 33 = 1001.3 | H | 34 = 1010.2 | H | 35 = 1017.9 |
| H | 36 = 1024.7 | H | 37 = 1030.6 | H | 38 = 1035.6 | H | 39 = 1039.8 | H | 40 = 1043.3 |
| | = -0 | | = -0 | | = -0 | | = -0 | | = -0 |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: 0.25

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 2 LOC=.25 T:IN=610F T:OUT=1065.59 Q/A=1.22369 Mw/M2
A21=42.418 A22=141.94 A23=195.80 A24=153.38 A25=82.444

A

| ITER NG. | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|---|-----------------|-----------------|----------------|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1069.6 | DT: NA = 459.59 | T:B NA = 839.79 | T:B M = 865.17 | | | | |
| DT M-N = 42.418 | DTI = 141.94 | DT P-N = 195.80 | DT P-M = 153.38 | DT2 = 82.444 | | | | |
| N = 0 | N = -0 | N = -0 | N = -0 | N = -0 | | | | |
| N 5 = 610.00 | N 1 = 612.87 | N 2 = 616.35 | N 3 = 620.50 | N 4 = 625.43 | | | | |
| N 10 = 631.21 | N 6 = 637.93 | N 7 = 645.65 | N 8 = 654.45 | N 9 = 664.37 | | | | |
| N 15 = 675.44 | N 11 = 687.67 | N 12 = 701.05 | N 13 = 715.55 | N 14 = 731.10 | | | | |
| N 20 = 747.61 | N 16 = 764.96 | N 17 = 783.02 | N 18 = 801.63 | N 19 = 820.62 | | | | |
| N 25 = 839.79 | N 21 = 858.97 | N 22 = 877.96 | N 23 = 896.57 | N 24 = 914.63 | | | | |
| N 30 = 931.98 | N 26 = 948.49 | N 27 = 964.04 | N 28 = 978.54 | N 29 = 991.92 | | | | |
| N 35 = 1004.2 | N 31 = 1015.2 | N 32 = 1025.1 | N 33 = 1033.9 | N 34 = 1041.7 | | | | |
| N 40 = 1048.4 | N 36 = 1054.2 | N 37 = 1059.1 | N 38 = 1063.2 | N 39 = 1066.7 | | | | |
| M = 0 | M = -0 | M = -0 | M = -0 | M = -0 | | | | |
| M 5 = 615.74 | M 1 = 619.85 | M 2 = 624.74 | M 3 = 630.50 | M 4 = 637.23 | | | | |
| M 10 = 644.98 | M 6 = 653.85 | M 7 = 663.88 | M 8 = 675.10 | M 9 = 687.53 | | | | |
| M 15 = 701.17 | M 11 = 715.96 | M 12 = 731.86 | M 13 = 748.75 | M 14 = 766.53 | | | | |
| M 20 = 785.04 | M 16 = 804.12 | M 17 = 823.57 | M 18 = 843.21 | M 19 = 862.82 | | | | |
| M 25 = 882.21 | M 21 = 901.18 | M 22 = 919.54 | M 23 = 937.12 | M 24 = 953.79 | | | | |
| M 30 = 969.42 | M 26 = 983.92 | M 27 = 997.24 | M 28 = 1009.3 | M 29 = 1020.2 | | | | |
| M 35 = 1029.9 | M 31 = 1038.4 | M 32 = 1045.8 | M 33 = 1052.2 | M 34 = 1057.6 | | | | |
| M 40 = 1062.1 | M 36 = 1066.0 | M 37 = 1069.1 | M 38 = 1071.6 | M 39 = 1073.7 | | | | |
| P = 0 | P = -0 | P = -0 | P = -0 | P = -0 | | | | |
| P 5 = 636.50 | P 1 = 645.08 | P 2 = 655.09 | P 3 = 666.66 | P 4 = 679.87 | | | | |
| P 10 = 694.78 | P 6 = 711.42 | P 7 = 729.76 | P 8 = 749.76 | P 9 = 771.29 | | | | |
| P 15 = 794.20 | P 11 = 818.26 | P 12 = 843.23 | P 13 = 868.80 | P 14 = 894.64 | | | | |
| P 20 = 920.40 | P 16 = 945.71 | P 17 = 970.20 | P 18 = 993.55 | P 19 = 1015.4 | | | | |
| P 25 = 1035.6 | P 21 = 1053.8 | P 22 = 1069.9 | P 23 = 1083.8 | P 24 = 1095.4 | | | | |
| P 30 = 1104.8 | P 26 = 1112.0 | P 27 = 1117.3 | P 28 = 1120.7 | P 29 = 1122.5 | | | | |
| P 35 = 1122.9 | P 31 = 1122.1 | P 32 = 1120.4 | P 33 = 1118.0 | P 34 = 1115.1 | | | | |
| P 40 = 1111.9 | P 36 = 1108.6 | P 37 = 1105.2 | P 38 = 1102.0 | P 39 = 1098.9 | | | | |
| G = 0 | G = -0 | G = -0 | G = -0 | G = -0 | | | | |
| G 5 = 625.34 | G 1 = 631.52 | G 2 = 638.78 | G 3 = 647.23 | G 4 = 656.96 | | | | |
| G 5 = 668.02 | G 6 = 680.49 | G 7 = 694.36 | G 8 = 709.64 | G 9 = 726.29 | | | | |
| G 10 = 744.21 | G 11 = 763.30 | G 12 = 783.39 | G 13 = 804.30 | G 14 = 825.81 | | | | |
| G 15 = 847.67 | G 16 = 869.63 | G 17 = 891.42 | G 18 = 912.77 | G 19 = 933.44 | | | | |
| G 20 = 953.18 | G 21 = 971.79 | G 22 = 989.10 | G 23 = 1005.0 | G 24 = 1019.3 | | | | |
| G 25 = 1032.0 | G 26 = 1043.2 | G 27 = 1052.8 | G 28 = 1060.9 | G 29 = 1067.5 | | | | |
| G 30 = 1072.9 | G 31 = 1077.1 | G 32 = 1080.3 | G 33 = 1082.6 | G 34 = 1084.2 | | | | |
| G 35 = 1085.2 | G 36 = 1085.7 | G 37 = 1085.8 | G 38 = 1085.7 | G 39 = 1085.4 | | | | |
| H = 0 | H = -0 | H = -0 | H = -0 | H = -0 | | | | |
| H 1 = 608.18 | H 2 = 610.70 | H 3 = 613.77 | H 4 = 617.49 | H 5 = 621.94 | | | | |
| H 6 = 627.21 | H 7 = 633.39 | H 8 = 640.55 | H 9 = 648.78 | H 10 = 658.12 | | | | |
| H 11 = 668.63 | H 12 = 680.32 | H 13 = 693.20 | H 14 = 707.25 | H 15 = 722.41 | | | | |
| H 16 = 738.60 | H 17 = 755.72 | H 18 = 773.64 | H 19 = 792.21 | H 20 = 811.24 | | | | |
| H 21 = 830.56 | H 22 = 849.97 | H 23 = 869.27 | H 24 = 888.27 | H 25 = 906.79 | | | | |
| H 26 = 924.64 | H 27 = 941.69 | H 28 = 957.80 | H 29 = 972.88 | H 30 = 986.83 | | | | |
| H 31 = 999.63 | H 32 = 1011.2 | H 33 = 1021.7 | H 34 = 1030.9 | H 35 = 1039.1 | | | | |
| H 36 = 1046.2 | H 37 = 1052.4 | H 38 = 1057.6 | H 39 = 1062.0 | H 40 = 1065.7 | | | | |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: 0.35

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 2 LOC=.35 T:IN=610F T:OUT=1086.21 C/A=1.26796 MW/M2
A21=43.684 A22=146.19 A23=201.96 A24=156.27 A25=85.216

4

| ITER NO. 2. | | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|-------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT = 1086.2 | DT: NA = 476.21 | T:B NA = 848.10 | T:B M = 874.23 | | | | | |
| DT M-N = 43.684 | DT1 = 146.19 | DT P-N = 201.96 | DT P-M = 158.27 | DT2 = 85.216 | | | | | |
| N = .0 | N 1 = .0 | N 2 = .0 | N 3 = .0 | N 4 = .0 | | | | | |
| N 5 = 610.00 | N 6 = 612.98 | N 7 = 616.58 | N 8 = 620.88 | N 9 = 625.99 | | | | | |
| N 10 = 631.98 | N 11 = 636.94 | N 12 = 646.94 | N 13 = 656.06 | N 14 = 666.33 | | | | | |
| N 15 = 677.80 | N 16 = 690.48 | N 17 = 704.35 | N 18 = 719.37 | N 19 = 735.48 | | | | | |
| N 20 = 752.58 | N 21 = 770.56 | N 22 = 789.28 | N 23 = 808.56 | N 24 = 828.23 | | | | | |
| N 25 = 848.10 | N 26 = 867.98 | N 27 = 887.65 | N 28 = 906.93 | N 29 = 925.65 | | | | | |
| N 30 = 943.03 | N 31 = 960.73 | N 32 = 976.84 | N 33 = 991.86 | N 34 = 1005.7 | | | | | |
| N 35 = 1018.4 | N 36 = 1029.9 | N 37 = 1040.2 | N 38 = 1049.3 | N 39 = 1057.3 | | | | | |
| N 40 = 1064.2 | N 36 = 1070.2 | N 37 = 1075.3 | N 38 = 1079.6 | N 39 = 1083.2 | | | | | |
| M = 1086.2 | M 1 = .0 | M 2 = .0 | M 3 = .0 | M 4 = .0 | | | | | |
| M 5 = 615.91 | M 6 = 620.16 | M 7 = 625.22 | M 8 = 631.18 | M 9 = 638.14 | | | | | |
| M 10 = 646.16 | M 11 = 655.34 | M 12 = 665.71 | M 13 = 677.32 | M 14 = 690.19 | | | | | |
| M 15 = 704.30 | M 16 = 719.62 | M 17 = 736.07 | M 18 = 753.56 | M 19 = 771.97 | | | | | |
| M 20 = 791.13 | M 21 = 810.89 | M 22 = 831.04 | M 23 = 851.38 | M 24 = 871.70 | | | | | |
| M 25 = 891.79 | M 26 = 911.44 | M 27 = 930.47 | M 28 = 948.69 | M 29 = 965.97 | | | | | |
| M 30 = 982.18 | M 31 = 997.22 | M 32 = 1011.0 | M 33 = 1023.6 | M 34 = 1034.9 | | | | | |
| M 35 = 1044.9 | M 36 = 1053.7 | M 37 = 1061.4 | M 38 = 1068.0 | M 39 = 1073.7 | | | | | |
| M 40 = 1078.4 | M 36 = 1082.4 | M 37 = 1085.6 | M 38 = 1088.3 | M 39 = 1090.4 | | | | | |
| P = 1092.1 | P 1 = .0 | P 2 = .0 | P 3 = .0 | P 4 = .0 | | | | | |
| P 5 = 637.33 | P 6 = 646.19 | P 7 = 656.54 | P 8 = 668.49 | P 9 = 682.14 | | | | | |
| P 10 = 697.55 | P 11 = 714.74 | P 12 = 733.70 | P 13 = 754.36 | P 14 = 776.62 | | | | | |
| P 15 = 800.30 | P 16 = 825.18 | P 17 = 851.00 | P 18 = 877.44 | P 19 = 904.17 | | | | | |
| P 20 = 930.81 | P 21 = 957.00 | P 22 = 982.35 | P 23 = 1006.5 | P 24 = 1029.2 | | | | | |
| P 25 = 1050.1 | P 26 = 1068.9 | P 27 = 1085.6 | P 28 = 1100.0 | P 29 = 1112.1 | | | | | |
| P 30 = 1121.9 | P 31 = 1129.4 | P 32 = 1134.9 | P 33 = 1138.5 | P 34 = 1140.4 | | | | | |
| P 35 = 1140.9 | P 36 = 1140.2 | P 37 = 1138.5 | P 38 = 1136.0 | P 39 = 1133.1 | | | | | |
| P 40 = 1129.8 | P 36 = 1126.4 | P 37 = 1122.9 | P 38 = 1119.6 | P 39 = 1116.5 | | | | | |
| G = 1113.5 | G 1 = .0 | G 2 = .0 | G 3 = .0 | G 4 = .0 | | | | | |
| G 5 = 625.80 | G 6 = 632.18 | G 7 = 639.69 | G 8 = 648.41 | G 9 = 658.46 | | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 669.89 | G 6 = 682.77 | G 7 = 697.11 | G 8 = 712.90 | G 9 = 730.10 |
| G 10 = 748.63 | G 11 = 768.37 | G 12 = 789.15 | G 13 = 810.77 | G 14 = 833.02 |
| G 15 = 855.64 | G 16 = 878.36 | G 17 = 900.92 | G 18 = 923.03 | G 19 = 944.43 |
| G 20 = 964.88 | G 21 = 984.17 | G 22 = 1002.1 | G 23 = 1018.6 | G 24 = 1033.4 |
| G 25 = 1046.7 | G 26 = 1058.3 | G 27 = 1068.2 | G 28 = 1076.7 | G 29 = 1083.6 |
| G 30 = 1089.2 | G 31 = 1093.6 | G 32 = 1097.0 | G 33 = 1099.4 | G 34 = 1101.1 |
| G 35 = 1102.1 | G 36 = 1102.7 | G 37 = 1102.9 | G 38 = 1102.7 | G 39 = 1102.4 |
| G 40 = 1102.0 | G 36 = .0 | G 37 = .0 | G 38 = .0 | G 39 = .0 |
| H 1 = 608.14 | H 2 = 610.75 | H 3 = 613.95 | H 4 = 617.81 | H 5 = 622.43 |
| H 6 = 627.90 | H 7 = 634.31 | H 8 = 641.74 | H 9 = 650.27 | H 10 = 659.97 |
| H 11 = 670.86 | H 12 = 682.99 | H 13 = 696.35 | H 14 = 710.91 | H 15 = 726.63 |
| H 16 = 743.41 | H 17 = 761.16 | H 18 = 779.73 | H 19 = 798.97 | H 20 = 818.69 |
| H 21 = 838.71 | H 22 = 858.82 | H 23 = 878.82 | H 24 = 898.50 | H 25 = 917.67 |
| H 26 = 936.17 | H 27 = 953.82 | H 28 = 970.51 | H 29 = 986.11 | H 30 = 1000.6 |
| H 31 = 1013.8 | H 32 = 1025.8 | H 33 = 1036.6 | H 34 = 1046.2 | H 35 = 1054.7 |
| H 36 = 1062.0 | H 37 = 1068.4 | H 38 = 1073.8 | H 39 = 1078.4 | H 40 = 1082.2 |
| H 40 = .0 | H 37 = .0 | H 38 = .0 | H 39 = .0 | H 40 = .0 |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: 0.45

T(Na-inlet) = 610 F

T(Na-outlet) :

Max = 1100F

PNL 2 LOC=.45 T:IN=610F T:OUT=1096.89 Q/A=1.29640 MW/M2
A21=44.498 A22=148.92 A23=205.91 A24=161.41 A25=86.996

A

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|-----------|----------|--|--------|----------|--------|-------------------|--------|---------|--------|
| T:NA IN = | 610.00 | T:NA OUT = | 1096.9 | DT: NA = | 486.89 | T:B NA = | 853.44 | T:B M = | 880.06 |
| DT M-N = | 44.498 | DT1 = | 148.92 | DT P-N = | 205.91 | DT P-M = | 161.41 | DT2 = | 86.996 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |
| N | = 610.00 | N 1 = | 613.04 | N 2 = | 616.72 | N 3 = | 621.13 | N 4 = | 626.35 |
| N 5 = | 632.47 | N 6 = | 635.59 | N 7 = | 647.77 | N 8 = | 657.09 | N 9 = | 667.60 |
| N 10 = | 679.33 | N 11 = | 692.28 | N 12 = | 706.46 | N 13 = | 721.82 | N 14 = | 738.29 |
| N 15 = | 755.78 | N 16 = | 774.16 | N 17 = | 793.30 | N 18 = | 813.01 | N 19 = | 833.13 |
| N 20 = | 853.44 | N 21 = | 873.76 | N 22 = | 893.88 | N 23 = | 913.59 | N 24 = | 932.73 |
| N 25 = | 951.11 | N 26 = | 968.60 | N 27 = | 985.07 | N 28 = | 1000.4 | N 29 = | 1014.6 |
| N 30 = | 1027.6 | N 31 = | 1039.3 | N 32 = | 1049.8 | N 33 = | 1059.1 | N 34 = | 1067.3 |
| N 35 = | 1074.4 | N 36 = | 1080.5 | N 37 = | 1085.8 | N 38 = | 1090.2 | N 39 = | 1093.8 |
| N 40 = | 1096.9 | | = .0 | | = .0 | | = .0 | | = .0 |
| M | = 616.02 | M 1 = | 620.36 | M 2 = | 625.53 | M 3 = | 631.62 | M 4 = | 638.72 |
| M 5 = | 646.92 | M 6 = | 656.29 | M 7 = | 666.89 | M 8 = | 678.75 | M 9 = | 691.90 |
| M 10 = | 706.31 | M 11 = | 721.96 | M 12 = | 738.77 | M 13 = | 756.65 | M 14 = | 775.46 |
| M 15 = | 795.05 | M 16 = | 815.24 | M 17 = | 835.84 | M 18 = | 856.63 | M 19 = | 877.40 |
| M 20 = | 897.94 | M 21 = | 918.04 | M 22 = | 937.49 | M 23 = | 956.13 | M 24 = | 973.80 |
| M 25 = | 990.38 | M 26 = | 1005.8 | M 27 = | 1019.9 | M 28 = | 1032.7 | M 29 = | 1044.3 |
| M 30 = | 1054.6 | M 31 = | 1063.6 | M 32 = | 1071.5 | M 33 = | 1078.2 | M 34 = | 1084.0 |
| M 35 = | 1088.9 | M 36 = | 1092.9 | M 37 = | 1096.3 | M 38 = | 1099.0 | M 39 = | 1101.2 |
| M 40 = | 1102.9 | | = .0 | | = .0 | | = .0 | | = .0 |
| P | = 637.87 | P 1 = | 646.91 | P 2 = | 657.47 | P 3 = | 669.67 | P 4 = | 683.60 |
| P 5 = | 699.32 | P 6 = | 716.87 | P 7 = | 736.22 | P 8 = | 757.32 | P 9 = | 780.04 |
| P 10 = | 804.22 | P 11 = | 825.62 | P 12 = | 855.98 | P 13 = | 882.99 | P 14 = | 910.28 |
| P 15 = | 937.49 | P 16 = | 964.24 | P 17 = | 990.15 | P 18 = | 1014.8 | P 19 = | 1038.0 |
| P 20 = | 1059.4 | P 21 = | 1078.6 | P 22 = | 1095.7 | P 23 = | 1110.4 | P 24 = | 1122.8 |
| P 25 = | 1132.8 | P 26 = | 1140.6 | P 27 = | 1146.2 | P 28 = | 1149.9 | P 29 = | 1151.9 |
| P 30 = | 1152.5 | P 31 = | 1151.7 | P 32 = | 1150.0 | P 33 = | 1147.6 | P 34 = | 1144.6 |
| P 35 = | 1141.3 | P 36 = | 1137.8 | P 37 = | 1134.3 | P 38 = | 1130.9 | P 39 = | 1127.7 |
| P 40 = | 1124.8 | | = .0 | | = .0 | | = .0 | | = .0 |
| G | = 626.10 | G 1 = | 632.61 | G 2 = | 640.26 | G 3 = | 649.17 | G 4 = | 659.42 |
| G 5 = | 671.09 | G 6 = | 684.24 | G 7 = | 698.87 | G 8 = | 714.99 | G 9 = | 732.56 |
| G 10 = | 751.48 | G 11 = | 771.63 | G 12 = | 792.84 | G 13 = | 814.93 | G 14 = | 837.65 |
| G 15 = | 860.76 | G 16 = | 883.98 | G 17 = | 907.02 | G 18 = | 929.62 | G 19 = | 951.49 |
| G 20 = | 972.40 | G 21 = | 992.12 | G 22 = | 1010.5 | G 23 = | 1027.3 | G 24 = | 1042.5 |
| G 25 = | 1056.1 | G 26 = | 1068.0 | G 27 = | 1078.2 | G 28 = | 1086.8 | G 29 = | 1093.9 |
| G 30 = | 1099.7 | G 31 = | 1104.3 | G 32 = | 1107.7 | G 33 = | 1110.2 | G 34 = | 1111.9 |
| G 35 = | 1113.0 | G 36 = | 1113.6 | G 37 = | 1113.8 | G 38 = | 1113.7 | G 39 = | 1113.4 |
| G 40 = | 1113.0 | | = .0 | | = .0 | | = .0 | | = .0 |
| H | = 608.12 | H 2 = | 610.79 | H 3 = | 614.06 | H 4 = | 618.02 | H 5 = | 622.75 |
| H 6 = | 628.34 | H 7 = | 634.90 | H 8 = | 642.51 | H 9 = | 651.24 | H 10 = | 661.15 |
| H 11 = | 672.30 | H 12 = | 684.71 | H 13 = | 698.37 | H 14 = | 713.26 | H 15 = | 729.34 |
| H 16 = | 746.51 | H 17 = | 764.65 | H 18 = | 783.65 | H 19 = | 803.32 | H 20 = | 823.48 |
| H 21 = | 843.95 | H 22 = | 864.51 | H 23 = | 884.95 | H 24 = | 905.07 | H 25 = | 924.67 |
| H 26 = | 943.57 | H 27 = | 961.62 | H 28 = | 978.67 | H 29 = | 994.62 | H 30 = | 1009.4 |
| H 31 = | 1022.9 | H 32 = | 1035.2 | H 33 = | 1046.2 | H 34 = | 1056.1 | H 35 = | 1064.7 |
| H 36 = | 1072.2 | H 37 = | 1078.7 | H 38 = | 1084.2 | H 39 = | 1088.9 | H 40 = | 1092.8 |
| | = .0 | | = .0 | | = .0 | | = .0 | | = .0 |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: FULL

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 2 LOC=FULLT:IN=610F T:OUT=1100.0 C/A=1.30468 MW/M2
A21=44.735 A22=149.71 A23=207.06 A24=162.33 A25=87.514

4

| ITER NO. | 2- | GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1100.0 | DT: NA = 490.00 | T:B NA = 855.00 | T:B M = 881.76 | | | | | |
| DT M-N = 44.735 | DT1 = 149.71 | DT F-N = 207.06 | DT P-M = 162.33 | DT2 = 87.514 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| N = 610.00 | N 1 = 613.06 | N 2 = 616.77 | N 3 = 621.20 | N 4 = 626.45 | | | | | |
| N 5 = 632.62 | N 6 = 635.76 | N 7 = 648.01 | N 8 = 657.39 | N 9 = 667.97 | | | | | |
| N 10 = 679.77 | N 11 = 692.81 | N 12 = 707.08 | N 13 = 722.53 | N 14 = 739.11 | | | | | |
| N 15 = 756.71 | N 16 = 775.21 | N 17 = 794.47 | N 18 = 814.31 | N 19 = 834.55 | | | | | |
| N 20 = 855.00 | N 21 = 875.45 | N 22 = 895.69 | N 23 = 915.53 | N 24 = 934.79 | | | | | |
| N 25 = 953.29 | N 26 = 970.89 | N 27 = 987.47 | N 28 = 1002.9 | N 29 = 1017.2 | | | | | |
| N 30 = 1030.2 | N 31 = 1042.0 | N 32 = 1052.6 | N 33 = 1062.0 | N 34 = 1070.2 | | | | | |
| N 35 = 1077.4 | N 36 = 1083.5 | N 37 = 1088.8 | N 38 = 1093.2 | N 39 = 1096.9 | | | | | |
| N 40 = 1100.0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| M = 616.05 | M 1 = 620.42 | M 2 = 625.62 | M 3 = 631.74 | M 4 = 638.89 | | | | | |
| M 5 = 647.14 | M 6 = 656.57 | M 7 = 667.23 | M 8 = 679.17 | M 9 = 692.39 | | | | | |
| M 10 = 706.90 | M 11 = 722.65 | M 12 = 739.56 | M 13 = 757.55 | M 14 = 776.48 | | | | | |
| M 15 = 796.19 | M 16 = 816.51 | M 17 = 837.24 | M 18 = 858.16 | M 19 = 879.07 | | | | | |
| M 20 = 899.73 | M 21 = 915.96 | M 22 = 939.54 | M 23 = 958.30 | M 24 = 976.08 | | | | | |
| M 25 = 992.77 | M 26 = 1008.3 | M 27 = 1022.5 | M 28 = 1035.4 | M 29 = 1047.0 | | | | | |
| M 30 = 1057.4 | M 31 = 1066.5 | M 32 = 1074.4 | M 33 = 1081.2 | M 34 = 1087.0 | | | | | |
| M 35 = 1091.9 | M 36 = 1096.0 | M 37 = 1099.3 | M 38 = 1102.1 | M 39 = 1104.3 | | | | | |
| M 40 = 1106.1 | = .0 | = .0 | = .0 | = .0 | | | | | |
| P = 638.02 | P 1 = 647.12 | P 2 = 657.74 | P 3 = 670.01 | P 4 = 684.02 | | | | | |
| P 5 = 699.84 | P 6 = 717.49 | P 7 = 736.96 | P 8 = 758.18 | P 9 = 781.04 | | | | | |
| P 10 = 805.36 | P 11 = 830.91 | P 12 = 857.43 | P 13 = 884.60 | P 14 = 912.06 | | | | | |
| P 15 = 939.44 | P 16 = 966.35 | P 17 = 992.42 | P 18 = 1017.3 | P 19 = 1040.6 | | | | | |
| P 20 = 1062.1 | P 21 = 1081.5 | P 22 = 1098.6 | P 23 = 1113.5 | P 24 = 1125.9 | | | | | |
| P 25 = 1136.0 | P 26 = 1143.8 | P 27 = 1149.5 | P 28 = 1153.3 | P 29 = 1155.3 | | | | | |
| P 30 = 1155.8 | P 31 = 1155.1 | P 32 = 1153.4 | P 33 = 1150.9 | P 34 = 1147.9 | | | | | |
| P 35 = 1144.6 | P 36 = 1141.1 | P 37 = 1137.6 | P 38 = 1134.2 | P 39 = 1131.0 | | | | | |
| P 40 = 1128.0 | = .0 | = .0 | = .0 | = .0 | | | | | |
| G = 626.18 | G 1 = 632.73 | G 2 = 640.43 | G 3 = 649.39 | G 4 = 659.70 | | | | | |
| G 5 = 671.44 | G 6 = 684.66 | G 7 = 699.38 | G 8 = 715.60 | G 9 = 733.27 | | | | | |
| G 10 = 752.30 | G 11 = 772.57 | G 12 = 793.92 | G 13 = 816.14 | G 14 = 839.00 | | | | | |
| G 15 = 862.25 | G 16 = 885.61 | G 17 = 908.80 | G 18 = 931.53 | G 19 = 953.55 | | | | | |
| G 20 = 974.59 | G 21 = 994.44 | G 22 = 1012.9 | G 23 = 1029.9 | G 24 = 1045.2 | | | | | |
| G 25 = 1058.8 | G 26 = 1070.8 | G 27 = 1081.1 | G 28 = 1089.8 | G 29 = 1097.0 | | | | | |
| G 30 = 1102.8 | G 31 = 1107.3 | G 32 = 1110.8 | G 33 = 1113.4 | G 34 = 1115.1 | | | | | |
| G 35 = 1116.2 | G 36 = 1116.8 | G 37 = 1117.0 | G 38 = 1116.9 | G 39 = 1116.6 | | | | | |
| G 40 = 1116.2 | = .0 | = .0 | = .0 | = .0 | | | | | |
| H 1 = 608.11 | H 2 = 610.80 | H 3 = 614.10 | H 4 = 618.08 | H 5 = 622.84 | | | | | |
| H 6 = 628.47 | H 7 = 635.08 | H 8 = 642.73 | H 9 = 651.52 | H 10 = 661.50 | | | | | |
| H 11 = 672.72 | H 12 = 685.21 | H 13 = 698.96 | H 14 = 713.95 | H 15 = 730.13 | | | | | |
| H 16 = 747.41 | H 17 = 765.67 | H 18 = 784.79 | H 19 = 804.58 | H 20 = 824.88 | | | | | |
| H 21 = 845.48 | H 22 = 866.16 | H 23 = 886.74 | H 24 = 906.98 | H 25 = 926.71 | | | | | |
| H 26 = 945.73 | H 27 = 963.89 | H 28 = 981.05 | H 29 = 997.10 | H 30 = 1012.0 | | | | | |
| H 31 = 1025.6 | H 32 = 1037.9 | H 33 = 1049.0 | H 34 = 1058.9 | H 35 = 1067.6 | | | | | |
| H 36 = 1075.2 | H 37 = 1081.7 | H 38 = 1087.3 | H 39 = 1092.0 | H 40 = 1095.9 | | | | | |
| = .0 | = .0 | = .0 | = .0 | = .0 | | | | | |



PANEL TEMPERATURE DISTRIBUTION

CASE 4

SET 3 Subpanel Boundaries

Solar Flux Distribution: OFF NORMAL

Orifices: None

Sodium Temperatures: T (Na-Inlet) = 610°F

T (Na-Outlet) = 1100°F maximum
(652.2 to 1100F)

5370F/sjh

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 1

PNL 1 LOC=1 T:IN=610 F T:OUT=1100.0 C/A=1.04374 MM/M2
 A21=37.270 A22=124.65 A23=170.76 A24=133.49 A25=71.175

Location x/L: 1.0 (OUT)

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100 F

4

| ITER NO. 2. | | GREATEST TEMPERATURE CHANGE PER ITERATION = -0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|--|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1100.0 | DT: NA = 490.00 | T:8 NA = 855.00 | T:8 M = 877.29 | | | | | |
| DT M-N = 37.270 | DT1 = 124.65 | DT P-N = 170.76 | DT P-M = 133.49 | DT2 = 71.175 | | | | | |
| N = 610.00 | N 1 = 613.06 | N 2 = 616.77 | N 3 = 621.20 | N 4 = 626.45 | | | | | |
| N 5 = 632.62 | N 6 = 635.78 | N 7 = 648.01 | N 8 = 657.39 | N 9 = 667.97 | | | | | |
| N 10 = 679.77 | N 11 = 692.81 | N 12 = 707.08 | N 13 = 722.53 | N 14 = 739.11 | | | | | |
| N 15 = 756.71 | N 16 = 775.21 | N 17 = 794.47 | N 18 = 814.31 | N 19 = 834.55 | | | | | |
| N 20 = 855.00 | N 21 = 875.45 | N 22 = 895.69 | N 23 = 915.53 | N 24 = 934.79 | | | | | |
| N 25 = 953.29 | N 26 = 970.89 | N 27 = 987.47 | N 28 = 1002.9 | N 29 = 1017.2 | | | | | |
| N 30 = 1030.2 | N 31 = 1042.0 | N 32 = 1052.6 | N 33 = 1062.0 | N 34 = 1070.2 | | | | | |
| N 35 = 1077.4 | N 36 = 1083.5 | N 37 = 1088.8 | N 38 = 1093.2 | N 39 = 1096.9 | | | | | |
| N 40 = 1100.0 | N = 0 | N = 0 | N = 0 | N = 0 | | | | | |
| M = 615.04 | M 1 = 619.19 | M 2 = 624.14 | M 3 = 629.98 | M 4 = 636.81 | | | | | |
| M 5 = 644.72 | M 6 = 653.77 | M 7 = 664.02 | M 8 = 675.53 | M 9 = 688.32 | | | | | |
| M 10 = 702.37 | M 11 = 717.67 | M 12 = 734.14 | M 13 = 751.71 | M 14 = 770.24 | | | | | |
| M 15 = 789.60 | M 16 = 805.62 | M 17 = 830.10 | M 18 = 850.84 | M 19 = 871.64 | | | | | |
| M 20 = 892.27 | M 21 = 912.53 | M 22 = 932.22 | M 23 = 951.16 | M 24 = 969.19 | | | | | |
| M 25 = 986.18 | M 26 = 1002.0 | M 27 = 1016.6 | M 28 = 1030.0 | M 29 = 1042.0 | | | | | |
| M 30 = 1052.8 | M 31 = 1062.4 | M 32 = 1070.7 | M 33 = 1078.0 | M 34 = 1084.2 | | | | | |
| M 35 = 1089.5 | M 36 = 1093.9 | M 37 = 1097.6 | M 38 = 1100.6 | M 39 = 1103.1 | | | | | |
| M 40 = 1105.0 | M = 0 | M = 0 | M = 0 | M = 0 | | | | | |
| P = 633.11 | P 1 = 641.15 | P 2 = 650.56 | P 3 = 661.45 | P 4 = 673.93 | | | | | |
| P 5 = 688.05 | P 6 = 703.87 | P 7 = 721.37 | P 8 = 740.51 | P 9 = 761.21 | | | | | |
| P 10 = 783.34 | P 11 = 806.70 | P 12 = 831.08 | P 13 = 856.19 | P 14 = 881.74 | | | | | |
| P 15 = 907.41 | P 16 = 932.84 | P 17 = 957.72 | P 18 = 981.69 | P 19 = 1004.5 | | | | | |
| P 20 = 1025.8 | P 21 = 1045.4 | P 22 = 1063.1 | P 23 = 1078.8 | P 24 = 1092.4 | | | | | |
| P 25 = 1104.0 | P 26 = 1113.5 | P 27 = 1121.1 | P 28 = 1126.9 | P 29 = 1131.1 | | | | | |
| P 30 = 1133.8 | P 31 = 1135.3 | P 32 = 1135.7 | P 33 = 1135.3 | P 34 = 1134.3 | | | | | |
| P 35 = 1132.8 | P 36 = 1131.0 | P 37 = 1129.1 | P 38 = 1127.0 | P 39 = 1125.0 | | | | | |
| P 40 = 1123.1 | P = 0 | P = 0 | P = 0 | P = 0 | | | | | |
| G = 623.48 | G 1 = 625.44 | G 2 = 636.48 | G 3 = 644.68 | G 4 = 654.14 | | | | | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 664.95 | G 6 = 677.16 | G 7 = 690.80 | G 8 = 705.87 | G 9 = 722.35 |
| G 10 = 740.18 | G 11 = 755.24 | G 12 = 779.40 | G 13 = 800.49 | G 14 = 822.30 |
| G 15 = 844.60 | G 16 = 867.15 | G 17 = 889.68 | G 18 = 911.93 | G 19 = 933.65 |
| G 20 = 954.59 | G 21 = 974.54 | G 22 = 993.31 | G 23 = 1010.7 | G 24 = 1026.7 |
| G 25 = 1041.2 | G 26 = 1054.1 | G 27 = 1065.4 | G 28 = 1075.2 | G 29 = 1083.6 |
| G 30 = 1090.6 | G 31 = 1096.4 | G 32 = 1101.1 | G 33 = 1104.8 | G 34 = 1107.6 |
| G 35 = 1109.7 | G 36 = 1111.2 | G 37 = 1112.3 | G 38 = 1112.9 | G 39 = 1113.3 |
| G 40 = 1113.5 | G = 0 | G = 0 | G = 0 | G = 0 |
| H 1 = 608.94 | H 2 = 611.81 | H 3 = 615.29 | H 4 = 619.49 | H 5 = 624.48 |
| H 6 = 630.37 | H 7 = 637.25 | H 8 = 645.20 | H 9 = 654.28 | H 10 = 664.57 |
| H 11 = 676.10 | H 12 = 688.88 | H 13 = 702.92 | H 14 = 718.18 | H 15 = 734.60 |
| H 16 = 752.08 | H 17 = 770.52 | H 18 = 789.75 | H 19 = 809.62 | H 20 = 829.94 |
| H 21 = 850.52 | H 22 = 871.13 | H 23 = 891.58 | H 24 = 911.66 | H 25 = 931.18 |
| H 26 = 949.96 | H 27 = 967.85 | H 28 = 984.73 | H 29 = 1000.5 | H 30 = 1015.0 |
| H 31 = 1028.4 | H 32 = 1040.4 | H 33 = 1051.2 | H 34 = 1060.8 | H 35 = 1069.2 |
| H 36 = 1076.6 | H 37 = 1082.9 | H 38 = 1088.3 | H 39 = 1092.8 | H 40 = 1096.6 |
| H = 0 | H = 0 | H = 0 | H = 0 | H = 0 |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: 0.0 (OUT)

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 2 LOC=0 T:IN=610F T:OUT=1002.0 Q/A=1.04374 MW/M2
A21=37.270 A22=124.65 A23=170.76 A24=133.49 A25=71.175

4

| ITER NO. | | 2. GREATEST TEMPERATURE CHANGE PER ITERATION = .0 | | | | CRITICAL NODE = 2 | | | |
|------------------|------------------|---|-----------------|----------------|--|-------------------|--|--|--|
| T:NA IN = 610.00 | T:NA OUT= 1002.0 | DT: NA = 392.00 | T:B NA = 806.00 | T:B M = 828.29 | | | | | |
| DT M-N = 37.270 | DT1 = 124.65 | DT P-N = 170.76 | DT P-M = 133.49 | DT2 = 71.175 | | | | | |
| N 5 = 610.00 | N 1 = 612.45 | N 2 = 615.41 | N 3 = 618.96 | N 4 = 623.16 | | | | | |
| N 6 = 628.09 | N 6 = 633.82 | N 7 = 640.41 | N 8 = 647.91 | N 9 = 656.37 | | | | | |
| N 10 = 665.81 | N 11 = 676.25 | N 12 = 687.66 | N 13 = 700.03 | N 14 = 713.29 | | | | | |
| N 15 = 727.37 | N 16 = 742.17 | N 17 = 757.58 | N 18 = 773.45 | N 19 = 789.64 | | | | | |
| N 20 = 806.00 | N 21 = 822.36 | N 22 = 838.55 | N 23 = 854.42 | N 24 = 869.83 | | | | | |
| N 25 = 884.63 | N 26 = 898.71 | N 27 = 911.97 | N 28 = 924.34 | N 29 = 935.75 | | | | | |
| N 30 = 946.19 | N 31 = 955.63 | N 32 = 964.09 | N 33 = 971.59 | N 34 = 978.18 | | | | | |
| N 35 = 983.91 | N 36 = 988.84 | N 37 = 993.04 | N 38 = 996.59 | N 39 = 999.55 | | | | | |
| N 40 = 1002.0 | | | | | | | | | |
| M 5 = 615.04 | M 1 = 618.58 | M 2 = 622.79 | M 3 = 627.75 | M 4 = 633.52 | | | | | |
| M 6 = 640.19 | M 6 = 647.81 | M 7 = 656.42 | M 8 = 666.06 | M 9 = 676.73 | | | | | |
| M 10 = 688.42 | M 11 = 701.11 | M 12 = 714.73 | M 13 = 729.20 | M 14 = 744.42 | | | | | |
| M 15 = 760.26 | M 16 = 776.57 | M 17 = 793.21 | M 18 = 809.98 | M 19 = 826.73 | | | | | |
| M 20 = 843.27 | M 21 = 859.44 | M 22 = 875.08 | M 23 = 890.05 | M 24 = 904.23 | | | | | |
| M 25 = 917.52 | M 26 = 929.84 | M 27 = 941.14 | M 28 = 951.40 | M 29 = 960.61 | | | | | |
| M 30 = 968.79 | M 31 = 975.98 | M 32 = 982.23 | M 33 = 987.60 | M 34 = 992.17 | | | | | |
| M 35 = 996.01 | M 36 = 999.20 | M 37 = 1001.8 | M 38 = 1004.0 | M 39 = 1005.7 | | | | | |
| M 40 = 1007.0 | | | | | | | | | |
| P 5 = 633.11 | P 1 = 640.54 | P 2 = 649.21 | P 3 = 659.21 | P 4 = 670.64 | | | | | |
| P 6 = 683.53 | P 6 = 697.91 | P 7 = 713.76 | P 8 = 731.03 | P 9 = 749.62 | | | | | |
| P 10 = 769.39 | P 11 = 790.14 | P 12 = 811.66 | P 13 = 833.68 | P 14 = 855.92 | | | | | |
| P 15 = 878.06 | P 16 = 895.80 | P 17 = 920.82 | P 18 = 940.83 | P 19 = 959.55 | | | | | |
| P 20 = 976.76 | P 21 = 992.26 | P 22 = 1005.9 | P 23 = 1017.7 | P 24 = 1027.5 | | | | | |
| P 25 = 1035.3 | P 26 = 1041.3 | P 27 = 1045.6 | P 28 = 1048.3 | P 29 = 1049.6 | | | | | |
| P 30 = 1049.8 | P 31 = 1048.9 | P 32 = 1047.2 | P 33 = 1044.9 | P 34 = 1042.3 | | | | | |
| P 35 = 1039.3 | P 36 = 1036.3 | P 37 = 1033.3 | P 38 = 1030.4 | P 39 = 1027.6 | | | | | |
| P 40 = 1025.1 | | | | | | | | | |
| G 5 = 623.48 | G 1 = 628.83 | G 2 = 635.12 | G 3 = 642.44 | G 4 = 650.85 | | | | | |
| G 5 = 660.43 | G 6 = 671.20 | G 7 = 683.19 | G 8 = 696.39 | G 9 = 710.76 | | | | | |
| G 10 = 726.22 | G 11 = 742.68 | G 12 = 759.98 | G 13 = 777.98 | G 14 = 796.48 | | | | | |
| G 15 = 815.26 | G 16 = 834.11 | G 17 = 852.79 | G 18 = 871.07 | G 19 = 888.74 | | | | | |
| G 20 = 905.59 | G 21 = 921.45 | G 22 = 936.17 | G 23 = 949.64 | G 24 = 961.77 | | | | | |
| G 25 = 972.52 | G 26 = 981.90 | G 27 = 989.93 | G 28 = 996.66 | G 29 = 1002.2 | | | | | |
| G 30 = 1006.6 | G 31 = 1010.0 | G 32 = 1012.6 | G 33 = 1014.4 | G 34 = 1015.6 | | | | | |
| G 35 = 1016.2 | G 36 = 1016.5 | G 37 = 1016.5 | G 38 = 1016.3 | G 39 = 1015.9 | | | | | |
| G 40 = 1015.5 | | | | | | | | | |
| H 1 = 608.33 | H 2 = 610.45 | H 3 = 613.05 | H 4 = 616.20 | H 5 = 619.96 | | | | | |
| H 6 = 624.42 | H 7 = 625.65 | H 8 = 635.72 | H 9 = 642.69 | H 10 = 650.62 | | | | | |
| H 11 = 659.54 | H 12 = 665.47 | H 13 = 680.42 | H 14 = 692.36 | H 15 = 705.26 | | | | | |
| H 16 = 719.04 | H 17 = 733.62 | H 18 = 748.89 | H 19 = 764.71 | H 20 = 780.94 | | | | | |
| H 21 = 797.43 | H 22 = 813.99 | H 23 = 830.47 | H 24 = 846.70 | H 25 = 862.52 | | | | | |
| H 26 = 877.78 | H 27 = 892.36 | H 28 = 906.14 | H 29 = 919.04 | H 30 = 930.99 | | | | | |
| H 31 = 941.94 | H 32 = 951.89 | H 33 = 960.83 | H 34 = 968.77 | H 35 = 975.77 | | | | | |
| H 36 = 981.87 | H 37 = 987.13 | H 38 = 991.63 | H 39 = 995.43 | H 40 = 998.61 | | | | | |

CASE # 4

Solar Flux: OFF-NORMAL

Orifices: NO

Sub-Panel: 2

Location x/L: 1.0(1N)

T(Na-inlet) = 610 F

T(Na-outlet) : Max = 1100F

PNL 2 LOC=1 T:IN=610F T:OUT=1100.0 Q/A=1.30468 MW/M2
A21=44.735 A22=149.71 A23=207.06 A24=162.33 A25=87.514

4

| ITER NO. | 2. | GREATEST TEMPERATURE CHANGE PER ITERATION = | .0 | CRITICAL NODE = | 2 |
|------------------|------------------|---|-----------------|-----------------|---|
| T:NA IN = 610.00 | T:NA CUT= 1100.0 | DT: NA = 490.00 | T:B NA = 855.00 | T:B M = 881.76 | |
| DT M-N = 44.735 | DT1 = 149.71 | DT P-N = 207.06 | DT P-M = 162.33 | DT2 = 87.514 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| N 5 = 610.00 | N 1 = 613.06 | N 2 = 616.77 | N 3 = 621.20 | N 4 = 626.45 | |
| N 10 = 632.62 | N 6 = 635.78 | N 7 = 648.01 | N 8 = 657.39 | N 9 = 667.97 | |
| N 15 = 679.77 | N 11 = 692.81 | N 12 = 707.08 | N 13 = 722.53 | N 14 = 739.11 | |
| N 20 = 756.71 | N 16 = 775.21 | N 17 = 794.47 | N 18 = 814.31 | N 19 = 834.55 | |
| N 25 = 855.00 | N 21 = 875.45 | N 22 = 895.69 | N 23 = 915.53 | N 24 = 934.79 | |
| N 30 = 953.29 | N 26 = 970.89 | N 27 = 987.47 | N 28 = 1002.9 | N 29 = 1017.2 | |
| N 35 = 1030.2 | N 31 = 1042.0 | N 32 = 1052.6 | N 33 = 1062.0 | N 34 = 1070.2 | |
| N 40 = 1071.4 | N 36 = 1083.5 | N 37 = 1088.8 | N 38 = 1093.2 | N 39 = 1096.9 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| M 5 = 616.05 | M 1 = 620.42 | M 2 = 625.62 | M 3 = 631.74 | M 4 = 638.89 | |
| M 10 = 647.14 | M 6 = 656.57 | M 7 = 667.23 | M 8 = 679.17 | M 9 = 692.39 | |
| M 15 = 706.90 | M 11 = 722.65 | M 12 = 739.56 | M 13 = 757.55 | M 14 = 776.48 | |
| M 20 = 796.19 | M 16 = 816.51 | M 17 = 837.24 | M 18 = 858.16 | M 19 = 879.07 | |
| M 25 = 899.73 | M 21 = 915.96 | M 22 = 939.54 | M 23 = 958.30 | M 24 = 976.08 | |
| M 30 = 942.77 | M 26 = 1008.3 | M 27 = 1022.5 | M 28 = 1035.4 | M 29 = 1047.0 | |
| M 35 = 1057.4 | M 31 = 1066.5 | M 32 = 1074.4 | M 33 = 1081.2 | M 34 = 1087.0 | |
| M 40 = 1091.9 | M 36 = 1096.0 | M 37 = 1099.3 | M 38 = 1102.1 | M 39 = 1104.3 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| P 5 = 638.02 | P 1 = 647.12 | P 2 = 657.74 | P 3 = 670.01 | P 4 = 684.02 | |
| P 10 = 699.84 | P 6 = 717.49 | P 7 = 736.96 | P 8 = 758.18 | P 9 = 781.04 | |
| P 15 = 805.36 | P 11 = 830.91 | P 12 = 857.43 | P 13 = 884.60 | P 14 = 912.06 | |
| P 20 = 934.44 | P 16 = 966.35 | P 17 = 992.42 | P 18 = 1017.3 | P 19 = 1040.6 | |
| P 25 = 1062.1 | P 21 = 1081.5 | P 22 = 1098.6 | P 23 = 1113.5 | P 24 = 1125.9 | |
| P 30 = 1136.0 | P 26 = 1143.8 | P 27 = 1149.5 | P 28 = 1153.3 | P 29 = 1155.3 | |
| P 35 = 1155.8 | P 31 = 1155.1 | P 32 = 1153.4 | P 33 = 1150.9 | P 34 = 1147.9 | |
| P 40 = 1144.6 | P 36 = 1141.1 | P 37 = 1137.6 | P 38 = 1134.2 | P 39 = 1131.0 | |
| = .0 | = .0 | = .0 | = .0 | = .0 | |
| G 5 = 626.18 | G 1 = 632.73 | G 2 = 640.43 | G 3 = 649.39 | G 4 = 659.70 | |

| | | | | |
|---------------|---------------|---------------|---------------|---------------|
| G 5 = 671.44 | G 6 = 684.66 | G 7 = 699.38 | G 8 = 715.60 | G 9 = 733.27 |
| G 10 = 752.30 | G 11 = 772.57 | G 12 = 793.92 | G 13 = 816.14 | G 14 = 839.00 |
| G 15 = 862.25 | G 16 = 885.61 | G 17 = 908.80 | G 18 = 931.53 | G 19 = 953.55 |
| G 20 = 974.59 | G 21 = 994.44 | G 22 = 1012.9 | G 23 = 1029.9 | G 24 = 1045.2 |
| G 25 = 1058.8 | G 26 = 1070.8 | G 27 = 1081.1 | G 28 = 1089.8 | G 29 = 1097.0 |
| G 30 = 1102.8 | G 31 = 1107.3 | G 32 = 1110.8 | G 33 = 1113.4 | G 34 = 1115.1 |
| G 35 = 1116.2 | G 36 = 1116.8 | G 37 = 1117.0 | G 38 = 1116.9 | G 39 = 1116.6 |
| = .0 | = .0 | = .0 | = .0 | = .0 |
| H 1 = 608.11 | H 2 = 610.80 | H 3 = 614.10 | H 4 = 618.08 | H 5 = 622.84 |
| H 6 = 628.47 | H 7 = 635.08 | H 8 = 642.73 | H 9 = 651.52 | H 10 = 661.50 |
| H 11 = 672.72 | H 12 = 685.21 | H 13 = 698.96 | H 14 = 713.95 | H 15 = 730.13 |
| H 16 = 747.41 | H 17 = 765.67 | H 18 = 784.79 | H 19 = 804.58 | H 20 = 824.88 |
| H 21 = 845.48 | H 22 = 866.16 | H 23 = 886.74 | H 24 = 906.98 | H 25 = 926.71 |
| H 26 = 945.73 | H 27 = 963.89 | H 28 = 981.05 | H 29 = 997.10 | H 30 = 1012.0 |
| H 31 = 1025.6 | H 32 = 1037.9 | H 33 = 1049.0 | H 34 = 1058.9 | H 35 = 1067.6 |
| H 36 = 1075.2 | H 37 = 1081.7 | H 38 = 1087.3 | H 39 = 1092.0 | H 40 = 1095.9 |
| = .0 | = .0 | = .0 | = .0 | = .0 |



ADD-3 TUBE-MANIFOLD TAP THERMAL MODEL SETUP

Of special interest for transient thermal stress analysis is the location of the tube-manifold wall joint. A stress model (nodes and elements) had been set up. The coordinates of the nodes had been established. These coordinates are then to be used as input to the STAMP computer program which sets up a nodal-connector network for use with the TAP computer program. Figures Add-III-1 and Add-III-2 show the geometry and the node/element model of the joint area. Table Add-III-1 shows the STAMP input data.

The analysis was suspended prior to completion. This model data is recorded here for later use.

5370F/sjh

FIGURE Add-III-1

83/04/15
 ICEB000
 16.3 4

83/4/15





FIGURE Add- III - 2

TUBE-MANIFOLD JOINT
STAMP OUT-PUT GEOMETRY

- RECTANGLES = ELEMENTS
- INTERSECTIONS = NODES



| *NODES | | *ELM* | Z | R | |
|--------|----------|----------|-----|---------|--------|
| 170 | 132 | 0 | 0 | 0 | |
| 1 | Z=.13400 | R=1.2500 | 88 | .26909 | .38005 |
| 2 | .13400 | 1.1925 | 89 | .31618 | .37709 |
| 3 | .13400 | 1.1350 | 90 | .36327 | .37414 |
| 4 | .13400 | 1.0775 | 91 | .41036 | .37118 |
| 5 | .13400 | 1.0200 | 92 | .45745 | .36823 |
| 6 | .13400 | .96250 | 93 | .50455 | .36527 |
| 7 | .13400 | .90500 | 94 | .55164 | .36232 |
| 8 | .13400 | .84750 | 95 | .59873 | .35936 |
| 9 | .13400 | .79000 | 96 | .64582 | .35641 |
| 10 | .13400 | .73250 | 97 | .69291 | .35345 |
| 11 | .13400 | .67500 | 98 | .74000 | .35050 |
| 12 | .13400 | .61750 | 99 | .80500 | .35050 |
| 13 | .13400 | .56000 | 100 | .87000 | .35050 |
| 14 | .13809 | .52894 | 101 | .93500 | .35050 |
| 15 | .15008 | .50000 | 102 | 1.00000 | .35050 |
| 16 | .16915 | .47515 | 103 | .03350 | 1.2500 |
| 17 | .19400 | .45608 | 104 | .03350 | 1.1898 |
| 18 | .22294 | .44409 | 105 | .03350 | 1.1295 |
| 19 | .25400 | .44000 | 106 | .03350 | 1.0693 |
| 20 | .29818 | .43409 | 107 | .03350 | 1.0090 |
| 21 | .34236 | .42818 | 108 | .03350 | .94875 |
| 22 | .38655 | .42227 | 109 | .03350 | .88850 |
| 23 | .43073 | .41636 | 110 | .03350 | .82825 |
| 24 | .47491 | .41045 | 111 | .03350 | .76800 |
| 25 | .51909 | .40455 | 112 | .03350 | .70775 |
| 26 | .56327 | .39864 | 113 | .03350 | .64750 |
| 27 | .60745 | .39273 | 114 | .03350 | .58725 |
| 28 | .65164 | .38682 | 115 | .03350 | .52700 |
| 29 | .69582 | .38091 | 116 | .03938 | .46235 |
| 30 | .74000 | .37500 | 117 | .05661 | .44075 |
| 31 | .80500 | .37500 | 118 | .08402 | .40502 |
| 32 | .87000 | .37500 | 119 | .11975 | .37761 |
| 33 | .93500 | .37500 | 120 | .16135 | .35038 |
| 34 | 1.00000 | .37500 | 121 | .20600 | .32450 |
| 35 | 1.0050 | 1.2500 | 122 | .25455 | .35302 |
| 36 | 1.0050 | 1.1916 | 123 | .30309 | .35155 |
| 37 | 1.0050 | 1.1332 | 124 | .35164 | .35007 |
| 38 | 1.0050 | 1.0748 | 125 | .40018 | .34859 |
| 39 | 1.0050 | 1.0163 | 126 | .44973 | .34711 |
| 40 | 1.0050 | .95792 | 127 | .49727 | .34564 |
| 41 | 1.0050 | .89950 | 128 | .54582 | .34416 |
| 42 | 1.0050 | .84108 | 129 | .59436 | .34268 |
| 43 | 1.0050 | .78267 | 130 | .64291 | .34120 |
| 44 | 1.0050 | .72425 | 131 | .69145 | .33973 |
| 45 | 1.0050 | .66583 | 132 | .74000 | .33825 |
| 46 | 1.0050 | .60742 | 133 | .80500 | .33825 |
| 47 | 1.0050 | .54900 | 134 | .87000 | .33825 |
| 48 | 1.0519 | .51341 | 135 | .93500 | .33825 |
| 49 | 1.1892 | .48025 | 136 | 1.00000 | .33825 |
| 50 | 1.4077 | .45177 | 137 | 0.0 | 1.2500 |
| 51 | 1.6925 | .42992 | 138 | 0.0 | 1.1888 |
| 52 | 2.0241 | .41619 | 139 | 0.0 | 1.1277 |
| 53 | .23800 | .41150 | 140 | 0. | 1.0665 |
| 54 | .28364 | .40707 | 141 | 0. | 1.0053 |
| 55 | .32927 | .40264 | 142 | 0. | .94417 |
| 56 | .37491 | .39820 | 143 | 0. | .88300 |
| 57 | .42055 | .39377 | 144 | 0. | .82183 |
| 58 | .46618 | .38934 | 145 | 0. | .76067 |
| 59 | .51182 | .38491 | 146 | 0. | .69950 |
| 60 | .55745 | .38048 | 147 | 0. | .63833 |
| 61 | .60309 | .37605 | 148 | 0. | .57717 |
| 62 | .64873 | .37161 | 149 | 0. | .51600 |
| 63 | .69436 | .36718 | 150 | .00647 | .46682 |
| 64 | .74000 | .36275 | 151 | .02546 | .42100 |
| 65 | .80500 | .36275 | 152 | .05565 | .38165 |
| 66 | .87000 | .36275 | 153 | .09500 | .35146 |
| 67 | .93500 | .36275 | 154 | .14082 | .33247 |
| 68 | 1.00000 | .36275 | 155 | .19000 | .32600 |
| 69 | .06700 | 1.2500 | 156 | .24000 | .32600 |
| 70 | .06700 | 1.1907 | 157 | .29000 | .32600 |
| 71 | .06700 | 1.1313 | 158 | .34000 | .32600 |
| 72 | .06700 | 1.0720 | 159 | .39000 | .32600 |
| 73 | .06700 | 1.0127 | 160 | .44000 | .32600 |
| 74 | .06700 | .95333 | 161 | .49000 | .32600 |
| 75 | .06700 | .89400 | 162 | .54000 | .32600 |
| 76 | .06700 | .83467 | 163 | .59000 | .32600 |
| 77 | .06700 | .77533 | 164 | .64000 | .32600 |
| 78 | .06700 | .71600 | 165 | .69000 | .32600 |
| 79 | .06700 | .65667 | 166 | .74000 | .32600 |
| 80 | .06700 | .59733 | 167 | .80500 | .32600 |
| 81 | .06700 | .53800 | 168 | .87000 | .32600 |
| 82 | .07228 | .49788 | 169 | .93500 | .32600 |
| 83 | .08777 | .46050 | 170 | 1.00000 | .32600 |
| 84 | .11240 | .42840 | | | |
| 85 | .14450 | .40377 | | | |
| 86 | .18188 | .38828 | | | |
| 87 | .22200 | .38300 | | | |

0
BODY
REVOLUTION

TABLE Add-III-1(a)

"STAMP" INPUT
SHEET 1 OF 2

(TO GENERATE TAP NETWORK)

NODAL COORDINATES(Z,R)

170 NODES (STEEL)
132 ELEMENTS

| 1-ELEM | 1 | 2 | 36 | 35 | NO | | | | |
|--------|-----|-----|-----|-----|------------------|------------------|------------------|------------------|-----|
| 2 | 35 | 36 | 70 | 69 | 94 | 58 | 59 | 93 | 92 |
| 3 | 69 | 70 | 104 | 103 | 95 | 92 | 93 | 127 | 126 |
| 4 | 138 | 137 | 103 | 104 | 96 | 161 | 160 | 126 | 127 |
| 5 | 2 | 3 | 37 | 36 | 97 | 25 | 26 | 60 | 59 |
| 6 | 36 | 37 | 71 | 70 | 98 | 59 | 60 | 94 | 93 |
| 7 | 70 | 71 | 105 | 104 | 99 | 93 | 94 | 128 | 127 |
| 8 | 139 | 138 | 104 | 105 | 100 | 162 | 161 | 127 | 128 |
| 9 | 3 | 4 | 38 | 37 | 101 | 26 | 27 | 61 | 60 |
| 10 | 37 | 38 | 72 | 71 | 102 | 60 | 61 | 95 | 94 |
| 11 | 71 | 72 | 106 | 105 | 103 | 94 | 95 | 129 | 128 |
| 12 | 140 | 139 | 105 | 106 | 104 | 163 | 162 | 128 | 129 |
| 13 | 4 | 5 | 39 | 38 | 105 | 27 | 28 | 62 | 61 |
| 14 | 38 | 39 | 73 | 72 | 106 | 61 | 62 | 96 | 95 |
| 15 | 72 | 73 | 107 | 106 | 107 | 95 | 96 | 130 | 129 |
| 16 | 141 | 140 | 106 | 107 | 108 | 164 | 163 | 129 | 130 |
| 17 | 5 | 6 | 40 | 39 | 109 | 28 | 29 | 63 | 62 |
| 18 | 39 | 40 | 74 | 73 | 110 | 62 | 63 | 97 | 96 |
| 19 | 73 | 74 | 108 | 107 | 111 | 96 | 97 | 131 | 130 |
| 20 | 142 | 141 | 107 | 108 | 112 | 165 | 164 | 130 | 131 |
| 21 | 6 | 7 | 41 | 40 | 113 | 29 | 30 | 64 | 63 |
| 22 | 40 | 41 | 75 | 74 | 114 | 63 | 64 | 98 | 97 |
| 23 | 74 | 75 | 109 | 108 | 115 | 97 | 98 | 132 | 131 |
| 24 | 143 | 142 | 108 | 109 | 116 | 166 | 165 | 131 | 132 |
| 25 | 7 | 8 | 42 | 41 | 117 | 30 | 31 | 65 | 64 |
| 26 | 41 | 42 | 76 | 75 | 118 | 64 | 65 | 99 | 98 |
| 27 | 75 | 76 | 110 | 109 | 119 | 98 | 99 | 133 | 132 |
| 28 | 144 | 143 | 109 | 110 | 120 | 167 | 166 | 132 | 133 |
| 29 | 8 | 9 | 43 | 42 | 121 | 31 | 32 | 66 | 65 |
| 30 | 42 | 43 | 77 | 76 | 122 | 65 | 66 | 100 | 99 |
| 31 | 76 | 77 | 111 | 110 | 123 | 99 | 100 | 134 | 133 |
| 32 | 145 | 144 | 110 | 111 | 124 | 168 | 167 | 133 | 134 |
| 33 | 9 | 10 | 44 | 43 | 125 | 32 | 33 | 67 | 66 |
| 34 | 43 | 44 | 78 | 77 | 126 | 66 | 67 | 101 | 100 |
| 35 | 77 | 78 | 112 | 111 | 127 | 100 | 101 | 135 | 134 |
| 36 | 146 | 145 | 111 | 112 | 128 | 169 | 168 | 134 | 135 |
| 37 | 10 | 11 | 45 | 44 | 129 | 33 | 34 | 68 | 67 |
| 38 | 44 | 45 | 79 | 78 | 130 | 67 | 68 | 102 | 101 |
| 39 | 78 | 79 | 113 | 112 | 131 | 101 | 102 | 136 | 135 |
| 40 | 147 | 146 | 112 | 113 | 132 | 170 | 169 | 135 | 136 |
| 41 | 11 | 12 | 46 | 45 | | | | | |
| 42 | 45 | 46 | 80 | 79 | | | | | |
| 43 | 79 | 80 | 114 | 113 | | | | | |
| 44 | 148 | 147 | 113 | 114 | | | | | |
| 45 | 12 | 13 | 47 | 46 | | | | | |
| 46 | 46 | 47 | 81 | 80 | | | | | |
| 47 | 80 | 81 | 115 | 114 | | | | | |
| 48 | 149 | 148 | 114 | 115 | | | | | |
| 49 | 13 | 14 | 48 | 47 | | | | | |
| 50 | 47 | 48 | 82 | 81 | | | | | |
| 51 | 81 | 82 | 116 | 115 | | | | | |
| 52 | 150 | 149 | 115 | 116 | | | | | |
| 53 | 14 | 15 | 49 | 48 | | | | | |
| 54 | 48 | 49 | 83 | 82 | 1137=Na137=Steel | | | | |
| 55 | 82 | 83 | 117 | 116 | 1138 | 138 | | | |
| 56 | 151 | 150 | 116 | 117 | 1139 | 139 | | | |
| 57 | 15 | 16 | 50 | 49 | 1140 | 140 | | | |
| 58 | 49 | 50 | 84 | 83 | 1141 | 141 | | | |
| 59 | 83 | 84 | 118 | 117 | 1142 | 142 | | | |
| 60 | 152 | 151 | 117 | 118 | 1143 | 143 | | | |
| 61 | 16 | 17 | 51 | 50 | 1144 | 144 | | | |
| 62 | 50 | 51 | 85 | 84 | 1145 | 145 | | | |
| 63 | 84 | 85 | 119 | 118 | 1146 | 146 | | | |
| 64 | 153 | 152 | 118 | 119 | 1147 | 147 | | | |
| 65 | 17 | 18 | 52 | 51 | 1148 | 148 | | | |
| 66 | 51 | 52 | 86 | 85 | 1149 | 149 | | | |
| 67 | 85 | 86 | 120 | 119 | 1150 | 150 | | | |
| 68 | 154 | 153 | 119 | 120 | 1151 | 151 | | | |
| 69 | 18 | 19 | 53 | 52 | 1152 | 152 | | | |
| 70 | 52 | 53 | 87 | 86 | 1153 | 153 | | | |
| 71 | 86 | 87 | 121 | 120 | 1154 | 154 | | | |
| 72 | 155 | 154 | 120 | 121 | 1155 | 155 | | | |
| 73 | 19 | 20 | 54 | 53 | 1156 | 156 | | | |
| 74 | 53 | 54 | 88 | 87 | 1157 | 157 | | | |
| 75 | 87 | 88 | 122 | 121 | 1158 | 158 | | | |
| 76 | 156 | 155 | 121 | 122 | 1159 | 159 | | | |
| 77 | 20 | 21 | 55 | 54 | 1160 | 160 | | | |
| 78 | 54 | 55 | 89 | 88 | 1161 | 161 | | | |
| 79 | 88 | 89 | 123 | 122 | 1162 | 162 | | | |
| 80 | 157 | 156 | 122 | 123 | 1163 | 163 | | | |
| 81 | 21 | 22 | 56 | 55 | 1164 | 164 | | | |
| 82 | 55 | 56 | 90 | 89 | 1165 | 165 | | | |
| 83 | 89 | 90 | 124 | 123 | 1166 | 166 | | | |
| 84 | 158 | 157 | 123 | 124 | 1167 | 167 | | | |
| 85 | 22 | 23 | 57 | 56 | 1168 | 168 | | | |
| 86 | 56 | 57 | 91 | 90 | 1169 | 169 | | | |
| 87 | 90 | 91 | 125 | 124 | 1170 | 170 | | | |
| 88 | 159 | 158 | 124 | 125 | -1 | | | | |
| 89 | 23 | 24 | 58 | 57 | 0=0 | 0.35 | 0.30 | 0.80 | |
| 90 | 57 | 58 | 92 | 91 | Z _{min} | Z _{max} | R _{min} | R _{max} | |
| 91 | 91 | 92 | 126 | 125 | | | | | |
| 92 | 160 | 159 | 125 | 126 | | | | | |
| 93 | 24 | 25 | 59 | 58 | | | | | |

TABLE

Add-III-1 (b)

"STAMP"

INPUT

(TO GENERATE
TAP NETWORK)

SHEET 2 OF 2

• ELEMENT CARDS

• Na → STEEL
CONNECTORS



| | | | | | |
|-----------------|------------------|------------------|--------------------|---|-----------------------|
| GO NO. 09479 | S/A NO. 13120 | PAGE 1 OF 168 | TOTAL PAGES 168 | REV LTR/CHG NO SEE SUMMARY OF CHG <i>DC</i> | NUMBER 079TI000001 |
|-----------------|------------------|------------------|--------------------|---|-----------------------|

PROGRAM TITLE
Solar Central Receiver Power PLant - Carrizo Plains, Unit No. 1

DOCUMENT TITLE
Preliminary Design Structural Analysis - Carrizo Plains Solar Receiver Subsystem

| | |
|--|-----------|
| DOCUMENT TYPE Technical Information | KEY NOUNS |
|--|-----------|

| | | | |
|---------------------|--------------------------------|-----------|------|
| ORIGINAL ISSUE DATE | REL. DATE <i>3-14-83 RK</i> | APPROVALS | DATE |
|---------------------|--------------------------------|-----------|------|

| | | | | |
|---|-------------|-------------------|---------------------------------------|------------------------|
| PREPARED BY/DATE <i>W. R. Castle</i> | DEPT 731 | MAIL ADDR LB30 | APPROVALS <i>H. M. Minami, Jr.</i> | DATE <i>3/10/83</i> |
|---|-------------|-------------------|---------------------------------------|------------------------|

IR&D PROGRAM? YES NO
IF YES, ENTER TPA NO.

| | |
|--------------|----------|
| DISTRIBUTION | ABSTRACT |
|--------------|----------|

| * NAME | MAIL ADDR | ABSTRACT |
|------------------|-----------|---|
| H. Minami, Jr. | LB30 | <p>This report documents the Preliminary Design analysis of the Carrizo Plains Receiver Subsystem. The analysis was performed in accordance with the requirements of the Rockwell International Receiver Specification N10049.</p> <p>Basic Code analyses were performed to demonstrate the gross structural integrity of the overall receiver subsystem under design condition loadings. Analyses of critical components of the receiver under combined loading were also performed.</p> <p>Further analyses are required to verify the structural adequacy of the entire receiver subsystem design.</p> |
| * E. Mouradian | LB30 | |
| L. Rico | LB30 | |
| B. Katz | LA19 | |
| * A. Ullman | LA19 | |
| * L. Glasgow | LA19 | |
| J. Ives | LA19 | |
| T. Anderson | LB26 | |
| * J. Miller | LA19 | |
| T. Springer | LA21 | |
| * T. Johnson (4) | LA19 | |
| * W. Propes | LB30 | |
| * C. Wahnsiedler | LB30 | |
| * W. Castle (3) | LB30 | |

RESERVED FOR PROPRIETARY/LEGAL NOTICES

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE DOE OFFICE OF PATENT COUNSEL

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY



TABLE OF CONTENTS

| | | |
|-------|---|-----|
| 1.0 | Introduction | 7 |
| 2.0 | Summary | 8 |
| 3.0 | Discussion | 11 |
| 3.1 | Design Description | 11 |
| 3.2 | Structural Criteria | 22 |
| 3.2.1 | Environmental Requirements | 22 |
| 3.2.2 | Code Requirements | 28 |
| 3.3 | Loading Combinations | 29 |
| 3.3.1 | Sodium Tubes and Headers | 29 |
| 3.3.2 | Balance of Receiver Subsystem | 29 |
| 3.4 | Thermal Environments | 30 |
| 3.5 | Material Properties | 39 |
| 3.6 | Allowable Stresses | 43 |
| 3.6.1 | ANSI B31.1 Power Piping | 43 |
| 3.6.2 | ASME Section VIII | 48 |
| 3.6.3 | Creep-Fatigue Damage Fraction | 49 |
| 3.7 | Methods of Analysis | 54 |
| 4.0 | Conclusions | 55 |
| 5.0 | References | 56 |
| 6.0 | Appendices | 58 |
| 6.1 | ASME Section VIII Analysis | 59 |
| 6.2 | Finite Element Model Descriptions | 66 |
| 6.2.1 | Receiver System Model..... | 67 |
| 6.2.2 | Single Tube Model | 84 |
| 6.2.3 | Tube Cross-section Model | 86 |
| 6.3 | Tube Stress Analysis | 91 |
| 6.4 | Tang Stress Analysis | 100 |
| 6.5 | Hatband Stress Analysis | 112 |



| | | |
|------|--|-----|
| 6.6 | Support Rod Stress Analysis | 117 |
| 6.7 | Header Stress Analysis | 121 |
| 6.8 | Support Beam Stress Analysis | 125 |
| 6.9 | Support Truss Stress Analysis .. | 130 |
| 6.10 | Finite Element Model Input Data Listings | 135 |



TABLES

| | |
|---|-----|
| 1. Summary of Results | 10 |
| 2. Environmental Requirements | 23 |
| 3. Axial Temperature Distribution, Tube at Outer Edge of Panel 1 | 34 |
| 4. Axial Temperature Distribution, Tube at Inboard Edge of Panel 1 | 36 |
| 5. Axial Temperature Distribution, Full Thermal Load Tube | 38 |
| 6. Material Properties | 40 |
| 7. Single Tube Model Tube Stresses | 97 |
| 8. Single Tube Model Tang Loads | 102 |



FIGURES

| | |
|--|----|
| 1. Carrizo Plains Solar Receiver Power Plant | 12 |
| 2. Carrizo Plains Solar Receiver Details | 13 |
| 3. Reference Vertical Flux Distribution - 30 MWe Solar Plant | 31 |
| 4. Reference Lateral Flux Distribution - 30 MWe Solar Plant | 32 |
| 5. Axial Temperature Distribution, Tube at Outboard Edge of Panel 1 | 33 |
| 6. Axial Temperature Distribution, Tube at Inboard Edge of Panel 1 | 35 |
| 7. Axial Temperature Distribution, Full Thermal Load Tube | 37 |
| 8. Minimum Yield Strength and Modulus of Elasticity vs. Temperature, 316 SS | 41 |
| 9. Instantaneous Coefficient of Thermal Expansion | 42 |
| 10. Carrizo Plains Solar Receiver Cyclic Histogram | 50 |
| 11. Expected Minimum Stress-to-Rupture Values, Type 316SS | 51 |
| 12. Design Fatigue Strain Range, ϵ_t , 304 and 316SS Elastic Analysis | 52 |
| 13. Carrizo Plains Solar Receiver SAP V System Model | 68 |
| 14. Carrizo Plains Receiver Panel Undeformed and Deformed Modal Shapes - Front View | 71 |
| 15. Carrizo Plains Receiver Panel Undeformed and Deformed Modal Shapes - Side View | 72 |
| 16. Carrizo Plains Receiver Panel Undeformed and Deformed Modal Shapes - Isometric View | 73 |
| 17. Carrizo Plains Solar Receiver Single Tube ANSYS Model | 84 |
| 18. Carrizo Solar Receiver Single Tube Model CRT | 85 |
| 19. Meshplot of The Tube Cross-Section - ANSYS Model | 87 |
| 20. Thermal Nodal Map of the Tube Cross-Section ANSYS Model | 88 |
| 21. Tube Cross-Section Model Temperature Distribution Map - Full Thermal Load Case | 89 |

DRAWINGS

| | | | |
|----|------------|---|----|
| 1. | 079R000001 | ... Panel Assembly - Solar Receiver, 30 MWe Power Station | 14 |
| 2. | 079R000002 | ... Manifold - Solar Receiver Panel, 30 MWe Design Layout | 16 |
| 3. | 079R000003 | ... Support Assembly - Solar Receiver Panel, Design Layout | 17 |
| 4. | 079R000005 | ... Solar Receiver Assembly - 30MWe Power Station Design Layout | 18 |
| 5. | 079R000021 | ... Solar Receiver Panel Assembly - Handling and Shipping | 19 |
| 6. | 079R000025 | ... Coolant Flow Orifice Assembly - Solar Receiver Panel | 20 |
| 7. | 079R000028 | ... Tie Bar Assembly - Panel Support, Solar Receiver Design Layout | 21 |



1.0 INTRODUCTION

The receiver subsystem is one of the most critical components in the 30MWe solar central power station which is to be constructed at the Carrizo Plains site, approximately 66 miles North of Santa Barbara in San Luis Obispo County, California. This report documents the receiver subsystem stress analyses and evaluations performed, to date, during the Preliminary Design phase of the program.

The evaluations contained in this report are intended to demonstrate that the proposed design configuration satisfies the gross requirements of the various structural design Codes for the conditions contained in the receiver Design Specification (Reference 1). The structural criteria, design requirements, and the specific areas of the design evaluated to date are presented in the report. In addition, areas which require further analyses are identified. This report will be updated as the design continues its evolution through the Preliminary and Final Design phases.



2.0 SUMMARY

The receiver subsystem sits atop the tower structure in the center of a field of mirrored helostats which focus and concentrate the rays of the sun on the receiver panels. The panels consist of an array of stainless steel tubes in which liquid sodium flows, collecting the solar heat. The main components of the receiver subsystem are the panel tubes, the inlet and outlet headers, the tube support tangs, the panel support hatbands, the support rods, and the receiver support frame steel structure. A description of the receiver design is presented in Section 3.1 of this report.

The structural design conditions specified for the receiver subsystem consist of internal pressure, deadweight, seismic, and wind loadings. The design temperature of the sodium pressure boundary components is 1050⁰F. The structural criteria to be used for the sodium containing pressure boundary are Section VIII of the ASME Boiler and Pressure Vessel Code, and Section B31.1 of the ANSI Power Piping Code. Supplementary creep-fatigue criteria are also applied to the high temperature sodium pressure boundary using the methodology of ASME Code Case N-47. The frame steel receiver support structure is designed in accordance with AISC Manual of Steel Construction. Details of the structural criteria and design loading combinations are contained in Sections 3.2 and 3.3 of this report.

The analyses and evaluations performed to date indicate that the proposed receiver design configuration satisfies the gross structural requirements and criteria described above. The detail analyses performed are presented in the Appendices to this report for the following receiver components:

1. Panel Sodium Tubes
2. Tube Support Tangs
3. Panel Support Band (Hatbands)



4. Panel Support Rods
5. Inlet and Outlet Headers
6. Receiver Support Box and Truss

The analyses of these components under the specified loading combinations, and the evaluations performed in accordance with the appropriate structural criteria are summarized in Table 1. All design margins are positive, which demonstrates the feasibility of the overall design concept.

Although the overall design has been shown to meet the gross structural design requirements, additional analyses are required to complete the structural evaluation and to confirm the structural integrity of the receiver subsystem. The following areas require additional or new analysis:

1. Header Structural Analysis
 - a. Inlet and Outlet Headers - ASME Section VIII
 - b. Inlet and Outlet Headers - Header to Tube Transition
2. Transient Analysis
 - a. Analyze thermal transient conditions for the receiver tubes and headers
3. Receiver Life Evaluation
 - a. Evaluate the creep-fatigue damage fractions for the receiver subsystem
4. Tube Support Tangs
 - a. Additional analyses for beam column effects
5. Inboard Receiver Panel Analyses
 - a. Analyze the inboard receiver panels for normal and off-normal flux distributions
6. Receiver Support Structure
 - a. Aanalyze the support structure for the receiver panel
7. Shipping and Handling Analyses

TABLE 1
SUMMARY OF RESULTS

| Component | Type of Loading | Material | Criteria | Stress Calculated | Values Allowable | Design Margin | Ref. Page |
|-------------------------------|-------------------------------------|-----------|--------------|-------------------|------------------|---------------|-----------|
| Sodium Tubes | Pressure | SS316 | Section VIII | 100 psi | 2000 psi | High | 61 |
| Sodium Tubes (Thermal Window) | Thermal Expansion | SS316 | ANSI B31.1 | 17320 psi | 18900 psi | 0.09 | 95 |
| Sodium Tubes (Thermal Window) | Thermal Expansion + Sustained Loads | SS316 | ANSI B31.1 | 17943 psi | 33400 psi | 0.86 | 95 |
| Sodium Tubes (Shaded Area) | Thermal Expansion | SS316 | ANSI B31.1 | 11790 psi | 18900 psi | 0.60 | 96 |
| Sodium Tubes (Shaded Area) | Thermal Expansion + Sustained Loads | SS316 | ANSI B31.1 | 15280psi | 33400 psi | 1.18 | 96 |
| Tangs | DW + TE + Seis + Wind | SS304 | AISC | 0.66 | 1.00 | 0.51 | 107 |
| Hatbands | DW + TE + Seis + Wind | ASTMA 366 | AISC | 0.39 | 1.00 | 1.56 | 116 |
| Support Rods | DW + TE + Seis + Wind | ASTMA 519 | AISC | 1720 psi | 11900 psi | 5.93 | 120 |
| Inlet and Outlet Headers | DW + TE + Seis + Wind | SS316 | ANSI B31.1 | 7130 psi | 18900 psi | 1.65 | 123 |
| Support Box Section | DW + TE + Seis + Wind | SS304 | AISC | 0.74 | 1.00 | 0.35 | 129 |
| Support Truss | DW + TE + Seis + Wind | ASTM A36 | AISC | 0.29 | 1.00 | 2.45 | 134 |

FORM 718-P REV. 2-80



3.0 DISCUSSION

The following section describes the structural criteria, loading combinations, material properties, material allowable stresses and the methods of analysis.


3.1 Design Description


The receiver and its support structure are located atop a 365 foot steel truss type tower. The mid-plane height of the receiver is at 410 feet above ground level, as shown in Figure 1. The receiver assembly consists of eight panels approximately 52 feet in width and 50 feet in height. The receiver aperture (thermal flux window) is approximately 40 feet in height and extends from approximately 4 feet above the lower sodium inlet header of the panel to approximately 6 feet below the sodium outlet header. Each panel consists of 102 Type 316 stainless steel tubes with a diameter of 0.75 inches and a wall thickness of 0.049 inches.

The sodium tubes are supported by 0.105 inch diameter rods (tang) which are attached to "hatband" type support sections. The "hatband" sections are connected to tie rods (free to translate in the direction of thermal growth) that are attached to the rigid structure of the strong back of the receiver. Details of this tube support system are shown in Figure 2 and the enclosed design layout drawings.

The sodium tubes interface at both the upper and lower ends with 6.0 inch diameter headers with a wall thickness of 0.375 inches. The headers are supported in the horizontal planes but are free to move vertically. The inlet and outlet headers are shown in the enclosed layout drawings.

Figure 1
Carrizo Plains Solar Receiver
Power Plant






CARRIZO PLAINS SOLAR RECEIVER DETAILS

Figure 2

2




079TI000001
Page 15

| REVISIONS | | |
|-----------|-------------|------|
| NO. | DESCRIPTION | DATE |
| | | |

IN WORK
DOCUMENT NOT RELEASED
DATE 12-10-82
BY R. KATY (S) 4
FOR INFO ONLY
FOR STORAGE

| | |
|--|--|
| Rockwell International Corporation Energy Systems Group | |
| DESIGNED BY J.A. MILLER 12-9-82 | PANEL ASSY - SOLAR RECEIVER, 30MW POWER STATION DESIGN L/6 |
| DATE 12-10-82 | 079R000001 |
| PAGE 2 OF 2 | |




| REVISIONS | |
|-----------|-------------|
| NO. | DESCRIPTION |
| | |

079TI000001
Page 17

IN WORK
DOCUMENT NOT RELEASED
DATE 12-16-82 BY 2
BY B. Kelly (JAM)
FOR INFO ONLY
FOR STORAGE

| | |
|--|--|
| Rockwell International Corporation Energy Systems Group | |
| DESIGNED BY J. J. MILLER 81-81 | SUPPORT ASSY - SOLAR RECEIVER PANEL DESIGNED L/O |
| DATE E | 079R000003 |
| SCALE | |

1079R000003



| REVISIONS | | |
|-----------|-------------|------|
| NO. | DESCRIPTION | DATE |
| | | |

079TI000001
Page 19

NOTE: UNLESS OTHERWISE SPECIFIED ON THIS DRAWING

SUPPORT PANEL - REMOVABLE
INSTALL FOR SHIPPING AND HANDLING
MATL: 3/4" PLYWOOD WITH 2x4 BASE
6 PLACES

VIEW A - A
SCALE 1" = 1'-0"

0° TO 75° REF
FOR ROTATION TO
VERTICAL LIFT
POSITION

HOIST POSITION FOR
ROTATING FROM HORIZONTAL
TO VERTICAL

HORIZONTAL LIFT POSITION

C.G.
5600 LBS - TOTAL LOAD

079R000001 PANEL ASSY - REF


ROLL BAR - END SUPPORT
WHEN ROTATING TO VERTICAL

LIFTING BAR - REMOVABLE

HOIST POINT FOR VERTICAL LIFT

SIDE ELEVATION
HOIST POINTS FOR HORIZONTAL LIFTS

MINIMUM SUPPORT IN
HORIZONTAL POSITION:
72 IN² 4 PLACES



BOTTOM VIEW

PADS FOR MOUNTING
TO TOWER STRUCTURE (REF)

PANEL SUPPORT STRUCTURE
MATL: 3"x4"x.250 WALL
RECTANGULAR C.S. TUBING
ASTM-A 36

IN WORK
DOCUMENT NOT RELEASED
DATE 1-24-85 BY B. S. (JLM)
FOR INFO ONLY
FOR STORAGE

| | | | |
|--|-------------|------------|--------|
| DESIGNED BY | J.A. MILLER | DATE | 1-7-85 |
| CHECKED BY | | | |
| Rockwell International Corporation Energy Systems Group | | | |
| SOLAR RECEIVER PANEL ASSY. HANDLING AND SHIPPING | | | |
| REV | DESCRIPTION | DATE | |
| E | | | |
| PART NUMBER | | 079R000021 | |
| SCALE | | 1" = 1'-0" | |



2

| REVISIONS | | | |
|-----------|-------------|------|----------|
| LTR | DESCRIPTION | DATE | APPROVED |
| | | | |

079TI000001

Page 20

NOTE: UNLESS OTHERWISE SPECIFIED ON THIS DRAWING



| | |
|------------------------------|-------------------------------------|
| IN WORK | |
| DOCUMENT NOT RELEASED | |
| DATE 1-17-83 | ISSUE NO. 2 |
| MGR. B. Katz (Gum) | |
| FOR INFO ONLY | <input checked="" type="checkbox"/> |
| FOR STORAGE | <input type="checkbox"/> |



| | | | |
|---------------------------|-------------|--|--|
| DR BY J.A. MILLER 1-14-83 | | Rockwell International Corporation Energy Systems Group | |
| CHK BY | | COOLANT FLOW ORIFICE ASSY - SOLAR RECEIVER PANEL | |
| M & P | SIZE D | DRAWING NO. 079R000025 | |
| STRESS | SCALE 2 X 1 | SHEET | |

1079R000025

2

| REVISIONS | | | |
|-------------|-------------|------|----------|
| LTR | DESCRIPTION | DATE | APPROVED |
| 079TI000001 | | | |

Page 21



DETAIL A SCALE 1/4

**IN WORK
DOCUMENT NOT RELEASED**

DATE 2-14-83 ISSUE NO 1

MGR R. Kelly (JAS)

FOR INFO ONLY

FOR STORAGE

FORM 1237 1 REV 7 78

| | | | |
|----------------------------------|--|---|-------------------------------|
| DR BY <u>J.A. MILLER</u> 2-11-83 | | Rockwell International Corporation Energy Systems Group | |
| CHK BY | | TIE BAR ASSY, PANEL SUPPORT - SOLAR RECEIVER | |
| M & P | | DESIGN L/O | |
| STRESS | | SIZE D | DRAWING NO. 079R000028 |
| SCALE 1/4" = 1'-0" | | SHEET | |

1079R000028



3.2 Structural Criteria

3.2.1 Environmental Requirements

The environmental requirements contained in the receiver subsystem specification (Reference 1), are shown in Table 2.

3.2.1.1 Seismic Design Basis

The receiver subsystem is designed to withstand seismic loads derived from the following horizontal and vertical earthquake force formulae:

$$\text{Horizontal Load} = 0.04W$$

$$\text{Vertical Load} = 2/3[0.40W] = 0.27W$$

Where: W = Structural and fluid weight (lbs)

The seismic loads are assumed to act in two horizontal directions and in the vertical direction, simultaneously. The rationale for the application of the above static seismic coefficients is given below:

The Uniform Building Code (Reference 2) provides the following formula for establishing the total lateral force (V) acting on a cantilever type building structure as a function of its weight (W):

$$V = ZIKCSW$$

where Z, I, K, C, S are factors related to the location, foundation, design configuration, importance, etc., of the structure. For the Carrizo Plains location (seismic zone 4), the formula has the value of:

$$V = 0.21W$$

In this formula, the factor ZIKCS may be used as a measure of the equivalent static seismic acceleration at the foundation of the structure.



TABLE 2
ENVIRONMENTAL REQUIREMENTS

| | |
|--|---------------------------------|
| Minimum temperature, °C (°F) | -18 (0) |
| Maximum temperature, °C (°F) | 45 (110) |
| Maximum operating wind (including gusts), ^a m/s (mph) | 13.3 (30) |
| Maximum survival wind (including gusts), ^a m/s (mph) | 40 (90) |
| Seismic environment | Zone 4 |
| Survival earthquake horizontal & vertical acceleration, g | 0.4 (equipment) 0.25 (civil) |
| Maximum dust devil wind speed, m/s (mph) | 18 (45) |
| Maximum static snow load, Pa (lb/ft ²) | 24 (0.5) |
| Maximum snow deposition weight, m/day (in./day) | 0.2 (4) |
| Average annual rainfall, mm (in.) | 88 (8.8) |
| Maximum 24-h rainfall, mm (in.) | TBD (TBD) |
| Hail maximum diameter, mm (in.) | 25 (1) |
| Hail ice deposit, mm (in.) | 25 (1) |
| Hail specific gravity | 0.9 |
| Hail maximum terminal velocity, m/s (fps) | 23 (75) |

^aAt reference height of 10 m (32.8 ft)



A summary of the natural frequency and response spectrum analysis results for a tower of similar size to that proposed for the Carrizo Plains site is contained in Reference 3. Based on the results presented in Figure 6 and Table 2 of Reference 3, a tower amplification factor of 1.57 is indicated when the SRSS acceleration at the centroid of the receiver (0.263g) is compared to the 0.15g zero period ground acceleration (ZPGA). Hence, using a ground acceleration (ZPGA) of 0.21 and an amplification factor of 1.57, the following formula is obtained:

$$\text{Horizontal Load} = 0.21W[1.57] = 0.33W$$

The horizontal load factor of 0.40 used for Carrizo Plains is thus conservative based upon the above rationale.

3.2.1.2 Wind Design Basis

From the receiver subsystem specification, the following wind velocities at 32.8 feet above grade are used in the evaluation of the receiver subsystem:

Maximum Operating Wind, $V_{30} = 30\text{mph}$

Maximum Survival Wind, $V_{90} = 90\text{mph}$

The effective wind velocity pressures on the receiver panels at the midplane height of 410 feet are calculated using the methods presented in ANSI A58.1-1972 (Reference 4). Based on the calculations in Section 6 of the document, the effective wind pressures at the receiver elevation are:

Maximum Operating Wind, $p_{30} = 5.07\text{psf}$

Maximum Survival Wind, $p_{90} = 54.0\text{psf}$



Survival Design Wind Pressure Derivation

Design Wind Velocity = 90 mph

From equation 6.3.4 of ANSI A58.1, the effective velocity pressure is:

$$q_{30} (90\text{mph}) = 0.00256 (90)^2 = 20.736 \text{ psf}$$

The effective velocity pressures of winds for buildings and structures, q_f , at various heights above ground are computed in accordance with the following formulas:

$$q_f = K_z G_f q_{30}$$

where: K_z = Velocity pressure coefficient which depends upon the type of exposure and height, z , above ground

G_f = Gust factors which depend upon the type of exposure and dynamic response

The receiver is assumed to be located in a Type C exposure, therefore from Figure A2 ~~of Reference 4~~:

$$K_z = 2.20$$

The calculation of the gust factor is presented below:

Receiver Mid-Height = 410 feet

Receiver Width = 52 feet

Fundamental Natural Frequency = 10.49Hz

Damping Ratio, = 0.01

Type of Exposure = C

Reference Velocity at 30 feet, $V_{30} = 90$ mph

From Figure A3

$$K_{30} = 1.00$$

$$K_{410} = 2.20$$



From Figure A3

$$T[2h/3] = 0.12$$

From Figure A4

$$1.12 \sqrt{K_{30}} [V_{30}]/f = 1.12 \sqrt{1.0} [90]/10.49 = 9.609$$

Therefore, P, the gust power factor = 0.02

From Figure A5

$$0.88fh/V_{30} \sqrt{K_h} = 0.88[10.49][410]/[90]\sqrt{2.2} = 28.35$$

$$h/c = 410/52 = 7.88$$

Therefore, F, the gust correlation factor = 10^{-4}

From Figure A6

S, the structure size factor = 0.82

Substituting in Equation A3

$$\sigma \sqrt{P} = 1.7[.12] \left[\frac{.785[0.02][10^{-4}]}{0.01} + \frac{.82}{1+.002[52]} \right]^{.5}$$

$$= 0.1758$$

Substituting in Equation A2

$$G_f = .65 + 1.95[.1758] = 0.99$$

The minimum allowable gust response factor is 1.0

The effective velocity wind pressure at 410 feet is:

$$q_f = K_z G_f q_{30} = 2.2[1.0][20.736] = 45.6 \text{ psf}$$

From Table 5, the effective velocity pressure for parts and portions of buildings and structures, q_p , for exposure C will conservatively use for the receiver survival pressure

$$q_f = 54 \text{ psf @ 450 feet} = 0.375 \text{ psi}$$

Maximum Design Operating Wind

Operating wind design velocity = 30 mph



$$q_{30} (30\text{mph}) = 0.00256[30]^2 = 2.304 \text{ psf}$$

$$q_f = K_z G_f q_{30}$$

Where: $K_z = 2.20$ (From 90mph analysis)

$G_f = 1.00$ (From 90mph analysis)

$$q_f = 2.20[1.0][2.304] = 5.07 \text{ psf} = 0.0352 \text{ psi}$$

Nominal Design Wind

Nominal wind design velocity = 8 mph

$$q_{30} (8 \text{ mph}) = .00256[8]^2 = 0.164 \text{ psf}$$

$$q_f = K_z G_f q_{30} = 2.20[1.0][0.164] = 0.361 \text{ psf}$$



3.2.2 Code Requirements

3.2.2.1 Pressure Boundary Analysis Requirements

3.2.2.1.1 ASME Section VIII Requirements (Reference 5)

The receiver tubes, inlet header and the outlet header shall meet the design requirements of ASME, Section VIII, Division 1. The loadings to be considered shall include pressure, dead-weight, seismic and wind. Thermal expansion loads are not required to be included in the Section VIII analysis, but will be considered in the structural criteria of Section 3.2.2.1.3. Allowable stresses for the ASME Section VIII evaluations are presented in Section 3.6.2 of this report

3.2.2.1.2 ANSI B31.1 Analysis Requirements (Reference 6)

The receiver tubes, inlet header and the outlet header shall meet the design requirements of ANSI B31.1-1977 Edition for Power Piping. The loadings to be considered shall include pressure, deadweight, seismic, wind, and restrained thermal expansion. The allowable stresses for the various sustained and occasional loadings are specified in Section 3.6.1 of this report.

3.2.2.1.3 Code Case N-47

The receiver tubes, inlet header and outlet header fatigue and creep damage evaluations shall be performed using ASME Code Case N-47 (Reference 7) as a guide. The creep-fatigue damage fraction allowables are presented in Section 3.6.3 of this report.

3.2.2.2 Non Pressure Boundary Requirements AISC (Reference 8)

The receiver subsystem, except for the pressure boundary components shall be designed in accordance with the American Institute of Steel Construction (AISC). Material yield and ultimate strength properties shall be obtained from accepted sources such as the Military Standardization Handbook (Mil-Hdbk 5B).



3.3 Loading Combinations

The following loading combinations have been used in the evaluation of the receiver subsystem.

3.3.1 Sodium Tubes and Headers

a) Section VIII Analysis

Design Pressure (100psi)
Design Temperature (1050^oF)
Design Wind (30mph)
Design Seismic (0.40g)

b) ANSI B31.1 Analysis

Pressure (30psi)
Temperature (610 to 1050^oF)
Wind (30mph)
Seismic (0.40g)
Thermal Expansion
Thermal Gradients

3.3.2 Balance of Receiver Subsystem

a) AISC Analysis

Temperature (200^oF)
Wind (30mph)
Seismic (0.40g)
Thermal Expansion



3.4 Thermal Environments

The Carrizo Plains receiver panels are designed for a peak incident flux limit of $1.2 \text{ MW}_t/\text{m}^2$. The design operating temperatures for the receiver are 610°F sodium inlet and 1050°F sodium outlet.

Figures 3 and 4 show the reference vertical flux distribution in the thermal window area and the reference lateral flux distribution across the 8 individual panels.

Based upon these figures, thermal analysis, Reference 10, was performed to determine the temperature profiles in the individual receiver tubes. Three areas were investigated in the thermal analysis:

- 1) Outboard edge, panel number 1
- 2) Inboard edge, Panel number 1
- 3) Full Load tube

The results of the thermal analysis are summarized graphically in Figures 5 through 7 and in tabular form in Tables 3 through 5.

The above temperatures were used as a basis for the structural evaluation of the receiver tubes.




FIGURE 3 REFERENCE VERTICAL FLUX DISTRIBUTION - 30 MW_e SOLAR PLANT




FIGURE 4 REFERENCE LATERAL FLUX DISTRIBUTION - 30 MW SOLAR PLANT




FIGURE 5

AXIAL TEMPERATURE DISTRIBUTION

CASE: TUBE AT OUTBOARD EDGE OF PANEL 1

$(Q/A) = 0.225 \text{ MW/m}^2$

$h(\text{Na})_o = 4700 \text{ BTU/hr ft}^2 \text{ }^\circ\text{F}$

T(Pk) = Peak Metal Temperature

T(Na) = Sodium Temperature

$\bar{T}(\text{met})$ = Mean Metal Temperature

$T(\text{"front"}) = \bar{T}(\text{met}) + \Delta T_i/2$

$T(\text{"back"}) = \bar{T}(\text{met}) - \Delta T_i/2$

$T(\text{Na-in}) = 610 \text{ F}$

$T(\text{Na-out}) = 1050 \text{ F}$



Table 3

CASE: OUTBOARD PANEL 1

$$(Q/A)_0 = 0.225 \frac{MW}{m^2}$$

- ① $(\bar{T}_{MET} - T_{Na})_0 = 9.94^\circ$
- ② $(\Delta T_1)_0 = 33.133^\circ$
- ③ $(T_{PK} - T_{Na})_0 = 43.17^\circ$
- ④ $(T_{PK} - \bar{T}_{MET})_0 = 33.23^\circ$
- ⑤ $(\Delta T_2)_0 = 16.662^\circ$

| ⑥ | ① | ② | ③ | ④ | ⑤ | ⑥ | ⑦ | ⑧ | ⑨ | ⑩ |
|----|-----------------------|-----------|--------------------|-----------------|------------------------|-----------------|----------------|---------------|----------------------------------|-----------------|
| Z | $T_{Na}(Z)$ SODIUM | $\Phi(Z)$ | $\bar{T}_{MET}(Z)$ | $\Delta T_1(Z)$ | $\frac{\Delta T_1}{Z}$ | T(Z) "FRONT" | T(Z) "BACK" | $T_{PEAK}(Z)$ | $(T_{PK} - \bar{T}_{MET})_{(Z)}$ | $\Delta T_2(Z)$ |
| 0 | 610.00 | .135335 | 611.35 | 4.48 | 2.24 | 613.59 | 609.10 | 615.84 | 4.50 | 2.75 |
| 1 | 612.75 | .164474 | 614.38 | 5.45 | 2.72 | 617.11 | 611.66 | 619.85 | 5.47 | 2.74 |
| 2 | 616.08 | .197899 | 618.05 | 6.56 | 3.28 | 621.33 | 614.77 | 624.62 | 6.58 | 3.30 |
| 3 | 620.06 | .235746 | 622.40 | 7.81 | 3.91 | 626.31 | 618.50 | 630.24 | 7.83 | 3.93 |
| 4 | 624.77 | .278037 | 627.53 | 9.21 | 4.61 | 632.14 | 622.93 | 636.77 | 9.24 | 4.63 |
| 5 | 630.31 | .324652 | 633.54 | 10.76 | 5.38 | 638.92 | 628.16 | 644.33 | 10.79 | 5.41 |
| 6 | 636.74 | .375311 | 640.47 | 12.44 | 6.22 | 646.69 | 634.25 | 652.94 | 12.47 | 6.25 |
| 7 | 644.14 | .429557 | 648.41 | 14.23 | 7.12 | 655.53 | 641.29 | 662.68 | 14.27 | 7.16 |
| 8 | 652.56 | .486752 | 657.40 | 16.13 | 8.06 | 665.46 | 649.33 | 673.57 | 16.17 | 8.11 |
| 9 | 662.05 | .546074 | 667.48 | 18.09 | 9.05 | 676.52 | 658.43 | 685.62 | 18.15 | 9.10 |
| 10 | 672.65 | .606531 | 678.68 | 20.10 | 10.05 | 688.73 | 668.63 | 698.83 | 20.16 | 10.11 |
| 11 | 684.36 | .666977 | 690.99 | 22.10 | 11.05 | 702.04 | 679.94 | 713.15 | 22.16 | 11.11 |
| 12 | 697.17 | .726149 | 704.39 | 24.06 | 12.03 | 716.42 | 692.36 | 728.52 | 24.13 | 12.10 |
| 13 | 711.05 | .782705 | 718.83 | 25.93 | 12.97 | 731.80 | 705.86 | 744.84 | 26.01 | 13.04 |
| 14 | 725.94 | .835270 | 734.24 | 27.68 | 13.84 | 748.08 | 720.41 | 762.00 | 27.76 | 13.92 |
| 15 | 741.74 | .882497 | 750.51 | 29.24 | 14.62 | 765.13 | 735.89 | 779.84 | 29.33 | 14.70 |
| 16 | 758.35 | .923116 | 767.53 | 30.59 | 15.29 | 782.82 | 752.23 | 798.20 | 30.68 | 15.38 |
| 17 | 775.65 | .955997 | 785.15 | 31.68 | 15.84 | 800.99 | 769.32 | 816.92 | 31.77 | 15.93 |
| 18 | 793.46 | .980199 | 803.20 | 32.48 | 16.24 | 819.44 | 786.96 | 835.78 | 32.57 | 16.33 |
| 19 | 811.64 | .995012 | 821.53 | 32.97 | 16.48 | 838.01 | 805.05 | 854.59 | 33.06 | 16.58 |
| 20 | 830.00 | 1.00 | 839.94 | 33.13 | 16.57 | 856.51 | 823.37 | 873.17 | 33.23 | 16.66 |
| 21 | 848.36 | .995012 | 858.27 | 32.97 | 16.48 | 874.75 | 841.79 | 891.33 | 33.06 | 16.58 |
| 22 | 866.54 | .980199 | 876.28 | 32.48 | 16.24 | 892.52 | 860.04 | 908.86 | 32.57 | 16.33 |
| 23 | 884.35 | .955997 | 893.85 | 31.68 | 15.84 | 909.69 | 878.02 | 925.62 | 31.77 | 15.93 |
| 24 | 901.65 | .923116 | 910.83 | 30.59 | 15.29 | 926.12 | 895.53 | 941.50 | 30.68 | 15.38 |
| 25 | 918.26 | .882497 | 927.03 | 29.24 | 14.62 | 941.65 | 912.41 | 956.36 | 29.33 | 14.70 |
| 26 | 934.06 | .835270 | 942.36 | 27.68 | 13.84 | 956.20 | 928.53 | 970.12 | 27.76 | 13.92 |
| 27 | 948.95 | .782705 | 956.73 | 25.93 | 12.97 | 969.70 | 943.76 | 982.74 | 26.01 | 13.04 |
| 28 | 962.83 | .726149 | 970.05 | 24.06 | 12.03 | 982.08 | 958.02 | 994.18 | 24.13 | 12.10 |
| 29 | 975.64 | .666977 | 982.27 | 22.10 | 11.05 | 993.32 | 971.22 | 1004.43 | 22.16 | 11.11 |
| 30 | 987.35 | .606531 | 993.38 | 20.10 | 10.05 | 1003.43 | 983.33 | 1013.53 | 20.16 | 10.11 |
| 31 | 997.45 | .546074 | 1003.38 | 18.09 | 9.05 | 1012.42 | 994.33 | 1021.52 | 18.15 | 9.10 |
| 32 | 1007.44 | .486752 | 1012.28 | 16.13 | 8.06 | 1020.34 | 1004.21 | 1028.45 | 16.17 | 8.11 |
| 33 | 1015.86 | .429557 | 1020.13 | 14.23 | 7.12 | 1027.25 | 1013.01 | 1034.40 | 14.27 | 7.16 |
| 34 | 1023.26 | .375311 | 1026.44 | 12.44 | 6.22 | 1033.21 | 1020.77 | 1039.46 | 12.47 | 6.25 |
| 35 | 1029.69 | .324652 | 1032.42 | 10.76 | 5.38 | 1038.30 | 1027.54 | 1043.71 | 10.79 | 5.41 |
| 36 | 1035.23 | .278037 | 1037.49 | 9.21 | 4.61 | 1042.60 | 1033.39 | 1047.23 | 9.24 | 4.63 |
| 37 | 1039.94 | .235746 | 1042.28 | 7.81 | 3.91 | 1046.19 | 1038.38 | 1050.12 | 7.83 | 3.93 |
| 38 | 1043.92 | .197899 | 1045.89 | 6.56 | 3.28 | 1049.17 | 1042.61 | 1052.46 | 6.58 | 3.30 |
| 39 | 1047.25 | .164474 | 1048.88 | 5.45 | 2.72 | 1051.61 | 1046.16 | 1054.35 | 5.47 | 2.74 |
| 40 | 1050.00 | .135335 | 1051.35 | 4.48 | 2.24 | 1053.59 | 1049.10 | 1055.84 | 4.50 | 2.25 |






Table 4

CASE: INBOARD; PANEL 1

$(q/A)_0 = 0.97 \text{ MW/m}^2$

(21) $(\bar{T}_{MET} - T_{Na})_d = 35.16^\circ$

(22) $(\Delta T_1)_d = 117.57^\circ$

(23) $(T_{PK} - T_{Na})_d = 160.50^\circ$

(24) $(T_{PK} - \bar{T}_{MET})_d = 125.34^\circ$

(25) $(\Delta T_2)_d = 66.558^\circ$

| (2) | (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) |
|-----|-----------------------|-----------|--------------------|-----------------|------------------------|-----------------|----------------|--------------|----------------------------|-----------------|
| Z | $T_{Na}(z)$ SODIUM | $\phi(z)$ | $\bar{T}_{MET}(z)$ | $\Delta T_1(z)$ | $\frac{\Delta T_1}{2}$ | T(z) "FRONT" | T(z) "BACK" | T(z) PEAK | $(T_{PK} - \bar{T}_{MET})$ | $\Delta T_2(z)$ |
| 0 | 610.0 | .135335 | 614.76 | 15.91 | 7.96 | 622.71 | 606.80 | 631.72 | 16.96 | 9.01 |
| 1 | 612.75 | .164474 | 618.53 | 19.34 | 9.67 | 628.20 | 608.86 | 639.15 | 20.62 | 10.95 |
| 2 | 616.08 | .197899 | 623.04 | 23.27 | 11.63 | 634.67 | 611.40 | 647.84 | 24.80 | 13.17 |
| 3 | 620.06 | .235746 | 628.35 | 27.72 | 13.86 | 642.21 | 614.49 | 657.90 | 29.55 | 15.69 |
| 4 | 624.77 | .278037 | 634.55 | 32.69 | 16.34 | 650.89 | 618.20 | 669.39 | 34.85 | 18.51 |
| 5 | 630.31 | .324652 | 641.72 | 38.17 | 19.08 | 660.81 | 622.64 | 682.42 | 40.69 | 21.61 |
| 6 | 636.74 | .375311 | 649.94 | 44.13 | 22.06 | 672.00 | 627.87 | 696.98 | 47.04 | 24.98 |
| 7 | 644.14 | .429557 | 659.24 | 50.50 | 25.25 | 684.49 | 633.99 | 713.08 | 53.84 | 28.59 |
| 8 | 652.56 | .486752 | 669.67 | 57.23 | 28.61 | 698.29 | 641.06 | 730.68 | 61.01 | 32.40 |
| 9 | 662.05 | .546074 | 681.25 | 64.20 | 32.10 | 713.35 | 649.15 | 749.69 | 68.44 | 36.35 |
| 10 | 672.65 | .606531 | 693.98 | 71.31 | 35.65 | 729.63 | 658.32 | 770.00 | 76.02 | 40.37 |
| 11 | 684.36 | .666977 | 707.81 | 78.42 | 39.21 | 747.02 | 668.60 | 791.41 | 83.60 | 44.39 |
| 12 | 697.17 | .726149 | 722.71 | 85.37 | 42.69 | 765.40 | 680.02 | 813.73 | 91.02 | 48.33 |
| 13 | 711.05 | .782705 | 738.57 | 92.02 | 46.01 | 784.58 | 692.56 | 836.67 | 98.10 | 52.10 |
| 14 | 725.94 | .835270 | 755.31 | 98.20 | 49.10 | 804.41 | 706.21 | 860.00 | 104.69 | 55.59 |
| 15 | 741.74 | .882497 | 772.77 | 103.76 | 51.88 | 824.65 | 720.89 | 883.38 | 110.61 | 58.74 |
| 16 | 758.35 | .923116 | 790.81 | 108.53 | 54.27 | 845.07 | 736.54 | 906.51 | 115.70 | 61.44 |
| 17 | 775.65 | .955997 | 809.26 | 112.40 | 56.20 | 865.46 | 753.06 | 929.09 | 119.82 | 63.63 |
| 18 | 793.46 | .980199 | 827.92 | 115.24 | 57.62 | 885.54 | 770.30 | 950.78 | 122.86 | 65.24 |
| 19 | 811.64 | .995012 | 846.62 | 116.98 | 58.49 | 905.12 | 788.13 | 971.34 | 124.71 | 66.23 |
| 20 | 830.00 | 1.00 | 865.16 | 117.57 | 58.79 | 923.95 | 806.38 | 990.50 | 125.34 | 66.56 |
| 21 | 848.36 | .995012 | 883.34 | 116.98 | 58.49 | 941.84 | 824.85 | 1008.06 | 124.71 | 66.23 |
| 22 | 866.54 | .980199 | 901.00 | 115.24 | 57.62 | 958.62 | 843.38 | 1023.86 | 122.86 | 65.24 |
| 23 | 884.35 | .955997 | 917.96 | 112.40 | 56.20 | 974.16 | 861.76 | 1037.79 | 119.82 | 63.63 |
| 24 | 901.65 | .923116 | 934.11 | 108.53 | 54.27 | 988.37 | 879.84 | 1049.81 | 115.70 | 61.44 |
| 25 | 918.26 | .882497 | 949.29 | 103.76 | 51.88 | 1001.17 | 897.41 | 1059.90 | 110.61 | 58.74 |
| 26 | 934.06 | .835270 | 963.43 | 98.20 | 49.10 | 1012.53 | 914.33 | 1068.12 | 104.69 | 55.59 |
| 27 | 948.95 | .782705 | 976.47 | 92.02 | 46.01 | 1022.48 | 930.46 | 1074.57 | 98.10 | 52.10 |
| 28 | 962.83 | .726149 | 988.36 | 85.37 | 42.69 | 1031.05 | 945.67 | 1079.38 | 91.02 | 48.33 |
| 29 | 975.64 | .666977 | 999.09 | 78.42 | 39.21 | 1038.30 | 959.88 | 1082.69 | 83.60 | 44.39 |
| 30 | 987.35 | .606531 | 1008.68 | 71.31 | 35.65 | 1044.33 | 973.02 | 1084.70 | 76.02 | 40.37 |
| 31 | 997.95 | .546074 | 1017.15 | 64.20 | 32.10 | 1049.25 | 985.05 | 1085.59 | 68.44 | 36.35 |
| 32 | 1007.44 | .486752 | 1024.55 | 57.23 | 28.61 | 1053.17 | 995.94 | 1085.56 | 61.01 | 32.40 |
| 33 | 1015.86 | .429557 | 1030.96 | 50.50 | 25.25 | 1056.21 | 1005.71 | 1084.80 | 53.84 | 28.59 |
| 34 | 1023.26 | .375311 | 1036.46 | 44.13 | 22.06 | 1058.52 | 1014.39 | 1083.50 | 47.04 | 24.98 |
| 35 | 1029.69 | .324652 | 1041.10 | 38.17 | 19.08 | 1060.19 | 1022.02 | 1081.80 | 40.69 | 21.61 |
| 36 | 1035.23 | .278037 | 1045.00 | 32.69 | 16.34 | 1061.35 | 1028.66 | 1079.85 | 34.85 | 18.51 |
| 37 | 1039.94 | .235746 | 1048.23 | 27.72 | 13.86 | 1062.09 | 1034.37 | 1077.78 | 29.55 | 15.69 |
| 38 | 1043.92 | .197899 | 1050.88 | 23.27 | 11.63 | 1062.51 | 1039.24 | 1075.68 | 24.80 | 13.17 |
| 39 | 1047.25 | .164474 | 1053.03 | 19.34 | 9.67 | 1062.70 | 1043.36 | 1073.65 | 20.62 | 10.95 |
| 40 | 1050.00 | .135335 | 1054.76 | 15.91 | 7.96 | 1062.71 | 1046.80 | 1071.72 | 16.96 | 9.01 |






Table 5

CASE: "FULL LOAD" TUBE
(Q/A) = 1.20 MW/m²

- ② $(\bar{T}_{MET} - T_{Na})_z = 41.74$
- ②② $(\Delta T_1)_z = 139.66$
- ②③ $(T_{PK} - T_{Na})_z = 192.50$
- ②④ $(T_{PK} - \bar{T}_{MET})_z = 150.76$
- ②⑤ $(\Delta T_2)_z = 80.98$

| ② Z LOCATION (FT) | ① T _{Na} (z) SODIUM | ② Φ(z) NORMALIZED ALTITUDE OF Δ CURVE | ③ T _{MET} (z) MEAN METAL TEMP | ④ ΔT ₁ (z) | ⑤ ΔT ₁ / 2 | ⑥ T _{FRONT} (z) | ⑦ T _{BACK} (z) | ⑧ T _{PEAK} (z) | ⑨ (T _{PK} - T _{MET}) (z) | ⑩ ΔT ₂ (z) |
|----------------------------|------------------------------------|---|--|--------------------------|-----------------------------|-----------------------------|----------------------------|----------------------------|---|--------------------------|
| 0 | 610.00 | .135335 | 615.65 | 18.90 | 9.45 | 625.10 | 606.20 | 636.05 | 20.40 | 10.96 |
| 1 | 612.75 | .164474 | 619.62 | 22.97 | 11.49 | 631.10 | 608.13 | 644.41 | 24.80 | 13.32 |
| 2 | 616.08 | .197899 | 624.34 | 27.64 | 13.82 | 638.16 | 610.52 | 654.18 | 29.84 | 16.03 |
| 3 | 620.06 | .235746 | 629.90 | 32.92 | 16.46 | 646.36 | 613.44 | 665.44 | 35.55 | 19.09 |
| 4 | 624.77 | .278037 | 636.38 | 38.83 | 19.42 | 655.79 | 616.96 | 678.29 | 41.93 | 22.52 |
| 5 | 630.31 | .324652 | 643.86 | 45.34 | 22.67 | 666.53 | 621.19 | 692.81 | 48.96 | 26.29 |
| 6 | 636.74 | .375311 | 652.41 | 52.42 | 26.21 | 678.61 | 626.20 | 708.99 | 56.60 | 30.39 |
| 7 | 644.14 | .429557 | 662.07 | 59.99 | 30.00 | 692.07 | 632.07 | 726.83 | 64.78 | 34.79 |
| 8 | 652.56 | .486752 | 672.88 | 67.98 | 33.99 | 706.87 | 638.89 | 746.26 | 73.40 | 39.42 |
| 9 | 662.05 | .546074 | 684.84 | 76.26 | 38.13 | 722.98 | 646.71 | 767.17 | 82.35 | 44.22 |
| 10 | 672.65 | .606531 | 697.97 | 84.71 | 42.35 | 740.32 | 655.61 | 789.91 | 91.46 | 49.12 |
| 11 | 684.36 | .666977 | 712.20 | 93.15 | 46.58 | 758.77 | 665.62 | 812.75 | 100.58 | 54.01 |
| 12 | 697.17 | .726149 | 727.48 | 101.41 | 50.71 | 778.19 | 676.77 | 836.95 | 109.50 | 58.80 |
| 13 | 711.05 | .782705 | 743.72 | 109.31 | 54.66 | 798.38 | 689.06 | 861.72 | 118.03 | 63.38 |
| 14 | 725.94 | .835270 | 760.80 | 116.65 | 58.33 | 819.13 | 702.48 | 886.73 | 125.96 | 67.64 |
| 15 | 741.74 | .882497 | 778.57 | 123.25 | 61.62 | 840.20 | 716.95 | 911.62 | 133.08 | 71.46 |
| 16 | 758.35 | .923116 | 796.88 | 128.92 | 64.46 | 861.34 | 732.42 | 936.05 | 139.21 | 74.75 |
| 17 | 775.65 | .955997 | 815.55 | 133.51 | 66.76 | 882.31 | 748.80 | 959.68 | 144.16 | 77.42 |
| 18 | 793.46 | .980199 | 834.37 | 136.89 | 68.45 | 902.82 | 765.93 | 982.15 | 147.81 | 79.38 |
| 19 | 811.64 | .995012 | 853.17 | 138.96 | 69.48 | 922.65 | 783.69 | 1003.18 | 150.05 | 80.58 |
| 20 | 830.00 | 1.00 | 871.74 | 139.66 | 69.83 | 941.57 | 801.91 | 1022.50 | 150.76 | 80.98 |
| 21 | 848.36 | .995012 | 889.89 | 138.96 | 69.48 | 959.37 | 820.41 | 1039.90 | 150.05 | 80.58 |
| 22 | 866.54 | .980199 | 907.45 | 136.89 | 68.45 | 975.90 | 839.01 | 1055.23 | 147.81 | 79.38 |
| 23 | 884.35 | .955997 | 924.25 | 133.51 | 66.76 | 991.01 | 857.50 | 1068.38 | 144.16 | 77.42 |
| 24 | 901.65 | .923116 | 940.18 | 128.92 | 64.46 | 1004.64 | 875.72 | 1079.35 | 139.21 | 74.75 |
| 25 | 918.26 | .882497 | 955.10 | 123.25 | 61.62 | 1016.72 | 893.47 | 1088.14 | 133.08 | 71.46 |
| 26 | 934.06 | .835270 | 968.92 | 116.65 | 58.33 | 1027.25 | 910.60 | 1094.85 | 125.96 | 67.64 |
| 27 | 948.95 | .782705 | 981.62 | 109.31 | 54.66 | 1036.28 | 926.96 | 1099.62 | 118.03 | 63.38 |
| 28 | 962.83 | .726149 | 993.14 | 101.41 | 50.71 | 1043.85 | 942.93 | 1102.61 | 109.50 | 58.80 |
| 29 | 975.64 | .666977 | 1003.48 | 93.15 | 46.58 | 1050.05 | 956.90 | 1104.03 | 100.58 | 54.01 |
| 30 | 987.35 | .606531 | 1012.67 | 84.71 | 42.35 | 1055.02 | 970.31 | 1104.11 | 91.46 | 49.12 |
| 31 | 997.95 | .546074 | 1020.74 | 76.26 | 38.13 | 1058.82 | 982.61 | 1103.07 | 82.35 | 44.22 |
| 32 | 1007.44 | .486752 | 1027.76 | 67.98 | 33.99 | 1061.75 | 993.77 | 1101.14 | 73.40 | 39.42 |
| 33 | 1015.86 | .429557 | 1033.79 | 59.99 | 30.00 | 1063.79 | 1003.79 | 1098.55 | 64.78 | 34.79 |
| 34 | 1023.26 | .375311 | 1038.93 | 52.42 | 26.21 | 1065.13 | 1012.72 | 1095.51 | 56.60 | 30.39 |
| 35 | 1029.69 | .324652 | 1043.24 | 45.34 | 22.67 | 1065.91 | 1020.57 | 1092.19 | 48.96 | 26.29 |
| 36 | 1035.23 | .278037 | 1046.84 | 38.83 | 19.42 | 1066.25 | 1027.42 | 1088.75 | 41.93 | 22.52 |
| 37 | 1039.94 | .235746 | 1049.78 | 32.92 | 16.46 | 1066.24 | 1033.32 | 1085.32 | 35.55 | 19.09 |
| 38 | 1043.92 | .197899 | 1052.18 | 27.64 | 13.82 | 1066.00 | 1038.36 | 1082.02 | 29.84 | 16.03 |
| 39 | 1047.25 | .164474 | 1054.12 | 22.97 | 11.49 | 1065.60 | 1042.63 | 1078.91 | 24.80 | 13.32 |
| 40 | 1050.00 | .135335 | 1055.65 | 18.90 | 9.45 | 1065.10 | 1046.20 | 1076.05 | 20.40 | 10.96 |



3.5 Material Properties

The properties for the materials of construction of the receiver subsystem are presented in Table 6. References for the properties are also presented.

Material Properties
Table 6

| Component | Material | Temp. oF | F _y ksi | F _{ult} ksi | E ksi | α in/in ^o F | |
|---------------|-------------------------------------|--------------|-----------------------|-------------------------|--------------|----------------------------------|--|
| Sodium Tubes | ASME SA-213TP316 Stainless Steel | 610- 1050 | See Fig. 8 | | See Fig.8 | See Fig. 9 | |
| Tangs | ASTM Type 304 Stainless Steel | 200- 1050 | 25.8 | | | | |
| Hatbands | ASTM A366 Carbon Steel | R.T. | 28.0 | | | | |
| Support Rods | ASTM A519 (1020) Low Alloy Steel | R.T. | 28.0 | | | | |
| Headers | ASME TP 316 Stainless Steel | 610- 1050 | See Fig.8 | | See Fig.8 | See Fig. 9 | |
| Support Beams | ASTM Type 304 Stainless Steel | 200 | 25.0 | | | | |
| Support Truss | ASTM A36 Carbon Steel | R.T. | 36.0 | | | | |







Figure 8



Instantaneous Coefficient of Thermal Expansion

Figure 9



3.6 Allowable Stresses

3.6.1 ANSI B31.1 Power Piping Stress Allowables

The requirements of either Equation 13A or Equation 14 in section 104.8.3 shall be met:

- a. Thermal Expansion (S_E)

$$S_E = \frac{iMc}{Z} = S_A$$

where: i = Stress Intensification Factor (Appendix D)

The product, $0.75i$, shall never be taken as less than 1.0

Z = Section Modulus, in^3

Mc = Range of resultant moments due to thermal expansion

S_A = The allowable stress range for expansion stresses

- b. Thermal Expansion + Sustained Loads

The effects of pressure, weight, and other sustained loads and thermal expansion must meet the requirements of Equation 14

$$S_{TE} = \frac{PDo}{4t_n} + \frac{.75iMa}{Z} + \frac{iMc}{Z} \leq S_H + S_A$$

where: p = Internal Design Pressure, psig

Do = Outside diameter of pipe, inches

t_n = Nominal wall thickness, inches

Ma = Resultant moment loading on cross-section due to weight and other sustained loads, inch-pounds

S_h = Basic material allowable stress at maximum temperature from allowable stress tables, psi

The allowable stresses for the receiver tubes vary depending if the tube is in the thermal window area or if it is in the shielded area with trace heating at 425°F. The allowable stresses are obtained from Reference 6 , ANSI B31.1.1-1977 Appendix A, Table A-3.

Thermal Window Area

| Temperature °F | S_h ksi | S_a ksi | $S_a + S_h$ ksi |
|-------------------|--------------|--------------|--------------------|
| -20 to 100 | 18.70 | 19.64 | 38.34 |
| 200 | 18.70 | 19.64 | 38.34 |
| 300 | 18.30 | 19.57 | 37.87 |
| 400 | 18.00 | 19.51 | 37.51 |
| 500 | 17.90 | 19.50 | 37.40 |
| 600 | 17.00 | 19.34 | 36.34 |
| 650 | 16.60 | 19.27 | 35.87 |
| 700 | 16.30 | 19.22 | 35.52 |
| 750 | 16.00 | 19.16 | 35.16 |
| 800 | 15.80 | 19.13 | 34.93 |
| 850 | 15.70 | 19.11 | 34.81 |
| 900 | 15.50 | 19.08 | 34.58 |
| 950 | 15.40 | 19.06 | 34.36 |
| 1000 | 15.30 | 19.04 | 34.34 |
| 1050 | 14.50 | 18.90 | 33.40 |
| 1100 | 12.40 | 18.53 | 30.93 |



Shielded Area

| Temperature °F | S _h ksi | S _a ksi | S _a + S _h ksi |
|-------------------|-----------------------|-----------------------|--|
| -20 to 100 | 18.70 | 28.05 | 46.75 |
| 200 | 18.70 | 28.05 | 46.75 |
| 300 | 18.30 | 27.95 | 46.25 |
| 400 | 18.00 | 27.88 | 45.88 |
| 500 | 17.90 | 27.85 | 45.75 |
| 600 | 17.00 | 27.63 | 44.63 |
| 650 | 16.60 | 27.53 | 44.13 |
| 700 | 16.30 | 27.45 | 43.75 |
| 750 | 16.00 | 27.38 | 43.38 |
| 800 | 15.80 | 27.33 | 43.13 |
| 850 | 15.70 | 27.30 | 43.00 |
| 900 | 15.50 | 27.25 | 42.75 |
| 950 | 15.40 | 27.23 | 42.63 |
| 1000 | 15.30 | 27.20 | 42.50 |
| 1050 | 14.50 | 27.00 | 41.50 |
| 1100 | 12.40 | 26.48 | 38.88 |

The allowable stresses are based upon the following ANSI B31.1 equations:

$$S_a = f[1.25S_c + 0.25S_h]$$

where: S_c = Basic material allowable stress at cold temperature from the allowable stress tables



S_h = Basic material allowable stress at (hot) temperature from the allowable stress tables

f = Stress range reduction factor for cyclic conditions for total number, N , of full temperature cycles over total number of years during which system is expected to be in operation, from Table 102.3.2,C of ANSI B31.1

The value of "f" for the thermal window area and the shielded area is given below:

Thermal Window Area

Number of cycles for 30 years are:

22,000 full range70°F to 1050°F

28,000 hold periods610°F to 1050°F

The equivalent full temperature cycles is

$$N = N_E + r_1^5 N_1$$

where: N_E = Number of cycles at full temperature change ΔT_E for which expansion stress S_E has been calculated.

N_1 = Number of cycles at lesser temperature changes ΔT_1

$$r_1 = \frac{\Delta T_1}{\Delta T_E}$$

N_E = 22,000 cycles

N_1 = 28,000 cycles

T_E = 980°F

T_1 = 440°F

$$r_1 = \frac{440}{980} = 0.449$$

$$N = 22,000 + [.449]^5 [28,000] = 22,510 \text{ cycles}$$

From Table 102.3.2,c, of ANSI B 31.1, $f = 0.70$

Shielded Area

Number of cycles for 30 years are:

50,000 partial range*.....425^oF to 1050^oF

$$r_1 = \frac{\Delta T_1}{\Delta T_E} = \frac{1050 - 425}{1050 - 70} = \frac{625}{980} = .638$$

$$N = [.638]^5 [50,000] = 5285 \text{ cycles}$$

From Table 102.3.2,c, of ANSI B31.1, $f = 1.0$

* Trace heated Area



3.6.2 ASME Section VIII Allowable Stresses

Maximum allowable stress values in Tension for High Alloy Steel

Material: SA-213 TP316 Smls Tube, 16Cr-12Ni-2Mo

Reference: ASME Section VIII, Division 1, Table UHA-23

Yield Strength @ Room Temperature = 30 ksi

Tensile Strength @ Room Temperature = 75 ksi

| Temperature °F | Allowable Stress KSI |
|-------------------|-------------------------|
| -20 to 100 | 18.80 |
| 200 | 18.80 |
| 300 | 18.40 |
| 400 | 18.10 |
| 500 | 18.00 |
| 600 | 17.00 |
| 650 | 16.70 |
| 700 | 16.30 |
| 750 | 16.10 |
| 800 | 15.90 |
| 850 | 15.70 |
| 900 | 15.50 |
| 950 | 15.40 |
| 1000 | 15.30 |
| 1050 | 14.50 |
| 1100 | 12.40 |



3.6.3 Creep-Fatigue Damage Fraction Allowables

The receiver tubes creep-fatigue evaluations for life predictions are based on the criteria presented in ASME Code Case N-47 (Reference 7)

The tube stresses are evaluated for accumulated creep and fatigue damage including hold time and strain rate effects. For a design to be acceptable, the creep and fatigue damage fraction shall satisfy the following relation:

$$\sum \left(\frac{n}{N_d} \right) + \sum \left(\frac{t}{T_d} \right) \leq D \leq 1.0$$

Where D = Total creep-fatigue damage fraction

n = Number of applied cycles of loading

N_d = Number of design allowable cycles


T_d = Allowable time at a given stress intensity
or at a given effective stress (for inelastic
analysis)

The number of applied cycles of loading is shown in Figure 10. The total number of cycles is 50,000. Of this number, 22,000 cycles are for startup/shutdown for 30 years while 28,000 cycles are for low power operation.

Figures 11 and 12 present the design creep stress to rupture curve and the design fatigue curve. From the ASME Criteria document (Reference 9), the design stress values were obtained from the best fit curves by applying a factor of two on stress or a factor of twenty on cycles, whichever was more conservative at each point. For the Carrizo Plains Solar Receiver it is felt that the conservative factor used for Nuclear Plants is not required. Therefore, the allowable design values used

Carrizo Plains Solar Receiver
 Cyclic Histogram
 Figure 10

- | | |
|-----------------------------|--|
| ① Dry Preheat - 10 minutes | ⑦ Drain - 2 minutes |
| ② Fill - 2 minutes | ⑧ Cool Down - 30 minutes |
| ③ Power Buildup - 5 minutes | Number Startup/Shutdown Cycles per 30 years = 22000 |
| ④ Operating - 441 minutes | Number Low Power Cycles per 30 Year = 28000 |
| ⑤ Cool Down - 5 minutes | Operating Hours per Day = 10 |
| ⑥ Hold - 10 minutes | |



CASES OF ASME BOILER AND PRESSURE VESSEL CODE

Table I-14.6B

Expected Minimum Stress-to-Rupture Values, 1000 psi
Type 316 SS

| Temp., °F | 1 hr | 10 hr | 30 hr | 10 ² hr | 3 × 10 ² hr | 10 ³ hr | 3 × 10 ³ hr | 10 ⁴ hr | 3 × 10 ⁴ hr | 10 ⁵ hr | 3 × 10 ⁵ hr |
|-----------|------|-------|-------|--------------------|------------------------|--------------------|------------------------|--------------------|------------------------|--------------------|------------------------|
| 800 | 64.5 | 64.5 | 64.5 | 64.5 | 64.5 | 64.5 | 64.5 | 64.5 | 64.5 | 64.5 | 64.5 |
| 850 | 63.3 | 63.3 | 63.3 | 63.3 | 63.3 | 63.3 | 63.3 | 63.3 | 60 | 56 | 52 |
| 900 | 62.2 | 62.2 | 62.2 | 62.2 | 62.1 | 62 | 58 | 54.1 | 48 | 42.6 | 38 |
| 950 | 60 | 60 | 60 | 60 | 56 | 51.6 | 46.5 | 42.6 | 37.5 | 32.4 | 28.3 |
| 1000 | 58.5 | 58.5 | 55 | 51.7 | 47 | 42.1 | 37.5 | 33.6 | 28.8 | 24.6 | 21 |
| 1050 | 56 | 52.9 | 47.5 | 43.4 | 38.2 | 34.4 | 30.2 | 26.4 | 22.3 | 18.8 | 16 |
| 1100 | 53.5 | 45.1 | 40 | 36.4 | 32.2 | 28.1 | 24.2 | 20.8 | 17.3 | 14.3 | 11.7 |
| 1150 | 46.5 | 38.4 | 34 | 30.5 | 26.6 | 23.0 | 19.5 | 16.4 | 13.4 | 10.9 | 8.8 |
| 1200 | 40 | 32.7 | 29 | 25.6 | 22 | 18.8 | 15.6 | 12.9 | 10.3 | 8.3 | 6.7 |
| 1250 | 35 | 27.8 | 24.3 | 21.4 | 18.1 | 15.4 | 12.7 | 10.2 | 8.1 | 6.3 | 4.9 |
| 1300 | 30 | 23.7 | 20.8 | 18.0 | 15 | 12.5 | 10.0 | 8.0 | 6.2 | 4.8 | 3.7 |
| 1350 | 26 | 20.0 | 17.5 | 15.0 | 12.7 | 10.4 | 8.2 | 6.4 | 4.9 | 3.6 | 2.7 |
| 1400 | 22.5 | 17.1 | 14.8 | 12.4 | 10.2 | 8.4 | 6.6 | 5.0 | 3.8 | 2.8 | 2.1 |
| 1450 | 19.5 | 14.6 | 12.6 | 10.5 | 8.6 | 6.8 | 5.2 | 3.9 | 2.9 | 2.1 | 1.5 |
| 1500 | 17 | 12.5 | 10.6 | 8.8 | 7.2 | 5.6 | 4.2 | 3.1 | 2.3 | 1.6 | 1.2 |




Fig. I-14.6B Stress-to-rupture (minimum)





CASES OF ASME BOILER AND PRESSURE VESSEL CODE




Fig. T-1430-1A,1B Design fatigue strain range, ϵ_f , 304 SS and 316 SS – elastic analysis

Table T-1430-1A, 1B

Design Fatigue Strain Range, ϵ_f , for 304 SS and 316 SS (Elastic Analysis)

| N_d Number of Cycles | ϵ_f , Strain Range (in./in.) at Temperature | | | | |
|------------------------------|--|--------|---------|---------|-------------|
| | 800 F | 850 F | 900 F | 950 F | 1000-1200 F |
| 10^1 | .0448 | .0303 | .0201 | .0137 | .00915 |
| 2×10^1 | .0318 | .020 | .0124 | .0078 | .00472 |
| 4×10^1 | .0231 | .0145 | .00867 | .0051 | .00322 |
| 10^2 | .0168 | .00982 | .00587 | .00355 | .00212 |
| 2×10^2 | .0125 | .00772 | .00469 | .0028 | .00174 |
| 4×10^2 | .00956 | .00612 | .00387 | .0024 | .00152 |
| 10^3 | .00711 | .00462 | .00304 | .00198 | .00129 |
| 2×10^3 | .00576 | .00382 | .00257 | .00173 | .00114 |
| 4×10^3 | .00476 | .00322 | .00222 | .00153 | .00104 |
| 10^4 | .00376 | .00261 | .00186 | .0013 | .000922 |
| 2×10^4 | .00316 | .00222 | .00164 | .00116 | .000842 |
| 4×10^4 | .00269 | .00202 | .00144 | .00106 | .000762 |
| 10^5 | .00224 | .00162 | .00122 | .000899 | .000662 |
| 2×10^5 | .00196 | .00147 | .00108 | .000799 | .000602 |
| 4×10^5 | .00176 | .00131 | .000966 | .000719 | .000544 |
| 10^6 | .00151 | .00112 | .000826 | .000619 | .000482 |

Figure 12



in this report for creep-fatigue damage calculations will be based on a factor of safety of 4.0 rather than 20.

$$N_d' = 5N_d$$

$$T_d' = 5T_d$$



3.7 Methods of Analysis

The analysis of the Carrizo Plains receiver subsystem is performed in accordance with the requirements of the ASME Code, Section VIII, ANSI B31.1 and the AISC Code.

Finite element analysis was used extensively in the evaluation of the receiver subsystem stresses. Three finite element models were used in the Preliminary Design of the receiver. The models are described briefly in this section of the report and in detail in Section 6.2.

(1) Receiver Subsystem Model: The SAP V finite element model includes the sodium tubes, tangs, hatbands, support rods, manifolds, inlet and outlet piping, and the support truss. Loadings considered include deadweight, thermal expansion, seismic, and wind.

(2) Single Tube Model: This model was used to determine the receiver loading due to a temperature differential between the flux side of the receiver tube and the back side of the tube.

(3) Tube Cross-section Model: This model was used to determine the effects of the through the wall gradient and across the tube gradient for the purpose of determining the creep-fatigue damage fraction life evaluations. This model considered the inelastic behavior of the sodium tubes.

In most cases, the loads from the finite element models were considered to be added absolutely (conservative) since loads due to seismic and wind may be a variable direction condition.



4.0 CONCLUSIONS

The structural evaluations of the Carrizo Plains Receiver Subsystem contained in this report demonstrates that the proposed Preliminary Design Configuration satisfies the gross requirements of the structural criteria and loading conditions contained in the Receiver Design Specification. However, additional analyses are required to verify the structural adequacy of the entire subsystem design for all of the loading and transient conditions anticipated. The additional analyses required are itemized in Section 2.0 of this report and will be performed during the remaining Preliminary and Final Design phases of the project.



5.0 REFERENCES

1. Receiver Subsystem Solar Central Power Plant, Carrizo Plains Unit 1 Design Specification N10049, Prepared by T.L. Johnson, Rockwell International, Energy Systems Group, 8900 Desoto Ave., Canoga Park, Ca. 91304
2. Uniform Building Code (UBC), 1979 Edition, International Conference of Building Officials, Whittier, Ca.
3. Receiver Tower Trade Study, Solar Repowering Study, Permian Basin - Unit No. 1, TESCO, A.W. McKenzie to T.H. Springer, Sterns Rodger Letter C-23147-16, Dated January 24, 1980
4. American National Standard Code For Minimum Design Loads in Buildings and other Structures, ANSI A58.1-1972 Edition, American National Standard Institute, Inc., 1430 Broadway New York, N.Y. 10018
5. ASME Boiler and Pressure Vessel Code, Section VIII, Division 1, Pressure Vessels, 1980 Edition, American Society of Mechanical Engineers, United Engineering Center, 345 East 47th St., New York, N.Y. 10017
6. American National Standard Code For Pressure Piping, ANSI B31.1-1977 Edition, American Society of Mechanical Engineers, United Engineering Center, 345 East 47th Street, New York, N.Y., 10017
7. ASME Boiler and Pressure Vessel Code, Code Case N-47, Nuclear Components, 1980 Edition, American Society of Mechanical Engineers, United Engineering Center, 345 East 47th Street, New York, N.Y. 10017
8. Manual of Steel Construction, Eighth Edition, American Institute of Steel Construction, Inc., 400 North Michigan Ave., Chicago, Ill., 60611



9. Criteria of the ASME Boiler and Pressure Vessel Code For Design by Analysis in Sections III and VIII, Division 2, American Society of Mechanical Engineers, United Engineering Center, 345 East 47th Street, New York, N.Y. 10017
10. Report 079TI000002, Thermal Analysis of Central Receiver for Preliminary Design Phase, Prepared by E. Mourdian, Rockwell International, Energy Systems Group, Dated March, 1983
11. Report N036TI6300007, "SAP V Users Manual", A.P.Gelman and A. Hromjak, Atomics International, November, 1976
12. ANSYS Engineering Analysis System Users Manual, November, 1977, Swanson Analysis Systems Inc., P.O. Box 65, Houston, Pennsylvania, 15342
13. Nuclear Systems Materials Handbook, TID 26666, Supporting Documentation for Design Data, Hanford Engineering Development Laboratory P.O. Box 1970 Richland, WA 99352




6.0 APPENDICES

- 6.1 ASME Section VIII Analysis
- 6.2 Finite Element Model Descriptions
 - 6.2.1 Receiver System Model
 - 6.2.2 Single Tube Model
 - 6.2.3 Tube Cross-Section Model
- 6.3 Tube Stress Analysis
- 6.4 Tang Stress Analysis
- 6.5 Hatband Stress Analysis
- 6.6 Support Rod Stress Analysis
- 6.7 Header Stress Analysis
- 6.8 Support Beam Stress Analysis
- 6.9 Support Truss Stress Analysis
- 6.10 Finite Element Model Input Data Listings




APPENDIX 6.1
ASME Section VIII Analysis

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>60</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>10-19-82</i> | | MODEL NO. |

RECEIVER TUBES - SECTION VIII ANALYSIS

SUMMARY



Material 316SS (SA-213 TP 316)
 Design Pressure: 100 psi
 Design Temperature: 1050 °F

① Internal Pressure

Allowable Pressure = 2000 psi Circumferential
 4640 psi Longitudinal
 Design Pressure = 100 psi
 D.M. = High

② Standard Hydrostatic Test Pressure


$P_{test} = 194 \text{ psi @ Room Temperature}$

③ Longitudinal Compression Stress Allowable

$F_{compression} = 10,000 \text{ psi @ } 1050 \text{ °F}$
 $= 12,000 \text{ psi @ } 610 \text{ °F}$

④ External Pressure Stress Allowable

$P_a = 784 \text{ psi @ } 1050 \text{ °F}$


| | | |
|----------------------------|--|---------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>61</i> OF |
| CHECKED BY: | | 079TI000001 REPORT NO. |
| DATE: <i>10-19-82</i> | | MODEL NO. |

RECEIVER TUBES - SECTION VIII ANALYSIS

① Internal Pressure

UG-31 Tubes, and Pipe when Used as Tubes or Shells.

The required wall thickness for tubes and pipe under internal pressure shall be determined in accordance with the rules for shells in UG-27. The applicable stress values given in the stress tables for welded tubes and pipe shall be used instead of the factor SE in the formulas of UG-27. No increase in these stress values shall be allowed for the performance of radiography.



Material: 316 SS (SA-213 TP316)
Design Pressure: 100 psi
Design Temperature: 1050°F

a) Circumferential stress

$$P = \frac{St}{R + 0.6t}$$


where: $S = 14,500 \text{ psi @ } 1050^\circ\text{F}$
Table UHA-23

$$t = 0.049 \text{ in.}$$

$$R = 0.326 \text{ in.}$$

$$P = \frac{14500(0.049)}{0.326 + 0.6(0.049)} = 2000 \text{ psi}$$

$$D.M. = \frac{2000}{100} - 1 = \underline{\underline{\text{High}}}$$

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <u>Castle</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>62</u> OF |
| CHECKED BY: | | REPORT NO. <u>07971000001</u> |
| DATE: <u>10-19-82</u> | | MODEL NO. |

RECEIVER TUBES ~ SECTION VIII ANALYSIS

① Internal Pressure ~ Cont'd.

b) Longitudinal Stress

$$P = \frac{2St}{R - 0.4t}$$

$$= \frac{2(14500)(0.049)}{0.326 - 0.4(0.049)} = 4640 \text{ psi}$$

$$D.M. = \frac{4640}{100} - 1 = \underline{\underline{\text{High}}}$$

② Standard Hydrostatic Test

UG-99 The hydrostatic test pressure shall be at least equal to 1.5 times the maximum allowable working pressure (design pressure) multiplied by the lowest ratio of the stress value S for the test temperature on the vessel to the stress value S for the design temperature.

$$P_{TEST} = 1.5 P_{DESIGN} \left[\frac{S_{R.T.}}{S_{DES. TEMP}} \right]$$

where: $P_{DESIGN} = 100 \text{ psi}$

$S_{RT} = 18800 \text{ psi}$ } Ref 5
 $S_{DESIGN TEMP} = 14500 \text{ psi}$ } UHA-23

$$P_{TEST} = 1.5(100) \left(\frac{18800}{14500} \right) = 194 \text{ psi}$$

RECEIVER TUBES - SECTION VIII ANALYSIS

③ Maximum Allowable Longitudinal Compressive Stress

UG-23 (b) The allowable longitudinal compressive stress shall be the smaller of the following values

- a) The maximum allowable tensile value from UHA-23: $S = 14500 \text{ psi @ } 1050^\circ \text{ F}$
- b) The value of The factor B

$t = 0.049 \text{ in}$

$R_o = 0.375 \text{ in.}$

$E = 22.1 \times 10^6 \text{ psi}$ Ref: Code Case N-47

$A = \frac{0.125}{(R_o/t)} = \frac{0.125}{(.375/.049)} = 0.0163$





FIG. UHA-28.2 CHART FOR DETERMINING SHELL THICKNESS OF CYLINDRICAL AND SPHERICAL VESSELS UNDER EXTERNAL PRESSURE WHEN CONSTRUCTED OF AUSTENITIC STEEL [18 CR-8 NI + MO, TYPE 316; 18 CR-8 NI + TI, TYPE 321; 18 CR-8 NI + CB, TYPE 347; 25 CR-12 NI, TYPE 309 (THROUGH 1100 F ONLY); 25 CR-20 NI, TYPE 310; AND 17 CR, TYPE 430B STAINLESS STEEL (THROUGH 700 F ONLY)] (NOTE 8)

| | | |
|----------------------------|--|-------------------------------|
| PREPARED BY: <u>Castle</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>64</u> OF |
| CHECKED BY: | | REPORT NO. <u>0797I000001</u> |
| DATE: <u>10-19-82</u> | | MODEL NO. |

RECEIVER TUBES ~ SECTION VIII ANALYSIS

③ Maximum Allowable Longitudinal Compressive Stress ~ Cont'd

From Figure UHA-28.2 :

$$\text{Factor B} = 10,000 \text{ psi @ } 1050^{\circ}\text{F}$$

$$= 12,000 \text{ psi @ } 610^{\circ}\text{F}$$

The maximum direct (membrane) stress due to any combination of loadings listed in UG-22 that are expected to occur simultaneously during normal operation of the vessel shall not exceed the Factor B.

④ Thickness of Shells and Tubes Under External Pressure - UG 28

$$\frac{D_o}{t} \geq 10 = \frac{0.75}{0.049} = 15.31$$

where : D_o = Outside Diameter of tube
 t = Tube thickness

$$\frac{L}{D_o} = \frac{4(12)}{0.75} = 64.0$$

where : L = Length between tube supports

From Figure UG0-28.0 (next page)

$$\text{Factor A} = 0.0048$$

From Figure UHA-28.2 (previous page)

$$\text{Factor B} = 9000$$

The maximum allowable pressure, P_a , is:

$$P_a = \frac{4B}{3(D_o/t)} = \frac{4(9000)}{3(15.31)} = 784 \text{ psi}$$

PREPARED BY: *Castle*



Rockwell International
Energy Systems Group

PAGE NO. *65* OF

0711000001
REPORT NO.

CHECKED BY:

DATE: *10-19-82*

MODEL NO.

RECEIVER TUBES - SECTION VIII ANALYSIS

④ Thickness of Shells and Tubes Under External Pressure - Cont'd




FIG. UGO-28.0 GEOMETRIC CHART FOR CYLINDRICAL VESSELS UNDER EXTERNAL OR COMPRESSIVE LOADING (FOR ALL MATERIALS)



APPENDIX 6.2

Finite Element Model Descriptions



RECEIVER SUBSYSTEM MODEL

An edge panel of the receiver subsystem was modeled in detail to determine the loading effects of deadweight, thermal expansion, seismic and wind environments. This model was also used to evaluate the dynamic characteristics of the panel.

The SAP V finite element code (Reference 11) was used to perform the evaluation. The model contains 520 nodes and 631 elements. Two types of elements are used in the model.

Type 2 ... Three dimensional Beam Elements:


Forces (axial and shear) and moments (bending and torsion are calculated (in local beam coordinate system) for each beam element. Gravity loadings in each coordinate direction and specified fixed end forces form the basic element load conditions.

Type 12 .. Three Dimensional Straight or Curved Pipe Elements:

Axial and shear forces, torque and bending moments are calculated for each beam element. Gravity loadings in the global (X,Y,Z) directions, uniform temperature changes (computed from input nodal temperatures), and extensional effects due to internal pressure form the basic member loading conditions.

The following components and their element type are included in the model and are shown in Figure 13.

| Component | Element Type |
|-------------------|--------------|
| Sodium Tubes | 12 |
| Tangs | 12 |
| Hatbands | 2 |
| Support Rods | 2 |
| Panel Support Box | 2 |



| | |
|------------------------------|----|
| Panel Support Truss | 2 |
| Inlet and Outlet Header Pipe | 12 |
| Headers | 2 |

Since it was not practical to model each of the 102 tubes and 2244 tangs in each panel, every 10th tube was modeled and each set of tangs was modeled as one tang.

The inlet and outlet header sodium piping was included in the model to evaluate the thermal growth restraint they produce on the receiver panel.

The nodal temperatures for the thermal expansion evaluation are obtained from Reference 10. The thermal profiles for the edge panel from Reference 10, are shown in Figures 5 and 6. At a given elevation, the temperature profile was assumed to vary linearly from the tube at the outboard edge of panel 1 to the tube at the inboard edge of panel 1. Temperatures from the inlet header to the thermal window and from the thermal window to the outlet header were assumed to be constant at 610°F and 1050°F respectively.

The earthquake loading was performed by inputting gravity factors of 0.40 in the planes lateral and normal to the panel and 0.27 in the vertical plane. The earthquake was conservatively assumed to act in three directions simultaneously. The earthquake design basis is presented in Section 3.2.1.1 of this report.

The wind loading was performed by inputting a gravity factor of 0.653 in the direction normal to the panel. The wind design basis is presented in Section 3.2.1.2 of this report and the gravity factor of 0.653 is derived on page 83 of this



report. The wind loading considered for the analysis is the maximum operating design wind of 30mph. The 90mph wind was evaluated separately and found not to be as severe as the deadweight, thermal expansion, seismic and 30mph wind combination presented in this report.

The SAP V model section property calculations are shown on pages 75 through 83 of this Appendix.

Undeformed and deformed modal shape plots of the SAP V analysis for deadweight, thermal expansion, seismic and wind are shown in Figures 14, 15, and 16. The solid lines in the plots represent the undeformed model shape while the dashed lines represent the deformed modal shape.

Figure 14
CARRIZO PLAINS RECEIVER PANEL
UNDEFORMED AND DEFORMED SHAPES




Figure 15
CARRIZO PLAINS RECEIVER PANEL
UNDEFORMED AND DEFORMED SHAPES





Figure 16
CARRIZO PLAINS RECEIVER PANEL
UNDEFORMED AND DEFORMED SHAPES






Undeformed

Dead Weight

Thermal Expansion


CARRIZO PLAINS RECEIVER PANAL
UNDEFORMED AND DEFORMED SHAPES
Figure 16 Con'd.



| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>75</i> OF |
| CHECKED BY: | | REPORT NO. <i>07971000001</i> |
| DATE: <i>Dec 3, 1982</i> | | MODEL NO. |

CARRIZO PLAINS RECEIVER PANEL

Tube Section Properties



$$D_o = 0.75 \text{ in.}$$

$$t_w = .049 \text{ in.}$$

$$A = 0.108 \text{ in}^2$$

$$I = 0.0067 \text{ in}^4$$

Model Tube represents 10.2 tubes ∴

$$\text{Model Area} = 10.2(0.108) = 1.102 \text{ in}^2$$

$$\text{Inertia} = 10.2(.0067) = .0683 \text{ in}^4$$

Input a tube diameter and thickness that will give the proper inertia. Adjust the density to give the proper weight

Use a 1.5" tube, $t_w = 0.058$

$$A = 0.26275 \text{ in}^2$$

$$I = 0.0684 \text{ in}^4 \quad \checkmark$$

Area inside actual tube

$$= \pi (.326)^2 = 0.334 \text{ in}^2$$

$$\text{sodium density} = 0.03 \text{ lbs/in}^3$$

Wt sodium per unit length for 10.2 tubes

$$= .334(.03)(10.2) = 0.102 \text{ lbs/in}$$

Metal area actual tube

$$= 0.108 \text{ in}^2$$

Wt metal per unit length for 10.2 tubes

$$= .108(.283)(10.2) = 0.312$$

$$\text{Model density} = .102 + .312 = 0.414 \text{ lbs/in.}$$

PREPARED BY:

Castle



Rockwell International
Energy Systems Group

PAGE NO. 76 OF

079 TIOU0001
REPORT NO.

CHECKED BY:



DATE:

Dec 3, 1982

MODEL NO.

CARRIZO PLAINS RECEIVER PANEL

Tang Section Properties



section AA

$$A = \pi (.05)^2 = .00785 \text{ in}^2$$

$$I = .25 \pi R^4$$

$$= .25 \pi (.05)^4 = 4.9 \times 10^{-6}$$

For 10.2 tubes there are $2(10.2) = 20.4$ tangs

$$I = 4.9 \times 10^{-6} \times 20.4 = 1.0 \times 10^{-4} \text{ in}^4$$

Use .250" ϕ x $t_w = 0.022$

$$I = 1.03 \times 10^{-4} \text{ in}^4$$


$$A = 0.1576 \text{ in}^2$$

$$\text{Actual Area} = 20.4 (.00785) = 0.160 \text{ in}^2$$

$$\text{wt/unit length} = 20.4 (.0078) (1.0) (.286) = .0455 \text{ lb/in}$$

PREPARED BY: *Castle*
 CHECKED BY:
 DATE: *Dec 10, 1982*

CARRIZO FLAINS RECEIVER PANEL
SAP II SECTION PROPERTIES



$$A = .125 [2(.875) + 1.75 + 2(1.25)] = 0.75 \text{ in}^2$$

$$I_{22} = \frac{.125(1.25)^3}{12} + 2 [.125(1.75)(.5625)^2] = 0.179 \text{ in}^4$$

$$I_{33} = \frac{.125(1.75)^3}{12} + 2 [.125(1.25)(.9375)^2 + .125(.875)(1.4375)^2]$$

$$= .0558 + 2 [.137 + .226] = 0.782 \text{ in}^4$$

$$A_{s22} = .125 (2+2) = 0.50 \text{ in}^2$$

$$A_{s33} = 2(1.25)(.125) = .3125 \text{ in}^2$$

Torsional Constant

$$\textcircled{1} \quad b/t = .875/.125 = 7 \quad \beta = .303$$

$$R = 2(.303)(.875)(.125)^3 = .001$$

$$\textcircled{2} \quad b/t = 1.25/.125 = 10 \quad \beta = .313$$

$$R = 2(.313)(1.25)(.125)^3 = .0015$$

$$\textcircled{3} \quad b/t = 1.75/.125 = 14 \quad \beta = .333$$

$$R = .333(1.75)(.125)^3 = .0011$$


$$\Sigma R = .0036 = J$$

PREPARED BY: Castle
 CHECKED BY:
 DATE: Dec 16, 1982

PAGE NO. 78 OF
079TI000001
 REPORT NO.
 MODEL NO.

CARRIZO PLAINS RECEIVER PANEL
SAP II SECTION PROPERTIES

Support Rods



0.083
 3/4" ϕ sch 10s pipe


$$A = 0.252 \text{ in}^2$$

$$I_{11} = I_{22} = 0.0297 \text{ in}^4$$

$$A_{s11} = A_{s22} = \frac{A}{K} = \frac{0.252}{1.885} = 0.134 \text{ in}^2$$

$$J = 2\pi r^3 t = 2I_{11} = 0.0594 \text{ in}^4$$

Manifolds




0.134
 6" ϕ sch 10 pipe

$$A = 2.733 \text{ in}^2$$

$$I_{11} = I_{22} = 14.40 \text{ in}^4$$


$$A_{s11} = A_{s22} = \frac{A}{K} = \frac{2.733}{1.885} = 1.45 \text{ in}^2$$

$$J = 2I_{11} = 2(14.4) = 28.8 \text{ in}^4$$

| | | |
|----------------------------|---|---------------------------------|
| PREPARED BY: <i>Castle</i> |  | PAGE NO. <i>79</i> OF |
| CHECKED BY: | | REPORT NO. <i>079 TI 000001</i> |
| DATE: <i>Dec 16, 1982</i> | | MODEL NO. |

CARRIZO PLAINS RECEIVER PANEL
SAP II SECTION PROPERTIES

Panel Support Beam Truss



$$A = 2.4(.375) = 0.90 \text{ in}^2$$

$$I_{33} = \frac{2.4(.375)^3}{12} = 0.011 \text{ in}^4$$

$$I_{22} = \frac{.375(2.4)^3}{12} = 0.432 \text{ in}^4$$


$$A_s = A_s = 2.4(.375) / 1.177 = 0.765 \text{ in}^2$$

Torsional Constant

$$b/t = 2.4/.375 = 6.4 \quad \beta \approx 0.301$$

$$J = 0.301(2.4)(.375)^2 = 0.102 \text{ in}^4$$

Panel Support Beam



From AISC Manual

$$A = 2.09 \text{ in}^2$$

$$I_{22} = 2.21 \text{ in}^4$$

$$I_{33} = 1.15 \text{ in}^4$$

$$A_{s22} = 2(2.0)(.25) = 1.0 \text{ in}^2$$

$$A_{s33} = 2(3.0)(.25) = 1.5 \text{ in}^2$$


Torsional Constant

$$J = \frac{2b^2h^2t^2}{t(b+t)} = \frac{2(1.75)^2(2.75)^2(.25)^2}{.25(1.75+2.75)} = 2.57$$

where $b = 1.75 \text{ in}$

$h = 2.75 \text{ in}$


$t = .25$

| | | |
|----------------------------|--|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Atomics International Division | PAGE NO. <i>80</i> OF |
| CHECKED BY: | | REPORT NO. <i>07971000001</i> |
| DATE: <i>Jan 14, 1983</i> | | MODEL NO. |

CARRIZO PLAINS RECEIVER

INLET PIPING SECTION PROPERTIES

6 inch Sch 40 C.S. Pipe with Sodium




$$\begin{aligned}
 t_{\text{wall}} &= 0.280 \text{ in} \\
 ID &= 6.065 \text{ in} \\
 A_{\text{inside}} &= 28.89 \text{ in}^2 \\
 A_{\text{metal}} &= 5.58 \\
 W &= 18.97 \text{ lbs/ft} = 1.58 \text{ lbs/in} \\
 I &= 28.14 \text{ in}^4
 \end{aligned}$$

wt sodium per unit length

$$W_s = 28.89 (1.0)(.03) = 0.867 \text{ lbs/in.}$$

$$\text{Model wt} = W + W_s = 1.58 + .867 = 2.45 \text{ lbs/in.}$$

| | | |
|----------------------------|--|---------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>81</i> OF |
| CHECKED BY: | | REPORT NO. <i>079 TI 000001</i> |
| DATE: <i>Jan 21, 1983</i> | | MODEL NO. |

CARRIZO PLAINS RECEIVER PANEL

SAP II MODEL PROPERTIES

Upper and Lower Manifold Density

6" Sch 10 pipe with sodium

$$\text{Inside Area} = 31.70 \text{ in}^2$$

$$\text{Sodium density} = 0.03 \text{ lbs/in}^3$$


$$\text{wt sodium} = 31.7 \times 0.03 = 0.951 \text{ lbs/in}$$

$$\text{wt pipe} = 9.29 \text{ lbs/ft} = 0.774 \text{ lbs/in}$$

$$\text{Total weight (pipe + sodium)} = .951 + .774 = 1.725 \text{ lbs/in}$$

$$\text{Metal Area} = 2.733 \text{ in}^2$$

$$\text{Model density} = \frac{1.725}{2.733} = 0.631 \text{ lbs/in}^3$$

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <u>Castle</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>82</u> OF |
| CHECKED BY: | | REPORT NO. <u>07977000001</u> |
| DATE: <u>Jan 7, 83</u> | | MODEL NO. |

SAP II Panel Pressure

Total Receiver weight = 3050 lbs

Hut bands

$A = 0.75 \text{ in}^2$

$l / \text{band} = 96.63 - 3.87 = 92.76 \text{ in}$

No. bands = 11

$wt = .75(92.76)(11)(.286) = \underline{220 \text{ lbs.}}$

Tie Rods

$A = 0.252 \text{ in}^2$

$l = 34.0 - 4 = 30 \text{ in}$

No rods = 22

$wt = .252(30)(22)(.286) = \underline{48 \text{ lbs}}$


Support Truss

$A = .90 \text{ in}^2$

$L = 34 + 39.24 = 73.24 \text{ in}$

No truss = 2

$wt = .90(73.24)(2)(.286) = \underline{38 \text{ lbs.}}$



Manifold

$P = .631$

$A = 2.733$

$l = 73.44 - 3.87 = 69.57 \text{ in}$

No manifold = 2


$wt = 2.733(69.57)(2)(.631) = \underline{240 \text{ lbs.}}$

Receiver Support

$A = 1.044 \text{ in}^2$

$l = 96.63 - 3.87 = 92.76 \text{ in}$

$wt = 1.044(92.76)(.286) = \underline{28 \text{ lbs}}$

| | | |
|----------------------------|--|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>83</i> OF |
| CHECKED BY: | | REPORT NO. <i>0797I000001</i> |
| DATE: <i>Jan 7, 83</i> | | MODEL NO. |

SAP II Panel Pressure

Total wt beam elements

$$= 220 + 48 + 38 + 240 + 28 = 574 \text{ lbs}$$

Total pipe element wt

$$= 3050 - 574 = 2476 \text{ lbs.}$$

Panel Pressure = 0.0352 psi for 30 mph wind

$$\text{Total force pressure} = 600(76.5)(.0352) = 1616 \text{ lbs.}$$

Pressure factor for model

$$= \frac{1616}{2476} = \underline{\underline{0.653}}$$

Panel Pressure = 0.375 psi for 90 mph wind

$$\text{Total force pressure} = 600(76.5)(.375) = 17213 \text{ lbs.}$$

Pressure factor for model

$$= \frac{17213}{2476} = 6.95$$



6.2.2 Single Tube Model

To evaluate the sodium tube and tang stresses due to the effects of a temperature differential from the flux side of the tube and the back insulated side, an ANSYS model was developed.



The model consists of a representation of a single tube of the receiver subsystem and the eleven sets of tangs supporting the sodium tubes. The model is shown in Figure 17.

The sodium tubes are modeled using the ANSYS STIFF 20 straight pipe element and the tangs are modeled using the ANSYS 3D elastic bar element. The input data listing for the model is presented in Appendix 6.2 of this report.

The temperature profiles along the length of the tube were obtained using the T(front) curve of Figure 7 and the T(back) curve of Figure 7.

The tube and tang loads obtained from this model were superimposed with the receiver subsystem model results to obtain the complete loading on the individual components of the receiver subsystem.

The tube and tang loads and stresses obtained from the single tube model are shown in Table 97 (tubes) and Table 102 (tangs).



- ◡ ELEMENTS
- NODES
- BOUNDARY NODES






Figure 17
W. PROPEL JANUARY 1983

CARRIZO PLAINS
SOLAR RECEIVER
ANSYS MODEL



CARRIZO SOLAR RECEIVER - (DWG. NO. 079000001) - SINGLE TUBE - THERMAL LOADING

Figure 18
Carrizo Solar Receiver Single Tube Model CRT



6.2.3 Tube Cross-Section Model

To determine the creep-fatigue life evaluation of the Carrizo Plains Receiver tubes, a model of a single tube was constructed using the ANSYS Computer Code (Reference 12). A two dimensional isoparametric element with the axisymmetric modeling option (STIFF 42) was used to evaluate the tube. A meshplot of the cross-section of the tube is shown in Figure 19, and the thermal nodal map is shown in Figure 20.

Since the sodium tube is modeled as an axisymmetric model with a radius of 100 inches, it is possible to have the same effects as a generalized plane strain representation of a straight tube. This modeling technique was used since the ANSYS Code does not have a two dimensional generalized plain strain element available.

The temperature profile used in the analysis represents the maximum temperature gradients across the tube for a full thermal load at the tube mid-height. The temperature profile is shown in Figure 21 and Table 7, and was obtained from Reference 10. Temperature dependent material properties for the Type 316 Stainless Steel tube was obtained from the Nuclear Systems Material Handbook (Reference 13).

The creep equation for annealed Type 316 Stainless Steel available in the ANSYS Code is described in the Nuclear Systems Material Handbook.

The cyclic thermal history of the receiver tubes used in the analysis is shown in Figure 10.




Figure 19

Meshplot of the Tube Cross-Section




Figure 20
Thermal Nodal Map of the
Single Tube Cross-Section
Model





Figure 21



The results of the creep-fatigue evaluation of the sodium tube are not complete at this time. The results of this assessment will be included in the next revision to this report.



APPENDIX 6.3
Tube Stress Analysis

| | | |
|----------------------------|---|---------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>92</i> OF |
| CHECKED BY: | | 079TI000001 REPORT NO. |
| DATE: <i>Feb 18, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
SODIUM TUBES

The analysis results for the stresses in the sodium tubes indicate that the highest stresses in the thermal window area occur at element 61 of the receiver system model and at element 240 in the shaded tube area. The stress calculations for both areas are shown below.

The loads on the sodium tubes include the effects of deadweight, thermal expansion, seismic, wind, and the ΔT from the flux side of the panel to the back side. All loads are conservatively added absolutely.


From the system receiver model, the loads due to deadweight, thermal expansion, seismic and wind are:

Element 61, Node 63 (Thermal Window Area)

| Load | D.W. | T.E. | Seismic | Wind | Total |
|----------------|------|------|---------|------|-------|
| P_1 | 51 | 321 | 25 | 11 | 408 |
| P_2 } lbs | 0 | 8 | 4 | 7 | 19 |
| P_3 } | 0 | 0 | 4 | 0 | 4 |
| M_1 | 0 | 1 | 43 | 1 | 45 |
| M_2 } in-lbs | 2 | 21 | 32 | 1 | 56 |
| M_3 } | 10 | 334 | 47 | 86 | 477 |

Element 240, Node 247 (Shaded Area)

| Load | D.W. | T.E. | Seismic | Wind | Total |
|----------------|------|------|---------|------|-------|
| P_1 | 43 | 139 | 5 | 0 | 187 |
| P_2 } lbs | 88 | 350 | 28 | 28 | 494 |
| P_3 } | 1 | 61 | 15 | 3 | 80 |
| M_1 | 2 | 168 | 49 | 7 | 226 |
| M_2 } in-lbs | 5 | 330 | 87 | 20 | 442 |
| M_3 } | 311 | 2073 | 135 | 145 | 2664 |

| | | |
|----------------------------|---|--------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>93</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI 0000 1</i> |
| DATE: <i>Feb 21, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
SODIUM TUBES


From the single tube model, the sodium tube loads for the thermal window and shaded areas are:

Thermal Window Area (Etc 55, Node 55)

- $P_1 = 1.0 \text{ lbs}$
- $P_2 = 0$
- $P_3 = 0$
- $M_1 = 0$
- $M_2 = 0$
- $M_3 = 20.17 \text{ lbs}$

The loads in the shaded area of the tube due to the flux AT are very small and will not be considered.

Sodium Tube Section Properties



$$A = 0.108 \text{ in}^2$$

$$I = 0.0067 \text{ in}^4$$

$$J = 2I = 0.0134 \text{ in}^4$$

$$Z = \frac{I}{c} = \frac{.0067}{.375} = 0.0179 \text{ in}^3$$

Sodium Tube stresses

The system receiver model loads are for 10 tubes \therefore all loads will be divided by 10 in calculating the stresses.

Pressure Stress - Axial

The operating pressure is 30 psi

$$\sigma_{axial} = \frac{P l}{2t} = \frac{30(.375)}{2(.049)} = 115 \text{ psi}$$

PREPARED BY: Castle



Rockwell International
Energy Systems Group

PAGE NO. 94 OF
REPORT NO. 0797I000001

CHECKED BY:

DATE: Feb 21, 1983

MODEL NO.

CARRIZO PLAINS SOLAR RECEIVER
SODIUM TUBES

Thermal Window Area Stresses

For thermal expansion stresses per ANSI B31.1

$$S_E = \frac{i M_c}{z} \leq S_A$$

where: $i = 1.0$

$$M_c = [M_1^2 + M_2^2 + M_3^2]^{1/2}$$

$$= [(1)^2 + (2)^2 + (53.4)^2]^{1/2}$$

$$= 53.45 \text{ in-lbs}$$

$$z = 0.0179 \text{ in}^3$$

$$S_E = \frac{53.45}{.0179} = 2986 \text{ psi}$$

$$S_A @ 1050^\circ\text{F} = 18900 \text{ psi}$$

$$D.M. = \frac{18900}{2986} - 1 = \underline{\underline{5.33}}$$

For thermal expansion + sustained loads per ANSI B31.1

$$S_{TE} = \frac{P D_o}{4 t_m} + \frac{.75 i M_A}{z} + \frac{i M_c}{z} \leq S_h + S_a$$

where: $P = 30 \text{ psi}$

$$D_o = 0.75 \text{ in}$$

$$t_m = 0.049 \text{ in}$$

$$i = 1.0$$

$$z = 0.0179 \text{ in}^3$$

$$M_A = [(4.4)^2 + (35)^2 + (14.3)^2]^{1/2}$$


$$= 15.37 \text{ in-lbs}$$

$$M_c = 53.45 \text{ in-lbs}$$

$$S_{TE} = \frac{30(.75)}{4(.049)} + \frac{15.37}{.0179} + \frac{53.37}{.0179} = 3955 \text{ psi}$$

$$S_h + S_A @ 1050^\circ\text{F} = 33400 \text{ psi}$$

$$D.M. = \frac{33400}{3955} - 1 = \underline{\underline{7.45}}$$

| | | |
|----------------------------|--|--------------------------------|
| PREPARED BY: <u>Pastle</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>95</u> OF |
| CHECKED BY: | | REPORT NO. <u>0797I 000001</u> |
| DATE: <u>Feb 21, 1983</u> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
SODIUM TUBES

Thermal Window Area Stresses ~ cont'd

Check the tubes in an area where the thermal stresses are maximum for the flux ΔT . From page 98, the highest stress occurs at element 30, Node 30 in the single tube model

$$M_3 = 309 \text{ in-lbs}$$

From the receiver system model (ele 187)

$$M_1 = .51 \text{ in-lbs}$$

$$M_2 = .01 \text{ in-lbs}$$

$$M_3 = 5.72 \text{ in-lbs}$$

$$S_e = \frac{i M_c}{z} \leq S_A$$

$$\text{where: } M_c = \left[(.051)^2 + (.001)^2 + (309.57)^2 \right]^{1/2} \\ = 310 \text{ in-lbs}$$

$$S_e = \frac{310}{.0179} = 17320 \text{ psc}$$

$$S_A @ 1050^\circ F = 18900 \text{ psc}$$

$$D.M. = \frac{18900}{17320} - 1 = \underline{\underline{0.09}}$$

From Element 52 of the receiver system model the D.W + seismic + wind loads are

$$M_1 = 1.84 \text{ in-lbs}$$

$$M_2 = 31.27 \text{ in-lbs}$$


$$M_3 = 85.29 \text{ in-lbs}$$

$$M_A = \left[(.184)^2 + (31.27)^2 + (85.29)^2 \right]^{1/2} = 9.086 \text{ in-lbs}$$

$$S_{TE} = \frac{30(.75)}{4(.049)} + 17320 + \frac{9.086}{0.0179} = 17943 \text{ psc}$$

$$S_a + S_n = 33,400 \text{ psc}$$

$$D.M. = \frac{33400}{17943} - 1 = \underline{\underline{0.86}}$$

| | | |
|----------------------------|--|-------------------------------|
| PREPARED BY: <u>Castle</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>96</u> OF |
| CHECKED BY: | | REPORT NO. <u>079TI000001</u> |
| DATE: <u>Feb 21, 1983</u> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
SODIUM TUBES

Shaded Area Tube Stresses

For thermal expansion stresses per ANSI B31.1

$$S_E = \frac{i M_c}{z} \leq S_A$$

where: $i = 1.0$

$$M_c = [(16.8)^2 + (33.0)^2 + (207.3)^2]^{1/2}$$

$$= 211 \text{ in-lbs}$$

$$z = 0.0179 \text{ in}^3$$

$$S_E = \frac{211}{0.0179} = 11790 \text{ psi}$$

$$S_E @ 1050^\circ \text{F} = 18900 \text{ psi}$$

$$D.M. = \frac{18900}{11790} - 1 = \underline{\underline{0.60}}$$

For thermal Expansion + Sustained loads

$$S_{TE} = \frac{P_o D_o}{4 t_n} + \frac{.75 i M_A}{z} + \frac{i M_c}{z} \leq S_h + S_a$$

where: $p = 30 \text{ psi}$

$$D_o = .75 \text{ in}$$

$$t_n = 0.049 \text{ in}$$

$$M_A = [(5.8)^2 + (11.2)^2 + (59.1)^2]^{1/2}$$

$$= 60.4 \text{ in-lbs}$$

$$M_c = 211 \text{ in-lbs}$$

$$S_{TE} = \frac{30(.75)}{4(.049)} + \frac{60.4}{.0179} + \frac{211}{.0179} = 15280 \text{ psi}$$

$$S_h + S_a @ 1050^\circ \text{F} = 33400 \text{ psi}$$

$$D.M. = \frac{33400}{15280} - 1 = \underline{\underline{1.18}}$$

CARRIZO PLAINS SOLAR RECEIVER
 Single Tube Model Tube Stresses




Table 7

| Ele | Node | T ₁ °F | T ₂ °F | ΔT °F | Bending Stress PSC | Displace- ment in. |
|-----|------|----------------------|----------------------|----------|--------------------------|--------------------------|
| 1 | 1 | 610 | 610 | 0 | 5 | 0 |
| 2 | 2 | 610 | 610 | 0 | 92 | -.0134 |
| 3 | 3 | 610 | 610 | 0 | 517 | -.0224 |
| 4 | 4 | 610 | 610 | 0 | 1033 | -.0258 |
| 5 | 5 | 610 | 610 | 0 | 1522 | -.0147 |
| 6 | 6 | 629 | 617 | 12 | 1601 | -.0124 |
| 7 | 7 | 635 | 620 | 15 | 2531 | .0019 |
| 8 | 8 | 642 | 626 | 16 | 3512 | .0021 |
| 9 | 9 | 650 | 632 | 18 | 4493 | -.0061 |
| 10 | 10 | 655 | 635 | 20 | 5423 | -.0134 |
| 11 | 11 | 660 | 639 | 21 | 5516 | -.0139 |
| 12 | 12 | 673 | 647 | 26 | 6256 | -.0163 |
| 13 | 13 | 684 | 657 | 27 | 7038 | -.0173 |
| 14 | 14 | 699 | 667 | 32 | 7820 | -.0166 |
| 15 | 15 | 706 | 673 | 33 | 8561 | -.0141 |
| 16 | 16 | 715 | 679 | 36 | 8689 | -.0139 |
| 17 | 17 | 730 | 691 | 39 | 9756 | -.0140 |
| 18 | 18 | 750 | 705 | 45 | 10882 | -.0139 |
| 19 | 19 | 767 | 719 | 48 | 12008 | -.0142 |
| 20 | 20 | 777 | 728 | 49 | 13077 | -.0152 |
| 21 | 21 | 787 | 735 | 52 | 13181 | -.0150 |
| 22 | 22 | 808 | 751 | 57 | 14034 | -.0129 |
| 23 | 23 | 830 | 769 | 61 | 14933 | -.0108 |
| 24 | 24 | 850 | 786 | 64 | 15833 | -.0122 |
| 25 | 25 | 860 | 796 | 64 | 16688 | -.0161 |
| 26 | 26 | 872 | 807 | 65 | 16742 | -.0164 |
| 27 | 27 | 891 | 825 | 66 | 16921 | -.0173 |
| 28 | 28 | 914 | 843 | 71 | 17110 | -.0136 |
| 29 | 29 | 930 | 861 | 69 | 17299 | -.0132 |
| | | | | | | |

PREPARED BY: *Castle*
 CHECKED BY:
 DATE: *Jan 26, 1983*



Rockwell International
 Energy Systems Group

PAGE NO. *98* OF
 REPORT NO. *079 TL 000001*
 MODEL NO.

CARRIZO PLAINS SOLAR RECEIVER

FLUX →



Table 7 ~ Cont'd


| Ele | Node | T ₁ °F | T ₂ °F | ΔT °F | Bending Stress PSC | Displace- ment in. |
|-----|------|----------------------|----------------------|----------|--------------------------|--------------------------|
| 30 | 30 | 940 | 871 | 69 | 17482 | -.0176 |
| 31 | 31 | 950 | 881 | 69 | 17469 | -.0180 |
| 32 | 32 | 966 | 899 | 67 | 17129 | -.0206 |
| 33 | 33 | 984 | 916 | 68 | 16770 | -.0204 |
| 34 | 34 | 997 | 932 | 65 | 16411 | -.0199 |
| 35 | 35 | 1004 | 940 | 64 | 16077 | -.0196 |
| 36 | 36 | 1010 | 947 | 63 | 16008 | -.0194 |
| 37 | 37 | 1023 | 961 | 62 | 15200 | -.0154 |
| 38 | 38 | 1033 | 975 | 58 | 14348 | -.0132 |
| 39 | 39 | 1041 | 987 | 54 | 13495 | -.0161 |
| 40 | 40 | 1045 | 993 | 52 | 12694 | -.0207 |
| 41 | 41 | 1048 | 999 | 49 | 12585 | -.0214 |
| 42 | 42 | 1053 | 1008 | 45 | 11538 | -.0243 |
| 43 | 43 | 1057 | 1016 | 41 | 10433 | -.0247 |
| 44 | 44 | 1060 | 1024 | 36 | 9328 | -.0240 |
| 45 | 45 | 1061 | 1027 | 34 | 8288 | -.0223 |
| 46 | 46 | 1063 | 1030 | 33 | 8182 | -.0222 |
| 47 | 47 | 1065 | 1035 | 30 | 7419 | -.0206 |
| 48 | 48 | 1066 | 1040 | 26 | 6616 | -.0214 |
| 49 | 49 | 1066 | 1045 | 21 | 5812 | -.0238 |
| 50 | 50 | 1066 | 1046 | 20 | 5058 | -.0232 |
| 51 | 51 | 1066 | 1049 | 17 | 4957 | -.0228 |
| 52 | 52 | 1066 | 1050 | 16 | 4026 | -.0150 |
| 53 | 53 | 1066 | 1052 | 14 | 3044 | -.0056 |
| 54 | 54 | 1065 | 1053 | 12 | 2062 | -.0055 |
| 55 | 55 | 1050 | 1050 | 0 | 1139 | -.0220 |
| 56 | 56 | 1050 | 1050 | 0 | 1066 | -.0249 |
| 57 | 57 | 1050 | 1050 | 0 | 812 | -.0429 |
| 58 | 58 | 1050 | 1050 | 0 | 544 | -.0483 |
| | | | | | | |



APPENDIX 6.4
Tang Stress Analysis

CARRIZO PLAINS SOLAR RECEIVER
TANG LOADS AND STRESSES

The tang loads and stresses summarized below are from the single tube model described in section 6.2.2 of this report. This model represents the effects of the temperature differential between the front (flux) side of the sodium tube and the back side of the tube. These loads and stresses must be combined with the deadweight, thermal expansion, seismic and wind tang loads in order to determine the complete tang loading.



| Tang Element | Tang Nodes | Axial Load - lbs. | Axial Stress - psi |
|--------------|------------|-------------------|--------------------|
| 84 | 56-85 | .526 | 61.9 |
| 83 | 55-84 | .526 | 61.9 |
| 82 | 51-83 | -.131 | 15.5 |
| 81 | 50-82 | -.131 | 15.5 |
| 80 | 46-81 | .222 | 26.1 |
| 79 | 45-80 | .222 | 26.1 |
| 78 | 41-79 | -.186 | 21.9 |
| 77 | 40-78 | -.186 | 21.9 |
| 76 | 36-77 | -.363 | 42.8 |
| 75 | 35-76 | -.363 | 42.8 |
| 74 | 31-75 | -.403 | 47.5 |
| 73 | 30-74 | -.403 | 47.5 |
| 72 | 26-73 | -.523 | 61.6 |
| 71 | 25-72 | -.523 | 61.6 |
| 70 | 21-71 | -.167 | 19.6 |
| 69 | 20-70 | -.167 | 19.6 |
| 68 | 16-69 | -.148 | 17.4 |
| 67 | 15-68 | .655 | 77.1 |
| 66 | 11-67 | -.147 | 17.2 |
| 65 | 10-66 | -.147 | 17.2 |
| 64 | 6-65 | .342 | 40.3 |
| 63 | 5-64 | .342 | 40.3 |

Table 8

PREPARED BY: *Castle*



Rockwell International
Energy Systems Group

PAGE NO. 103 OF

CHECKED BY:

079TI00001
REPORT NO.


DATE: Feb 15, 1983

MODEL NO.

CARRIZO PLAINS SOLAR RECEIVER
PANEL TANGS

Tang Section Properties

Material: 304 stainless Steel
 $F_y = 30,000 \text{ psi}$



$$A = \pi (.0525)^2 = 0.00866 \text{ in}^2$$

$$I = .25 \pi (.0525)^4 = 6 \times 10^{-6} \text{ in}^4$$

$$r = \sqrt{\frac{I}{A}} = 0.0262 \text{ in}$$

Buckling Allowable

Assume the average temperature of the tang is 400°F

$$F_y = 21400 \text{ psi}$$

$$E = 26.6 \times 10^6 \text{ psi}$$

From AISC, section 1.5.1.3

$$F_a = \frac{\left[1 - \frac{(Kl/r)^2}{2C_c^2} \right] F_y}{\frac{5}{3} + \frac{3(Kl/r)}{8C_c} + \frac{(Kl/r)^3}{8C_c^3}}$$

From table D1.8.1 case a, $K = 0.65$

Tang length = 4.0 inches


$$\frac{Kl}{r} = \frac{0.65(4)}{0.0262} = 99.2$$

$$C_c = \sqrt{\frac{2\pi^2 E}{F_y}} = \sqrt{\frac{2\pi^2 (26.6 \times 10^6)}{21400}} = 156.6$$

$$F_a = \frac{\left[1 - \frac{(99.2)^2}{2(156.6)^2} \right] [21400]}{\frac{5}{3} + \frac{3(99.2)}{8(156.6)} + \frac{(99.2)^3}{8(156.6)^3}} = 8836 \text{ psi}$$

$$P_{allowable} = F_a A =$$

$$= 8836 (.00866) = 76.5 \text{ lbs.}$$

| | | |
|----------------------------|--|------------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>104</i> OF |
| CHECKED BY: | | <i>079 TI 000001</i> REPORT NO. |
| DATE: <i>Feb 15, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL TANGS

Allowable Bending Stresses

Two allowables are required since the tang end attached to the sodium tube will be hotter than the tang end at the hatband.

$$T_{\text{tube end}} = 1050^{\circ}\text{F}$$

$$T_{\text{hatband end}} = 200^{\circ}\text{F}$$

From AISC, Section 1.5.1.4.1

$$F_b = 0.66 F_y$$

$$F_y @ 1050^{\circ}\text{F} = 16700 \text{ psi}$$

$$@ 200^{\circ}\text{F} = 25800 \text{ psi}$$

$$F_b @ 1050^{\circ}\text{F} = 0.66(16700) = 11022 \text{ psi}$$

$$F_b @ 200^{\circ}\text{F} = 0.66(25800) = 17028 \text{ psi}$$

From AISC, Section 1.5.6, the allowable stresses may be increased $\frac{1}{3}$ above the values otherwise provided when produced by wind or seismic loading provided the required section computed on this basis is not less than that required for the design dead and live load, computed without the $\frac{1}{3}$ stress increase.


$$F_b @ 1050^{\circ}\text{F} = 1.33(11022) = 14660 \text{ psi}$$

$$F_b @ 200^{\circ}\text{F} = 1.33(17028) = 22650 \text{ psi}$$

PREPARED BY: *Castle*
 CHECKED BY:
 DATE: *Feb 15, 1983*

CARRIZO PLAINS SOLAR RECEIVER
PANEL TANGS

Tang Stresses ~ Cont'd.



For the receiver system model element 384 represents 20 tangs, therefore, the loads in the table on the previous page will be divided by 20. The single tube model loads represent the loads on one tang, therefore, they will not be factored.

Stresses Due To D.W. + Thermal Expansion + ΔT
At Node 133

$$P_x = \frac{1.2 + 38.3}{20} + .526 = 2.50 \text{ lbs}$$

$$P_y = \frac{.17 + 2.35}{20} = .126 \text{ lbs}$$

$$P_z = \frac{2.31 + 7.67}{20} = .499 \text{ lbs}$$

$$M_x = \frac{.03 + .57}{10} = .06 \text{ in-lbs}$$

$$M_y = \frac{8.21 + 20.73}{10} = 2.89 \text{ in-lbs}$$

$$M_z = \frac{.34 + 3.58}{20} + .1187 = .31 \text{ in-lbs}$$

$$\sqrt{x} = \frac{P_x}{A} + \frac{M_y}{1.25A}$$

$$= \frac{2.50}{.00866} + \frac{2.89}{1.25(.00866)} = 556 \text{ psi}$$

PREPARED BY:

Castle



Rockwell International

Energy Systems Group

PAGE NO. 106 OF

0797I 000001

REPORT NO.

CHECKED BY:

DATE: Feb 15, 1983

MODEL NO.

CARRIZO PLAINS SOLAR RECEIVER PANEL TANGS

Tang Stresses - Cont'd

$$\begin{aligned}\sigma_y &= \frac{P_y}{A} + \frac{M_x}{1.25 A} \\ &= \frac{.126}{.00866} + \frac{.06}{1.25(.00866)} = 20.1 \text{ psi}\end{aligned}$$

$$\sigma_z = \frac{P_z}{A} = \frac{.499}{.00866} = 57.6 \text{ psi}$$

$$\sigma_{y-z} = (\sigma_y^2 + \sigma_z^2)^{1/2} = 61 \text{ psi}$$

$$\sigma_{\text{bending}} = \frac{M_z c}{I} = \frac{.31 (.0525)}{6 \times 10^{-6}} = 2713 \text{ psi}$$

Combined Stress D.M (AISC, Section 1.6-2)

$$\frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

$$\frac{556}{8836} + \frac{2713}{11022} = 0.309$$

$$D.M. = \frac{1}{0.309} - 1 = \underline{\underline{2.24}}$$

Shear D.M

$$F_v = 0.4 F_y = 0.4 (16700) = 6680 \text{ psi}$$

$$D.M. = \frac{6680}{61} - 1 = \underline{\underline{\text{High}}}$$


Stresses Due to D.W. + Thermal Expansion + AT
+ Seismic + Wind at Node 133

$$P_x = \frac{.12 + 38.3 + 9.56 + 16.61}{20} + .526 = 3.81 \text{ lbs}$$

$$P_y = \frac{.17 + 2.35 + 8.88 + .03}{20} = 0.57 \text{ lbs}$$

$$P_z = \frac{2.31 + 7.67 + 1.24 + .91}{20} = 0.61 \text{ lbs}$$

$$M_x = \frac{.03 + .57 + .02 + .01}{10} = 0.063 \text{ in-lbs}$$

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>107</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>Feb 16, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL TANGS

Tang Stresses - Cont'd

$$M_y = \frac{8.21 + 20.73 + 4.81 + 3.99}{10} + .12 = 3.89 \text{ in-lbs}$$

$$M_z = \frac{.34 + 3.58 + 15.34 + 0}{20} = 0.96 \text{ in-lbs}$$

$$\sigma_x = \frac{P_x}{A} + \frac{M_y}{1.25A} = \frac{3.81}{.00866} + \frac{3.89}{1.25(.00866)} = 799 \text{ psi}$$

$$\sigma_y = \frac{P_y}{A} + \frac{M_x}{1.25A} = \frac{.57}{.00866} + \frac{.063}{1.25(.00866)} = 72 \text{ psi}$$

$$\sigma_z = \frac{P_z}{A} = \frac{.61}{.00866} = 70 \text{ psi}$$

$$\sigma_{yz} = (\sigma_y^2 + \sigma_z^2)^{1/2} = 100 \text{ psi}$$

$$\sigma_{\text{bending}} = \frac{M_z C}{I} = \frac{.96 (.0525)}{6 \times 10^{-6}} = 8400 \text{ psi}$$

Combined Stress D.M

$$\frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

$$\frac{799}{8836} + \frac{8400}{14660} = 0.66$$

$$D.M. = \frac{1}{0.66} - 1 = \underline{\underline{0.51}}$$

Shear Design Margin

$$F_v = 6680 \text{ psi}$$


$$f_{yz} = 141 \text{ psi}$$

$$D.M. = \frac{6680}{100} - 1 = \underline{\underline{\text{High}}}$$

Stresses Due to D.W. + Thermal Expansion + ΔT
At Node 394

$$P_x = 2.50 \text{ lbs}$$

$$P_y = .126 \text{ lbs}$$

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <i>Castle</i> |  | PAGE NO. <i>108</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>Feb 16, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL TANGS

Tang Stresses ~ Cont'd

$$P_z = .499 \text{ lbs}$$

$$M_x = .06 \text{ in-lbs}$$

$$M_y = \frac{.67 + 9.93}{10} + .12 = 1.18 \text{ in-lbs}$$

$$M_z = \frac{.34 + 5.83}{20} = .31 \text{ in-lbs}$$

$$\sigma_x = \frac{P_x}{A} + \frac{M_y}{1.25A} = \frac{2.50}{.00866} + \frac{1.18}{1.25(.00866)} = 398 \text{ psi}$$

$$\sigma_y = \frac{P_y}{A} + \frac{M_x}{1.25A} = \frac{.126}{.00866} + \frac{.06}{1.25(.00866)} = 20 \text{ psi}$$

$$\sigma_z = \frac{P_z}{A} = \frac{.499}{.00866} = 58 \text{ psi}$$

$$\sigma_{yz} = (\sigma_y^2 + \sigma_z^2)^{1/2} = 61 \text{ psi}$$

$$\sigma_{\text{bending}} = \frac{M_z C}{I} = \frac{.31(.0525)}{6 \times 10^{-6}} = 2713 \text{ psi}$$

Combined Stress Design Margin

$$\frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

$$\frac{398}{8836} + \frac{2713}{17028} = 0.204$$


$$D.M. = \frac{1}{.204} - 1 = \underline{\underline{3.89}}$$

Stresses Due to D.W. + Thermal Expansion + ΔT
+ Seismic + Wind at Node 394

$$P_x = 3.81 \text{ lbs}$$

$$P_y = .57 \text{ lbs}$$

$$P_z = .61 \text{ lbs}$$

| | | |
|----------------------------|---|---------------------------------|
| PREPARED BY: <i>Castle</i> |  | PAGE NO. <i>109</i> OF |
| CHECKED BY: | | REPORT NO. <i>079 TL 000001</i> |
| DATE: <i>Feb 16, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL TANGS

Tang Stresses ~ Cont'd

$$M_x = .063 \text{ in-lbs}$$

$$M_y = \frac{.67 + 9.93 + .04 + .37}{10} + .12 = 1.22 \text{ in-lbs}$$

$$M_z = \frac{.34 + 5.83 + 20.32 + .13}{20} = 1.33 \text{ in-lbs}$$

$$\sigma_x = \frac{P_x}{A} + \frac{M_y}{1.25A} = \frac{3.81}{.00866} + \frac{1.22}{1.25(.00866)} = 553 \text{ psi}$$

$$\sigma_y = \frac{P_y}{A} + \frac{M_x}{1.25A} = \frac{.57}{.00866} + \frac{.063}{1.25(.00866)} = 72 \text{ psi}$$

$$\sigma_z = \frac{P_z}{A} = \frac{.61}{.00866} = 70 \text{ psi}$$

$$\sigma_{yz} = (\sigma_y^2 + \sigma_z^2)^{1/2} = 100 \text{ psi}$$

$$\sigma_{\text{bending}} = \frac{M_z c}{I} = \frac{1.33 (.0525)}{6 \times 10^{-6}} = 11640 \text{ psi}$$

Combined Stress Design Margin

$$\frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

$$\frac{553}{8836} + \frac{11640}{22650} = 0.58$$


$$D.M. = \frac{1}{.58} - 1 = \underline{\underline{0.73}}$$

Shear Design Margin

$$\tau_{xz} =$$

$$F_v = .4(25800) = 10320 \text{ psi}$$


$$D.M. = \frac{10320}{100} - 1 = \underline{\underline{\text{High}}}$$


| | | |
|----------------------------|--|--------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>110</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI 000001</i> |
| DATE: <i>3-8-83</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL TANGS

Buckling Strength

In order to evaluate the buckling strength of the sodium support tangs a test was conducted. This test was performed to evaluate Sandias concerns about a prebent tang in compression. A sketch of the test set-up is shown below.



| | | |
|----------------------------|---|----------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>111</i> OF |
| CHECKED BY: | | <i>079TI000001</i> REPORT NO. |
| DATE: <i>3-9-83</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER


The tangs were permanently displaced 0.30 inches, as shown in Section AA, prior to the test. In this configuration, lead weights were loaded onto the tubes. The maximum load applied was 65 lbs. At this load the tangs were supporting the load without buckling.

The results of this test indicate that the tangs with an offset of 0.30 inch (far in excess to that expected during operation) can support 65 lbs. or 16.3 lbs per tang.

The maximum expected load on the tang is approximately 6 lbs, therefore a factor of safety of 2.7 is indicated.



APPENDIX 6.5
Hatband Stress Analysis

| | | |
|----------------------------|--|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>113</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>Feb 7, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT HAT BANDS

The analysis results for the stresses in the panel support hat bands indicate that the highest stresses occur in the next from top hat-band near the outlet header.

The loads on the hat bands include the effects of deadweight, thermal expansion, seismic, wind, and the ΔT from the flux side of the panel to the back side. All loads are conservatively added absolutely.

From the system receiver model, the loads due to deadweight, thermal expansion, seismic and wind are:


Element 120, Node 437

| Load | D.W. | T.E. | Seismic | Wind | Total |
|----------------|-------|-------|---------|-------|-------|
| P_1 | .20 | 12.58 | 61.5 | .0 | 64.3 |
| P_2 } lbs | .65 | 2.98 | .45 | 1.15 | 5.23 |
| P_3 | .65 | 43.46 | 18.15 | 20.35 | 82.61 |
| M_1 | 1.48 | 3.08 | .19 | .73 | 5.48 |
| M_2 } in-lbs | 16.74 | 1326 | 127 | 143.2 | 1613 |
| M_3 | 28.99 | 233 | 14.67 | 8.38 | 285 |

From the single tube model the tang loads for elements 81 and 82 combined is 0.263 lbs. for a single tube. Since there are 1.33 tubes per inch the ΔT thermal condition loads up the hat band with $1.33 \times 0.263 = 0.35$ lbs/inch. The maximum hat band stress will be calculated for the 0.35 lbs/inch and added absolutely to the stresses from the receiver system model.

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT HAT BANDS


Each panel is supported by two tie rods.



Assuming a 19.34 in long cantilever beam the maximum moment occur at point A.

$$M_2 = \frac{wl^2}{2} = \frac{0.35(19.34)^2}{2} = 65 \text{ in-lbs.}$$

Hat Band Section Properties



$A = 0.75 \text{ in}^2$
 $I_{22} = 0.179 \text{ in}^4$
 $I_{33} = 0.782 \text{ in}^4$
 $A_{s22} = 0.50 \text{ in}^2$
 $A_{s33} = 0.3125 \text{ in}^2$
 Torsional Constant
 $R = 0.0036$

Material: Carbon Steel
 ASTM - A366

Hat band Stresses


$$\tau_{axial} = \frac{P_1}{A} = \frac{64.3}{0.75} = 86 \text{ psi}$$

$$\tau_{shear} = \frac{P_2}{A_2} + \frac{P_3}{A_3} + \frac{M_1 t}{R}$$

$$= \frac{5.23}{.50} + \frac{82.61}{.3125} + \frac{5.48(.125)}{.0036} = 465 \text{ psi}$$

$$\tau_{bending (2-2)} = \frac{M_2 (c)}{I_{22}} = \frac{(1613 + 65)(.625)}{0.179} = 5860 \text{ psi}$$

$$\tau_{bending (3-3)} = \frac{M_3 c}{I_{33}} = \frac{285(1.875)}{0.782} = 683 \text{ psi}$$

| | | |
|----------------------------|--|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>115</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>Feb 7, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT HAT BANDS

Allowable Buckling Loads (AISC)

From AISC Section 1.9.1.2 "Unstiffened elements subject to axial compression or compression due to bending shall be considered as fully effective when the ratio of width to thickness is not greater than the following:




$$\frac{95}{\sqrt{F_y}} = \frac{95}{\sqrt{28}} = 17.95$$

$$\frac{b}{t} = \frac{1.0}{.125} = 8.0$$

$$b/t < \frac{95}{\sqrt{28}} \therefore \text{Flange Fully Effective}$$

From AISC Section 1.9.2 "Stiffened elements subject to axial compression or to uniform compression due to bending shall be considered as fully effective when the ratio of width to thickness is not greater than the following:



$$\frac{238}{\sqrt{F_y}} = \frac{238}{\sqrt{28}} = 45$$


$$\frac{b}{t} = \frac{2.0}{.125} = 16$$

$$\frac{b}{t} < \frac{238}{\sqrt{28}} \therefore \text{Web fully Effective}$$

Allowable Stresses

$$\sigma_a = .6(F_{T_y}) = .6(28) = 16,800 \text{ psi}$$

$$\tau_b = .6(F_{T_y}) = 16,800 \text{ psi}$$

| | | |
|----------------------------|--|--------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>116</i> OF |
| CHECKED BY: | | REPORT NO. <i>0797I 000001</i> |
| DATE: <i>Feb 7 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT HAT BANDS

For combined axial compression and bending


$$\frac{f_a}{F_a} + \frac{f_{b2}}{F_{b2}} + \frac{f_{b3}}{F_{b3}} \leq 1.0$$

$$\frac{86}{16800} + \frac{5860}{16800} + \frac{683}{16800} = 0.39$$

$$D.M. = \frac{1.0}{0.39} - 1 = \underline{\underline{1.56}}$$



APPENDIX 6.6
Support Rod Stress Analysis

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <i>Castle</i> |  | PAGE NO. <i>118</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>Feb 7, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT TIE RODS

The analysis results for the stresses in the panel support tie rods indicate that the highest stresses occur in the tie rod nearest the inlet header.

The loads on the tie rods include the effects of deadweight, thermal expansion, seismic, wind, and the ΔT from the flux side of the panel to the back side. All loads are conservatively added absolutely.

From the system receiver model the loads due to deadweight, thermal expansion, seismic and wind are:

Element 12, Modes 428 - 472

| Load | D.W. | T.E. | SEISMIC | WIND | TOTAL |
|----------------|------|------|---------|------|-------|
| P_1 | 4.23 | 321 | 30.55 | 42.0 | 398 |
| P_2 } lbs | — | — | — | — | — |
| P_3 } | — | — | — | — | — |
| M_1 | 0.50 | 0.07 | 0.67 | 0.07 | 1.31 |
| M_2 } in-lbs | — | — | — | — | — |
| M_3 } | — | — | — | — | — |

From the single tube model, the tie rod load for elements 63 and 64 combined is 0.684 lbs for one tube. Since one tie rod must react the loads of $\frac{1}{2}$ panel (51 tubes), the tie rod axial load is:

$$P_{\Delta T \text{ axial}} = 51(.684) = 35.0 \text{ lbs}$$

The total tie rod axial load is:

$$P_T' = 398 + 35.0 = 433 \text{ lbs.}$$

PREPARED BY:

Castle



Rockwell International
Energy Systems Group

PAGE NO. 119 OF

079TJ000001
REPORT NO.


CHECKED BY:

DATE: Feb 7, 1983

MODEL NO.

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT TIE RODS

Tie Rod Section Properties



0.083 in.

0.75 in ϕ Schedule 10S pipe

$$A = 0.252 \text{ in}^2$$

$$I = 0.0297 \text{ in}^4$$

$$C = .525 \text{ in}$$

Material: Low Alloy Steel

ASTM-A-519


($F_y = 28 \text{ KSI}$ for 1020 Annealed)

Tie Rod Stresses

$$\sigma_{\text{axial}} = \frac{P_T'}{A} = \frac{433}{0.252} = 1720 \text{ psi}$$

$$\tau_{\text{Torsion}} = \frac{M_t C}{2I} = \frac{1531(.525)}{2(.0297)} = 12 \text{ psi}$$

Allowable Buckling Load (AISC)




$$F_a = \frac{\left[1 - \frac{(KL/r)^2}{2(C_c)^2}\right] F_y}{\frac{5}{3} + \frac{3(KL/r)}{8C_c} - \frac{(KL/r)^3}{8C_c^3}}$$

$$C_c = \sqrt{\frac{2\pi^2 E}{F_y}} = \sqrt{\frac{2\pi^2 (29 \times 10^6)}{28000}} = 143$$

$$r = \sqrt{\frac{I}{A}} = \sqrt{\frac{.0297}{.252}} = .343 \text{ in}$$

$$\frac{KL}{r} = \frac{1.0(31.25)}{.343} = 91.0 \quad (K \text{ from AISC Table C1.8.1})$$

$$F_a = \frac{\left[1 - \frac{(91)^2}{2(143)^2}\right] 28000}{\frac{5}{3} + \frac{3(91)}{8(143)} - \frac{(91)^3}{8(143)^3}} = 11920 \text{ psi}$$

| | | |
|----------------------------|--|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>120</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>Feb 7, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT TIE RODS

$$T_{allow} \text{ (Compression or tension)} = .6 F_{ty}$$

$$= .60 (28000) = 16800 \text{ psi}$$

$$D.M. = \frac{11920}{1720} - 1 = \frac{5.93}{\text{AXIAL BUCKLING}}$$


$$T_{allow} \text{ (Torsion)} = .4 F_y$$

$$= .4 (28000) = 11200 \text{ psi}$$

$$D.M. = \frac{11200}{112} - 1 = \underline{\underline{High}}$$



APPENDIX 6.7
Header Stress Analysis

| | | |
|----------------------------|---|---------------------------------|
| PREPARED BY: <i>Castle</i> |  | PAGE NO. <i>122</i> OF |
| CHECKED BY: | | REPORT NO. <i>07973 000 001</i> |
| DATE: <i>Feb 9, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
INLET AND OUTLET HEADERS

The analysis results for the stresses in the inlet and outlet headers are summarized in Table. A typical evaluation method to obtain the results is shown below.

The loads on the headers include the effects of deadweight, thermal expansion, seismic, wind and the ΔT from the flux side of the panel to the back side. All loads are conservatively added absolutely.

From the receiver system model, the loads due to dead weight, thermal expansion, seismic and wind are:

Element 147, Node 495

| Load | D.W. | T.E. | Seis. | Wind | Total |
|--------------|------|-------|-------|------|-------|
| P_1 | 1 | 177 | 2 | 1 | |
| P_2 lbs | 8 | 556 | 19 | 5 | |
| P_3 | 3 | 1134 | 8 | 5 | |
| M_1 | 0 | 7629 | 435 | 707 | |
| M_2 in-lbs | 79 | 26270 | 173 | 112 | |
| M_3 | 221 | 14370 | 55 | 98 | |


From the single tube model, the sodium tube loads (interception of the manifold) are:

$$\begin{aligned}
 P_1 &= .39 \text{ lbs (neglect)} & M_1 &= 0 \\
 P_2 &= 0 & M_2 &= 0 \\
 P_3 &= 0 & M_3 &= 8.38 \text{ in-lbs}
 \end{aligned}$$

$M_3 = 8.38$ for 1 tube
 For one-fourth of the 102 tubes


Note: M_3 tube
 = M_1 Header

$$M_1 = 8.38 \left(\frac{102}{4} \right) = 214 \text{ in-lbs}$$

| | | |
|----------------------------|---|------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>123</i> OF |
| CHECKED BY: | | REPORT NO. <i>0797100001</i> |
| DATE: <i>Feb 9, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
INLET AND OUTLET HEADERS

Header Section Properties



6" ϕ Sch 10 pipe
 $A = 2.733 \text{ in}^2$
 $I = 14.40 \text{ in}^4$
 $J = 2I = 28.8 \text{ in}^4$
 $Z = 4.347 \text{ in}^3$

Header Stresses

For thermal expansion stresses per ANSI B31.1

$$S_E = \frac{i M_c}{Z} \leq S_A$$

where: $i = 1.0$

$$Z = 4.347 \text{ in}^3$$

$$M_c = [M_1^2 + M_2^2 + M_3^2]^{1/2}$$

$$= [(17629)^2 + (26270)^2 + (14584)^2]^{1/2}$$

$$= 31000 \text{ in-lbs}$$

$$S_E = \frac{31000}{4.347} = 7130 \text{ psi}$$

$$S_A @ 1050^\circ\text{F} = 18900 \text{ psi}$$

$$D.M. = \frac{18900}{7130} - 1 = \underline{\underline{1.65}}$$


For thermal expansion + sustained loads per ANSI B31.1

$$S_{TE} = \frac{p D_o}{4 t_m} + \frac{.75 L M_A}{Z} + \frac{i M_c}{Z} \leq S_h + S_a$$

where: $p = 30 \text{ psi}$

$$D_o = 6.625 \text{ in}$$

$$t_m = .134$$

| | | |
|----------------------------|---|---------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. 124 OF |
| CHECKED BY: | | 07971000001 REPORT NO. |
| DATE: <i>Feb 10, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
INLET AND OUTLET HEADERS

$$z = 4.347 \text{ in}^3$$

$$i = 1.0$$

$$M_A = [(1142)^2 + (364)^2 + (374)^2]^{1/2} = 1256 \text{ in-lbs}$$

$$M_C = 31000 \text{ in-lbs}$$


$$S_{TE} = \frac{30(6.625)}{4(.134)} + \frac{1256}{4.347} + \frac{31000}{4.347} = 7790 \text{ psi}$$

$$S_h + S_A @ 1050^\circ\text{F} = 33400 \text{ psi}$$

$$D.M. = \frac{33400}{7790} - 1 = \underline{\underline{3.29}}$$



APPENDIX 6.8
Support Beam Stress Analysis

| | | |
|----------------------------|---|--------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. 126 OF |
| CHECKED BY: | | 0797200001 REPORT NO. |
| DATE: <i>Feb 7, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
RECEIVER SUPPORT BOX

The analysis results for the stresses in the support box member indicate that the highest stresses occur in Element 101 at the inboard edge of the panel.

The loads on the support box includes the effects of dead weight, thermal expansion, seismic, wind and the ΔT from the flux side of the panel to the back side. All loads are conservatively added absolutely.

From the system receiver model, the loads due to dead weight, thermal expansion, seismic and wind are:

Element 153, Node 76

| Load | D.W. | T.E. | Seismic | Wind | Total |
|----------------|------|------|---------|------|-------|
| P_1 | -17 | 132 | 40 | 3 | 192 |
| P_2 } lbs | 539 | 157 | 191 | 8 | 895 |
| P_3 | 26 | 505 | 46 | 22 | 599 |
| M_1 | 229 | 537 | 84 | 54 | 904 |
| M_2 } in-lbs | 268 | 5058 | 359 | 230 | 5915 |
| M_3 | 5110 | 392 | 1752 | 49 | 7303 |

From the single tube model the support box loads for element 1, Node 1 are

$$P_2 = .76 \text{ lbs}$$

$$M_1 = 1.63 \text{ in-lbs}$$

Since there are 1.33 tubes per inch, the thermal condition loads up the support box with the following loads


$$P_2 = 1.33 (.76) = 1.01 \text{ lbs/in.}$$

$$M_1 = 1.33 (1.63) = 2.17 \text{ in-lbs/in.}$$

CARRIZO PLAINS SOLAR RECEIVER
RECEIVER SUPPORT BOX

The maximum box beam stress will be calculated for the WT loads and added absolutely to the stresses from the receiver system model.

The box beam is supported at two locations at 1/4 span for each panel as shown below




Assuming a 38.68 in long fixed-fixed beam, the maximum loads occur at point A

$$P_2 = 38.68 (1.01) = 39.0 \text{ lbs}$$

$$M_3 = \frac{P_2 l}{12} = \frac{39 (38.68)}{12} = 126 \text{ in-lbs}$$

$$M_1 = 2.17 (38.68) / 2 = 42 \text{ in-lbs}$$

Support box Section Properties



$$A = 2.09 \text{ in}^2$$

$$I_{22} = 2.21 \text{ in}^4$$

$$I_{33} = 1.15 \text{ in}^4$$

$$A_{s22} = 1.0 \text{ in}^2$$

$$A_{s33} = 1.5 \text{ in}^2$$

$$[A] = 2.5 (1.5) = 3.75 \text{ in}^2$$

Material: 304 S.S.

Support Box Stresses

$$\tau_{axial} = \frac{P_1}{A} = \frac{192}{2.09} = 92 \text{ psi}$$

CARRIZO PLAINS SOLAR RECEIVER
RECEIVER SUPPORT BOX

Support Box Stresses ~ Contd

$$\tau_{\text{shear}} = \frac{P_2}{A_2} + \frac{P_3}{A_3} + \frac{M_1}{2[A]t}$$


$$= \frac{934}{1.0} + \frac{599}{1.5} + \frac{946}{2(3.75)(.25)} = 1838 \text{ psi}$$

$$\sigma_{\text{bending}} (2-2) = \frac{M_2 C}{I_{22}} = \frac{5915 (1.5)}{1.15} = 7715 \text{ psi}$$

$$\sigma_{\text{bending}} (3-3) = \frac{M_3 C}{I_{33}} = \frac{(7303+126)(1)}{2.21} = 3360 \text{ psi}$$

Allowable Buckling Loads

From AISC Section 1.9.2 "Stiffened elements subject to axial compression or to uniform compression due to bending shall be considered as fully effective when the ratio of width to thickness is not greater than the following



$$\frac{238}{\sqrt{F_y}} = \frac{238}{\sqrt{25}} = 47.6$$

$$\frac{b}{t} = \frac{3.0}{.25} = 12$$

$$\frac{b}{t} < \frac{238}{\sqrt{25}} \therefore \text{Web Fully Effective}$$

Allowable stresses


$$\tau_a = .6 F_{T7} = .6 (25000) = 15000 \text{ psi}$$

$$\tau_b = .6 F_{T7} = 15000 \text{ psi}$$

$$\tau_s = .4 F_{T7} = .4 (25000) = 10000 \text{ psi}$$

For combined axial compression and bending

$$\frac{f_a}{F_a} + \frac{f_{b22}}{F_b} + \frac{f_{b33}}{F_b} < 1$$

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>129</i> of |
| CHECKED BY: | | REPORT NO. <i>079T1000001</i> |
| DATE: <i>Feb 8, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
RECEIVER SUPPORT BOX

$$\frac{92}{15000} + \frac{7715}{15000} + \frac{3360}{15000} = 0.74$$

$$D.M. = \frac{1}{.74} - 1 = \underline{\underline{0.35}}$$

For a shear stress of 1284.

$$D.M. = \frac{10000}{1838} - 1 = \underline{\underline{4.44}}$$



APPENDIX 6.9
Support Truss Stress Analysis

PREPARED BY:

Castle



Rockwell International

Energy Systems Group

PAGE NO. 131 OF


0797I 000001
REPORT NO.

CHECKED BY:

DATE: *Feb 8, 1983*

MODEL NO.


CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT TRUSS



*Structural
Tee
3 x 2 1/2 x .31
Material
ASTM-A36
Carbon Steel*

Each of the 8 receiver panels is supported by 2 truss supports located at the 1/4 points on the panel.

The loads on the trusses include the effects of dead weight, thermal expansion, seismic, wind, and the ΔT from the flux side of the panel to the back side. All loads are conservatively added absolutely.

| | | |
|----------------------------|---|------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. 132 of |
| CHECKED BY: | | REPORT NO. 079TI000001 |
| DATE: <i>Feb 8, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT TRUSS

From the system receiver model, the loads due to deadweight, thermal expansion, seismic and wind are:

| ELE | NODE | LOAD | D.W. | T.E. | SEIS. | Wind | Total |
|-----|----------|----------------|------|------|-------|------|-------|
| 23 | 76 I | P ₁ | 2862 | 1716 | 879 | 44 | 5501 |
| | | M ₁ | 4 | 0 | 4 | 1 | 9 |
| | | M ₃ | 0 | 12 | 1 | 1 | 14 |
| | 498 J | P ₁ | 2862 | 1716 | 879 | 44 | 5501 |
| | | M ₁ | 4 | 0 | 4 | 1 | 9 |
| | | M ₃ | 0 | 6 | 0 | 0 | 6 |
| 162 | 76 I | P ₁ | 3343 | 454 | 1125 | 35 | 4657 |
| | | M ₁ | 3 | 5 | 3 | 0 | 11 |
| | | M ₃ | 2 | 9 | 1 | 1 | 13 |
| | 499 J | P ₁ | 3343 | 154 | 1125 | 35 | 4657 |
| | | M ₁ | 3 | 5 | 3 | 0 | 11 |
| | | M ₃ | 1 | 4 | 1 | 1 | 7 |
| 163 | 251 I | P ₁ | 2457 | 1773 | 527 | 8 | 4765 |
| | | M ₁ | 11 | 1 | 5 | 0 | 17 |
| | | M ₃ | 2 | 14 | 0 | 0 | 16 |
| | 500 J | P ₁ | 2457 | 1773 | 527 | 8 | 4765 |
| | | M ₁ | 11 | 1 | 5 | 0 | 17 |
| | | M ₃ | 1 | 7 | 0 | 0 | 8 |
| 164 | 251 I | P ₁ | 2932 | 27 | 737 | 130 | 3826 |
| | | M ₁ | 9 | 4 | 4 | 0 | 17 |
| | | M ₃ | 4 | 11 | 2 | 0 | 17 |
| | 501 J | P ₁ | 2932 | 27 | 737 | 130 | 3826 |
| | | M ₁ | 9 | 4 | 4 | 0 | 17 |
| | | M ₃ | 4 | 6 | 1 | 0 | 11 |

Note: P = lbs
 M = in-lbs.

PREPARED BY: *Castle*



Rockwell International
Energy Systems Group


PAGE NO. 133 of

079T1000001
REPORT NO.

CHECKED BY:
DATE: *Feb 8, 1983*

MODEL NO.

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT TRUSS



The highest loads occur for beam elements 23 and 162. Conservatively use the following loads

$$P_1 = 5501 \text{ lbs} \quad M_1 = 11 \text{ in-lbs} \quad M_3 = 14 \text{ in-lbs.}$$

For the cross-section BB


$$A = 3(.31) = 0.93 \text{ in}^2$$

$$I_{33} = \frac{3(.31)^3}{12} = .0074 \text{ in}^4$$

$$\sigma_{axial} = \frac{5501}{.93} = 5915 \text{ psi}$$

$$\sigma_{bending} = \frac{M_3 c}{I} = \frac{14(.155)}{.0074} = 293 \text{ psi}$$

$$\sigma_{torsion} = \frac{3M_1}{bt^2} = \frac{(81)}{3(.31)^2} = 281 \text{ psi}$$

| | | |
|----------------------------|---|-------------------------------|
| PREPARED BY: <i>Castle</i> |  Rockwell International Energy Systems Group | PAGE NO. <i>134</i> OF |
| CHECKED BY: | | REPORT NO. <i>079TI000001</i> |
| DATE: <i>Feb 16, 1983</i> | | MODEL NO. |

CARRIZO PLAINS SOLAR RECEIVER
PANEL SUPPORT TRUSS

For ASTM A-36 Carbon Steel

$$F_y = 36000 \text{ psi}$$

$$F_a = .6 (36000) = 21600 \text{ psi}$$

$$F_b = 21600 \text{ psi}$$

Check Buckling allowable

$$P_{cr} = \frac{\pi^2 EI}{L^2} \quad (\text{Roark 4th Ed, Table 8V})$$

$$\text{where: } E = 29 \times 10^6$$

$$I = .0074 \text{ in}^4$$

$$L = 10 \text{ in.}$$

$$P_{cr} = \frac{\pi^2 (29 \times 10^6) (.0074)}{(10)^2} = 21180 \text{ lbs}$$

$$T_{cr} = \frac{P_{cr}}{A} = \frac{21180}{.93} = 22775 \text{ psi}$$

$22775 > 21600 \therefore$ Buckling Not Critical

Combined Stress Design Margin

$$\frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

$$\frac{.5915}{21600} + \frac{293}{21600} = 0.29$$

$$D.M. = \frac{1}{.29} - 1 = \underline{\underline{2.45}}$$

Note: Section AA is adequate by inspection.



APPENDIX 6.10

Finite Element Model Input Data Listings

PROGRAM INPUT DATA

ESG CARRIZO PLAINS SOLAR RECEIVER PANEL - W. CASTLE - JANUARY 1983

| 520 | 3 | 4 | 1 | 1 | 3 |
|-----|---|---|--------|-------|-------|
| 1 | | | 0.00 | 0.00 | 3.87 |
| 2 | | | 2.34 | 2.34 | 3.87 |
| 3 | | | 5.03 | 5.03 | 3.87 |
| 4 | | | 7.15 | 5.75 | 3.87 |
| 5 | | | 9.27 | 5.03 | 3.87 |
| 6 | | | 14.36 | 0.00 | 3.87 |
| 7 | | | 31.00 | 0.00 | 3.87 |
| 8 | | | 48.00 | 0.00 | 3.87 |
| 9 | | | 72.00 | 0.00 | 3.87 |
| 10 | | | 96. | 0.00 | 3.87 |
| 11 | | | 120. | 0.00 | 3.87 |
| 12 | | | 144. | 0.00 | 3.87 |
| 13 | | | 168. | 0.00 | 3.87 |
| 14 | | | 192. | 0.00 | 3.87 |
| 15 | | | 216. | 0.00 | 3.87 |
| 16 | | | 240. | 0.00 | 3.87 |
| 17 | | | 264. | 0.00 | 3.87 |
| 18 | | | 288. | 0.00 | 3.87 |
| 19 | | | 312. | 0.00 | 3.87 |
| 20 | | | 336. | 0.00 | 3.87 |
| 21 | | | 360. | 0.00 | 3.87 |
| 22 | | | 384. | 0.00 | 3.87 |
| 23 | | | 408. | 0.00 | 3.87 |
| 24 | | | 432. | 0.00 | 3.87 |
| 25 | | | 456. | 0.00 | 3.87 |
| 26 | | | 480. | 0.00 | 3.87 |
| 27 | | | 504. | 0.00 | 3.87 |
| 28 | | | 528. | 0.00 | 3.87 |
| 29 | | | 556.82 | 0.00 | 3.87 |
| 30 | | | 585.64 | 0.00 | 3.87 |
| 31 | | | 590.73 | 5.03 | 3.87 |
| 32 | | | 592.85 | 5.75 | 3.87 |
| 33 | | | 594.97 | 5.03 | 3.87 |
| 34 | | | 597.66 | 2.34 | 3.87 |
| 35 | | | 600. | 0.00 | 3.87 |
| 36 | | | 0. | 0.00 | 11.60 |
| 37 | | | 2.34 | -2.34 | 11.60 |
| 38 | | | 5.03 | -5.03 | 11.60 |
| 39 | | | 7.15 | -5.75 | 11.60 |
| 40 | | | 9.27 | -5.03 | 11.60 |
| 41 | | | 14.36 | 0.00 | 11.60 |
| 42 | | | 31.00 | 0.00 | 11.60 |
| 43 | | | 48. | 0.00 | 11.60 |
| 44 | | | 72. | 0.00 | 11.60 |
| 45 | | | 96. | 0.00 | 11.60 |
| 46 | | | 120. | 0.00 | 11.60 |
| 47 | | | 144. | 0.00 | 11.60 |
| 48 | | | 168. | 0.00 | 11.60 |
| 49 | | | 192. | 0.00 | 11.60 |
| 50 | | | 216. | 0.00 | 11.60 |
| 51 | | | 240. | 0.00 | 11.60 |
| 52 | | | 264. | 0.00 | 11.60 |
| 53 | | | 288. | 0.00 | 11.60 |
| 54 | | | 312. | 0.00 | 11.60 |
| 55 | | | 336. | 0.00 | 11.60 |
| 56 | | | 360. | 0.00 | 11.60 |

SAP V RECEIVER SYSTEM
MODEL INPUT DATA LISTING

079T1000001
Page 136

| | | | | |
|-----|--------|-------|-------|--------|
| 57 | 384. | 0.00 | 11.60 | 972.7 |
| 58 | 408. | 0.00 | 11.60 | 993.4 |
| 59 | 432. | 0.00 | 11.60 | 1014.1 |
| 60 | 456. | 0.00 | 11.60 | 1026.6 |
| 61 | 480. | 0.00 | 11.60 | 1039. |
| 62 | 504. | 0.00 | 11.60 | 1045.4 |
| 63 | 528. | 0.00 | 11.60 | 1051.8 |
| 64 | 556.82 | 0.00 | 11.60 | 1050. |
| 65 | 585.64 | 0.00 | 11.60 | 1050. |
| 66 | 590.73 | -5.03 | 11.60 | 1050. |
| 67 | 592.85 | -5.75 | 11.60 | 1050. |
| 68 | 594.97 | -5.03 | 11.60 | 1050. |
| 69 | 597.66 | -2.34 | 11.60 | 1050. |
| 70 | 600.00 | 0.00 | 11.60 | 1050. |
| 71 | 0.00 | 0.00 | 19.33 | 610. |
| 72 | 2.34 | 2.34 | 19.33 | 610. |
| 73 | 5.03 | 5.03 | 19.33 | 610. |
| 74 | 7.15 | 5.75 | 19.33 | 610. |
| 75 | 9.27 | 5.03 | 19.33 | 610. |
| 76 | 14.36 | 0.00 | 19.33 | 610. |
| 77 | 31.00 | 0.00 | 19.33 | 610. |
| 78 | 48.00 | 0.00 | 19.33 | 612.2 |
| 79 | 72. | 0.00 | 19.33 | 620.8 |
| 80 | 96. | 0.00 | 19.33 | 629.3 |
| 81 | 120. | 0.00 | 19.33 | 644.9 |
| 82 | 144. | 0.00 | 19.33 | 660.5 |
| 83 | 168. | 0.00 | 19.33 | 684.8 |
| 84 | 192. | 0.00 | 19.33 | 709.0 |
| 85 | 216. | 0.00 | 19.33 | 741.2 |
| 86 | 240. | 0.00 | 19.33 | 773.4 |
| 87 | 264. | 0.00 | 19.33 | 809.9 |
| 88 | 288. | 0.00 | 19.33 | 846.3 |
| 89 | 312. | 0.00 | 19.33 | 881.5 |
| 90 | 336. | 0.00 | 19.33 | 916.7 |
| 91 | 360. | 0.00 | 19.33 | 945.7 |
| 92 | 384. | 0.00 | 19.33 | 974.6 |
| 93 | 408. | 0.00 | 19.33 | 995.0 |
| 94 | 432. | 0.00 | 19.33 | 1015.4 |
| 95 | 456. | 0.00 | 19.33 | 1027.6 |
| 96 | 480. | 0.00 | 19.33 | 1039.7 |
| 97 | 504. | 0.00 | 19.33 | 1046. |
| 98 | 528. | 0.00 | 19.33 | 1052.2 |
| 99 | 556.82 | 0.00 | 19.33 | 1050. |
| 100 | 585.64 | 0.00 | 19.33 | 1050. |
| 101 | 590.73 | 5.03 | 19.33 | 1050. |
| 102 | 592.85 | 5.75 | 19.33 | 1050. |
| 103 | 594.97 | 5.03 | 19.33 | 1050. |
| 104 | 597.66 | 2.34 | 19.33 | 1050. |
| 105 | 600.00 | 0.00 | 19.33 | 1050. |
| 106 | 0.00 | 0.00 | 27.06 | 610. |
| 107 | 2.34 | -2.34 | 27.06 | 610. |
| 108 | 5.03 | -5.03 | 27.06 | 610. |
| 109 | 7.15 | -5.75 | 27.06 | 610. |
| 110 | 9.27 | -5.03 | 27.06 | 610. |
| 111 | 14.36 | 0.00 | 27.06 | 610. |
| 112 | 31.00 | 0.00 | 27.06 | 610. |
| 113 | 48.00 | 0.00 | 27.06 | 612.5 |
| 114 | 72. | 0.00 | 27.06 | 621.3 |
| 115 | 96. | 0.00 | 27.06 | 630. |
| 116 | 120. | 0.00 | 27.06 | 645.9 |
| 117 | 144. | 0.00 | 27.06 | 661.7 |
| 118 | 168. | 0.00 | 27.06 | 686.3 |

079T1000001
 Page 137

| | | | | |
|-----|--------|-------|-------|--------|
| 119 | 192. | 0.00 | 27.06 | 710.8 |
| 120 | 216. | 0.00 | 27.06 | 743.3 |
| 121 | 240. | 0.00 | 27.06 | 775.7 |
| 122 | 264. | 0.00 | 27.06 | 812.6 |
| 123 | 288. | 0.00 | 27.06 | 848.8 |
| 124 | 312. | 0.00 | 27.06 | 883.9 |
| 125 | 336. | 0.00 | 27.06 | 919. |
| 126 | 360. | 0.00 | 27.06 | 947.8 |
| 127 | 384. | 0.00 | 27.06 | 976.5 |
| 128 | 408. | 0.00 | 27.06 | 996.5 |
| 129 | 432. | 0.00 | 27.06 | 1016.6 |
| 130 | 456. | 0.00 | 27.06 | 1028.5 |
| 131 | 480. | 0.00 | 27.06 | 1040.4 |
| 132 | 504. | 0.00 | 27.06 | 1046.5 |
| 133 | 528. | 0.00 | 27.06 | 1052.5 |
| 134 | 556.82 | 0.00 | 27.06 | 1050.0 |
| 135 | 585.64 | 0.00 | 27.06 | 1050. |
| 136 | 590.73 | -5.03 | 27.06 | 1050. |
| 137 | 592.85 | -5.75 | 27.06 | 1050. |
| 138 | 594.97 | -5.03 | 27.06 | 1050. |
| 139 | 597.66 | -2.34 | 27.06 | 1050. |
| 140 | 600.00 | 0.00 | 27.06 | 1050. |
| 141 | 0.00 | 0.00 | 34.79 | 610. |
| 142 | 2.34 | 2.34 | 34.79 | 610. |
| 143 | 5.03 | 5.03 | 34.79 | 610. |
| 144 | 7.15 | 5.75 | 34.79 | 610. |
| 145 | 9.27 | 5.03 | 34.79 | 610. |
| 146 | 14.36 | 0.00 | 34.79 | 610. |
| 147 | 31. | 0.00 | 34.79 | 610. |
| 148 | 48. | 0.00 | 34.79 | 612.9 |
| 149 | 72. | 0.00 | 34.79 | 621.8 |
| 150 | 96. | 0.00 | 34.79 | 630.7 |
| 151 | 120. | 0.00 | 34.79 | 646.8 |
| 152 | 144. | 0.00 | 34.79 | 662.9 |
| 153 | 168. | 0.00 | 34.79 | 687.8 |
| 154 | 192. | 0.00 | 34.79 | 712.6 |
| 155 | 216. | 0.00 | 34.79 | 745.3 |
| 156 | 240. | 0.00 | 34.79 | 778.0 |
| 157 | 264. | 0.00 | 34.79 | 814.7 |
| 158 | 288. | 0.00 | 34.79 | 851.3 |
| 159 | 312. | 0.00 | 34.79 | 886.3 |
| 160 | 336. | 0.00 | 34.79 | 921.3 |
| 161 | 360. | 0.00 | 34.79 | 949.8 |
| 162 | 384. | 0.00 | 34.79 | 978.3 |
| 163 | 408. | 0.00 | 34.79 | 998.1 |
| 164 | 432. | 0.00 | 34.79 | 1017.8 |
| 165 | 456. | 0.00 | 34.79 | 1029.5 |
| 166 | 480. | 0.00 | 34.79 | 1041.1 |
| 167 | 504. | 0.00 | 34.79 | 1047. |
| 168 | 528. | 0.00 | 34.79 | 1052.9 |
| 169 | 556.82 | 0.00 | 34.79 | 1050. |
| 170 | 585.64 | 0.00 | 34.79 | 1050. |
| 171 | 590.73 | 5.03 | 34.79 | 1050. |
| 172 | 592.85 | 5.75 | 34.79 | 1050. |
| 173 | 594.97 | 5.03 | 34.79 | 1050. |
| 174 | 597.66 | 2.34 | 34.79 | 1050. |
| 175 | 600.00 | 0.00 | 34.79 | 1050. |
| 176 | 0.00 | 0.00 | 42.52 | 610. |
| 177 | 2.34 | -2.34 | 42.52 | 610. |
| 17R | 5.03 | -5.03 | 42.5 | 610. |
| 17 | 7.15 | -5.75 | 42 | 610. |
| 18 | 9.27 | -5.03 | 42 | 610. |

| | | | | |
|-----|--------|-------|-------|--------|
| 181 | 14.36 | 0.00 | 42.52 | 610. |
| 182 | 31. | 0.00 | 42.52 | 610. |
| 183 | 48. | 0.00 | 42.52 | 613.2 |
| 184 | 72. | 0.00 | 42.52 | 622.3 |
| 185 | 96. | 0.00 | 42.52 | 631.4 |
| 186 | 120. | 0.00 | 42.52 | 647.8 |
| 187 | 144. | 0.00 | 42.52 | 664.2 |
| 188 | 168. | 0.00 | 42.52 | 689.4 |
| 189 | 192. | 0.00 | 42.52 | 714.5 |
| 190 | 216. | 0.00 | 42.52 | 747.4 |
| 191 | 240. | 0.00 | 42.52 | 780.3 |
| 192 | 264. | 0.00 | 42.52 | 817.1 |
| 193 | 288. | 0.00 | 42.52 | 853.8 |
| 194 | 312. | 0.00 | 42.52 | 888.7 |
| 195 | 336. | 0.00 | 42.52 | 923.6 |
| 196 | 360. | 0.00 | 42.52 | 951.9 |
| 197 | 384. | 0.00 | 42.52 | 980.1 |
| 198 | 408. | 0.00 | 42.52 | 999.6 |
| 199 | 432. | 0.00 | 42.52 | 1019.0 |
| 200 | 456. | 0.00 | 42.52 | 1030.5 |
| 201 | 480. | 0.00 | 42.52 | 1041.9 |
| 202 | 504. | 0.00 | 42.52 | 1047.6 |
| 203 | 528. | 0.00 | 42.52 | 1053.2 |
| 204 | 556.82 | 0.00 | 42.52 | 1050. |
| 205 | 585.64 | 0.00 | 42.52 | 1050. |
| 206 | 590.73 | -5.03 | 42.52 | 1050. |
| 207 | 592.85 | -5.75 | 42.52 | 1050. |
| 208 | 594.97 | -5.03 | 42.52 | 1050. |
| 209 | 597.66 | -2.34 | 42.52 | 1050. |
| 210 | 600. | 0.00 | 42.52 | 1050. |
| 211 | 0.00 | 0.00 | 50.25 | 610. |
| 212 | 2.34 | 2.34 | 50.25 | 610. |
| 213 | 5.03 | 5.03 | 50.25 | 610. |
| 214 | 7.15 | 5.75 | 50.25 | 610. |
| 215 | 9.27 | 5.03 | 50.25 | 610. |
| 216 | 14.36 | 0.00 | 50.25 | 610. |
| 217 | 31. | 0.00 | 50.25 | 610. |
| 218 | 48. | 0.00 | 50.25 | 613.6 |
| 219 | 72. | 0.00 | 50.25 | 622.9 |
| 220 | 96. | 0.00 | 50.25 | 632.1 |
| 221 | 120. | 0.00 | 50.25 | 648.8 |
| 222 | 144. | 0.00 | 50.25 | 665.4 |
| 223 | 168. | 0.00 | 50.25 | 690.9 |
| 224 | 192. | 0.00 | 50.25 | 716.3 |
| 225 | 216. | 0.00 | 50.25 | 749.5 |
| 226 | 240. | 0.00 | 50.25 | 782.7 |
| 227 | 264. | 0.00 | 50.25 | 819.5 |
| 228 | 288. | 0.00 | 50.25 | 856.3 |
| 229 | 312. | 0.00 | 50.25 | 891.2 |
| 230 | 336. | 0.00 | 50.25 | 926. |
| 231 | 360. | 0.00 | 50.25 | 954. |
| 232 | 384. | 0.00 | 50.25 | 982. |
| 233 | 408. | 0.00 | 50.25 | 1001.2 |
| 234 | 432. | 0.00 | 50.25 | 1020.3 |
| 235 | 456. | 0.00 | 50.25 | 1031.5 |
| 236 | 480. | 0.00 | 50.25 | 1042.6 |
| 237 | 504. | 0.00 | 50.25 | 1048.1 |
| 238 | 528. | 0.00 | 50.25 | 1053.6 |
| 239 | 556.82 | 0.00 | 50.25 | 1050. |
| 240 | 585.64 | 0.00 | 50.25 | 1050. |
| 241 | 590.73 | 5.03 | 50.25 | 1050. |
| 242 | 592.85 | 5.75 | 50.25 | 1050. |

| | | | | | |
|-----|-----|--------|-------|-------|--------|
| 243 | | 594.97 | 5.03 | 50.25 | 1050. |
| 244 | | 597.66 | 2.34 | 50.25 | 1050. |
| 245 | | 600. | 0.00 | 50.25 | 1050. |
| 246 | | 0.00 | 0.00 | 57.98 | 610. |
| 247 | | 2.34 | -2.34 | 57.98 | 610. |
| 248 | | 5.03 | -5.03 | 57.98 | 610. |
| 249 | | 7.15 | -5.75 | 57.98 | 610. |
| 250 | | 9.27 | -5.03 | 57.98 | 610. |
| 251 | | 14.36 | 0.00 | 57.98 | 610. |
| 252 | | 31. | 0.00 | 57.98 | 610. |
| 253 | | 48. | 0.00 | 57.98 | 613.9 |
| 254 | | 72. | 0.00 | 57.98 | 623.4 |
| 255 | | 96. | 0.00 | 57.98 | 632.8 |
| 256 | | 120. | 0.00 | 57.98 | 649.7 |
| 257 | | 144. | 0.00 | 57.98 | 666.6 |
| 258 | | 168. | 0.00 | 57.98 | 692.4 |
| 259 | | 192. | 0.00 | 57.98 | 718.1 |
| 260 | | 216. | 0.00 | 57.98 | 751.6 |
| 261 | | 240. | 0.00 | 57.98 | 785. |
| 262 | | 264. | 0.00 | 57.98 | 822. |
| 263 | | 288. | 0.00 | 57.98 | 858.9 |
| 264 | | 312. | 0.00 | 57.98 | 893.6 |
| 265 | | 336. | 0.00 | 57.98 | 928.3 |
| 266 | | 360. | 0.00 | 57.98 | 956.1 |
| 267 | | 384. | 0.00 | 57.98 | 983.8 |
| 268 | | 408. | 0.00 | 57.98 | 1002.7 |
| 269 | | 432. | 0.00 | 57.98 | 1021.5 |
| 270 | | 456. | 0.00 | 57.98 | 1032.4 |
| 271 | | 480. | 0.00 | 57.98 | 1043.3 |
| 272 | | 504. | 0.00 | 57.98 | 1048.6 |
| 273 | | 528. | 0.00 | 57.98 | 1053.9 |
| 274 | | 556.82 | 0.00 | 57.98 | 1050. |
| 275 | | 585.64 | 0.00 | 57.98 | 1050. |
| 276 | | 590.73 | -5.03 | 57.98 | 1050. |
| 277 | | 592.85 | -5.75 | 57.98 | 1050. |
| 278 | | 594.97 | -5.03 | 57.98 | 1050. |
| 279 | | 597.66 | -2.34 | 57.98 | 1050. |
| 280 | 1 1 | 600. | 0.00 | 57.98 | 1050. |
| 281 | | 0.00 | 0.00 | 65.71 | 610. |
| 282 | | 2.34 | 2.34 | 65.71 | 610. |
| 283 | | 5.03 | 5.03 | 65.71 | 610. |
| 284 | | 7.15 | 5.75 | 65.71 | 610. |
| 285 | | 9.27 | 5.03 | 65.71 | 610. |
| 286 | | 14.36 | 0.00 | 65.71 | 610. |
| 287 | | 31.0 | 0.00 | 65.71 | 610. |
| 288 | | 48. | 0.00 | 65.71 | 614.3 |
| 289 | | 72. | 0.00 | 65.71 | 623.9 |
| 290 | | 96. | 0.00 | 65.71 | 633.5 |
| 291 | | 120. | 0.00 | 65.71 | 650.7 |
| 292 | | 144. | 0.00 | 65.71 | 667.8 |
| 293 | | 168. | 0.00 | 65.71 | 693.9 |
| 294 | | 192. | 0.00 | 65.71 | 720. |
| 295 | | 216. | 0.00 | 65.71 | 753.7 |
| 296 | | 240. | 0.00 | 65.71 | 787.3 |
| 297 | | 264. | 0.00 | 65.71 | 824.4 |
| 298 | | 288. | 0.00 | 65.71 | 861.4 |
| 299 | | 312. | 0.00 | 65.71 | 896. |
| 300 | | 336. | 0.00 | 65.71 | 930.6 |
| 301 | | 360. | 0.00 | 65.71 | 958.1 |
| 302 | | 384. | 0.00 | 65.71 | 985.6 |
| 303 | | 408. | 0.00 | 65.71 | 1004.2 |
| 304 | | 432. | 0.00 | 65.71 | 1022.7 |

079T1000001
Page 140

| | | | | |
|-----|--------|-------|-------|--------|
| 305 | 456. | 0.00 | 65.71 | 1033.4 |
| 306 | 480. | 0.00 | 65.71 | 1044. |
| 307 | 504. | 0.00 | 65.71 | 1049.2 |
| 308 | 528. | 0.00 | 65.71 | 1054.3 |
| 309 | 556.82 | 0.00 | 65.71 | 1050. |
| 310 | 585.64 | 0.00 | 65.71 | 1050. |
| 311 | 590.73 | 5.03 | 65.71 | 1050. |
| 312 | 592.85 | 5.75 | 65.71 | 1050. |
| 313 | 594.97 | 5.03 | 65.71 | 1050. |
| 314 | 597.66 | 2.34 | 65.71 | 1050. |
| 315 | 600. | 0.00 | 65.71 | 1050. |
| 316 | 0.00 | 0.00 | 73.44 | 610. |
| 317 | 2.34 | -2.34 | 73.44 | 610. |
| 318 | 5.03 | -5.03 | 73.44 | 610. |
| 319 | 7.15 | -5.75 | 73.44 | 610. |
| 320 | 9.27 | -5.03 | 73.44 | 610. |
| 321 | 14.36 | 0.00 | 73.44 | 610. |
| 322 | 31. | 0.00 | 73.44 | 610. |
| 323 | 48. | 0.00 | 73.44 | 614.6 |
| 324 | 72. | 0.00 | 73.44 | 624.4 |
| 325 | 96. | 0.00 | 73.44 | 634.2 |
| 326 | 120. | 0.00 | 73.44 | 651.7 |
| 327 | 144. | 0.00 | 73.44 | 669.1 |
| 328 | 168. | 0.00 | 73.44 | 695.5 |
| 329 | 192. | 0.00 | 73.44 | 721.8 |
| 330 | 216. | 0.00 | 73.44 | 755.8 |
| 331 | 240. | 0.00 | 73.44 | 789.7 |
| 332 | 264. | 0.00 | 73.44 | 826.8 |
| 333 | 288. | 0.00 | 73.44 | 863.9 |
| 334 | 312. | 0.00 | 73.44 | 898.5 |
| 335 | 336. | 0.00 | 73.44 | 933. |
| 336 | 360. | 0.00 | 73.44 | 960.2 |
| 337 | 384. | 0.00 | 73.44 | 987.4 |
| 338 | 408. | 0.00 | 73.44 | 1005.7 |
| 339 | 432. | 0.00 | 73.44 | 1023.9 |
| 340 | 456. | 0.00 | 73.44 | 1034.3 |
| 341 | 480. | 0.00 | 73.44 | 1044.7 |
| 342 | 504. | 0.00 | 73.44 | 1049.7 |
| 343 | 528. | 0.00 | 73.44 | 1054.6 |
| 344 | 556.82 | 0.00 | 73.44 | 1050. |
| 345 | 585.64 | 0.00 | 73.44 | 1050. |
| 346 | 590.73 | -5.03 | 73.44 | 1050. |
| 347 | 592.85 | -5.75 | 73.44 | 1050. |
| 348 | 594.97 | -5.03 | 73.44 | 1050. |
| 349 | 597.66 | -2.34 | 73.44 | 1050. |
| 350 | 600. | 0.00 | 73.44 | 1050. |
| 351 | 48. | -4.00 | 3.87 | 200. |
| 352 | 96. | -4.00 | 3.87 | 200. |
| 353 | 144. | -4.00 | 3.87 | 200. |
| 354 | 192. | -4.00 | 3.87 | 200. |
| 355 | 240. | -4.00 | 3.87 | 200. |
| 356 | 288. | -4.00 | 3.87 | 200. |
| 357 | 336. | -4.00 | 3.87 | 200. |
| 358 | 384. | -4.00 | 3.87 | 200. |
| 359 | 432. | -4.0 | 3.87 | 200. |
| 360 | 480. | -4.0 | 3.87 | 200. |
| 361 | 528. | -4.0 | 3.87 | 200. |
| 362 | 48. | -4.0 | 11.60 | 200. |
| 363 | 96. | -4.0 | 11.60 | 200. |
| 364 | 144. | -4.0 | 11.60 | 200. |
| 365 | 192. | -4.0 | 11.60 | 200. |
| 366 | 240. | -4.0 | 11.60 | 200. |

079TI000001
 Page 141

| | | | | |
|-----|------|-------|-------|------|
| 367 | 288. | -4.0 | 11.60 | 200. |
| 368 | 336. | -4.0 | 11.60 | 200. |
| 369 | 384. | -4.0 | 11.60 | 200. |
| 370 | 432. | -4.0 | 11.60 | 200. |
| 371 | 480. | -4.0 | 11.60 | 200. |
| 372 | 528. | -4.0 | 11.60 | 200. |
| 373 | 48. | -4.0 | 19.33 | 200. |
| 374 | 96. | -4.0 | 19.33 | 200. |
| 375 | 144. | -4.0 | 19.33 | 200. |
| 376 | 192. | -4.0 | 19.33 | 200. |
| 377 | 240. | -4.0 | 19.33 | 200. |
| 378 | 288. | -4.0 | 19.33 | 200. |
| 379 | 336. | -4.0 | 19.33 | 200. |
| 380 | 384. | -4.0 | 19.33 | 200. |
| 381 | 432. | -4.0 | 19.33 | 200. |
| 382 | 480. | -4.00 | 19.33 | 200. |
| 383 | 528. | -4.0 | 19.33 | 200. |
| 384 | 48. | -4.0 | 27.06 | 200. |
| 385 | 96. | -4.0 | 27.06 | 200. |
| 386 | 144. | -4.0 | 27.06 | 200. |
| 387 | 192. | -4.0 | 27.06 | 200. |
| 388 | 240. | -4.0 | 27.06 | 200. |
| 389 | 288. | -4.0 | 27.06 | 200. |
| 390 | 336. | -4.0 | 27.06 | 200. |
| 391 | 384. | -4.0 | 27.06 | 200. |
| 392 | 432. | -4.0 | 27.06 | 200. |
| 393 | 480. | -4.0 | 27.06 | 200. |
| 394 | 528. | -4.0 | 27.06 | 200. |
| 395 | 48. | -4.0 | 34.79 | 200. |
| 396 | 96. | -4.0 | 34.79 | 200. |
| 397 | 144. | -4.0 | 34.79 | 200. |
| 398 | 192. | -4.0 | 34.79 | 200. |
| 399 | 240. | -4.0 | 34.79 | 200. |
| 400 | 288. | -4.0 | 34.79 | 200. |
| 401 | 336. | -4.0 | 34.79 | 200. |
| 402 | 384. | -4.0 | 34.79 | 200. |
| 403 | 432. | -4.0 | 34.79 | 200. |
| 404 | 480. | -4.0 | 34.79 | 200. |
| 405 | 528. | -4.0 | 34.79 | 200. |
| 406 | 48. | -4.0 | 42.52 | 200. |
| 407 | 96. | -4.00 | 42.52 | 200. |
| 408 | 144. | -4.00 | 42.52 | 200. |
| 409 | 192. | -4.00 | 42.52 | 200. |
| 410 | 240. | -4.00 | 42.52 | 200. |
| 411 | 288. | -4.00 | 42.52 | 200. |
| 412 | 336. | -4.00 | 42.52 | 200. |
| 413 | 384. | -4.00 | 42.52 | 200. |
| 414 | 432. | -4.00 | 42.52 | 200. |
| 415 | 480. | -4.00 | 42.52 | 200. |
| 416 | 528. | -4.00 | 42.52 | 200. |
| 417 | 48. | -4.00 | 50.25 | 200. |
| 418 | 96. | -4.00 | 50.25 | 200. |
| 419 | 144. | -4.00 | 50.25 | 200. |
| 420 | 192. | -4.00 | 50.25 | 200. |
| 421 | 240. | -4.00 | 50.25 | 200. |
| 422 | 288. | -4.00 | 50.25 | 200. |
| 423 | 336. | -4.00 | 50.25 | 200. |
| 424 | 384. | -4.00 | 50.25 | 200. |
| 425 | 432. | -4.00 | 50.25 | 200. |
| 426 | 480. | -4.00 | 50.25 | 200. |
| 427 | 528. | -4.00 | 50.25 | 200. |
| 428 | 48. | -4.00 | 57.9 | 200. |

079T1000001
Page 142

| | | | | | | | | |
|-----|---|---|---|---|--------|--------|-------|------|
| 429 | | | | | 96. | -4.00 | 57.98 | 200. |
| 430 | | | | | 144. | -4.0 | 57.98 | 200. |
| 431 | | | | | 192. | -4.0 | 57.98 | 200. |
| 432 | | | | | 240. | -4.0 | 57.98 | 200. |
| 433 | | | | | 288. | -4.0 | 57.98 | 200. |
| 434 | | | | | 336. | -4.0 | 57.98 | 200. |
| 435 | | | | | 384. | -4.0 | 57.98 | 200. |
| 436 | | | | | 432. | -4.0 | 57.98 | 200. |
| 437 | | | | | 480. | -4.0 | 57.98 | 200. |
| 438 | | | | | 528. | -4.0 | 57.98 | 200. |
| 439 | | | | | 48. | -4.0 | 65.71 | 200. |
| 440 | | | | | 96. | -4.0 | 65.71 | 200. |
| 441 | | | | | 144. | -4.0 | 65.71 | 200. |
| 442 | | | | | 192. | -4.0 | 65.71 | 200. |
| 443 | | | | | 240. | -4.0 | 65.71 | 200. |
| 444 | | | | | 288. | -4.0 | 65.71 | 200. |
| 445 | | | | | 336. | -4.0 | 65.71 | 200. |
| 446 | | | | | 384. | -4.0 | 65.71 | 200. |
| 447 | | | | | 432. | -4.0 | 65.71 | 200. |
| 448 | | | | | 480. | -4.0 | 65.71 | 200. |
| 449 | | | | | 528. | -4.0 | 65.71 | 200. |
| 450 | | | | | 48. | -4.0 | 73.44 | 200. |
| 451 | | | | | 96. | -4.0 | 73.44 | 200. |
| 452 | | | | | 144. | -4.0 | 73.44 | 200. |
| 453 | | | | | 192. | -4.0 | 73.44 | 200. |
| 454 | | | | | 240. | -4.0 | 73.44 | 200. |
| 455 | | | | | 288. | -4.00 | 73.44 | 200. |
| 456 | | | | | 336. | -4.00 | 73.44 | 200. |
| 457 | | | | | 384. | -4.00 | 73.44 | 200. |
| 458 | | | | | 432. | -4.00 | 73.44 | 200. |
| 459 | | | | | 480. | -4.00 | 73.44 | 200. |
| 460 | | | | | 528. | -4.00 | 73.44 | 200. |
| 461 | 1 | 1 | 1 | 1 | 48.14 | -34.00 | 19.33 | 100. |
| 462 | 1 | 1 | 1 | 1 | 96.28 | -34.00 | 19.33 | 100. |
| 463 | 1 | 1 | 1 | 1 | 144.43 | -34.00 | 19.33 | 100. |
| 464 | 1 | 1 | 1 | 1 | 192.59 | -34.00 | 19.33 | 100. |
| 465 | 1 | 1 | 1 | 1 | 240.77 | -34.00 | 19.33 | 100. |
| 466 | 1 | 1 | 1 | 1 | 288.97 | -34.00 | 19.33 | 100. |
| 467 | 1 | 1 | 1 | 1 | 337.19 | -34.00 | 19.33 | 100. |
| 468 | 1 | 1 | 1 | 1 | 385.44 | -34.00 | 19.33 | 100. |
| 469 | 1 | 1 | 1 | 1 | 433.69 | -34.00 | 19.33 | 100. |
| 470 | 1 | 1 | 1 | 1 | 481.96 | -34.00 | 19.33 | 100. |
| 471 | 1 | 1 | 1 | 1 | 530.23 | -34.00 | 19.33 | 100. |
| 472 | 1 | 1 | 1 | 1 | 48.14 | -34.00 | 57.98 | 100. |
| 473 | 1 | 1 | 1 | 1 | 96.28 | -34.00 | 57.98 | 100. |
| 474 | 1 | 1 | 1 | 1 | 144.43 | -34.00 | 57.98 | 100. |
| 475 | 1 | 1 | 1 | 1 | 192.59 | -34.00 | 57.98 | 100. |
| 476 | 1 | 1 | 1 | 1 | 240.77 | -34.00 | 57.98 | 100. |
| 477 | 1 | 1 | 1 | 1 | 288.97 | -34.00 | 57.98 | 100. |
| 478 | 1 | 1 | 1 | 1 | 337.19 | -34.00 | 57.98 | 100. |
| 479 | 1 | 1 | 1 | 1 | 385.44 | -34.00 | 57.98 | 100. |
| 480 | 1 | 1 | 1 | 1 | 433.69 | -34.00 | 57.98 | 100. |
| 481 | 1 | 1 | 1 | 1 | 481.96 | -34.00 | 57.98 | 100. |
| 482 | 1 | 1 | 1 | 1 | 530.23 | -34.00 | 57.98 | 100. |
| 483 | | 1 | 1 | 1 | 48. | -4.00 | 96.63 | 200. |
| 484 | | 1 | 1 | 1 | 96. | -4.00 | 96.63 | 200. |
| 485 | 1 | 1 | 1 | 1 | 144. | -4.00 | 96.63 | 200. |
| 486 | | 1 | 1 | 1 | 192. | -4.00 | 96.63 | 200. |
| 487 | | 1 | 1 | 1 | 240. | -4.00 | 96.63 | 200. |
| 488 | | 1 | 1 | 1 | 288. | -4.00 | 96.63 | 200. |
| 489 | 1 | 1 | 1 | 1 | 336. | -4.00 | 96.63 | 200. |
| 490 | 1 | 1 | 1 | 1 | 384. | -4.00 | 96.63 | 200. |

079TI000001
 Page 143

| | | | | | | | | | | |
|-----------------------------|-------|--------|----|------|--------|---|----------|---------|------------------|-------|
| 491 | 1 | 1 | 1 | 1 | 1 | 1 | 432. | -4.00 | 96.63 | 200. |
| 492 | 1 | 1 | 1 | 1 | 1 | 1 | 480. | -4.00 | 96.63 | 200. |
| 493 | 1 | 1 | 1 | 1 | 1 | 1 | 528. | -4.00 | 96.63 | 200. |
| 494 | 1 | 1 | 1 | 1 | 1 | 1 | 14.36 | 0.00 | 96.63 | 200. |
| 495 | | | | | | | 600. | 0.00 | 39.00 | 1050. |
| 496 | | | | | | | 0.00 | 0.00 | 39.00 | 610. |
| 497 | 1 | 1 | 1 | 1 | 1 | 1 | 610. | 7.00 | 39.00 | 70. |
| 498 | 1 | 1 | 1 | 1 | 1 | 1 | 14.36 | -34.00 | 19.33 | 100. |
| 499 | 1 | 1 | 1 | 1 | 1 | 1 | -5.24 | -34.00 | 19.33 | 100. |
| 500 | 1 | 1 | 1 | 1 | 1 | 1 | 14.36 | -34.00 | 57.98 | 100. |
| 501 | 1 | 1 | 1 | 1 | 1 | 1 | -5.24 | -34.00 | 57.98 | 100. |
| 502 | | | | | | | -24.00 | 0.00 | 39.00 | 610. |
| 503 | | | | | | | -24.00 | -42.00 | 81.00 | 610. |
| 504 | | | | | | | -24.00 | -92.90 | 30.10 | 610. |
| 505 | | | | | | | -24.00 | -143.90 | 81.10 | 610. |
| 506 | 1 | 1 | 1 | 1 | 1 | 1 | 12.00 | -143.90 | 81.10 | 610. |
| 507 | | | | | | | 612.00 | 0.00 | 39.00 | 1050. |
| 508 | | | | | | | 612.00 | -147.20 | 124.00 | 1050. |
| 509 | | | | | | | 612.00 | -173.70 | 78.10 | 1050. |
| 510 | | | | | | | 684.00 | -173.70 | 78.10 | 1050. |
| 511 | | | | | | | 684.00 | -59.40 | 12.10 | 1050. |
| 512 | | | | | | | 756.00 | -59.40 | 12.10 | 1050. |
| 513 | | | | | | | 756.00 | -161.60 | 71.10 | 1050. |
| 514 | | | | | | | 756.00 | -161.60 | 191.10 | 1050. |
| 515 | 1 | 1 | 1 | 1 | 1 | 1 | 756.00 | -161.60 | 311.10 | 1050. |
| 516 | | | | | | | 612.00 | -73.60 | 81.50 | 1050. |
| 517 | 1 | 1 | 1 | 1 | 1 | 1 | 622.00 | -73.60 | 81.50 | 1050. |
| 518 | 1 | 1 | 1 | 1 | 1 | 1 | 694.00 | -173.70 | 78.10 | 1050. |
| 519 | 1 | 1 | 1 | 1 | 1 | 1 | 766.00 | -59.40 | 12.10 | 1050. |
| 520 | 1 | 1 | 1 | 1 | 1 | 1 | 766.00 | -161.60 | 191.10 | 1050. |
| 12 | 465 | 2 | 13 | 5 | | | | | | |
| 1 | 13 | | | | | | | | | |
| RECEIVER TUBES, TANGS, RODS | | | | | | | | | | |
| 70. | | 28.3E6 | | .3 | | | 9.11E-6 | | | |
| 100. | | 28.3E6 | | .3 | | | 9.21E-6 | | | |
| 200. | | 27.7E6 | | .3 | | | 9.50E-6 | | | |
| 300. | | 27.1E6 | | .3 | | | 9.73E-6 | | | |
| 400. | | 26.6E6 | | .3 | | | 9.99E-6 | | | |
| 500. | | 26.1E6 | | .3 | | | 10.20E-6 | | | |
| 600. | | 25.4E6 | | .3 | | | 10.43E-6 | | | |
| 700. | | 24.8E6 | | .3 | | | 10.66E-6 | | | |
| 800. | | 24.1E6 | | .3 | | | 10.90E-6 | | | |
| 900. | | 23.3E6 | | .3 | | | 11.11E-6 | | | |
| 1000. | | 22.5E6 | | .3 | | | 11.35E-6 | | | |
| 1100. | | 21.7E6 | | .3 | | | 11.58E-6 | | | |
| 1200. | | 20.9E6 | | .3 | | | 11.81E-6 | | | |
| 2 | 9 | | | | | | | | | |
| INLET PIPING | | | | | | | | | | |
| 70. | | 27.9E6 | | .3 | | | 6.07E-6 | | | |
| 100. | | 27.8E6 | | .3 | | | 6.22E-6 | | | |
| 200. | | 27.7E6 | | .3 | | | 6.38E-6 | | | |
| 300. | | 27.4E6 | | .3 | | | 6.60E-6 | | | |
| 400. | | 27.0E6 | | .3 | | | 6.82E-6 | | | |
| 500. | | 26.4E6 | | .3 | | | 7.02E-6 | | | |
| 600. | | 25.7E6 | | .3 | | | 7.23E-6 | | | |
| 700. | | 24.8E6 | | .3 | | | 7.44E-6 | | | |
| 800. | | 23.4E6 | | .3 | | | 7.65E-6 | | | |
| 1 | 1.50 | .058 | | 20.4 | .4140 | | | | RECEIVER TUBES | |
| 2 | 0.25 | .022 | | 20.4 | .0455 | | | | RECEIVER TANGS | |
| 3 | 6.00 | .250 | | 2.0 | .1000 | | | | TUBE AT MANIFOLD | |
| 4 | 6.625 | .280 | | 2.0 | 2.4500 | | | | INLET PIPE | |
| 5 | 2.750 | .375 | | 2.0 | 7.5200 | | | | OUTLET PIPE 2IN | |

079TI000001
 Page 144

-.270
 -.400 -.653

.400

1.00

| | | | | | |
|----|----|----|---|---|-----|
| 1 | 1 | 2 | 1 | 3 | 70. |
| 2 | 2 | 3 | 1 | 1 | 70. |
| 3 | 3 | 4 | 1 | 1 | 70. |
| 4 | 4 | 5 | 1 | 1 | 70. |
| 5 | 5 | 6 | 1 | 1 | 70. |
| 6 | 6 | 7 | 1 | 1 | 70. |
| 7 | 7 | 8 | 1 | 1 | 70. |
| 8 | 8 | 9 | 1 | 1 | 70. |
| 9 | 9 | 10 | 1 | 1 | 70. |
| 10 | 10 | 11 | 1 | 1 | 70. |
| 11 | 11 | 12 | 1 | 1 | 70. |
| 12 | 12 | 13 | 1 | 1 | 70. |
| 13 | 13 | 14 | 1 | 1 | 70. |
| 14 | 14 | 15 | 1 | 1 | 70. |
| 15 | 15 | 16 | 1 | 1 | 70. |
| 16 | 16 | 17 | 1 | 1 | 70. |
| 17 | 17 | 18 | 1 | 1 | 70. |
| 18 | 18 | 19 | 1 | 1 | 70. |
| 19 | 19 | 20 | 1 | 1 | 70. |
| 20 | 20 | 21 | 1 | 1 | 70. |
| 21 | 21 | 22 | 1 | 1 | 70. |
| 22 | 22 | 23 | 1 | 1 | 70. |
| 23 | 23 | 24 | 1 | 1 | 70. |
| 24 | 24 | 25 | 1 | 1 | 70. |
| 25 | 25 | 26 | 1 | 1 | 70. |
| 26 | 26 | 27 | 1 | 1 | 70. |
| 27 | 27 | 28 | 1 | 1 | 70. |
| 28 | 28 | 29 | 1 | 1 | 70. |
| 29 | 29 | 30 | 1 | 1 | 70. |
| 30 | 30 | 31 | 1 | 1 | 70. |
| 31 | 31 | 32 | 1 | 1 | 70. |
| 32 | 32 | 33 | 1 | 1 | 70. |
| 33 | 33 | 34 | 1 | 1 | 70. |
| 34 | 34 | 35 | 1 | 3 | 70. |
| 35 | 36 | 37 | 1 | 3 | 70. |
| 36 | 37 | 38 | 1 | 1 | 70. |
| 37 | 38 | 39 | 1 | 1 | 70. |
| 38 | 39 | 40 | 1 | 1 | 70. |
| 39 | 40 | 41 | 1 | 1 | 70. |
| 40 | 41 | 42 | 1 | 1 | 70. |
| 41 | 42 | 43 | 1 | 1 | 70. |
| 42 | 43 | 44 | 1 | 1 | 70. |
| 43 | 44 | 45 | 1 | 1 | 70. |
| 44 | 45 | 46 | 1 | 1 | 70. |
| 45 | 46 | 47 | 1 | 1 | 70. |
| 46 | 47 | 48 | 1 | 1 | 70. |
| 47 | 48 | 49 | 1 | 1 | 70. |
| 48 | 49 | 50 | 1 | 1 | 70. |
| 49 | 50 | 51 | 1 | 1 | 70. |
| 50 | 51 | 52 | 1 | 1 | 70. |
| 51 | 52 | 53 | 1 | 1 | 70. |
| 52 | 53 | 54 | 1 | 1 | 70. |
| 53 | 54 | 55 | 1 | 1 | 70. |
| 54 | 55 | 56 | 1 | 1 | 70. |
| 55 | 56 | 57 | 1 | 1 | 70. |
| 56 | 57 | 58 | 1 | 1 | 70. |
| 57 | 58 | 59 | 1 | 1 | 70. |
| 58 | 59 | 60 | 1 | 1 | 70. |
| 59 | 60 | 61 | 1 | 1 | 70. |

079TI000001
Page 145

| | | | | | |
|-----|-----|-----|---|---|-----|
| 60 | 61 | 62 | 1 | 1 | 70. |
| 61 | 62 | 63 | 1 | 1 | 70. |
| 62 | 63 | 64 | 1 | 1 | 70. |
| 63 | 64 | 65 | 1 | 1 | 70. |
| 64 | 65 | 66 | 1 | 1 | 70. |
| 65 | 66 | 67 | 1 | 1 | 70. |
| 66 | 67 | 68 | 1 | 1 | 70. |
| 67 | 68 | 69 | 1 | 1 | 70. |
| 68 | 69 | 70 | 1 | 3 | 70. |
| 69 | 71 | 72 | 1 | 3 | 70. |
| 70 | 72 | 73 | 1 | 1 | 70. |
| 71 | 73 | 74 | 1 | 1 | 70. |
| 72 | 74 | 75 | 1 | 1 | 70. |
| 73 | 75 | 76 | 1 | 1 | 70. |
| 74 | 76 | 77 | 1 | 1 | 70. |
| 75 | 77 | 78 | 1 | 1 | 70. |
| 76 | 78 | 79 | 1 | 1 | 70. |
| 77 | 79 | 80 | 1 | 1 | 70. |
| 78 | 80 | 81 | 1 | 1 | 70. |
| 79 | 81 | 82 | 1 | 1 | 70. |
| 80 | 82 | 83 | 1 | 1 | 70. |
| 81 | 83 | 84 | 1 | 1 | 70. |
| 82 | 84 | 85 | 1 | 1 | 70. |
| 83 | 85 | 86 | 1 | 1 | 70. |
| 84 | 86 | 87 | 1 | 1 | 70. |
| 85 | 87 | 88 | 1 | 1 | 70. |
| 86 | 88 | 89 | 1 | 1 | 70. |
| 87 | 89 | 90 | 1 | 1 | 70. |
| 88 | 90 | 91 | 1 | 1 | 70. |
| 89 | 91 | 92 | 1 | 1 | 70. |
| 90 | 92 | 93 | 1 | 1 | 70. |
| 91 | 93 | 94 | 1 | 1 | 70. |
| 92 | 94 | 95 | 1 | 1 | 70. |
| 93 | 95 | 96 | 1 | 1 | 70. |
| 94 | 96 | 97 | 1 | 1 | 70. |
| 95 | 97 | 98 | 1 | 1 | 70. |
| 96 | 98 | 99 | 1 | 1 | 70. |
| 97 | 99 | 100 | 1 | 1 | 70. |
| 98 | 100 | 101 | 1 | 1 | 70. |
| 99 | 101 | 102 | 1 | 1 | 70. |
| 100 | 102 | 103 | 1 | 1 | 70. |
| 101 | 103 | 104 | 1 | 1 | 70. |
| 102 | 104 | 105 | 1 | 3 | 70. |
| 103 | 106 | 107 | 1 | 3 | 70. |
| 104 | 107 | 108 | 1 | 1 | 70. |
| 105 | 108 | 109 | 1 | 1 | 70. |
| 106 | 109 | 110 | 1 | 1 | 70. |
| 107 | 110 | 111 | 1 | 1 | 70. |
| 108 | 111 | 112 | 1 | 1 | 70. |
| 109 | 112 | 113 | 1 | 1 | 70. |
| 110 | 113 | 114 | 1 | 1 | 70. |
| 111 | 114 | 115 | 1 | 1 | 70. |
| 112 | 115 | 116 | 1 | 1 | 70. |
| 113 | 116 | 117 | 1 | 1 | 70. |
| 114 | 117 | 118 | 1 | 1 | 70. |
| 115 | 118 | 119 | 1 | 1 | 70. |
| 116 | 119 | 120 | 1 | 1 | 70. |
| 117 | 120 | 121 | 1 | 1 | 70. |
| 118 | 121 | 122 | 1 | 1 | 70. |
| 119 | 122 | 123 | 1 | 1 | 70. |
| 120 | 123 | 124 | 1 | 1 | 70. |
| 121 | 124 | 125 | 1 | 1 | 70. |

079TI000001
 Page 146

| | | | | | |
|-----|-----|-----|---|---|-----|
| 122 | | 126 | 1 | 1 | 70. |
| 123 | 126 | 127 | 1 | 1 | 70. |
| 124 | 127 | 128 | 1 | 1 | 70. |
| 125 | 128 | 129 | 1 | 1 | 70. |
| 126 | 129 | 130 | 1 | 1 | 70. |
| 127 | 130 | 131 | 1 | 1 | 70. |
| 128 | 131 | 132 | 1 | 1 | 70. |
| 129 | 132 | 133 | 1 | 1 | 70. |
| 130 | 133 | 134 | 1 | 1 | 70. |
| 131 | 134 | 135 | 1 | 1 | 70. |
| 132 | 135 | 136 | 1 | 1 | 70. |
| 133 | 136 | 137 | 1 | 1 | 70. |
| 134 | 137 | 138 | 1 | 1 | 70. |
| 135 | 138 | 139 | 1 | 1 | 70. |
| 136 | 139 | 140 | 1 | 3 | 70. |
| 137 | 141 | 142 | 1 | 3 | 70. |
| 138 | 142 | 143 | 1 | 1 | 70. |
| 139 | 143 | 144 | 1 | 1 | 70. |
| 140 | 144 | 145 | 1 | 1 | 70. |
| 141 | 145 | 146 | 1 | 1 | 70. |
| 142 | 146 | 147 | 1 | 1 | 70. |
| 143 | 147 | 148 | 1 | 1 | 70. |
| 144 | 148 | 149 | 1 | 1 | 70. |
| 145 | 149 | 150 | 1 | 1 | 70. |
| 146 | 150 | 151 | 1 | 1 | 70. |
| 147 | 151 | 152 | 1 | 1 | 70. |
| 148 | 152 | 153 | 1 | 1 | 70. |
| 149 | 153 | 154 | 1 | 1 | 70. |
| 150 | 154 | 155 | 1 | 1 | 70. |
| 151 | 155 | 156 | 1 | 1 | 70. |
| 152 | 156 | 157 | 1 | 1 | 70. |
| 153 | 157 | 158 | 1 | 1 | 70. |
| 154 | 158 | 159 | 1 | 1 | 70. |
| 155 | 159 | 160 | 1 | 1 | 70. |
| 156 | 160 | 161 | 1 | 1 | 70. |
| 157 | 161 | 162 | 1 | 1 | 70. |
| 158 | 162 | 163 | 1 | 1 | 70. |
| 159 | 163 | 164 | 1 | 1 | 70. |
| 160 | 164 | 165 | 1 | 1 | 70. |
| 161 | 165 | 166 | 1 | 1 | 70. |
| 162 | 166 | 167 | 1 | 1 | 70. |
| 163 | 167 | 168 | 1 | 1 | 70. |
| 164 | 168 | 169 | 1 | 1 | 70. |
| 165 | 169 | 170 | 1 | 1 | 70. |
| 166 | 170 | 171 | 1 | 1 | 70. |
| 167 | 171 | 172 | 1 | 1 | 70. |
| 168 | 172 | 173 | 1 | 1 | 70. |
| 169 | 173 | 174 | 1 | 1 | 70. |
| 170 | 174 | 175 | 1 | 3 | 70. |
| 171 | 176 | 177 | 1 | 3 | 70. |
| 172 | 177 | 178 | 1 | 1 | 70. |
| 173 | 178 | 179 | 1 | 1 | 70. |
| 174 | 179 | 180 | 1 | 1 | 70. |
| 175 | 180 | 181 | 1 | 1 | 70. |
| 176 | 181 | 182 | 1 | 1 | 70. |
| 177 | 182 | 183 | 1 | 1 | 70. |
| 178 | 183 | 184 | 1 | 1 | 70. |
| 179 | 184 | 185 | 1 | 1 | 70. |
| 180 | 185 | 186 | 1 | 1 | 70. |
| 181 | 186 | 187 | 1 | 1 | 70. |
| 182 | 187 | 188 | 1 | 1 | 70. |
| 183 | 188 | 189 | 1 | 1 | 70. |

079TI000001
 Page 147

| | | | | | |
|-----|-----|-----|---|---|-----|
| 184 | 189 | 190 | 1 | 1 | 70. |
| 185 | 190 | 191 | 1 | 1 | 70. |
| 186 | 191 | 192 | 1 | 1 | 70. |
| 187 | 192 | 193 | 1 | 1 | 70. |
| 188 | 193 | 194 | 1 | 1 | 70. |
| 189 | 194 | 195 | 1 | 1 | 70. |
| 190 | 195 | 196 | 1 | 1 | 70. |
| 191 | 196 | 197 | 1 | 1 | 70. |
| 192 | 197 | 198 | 1 | 1 | 70. |
| 193 | 198 | 199 | 1 | 1 | 70. |
| 194 | 199 | 200 | 1 | 1 | 70. |
| 195 | 200 | 201 | 1 | 1 | 70. |
| 196 | 201 | 202 | 1 | 1 | 70. |
| 197 | 202 | 203 | 1 | 1 | 70. |
| 198 | 203 | 204 | 1 | 1 | 70. |
| 199 | 204 | 205 | 1 | 1 | 70. |
| 200 | 205 | 206 | 1 | 1 | 70. |
| 201 | 206 | 207 | 1 | 1 | 70. |
| 202 | 207 | 208 | 1 | 1 | 70. |
| 203 | 208 | 209 | 1 | 1 | 70. |
| 204 | 209 | 210 | 1 | 3 | 70. |
| 205 | 211 | 212 | 1 | 3 | 70. |
| 206 | 212 | 213 | 1 | 1 | 70. |
| 207 | 213 | 214 | 1 | 1 | 70. |
| 208 | 214 | 215 | 1 | 1 | 70. |
| 209 | 215 | 216 | 1 | 1 | 70. |
| 210 | 216 | 217 | 1 | 1 | 70. |
| 211 | 217 | 218 | 1 | 1 | 70. |
| 212 | 218 | 219 | 1 | 1 | 70. |
| 213 | 219 | 220 | 1 | 1 | 70. |
| 214 | 220 | 221 | 1 | 1 | 70. |
| 215 | 221 | 222 | 1 | 1 | 70. |
| 216 | 222 | 223 | 1 | 1 | 70. |
| 217 | 223 | 224 | 1 | 1 | 70. |
| 218 | 224 | 225 | 1 | 1 | 70. |
| 219 | 225 | 226 | 1 | 1 | 70. |
| 220 | 226 | 227 | 1 | 1 | 70. |
| 221 | 227 | 228 | 1 | 1 | 70. |
| 222 | 228 | 229 | 1 | 1 | 70. |
| 223 | 229 | 230 | 1 | 1 | 70. |
| 224 | 230 | 231 | 1 | 1 | 70. |
| 225 | 231 | 232 | 1 | 1 | 70. |
| 226 | 232 | 233 | 1 | 1 | 70. |
| 227 | 233 | 234 | 1 | 1 | 70. |
| 228 | 234 | 235 | 1 | 1 | 70. |
| 229 | 235 | 236 | 1 | 1 | 70. |
| 230 | 236 | 237 | 1 | 1 | 70. |
| 231 | 237 | 238 | 1 | 1 | 70. |
| 232 | 238 | 239 | 1 | 1 | 70. |
| 233 | 239 | 240 | 1 | 1 | 70. |
| 234 | 240 | 241 | 1 | 1 | 70. |
| 235 | 241 | 242 | 1 | 1 | 70. |
| 236 | 242 | 243 | 1 | 1 | 70. |
| 237 | 243 | 244 | 1 | 1 | 70. |
| 238 | 244 | 245 | 1 | 3 | 70. |
| 239 | 246 | 247 | 1 | 3 | 70. |
| 240 | 247 | 248 | 1 | 1 | 70. |
| 241 | 248 | 249 | 1 | 1 | 70. |
| 242 | 249 | 250 | 1 | 1 | 70. |
| 243 | | 251 | 1 | 1 | 70. |
| 244 | | 252 | 1 | 1 | 70. |
| 245 | | 253 | 1 | 1 | 70. |

079TI000001
Page 148

| | | | | | |
|-----|-----|-----|---|---|-----|
| 246 | | 254 | 1 | 1 | 70. |
| 247 | 254 | 255 | 1 | 1 | 70. |
| 248 | 255 | 256 | 1 | 1 | 70. |
| 249 | 256 | 257 | 1 | 1 | 70. |
| 250 | 257 | 258 | 1 | 1 | 70. |
| 251 | 258 | 259 | 1 | 1 | 70. |
| 252 | 259 | 260 | 1 | 1 | 70. |
| 253 | 260 | 261 | 1 | 1 | 70. |
| 254 | 261 | 262 | 1 | 1 | 70. |
| 255 | 262 | 263 | 1 | 1 | 70. |
| 256 | 263 | 264 | 1 | 1 | 70. |
| 257 | 264 | 265 | 1 | 1 | 70. |
| 258 | 265 | 266 | 1 | 1 | 70. |
| 259 | 266 | 267 | 1 | 1 | 70. |
| 260 | 267 | 268 | 1 | 1 | 70. |
| 261 | 268 | 269 | 1 | 1 | 70. |
| 262 | 269 | 270 | 1 | 1 | 70. |
| 263 | 270 | 271 | 1 | 1 | 70. |
| 264 | 271 | 272 | 1 | 1 | 70. |
| 265 | 272 | 273 | 1 | 1 | 70. |
| 266 | 273 | 274 | 1 | 1 | 70. |
| 267 | 274 | 275 | 1 | 1 | 70. |
| 268 | 275 | 276 | 1 | 1 | 70. |
| 269 | 276 | 277 | 1 | 1 | 70. |
| 270 | 277 | 278 | 1 | 1 | 70. |
| 271 | 278 | 279 | 1 | 1 | 70. |
| 272 | 279 | 280 | 1 | 3 | 70. |
| 273 | 281 | 282 | 1 | 3 | 70. |
| 274 | 282 | 283 | 1 | 1 | 70. |
| 275 | 283 | 284 | 1 | 1 | 70. |
| 276 | 284 | 285 | 1 | 1 | 70. |
| 277 | 285 | 286 | 1 | 1 | 70. |
| 278 | 286 | 287 | 1 | 1 | 70. |
| 279 | 287 | 288 | 1 | 1 | 70. |
| 280 | 288 | 289 | 1 | 1 | 70. |
| 281 | 289 | 290 | 1 | 1 | 70. |
| 282 | 290 | 291 | 1 | 1 | 70. |
| 283 | 291 | 292 | 1 | 1 | 70. |
| 284 | 292 | 293 | 1 | 1 | 70. |
| 285 | 293 | 294 | 1 | 1 | 70. |
| 286 | 294 | 295 | 1 | 1 | 70. |
| 287 | 295 | 296 | 1 | 1 | 70. |
| 288 | 296 | 297 | 1 | 1 | 70. |
| 289 | 297 | 298 | 1 | 1 | 70. |
| 290 | 298 | 299 | 1 | 1 | 70. |
| 291 | 299 | 300 | 1 | 1 | 70. |
| 292 | 300 | 301 | 1 | 1 | 70. |
| 293 | 301 | 302 | 1 | 1 | 70. |
| 294 | 302 | 303 | 1 | 1 | 70. |
| 295 | 303 | 304 | 1 | 1 | 70. |
| 296 | 304 | 305 | 1 | 1 | 70. |
| 297 | 305 | 306 | 1 | 1 | 70. |
| 298 | 306 | 307 | 1 | 1 | 70. |
| 299 | 307 | 308 | 1 | 1 | 70. |
| 300 | 308 | 309 | 1 | 1 | 70. |
| 301 | 309 | 310 | 1 | 1 | 70. |
| 302 | 310 | 311 | 1 | 1 | 70. |
| 303 | 311 | 312 | 1 | 1 | 70. |
| 304 | 312 | 313 | 1 | 1 | 70. |
| 305 | 313 | 314 | 1 | 1 | 70. |
| 306 | 314 | 315 | 1 | 3 | 70. |
| 307 | 316 | 317 | 1 | 3 | 70. |

079T100001
Page 149

| | | | | | |
|-----|-----|-----|---|---|-----|
| 308 | 317 | 318 | 1 | 1 | 70. |
| 309 | 318 | 319 | 1 | 1 | 70. |
| 310 | 319 | 320 | 1 | 1 | 70. |
| 311 | 320 | 321 | 1 | 1 | 70. |
| 312 | 321 | 322 | 1 | 1 | 70. |
| 313 | 322 | 323 | 1 | 1 | 70. |
| 314 | 323 | 324 | 1 | 1 | 70. |
| 315 | 324 | 325 | 1 | 1 | 70. |
| 316 | 325 | 326 | 1 | 1 | 70. |
| 317 | 326 | 327 | 1 | 1 | 70. |
| 318 | 327 | 328 | 1 | 1 | 70. |
| 319 | 328 | 329 | 1 | 1 | 70. |
| 320 | 329 | 330 | 1 | 1 | 70. |
| 321 | 330 | 331 | 1 | 1 | 70. |
| 322 | 331 | 332 | 1 | 1 | 70. |
| 323 | 332 | 333 | 1 | 1 | 70. |
| 324 | 333 | 334 | 1 | 1 | 70. |
| 325 | 334 | 335 | 1 | 1 | 70. |
| 326 | 335 | 336 | 1 | 1 | 70. |
| 327 | 336 | 337 | 1 | 1 | 70. |
| 328 | 337 | 338 | 1 | 1 | 70. |
| 329 | 338 | 339 | 1 | 1 | 70. |
| 330 | 339 | 340 | 1 | 1 | 70. |
| 331 | 340 | 341 | 1 | 1 | 70. |
| 332 | 341 | 342 | 1 | 1 | 70. |
| 333 | 342 | 343 | 1 | 1 | 70. |
| 334 | 343 | 344 | 1 | 1 | 70. |
| 335 | 344 | 345 | 1 | 1 | 70. |
| 336 | 345 | 346 | 1 | 1 | 70. |
| 337 | 346 | 347 | 1 | 1 | 70. |
| 338 | 347 | 348 | 1 | 1 | 70. |
| 339 | 348 | 349 | 1 | 1 | 70. |
| 340 | 349 | 350 | 1 | 3 | 70. |
| 341 | 8 | 351 | 1 | 2 | 70. |
| 342 | 10 | 352 | 1 | 2 | 70. |
| 343 | 12 | 353 | 1 | 2 | 70. |
| 344 | 14 | 354 | 1 | 2 | 70. |
| 345 | 16 | 355 | 1 | 2 | 70. |
| 346 | 18 | 356 | 1 | 2 | 70. |
| 347 | 20 | 357 | 1 | 2 | 70. |
| 348 | 22 | 358 | 1 | 2 | 70. |
| 349 | 24 | 359 | 1 | 2 | 70. |
| 350 | 26 | 360 | 1 | 2 | 70. |
| 351 | 28 | 361 | 1 | 2 | 70. |
| 352 | 43 | 362 | 1 | 2 | 70. |
| 353 | 45 | 363 | 1 | 2 | 70. |
| 354 | 47 | 364 | 1 | 2 | 70. |
| 355 | 49 | 365 | 1 | 2 | 70. |
| 356 | 51 | 366 | 1 | 2 | 70. |
| 357 | 53 | 367 | 1 | 2 | 70. |
| 358 | 55 | 368 | 1 | 2 | 70. |
| 359 | 57 | 369 | 1 | 2 | 70. |
| 360 | 59 | 370 | 1 | 2 | 70. |
| 361 | 61 | 371 | 1 | 2 | 70. |
| 362 | 63 | 372 | 1 | 2 | 70. |
| 363 | 78 | 373 | 1 | 2 | 70. |
| 364 | 80 | 374 | 1 | 2 | 70. |
| 365 | 82 | 375 | 1 | 2 | 70. |
| 366 | 84 | 376 | 1 | 2 | 70. |
| 367 | | 377 | 1 | 2 | 70. |
| 368 | | 378 | 1 | 2 | 70. |
| 369 | | 379 | 1 | 2 | 70. |

079T100001
 Page 150

| | | | | | |
|-----|-----|-----|---|---|-----|
| 370 | | 380 | 1 | 2 | 70. |
| 371 | 94 | 381 | 1 | 2 | 70. |
| 372 | 96 | 382 | 1 | 2 | 70. |
| 373 | 98 | 383 | 1 | 2 | 70. |
| 374 | 113 | 384 | 1 | 2 | 70. |
| 375 | 115 | 385 | 1 | 2 | 70. |
| 376 | 117 | 386 | 1 | 2 | 70. |
| 377 | 119 | 387 | 1 | 2 | 70. |
| 378 | 121 | 388 | 1 | 2 | 70. |
| 379 | 123 | 389 | 1 | 2 | 70. |
| 380 | 125 | 390 | 1 | 2 | 70. |
| 381 | 127 | 391 | 1 | 2 | 70. |
| 382 | 129 | 392 | 1 | 2 | 70. |
| 383 | 131 | 393 | 1 | 2 | 70. |
| 384 | 133 | 394 | 1 | 2 | 70. |
| 385 | 148 | 395 | 1 | 2 | 70. |
| 386 | 150 | 396 | 1 | 2 | 70. |
| 387 | 152 | 397 | 1 | 2 | 70. |
| 388 | 154 | 398 | 1 | 2 | 70. |
| 389 | 156 | 399 | 1 | 2 | 70. |
| 390 | 158 | 400 | 1 | 2 | 70. |
| 391 | 160 | 401 | 1 | 2 | 70. |
| 392 | 162 | 402 | 1 | 2 | 70. |
| 393 | 164 | 403 | 1 | 2 | 70. |
| 394 | 166 | 404 | 1 | 2 | 70. |
| 395 | 168 | 405 | 1 | 2 | 70. |
| 396 | 183 | 406 | 1 | 2 | 70. |
| 397 | 185 | 407 | 1 | 2 | 70. |
| 398 | 187 | 408 | 1 | 2 | 70. |
| 399 | 189 | 409 | 1 | 2 | 70. |
| 400 | 191 | 410 | 1 | 2 | 70. |
| 401 | 193 | 411 | 1 | 2 | 70. |
| 402 | 195 | 412 | 1 | 2 | 70. |
| 403 | 197 | 413 | 1 | 2 | 70. |
| 404 | 199 | 414 | 1 | 2 | 70. |
| 405 | 201 | 415 | 1 | 2 | 70. |
| 406 | 203 | 416 | 1 | 2 | 70. |
| 407 | 218 | 417 | 1 | 2 | 70. |
| 408 | 220 | 418 | 1 | 2 | 70. |
| 409 | 222 | 419 | 1 | 2 | 70. |
| 410 | 224 | 420 | 1 | 2 | 70. |
| 411 | 226 | 421 | 1 | 2 | 70. |
| 412 | 228 | 422 | 1 | 2 | 70. |
| 413 | 230 | 423 | 1 | 2 | 70. |
| 414 | 232 | 424 | 1 | 2 | 70. |
| 415 | 234 | 425 | 1 | 2 | 70. |
| 416 | 236 | 426 | 1 | 2 | 70. |
| 417 | 238 | 427 | 1 | 2 | 70. |
| 418 | 253 | 428 | 1 | 2 | 70. |
| 419 | 255 | 429 | 1 | 2 | 70. |
| 420 | 257 | 430 | 1 | 2 | 70. |
| 421 | 259 | 431 | 1 | 2 | 70. |
| 422 | 261 | 432 | 1 | 2 | 70. |
| 423 | 263 | 433 | 1 | 2 | 70. |
| 424 | 265 | 434 | 1 | 2 | 70. |
| 425 | 267 | 435 | 1 | 2 | 70. |
| 426 | 269 | 436 | 1 | 2 | 70. |
| 427 | 271 | 437 | 1 | 2 | 70. |
| 428 | 273 | 438 | 1 | 2 | 70. |
| 429 | 288 | 439 | 1 | 2 | 70. |
| 430 | 290 | 440 | 1 | 2 | 70. |
| 431 | 292 | 441 | 1 | 2 | 70. |

079TI000001
 Page 151

| | | | | | | |
|----|-----|-----|-----|---|---|----|
| 8 | 380 | 468 | 479 | 1 | 1 | 11 |
| 9 | 381 | 469 | 480 | 1 | 1 | 11 |
| 10 | 382 | 470 | 481 | 1 | 1 | 11 |
| 11 | 383 | 471 | 482 | 1 | 1 | 11 |
| 12 | 428 | 472 | 461 | 1 | 1 | 11 |
| 13 | 429 | 473 | 462 | 1 | 1 | 11 |
| 14 | 430 | 474 | 463 | 1 | 1 | 11 |
| 15 | 431 | 475 | 464 | 1 | 1 | 11 |
| 16 | 432 | 476 | 465 | 1 | 1 | 11 |
| 17 | 433 | 477 | 466 | 1 | 1 | 11 |
| 18 | 434 | 478 | 467 | 1 | 1 | 11 |
| 19 | 435 | 479 | 468 | 1 | 1 | 11 |
| 20 | 436 | 480 | 469 | 1 | 1 | 11 |
| 21 | 437 | 481 | 470 | 1 | 1 | 11 |
| 22 | 438 | 482 | 471 | 1 | 1 | 11 |
| 23 | 76 | 498 | 251 | 6 | 5 | 1 |
| 24 | 351 | 362 | 352 | 4 | 3 | |
| 25 | 362 | 373 | 352 | 4 | 3 | |
| 26 | 373 | 384 | 352 | 4 | 3 | |
| 27 | 384 | 395 | 352 | 4 | 3 | |
| 28 | 395 | 406 | 352 | 4 | 3 | |
| 29 | 406 | 417 | 352 | 4 | 3 | |
| 30 | 417 | 428 | 352 | 4 | 3 | |
| 31 | 428 | 439 | 352 | 4 | 3 | |
| 32 | 439 | 450 | 352 | 4 | 3 | |
| 33 | 450 | 483 | 352 | 4 | 3 | 1 |
| 34 | 352 | 363 | 351 | 4 | 3 | |
| 35 | 363 | 374 | 351 | 4 | 3 | |
| 36 | 374 | 385 | 351 | 4 | 3 | |
| 37 | 385 | 396 | 351 | 4 | 3 | |
| 38 | 396 | 407 | 351 | 4 | 3 | |
| 39 | 407 | 418 | 351 | 4 | 3 | |
| 40 | 418 | 429 | 351 | 4 | 3 | |
| 41 | 429 | 440 | 351 | 4 | 3 | |
| 42 | 440 | 451 | 351 | 4 | 3 | |
| 43 | 451 | 484 | 351 | 4 | 3 | 1 |
| 44 | 353 | 364 | 351 | 4 | 3 | |
| 45 | 364 | 375 | 351 | 4 | 3 | |
| 46 | 375 | 386 | 351 | 4 | 3 | |
| 47 | 386 | 397 | 351 | 4 | 3 | |
| 48 | 397 | 408 | 351 | 4 | 3 | |
| 49 | 408 | 419 | 351 | 4 | 3 | |
| 50 | 419 | 430 | 351 | 4 | 3 | |
| 51 | 430 | 441 | 351 | 4 | 3 | |
| 52 | 441 | 452 | 351 | 4 | 3 | |
| 53 | 452 | 485 | 351 | 4 | 3 | 1 |
| 54 | 354 | 365 | 351 | 4 | 3 | |
| 55 | 365 | 376 | 351 | 4 | 3 | |
| 56 | 376 | 387 | 351 | 4 | 3 | |
| 57 | 387 | 398 | 351 | 4 | 3 | |
| 58 | 398 | 409 | 351 | 4 | 3 | |
| 59 | 409 | 420 | 351 | 4 | 3 | |
| 60 | 420 | 431 | 351 | 4 | 3 | |
| 61 | 431 | 442 | 351 | 4 | 3 | |
| 62 | 442 | 453 | 351 | 4 | 3 | |
| 63 | 453 | 486 | 351 | 4 | 3 | 1 |
| 64 | 355 | 366 | 351 | 4 | 3 | |
| 65 | 366 | 377 | 351 | 4 | 3 | |
| 66 | 377 | 388 | 351 | 4 | 3 | |
| 67 | 388 | 399 | 351 | 4 | 3 | |
| 68 | 399 | 410 | 351 | 4 | 3 | |
| 69 | 410 | 421 | 351 | 4 | 3 | |

079T1000001
 Page 153

| | | | | | |
|-----|-----|-----|-----|---|---|
| 70 | 421 | 432 | 351 | 4 | 3 |
| 71 | 432 | 443 | 351 | 4 | 3 |
| 72 | 443 | 454 | 351 | 4 | 3 |
| 73 | 454 | 487 | 351 | 4 | 3 |
| 74 | 356 | 367 | 351 | 4 | 3 |
| 75 | 367 | 378 | 351 | 4 | 3 |
| 76 | 378 | 389 | 351 | 4 | 3 |
| 77 | 389 | 400 | 351 | 4 | 3 |
| 78 | 400 | 411 | 351 | 4 | 3 |
| 79 | 411 | 422 | 351 | 4 | 3 |
| 80 | 422 | 433 | 351 | 4 | 3 |
| 81 | 433 | 444 | 351 | 4 | 3 |
| 82 | 444 | 455 | 351 | 4 | 3 |
| 83 | 455 | 488 | 351 | 4 | 3 |
| 84 | 357 | 368 | 351 | 4 | 3 |
| 85 | 368 | 379 | 351 | 4 | 3 |
| 86 | 379 | 390 | 351 | 4 | 3 |
| 87 | 390 | 401 | 351 | 4 | 3 |
| 88 | 401 | 412 | 351 | 4 | 3 |
| 89 | 412 | 423 | 351 | 4 | 3 |
| 90 | 423 | 434 | 351 | 4 | 3 |
| 91 | 434 | 445 | 351 | 4 | 3 |
| 92 | 445 | 456 | 351 | 4 | 3 |
| 93 | 456 | 489 | 351 | 4 | 3 |
| 94 | 358 | 369 | 351 | 4 | 3 |
| 95 | 369 | 380 | 351 | 4 | 3 |
| 96 | 380 | 391 | 351 | 4 | 3 |
| 97 | 391 | 402 | 351 | 4 | 3 |
| 98 | 402 | 413 | 351 | 4 | 3 |
| 99 | 413 | 424 | 351 | 4 | 3 |
| 100 | 424 | 435 | 351 | 4 | 3 |
| 101 | 435 | 446 | 351 | 4 | 3 |
| 102 | 446 | 457 | 351 | 4 | 3 |
| 103 | 457 | 490 | 351 | 4 | 3 |
| 104 | 359 | 370 | 351 | 4 | 3 |
| 105 | 370 | 381 | 351 | 4 | 3 |
| 106 | 381 | 392 | 351 | 4 | 3 |
| 107 | 392 | 403 | 351 | 4 | 3 |
| 108 | 403 | 414 | 351 | 4 | 3 |
| 109 | 414 | 425 | 351 | 4 | 3 |
| 110 | 425 | 436 | 351 | 4 | 3 |
| 111 | 436 | 447 | 351 | 4 | 3 |
| 112 | 447 | 458 | 351 | 4 | 3 |
| 113 | 458 | 491 | 351 | 4 | 3 |
| 114 | 360 | 371 | 351 | 4 | 3 |
| 115 | 371 | 382 | 351 | 4 | 3 |
| 116 | 382 | 393 | 351 | 4 | 3 |
| 117 | 393 | 404 | 351 | 4 | 3 |
| 118 | 404 | 415 | 351 | 4 | 3 |
| 119 | 415 | 426 | 351 | 4 | 3 |
| 120 | 426 | 437 | 351 | 4 | 3 |
| 121 | 437 | 448 | 351 | 4 | 3 |
| 122 | 448 | 459 | 351 | 4 | 3 |
| 123 | 459 | 492 | 351 | 4 | 3 |
| 124 | 361 | 372 | 351 | 4 | 3 |
| 125 | 372 | 383 | 351 | 4 | 3 |
| 126 | 383 | 394 | 351 | 4 | 3 |
| 127 | 394 | 405 | 351 | 4 | 3 |
| 128 | 405 | 416 | 351 | 4 | 3 |
| 129 | | 427 | 351 | 4 | 3 |
| 130 | | 8 | 351 | 4 | 3 |
| 131 | | 9 | 351 | 4 | 3 |

079T1000001
 Page 154

| | | | | | |
|-----|-----|-----|-----|---|---|
| 132 | 449 | 460 | 351 | 4 | 3 |
| 133 | 460 | 493 | 351 | 4 | 3 |
| 134 | 1 | 36 | 6 | 3 | 2 |
| 135 | 36 | 71 | 6 | 3 | 2 |
| 136 | 71 | 106 | 6 | 3 | 2 |
| 137 | 106 | 141 | 6 | 3 | 2 |
| 138 | 141 | 496 | 6 | 3 | 2 |
| 139 | 176 | 211 | 6 | 3 | 2 |
| 140 | 211 | 246 | 6 | 3 | 2 |
| 141 | 246 | 281 | 6 | 3 | 2 |
| 142 | 281 | 316 | 6 | 3 | 2 |
| 143 | 35 | 70 | 6 | 2 | 2 |
| 144 | 70 | 105 | 6 | 2 | 2 |
| 145 | 105 | 140 | 6 | 2 | 2 |
| 146 | 140 | 175 | 6 | 2 | 2 |
| 147 | 175 | 210 | 6 | 2 | 2 |
| 148 | 210 | 245 | 6 | 2 | 2 |
| 149 | 245 | 280 | 6 | 2 | 2 |
| 150 | 280 | 315 | 6 | 2 | 2 |
| 151 | 315 | 350 | 6 | 2 | 2 |
| 152 | 6 | 41 | 7 | 5 | 4 |
| 153 | 41 | 76 | 7 | 5 | 4 |
| 154 | 76 | 111 | 7 | 5 | 4 |
| 155 | 111 | 146 | 7 | 5 | 4 |
| 156 | 146 | 181 | 7 | 5 | 4 |
| 157 | 181 | 216 | 7 | 5 | 4 |
| 158 | 216 | 251 | 7 | 5 | 4 |
| 159 | 251 | 286 | 7 | 5 | 4 |
| 160 | 286 | 321 | 7 | 5 | 4 |
| 161 | 321 | 494 | 7 | 5 | 4 |
| 162 | 76 | 499 | 251 | 6 | 5 |
| 163 | 251 | 500 | 76 | 6 | 5 |
| 164 | 251 | 501 | 76 | 6 | 5 |
| 165 | 495 | 210 | 6 | 2 | 2 |
| 166 | 496 | 176 | 6 | 3 | 2 |

| | | | | | |
|----|----|-----|-----|----|---|
| 1. | | | | | |
| | 1. | | | | |
| | | 1. | | | |
| | | | 1. | | |
| 0. | 0. | 0. | | | |
| 1 | 1 | | | -1 | 1 |
| 1 | 1 | | 90. | -1 | 1 |
| 1 | 1 | 45. | 45. | -1 | 1 |

***** ANSYS INPUT DATA LISTING (FILE18) *****

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|----|---|-------|---------|---------|------|------|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 1 | CARIZZO SOLAR RECEIVER-(DWG.NO.079000001)-SINGLE TUBE-THERMAL LOADING | | | | | | | | | | | | |
| 2 | W.PROPES | | | | | | | | | | | | |
| 3 | | 1 | 1 | 1 | 9 | | | | | | | | |
| 4 | | 70. | | 70. | | | | | | | | | |
| 5 | 1 | 20 | 1 | | | | | | | | | | |
| 6 | 2 | 4 | 1 | | | | | | | | | | |
| 7 | -1 | | | | | | | | | | | | |
| 8 | | .75 | .049 | | | | | | | | | | |
| 9 | | .0085 | 5.74E-6 | 5.74E-6 | .104 | .104 | 0. | | | | | | |
| 10 | | 1. | 10. | 10. | 1. | 1. | | | | | | | |
| 11 | -1 | | | | | | | | | | | | |
| 12 | /COM ELEMENT DEFINITION | | | | | | | | | | | | |
| 13 | 1 | 2 | | | | | | | | | | | |
| 14 | 2 | 3 | | | | | | | | | | | |
| 15 | 3 | 4 | | | | | | | | | | | |
| 16 | 4 | 5 | | | | | | | | | | | |
| 17 | 5 | 6 | | | | | | | | | | | |
| 18 | 6 | 7 | | | | | | | | | | | |
| 19 | 7 | 8 | | | | | | | | | | | |
| 20 | 8 | 9 | | | | | | | | | | | |
| 21 | 9 | 10 | | | | | | | | | | | |
| 22 | 10 | 11 | | | | | | | | | | | |
| 23 | 11 | 12 | | | | | | | | | | | |
| 24 | 12 | 13 | | | | | | | | | | | |
| 25 | 13 | 14 | | | | | | | | | | | |
| 26 | 14 | 15 | | | | | | | | | | | |
| 27 | 15 | 16 | | | | | | | | | | | |
| 28 | 16 | 17 | | | | | | | | | | | |
| 29 | 17 | 18 | | | | | | | | | | | |
| 30 | 18 | 19 | | | | | | | | | | | |
| 31 | 19 | 20 | | | | | | | | | | | |
| 32 | 20 | 21 | | | | | | | | | | | |
| 33 | 21 | 22 | | | | | | | | | | | |
| 34 | 22 | 23 | | | | | | | | | | | |
| 35 | 23 | 24 | | | | | | | | | | | |
| 36 | 24 | 25 | | | | | | | | | | | |
| 37 | 25 | 26 | | | | | | | | | | | |
| 38 | 26 | 27 | | | | | | | | | | | |
| 39 | 27 | 28 | | | | | | | | | | | |
| 40 | 28 | 29 | | | | | | | | | | | |
| 41 | 29 | 30 | | | | | | | | | | | |
| 42 | 30 | 31 | | | | | | | | | | | |
| 43 | 31 | 32 | | | | | | | | | | | |
| 44 | 32 | 33 | | | | | | | | | | | |
| 45 | 33 | 34 | | | | | | | | | | | |
| 46 | 34 | 35 | | | | | | | | | | | |
| 47 | 35 | 36 | | | | | | | | | | | |
| 48 | 36 | 37 | | | | | | | | | | | |
| 49 | 37 | 38 | | | | | | | | | | | |
| 50 | 38 | 39 | | | | | | | | | | | |
| | A | A | A | A | A | A | A | A | A | A | A | A | A |

ANSYS SINGLE TUBE MODEL
INPUT DATA LISTING

079TI000001
Page 156

***** ANSYS INPUT DATA LISTING (FILE18) *****

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|-----|--------------------|-----|----|----|----|----|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 51 | 39 | 40 | | | | | | | | | 1 | | |
| 52 | 40 | 41 | | | | | | | | | 1 | | |
| 53 | 41 | 42 | | | | | | | | | 1 | | |
| 54 | 42 | 43 | | | | | | | | | 1 | | |
| 55 | 43 | 44 | | | | | | | | | 1 | | |
| 56 | 44 | 45 | | | | | | | | | 1 | | |
| 57 | 45 | 46 | | | | | | | | | 1 | | |
| 58 | 46 | 47 | | | | | | | | | 1 | | |
| 59 | 47 | 48 | | | | | | | | | 1 | | |
| 60 | 48 | 49 | | | | | | | | | 1 | | |
| 61 | 49 | 50 | | | | | | | | | 1 | | |
| 62 | 50 | 51 | | | | | | | | | 1 | | |
| 63 | 51 | 52 | | | | | | | | | 1 | | |
| 64 | 52 | 53 | | | | | | | | | 1 | | |
| 65 | 53 | 54 | | | | | | | | | 1 | | |
| 66 | 54 | 55 | | | | | | | | | 1 | | |
| 67 | 55 | 56 | | | | | | | | | 1 | | |
| 68 | 56 | 57 | | | | | | | | | 1 | | |
| 69 | 57 | 58 | | | | | | | | | 1 | | |
| 70 | 58 | 59 | | | | | | | | | 1 | | |
| 71 | 59 | 60 | | | | | | | | | 1 | | |
| 72 | 60 | 61 | | | | | | | | | 1 | | |
| 73 | 61 | 62 | | | | | | | | | 1 | | |
| 74 | 62 | 63 | | | | | | | | | 1 | | |
| 75 | 5 | 64 | | | | | | | 2 | 2 | | | |
| 76 | 6 | 65 | | | | | | | 2 | 2 | | | |
| 77 | 10 | 66 | | | | | | | 2 | 2 | | | |
| 78 | 11 | 67 | | | | | | | 2 | 2 | | | |
| 79 | 15 | 68 | | | | | | | 2 | 2 | | | |
| 80 | 16 | 69 | | | | | | | 2 | 2 | | | |
| 81 | 20 | 70 | | | | | | | 2 | 2 | | | |
| 82 | 21 | 71 | | | | | | | 2 | 2 | | | |
| 83 | 25 | 72 | | | | | | | 2 | 2 | | | |
| 84 | 26 | 73 | | | | | | | 2 | 2 | | | |
| 85 | 30 | 74 | | | | | | | 2 | 2 | | | |
| 86 | 31 | 75 | | | | | | | 2 | 2 | | | |
| 87 | 35 | 76 | | | | | | | 2 | 2 | | | |
| 88 | 36 | 77 | | | | | | | 2 | 2 | | | |
| 89 | 40 | 78 | | | | | | | 2 | 2 | | | |
| 90 | 41 | 79 | | | | | | | 2 | 2 | | | |
| 91 | 45 | 80 | | | | | | | 2 | 2 | | | |
| 92 | 46 | 81 | | | | | | | 2 | 2 | | | |
| 93 | 50 | 82 | | | | | | | 2 | 2 | | | |
| 94 | 51 | 83 | | | | | | | 2 | 2 | | | |
| 95 | 55 | 84 | | | | | | | 2 | 2 | | | |
| 96 | 56 | 85 | | | | | | | 2 | 2 | | | |
| 97 | 64 | 104 | | | | | | | 2 | 3 | 11 | 2 | |
| 98 | 104 | 65 | | | | | | | 2 | 3 | 11 | 2 | |
| 99 | -1 | | | | | | | | | | | | |
| 100 | /COM TUBE GEOMETRY | | | | | | | | | | | | |
| | A | A | A | A | A | A | A | A | A | A | A | A | A |

079TI000001
 Page 157

***** ANSYS INPUT DATA LISTING (FILE18) *****

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|-----|----|----|----|------|----|--------|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 101 | 1 | | | 2.14 | | 12. | | 0. | | | | | |
| 102 | 2 | | | 0. | | 14.14 | | 0. | | | | | |
| 103 | 3 | | | 0. | | 24. | | 0. | | | | | |
| 104 | 4 | | | 0. | | 36. | | 0. | | | | | |
| 105 | 5 | | | 0. | | 47.37 | | 0. | | | | | |
| 106 | 6 | | | 0. | | 48.63 | | 0. | | | | | |
| 107 | 7 | | | 0. | | 60. | | 0. | | | | | |
| 108 | 8 | | | 0. | | 72. | | 0. | | | | | |
| 109 | 9 | | | 0. | | 84. | | 0. | | | | | |
| 110 | 10 | | | 0. | | 95.37 | | 0. | | | | | |
| 111 | 11 | | | 0. | | 96.63 | | 0. | | | | | |
| 112 | 12 | | | 0. | | 108. | | 0. | | | | | |
| 113 | 13 | | | 0. | | 120. | | 0. | | | | | |
| 114 | 14 | | | 0. | | 132. | | 0. | | | | | |
| 115 | 15 | | | 0. | | 143.37 | | 0. | | | | | |
| 116 | 16 | | | 0. | | 144.63 | | 0. | | | | | |
| 117 | 17 | | | 0. | | 156. | | 0. | | | | | |
| 118 | 18 | | | 0. | | 168. | | 0. | | | | | |
| 119 | 19 | | | 0. | | 180. | | 0. | | | | | |
| 120 | 20 | | | 0. | | 191.37 | | 0. | | | | | |
| 121 | 21 | | | 0. | | 192.63 | | 0. | | | | | |
| 122 | 22 | | | 0. | | 204. | | 0. | | | | | |
| 123 | 23 | | | 0. | | 216. | | 0. | | | | | |
| 124 | 24 | | | 0. | | 228. | | 0. | | | | | |
| 125 | 25 | | | 0. | | 239.37 | | 0. | | | | | |
| 126 | 26 | | | 0. | | 240.63 | | 0. | | | | | |
| 127 | 27 | | | 0. | | 252. | | 0. | | | | | |
| 128 | 28 | | | 0. | | 264. | | 0. | | | | | |
| 129 | 29 | | | 0. | | 276. | | 0. | | | | | |
| 130 | 30 | | | 0. | | 287.37 | | 0. | | | | | |
| 131 | 31 | | | 0. | | 288.63 | | 0. | | | | | |
| 132 | 32 | | | 0. | | 300. | | 0. | | | | | |
| 133 | 33 | | | 0. | | 312. | | 0. | | | | | |
| 134 | 34 | | | 0. | | 324. | | 0. | | | | | |
| 135 | 35 | | | 0. | | 335.37 | | 0. | | | | | |
| 136 | 36 | | | 0. | | 336.63 | | 0. | | | | | |
| 137 | 37 | | | 0. | | 348. | | 0. | | | | | |
| 138 | 38 | | | 0. | | 360. | | 0. | | | | | |
| 139 | 39 | | | 0. | | 372. | | 0. | | | | | |
| 140 | 40 | | | 0. | | 383.37 | | 0. | | | | | |
| 141 | 41 | | | 0. | | 384.63 | | 0. | | | | | |
| 142 | 42 | | | 0. | | 396. | | 0. | | | | | |
| 143 | 43 | | | 0. | | 408. | | 0. | | | | | |
| 144 | 44 | | | 0. | | 420. | | 0. | | | | | |
| 145 | 45 | | | 0. | | 431.37 | | 0. | | | | | |
| 146 | 46 | | | 0. | | 432.63 | | 0. | | | | | |
| 147 | 47 | | | 0. | | 444. | | 0. | | | | | |
| 148 | 48 | | | 0. | | 456. | | 0. | | | | | |
| 149 | 49 | | | 0. | | 468. | | 0. | | | | | |
| 150 | 50 | | | 0. | | 479.37 | | 0. | | | | | |
| | A | A | A | A | A | A | A | A | A | A | A | A | A |

079TI1000004
 Page 158

***** ANSYS INPUT DATA LISTING (FILE18) *****

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|-----|------|-----|-----|------|----|--------|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 151 | 51 | | | 0. | | 480.63 | | 0. | | | | | |
| 152 | 52 | | | 0. | | 492. | | 0. | | | | | |
| 153 | 53 | | | 0. | | 504. | | 0. | | | | | |
| 154 | 54 | | | 0. | | 516. | | 0. | | | | | |
| 155 | 55 | | | 0. | | 527.37 | | 0. | | | | | |
| 156 | 56 | | | 0. | | 528.63 | | 0. | | | | | |
| 157 | 57 | | | 0. | | 540. | | 0. | | | | | |
| 158 | 58 | | | 0. | | 552. | | 0. | | | | | |
| 159 | 59 | | | 0. | | 564. | | 0. | | | | | |
| 160 | 60 | | | 0. | | 576. | | 0. | | | | | |
| 161 | 61 | | | 0. | | 585.86 | | 0. | | | | | |
| 162 | 62 | | | 7.07 | | 592.93 | | 0. | | | | | |
| 163 | 63 | | | 2.34 | | 597.66 | | 0. | | | | | |
| 164 | 64 | | | 4.38 | | 47.37 | | 0. | | | | | |
| 165 | 65 | | | 4.38 | | 48.63 | | 0. | | | | | |
| 166 | 66 | | | 4.38 | | 95.37 | | 0. | | | | | |
| 167 | 67 | | | 4.38 | | 96.63 | | 0. | | | | | |
| 168 | 68 | | | 4.38 | | 143.37 | | 0. | | | | | |
| 169 | 69 | | | 4.38 | | 144.63 | | 0. | | | | | |
| 170 | 70 | | | 4.38 | | 191.37 | | 0. | | | | | |
| 171 | 71 | | | 4.38 | | 192.63 | | 0. | | | | | |
| 172 | 72 | | | 4.38 | | 239.37 | | 0. | | | | | |
| 173 | 73 | | | 4.38 | | 240.63 | | 0. | | | | | |
| 174 | 74 | | | 4.38 | | 287.37 | | 0. | | | | | |
| 175 | 75 | | | 4.38 | | 288.63 | | 0. | | | | | |
| 176 | 76 | | | 4.38 | | 335.37 | | 0. | | | | | |
| 177 | 77 | | | 4.38 | | 336.63 | | 0. | | | | | |
| 178 | 78 | | | 4.38 | | 383.37 | | 0. | | | | | |
| 179 | 79 | | | 4.38 | | 384.63 | | 0. | | | | | |
| 180 | 80 | | | 4.38 | | 431.37 | | 0. | | | | | |
| 181 | 81 | | | 4.38 | | 432.63 | | 0. | | | | | |
| 182 | 82 | | | 4.38 | | 479.37 | | 0. | | | | | |
| 183 | 83 | | | 4.38 | | 480.63 | | 0. | | | | | |
| 184 | 84 | | | 4.38 | | 527.37 | | 0. | | | | | |
| 185 | 85 | | | 4.38 | | 528.63 | | 0. | | | | | |
| 186 | 104 | | | 4.38 | | 48. | | 0. | | | | | |
| 187 | 106 | | | 4.38 | | 96. | | 0. | | | | | |
| 188 | 108 | | | 4.38 | | 143. | | 0. | | | | | |
| 189 | 110 | | | 4.38 | | 192. | | 0. | | | | | |
| 190 | 112 | | | 4.38 | | 240. | | 0. | | | | | |
| 191 | 114 | | | 4.38 | | 288. | | 0. | | | | | |
| 192 | 116 | | | 4.38 | | 336. | | 0. | | | | | |
| 193 | 118 | | | 4.38 | | 384. | | 0. | | | | | |
| 194 | 120 | | | 4.38 | | 432. | | 0. | | | | | |
| 195 | 122 | | | 4.38 | | 480. | | 0. | | | | | |
| 196 | 124 | | | 4.38 | | 528. | | 0. | | | | | |
| 197 | -1 | | | | | | | | | | | | |
| 198 | VIEW | | | | | | | | | | | | |
| 199 | | 0.0 | 0.0 | 1.0 | | | | | | | | | |
| 200 | PLOT | | 1 | 4 | | | | | | | | | |
| | A | A | A | A | A | A | A | A | A | A | A | A | A |

079TI000001
Page 159

***** ANSYS INPUT DATA LISTING (FILE18) *****

6 12 18 24 30 36 42 48 54 60 66 72 78
 V V V V V V V V V V V V V

201 -1
 202 /COM MATERIAL PROPERTY DEFINITIONS
 203 EX 2.833669E7-2.892211E+3-3.697849E-07.709183E-04
 204 ALPX 2
 205 12 100. 100.
 206 8.4732E-6 8.7389E-6 8.9839E-6 9.2093E-6 9.4160E-6 9.6051E-6
 207 9.7777E-6 9.9350E-6 10.0789E-6 10.0208E-6 10.0326E-6 10.4320E-6
 208 NUXY 2.624811E-1 4.265787E-5
 209 DENS 2
 210 2 100. 1100.
 211 744.E-6 749.E-6

212 -1
 213 1 1 1

215 /COM DISPLACEMENT DEFINITIONS

216 1 UX 0.
 217 1 UY 0.
 218 1 UZ 0.
 219 1 ROTX 0.
 220 1 ROTY 0.
 221 63 UX
 222 63 UZ
 223 63 ROTX
 224 63 ROTY
 225 63 ROTZ
 226 104 UX 0. 124 2
 227 104 UZ 0. 124 2
 228 104 ROTX 0. 124 2
 229 104 ROTY 0. 124 2

230 -1
 231

233 /COM ELEMENT TEMPERATURES

234 610. 610. 610. 5
 235 617. 617. 629.
 236 620. 620. 635.
 237 626. 626. 642.
 238 632. 632. 650.
 239 635. 635. 655.
 240 639. 639. 660.
 241 647. 647. 673.
 242 657. 657. 684.
 243 667. 667. 699.
 244 673. 673. 706.
 245 679. 679. 715.
 246 691. 691. 730.
 247 705. 705. 750.
 248 719. 719. 767.
 249 728. 728. 777.
 250 735. 735. 787.

A A A A A A A A A A A A A

079T1000001
 Page 160

***** ANSYS INPUT DATA LISTING (FILE18) *****

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|-----|----------|-------|-------|----|----|----|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 251 | 751. | 751. | 808. | | | | | | | | | | |
| 252 | 769. | 769. | 830. | | | | | | | | | | |
| 253 | 786. | 786. | 850. | | | | | | | | | | |
| 254 | 796. | 796. | 860. | | | | | | | | | | |
| 255 | 807. | 807. | 872. | | | | | | | | | | |
| 256 | 825. | 825. | 891. | | | | | | | | | | |
| 257 | 843. | 843. | 914. | | | | | | | | | | |
| 258 | 861. | 861. | 930. | | | | | | | | | | |
| 259 | 871. | 871. | 940. | | | | | | | | | | |
| 260 | 881. | 881. | 950. | | | | | | | | | | |
| 261 | 899. | 899. | 966. | | | | | | | | | | |
| 262 | 916. | 916. | 984. | | | | | | | | | | |
| 263 | 932. | 932. | 997. | | | | | | | | | | |
| 264 | 940. | 940. | 1004. | | | | | | | | | | |
| 265 | 947. | 947. | 1010. | | | | | | | | | | |
| 266 | 961. | 961. | 1023. | | | | | | | | | | |
| 267 | 975. | 975. | 1033. | | | | | | | | | | |
| 268 | 987. | 987. | 1041. | | | | | | | | | | |
| 269 | 993. | 993. | 1045. | | | | | | | | | | |
| 270 | 999. | 999. | 1048. | | | | | | | | | | |
| 271 | 1008. | 1008. | 1053. | | | | | | | | | | |
| 272 | 1016. | 1016. | 1057. | | | | | | | | | | |
| 273 | 1024. | 1024. | 1060. | | | | | | | | | | |
| 274 | 1027. | 1027. | 1061. | | | | | | | | | | |
| 275 | 1030. | 1030. | 1063. | | | | | | | | | | |
| 276 | 1035. | 1035. | 1065. | | | | | | | | | | |
| 277 | 1040. | 1040. | 1066. | | | | | | | | | | |
| 278 | 1045. | 1045. | 1066. | | | | | | | | | | |
| 279 | 1046. | 1046. | 1066. | | | | | | | | | | |
| 280 | 1049. | 1049. | 1066. | | | | | | | | | | |
| 281 | 1050. | 1050. | 1066. | | | | | | | | | | |
| 282 | 1052. | 1052. | 1066. | | | | | | | | | | |
| 283 | 1053. | 1053. | 1065. | | | | | | | | | | |
| 284 | 1050. | 1050. | 1050. | | | | | | | | | | |
| 285 | 405. | 405. | 405. | | | | | | | | | 8 | |
| 286 | 408. | 408. | 408. | | | | | | | | | 2 | |
| 287 | 420. | 420. | 420. | | | | | | | | | 2 | |
| 288 | 440. | 440. | 440. | | | | | | | | | 2 | |
| 289 | 466. | 466. | 466. | | | | | | | | | 2 | |
| 290 | 501. | 501. | 501. | | | | | | | | | 2 | |
| 291 | 538. | 538. | 538. | | | | | | | | | 2 | |
| 292 | 571. | 571. | 571. | | | | | | | | | 2 | |
| 293 | 597. | 597. | 597. | | | | | | | | | 2 | |
| 294 | 613. | 613. | 613. | | | | | | | | | 2 | |
| 295 | 622. | 622. | 622. | | | | | | | | | 25 | |
| 296 | END | | | | | | | | | | | | |
| 297 | FINISH | | | | | | | | | | | | |
| 298 | /POST22 | | | | | | | | | | | | |
| 299 | RATIO,20 | | | | | | | | | | | | |
| 300 | PLDISP | | | | | | | | | | | | |

A A A A A A A A A A A A A

079T1000001
Page 161

***** ANSYS INPUT DATA LISTING (FILE18) *****

| | | | | | | | | | | | | |
|---|----|----|----|----|----|----|----|----|----|----|----|----|
| 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
| V | V | V | V | V | V | V | V | V | V | V | V | V |

301 FINISH


079T1000001
Page 162

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|----|---|----|----|----|----|----|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 1 | /PREP7 | | | | | | | | | | | | |
| 2 | /TITLE SOLAR PANEL TUBE | | | | | | | | | | | | |
| 3 | KAN,0 | | | | | | | | | | | | |
| 4 | ET,1,42,1,1 | | | | | | | | | | | | |
| 5 | TREF,70. | | | | | | | | | | | | |
| 6 | KNL,1 | | | | | | | | | | | | |
| 7 | TQFFST,460. | | | | | | | | | | | | |
| 8 | MPTEMP,1,70.,700.,800.,900.,1000.,1100. | | | | | | | | | | | | |
| 9 | MPDATA,ALPX,1,1,8.473E-6,9.778E-6,9.935E-6,10.08E-6,10.21E-6,10.33E-6 | | | | | | | | | | | | |
| 10 | MPDATA,EX,1,1,28.01E6,24.77E6,24.06E6,23.31E6,22.53E6,21.72E6 | | | | | | | | | | | | |
| 11 | NL,1,1,1.0,10.0 | | | | | | | | | | | | |
| 12 | NL,1,7,0.0 | | | | | | | | | | | | |
| 13 | NL,1,13,2 | | | | | | | | | | | | |
| 14 | NL,1,19,800,1000,1200 | | | | | | | | | | | | |
| 15 | NL,1,25,17000,15500,14500 | | | | | | | | | | | | |
| 16 | NL,1,31,089,096,103 | | | | | | | | | | | | |
| 17 | MPLIST | | | | | | | | | | | | |
| 18 | LOCAL,11,1,100.,0.,0 | | | | | | | | | | | | |
| 19 | N,1,375,180.,0 | | | | | | | | | | | | |
| 20 | N,6,326,180.,0 | | | | | | | | | | | | |
| 21 | N,211,375,-170.,0 | | | | | | | | | | | | |
| 22 | N,216,326,-170.,0 | | | | | | | | | | | | |
| 23 | FILL,1,211,34,7,6 | | | | | | | | | | | | |
| 24 | FILL,6,216,34,12,6 | | | | | | | | | | | | |
| 25 | FILL,1,6,4,2,1,36,6 | | | | | | | | | | | | |
| 26 | NLIST | | | | | | | | | | | | |
| 27 | NPLOT,1 | | | | | | | | | | | | |
| 28 | VIEW,0,0,1,0 | | | | | | | | | | | | |
| 29 | GRANGE,99.,101.,1.0,-1.0,0.,0 | | | | | | | | | | | | |
| 30 | E,1,2,8,7 | | | | | | | | | | | | |
| 31 | EGEN,5,1,1 | | | | | | | | | | | | |
| 32 | EGEN,35,6,1,5 | | | | | | | | | | | | |
| 33 | E,211,212,2,1 | | | | | | | | | | | | |
| 34 | E,212,213,3,2 | | | | | | | | | | | | |
| 35 | E,213,214,4,3 | | | | | | | | | | | | |
| 36 | E,214,215,5,4 | | | | | | | | | | | | |
| 37 | E,215,216,6,5 | | | | | | | | | | | | |
| 38 | ELIST | | | | | | | | | | | | |
| 39 | NPLOT | | | | | | | | | | | | |

ANSYS TUBE CROSS_SECTION
MODEL INPUT DATA LISTING

40 ENUM,1
41 EPLOT
42 NRANGE
43 ELIST,1,180
44 NLIST,1,216
45 D,163,UY,.0
46 ITER,-10,10
47 LPRINT,1
48 KTEMP,-1
49 T,109,1022.5
50 T,110,997.4

A A A A A A A A A A A



***** ANSYS INPUT DATA LISTING (.....E18) *****

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|----|--------------------|----|----|----|----|----|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 51 | T,111,971.5 | | | | | | | | | | | | |
| 52 | T,112,944.7 | | | | | | | | | | | | |
| 53 | T,113,916.9 | | | | | | | | | | | | |
| 54 | T,114,888.1 | | | | | | | | | | | | |
| 55 | T,115,1019.7 | | | | | | | | | | | | |
| 56 | T,116,994.90 | | | | | | | | | | | | |
| 57 | T,117,969.40 | | | | | | | | | | | | |
| 58 | T,118,943.0 | | | | | | | | | | | | |
| 59 | T,119,915.6 | | | | | | | | | | | | |
| 60 | T,120,887.2 | | | | | | | | | | | | |
| 61 | TGEN,6,-12,115,120 | | | | | | | | | | | | |
| 62 | T,121,1011.3 | | | | | | | | | | | | |
| 63 | T,122,987.60 | | | | | | | | | | | | |
| 64 | T,123,963.1 | | | | | | | | | | | | |
| 65 | T,124,937.9 | | | | | | | | | | | | |
| 66 | T,125,911.7 | | | | | | | | | | | | |
| 67 | T,126,884.6 | | | | | | | | | | | | |
| 68 | TGEN,6,-24,121,126 | | | | | | | | | | | | |
| 69 | T,127,997.5 | | | | | | | | | | | | |
| 70 | T,128,975.50 | | | | | | | | | | | | |
| 71 | T,129,952.9 | | | | | | | | | | | | |
| 72 | T,130,929.5 | | | | | | | | | | | | |
| 73 | T,131,905.4 | | | | | | | | | | | | |
| 74 | T,132,880.3 | | | | | | | | | | | | |
| 75 | TGEN,6,-36,127,132 | | | | | | | | | | | | |
| 76 | T,133,978.6 | | | | | | | | | | | | |
| 77 | T,134,959.1 | | | | | | | | | | | | |
| 78 | T,135,939.0 | | | | | | | | | | | | |
| 79 | T,136,918.2 | | | | | | | | | | | | |
| 80 | T,137,896.7 | | | | | | | | | | | | |
| 81 | T,138,874.5 | | | | | | | | | | | | |
| 82 | TGEN,6,-48,133,138 | | | | | | | | | | | | |
| 83 | T,139,955.3 | | | | | | | | | | | | |
| 84 | T,140,938.70 | | | | | | | | | | | | |
| 85 | T,141,921.7 | | | | | | | | | | | | |
| 86 | T,142,904.2 | | | | | | | | | | | | |
| 87 | T,143,886.1 | | | | | | | | | | | | |
| 88 | T,144,867.4 | | | | | | | | | | | | |
| 89 | TGEN,6,-60,139,144 | | | | | | | | | | | | |

90 T,145,928.0
91 T,146,915.1
92 T,147,901.7
93 T,148,888.0
94 T,149,873.8
95 T,150,859.1
96 TGEN,6,-72,145,150
97 T,151,879.9
98 T,152,888.90
99 T,153,879.7
100 T,154,870.2

A A A A A A A A A A A A

***** ANSYS INPUT DATA LISTING (FILE18) *****

| | 6 | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 | 66 | 72 | 78 |
|-----|---------------------|----|----|----|----|----|----|----|----|----|----|----|----|
| | V | V | V | V | V | V | V | V | V | V | V | V | V |
| 101 | T,155,860.3 | | | | | | | | | | | | |
| 102 | F,156,850.1 | | | | | | | | | | | | |
| 103 | TGEN,6,-84,151,156 | | | | | | | | | | | | |
| 104 | I,157,866.6 | | | | | | | | | | | | |
| 105 | T,158,862.0 | | | | | | | | | | | | |
| 106 | T,159,857.1 | | | | | | | | | | | | |
| 107 | T,160,852.0 | | | | | | | | | | | | |
| 108 | T,161,846.6 | | | | | | | | | | | | |
| 109 | T,162,841.0 | | | | | | | | | | | | |
| 110 | TGEN,6,-96,157,162 | | | | | | | | | | | | |
| 111 | T,163,838.4 | | | | | | | | | | | | |
| 112 | T,164,838.20 | | | | | | | | | | | | |
| 113 | T,165,837.5 | | | | | | | | | | | | |
| 114 | T,166,836.4 | | | | | | | | | | | | |
| 115 | T,167,835.0 | | | | | | | | | | | | |
| 116 | T,168,833.0 | | | | | | | | | | | | |
| 117 | TGEN,6,-108,163,168 | | | | | | | | | | | | |
| 118 | F,169,832.2 | | | | | | | | | | | | |
| 119 | T,170,832.2 | | | | | | | | | | | | |
| 120 | T,171,832.0 | | | | | | | | | | | | |
| 121 | T,172,831.7 | | | | | | | | | | | | |
| 122 | T,173,831.4 | | | | | | | | | | | | |
| 123 | T,174,830.9 | | | | | | | | | | | | |
| 124 | TGEN,6,-120,169,174 | | | | | | | | | | | | |
| 125 | T,175,830.5 | | | | | | | | | | | | |
| 126 | T,176,830.50 | | | | | | | | | | | | |
| 127 | T,177,830.5 | | | | | | | | | | | | |
| 128 | T,178,830.5 | | | | | | | | | | | | |
| 129 | T,179,830.5 | | | | | | | | | | | | |
| 130 | T,180,830.5 | | | | | | | | | | | | |
| 131 | TGEN,37,1,180 | | | | | | | | | | | | |
| 132 | T,1,830.5 | | | | | | | | | | | | |
| 133 | TGEN,48,1,1 | | | | | | | | | | | | |
| 134 | LWRITE | | | | | | | | | | | | |
| 135 | TIME,7.35 | | | | | | | | | | | | |
| 136 | ITEK,-10,10 | | | | | | | | | | | | |
| 137 | LPRINT,1 | | | | | | | | | | | | |
| 138 | LWRITE | | | | | | | | | | | | |
| 139 | AFWRITE | | | | | | | | | | | | |

140 FINISH
141 /INPUT,27
142 FINISH



| | | | | | |
|-----------------|------------------|-----------------|-------------------|--|-----------------------|
| GO NO. 09479 | S/A NO. 13400 | PAGE 1 OF 73 | TOTAL PAGES 73 | REV LTR/CHG NO SEE SUMMARY OF CHG NC | NUMBER 079TI000007 |
|-----------------|------------------|-----------------|-------------------|--|-----------------------|

PROGRAM TITLE
Preliminary Design of the Carrizo Plains Solar Central Receiver Power Plant

DOCUMENT TITLE
Sodium Safety Plan

| | |
|--|-----------|
| DOCUMENT TYPE Technical Information | KEY NOUNS |
|--|-----------|

| | | | |
|---|-------------------------|-------------------------------|---|
| ORIGINAL ISSUE DATE April 18, 1983 | REL. DATE 5-17-83 RK | APPROVALS | DATE |
| PREPARED BY/DATE C. E. McDade P. A. Scofield | DEPT 360 360 | MAIL ADDR EMSC EMSC | G. Lauer SJ A. Z. Ullman <i>A. Z. Ullman</i> T. H. Springer <i>T. H. Springer</i> |
| IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> | | 4/20/83 5/13/83 5/12/83 | |
| IF YES, ENTER TPA NO. | | | |

| | |
|--------------|----------|
| DISTRIBUTION | ABSTRACT |
|--------------|----------|

| * NAME | MAIL ADDR |
|---------------------|-----------|
| * A. Z. Ullman (4) | LA19 |
| * T. H. Springer(3) | LA18 |
| * G. J. Hallinan | LA24 |
| * R. E. Durand | LB23 |
| * C. E. McDade | EMSC |
| * P. A. Scofield | EMSC |

A safety plan for sodium-containing portions of the Carrizo Plains solar power plant is presented. The plan specifies required personnel protective equipment for workers with varying levels of potential exposure to sodium. Hazard control and safety equipment requirements are specified. Emergency operating procedures are developed for sodium-related accidents, and spill counter measures are given.

RESERVED FOR PROPRIETARY/LEGAL NOTICES

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE DOE OFFICE OF PATENT COUNSEL

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY

Table of Contents

| | Page |
|--|------|
| 1.0 INTRODUCTION | 1-1 |
| 1.1 DESCRIPTION OF PROJECT | 1-1 |
| 1.2 SUMMARY OF RECOMMENDATIONS | 1-2 |
| 2.0 FEDERAL, STATE & LOCAL GOVERNMENTAL SAFETY REQUIREMENTS | 2-1 |
| 2.1 FEDERAL REQUIREMENTS | 2-1 |
| 2.2 STATE REQUIREMENTS | 2-3 |
| 2.3 COUNTY REQUIREMENTS. | 2-5 |
| 2.4 CODES, STANDARDS, AND GUIDES | 2-7 |
| 3.0 PERSONNEL PROTECTION | 3-1 |
| 4.0 CONTROL EQUIPMENT. | 4-1 |
| 4.1 SPILL CONTAINMENT. | 4-1 |
| 4.2 ISOLATION AND SHIELDING. | 4-3 |
| 4.3 VENTING AND VENTILATION. | 4-3 |
| 4.4 AUTOMATIC ISOLATION. | 4-4 |
| 5.0 SAFETY EQUIPMENT | 5-1 |
| 5.1 LEAK DETECTORS | 5-1 |
| 5.2 FIRE EXTINGUISHERS | 5-4 |
| 5.3 SAFETY SHOWERS AND EYE WASHES. | 5-7 |
| 6.0 EMERGENCY OPERATING PROCEDURES | 6-1 |
| 6.1 FIRE FIGHTING. | 6-1 |
| 6.2 FIRST AID. | 6-2 |
| 6.3 EMERGENCY EVACUATION | 6-3 |
| 7.0 SPILL COUNTERMEASURES. | 7-1 |
| 7.1 DISPOSAL OF WASTE SODIUM | 7-1 |
| 7.2 CLEANING CONTAMINATED EQUIPMENT. | 7-2 |
| 7.3 HAZARDOUS WASTE PERMITS. | 7-2 |
| 8.0 REFERENCES | 8-1 |
| A LIQUID SODIUM SAFETY HISTORY | A-1 |
| B MODELING STUDY | B-1 |
| C PROPERTIES AND HAZARDS OF LIQUID SODIUM. | C-1 |
| C.1 PROPERTIES OF LIQUID SODIUM. | C-1 |
| C.2 LIQUID SODIUM HAZARDS. | C-2 |

Table of Contents (Continued)

| | Page |
|--|------|
| D GENERAL INDUSTRY SAFETY ORDERS | D-1 |

1.0 INTRODUCTION

1.1 DESCRIPTION OF PROJECT

This document presents a safety plan for the heat transport system at the proposed Carrizo Plain solar power plant. The plant design will utilize a heliostat field and a 350 ft solar receiver tower. Liquid sodium will flow through the receiver tower as the heat transport medium, carrying heat to a series of steam generators, steam from which will drive a turbine to produce electricity. The sodium temperatures before and after passage through the receiver tower will be 610°F and 1050°F, respectively. The total system sodium capacity will be 470,000 gallons, and sodium will be stored in hot and cold storage tanks adjacent to the receiver tower. Each tank will be capable of accommodating the entire system sodium inventory.

This safety plan covers all major aspects of liquid sodium safety. The safety procedures apply to all facets of the heat transport system, including the solar receiver, sodium heat transport loop, sodium handling equipment, steam generators, thermal storage tanks, and auxiliary equipment. This document deals with only those topics directly or indirectly related to liquid sodium safety.

Several topics related to the liquid sodium safety plan are included in the appendices. Appendix A presents a brief history of the safety of liquid sodium heat transport systems. The report of an atmospheric dispersion modeling study designed to simulate sodium spills in a solar power plant is included as Appendix B. Appendix C consists of a brief discussion of the physical and chemical properties of liquid sodium, and an examination of the effects of sodium exposure upon people. Abundant references are available to the reader who wishes to learn more about sodium properties or biological effects (see, for example, Jackson, 1955). Appendix D contains several sections of the General Industry Safety Orders dealing with flammable substances.

1.2 SUMMARY OF RECOMMENDATIONS

Presented below is a summary of the recommendations which are made in this report to protect the plant employees, the public, and the plant equipment. Each of these recommendations is discussed in detail in this safety plan.

1. Although a number of governmental regulations address plant safety, few are directly applicable to liquid sodium. Thus, many regulatory decisions will be made on a case-by-case basis, so it is essential that the plant designers communicate with the regulatory agencies during the design phase.
2. Protective clothing shall be available to all plant personnel both for everyday use and for fire fighting and emergency protection.
3. Drip pans shall be placed under all system components which may be subject to leakage, and berms shall be constructed around large storage tanks. The sodium loop shall be designed so that sections can be isolated and drained.
4. All enclosed areas shall have adequate ventilation to disperse smoke from a sodium fire.
5. Leak detectors shall be placed near all system components which may be subject to leakage. Smoke detectors shall be placed on or near the ceiling in all enclosed areas.
6. Na-X fire extinguishers shall be placed at strategic locations throughout the sodium loop area.
7. Safety showers and eye washes shall be located in the vicinity of the sodium loop, yet far enough away that there is no possibility of the shower area being involved in a sodium spill.
8. All plant personnel shall be trained in fire fighting and first aid for sodium spills. Fire fighting and first aid equipment shall be located at the plant.
9. A plan for emergency evacuation of plant personnel shall be developed. Safe areas shall be provided for employee evacuation during emergencies.
10. All waste sodium shall be disposed of properly. Hazardous waste permits shall be obtained as necessary.

NO. 079TI000007

PAGE. 6

11. Sodium warning signs (Section 2.2) shall be posted at the access points to the sodium handling area.

2.0 FEDERAL, STATE & LOCAL GOVERNMENTAL SAFETY REQUIREMENTS

The Federal, state, and local safety requirements applicable to the design of the Carrizo Plain solar power plant are delineated in this section. Due to the nature of the facility (e.g, utilization of the sodium heat transport loop, equipment, and storage facilities) most of the existing regulations are not specific and comprehensive for sodium systems. Based on this preliminary evaluation, it appears that the state and county officials would require safety design information from the contractor to evaluate the plant safety needs on a case-by-case basis.

2.1 FEDERAL REQUIREMENTS

The primary Federal acts and regulations that would be applicable in the operation of the Carrizo Plain Solar Power Plant include:

- * The Occupational Safety and Health Act of 1970 as amended, Public Law 91-596.
- * Occupational Safety and Health Administration (OSHA) Safety and Health Standards (29 CFR 1910) - "General Industry Standards."

Section 5.(A)(1) of the Occupational Safety and Health Act specifies the duties of an employer:

DUTIES [Employer]

Sec. 5. (a) Each employer--

1. shall furnish to each of his employees employment and a place of employment which are free from recognized hazards that are causing or are likely to cause death or serious physical harm to his employees;
2. shall comply with occupational safety and health standards promulgated under this Act.

This means that even where there are no existing standards covering a given situation, the employer must furnish employment and a place of employment that are free from "recognized hazards." Failure of an employer to comply with the "recognized hazard" duty could result in a citation, or notice of violation and, if established, the imposition of a penalty.

The Federal OSHA, "General Industry, Occupational Safety and Health Standards" (29 CFR 1910) are, as the title denotes, applicable to general industry. For example, Subpart D, Working Surfaces, and Subpart E, Walking-Working Surfaces, would be generally applicable to the solar power plant as they would to any other industry. There are regulations applicable to hazardous substances that could also be applicable to the solar power facility. These regulations include Subpart H, Hazardous Materials, and Subpart L, Fire Protection.

The regulations specified in Subpart H, 29 CFR 1910.106 for flammable and combustible liquids could be generally extrapolated to sodium. It must be noted, however, that the definitions and regulations for combustible and flammable liquids take into account flashpoint and ignition sources. This is not sufficient for sodium, since it is a spontaneously combustible material in air and it does not require an ignition source.

Subpart H, Section 106, also specifies:

- * Tank storage design and construction requirements,
- * Piping, valves, and fitting requirements,
- * Drainage dikes and walls for above ground tank design and construction requirements,
- * Spill containment requirements, and
- * Fire control measures (including alarm systems).

In Subpart L, Fire Protection, Section 1910.156, a class D fire is defined as "fire in combustible metals such as magnesium, titanium, zirconium, sodium and potassium." This section identifies requirements for portable fire extinguishers, fixed fire suppression equipment and other fire protection systems (29 CFR 1910.167, Local Fire Alarm Signaling Systems).

Examples of codes and standards delineated in the Federal OSHA regulations include:

- * ASME Boiler and Pressure Vessel Code, Section VIII.

- * National Fire Protection Codes
- * Title 49 Code of Federal Regulations, Transportation Regulations

These Federal OSHA regulations would be generally applicable to the Carrizo Plain Solar Power Plant, but would be superceded by the California Occupational Safety and Health Standards (see Section 2.2 for further details on state requirements). As a general rule-of-thumb, the state regulations cannot be less stringent than the Federal regulations and are often more stringent, especially in California.

2.2 STATE REQUIREMENTS

As mentioned at the beginning of this section, most of the existing regulations are not directly applicable, and the safety impacts would be assessed on a case-by-case basis. The state regulations generally applicable for the solar power plant include:

- * California Administrative Code, Title 8 - General Industry Safety Orders and Electrical Safety Orders; and Title 24, Electrical Building Codes, as promulgated under the California Occupational Safety and Health Act (CALOSHA).
- * California Environmental Quality Act.
- * Uniform Building Code.

The General Industry Safety and Electrical Safety Orders would apply for overall plant safety. However, Title 8, Group 16, Article 109, "Hot, Flammable, Poisonous, Corrosive and Irritant Substances," has some applicability for sodium. Sodium is cited in Title 8, Section 5161 as a spontaneously flammable substance, defined as "a substance which, upon contact with air or moisture reacts so violently as to ignite or cause ignition."

Section 5176 of Article 109 specifies the regulations that pertain to spontaneously flammable substances. These are as follows:

- A. Spontaneously flammable materials shall, as far as practicable, be stored and handled under a suitable liquid which will prevent contact of the material with air and with moisture if the substance reacts violently with water.

- B. Where such substances are handled or used in the dry state, the amount at each work station shall not be more than one half-day's supply or product; provided, however, that where less than one half-day's supply or product may constitute a serious hazard, the permissible amount may be restricted to less than a half-day's supply.
- C. Work stations where spontaneously flammable substances are used or handled in the dry state shall be separated by distance, barricades, or other means so that a fire in the material at one station will not ignite material at any other station.
- D. All containers, either open, closed, or covered, which contain a spontaneously flammable substance shall be plainly marked, with an appropriate warning legend, or painted a distinctive color or otherwise distinguished, except that:
1. Where there are a number of containers, which usually contain spontaneously flammable substances warning signs may be posted in the room or area in which such containers are located instead of marking individual containers; however, portable containers in which spontaneously flammable substances are used, stored, or transported shall be marked in one of the manners described above. These containers should not be used for other purposes.
 2. Original containers, marked as required by the General Industry Safety Orders, Article 112, labeling of injurious substances, shall be considered to comply with the requirements of this section. Containers (such as drums, cans, bottles, and carboys) in which spontaneously flammable substances are sold, shipped, or distributed, need not be marked, during time between filling and labeling.

The impacts of Section 5176 upon the Carrizo Plain liquid sodium system can be summarized as follows:

Part A - A liquid cover is not necessary since the sodium loop is a closed system.

Parts B and C - Applicable to laboratory and production facilities, not to closed loop systems such as Carrizo Plain.

Part D - Requires posting of warning signs around the heat transport system.

For additional regulations pertaining to flammable liquids, see Appendix D.

Other regulations within the General Industry Safety Orders that could be generally applicable to the Carrizo Plain power plant include the implementation of an Accident Program (Section 3203) and hazardous substance information requirements as specified in Section 5194, Material Safety Data Sheets.

The safety provisions stated in most of these sections are not oriented toward a sodium heat transport loop or the quantities utilized in the operation of the solar power plant. However, CALOSHA has stated that they would be interested in evaluating the safety design specifications for the power plant on a case-by-case basis (Eisen, 1983). This is due to the fact that the General Industry Safety Orders are not specific to sodium.

The California Environmental Quality Act will not impact the overall safety design requirements, but it may impact overall facility construction and operation. This act requires an analysis of any adverse environmental impacts resulting from the location and operation of the solar power plant. San Luis Obispo County will be the lead agency in determining whether an Environmental Impact Report (EIR) should be prepared (see Section 2.3 for further details). The California Uniform Building code would only be generally applicable for overall facility design.

2.3 COUNTY REQUIREMENTS

The lead governmental agency that would assess the public safety and environmental impacts of the facility would be the county. There are few county regulations that would be directly applicable to the Carrizo Plain solar power plant. The county agencies would need to evaluate the potential impacts of the plant on a case-by-case basis.

The primary written criterion that may be applicable to the facility is in the "Water Quality Control Plan" for the San Luis Obispo County Water Quality Control District (WQCD). The upper pH limit for wastewater discharge into a natural waterway can not exceed 8.5. There is also a sodium concentration limit of 69 ppm for water used in the irrigation of agricultural areas. It must be noted that these water quality requirements are not fixed and are also assessed on a case-by-case basis (Baldrige, 1983).

The Air Pollution Control District (APCD) in San Luis Obispo County has no specific or general criteria that would impact the facility (Allen, 1983). For comparison, the APCD in Ventura County does have a rule (Rule 62) for hazardous materials released in the atmosphere as shown below.

Rule 62. Hazardous Materials (Adopted 5/23/72)

No hazardous materials shall be discharged from any source so as to result in concentrations at or beyond the property line in excess of any State, Federal or local standards or emission limits established.

In the absence of specific standards for a particular hazardous material, the airborne concentrations of such materials shall not exceed those levels and time intervals established by the State Division of Industrial Safety or the Occupational Safety and Health Administration.

There will be no release of sodium to the atmosphere under normal power plant operating conditions, so these air quality regulations should have minimal effect upon plant operations. Only during an emergency release or spill would an exceedance of recommended levels be expected (see Section 5.1 and Appendix B). Such an exceedance, however, would continue only for a brief period until the spilled sodium was contained. Plant operating personnel would be expected to report any releases to the San Luis Obispo County APCD.

As previously mentioned, San Luis Obsipo County will determine whether an Environmental Impact Report (EIR) needs to be prepared pursuant to the California Environmental Quality Act (Hamm, 1983). The EIR is prepared to assess the ecological, economical, social, and archaeological impacts resulting from a facility. Based on the EIR results, the plant may or may not be permitted to operate in a specific area or required to operate under specific restrictions.

In conclusion, the primary governmental safety requirements that may impact the design of the Carrizo Plain solar power plant are the CALOSHA case-by-case evaluation and the General Industry Safety Orders. The primary governmental environmental requirements that may impact the design and operation of the facility would be the San Luis Obispo County adverse impact determination as required by the California Environmental Quality Act. At this time, it appears that there are little or no governmental safety requirements at the Federal, state or county level for sodium, especially as it relates to a solar power plant.

Therefore, plant safety determination will have to be made on a case-by-case basis by both state and county regulatory agencies.

2.4 CODES, STANDARDS, AND GUIDES

In addition to the governmental safety requirements for the design of the solar power plant, other types of industrial or trade organization safety requirements may be applicable. Examples of these codes, standards, or guides are delineated below:

- * National Fire Protection Association (NFPA), "National Fire Codes."
- * Underwriters Laboratories (UL) approved equipment listings, and Factory Mutual (FM) approved equipment guide.
- * ANSI Standard B31.1 - Power Piping.
- * API Standard 620 Recommended Rules for Design and Construction of Large, Welded, Low-Pressure Storage Tanks.
- * ANSI/ASME Boiler and Pressure Vessel Code, Section VIII, Division I.
- * National Electrical Manufacturers Association Standards

Furthermore, insurance companies have their own safety standards, so it is important that the insurer be kept informed of the plant safety design so that required features can be incorporated.

3.0 PERSONNEL PROTECTION

Appropriate protective clothing should be available at any liquid sodium facility. Due to thick, caustic smoke and the possibility of sodium skin contact, it is inadvisable to perform any rescue or fire fighting duties without protective gear. For the purpose of defining adequate protective clothing, power plant personnel can be separated into three general categories - exposed operators, potentially exposed operators, and unexposed operators. Exposed operators would be those participating in fire fighting, rescue, or sodium disposal operations following a sodium leak or accident. Potentially exposed operators would be those working on the tower in the solar receiver area. In most cases, potentially exposed operators will not actually come in contact with liquid sodium. Nevertheless, they will be working in an area with many valves so the probability of a leak will be higher than normal, and they will be in an enclosed tower so rapid escape will not be possible. Unexposed operators would be those in no real danger of contact with liquid sodium, primarily those operators working at ground level in the control room, heliostat, or steam generator and turbine/pump areas. Unlike tower workers, unexposed operators will have rapid escape routes available to them in case of a sodium accident.

Exposed operators shall wear complete protective clothing at all times. The protective clothing provided will permit the operators to perform their duties but will afford adequate protection against injury. Protection for exposed operators should include:

Eye protection - Snug fitting, cup type safety goggles are required. Non-flammable, full-length face shields also shall be worn in addition to goggles (but not in place of goggles). A face shield alone is insufficient because liquid sodium may splash under it and caustic mists in the air can penetrate any non-sealed barriers.

Head protection - A phenolic resin hard hat is preferred. Hard hats made of reactive materials, aluminum, or asbestos shall not be used. Fire protection hoods covering the entire head and shoulders are available, and are recommended for fire fighting and rescue. These hoods normally include a safety hat.

Foot protection - Leather shoes with chrome leather leggings shall be worn. Care should be taken that leggings are

tight and do not creep up the leg. Otherwise, splashed sodium may enter the top of the shoe and result in severe foot burns.

Body protection - All protective clothing shall have full-length sleeves and trousers. Especially recommended are flameproof coveralls with no cuffs, pockets, or other potential traps for splashed sodium. All clothing shall have snaps for rapid removal in case of accident.

As an option, fire fighting suits designed especially for liquid sodium may be substituted for flameproof coveralls. A number of protective suits are available, but one of the best was developed by the Hanford Engineering Development Laboratory (Ballif, 1979). The Hanford suit has separate pants and torso sections, as well as a head piece with a self-contained breathing device. The suit material consists of one-mil-thick annealed nickel foil to prevent the penetration of the liquid sodium. Fiber glass cloth was added for strength, and a layer of ceramic fiber insulation was added to protect the wearer from heat. The suit was designed for use only by trained fire fighters because it utilizes a self-contained breathing device and because its weight (60 pounds, including the breathing system) requires the wearer to be in good physical condition.

Gloves - PVC or chrome leather gloves are recommended; if these are unavailable, then flame retardant cotton or heavy moleskin are acceptable. Wool, leather, and asbestos gloves shall not be used. All gloves should be loose-fitting for easy removal if splashed. Gloves with elastic around the tops are unacceptable.

Respiratory protection - Exposed workers who are participating in sodium transfer operations and who are not directly exposed to sodium smoke need not wear full respiratory protection. However, each such worker should carry on his person a half-face mask with high efficiency filter for escape use in emergencies. This device should be used only as an escape mask and not as protection for fire fighting or work in sodium aerosols. For fire fighting, a self-contained breathing apparatus with full face piece is recommended; this apparatus can be designed into a complete protective suit as discussed above if desired. The self-contained breathing apparatus is superior to the half-face filter mask because it affords protection from any concentration of smoke, and it may be used in low levels of oxygen.

Potentially exposed operators shall wear goggles, face shield, hard hat, leather shoes (without leggings), and flameproof coveralls. Self-contained breathing apparatus need not be used, but a half-face filter mask should be carried for escape use in emergencies. Unexposed operators should not be required to wear special sodium protective clothing, although it is assumed that they will have hard hats, safety glasses, and leather shoes as one would expect at any industrial facility.

Full protective gear as described for exposed operators shall be available on-site for emergency use in rescue, fire fighting, or escape. Emergency protective clothing shall be stored within the immediate plant area but sufficiently removed from the sodium loop that a fire would not prevent access to the gear. One or more sets of protective clothing shall be stored in the control room, since this will be a protected area. As shown in the accompanying blueprint, protective clothing shall also be placed along principal foot traffic and escape routes, one set near the steam generators and one near the base of the tower. One set shall also be placed in the tower, preferably at the 417 foot level (near the midpoint). This set of clothing could be used by an operator who was in the tower when a leak occurred.

4.0 CONTROL EQUIPMENT

4.1 SPILL CONTAINMENT

There are two stages in controlling a spill once a leak is discovered - the first stage is to drain the leaking system component, and the second is to contain, extinguish, and clean up the sodium once it has leaked out. A properly designed plant will incorporate both of these safety features.

The concept of system drainage is quite simple and straightforward. Each component of the sodium loop (e.g., receiver tower, steam generator, etc.) should be designed so that it can be drained of liquid sodium within several minutes if a leak is discovered. An underground drainage sump should be provided to allow drainage by gravity flow. The drain lines must be maintained at a temperature above the melting point of sodium (208°F) to ensure fluidity at all times.

Leakage in one of the thermal storage tanks would require transfer of the liquid sodium to the other tank. The Carrizo Plain plant is designed so that a tank-to-tank transfer could be completed in one hour. This design should be sufficient to mitigate all but the most catastrophic leaks. It should be noted, however, that simultaneous serious damage to both tanks would leave the system without a drainage reservoir and could result in a major sodium spill.

If the sodium loop develops a leak, it is expected that some sodium will leak out before the system can be drained. It is essential that containment vessels be designed to control the leaking sodium and protect nearby personnel and equipment. It is especially important to avoid sodium contact with electrical wiring, water (including moist soil), and concrete. Burning sodium on a concrete floor can cause the concrete to spall and scatter sodium over a wide area. Sodium can react violently with both the concrete chemicals themselves and with the residual moisture in the concrete.

Metal drip pans are recommended to protect concrete and electrical wiring from sodium spills. The pan should be designed to contain approximately 150% of the expected maximum volume of the leak,

allowing for expansion of the sodium as it burns. The Carrizo Plain receiver tower has been designed with a large metal pan (actually a flooring) below the solar receiver and above the cable spreading room, separating the sodium loop from the electrical wiring area. The volume of this pan is approximately 7000 gallons. Since the entire tower can be drained of sodium in less than two minutes, this pan should be sufficient to contain any sodium that may leak out before drainage is complete. In fact, it might be wise to include shallow partitions in the floor (similar to speed bumps) to confine the surface area of small leaks and thus make fire fighting and cleanup easier. Leak-prone system components at ground level as well as in the tower shall also be provided with drip pans or metal-lined pits; this will include all valves, steam generators, and pumps. Since the various portions of the system can be drained within minutes, pans of approximately 100 gallon volume should be sufficient. These pans should be adequately drained to prevent accumulation of rainwater.

Containment of leaks from the thermal storage tanks involves slightly different problems. Each tank is designed with a surrounding berm which can contain approximately 12,000 gallons. Total system volume is 470,000 gallons of sodium, so the berm cannot contain all of the sodium in the tank. However, the berm could contain a 200 gallon per minute leak for one hour, which is the time required to drain one tank to the other. Since 200 gallons per minute is a very large leak, the designed berm volume should be sufficient.

Construction material for the berm is an important consideration. Concrete and untreated earth should not be used because excess moisture in the material could react with spilled sodium (Gaylord, 1983). Concrete lined with metal would be acceptable, but would also be quite expensive and might be considered "over-designed" for a plant in routine operation. Two alternatives seem acceptable. One would be a dirt berm lined with gunite or ferrocement. These materials contain very little water when cured, and they readily shed water. An adequate drainage system would be required so that no standing water would remain following a rainstorm. The second alternative would be a treated or modified earth berm. Porous earthen materials would be required to leach moisture down and away from the surface of the berm so that spilled sodium would not come in contact with water in moist soil. Extensive leaching of sodium would not be expected since sodium solidifies as it cools.

4.2 ISOLATION AND SHIELDING

For a low pressure sodium system such as the Carrizo Plain plant, equipment failure should not result in dispersion of burning sodium beyond the immediate area of the system and its drip pan. One would not expect to see high pressure jets of burning sodium endangering operating personnel, equipment, and buildings over a wide area. Thus, the thermal insulation should afford adequate shielding for most system components. If any parts of the sodium loop are not adequately insulated (valves, for example), then a simple metal shield can be provided to deflect any leaking sodium into the drip pan.

Equipment failure in the steam generator area could result in a violent reaction between high pressure water and sodium in the coolant loop. Burst diaphragms shall be designed into the system to eliminate the possibility of excessive pressure buildup in the sodium loop. If this is not done, then the steam generators shall be isolated from personnel and other equipment by blast walls to withstand a possible explosion.

4.3 VENTING AND VENTILATION

Since most of the sodium loop at the Carrizo Plant will be outdoors, an elaborate fan and ventilation system will not be required. The control room shall be adequately sealed and ventilated so that smoke will not collect in the room and endanger plant operating personnel during a sodium leak. The only enclosed area which will be directly subject to sodium leaks is the receiver area on the tower. An adequate ventilation system will be required on the tower to disperse sodium smoke and to protect workers in case of a leak.

Ventilation of an enclosed sodium operating area is required when a sodium fire occurs since burning sodium evolves large quantities of dense white smoke, reducing visibility and seriously hampering fire fighting and rescue operations. Mouth, throat, lung, and eye protection are afforded by protective equipment, but the density of the smoke where inadequate ventilation exists is such that little activity is possible due to lack of visibility. Exhaust fans should be located at the highest elevations in the area, with provision made for air supply at floor level. Louvers at various levels in the enclosed receiver tower may be necessary if floor ventilation alone proves to be inadequate. All ventilation equipment should be operated by power that will not be affected by a sodium leak.

Several portable fans should be stored in the control room for emergency use. These can be used to clear smoke from the control room, or they can be taken out to ventilate the area around the fire in order to make fire suppression easier. They should not be directed at the fire, however, because they will add to the flow of oxygen over the fire and increase its intensity.

4.4 AUTOMATIC ISOLATION

The sodium loop should be designed so that all or part of the electrical system and the sodium plumbing system can be easily isolated or shut down in case of emergency. There should be shutoff valves throughout the sodium loop to allow isolation and draining of specific sections of the loop if leaks are discovered. This design will promote worker safety and will also limit equipment loss in case of a leak.

System shutoff would normally be tied into the central power plant control room. Procedures should be developed to disable any or all valves and pumps in the loop, and to shut off electrical power as necessary. Separate shutoff and isolation procedures should be developed for the various sections of the loop, but there should also be a total system scram to allow the operator to quickly initiate shutdown of the entire power plant if rapid evacuation is necessary in an emergency. Written procedures and plans should be prepared for all nonroutine and emergency activities, and copies of the procedures should be prominently posted in the control room. All plant personnel should be trained in the emergency shutoff procedures, and emergency dry runs should be implemented.

5.0 SAFETY EQUIPMENT

5.1 LEAK DETECTORS

Automated leak detectors are recommended in liquid sodium systems for two principal reasons. First, certain sections of the plant may not be routinely staffed by operating personnel, so the smoke from a burning sodium leak may not be seen for some time. Second, some small but potentially dangerous leaks may not produce visible effects, whereas they may be detectable by sufficiently sensitive monitoring devices. This is especially true in well-insulated systems, where seepage leaks may be evident to the human eye only after many hours of operation.

Leak detectors for liquid sodium systems may be separated into two general classes - monitors within the sodium loop itself, and ambient air monitors (e.g., smoke or heat detectors) in the vicinity of the sodium loop. Monitors within the loop are especially important for detecting leaks in the steam generators, which may lead to the formation of hydrogen. An adequately sensitive detector for hydrogen in sodium makes use of a metal membrane such as nickel or palladium which is permeable to hydrogen but leak tight to sodium. A reference hydrogen concentration threshold in sodium must be established, however, since there will always be some hydrogen present in the sodium loop.

A number of ambient air sodium leak detectors are available. Some monitor smoke or vapor, some monitor heat, and others monitor the leaking liquid sodium itself. Several of the more common detection devices are listed in Table 5-1 (Ballif, 1979). Selection of a device is dependent upon the needs of a particular application, so the leak detection system must be designed on a case-by-case basis. Two or more types of leak detectors (e.g., heat and smoke) should be interspersed throughout the plant so that if one type of detector fails to detect a leak, the other type will.

Spacing and placement of leak detectors is also dependent upon the specific requirements of the power plant, although the NFPA fire code makes some suggestions in this area. In general, leak detectors should be placed in the vicinity of leak-prone

Table 5-1. TYPES OF SODIUM LEAK DETECTORS

| Type of Emission Detected | Type Detector | Sensitivity | Comments |
|---|---|---|---|
| Liquid Sodium | Pair of electrodes (i.e., "spark plug") | 160 g/hr | Widely used in USA and in Europe |
| | Pair of Wires Serving as Electrodes | Comparable to spark plug | Used by Dutch and French |
| Sodium Vapor | Absorption of Specific Frequencies of Light | 75×10^{-6} g/m ³ | No test data under bench test conditions |
| (Emitted from non-Flowing Leaks) | Flame Photometry | 1 ppb | Requires piping of samples to chemical analysis room |
| | Chemical Method (color indication phenolphthalein or thymol blue) | 2.3×10^{-4} g/m ³ | Final analysis performed in laboratory |
| | pH Method | 1 ppb | Commercial pH meters available. Method suitable for on-line use |
| | Conductivity Method | 1 ppb | Commercial meters available. Method suitable for on-line use. |
| Sodium Vapor-Sodium Oxide Mixture | Plugging Type Flowmeter | "As Responsive as any meter" | Sensitive to false alarms |
| | Filter Type Flowmeter | Probably better than plugging type | No test data. Sensitive to false alarms. |
| Smoke Detection | Various Methods (ionization, photo electric, laser beam) | Variable-Limit 1.5×10^{-3} g/l | Methods have been applied to sodium systems |
| Hydrogen (from Na reaction with H ₂ O) | Hydrogen Detector | Above 1.5 g/hr | Tested successfully |
| Heat | Infrared Detector | Not Avail. | Uses on-line light sensors |

components (e.g., valves), and especially in enclosed areas where sodium smoke could be very hazardous to employees, such as in the receiver tower. A smoke trap should be placed above any smoke detector which is not mounted directly to the ceiling; an 18 inch diameter disk (similar to a pie pan) is recommended. Smoke traps help to ensure that buoyant plumes will not go undetected. During the planning and construction of the power plant, it is recommended that smoke generators be used to aid in the placement of smoke detectors. If the smoke generator is placed near the probable leak points, then the dispersion of the smoke can be observed and the detectors can be placed where necessary on the wall, ceiling, and/or floor. Such field testing can often make the difference between success and failure of a detection system.

For the Carrizo Plain plant, leak detectors shall be placed near each pump, steam generator, and valve, both at ground level and in the solar receiver tower. Smoke and heat detectors shall be placed on the ceiling of the enclosed tower area, as well as at each metal-grating floor level (these should also have smoke traps). All detectors shall be tied into an alarm system in the control room, and the detectors in the tower shall activate a warning light at the tower entrance to caution unprotected workers to stay out.

This discussion of detection devices has so far dealt only with leak detection and protection of employees within the power plant. A further consideration is atmospheric transport beyond the power plant boundaries and protection of the general public. A modeling study (Wang and Lauer, 1980; see Appendix B) has shown that, for a typical leak, sodium hydroxide will be deposited out to about 300 meters of the release point, with particulate matter beyond that distance being deposited as sodium carbonate, an innocuous substance. The plant boundary is less than 300 meters from the sodium loop on the south side, so there is a potential sodium hydroxide impact beyond the fence. The recommended NIOSH exposure limit for sodium hydroxide is 2 mg/m^3 of air for any 15-minute sampling period, and it is likely that this level would be exceeded during a significant sodium leak. However, there are no real-time monitoring methods for sodium hydroxide. It is monitored by collecting filter samples and analyzing them in a laboratory, so any sodium leaks would be contained long before the laboratory results were returned. Thus, there is no public safety advantage to be gained by monitoring for sodium hydroxide. Any sodium leaks which might endanger public safety should be adequately monitored by leak detectors within the plant boundaries. It shall be the responsibility of plant operating personnel to notify local law enforcement officials if evacuation of areas outside the plant boundaries appears to be necessary. A pre-planning session should be held with local officials to develop an evacuation plan.


5.2 FIRE EXTINGUISHERS

A sodium fire is generally extinguished by the removal of oxygen and cooling of the sodium below the melting point. Extinguishing agents normally used in conventional firefighting must not be applied to sodium fires because of the violent reaction of sodium with such common extinguishing materials as water, halon 1211, and sodium bicarbonate. Placement of these extinguishing agents in the vicinity of the sodium loop should be avoided if possible.


The required extinguishing agent for sodium fires is Na-X powder. Na-X is composed of sodium carbonate, stearates, attaclay for flow characteristics, and nylon. Ansul developed this agent of low chloride (less than 0.03%) to control the rapid rate of stress corrosion on austenitic stainless steel at elevated temperatures. Na-X will extinguish sodium fires at temperatures up to 1400°F. It is available in 30 lb, 150 lb, and 350 lb extinguishers, in 2000 or 3000 lb skid-mounted trailers, or in bulk to be applied by scoop or shovel. Yellow has been adopted as the standard color for sodium fire extinguishers, and all containers for Na-X should be painted this color for easy identification. Any buckets containing Na-X should be labeled and numbered just like any other fire extinguisher. Dry sodium carbonate shall not be used for fire fighting, although it may be used to separate layers of non-burning sodium in cleanup operations.

The amount of Na-X required to extinguish a fire depends upon the surface area of the burning sodium. Concentrations of burning sodium of 1/2 inch in depth or less will take 6 lbs of extinguishing agent per square foot, and depths greater than 1/2 inch will require 10 lbs per square foot for extinguishment (Rocketdyne, 1976). The Na-X powder should be applied first in a thin layer since it tends to fuse and form a crust over the burning sodium. Additional layers should then be added to further blanket the fire.

As shown in Figures 1 and 2, Na-X fire extinguishers shall be located near the sodium pumps and steam generators, on elevated walkways in the vicinity of all valves, near the sodium storage tanks, and at all levels in the enclosed portion of the solar receiver tower. It is recommended that the Na-X available for initial application to a sodium fire be supplied in 30 lb extinguishers since they are light and easy to handle in an emergency. Additional Na-X may be stored in covered drums or buckets (scoops or shovels should be provided) or in 150 lb or larger extinguishers stored at the facility. Note that 30 lb extinguishers from adjacent plant areas can be consolidated to extinguish a sodium fire.



- SHOWER & EYE WASH
- ▲ PROTECTIVE CLOTHING
- DRIP PANS
- ⊕ FIRE EXTINGUISHER



PACIFIC GAS AND ELECTRIC COMPANY
SOLAR CENTRAL RECEIVER
POWER PLANT
CARRIZO PLAINS - UNIT 1
FORM 723-P-1 NEW 10-62

| | | | | | | | |
|-------------|--|-------------|--|-----------------------|--|--|--|
| | | | | DR BY L TUEGEL 2-1963 | | Rockwell International Corporation Energy Systems Group | |
| | | | | CHK BY | | CARRIZO PLAINS POWER PLANT - PIPING LAYOUT | |
| | | | | MAP | | PLAN VIEW | |
| | | | | STRESS | | SIZE E FIGURE 1: STEAM GENERATOR AREA SAFETY EQUIPMENT | |
| APPLICATION | | EFFECTIVITY | | SCALE 3/16" = 1' | | SHEET | |

The total amount of Na-X required will be dependent upon the surface area of the burning sodium, and may be minimized by including partitions in the drip pans and berms. The floor area in the receiver tower, for example, is approximately 900 square feet, which would require 5400 lbs of Na-X at 6 lbs per square foot. If the floor were partitioned into 10 sections, however, this number could be decreased to 540 lbs, which should be sufficient to extinguish the amount of sodium that would be lost due to a leak before the tower loop could be drained (approximately two minutes).

5.3 SAFETY SHOWERS AND EYE WASHES

A person who has been splashed with molten sodium should remove all outer clothing and flood the affected area with water as quickly as possible. Safety showers should be located in the vicinity of the sodium loop, yet far enough away that there is no possibility of the shower area being involved in a sodium spill. Two safety showers shall be installed at the Carrizo Plain plant along principal foot traffic and escape routes, one near the steam generators and one near the base of the tower; both are marked on Figure 1. The showers shall be shielded on the sodium loop side to avoid sodium/water contact, and shall be drained below plant level so that water will not flow into the drip pans or berms. Safety showers shall be of the quick opening type which provide a large volume of water since it is essential that any sodium remaining on the body be removed as quickly as possible because of the reaction which occurs when water contacts sodium.

A standard eye fountain shall be provided in the vicinity of each safety shower for washing eyes with clean, low pressure water. High pressure water is not recommended because excessive washing with a high pressure stream can cause permanent damage to the eyes.

6.0 EMERGENCY OPERATING PROCEDURES

6.1 FIRE FIGHTING

Burning sodium gives off large quantities of opaque, white smoke making visibility very poor. No flame is visible - only a glowing mass of sodium. Sodium fires are not generally difficult to control and extinguish, provided that smoke does not mask the location of the fire, and that proper techniques are used. Complete protective clothing and breathing apparatus shall be worn by all fire fighters. It is important that fire fighters practice controlling sodium fires, since the materials and techniques involved are unusual. All plant personnel shall be trained in fighting sodium fires.

Complete coverage of the burning area with Na-X is essential if the fire is to be extinguished. When heated, Na-X fuses to form a crust which excludes air from the burning sodium. Until this crust is formed, the fire can be controlled but not extinguished. Formation of this crust is best accomplished by careful application of the material in several shallow layers rather than one deep layer to prevent disturbing the burning material. Intermittent dusting of the surface increases the rapidity of crust formation and fire extinction since there is less tendency for the powder to sink in the sodium. Sodium fires on vertical or irregular surfaces pose a problem because of the difficulty of applying extinguishing powder and making it stick.

Na-X should be applied carefully to prevent splashing of the burning metal. Since no volatile combustibles are evolved from sodium fires, there will be no flame but merely a glowing mass of burning sodium. If the material is contained in a berm or metal drip pan, it will burn quietly and may be approached with little danger to fire fighting personnel. A sodium fire in itself is not particularly hazardous; the secondary reactions with other materials increase the hazard. In case of a sodium fire on a concrete floor, the concrete will become overheated, spall, and throw burning sodium over a wide area, spreading the danger and damage far beyond the normal scope of the fire. Fire fighting and/or rescue work under such conditions can be quite hazardous, whereas provision of a metal pan to confine possible sodium spills would reduce the hazard and permit effective fire fighting.

The following rules should be followed to ensure prompt action, prevent spread of the fire, and effect its prompt extinction:

1. Make certain that proper and adequate respiratory protection and fire fighting materials are available for instant use, and that plant personnel have been trained in fire fighting techniques.
2. Remove as much of the potential fire hazard as possible by draining the remaining sodium from the involved components.
3. Apply a blanket of Na-X to exclude oxygen and extinguish the fire; use caution to avoid splashing.
4. Clean up and dispose of all remaining sodium immediately. It will absorb water from the air and make cleanup hazardous if allowed to stand. Dry sodium carbonate may be used to separate layers of waste sodium.

6.2 FIRST AID

Sodium will destroy tissue as a result of thermal and/or chemical reaction with the moisture in tissue. Both reactions occur simultaneously as a result of (1) heat from hot or burning sodium, and (2) the formation of sodium hydroxide with body fluids.

Personnel splashed with molten sodium should remove all outer clothing and wash the affected area in a safety shower. Immediate flushing is recommended to wash off gross sodium contamination, extinguish any fire, and cool tissues, and to quickly react the sodium that may be clinging to the skin so as to reduce the sodium hydroxide reaction with body fluids. The recommended first aid is cold water or iced sterile compresses over the affected area. The services of an emergency hospital and physician should be obtained.

Even if eye protection is worn, minute particles of sodium and sodium hydroxide may enter the eye during a sodium release. Water flushing is recommended and the services of an ophthalmologist should be obtained immediately. Treatment of sodium eye injuries with boric acid and/or mineral oil or other types of eye medication has been discouraged. These materials are difficult to remove from the eye and interfere with evaluation of the extent of the injury.

Persons wearing contact lenses shall not be allowed to work with sodium systems regardless of the type of eye protection used. Loss of a contact lens in an emergency situation, rotation of the lens behind the eyeball, and/or the reaction of sodium with plastics used in contact lenses may result in more serious injury. A minute particle of sodium worked under a contact lens will produce a much more aggravated injury than the reaction with tears and water flushing. Ordinary eyeglasses with plastic lenses shall also be forbidden around sodium systems. Only approved safety glasses shall be worn.

The effects on the mouth, throat, and lungs will be mainly those of the reaction of the oxides into hydroxides and the resultant caustic burn to sensitive mucous tissues. Immediate use of the safety shower, eye wash station, drinking fountain or other sources of water is recommended. Complaints of soreness in the mouth, throat, and lungs should be noted and the services of a physician, preferably an otolaryngologist, should be obtained immediately.

6.3 EMERGENCY EVACUATION

The power plant facility should be provided with an area or areas from which personnel can remotely control, monitor, and observe operations to maintain the plant in a safe operating status at all times. This area should be sufficiently isolated or provided with adequate protection to permit occupancy and access under accident conditions. For example, if leaks occur, the operators must be able to control pumps, isolation valves, drain systems, and ventilation systems without danger of injury or exposure to hazardous materials. Consideration should be given to protection against missile and blast hazards, heat hazards, and contamination and inhalation hazards which may occur in the facility as a result of sodium fires. It is expected that the power plant control room will satisfy these protection criteria.

Escape routes and exits should be preplanned and provided in the design of the power plant. There should be secondary exits available in case the primary exit routes are blocked. The plant safety system shall include an audible evacuation alarm which will be activated by the smoke or heat alarm system, but which can also be activated manually if necessary. At the sound of the alarm, plant employees shall proceed to one of several designated evacuation areas, avoiding those that are downwind of the sodium fire. Personnel protective equipment shall be available at convenient locations throughout the plant, as shown on the accompanying blueprint. In particular, half-face filter masks

should be available so that all employees can escape from the sodium smoke cloud without respiratory damage. The small size and low cost of this type of respirator make it desirable to be carried on the person of every worker in the facility.

Protective gear for fire fighting should be available at a central location such as the control room. Only those individuals trained in fire fighting techniques and wearing complete fire fighting gear shall be allowed in the vicinity of a sodium fire; all others should be evacuated to a safe location. It is recommended that evacuation drills be conducted on a periodic basis.

Due to the low frequency of occurrence of sodium fires, the low population density in the Carrizo Plain area, and the expected limited range of sodium hydroxide impact (less than 1 kilometer), it is not anticipated that evacuation of nearby communities will be necessary. The worst case public impact that would reasonably be expected would be a sodium hydroxide cloud drifting across the state highway adjacent to the power plant. Local fire fighting and law enforcement officials shall be contacted to develop a contingency plan for stopping traffic on the highway if smoke from a sodium fire becomes a hazard. The details of this plan shall be worked out in a pre-planning session with local officials before plant operation begins.

7.0 SPILL COUNTERMEASURES

7.1 DISPOSAL OF WASTE SODIUM

As soon as possible after a sodium spill occurs, the remaining sodium or sodium residue should be shoveled into a dry metal container with a lid to exclude oxygen. To assure safe disposal, the sodium or residue should then be converted to a non-reactive form prior to final disposal. This is necessary to avoid the possibility of subsequent chemical reactions which could injure waste handling personnel or the public (e.g., burns, fires, or hydrogen explosion). Conversion to a less reactive form may be performed by burning or reacting the sodium or residue with water, steam, or other chemical compounds under controlled conditions.

Small amounts of sodium (gram batches) can be conveniently disposed of by burning in a heavy metal disk under a hood or in a well-ventilated outdoor area, using a gas flame. The residues may be disposed of by flushing with water to normal waste systems. Small amounts may also be disposed of by reacting with alcohol in a pan with proper ventilation. The mixture may then be disposed of as normal industrial waste.

Larger amounts of sodium (e.g., 1 pound batches) may be burned in large shallow pans if controlled, isolated, or remote areas are available. The sodium should be spread out and then sprayed with a fog nozzle. Sufficient ventilation must be available to prevent potential hazards from hydrogen buildup and to protect operating personnel.

Disposal of bulk amounts of waste sodium will probably not be feasible at the Carrizo Plain site. In the event of a major spill, the waste material should be placed in covered containers and should be transported to an approved waste disposal facility as soon as possible. Proper transportation and disposal of large amounts of liquid sodium can be performed by a private contractor or perhaps by the Rockwell liquid metals group at the Santa Susana Field Laboratory.

If bulk waste disposal is required, the waste sodium must be safely stored while awaiting removal from the facility. The covered, sealed metal containers should be stored in a dry,

fireproof building. The containers should be stored slightly above floor level (e.g., on pallets) to prevent contact with metal which might leak from another container. The storage area must be kept free from highly combustible materials or from materials which may react with sodium. The area should have sufficient air circulation to prevent accumulation of hydrogen.

7.2 CLEANING CONTAMINATED EQUIPMENT

If equipment is contaminated with sodium and needs to be cleaned, it should be moved to a decontamination area. If the equipment contains more than just surface contamination (e.g., solid sodium), the excess should be removed by chipping or scraping off the material. If the contaminant is not accessible, hot oil baths or controlled heating may be used to melt out the material. Decontamination of the equipment may then be accomplished by burning, or by treating with dry steam or with alcohol. A steam hood or steam cabinet is useful for this operation. Water sprays or immersion may be used to remove surface films. Once the item is free of significant sodium it can be placed back into service, shipped out for repair, or disposed of by normal methods.

7.3 HAZARDOUS WASTE PERMITS

Sodium is a hazardous substance and thus should not be disposed of without the appropriate permits. Before disposal operations begin, the power plant operators should contact state and local authorities to acquire disposal permits which will account for the waste sodium. It is important to note that even if disposal is performed by a commercial contractor, the plant itself is still legally responsible for the waste sodium. Therefore, it is critical that a reputable contractor be chosen and that all shipping and disposal documents are complete. A copy of the shipping manifest should be retained by the power plant operator.

8.0 REFERENCES

- Allen, P., San Luis Obsipo County Air Pollution Control District, personal communication, 1983.
- Baldrige, R., San Luis Obsipo County Water Pollution Control District, personal communication, 1983.
- Ballif, J.L., "Liquid Metals Fire Control Engineering Handbook," Hanford Engineering Development Laboratory Report # HEDL-TME-79-17, February 1979.
- Eisen, J., CALOSHA, personal communication, 1983.
- Gaylord, G.G., Rockwell International, personal communication, 1983.
- Hamm, J., San Luis Obispo County Planning Department, personal communication, 1983.
- Jackson, C.B., "Liquid Metals Handbook: Sodium (NaK) Supplement, Third Edition," U.S. Atomic Energy Commission, 1955.
- Rocketdyne Division, Rockwell International, "Protective Services Basic Training Course: Fire Extinguishment," February 1976.
- Wang, I.T., and Lauer, G., "A Mathematical Model for the Fallout of Particulate Matter and Its Application to the Combustion of Sodium Aerosols," Rockwell International Environmental Monitoring & Services Center Report, June 1980.

Appendix A

LIQUID SODIUM SAFETY HISTORY

Liquid sodium heat transfer systems have been used in component testing and routine operation for approximately 20 years. During this time, significant leaks (i.e., more than seepage of trace amounts) have been extremely rare, and most of the recorded leaks have been only a few gallons or less. Leaks are so rare that there appear to be no statistical evaluations of leak rates (leaks per hundred hours of operation, for example). Instead, leaks are reported as individual events since there are so few of them.

Table 1 presents a summary of all known Sodium Spill Unusual Occurrence Reports (UORs) in the United States during a five year period from 1977 to 1982 (Peterson, 1983). Only 21 spills occurred during the entire period, and the largest reported magnitude was approximately five gallons; many were less than one gallon. Furthermore, many of the reported leaks were in test facilities, which would be expected to have higher leakage probabilities than a fully tested, routinely operating plant such as the Carrizo Plain solar facility.

Similar rare leak occurrences have been reported in French sodium systems (DOE, 1982). During the past 15 years there have been approximately 70 reported sodium spills at five separate installations in France. The leaks observed were all considered minor leaks since the amounts of sodium spilled did not exceed several kilograms, with average leakage rates of only several liters per day. The development of the leakage rate was always slow.

The Rockwell International Energy Technology Engineering Center (ETEC) has been testing sodium components approximately full time for over 20 years. During that time, they have had six reportable spills, the largest of which was approximately 20 gallons (DeBear, 1983). Three of these six spills were due to heater failure, which will not be a factor at Carrizo Plain since the heating will come from the solar receiver.

REFERENCES - APPENDIX A

DeBear, W.S., Rockwell International, personal communication,

1983.

DOE Report, "Service for Sodium-Cooled Reactor Technology:
Fast Neutron Line," #DOE/CEA/BMFT--87, 1982.

Peterson, E.V., "SCTI Fire Suppression System Study for
Economizer Building," Rockwell International ETEC Report
#355-XR-0009, 1983.

Table 1. Summary of Sodium Spill Unusual Occurrence Reports
US Experience

| Item | Component | Description of Incident | Quantity of Sodium Leaked | Detection | Date | Documentation |
|------|---|--|---------------------------|------------------------|---------------------|---------------------------|
| 1 | Source Term Control Loop #4 (STCL-4) (Hanford Engineering Development Laboratory) | The loop was being brought up to temperature after a routine shutdown when abnormalities were noticed in the cover gas pressure, surge tank level, and temperature. Visual inspection located the leak. Subsequent investigation determined that the leak was due to poor sealing at a Greyloc flange. The seal was a reused one that had previously been used several times at temperatures above its upper design limit and had undergone permanent plastic deformation. | Less than 1/2 lb | Visual | 01/24/77 1430 hr | UOR 3-77 (HEDL) |
| 2 | LMEC 6-inch Drag Valve (in SCTL) | Sodium leaked between the seal ring and the valve body seal face because the operating pressure (200 psi) was insufficient to effect a tight seal (valve was designed for steam service at 1500 psi). | Given as small | Fire alarm in high bay | 10/02/77 0258 hr | UOR SCTL-77-3 (LMEC) |
| 3 | Mechanical Property System #3 (MPS-3) (Westinghouse) | A trace heater failed and shorted to a tube wall, causing the sodium leakage. The tube was Type 316 SS with 0.500-in. OD x 0.049-in. wall. | Given as small | Visual | 11/21/77 0330 hr | UOR 77-07 (WARD) |
| 4 | Sodium Sample Station (SCTL) | A vent valve (V-10G) on the sodium sample station was left open. Closure of the valve stopped the leak. | Approx. 1 lb | Visual | 08/11/78 1932 hr | UOR ETEC-78-09 SCTL-78-01 |
| 5 | Vapor Trap VT-3 Vent System (SCTI) | A defective level indicator allowed T-3 to be overfilled with sodium and the sodium leaked across the vent valve ORV-710B2. | Approx. 5 gal | Visual | 08/25/78 2303 hr | UOR ETEC 78-10 |
| 6 | AI Advanced Pump (SCTL) | A wisp of smoke was noticed by an operator. Investigation revealed a small sodium leak at the north pump flange. Evaluation of the leak determined that it was due to leakage of the cover gas which allowed the sodium to rise to the level of the flange. | Approx. 2 pints | Visual | 09/02/78 0835 hr | UOR ETEC 78-11 SCTL 78-02 |

Table 1. Summary of Sodium Spill Unusual Occurrence Reports
US Experience

| Item | Component | Description of Incident | Quantity of Sodium Leaked | Detection | Date | Documentation |
|------|---|--|---------------------------|---------------------------------------|---------------------|----------------------------------|
| 7 | Return Mixing Tee - SSGM Double Wall S/G Test (Westinghouse Advanced Reactors Div.) | The sodium leaked through a crack adjacent to the pipe-to-tee weld in the vertical discharge line from the tee. The crack was circumferential in nature and had progressed approximately 90° around the circumference of the pipe. | Not given. | Visual | 02/23/77 1600 hr | UOR 77-02 (WARD) |
| 8 | Rupture Disc Assembly - Auxiliary Loops A&B (Westinghouse Advanced Reactors Div.) | A thermocouple downstream of the rupture disc assembly was being removed. The system was non-operational and drained. During the thermocouple/Swagelok assembly removal, sodium was released. The presence of sodium was unexpected. The sodium was released by the 10 psig-to-atmosphere pressure differential. | Approx. 1 to 5 lb | Inadvertent release by test personnel | 10/24/78 1400 hr | UOR WARD-78-06 GPL2-78-2 |
| 9 | ISSS-ACA Test Item | An argon vent line was plugged (later it was hypothesized that the plug was sodium). The line was opened to inspect the vent valve. When this was done, sodium was sprayed out of the line until ambient pressure was attained. | 1 lb | Inadvertent release by personnel | 01/03/79 1403 hr | UOR ETEC-79-01 T032-79-01 |
| 10 | Tubing at MPS-3, Small Sodium Loop (Westinghouse Advanced Reactors Div.) | During preheat of the system (prior to sodium fill), a heater was left on longer than procedure dictated. The tubing overheated and residual sodium leaked out and burned. | Small (residual sodium) | Not reported; implied visual | 04/05/79 0945 hr | UOR WARD-79-01 MPS/3-79-01 |
| 11 | L-5 Leak Detector (SCTL) | L-5 was flooded (no reason given) and sodium leaked from the upper flange. | Not given | Visual | 03/14/79 0412 hr | UOR ETEC-79-05 SCTL-79-03 |

Table 1. Summary of Sodium Spill Unusual Occurrence Reports
US Experience

| Item | Component | Description of Incident | Quantity of Sodium Leaked | Detection | Date | Documentation |
|------|--|--|---------------------------|--|---------------------|----------------------------------|
| 12 | Rig 1 - Sodium Sample Station #1 | A sample station extension tube (0.5-in. OD SS tubing) ruptured, causing the leak. Investigation revealed that the tube was crimped where ruptured, thus weakening the tube. | 1 pint | Bldg 032 control room audio fire alarm | 12/13/79 1545 hr | UOR ETEC-79-28 032-79-05 |
| 13 | Cold Trap at MPS-3 Sodium Loop (Westinghouse Advanced Reactors Div.) | Attachment of a flowmeter lead to 1/2-in. tubing melted through the tubing wall at the weld and the weld cover gas caused a "blow-out" at this location. | Less than 30 grams | Visual and fire alarm | 05/05/80 1430 hr | UOR WARD-80-03 |
| 14 | GPL-1 and GPL-1A Loops in Thermal Stripping Test Facility (TSTF) (Westinghouse Advanced Reactors Div.) | The nozzle design caused sodium splashing which plugged the cover gas line; this plugging reduced the effectiveness of the Stein seal (by reducing the pressure differential). When sodium finally contacted the Stein seal, leakage occurred. | 6 lb | Smoke Detectors | 04/12/80 1350 hr | UOR WARD-80-02 TSTF-80-02 |
| 15 | Dump Valve in Sodium Pre-Exposure Loop (Westinghouse Advanced Reactors Div.) | The bellows on the valve failed due to fatigue cracking. | 1-2 lb | Smoke Alarm | 07/20/80 1930 hr | UOR WARD-80-04 PEL-80-01 |
| 16 | GPL-2 Electromagnetic Pump (Westinghouse Advanced Reactors Div.) | Suspected area of leak is one of the header tubes between the bottom of the pump outlet header and the top of the stator laminations. (Initial report only.) | 90 grams | Smoke Alarm | 01/24/81 1945 hr | UOR WARD-81-01 GPL/2-81-01 |

Table 1. Summary of Sodium Spill Unusual Occurrence Reports
US Experience

| Item | Component | Description of Incident | Quantity of Sodium Leaked | Detection | Date | Documentation |
|------|---|---|--|------------------------------------|---------------------|---------------------------------|
| 17 | SASS-ACA Test Article Lower Housing | Sodium residue was discovered during demolition. It is hypothesized that somehow sodium hydroxide formed during testing and initiated transgranular stress corrosion cracking, causing the leak path. | Small - pipe area covered was 1-2 in. ² | Visual | 12/09/80 0930 hr | UOR ETEC-80-21 T032-80-05 |
| 18 | Main Flow Loop (MFL) Venturi Flowmeter (SPTF) | The 1/2-in. stainless steel line to the pressure sensor had undergone intergranular attack, initiating the sodium leak. The IGA was attributed to the use of mineral fiber insulation. Similar occurrences had also been attributed to the use of mineral fiber insulation, so use of that type of insulation was discontinued. | 1-2 gallons | Doesn't say; implies visual | 05/19/81 0045 hr | UOR ETEC-81-05 SPTF-81-01 |
| 19 | H-1 Sodium Heater (SCTI) | There was extensive intergranular attack (IGA) of 304H SS tubing in both H-1 and the H-1 preheater. The corrosion initiated on the exteriors of the tubes. A definite source for the IGA was not identified. However, the tubes had been in service for over 25 years and the presence of surface contaminants was not surprising. | Not adequately defined; i.e.: H-1 - a small mound of sodium reaction products. H-1 preheater - large accumulations of sodium reaction products. | Smoke Detector SME-H-1 & visual | 09/10/80 2047 hr | UOR ETEC-80-13 SCTI-80-02 |
| 20 | GPL-1 Electromagnetic Pump (Westinghouse Advanced Reactors Div.) | A single tube on the suction side of the pump failed. Identical failures had occurred twice before at GPL-2. Severe thin-walling of the tube had been identified as the cause of the leak in the previous two incidents. It is suspected that the design imposed higher than anticipated stresses at the leak location. Design modifications were initiated to alleviate the problem. | Minimum sodium leakage | Visual | 03/17/82 1115 hr | UOR WARD-82-01 GPL1-82-01 |

Table 1. Summary of Sodium Spill Unusual Occurrence Reports
US Experience

| Item | Component | Description of Incident | Quantity of Sodium Leaked | Detection | Date | Documentation |
|------|--|---|---|-------------------------------------|---------------------|---------------------------------|
| 21 | 2-in. Header to Purification System (P/S) Pumps (SPTF) | The leak occurred at a tee in the 2-in. suction header to the P/S EM pumps. It was determined that the leaks were due to intergranular attack (IGA) of the pipe, originating on the outside surface. The initial attack was attributed to the use of mineral fiber insulation, which has caused similar problems in the past (see Item 18). | A "small sodium leak" with a "substantial buildup of sodium reaction products." | Ground Fault Interrupter (GFI) trip | 07/25/81 0124 hr | UOR ETEC-81-08 SPTF-81-03 |

NO. 079TI000007

PAGE. 42

Appendix B

MODELING STUDY

A MATHEMATICAL MODEL FOR THE FALLOUT OF
PARTICULATE MATTER AND ITS APPLICATION
TO THE COMBUSTION OF SODIUM AEROSOLS

Prepared by:

I-Tung Wang, Ph.D.
George Lauer, Ph.D.

June 1980



Rockwell International

Environmental Monitoring & Services Center
Environmental & Energy Systems Division
2421 West Hillcrest Drive
Newbury Park, CA 91320
(805) 498-6771

TABLE OF CONTENTS

| | PAGE |
|--|------|
| 1.0 INTRODUCTION | 1-1 |
| 2.0 FORMULATION. | 2-1 |
| 2.1 Equations for the Buoyant Rise of the Puff | 2-1 |
| 2.1.1 Equation of Vertical Motion | 2-1 |
| 2.1.2 Equations of Horizontal Motion. | 2-2 |
| 2.1.3 Equation of Temperature | 2-2 |
| 2.1.4 Entrainment Equations | 2-2 |
| 2.2 Dispersion and Deposition | 2-3 |
| 3.0 APPLICATION. | 3-1 |
| 3.1 Comparison with Field Data | 3-2 |
| 3.2 Five Hypothetical Scenarios. | 3-4 |
| 3.3 Chemical Composition of the Sodium Aerosols. | 3-6 |
| 4.0 ACKNOWLEDGMENTS. | 4-1 |
| 5.0 REFERENCES | 5-1 |

1.0 INTRODUCTION

This document has been prepared in response to questions concerning the potential environmental impact(s) of accidental releases of hot liquid sodium which might result from a liquid sodium cooled solar tower facility. The report addresses those impacts which could result from a set of hypothetical "credible" accidents and are based on the field work of Johnson, et.al. (1978). It is concluded that although sodium oxide will deposit in the near field (out to 300 meters of the release point), the particulate matter carried off site (beyond one kilometer) will be in the form of sodium carbonate which is innocuous in terms of environmental impact on the local ecology.

A generally useful air quality model has been developed to simulate the physical phenomena of buoyant rise, transport, dispersion, and fallout of combustion aerosol particles. It differs from the conventional steady-state plume dispersion-deposition models in several aspects:

1. use of detailed dynamic equations to describe the entrainment and buoyant rise of the contaminated air parcel or the smoke puff;
2. a travel-time-dependent Gaussian puff formulation for calculating the transport and dispersion of the puff; and
3. use of generalized terminal velocity calculations by Beard (1976) to calculate the rates of fallout of polydisperse aerosol particles.

Model predictions are compared with field data (Johnson et al., 1978) of sodium oxide deposition resulting from low-level spray releases of heated sodium particles. The predictions are based on measured sodium oxide aerosol particle size distributions. The model is also used to predict the ground-level air quality impacts and depositions under five different release conditions. In each case, a predetermined set of worst-case meteorological parameters is used as model input.

2.0 FORMULATION

2.1 Equations for the Buoyant Rise of the Puff

The mechanical and thermal properties of the rising puff are described by the following set of equations, in which O_x and R_x denote the entrainment coefficient and effective radius of the puff^x with the subscripts m and t signifying the momentum and temperature puffs respectively. E_m is the ratio of the effective momentum flux to the momentum flux within the temperature puff, i.e., $E_m = (R_m/R_t)^2$. The concept of describing the plume element in terms of the momentum, temperature, and moisture components has been discussed by Hanna (1976).

2.1.1 Equation of Vertical Motion

$$\frac{1}{2} \frac{\partial (w^2)}{\partial z} = \frac{g}{E_m} \left(\frac{T_p - T_e}{T_p} \right) - O_m \frac{w^2}{R_m} \quad (1)$$

Equation (1) is based on momentum conservation and determines the change of the vertical velocity of the puff, w , with height. The first term on the right-hand side of Equation (1) is the force per unit mass of the puff due to buoyancy, expressed in terms of the temperature of the puff, T_p , and that of the ambient air, T_e . The second term expresses the drag force per unit mass due to the entrainment of ambient air.

2.1.2 Equations of Horizontal Motion

$$\frac{\partial V_c}{\partial z} = -Q_m \frac{V_c}{R_m}, \quad (2a)$$

$$V = V_c + U. \quad (2b)$$

Equation (2a) is also derived from conservation of momentum. The buoyancy force is not present, however, leaving only the drag term on the right. V_c is the horizontal component of the puff velocity with respect to still air. It is added to the ambient wind velocity, U , to obtain the horizontal puff velocity, V , with respect to the ground, in Equation (2b).

2.1.3 Equation of Temperature

$$\frac{\partial T_p}{\partial z} = -\frac{g}{c_p} - Q_t \frac{(T_p - T_e)}{R_t}. \quad (3)$$

This equation describes the change of puff temperature with height. The first term on the right-hand side of Equation (3) expresses the temperature change due to adiabatic expansion, and the second term is the temperature change due to the entrainment of ambient air. c_p is the heat capacity of the puff at constant pressure.

2.1.4 Entrainment Equations

$$\frac{\partial R_t}{\partial z} = 0.3 - \frac{R_t}{2U} \frac{\partial U}{\partial z}, \quad (4a)$$

$$\frac{\partial R_m}{\partial z} = 1.5 \frac{\partial R_t}{\partial z}. \quad (4b)$$

In Equations (1) to (3), the entrainment coefficients are given by

$$O_t = 0.8, \quad (5a)$$

$$O_m = 1.2. \quad (5b)$$

The above dynamic equations are appropriate for buoyant puffs that do not have significant water contents. For wet puffs, the above equations can be generalized to include latent heat and cloud physics effects (see, e.g., Hanna, 1976). These puff dynamic equations are used mainly to describe the buoyant rise of the puff and its interaction with the vertical variations of ambient temperature such as inversions, if any. Vertical temperature and wind speed profiles, as well as the initial physical conditions of the puff, its temperature, size, and velocities, are required as model input.

2.2 Dispersion and Deposition

The spread of the puff is governed by the turbulent dispersive action of the atmospheric boundary layer. The turbulent motion of the air spreads the puff both vertically and horizontally to a degree determined in part by the wind profile and in part by the thermal stratification of the boundary layer. A convenient method of describing this dispersion is in terms of the Gaussian puff dispersion equations with the horizontal and vertical standard deviations determined by field data for low level releases of short durations. The best known data are those compiled by Pasquill and Gifford for three-minute sampling time (see Pasquill, 1978).

Gravitational settling of particulate matters can be modelled by incorporating the downward drift of the particles in the vertical component of the puff dispersion. Thus the puff can be visualized as an aggregate of puffs each consisting of particles of a specified size range with an average terminal velocity v_s and effective elevation $H - v_s * x / U$, H being the effective elevation of the puff had there been no downward gravitational drift. The net rate of particulate deposition (mass per unit area) is then obtained by summing over the entire particle size spectrum,

$$D(x, y) = \frac{2Q}{(2\pi)^{3/2} \sigma_H^2 \sigma_z^2} \exp\left\{-\frac{(x-Ut)^2}{2\sigma_H^2}\right\} \exp\left\{-\frac{y^2}{2\sigma_H^2}\right\} \sum_i v_s(d_i) \exp\left\{-\frac{(H-x v_s(d_i)/U)^2}{2\sigma_z^2}\right\} \cdot p(d_i), \quad (6)$$

where $p(d_i)$ is the normalized size spectrum weighting factor for size d_i . U is the wind speed at the effective puff height, and U is the mean wind speed between the effective puff height and the ground. The functional dependence of the terminal velocity, v_s , on the aerosol particle size, d_i , and ambient conditions, as determined by Beard (1976) is used in the present model.

It should be noted that the above formulation is applicable to a puff that has completed its initial phase of buoyant rise and has attained thermal equilibrium with the ambient air. In the case of a rising puff, the simple assumption is made that only aerosol particles with terminal velocities greater than the effective vertical velocity of the puff will fall out.

2.3 CHEMICAL TRANSFORMATIONS

When sodium burns in the atmosphere a number of reactions are possible. The primary reactions are:




Reaction (7) is predominant when there is insufficient oxygen for reaction (8). However Na_2O , itself reacts with oxygen according to:





Sodium peroxide is stable only at temperatures below 650°C . The temperature of the plume, as is shown below, is below this critical temperature within a few meters of the sodium fire.

Sodium oxide as well as sodium peroxide will both react with water to form the hydroxide:



Sodium hydroxide will react with carbon dioxide to form the carbonate; in

addition, sodium peroxide will react directly with CO_2 to form the carbonate:



It can be seen that in the presence of sufficient carbon dioxide, the reaction will go to the carbonate in all cases. The primary question then is whether there is sufficient CO_2 in the plume for the reaction to go to completion. This question is treated in the next chapter.

3.0 APPLICATION

In the model applications discussed below, the particle size spectrum has been determined on the basis of experimental data obtained near the ground at distances of 100m and 200m from the source, at which points the large particles have already fallen out of the puff; and Equation (6) is used to compute the deposition of combustion aerosols beyond the 100m range. The emission strength, Q in Equation (6), was obtained by multiplying the total sodium aerosol mass generated in each case by a factor $f = f_d * f_r$ where f_d denotes the fraction (in mass) of aerosols that fallout and f_r is the fraction of fallout (in mass) that reach beyond the 100m range. For spray releases, the fallout mass fraction was observed by Johnson et al. to be $f_d = 0.17$. The second factor, f_r , was derived from the actual observed sodium oxide deposition data by Johnson et al., shown in Figure 1, by integrating the empirically determined distribution functions as indicated in the figure. The result was $f_r = 0.108$. The experimental data of Johnson et al. also indicated that at 100 m downwind of low-level spray releases, about ninety percent of the sodium released was converted to Na_2O and the rest to Na_2CO_3 and $NaOH$, depending on the ambient humidity. This particular chemical composition, however, is not expected to be applicable to all downwind distances. As will be discussed in Section 3.3, the chemical composition of the aerosol particle is dependent on its surface area or size. For the smaller aerosol particles that fall out at greater downwind distances, it is expected that the stable form of sodium carbonate, Na_2CO_3 , will dominate.

3.1 Comparison with Field Data

A brief comparison has been carried out to test the accuracy of the model using the spray release data of Johnson et al. The initial radius, R , of the smoke puff is set to be 1 m for the spray releases, on the basis of actual field observations (Johnson, 1980). The initial temperature is then estimated using the heat release rate, Q_h , for oxidation of sodium particles in the air. Assuming a steady wind speed, U_r , at the release height, the initial average

temperature of the puff and that of the ambient air differ by an amount ΔT that is given by the following relationship:

$$\pi C_p \rho \cdot U_r \cdot t \cdot R^2 \cdot \Delta T = M \cdot Q_h \quad (14)$$

In the above, t is the total release time, and M the total mass of sodium released. Q_h is taken to be 14.2 MJ per kg of sodium.

In the simulation, a constant temperature lapse rate of +0.025 K/m was used for Test 1. For Test 2, the lapse rate was taken to be -0.033 K/m up to the 30m level, and -0.01 K/m above 30m. These vertical temperature lapse rates were used to approximate the actual measured vertical temperature profiles.

The Pasquill-Gifford horizontal and vertical plume spreads, σ_y and σ_z , were used, whereby a release time conversion factor of $(t/180)^{0.2}$ was incorporated in the horizontal spread following Pasquill's suggestion that the standard Pasquill-Gifford σ_y corresponds to a three-minute release time. The classical Pasquill-Gifford vertical plume spread for stability A has been known to have an artificial upward trend beyond 800m downwind distance that is too high (see, for example, Pasquill, 1978). It is replaced, in the present study, by the more recent simple functional form recommended by Pasquill (1974). Based on the observed wind speeds and cloud conditions, the Pasquill stability categories for Test 1 and Test 2 were determined to be C and B respectively. Table 1 compares the modelled area deposition densities with the observed values.

Table 1. Observed and modelled average fallout area densities of sodium aerosols(g/m²)

| Radial distance (m) | Test 1 | | Test 2 | |
|---------------------|---------------------|-------------------------|---------------------|-------------------------|
| | Observation | Model | Observation | Model |
| 100 | $1.9 \cdot 10^{-2}$ | $2.0-3.4 \cdot 10^{-2}$ | $1.6 \cdot 10^{-2}$ | $1.5-2.5 \cdot 10^{-2}$ |
| 200 | $9.1 \cdot 10^{-3}$ | $4.7-7.7 \cdot 10^{-3}$ | $3.6 \cdot 10^{-3}$ | $5.2-8.6 \cdot 10^{-3}$ |
| 400 | $1.5 \cdot 10^{-3}$ | $0.8-1.1 \cdot 10^{-3}$ | $5.0 \cdot 10^{-4}$ | $0.9-1.3 \cdot 10^{-3}$ |
| 800 | $5.9 \cdot 10^{-4}$ | $4.9-5.5 \cdot 10^{-4}$ | $4.7 \cdot 10^{-4}$ | $4.6-5.1 \cdot 10^{-4}$ |

In making the comparison, the receptor locations were specified in such a way as to resemble closely the actual collector positions used in the field study. The average fallout in the table was taken to be the area deposition density averaged over a ninety degree quadrant about the plume center line; and, a constant measured background value of $4 \times 10^{-4} \text{ g/m}^2$ has been added to each of the modelled area densities. Recognizing the complex sodium aerosol chemistry and surface effects, the modelled values are expressed in terms of ranges where the lower limits represent total conversions into Na_2O , and the upper limits total conversions into Na_2CO_3 . As will be discussed in Section 3.3, the lower limits probably apply to large aerosol particles that fall out close to the source and the upper limits may be applicable to a few hundred meters from the source and beyond, where the deposition is expected to be mostly in the stable form of sodium carbonate.

3.2 Five Credible Spill Scenarios

Five scenarios of sodium combustion product release are considered. The first two involve ground level releases that last for three hours. The other three are elevated releases (at heights of 166-184m) of shorter durations. Computer simulations under different assumptions of stability and temperature lapse rate have indicated that for ground level releases, stable atmospheric conditions tend to lead to the highest ground-level impacts. Also, it is clear that, for each assumed stability category, the higher the surface wind speed the lower the effective plume rise. Therefore, the worst-case meteorological conditions for ground releases were assumed to have Pasquill F stability and a surface wind speed (at the 10m level) of 3 m/sec. For elevated releases, similar test runs indicated that the most adverse meteorological conditions would correspond to Pasquill stability A and surface wind speed of 3 m/sec. The complete set of assumed meteorological conditions is presented in Table 2.

Table 2. Worst-case meteorological conditions

| | Ground release | Elevated release |
|------------------------|----------------|------------------|
| Pasquill stability | F | A |
| Surface wind speed | 3 m/sec | 3 m/sec |
| Surface temperature | 300 K | 300 K |
| Temperature lapse rate | +0.03 K/m | -0.02 K/m |

The total mass of sodium released, the release time, and the assumed initial puff temperature, radius and elevation for each of the five scenarios are given in Table 3.

Table 3. Assumed source and initial puff conditions

| Scenario | Total mass of Na(kg) | Release time(sec) | Initial puff conditions | | |
|---------------|-------------------------|----------------------|-------------------------|-----------|--------------|
| | | | temp.(K) | radius(m) | elevation(m) |
| 1. Tank fire | $0.227 \cdot 10^5$ | $0.108 \cdot 10^5$ | 334.0 | 15.2 | 0 |
| 2. Small fire | $0.222 \cdot 10^2$ | $0.108 \cdot 10^5$ | 348.5 | 0.4 | 0 |
| 3. Spray rel. | $0.500 \cdot 10^3$ | $0.100 \cdot 10^4$ | 765.0 | 1.0 | 166 |
| 4. Spray rel. | $0.300 \cdot 10^5$ | $0.566 \cdot 10^3$ | 513.0 | 15.2 | 174 |
| 5. Spray rel. | $0.200 \cdot 10^5$ | $0.900 \cdot 10^2$ | 1192.0 | 15.2 | 174 |

In Table 3, the total sodium mass for ground releases (scenarios 1 and 2) has been adjusted for thirty percent aerosol formation.

The maximum calculated ground-level sodium aerosol concentrations as well as the maximum calculated deposition densities for the five hypothetical scenarios are given in Table 4. It is seen that scenario 1 is predicted to have the highest ground-level impact, with a maximum area deposition of sodium aerosol of 3.7-6.3 g/m². The more detailed predicted ground deposition

density distributions are presented in Figures 2 to 6 for the five scenarios. For reasons discussed in Sections 3.1 and 3.3, the deposition densities plotted for scenarios 1,3,4, and 5 correspond to the upper limits, and those for scenario 2 the lower limits. Although the predicted deposition density of Na_2O was fairly high in scenario 2 at the 100m point, it can be seen from Figure 3 that it drops off very rapidly within a few hundred meters.

Table 4. Maximum ground-level sodium aerosol concentrations and deposition densities

| Scenario | Downwind distance (m) | Maximum concentration (g/m^3) | Maximum deposition (g/m^2) |
|---------------|-----------------------|---|--|
| 1. Tank fire | $4.0 \cdot 10^2$ | $0.31-0.54 \cdot 10^{-1}$ | $0.37-0.63 \cdot 10^{+1}$ |
| 2. Small fire | $1.0 \cdot 10^2$ | $0.22-0.38 \cdot 10^{-1}$ | $0.16-0.27 \cdot 10^{+1}$ |
| 3. Spray rel. | $5.5 \cdot 10^2$ | $0.26-0.44 \cdot 10^{-4}$ | $0.68-1.2 \cdot 10^{-2}$ |
| 4. Spray rel. | $4.5 \cdot 10^3$ | $0.28-0.48 \cdot 10^{-4}$ | $0.27-0.45 \cdot 10^{-1}$ |
| 5. Spray rel. | $4.5 \cdot 10^3$ | $0.27-0.46 \cdot 10^{-4}$ | $0.27-0.47 \cdot 10^{-1}$ |

3.3 Chemical Composition of the Sodium Aerosols

It is expected that the fine sodium particles are rapidly oxidized at high temperatures near the release point. To understand the chemical transitions of the plume element as it is transported downwind, it is useful to neglect for the time being the effects of particle agglomeration and formation of protective layers of chemicals on the aerosol surface. Under such simplified, hypothetical conditions, the entrained water vapor will react with the oxides rapidly into sodium hydroxide. The entrained carbon dioxide will then interact quickly with part of the sodium hydroxide and form sodium carbonate which is relatively stable and hygroscopic.

The source and meteorological conditions in Scenario 1 were used to study the plume chemical composition by assuming an ambient water vapor mixing ratio of

2.5 g/kg, corresponding to a low relative humidity of 15-20% depending on the ambient air pressure, and the standard CO₂ concentration of 357 ppm. The surface wind speed was assumed to be 3 m/sec. Figure 7 shows the expected sodium aerosol chemical composition under the hypothetical conditions that all sodium oxide molecules were exposed to react with entrained water vapor and carbon dioxide molecules. It is seen that at a few hundred meters downwind, virtually all sodium aerosol particles had settled into the stable form of sodium carbonate.

With rapid particle agglomeration and formation of protective layers on the aerosol particle surfaces, the conversion into carbonate is probably not as thorough as depicted in Figure 7. The larger particles that carry less effective surface per unit mass are expected to have less carbonate content. This is reflected in the observed chemical composition at 100 m. It would be of significant interest to have chemical analyses performed on species collected much further downwind, as the small particles with greater effective surface per unit mass are expected to have much greater carbonate content than that measured at 100 m from the source, as predicted by the entrainment model.




Figure 1. Fallout Line Density vs Radial Distance

Figure 2. Area Density of Sodium Aerosol Deposition (gm/m^2)
(Case 1)




Figure 3. Area Density of Sodium Aerosol Deposition (gm/m^2)
(Case 2)




Figure 4. Area Density of Sodium Aerosol Deposition (gm/m^2)

(Case 3)




Figure 5. Area Density of Sodium Aerosol Deposition (gm/m^2)

(Case 4)





Figure 6. Area Density of Sodium Aerosol Deposition (gm/m^2)
(Case 5)






Figure 7. Modelled Aerosol Chemical Composition

4.0 ACKNOWLEDGMENTS

Helpful discussions by Allen Allman and Richard Johnson are gratefully acknowledged.

5.0 REFERENCES

Beard, K.V., 1976: Terminal velocity and shape of cloud and precipitation drops aloft, J. Atmos. Sci., 33, 851-864.

Hanna, S.R., 1976: Predicted and observed cooling tower plume rise and visible plume length at the John E. Amos power plant, Atmos. Environ., 10, 1043-1052.

Johnson, R.P., C. Guderjahn, H.A. Morewitz, C.T. Nelson, and J. Otter, 1978: Atmospheric fallout of sodium combustion aerosols, Rockwell International Energy Systems Group report on work performed under DOE Contract EY-76-C-03-0824.

Johnson, R.P., 1980: Private communication.

Pasquill, F., 1974: Atmospheric diffusion. John Wiley and Son, New York.

Pasquill, F., 1976: Atmospheric dispersion parameters in Gaussian plume modeling. Part 2. Possible requirements for change in the Turner Workbook values. EPA-600/4-76-030b.

Appendix C

PROPERTIES AND HAZARDS OF LIQUID SODIUM

This appendix presents a brief discussion of the properties and hazards of liquid sodium. This discussion is oriented toward the fundamental properties and behavior of liquid sodium, showing how sodium can react in the event of a spill. It is important to realize, however, that the Carrizo Plain plant is designed for zero release during normal operation, so the reactions and hazards described here will be rare occurrences in the operating power plant. Appendix A gives an outline of the safety history of sodium loops, illustrating the rarity of significant spills.

C.1 PROPERTIES OF LIQUID SODIUM

Sodium is a slightly spongy solid at room temperature. However, the melting point of sodium at 1 atmosphere pressure is 208°F, so the sodium in the Carrizo Plain system will all be liquid. Liquid sodium has very high thermal conductivity, so it is well-suited for use in a heat transfer loop.

Sodium reacts vigorously with water, oxygen, and several other common substances. The initial reactions (e.g., sodium + H₂O) and secondary reactions (e.g., liberated H₂ burning in air) may be violent.

When liquid sodium and water are brought into contact with each other, a vigorous exothermic chemical reaction takes place. Sodium hydroxide and sodium oxides are formed and heat and hydrogen are liberated. If the sodium-water reaction occurs in air, ignition of the liberated hydrogen and oxygen from the air can occur. Steam and additional heat will be produced, and if sufficient water and sodium are present the reaction may be explosive. If the sodium-water reaction occurs within the sodium loop, the most severe immediate problem will be generation of heat and free hydrogen. The reaction rate is very rapid and can result in a rapid rise in system pressure. If sufficient water and sodium are involved to cause pressures exceeding system limitations, then leaks can occur through rupture disks. However, the Carrizo Plain plant is designed to withstand a certain amount of water in the sodium system.

A common reaction encountered in using liquid sodium is its interaction with air. Liquid sodium will ignite spontaneously in air and combustion will be sustained if initial conditions of temperature and environment continue to prevail. The initial reaction of sodium with oxygen will form sodium oxides. However, these oxides react quickly with the moisture in the air to form sodium hydroxide; as mentioned previously, sodium hydroxide is also formed in the air by the direct reaction of sodium and water. Dense clouds of sodium hydroxide and sodium oxides resulting from sodium leaks can pose a significant hazard to personnel working within the plant area. However, sodium hydroxide will eventually react with carbon dioxide in the air to form the carbonate, which is essentially harmless compared to the very caustic nature of sodium hydroxide. A modeling study (Wang and Lauer, 1980) has shown that, for a typical sodium leak, reaction to the carbonate is complete at the time of aerosol deposition beyond approximately 1 kilometer or less from the release point, so there are no long-range effects.

C.2 LIQUID SODIUM HAZARDS

Plant personnel may be exposed to sodium as a result of accidents or fire fighting activities. The most likely organs affected would be the skin, eyes, and mouth or mucous membranes. Reaction of sodium with the skin and eyes is of prime concern in any sodium accident. Sodium will destroy tissues as a result of thermal contact and/or chemical reaction with the moisture in tissue. Both reactions occur simultaneously as a result of (1) heat from hot or burning sodium, and (2) the formation of sodium hydroxide with body fluids. Treatment of a sodium burn is not the same as treatment of a typical thermal burn since the hydroxide penetrates the tissues and must be neutralized or removed before effective healing begins. Sodium burns are self-cauterizing and are rarely accompanied by bleeding.

Sodium contact with the eyes is very serious and can result in blindness if not treated promptly. Even if eye protection is worn, minute particles of sodium or its oxides and hydroxide may enter the eye during release. Water flushing is recommended and the services of an ophthalmologist should be obtained immediately. Further eye damage ceases once the eye has been thoroughly flushed.

The possibility of a reaction between sodium and the mouth, throat, and lungs is generally limited to contact of oxide smoke from a fire or caustic mist from a sodium-water reaction. Chronic exposure is very unlikely since contact of sodium oxide smoke or

hydroxide mist with the mouth, throat, and lungs is very irritating and generally cannot be tolerated due the stinging and coughing caused by the smoke. There is no recognized local or systemic form of acute or chronic toxicity resulting from sodium or sodium oxide smoke. The fumes do not act as a poison, but rather as an irritant. Any injury to the mouth, throat, or lungs resulting from contact with sodium or sodium oxide would be due to thermal or alkali burns and not to any toxicity of the fumes, metal, or smoke.

Plant operating personnel should be made aware of the potential reactions and physiological effects of sodium accidents so that they can take prompt and proper action to prevent or minimize injury. Appropriate first aid and medical assistance should be provided to further minimize damage and treat injuries. First aid procedures are discussed in greater detail in Section 6.0 of this document.

NO. 079TI000007

PAGE. 69

Appendix D

GENERAL INDUSTRY SAFETY ORDERS

TITLE 8 GENERAL INDUSTRY SAFETY ORDERS
(Register 78, No. 38—8-8-78)

§ 5417
(p. 526.6.5)

Article 135. General

5416. Flammable Vapors.

(a) Ventilation shall be sufficient so that under normal operating conditions concentrations of flammable vapors or gases in buildings, rooms or similarly enclosed places shall not exceed 20 percent of the lower explosive limit for such vapors except that in pits, sumps, or other locations which are not normally entered, except in cases of emergency, such ventilation will not be required. In such locations, the provisions of paragraph (c) shall be complied with.

(b) No source of ignition shall be permitted in or near a pit or sump in a location near which flammable liquids are regularly and frequently, or have recently been, used, handled or stored in other than closed containers unless tests have been made which indicate that the concentration of flammable vapor is less than 20 percent of the lower explosive limit.

(c) No source of ignition shall be permitted in any location, indoors or outdoors, where the concentration of the flammable gases or vapors exceeds or may reasonably be expected to exceed 20 percent of the lower explosive limit in the working atmosphere. Tests shall be made to ascertain that this limit is not exceeded before a source of ignition is introduced into such location, and such tests shall be repeated frequently (or a continuous indicator used) as long as conditions giving rise to such concentrations of flammable vapors or gases continue and a source of ignition is present.

(d) Smoking shall be forbidden in any location where flammable vapors in concentrations greater than 20 percent of the lower explosive limit may reasonably be expected.

5417. Flammable Liquids—General.

(a) All containers, either open or closed, which contain a flammable liquid shall be plainly marked with an appropriate warning legend or painted a distinctive color or otherwise distinguished from containers which contain non-flammable substances, except that:

(1) Where there are a number of fixed or permanent containers which usually contain flammable liquids, warning signs may be posted in the room or area in which such containers are located instead of marking individual containers; however, portable containers in which flammable liquids are used, stored, or transported, shall be marked in one of the manners described above unless such containers are used under controlled conditions that reduce the possibility of confusion to a minimum. Nonflammable liquids should not be placed in such containers.

(2) Original containers marked as required by the General Industry Safety Orders, Article 112, Labeling of Injurious Substances, shall be considered to comply with the requirements of this section. Containers such as drums, bottles, or carboys, in which flammable liquids are placed for sale, distribution, or shipment need not be marked during the time between filling and labeling.

(b) Flammable liquids shall not be used to wash floors, walls, ceilings, structural members, furniture, equipment, machines or machine parts, unless ventilation is provided and maintained in accordance with Section 5143.

(c) Spraying of flammable liquids for cleaning purposes shall be forbidden except when performed as follows:

(1) In a booth equipped with adequate ventilation. See Section 5153.

(2) Outdoors, or in open sheds, with no source of ignition within 25 feet of the spraying operation.

§ 5418
(p. 526.6.6)

GENERAL INDUSTRY SAFETY ORDERS

TITLE 8

(Register 78, No. 38—9-8-79)

(d) Class IA flammable liquids shall not be used for washing except that two quarts or less may be so used in an enclosed booth provided adequate ventilation is maintained and all sources of ignition are excluded from locations where concentrations of vapors of such liquids may reasonably be expected to exceed 20 percent of lower explosive limit.

(e) Flammable liquids shall be kept in covered containers when not actually in use, being processed or compounded, or shall be stored in permanent storage tanks. Such liquids shall not be transported from storage areas to areas of use in open containers. Containers used to transport flammable liquids or as dispensing devices shall be covered containers or original closed containers. Closures of such containers shall be kept in place at all times except when liquid is being drawn from the container. See Articles 141 and 145.

(f) Tubular gauges on stationary tanks, vats, or containers which contain flammable liquids shall be shielded to prevent liquid spray from endangering employees should the gauge break. All such gauges shall be guarded when exposed to the hazards of being broken by accidental impact and in all cases when located less than 7 feet above or 3 feet laterally from working levels or passageways. All such gauges shall be provided with valves which can be readily closed in case of breakage. Where practicable, ball-check or other self-closing valves shall be used.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.

HISTORY:

1. New subsection (f) filed 3-2-76; effective thirtieth day thereafter (Register 76, No. 10).
2. Amendment of subsections (d) and (e) filed 11-18-76; effective thirtieth day thereafter (Register 76, No. 47).
3. Amendment of subsections (b) and (d) filed 7-13-78; effective thirtieth day thereafter (Register 78, No. 28).
4. Amendment of subsection (b) filed 9-6-79 as procedural and organizational; effective upon filing (Register 79, No. 36).

5418. Carboys Containing Flammable Liquids.

(a) Carboys containing flammable liquids shall not be stored near steam coils or other source of heat.

(b) Carboys containing flammable liquids shall not be emptied by air pressure except as produced by hand pumps or bulbs.

5419. Drums Containing Flammable Liquids.

(a) Drums containing flammable liquids shall not be stored where they are exposed to heat sufficient to rupture the containers.

TITLE 8

DIVISION OF INDUSTRIAL SAFETY
GENERAL INDUSTRY SAFETY ORDERS

526.6.7

(Register 78, No. 28—7-15-78)

(b) Drums containing flammable liquids shall not be emptied by air pressure except as produced by hand pumps or bulbs. Faucets or cocks shall be used where practicable.

(c) No naked flame, torch, or similar source of ignition shall be allowed in contact with drums which contain or have last contained flammable or combustible liquids except for purposes of repair as provided in (d).

(d) Repair of drums which contain or have last contained a flammable liquid:

Before repair work involving the use of open flames or other source of ignition, drums shall be purged of flammable vapors and insofar as is practicable, cleansed of residues which may give rise to such vapors. Ventilation, water, inert gas, or other suitable and effective means shall be used to prevent formation of explosive mixtures as necessary. Where such work is regularly or frequently undertaken, means shall be provided for testing the air in drums for explosibility.

(e) When drums containing or having last contained a flammable liquid are opened, any pressure which may have developed in the drum shall be relieved through a loosened plug before plugs are removed. During such operation, no source of ignition shall be permitted within 25 feet of the drum.

5420. Tanks, Vats and Containers Containing Flammable Liquids.

(a) When repairs, alterations, or cleaning operations are performed on tanks, vats, or confined spaces, which contain or have last contained a flammable liquid or a substance giving rise to flammable vapors the following procedure shall be followed:

(1) All employees engaged in the operation shall be advised of hazards they may encounter.

(2) Lines which may convey hazardous materials to the vessels shall be disconnected, or other positive means shall be used to prevent discharge of such material into the vessel.

(3) If work involving the use of flame, arc, spark, or other source of ignition is to be done, the vessel shall be emptied, flushed or otherwise purged of flammable vapors. A test for flammability of the vapors in the vessel shall be made, using an appropriate device for this purpose, and no source of ignition shall be permitted in or in contact with the vessel if the percentage of combustible vapor is greater than 20 percent of the lower explosive limit. As long as a source of ignition is used in or in contact with the vessel, frequent tests shall be made to determine the concentration of combustible vapors. If this concentration exceeds 20 percent of the lower explosive limit of the vapor present, sources of ignition shall be extinguished or removed until such concentration is reduced below 20 percent of the lower explosive limit.

526.6.8

INDUSTRIAL RELATIONS

TITLE 8

(Register 78, No. 28—7-16-78)

(4) Fire extinguishing equipment adequate to cope with the hazards which may be encountered shall be provided and maintained close at hand.

Note: See Section 5182 for further instruction when working in confined spaces.

NOTE: Authority cited: Section 142.3, Labor Code.

History: 1. New section filed 7-13-78; effective thirtieth day thereafter (Register 78, No. 28).

Article 136. Dip Tanks

5426. Construction of Dip Tanks. **Note:** Closed system quench tanks of integral quench furnaces are not included in this Article.

(a) Dip tanks, including drain boards if provided, shall be constructed of substantial noncombustible material, and their supports shall be of heavy metal, reinforced concrete or masonry.

Note: Where dip tanks extend through a floor to the story below or where the weakening of the tank supports by fire may result in the tank collapse, supports should be of material having not less than one-hour fire resistance.

(b) Dip tanks of over 150 gallons in capacity or 10 square feet in liquid surface area shall be equipped with a properly trapped overflow pipe leading to a safe location outside buildings. Smaller dip tanks should also be so equipped, where practical. The discharge of the overflow pipe should be so located and arranged that if the entire combustible contents of dip tank is overflowed through overflow pipe by the application of water during fire fighting, property will not be endangered. The size of the overflow pipe should be sufficient to conduct the maximum rate of flow of water expected to be applied to the liquid surface of the dip tank from automatic sprinklers or from other sources in the event of fire.

(c) Overflow pipes shall be of sufficient capacity to overflow the maximum delivery of dip tank liquid fill pipes but shall not be less than 3 inches in diameter and shall be increased in size depending upon the area of the liquid surface and the length and pitch of pipe.

(d) If the liquid surface area of dip tank (and drain board, unless drain board is arranged to positively prevent drainage into dip tank) is 75-150 square feet, diameter of overflow pipe should be not less than 4 inches; if 150-225 square feet, not less than 5 inches; if 225-325 square feet, not less than 6 inches.

(e) On large dip tanks, multiple overflow connections are preferable to a single large pipe, provided the aggregate cross sectional area is equivalent.

(f) Overflow pipes should be connected to dip tanks through a flared outlet where the accumulation of caked or dried material may clog the overflow opening.

(g) Piping connections on drains and overflow lines shall be designed so as to permit ready access for inspection and cleaning of interior.



| | | | | | |
|-----------------|------------------|----------------|------------------|--|-----------------------|
| GO NO. 09479 | S/A NO. 11000 | PAGE 1 OF 8 | TOTAL PAGES 8 | REV LTR/CHG NO SEE SUMMARY OF CHG Rev. A | NUMBER 079TI000004 |
|-----------------|------------------|----------------|------------------|--|-----------------------|

PROGRAM TITLE
Solar Central Receiver Power Plant (SCRPP)

DOCUMENT TITLE
Materials of Construction, Carrisa Plains SCRPP

| | |
|--|---------------------------------------|
| DOCUMENT TYPE Technical Information | KEY NOUNS Corrosion, Carburization |
|--|---------------------------------------|

| | | | |
|---------------------|-------------------------|--|-----------------|
| ORIGINAL ISSUE DATE | REL. DATE 4-20-83 RK | APPROVALS D. Kramer <i>David Kramer</i> | DATE 3/16/83 |
|---------------------|-------------------------|--|-----------------|

| | | |
|--|-----------------|-------------------|
| PREPARED BY/DATE <i>W. H. Friske</i> W. H. Friske 3/16/83 | DEPT 737-730 | MAIL ADDR LB30 |
| IR&D PROGRAM? YES <input type="checkbox"/> NO <input type="checkbox"/> | | |
| IF YES, ENTER TPA NO. | | |

| | |
|--------------|----------|
| DISTRIBUTION | ABSTRACT |
|--------------|----------|

| * NAME | MAIL ADDR |
|-----------------|-----------|
| * L. Glasgow | LA19 |
| * T. Ricci | LB26 |
| * A. Ullman | LA19 |
| * T. Johnson | LA19 |
| * D. Nelson | LA19 |
| * B. Katz | LA19 |
| * H. Minami | LB30 |
| * F. Cubillos | LB26 |
| * D. Kramer | NA02 |
| * F. Koepenick | NA02 |
| * A. Carnazzola | LB30 |

This document addresses two materials - related concerns in the design of the Carrisa Plains (SCRPP), stress corrosion cracking and carburization of austenitic stainless steels. It is concluded that these concerns are not design-limiting. The rationale for this conclusion is presented.

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE DOE OFFICE OF PATENT COUNSEL

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY

| REV | SUMMARY OF CHANGE | APPROVALS AND DATE |
|-----|---|--|
| A | Editorial changes. Added: 9. <u>Sodium Corrosion</u> | <i>W.H. Smith</i> 4-19-83 <i>D.F. Otakis for</i> <i>D. Krumer</i> 4-19-83 <i>Rd. Note</i> 4-20-83 <i>RK</i> |
| | | |

Internal Letter



Rockwell International

Date: February 2, 1983

No: .

TO: (Name, Organization, Internal Address)
 L. E. Glasgow
 715, 071-LA19

FROM: (Name, Organization, Internal Address, Phone)
 W. H. Friske
 737, 071-LB30
 3261

Subject: Materials of Construction, Carrisa Plains SCRPP

SUMMARY

The purpose of this letter is to address two materials-related concerns in the design of the Carrisa Plains SCRPP, namely: (1) stress-corrosion-cracking and intergranular corrosion of austenitic stainless steel components in the presence of halogen- or caustic-bearing environments and (2) carburization of austenitic stainless steel receiver panel tubes due to carbon transport from the ferritic steel steam generator tubes. I have evaluated these concerns and concluded that, with proper design, materials selection, fabrication, inspection, and maintenance controls, these concerns are not design limiting. The rationale for this conclusion is presented in the following paragraphs.

I. CORROSION

Type 304 stainless steel has been selected for the hot leg piping and storage tanks and Type 316 for the receiver panel tubing and headers. The reliability of these steels has been demonstrated by usage in essentially all sodium heat transport systems in this country and abroad. In a few systems, the stabilized grades of stainless steels (Types 321 or 347) have been used. ESG-designed sodium systems have historically used Type 304, with Type 316 being selected for those components where higher elevated temperature strength was required. ESG sodium systems have included the SRE and Hallam power plants, component test facilities such as the SCTI, SCTL, and SPTF, plus numerous laboratory test loops.

While it is well documented that austenitic stainless steels are susceptible to stress corrosion cracking and intergranular corrosion, component failures due to these corrosion modes have been infrequent in sodium systems. The austenitic stainless steels are highly resistant to corrosion by the sodium. When corrosion failures have occurred, failure analyses have consistently attributed the cause to contamination, primarily chloride or caustic-bearing solutions, from off-design and unforeseen environmental conditions.* Typically, when sodium leaks have been detected, the failure can be traced to such sources as (1) chlorides leached from thermal insulation by exposure to water and then concentrated by alternate wet-dry conditions;

*LMEC Memo 71-5, "Sodium Piping and Component Failures of the Large Component Test Loop"

L. Glasgow
February 2, 1983
Page 2

(2) residual halogen-bearing weld fluxes, entrapped in crevices; (3) residual halogenated lubricants or oils used in fabrication or assembly; (4) residual sodium which forms caustic (hydroxide ions) in the presence of moisture; or (5) residuals from chlorinated cleaning solutions. Stainless steel components that are exposed to such contamination are subject to stress-corrosion-cracking if tensile stresses are present (stress-corrosion-cracking does not occur with compressive stresses). Also, the stainless steels are susceptible to intergranular corrosion, in the absence of any stresses, in the sensitized condition (i.e., prior exposure to the temperature range of about 850 to 1500°F). When sensitized, the grain boundaries are depleted of the alloying element chromium; hence, the inherent corrosion resistance is diminished.

Preventative action and controls imposed on the Carrisa Plains SCRPP to minimize the risk of corrosion-related failures in stainless steel components are as follows:

1. Design

The heat transport system will be designed to eliminate crevices and nondrainable areas in the piping and tanks. This will eliminate sites for any corrosive contaminants to collect and concentrate, thus minimizing the risk of stress-corrosion-cracking and intergranular corrosion. Also, there will be no stagnant or residual sodium if the system is drained, thus eliminating the potential for caustic-stress-corrosion-cracking.

2. Materials

All materials for the heat transport system will be procured to code specifications. The stainless steel components will be in the solution annealed condition for maximum corrosion resistance. Grain flow control will assure that any inclusions in the microstructure will be parallel to the pressure boundary. This will prevent penetration of the pressure boundary by sodium corrosion of the inclusion material.

3. Welding

All sodium containment welding will be in accordance with the requirements of the applicable code. All containment welds will be full penetration. This eliminates crevices at the weld joints, which in turn, eliminates potential sites where corrosive contaminants can collect and concentrate.

All welds will be made without a flux. This eliminates one source of halogen contaminants that can cause stress corrosion cracking in the weldment or intergranular corrosion in the sensitized area of the weldment.

L. Glasgow
February 2, 1983
Page 3

Weld procedures, weldors, nondestructive examination procedures, and inspectors will be Code qualified. This imposes a high level of welding expertise and quality assurance in fabrication. Backup plates will not be used in welding. This eliminates potential crevices in welded joints and the potential of corrosion cracking.

4. Cleanness

All materials, components, and subsystems will be cleaned in conformance to cleaning and cleanliness requirements which impose controls on cleaning solutions, water quality, lubricants, corrosion inhibitors, degreasing procedures, cleaning procedures, handling procedures, and assembly testing.

5. Sodium System Heating

Except for the solar panel tubes, the entire sodium containment system will be trace heated to provide the capability of maintaining the sodium in the liquid condition at all times. This trace heating also eliminates alternate wet-dry conditions which can concentrate any corrosive contaminants on the surfaces of the stainless steel.

6. Insulation

Thermal insulation on the heat transport system shall meet the test requirements for thermal insulating materials for use on stainless steels. Insulation materials conforming to this specification will have passed the test for susceptibility to chloride stress-corrosion-cracking.

The insulation on all piping and tanks will be weatherproofed. This will prevent moisture, rain, etc., from contacting the insulation and subsequently leaching out any trace chloride or other corrosive contaminants which could be deposited on the stainless steel. Even in the event of rupture of the weatherproofing, any water leaching would not promote corrosion because the trace heating prevents alternate wet-dry chloride concentration from occurring.

7. Sodium Removal

As mentioned, the design and fabrication will preclude nondrainable areas and crevices in the sodium containment where possible. This means that sodium can be drained from the sodium lines without entrapment of residual sodium. It is this residual sodium, if it is eventually exposed to moisture to form sodium hydroxide, that can promote caustic stress-corrosion-cracking.

L. Glasgow
February 2, 1983
Page 4

8. Receiver Panels

The Type 316 stainless steel tubes of the receiver panel will be exposed to the weather and subjected to daily thermal cycles between ambient and the 600-1050°F temperature range with concomitant draining of the sodium from the panel. In the lower half of the panel, where the temperature does not exceed about 850°F, the tube material will retain its inherent resistance to corrosion since it remains in the solution-annealed condition. In the upper section of the panel, the material will become sensitized during exposure to temperatures above 850°F. When sensitized, stainless steels are susceptible to intergranular stress-corrosion-cracking, in the presence of tensile stresses and to intergranular corrosion, even in the absence of stresses.

In the case of these receiver tubes, the only credible source of contamination is from airborne sodium chlorides which could conceivably be concentrated by the alternate condensation of moisture after cooldown and the evaporation of the condensed moisture upon heatup. Even with the unlikely assumption that the tubes do become chloride contaminated, stress corrosion cracking is not probable since (1) the stresses during initial stages of heatup will be too low (i.e., below the threshold level for stress-corrosion-cracking to occur) and (2) as the temperature increases, the moisture will evaporate and the contamination will not be in the prerequisite ion form. Similarly, intergranular corrosion is expected to be limited to surface effects which would not effect life or performance significantly. This is supported by the absence of intergranular corrosion on the ESG test panel which was exposed to the environment in the recent test at White Sands.

The headers of the receiver panel, including the tube-to-header welds, will be trace heated, insulated, and weatherproofed; therefore, they will not be susceptible to this corrosion.

It is recognized that the welded junctions between the tubes and the supporting tangs could serve as crevices. The final design of this attachment will provide some means for drainage of water or moisture from this area to prevent accumulation of contaminants that could cause stress corrosion cracking.

9. Sodium Corrosion

At the hot leg design temperature of 1050°F, the maximum sodium corrosion rate for stainless steel is about 0.032 mils per year per ppm of oxygen. Accordingly, the expected sodium corrosion at various sodium plugging temperatures is as follows (data source: TID 26666).

L. Glasgow
February 2, 1983
Page 5

| Plugging Temperature (°F) | Oxygen (ppm) | Corrosion | |
|---------------------------------|-----------------|-----------|-------------------|
| | | (mpy) | mils in 30 years* |
| 350 | 6 | 0.186 | 1.86 |
| 400 | 12 | 0.372 | 3.72 |
| 450 | 24 | 0.744 | 7.44 |

*Assume 0.33 plant factor

Assuming that the plugging temperature does not exceed 450°F, the maximum reduction of wall thickness will be 7.5 mils during the 30-year plant life. In the case of the receiver panel tubes, this is less than 15 percent of the original wall thickness of 49 mils.

Sodium corrosion of 2-1/4 Cr - 1 Mo is of the same magnitude. In the case of steam generator tubes (109 mil wall), the maximum wall thickness reduction due to corrosion in 1050°F sodium will be less than 7 percent during the plant life. Sodium corrosion in the cold leg, design temperature of 610°F, is negligible for stainless steel, 2-1/4 Cr - 1 Mo, or carbon steel.

II. CARBURIZATION

The material of construction for the steam generator is 2-1/4 Cr - 1 Mo steel. Liquid sodium acts as a carbon transport medium, transferring carbon from the 2-1/4 Cr - 1 Mo ferritic steel (the source of the carbon) to the higher temperature Type 316 stainless steel of the receiver panel (the sink for carbon). The concern is whether the carbon diffusing into the tubes (carburization) will produce a brittle surface that might crack under stress and lead to failure of the tube.

In an analysis of decarburization-carburization kinetics for the Modular Steam Generator (MSG),* it was concluded that the maximum carbon level on the stainless steel tubes of the intermediate heat exchanger would be 0.64% in about 150,000 hours of service, assuming all carburization occurred in a uniform temperature gradient of 800°F to 1050°F. After this time, the carbon level would decrease as it diffused into the bulk thickness of the tubes. It was concluded that (1) the carbon increase due to carburization would not limit the performance of the material by embrittlement and (2) there would be a small increase in strength that would actually improve the design margin of the Code-allowable stresses. The carburization-decarburization kinetics have also been extensively evaluated in the CRBRP programs with the same general conclusions. However, the service temperatures were lower than for the MSG.

L. Glasgow
February 2, 1983
Page 6

In the Carrisa Plains SCRPP, the temperature of the 316 stainless steel tubes will be higher (1050°F), thus the diffusion rate of the carbon into the material will also be higher than for other systems. However, the tubes are not at temperature continuously. The receiver tubes are also subjected to thermal stresses due to temperature gradients and to thermal shock when drained of sodium.

An analysis of the carburization kinetics specific to SCRPP conditions was beyond the scope of this paper. However, it is believed that the potential for embrittlement of the receiver panel tubes due to carburization is not significantly different than for the MSG and is therefore not design limiting.

*TI-095-33-072, "Carbon Transfer - Croloy Steam Generator to Type 304 Stainless Steel IHX," W. J. Anderson, July 11, 1968



W. H. Friske
Materials and Producibility

0086G/kld

cc: A. Ullman, T. Johnson, B. Katz, D. Kramer, F. Koepenick,
H. Minami, W. Castle, W. Lee, A. Pard





| | | | | | |
|------------------------|-------------------------|-------------------------|---------------------------|---|------------------------------|
| GO NO. 09479 | S/A NO. 13400 | PAGE 1 OF 255 | TOTAL PAGES 255 | REV LTR/CHG NO SEE SUMMARY OF CHG NC | NUMBER 079TI000008 |
|------------------------|-------------------------|-------------------------|---------------------------|---|------------------------------|

PROGRAM TITLE
Preliminary Design of Heat Transport Loop - Carrisa Plains - Unit 1

DOCUMENT TITLE
**Preliminary Piping Stress Report
Carrisa Plains - Unit 1 Solar Power Plant**

| | |
|---|---|
| DOCUMENT TYPE Technical Information | KEY NOUNS Sodium Piping, Stress Steam Piping, Solar Power |
|---|---|

| | | | |
|---------------------|--------------------------------|---|------------------------|
| ORIGINAL ISSUE DATE | REL. DATE 4-29-83 RK | APPROVALS  | DATE 4-29-83 |
|---------------------|--------------------------------|---|------------------------|

| | | |
|---|--------------------|--------------------------|
| PREPARED BY/DATE  K. C. Gursahani | DEPT 731 | MAIL ADDR LB30 |
|---|--------------------|--------------------------|

IR&D PROGRAM? YES NO
IF YES, ENTER TPA NO.

| | |
|--------------|----------|
| DISTRIBUTION | ABSTRACT |
|--------------|----------|

| * | NAME | MAIL ADDR |
|---|----------------|-----------|
| | T. L. Anderson | LB26 |
| * | W. Castle | LB30 |
| | F. Cubillos | LB26 |
| | L. E. Glasgow | LA19 |
| * | K. R. Jaquay | LB30 |
| | B. Katz | LA19 |
| * | J. Moldenhauer | LB30 |
| | D. K. Nelson | LA19 |
| * | T. Springer | LA24 |
| | A. Z. Ullman | LA29 |
| * | W. Veljovich | LB30 |

The piping used in the heat transport system of Carrisa Plains Solar Power Plant is analyzed in accordance with the rules of Power Piping Code ANSI B31.1, 1980 Edition.

This report documents the preliminary analyses and calculations performed that show that the piping has enough thermal flexibility and the stress levels are below the Code allowable values.

RESERVED FOR PROPRIETARY/LEGAL NOTICES

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE DOE OFFICE OF PATENT COUNSEL

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

5332F/jjs

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY



CONTENTS

| | Page |
|--|------|
| 1.0 Introduction..... | 3 |
| 2.0 Summary..... | 4 |
| 3.0 Discussion..... | 19 |
| 4.0 Conclusions..... | 20 |
| 5.0 References..... | 21 |
| 6.0 Appendices: Input and Output Data | |
| 6.1 Na Inlet and Outlet Lines to the Steam Generator and Main Steam Piping..... | 22 |
| 6.2 Steam Generator Pump Discharge and Connected Piping..... | 139 |
| 6.3 Steam Generator Pumps Suction Piping..... | 172 |
| 6.4 Sodium Piping to and from the Receiver (Lower and Upper Manifold)..... | 182 |
| 6.5 Sodium Piping to the Receiver (Lower Manifold Only)..... | 212 |
| 6.6 Sodium Piping in Tower..... | 232 |






1.0 INTRODUCTION

This report contains the preliminary stress analyses results of the sodium and the main steam piping for Carrisa Plains Solar Unit 1. With the exception of sodium inlet and outlet lines to the steam generator, all the sodium lines within the scope of this report were analyzed for thermal flexibility only. For these lines, the rest of the loading conditions will be analyzed in the next phase of the project. The main steam line, sodium inlet and outlet lines to the steam generator were analyzed for deadweight, thermal, seismic, and wind loading conditions. All the lines were analyzed to meet the stress requirements of ANSI B31.1, 1980 Edition.



2.0 SUMMARY

Piping shown in Figures 1 through 8 were analyzed. The maximum stresses from the analyses are summarized in Tables 1 through 5. Detailed input and computer results are included in Appendices 6.1 through 6.6. Analysis of lower manifold piping shown in Figure 6 are included with the analysis of the upper manifold piping shown in Figure 5.




TURBINE NOZZLE


NOTE SEE FIG. 1

Main Steam Line to Turbine

Figure 2.




S.G. Pump Suction
Figure 4.




FORM 719-P RE1

Upper Manifold
Figure 5.



Lower Manifold
Part 2 - Figure 7



Sodium Piping in Tower
Figure 8.



TABLE 1
SODIUM OUTLET PIPING
(FIGURE 1)

| | Stress Due To Sustained Loads Dead wt + P + 30 mph Wind Eq. 11 | Stress Due To Occasional Loads Eq. 12 | | Thermal Expansion Stress Eq. 13 | Sustained Plus Thermal Expansion Stress Eq. 14 |
|--|---|--|------------------------------|------------------------------------|---|
| | | Dead wt + P + OBE + 30 mph Wind | Dead wt + P + 90 mph Wind | | |
| Component | 6 in. Elbow | 6 in. Elbow | 6 in. Pipe Anchor | 6 in. Elbow | 6 in. Elbow |
| Node Point | 510 | 510 | 630 | 510 | 510 |
| Stress Intensification Factor | 2.267 | 2.267 | 1.0 | 2.267 | 2.267 |
| Calculated Stress | 1,802 psi | 2,955 psi | 3,984 psi | 21,029 psi | 22,831 psi |
| Allowable Stress | 15,000 psi | 18,000 psi | 18,000 psi | 20,250 psi | 35,250 psi |
| Damage Fraction = $\frac{\text{Calculated}}{\text{Allowable}}$ | 0.12 | 0.16 | 0.22 | 1.04* | 0.65 |

5332F/k1d

* Not needed to be less than unity if Eq 14. damage fraction less than unity

TABLE 2
SODIUM INLET PIPING
(FIGURE 1)

| | Stress Due To Sustained Loads Dead wt + P + 30 mph Wind Eq. 11 | Stress Due To Occasional Loads Eq. 12 | | Thermal Expansion Stress Eq. 13 | Sustained Plus Thermal Expansion Stress Eq. 14 |
|---|--|---|------------------------------|--|---|
| | | Dead wt + P + OBE + 30 mph Wind | Dead wt + P + 90 mph Wind | | |
| Component | 6 in. Straight Pipe | 6 in. Straight Pipe | 6 in. Straight Pipe | 12 in. x 6 in. Reducer | 12 in. x 6 in. Reducer |
| Node Point | 335 | 335 | 335 | 295 | 295 |
| Stress Intensifica- tion Factor | 1.0 | 1.0 | 1.0 | 2.0 | 2.0 |
| Calculated Stress | 7,047 psi | 8,176 psi | 9,514 psi | 11,010 psi | 14,171 psi |
| Allowable Stress | 12,400 psi | 14,880 psi | 18,480 psi | 23,800 psi | 36,200 psi |
| Damage = $\frac{\text{Calculated}}{\text{Allowable}}$ Fraction | 0.57 | 0.55 | 0.51 | 0.46 | 0.39 |

5332F/k1d



TABLE 3
STEAM LINE
(FIGURE 1)

| Component | Stress Due To Sustained Loads Dead wt + P + 30 mph Wind Eq. 11 | Stress Due To Occasional Loads Eq. 12 | | Thermal Expansion Stress Eq. 13 | Sustained Plus Thermal Expansion Stress Eq. 14 |
|---|--|---|------------------------------|--|---|
| | | Dead wt + P + OBE + 30 mph Wind | Dead wt + P + 90 mph Wind | | |
| Component | Butt Weld 6 in. Pipe | Butt Weld 6 in. Pipe | Straight Pipe Pipe 6 in. | Butt Weld 6 in. Pipe | Butt Weld 6 in. Pipe |
| Node Point | 23 | 23 | 173 | 23 | 23 |
| Stress Intensifica- tion Factor | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Calculated Stress | 5,108 psi | 5,775 psi | 6,994 psi | 9,468 psi | 14,577 psi |
| Allowable Stress | 7,500 psi | 9,000 psi | 17,280 psi | 18,560 psi | 26,060 psi |
| Damage = $\frac{\text{Calculated}}{\text{Allowable}}$ Fraction | 0.68 | 0.64 | 0.40 | 0.51 | 0.56 |

5332F/kld



TABLE 4
Na INLET PIPING HEADER
(FIGURE 1)

| Component | Stress Due To Sustained Loads Dead wt + P + 30 mph Wind Eq. 11 | Stress Due To Occasional Loads Eq. 12 | | Thermal Expansion Stress Eq. 13 | Sustained Plus Thermal Expansion Stress Eq. 14 |
|--|---|--|---------------------------|------------------------------------|---|
| | | Dead wt + P + OBE + 30 mph Wind | Dead wt + P + 90 mph Wind | | |
| Component | 6 in. Pipe Anchor | 6 in. Pipe Anchor | 6 in. Pipe Anchor | 6 in. Elbow | 6 in. Elbow |
| Node Point | 450 | 450 | 450 | 1450 & 1510 | 1490 |
| Stress Intensification Factor | 1.0 | 1.0 | 1.0 | 2.606 | 2.606 |
| Calculated Stress | 2,367 psi | 4,299 psi | 5,736 psi | 20,994 psi | 22,042 psi |
| Allowable Stress | 12,400 psi | 14,880 psi | 18,480 psi | 23,800 psi | 36,200 psi |
| Damage Fraction = $\frac{\text{Calculated}}{\text{Allowable}}$ | 0.19 | 0.29 | 0.31 | 0.88 | 0.61 |

5332F/kld



TABLE 5
MAXIMUM THERMAL STRESSES

| Line Description | Component | Node Point | Stress Intensification Factor | Thermal Expansion Stress Eq. 13 | | Damage: Calculated Allowable |
|--|--------------|------------------------|-------------------------------|---------------------------------|------------|------------------------------|
| | | | | Calculated | Allowable | |
| Steam Gen. Pump Suction Loop | 20 in. Elbow | 50 and 130 Figure 4 | 3.768 | 22,303 psi | 23,800 psi | 0.94 |
| Steam Gen. Pump Discharge Loop | 4 in. Elbow | 585 Figure 3 | 1.953 | 10,536 psi | 22,500 psi | 0.47 |
| Sodium Outlet From Receiver (Upper Manifold) | 6 in. Elbow | 315 Figure 5 | 2.267 | 23,966 psi | 25,575 psi | 0.94 |
| Sodium Inlet to Receiver (Lower Manifold) | 6 in. Elbow | 6130 Figure 7 | 2.267 | 24,026 psi | 26,215 psi | 0.92 |
| Sodium Piping in Tower | 8 in. Elbow | 1050 Figure 8 | 2.440 | 18,249 | 25,575 psi | 0.71 |
| Main Steam Line | 6 in. Pipe | 3195 Figure 2 | 1.0 | 17,861 psi | 18,560 psi | 0.96 |

5332F/k1d



Note: Page left intentionally blank.



3.0 DISCUSSIONS

The main steam line and the sodium inlet and outlet lines to the steam generator are shown in Figures 1 and 2. The lines shown in Figure 1 were analyzed for deadweight, thermal, seismic, and wind loading conditions. The routings shown are typical for three steam generators. Although Figure 1 shows steam lines anchored at node point 195 and was modeled as such in the analysis, it was subsequently replaced by a guide at node 195 and a support in the third direction at node 178. Figure 2 shows the routing between these virtual anchors for three steam generators and the steam turbine.

In order to validate the runs made according to Figure 1, the following procedure was used:

A thermal run was made for the steam generator model only (with no connected piping) in order to determine the thermal growth of the steam nozzle (node point 23). Next three steam lines shown on Figure 2 were extended to SG nozzles and anchored. Thermal movements obtained from Run 1 were imposed on each nozzle. Runs were made for different thermal modes to determine the degree of thermal coupling of three steam generators. The forces and the moments at the SG nozzles showed little change when one of the other steam generators was shut down. This led to the conclusion that the three steam generators were not thermally interconnected and that analyses done as per Figure 1 was valid.

Thermal flexibility of the steam piping shown in Figure 2 was checked by analysis with the node points 195, 2195, and 3195 anchored.

Calculations for wind loading are included in Appendix 6.1. For all piping shown in Figures 1 through 8, stress identification factor of 1.0 was used at the girth butt weld if the pipe weld thickness exceeded 3/16 in. This meets the Code requirement since Reference 2 restricts the δ/t value specified in Code to ≤ 0.1 .



4.0 CONCLUSION

On the basis of the analyses performed, it is concluded that all the sodium and steam piping shown in Figures 1 through 8 have adequate thermal flexibility and the stresses are below allowable limits as per the requirements of the Code.



5.0 REFERENCES

- 1.0 Power Piping ANSI B31.1 - 1980 Edition
- 2.0 Design Specification - Solar Central Receiver Power Plant Carrisa Plains, Unit 1
- 3.0 Carrisa Plains - Unit 1, Main Heat Transport Systems P&ID 079R000029
- 4.0 American National Standard Code For Minimum Design Loads in Buildings and other structures, ANSI A58.1-1972 Edition, American National Standard Institute, Inc., 1430 Broadway New York, N.Y. 10018



APPENDIX 6.1
INPUT AND OUTPUT DATA FOR NA INLET AND OUTLET LINES
TO SG AND MAIN STEAM PIPING

PROJECT: CARRIZO PLANT SOLEAR PUMP PLANT
 MAIN STEAM LAYOUT (COMMITTED PRELIMINARY)
 DRAWN BY: W. AYLLAN DATE: 02-18-83
 CHECKED BY: _____
 APPROVED BY: _____
 LOCATION: 079T1000008




FIGURE 2

NOTES:

1. SEE DWG. 511706, REV. 04, FOR PIPE ROUTING TO TURBINE NOZZLE


| | | |
|-------------------------|--|------------------------|
| PREPARED BY: <i>KCh</i> |  Rockwell International Energy Systems Group | 25 |
| CHECKED BY: | | PAGE NO. 02 |
| DATE: 2-8-83 | | REPORT NO. 079TI000008 |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | STEAM LINE | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0200 - G - B4DB 0201 - G - B4DB 0202 - G - B4DB | | | |
| Design Temperature | 1015°F | | | |
| Design Pressure | 1575 psig | | | |
| Normal operating Temperature | 1003°F | | | |
| Normal operating Pressure | 1500 psig | | | |
| Pipe O.D./schedule | 6.625 / XXS | | | |
| Pipe Thickness | 0.864" | | | |
| Pipe Material | 2 1/4 Cr - 1 Mo | | | |
| Insulation Type | | | | |
| Weight of Pipe LBS/FT | 53.16 | | | |
| Weight of Contents LBS/ft | 8.17 | | | |
| Weight of Insulation LBS/ft | 24.2 | | | |
| Total Weight LBS/ft | 85.5 | | | |
| E _c | 29.9 | | | |
| Seismic Category | II | | | |


| | | |
|------------------|--|---------------------------|
| PREPARED BY: KCG |  Rockwell International Energy Systems Group | 26 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: 2-8-83 | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | Na Outlet Header | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 12.75/sch. 40S | | | |
| Pipe Thickness | 0.375" | | | |
| Pipe Material | C.S. 106 | | | |
| Insulation Type | Cal. Silicate 6" thick | | | |
| Weight of Pipe Lbs/Ft | 49.56 | | | |
| Weight of Contents Lbs/ft | 49 X .91 = 44.6 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (24.75^2 - 12.75^2) \times \frac{14}{144}$ = 34.4 | | | |
| Total Weight Lbs/ft | 128.5 | | | |
| E _c | 27.9 | | | |
| Seismic Category | I | | | |


| | | |
|-------------------------|---|-------------|
| PREPARED BY: <u>KCS</u> |  | 27 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <u>2-8-83</u> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | Na Outlet from Steam Generator | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0030, 0031 & 0032 - G - HBDA | | | |
| Design Temperature | 610°F | | | |
| Design Pressure | 65 psi. | | | |
| Normal Operating Temperature | 610°F. | | | |
| Normal Operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 6.625 / sch 40 | | | |
| Pipe Thickness | .28" | | | |
| Pipe Material | CS L06 | | | |
| Insulation Type | Cal. Silicate 6" thick | | | |
| Weight of Pipe LBS/FT | 18.97 | | | |
| Weight of Contents LBS/ft | 11.26 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} (18.625^2 - 6.625^2) \times \frac{14}{144}$ = 23.14 | | | |
| Total Weight LBS/ft | 53.4 #/ft. | | | |
| E _c | 28.3 x 10 ⁶ | | | |
| Seismic Category | III | | | |


| | | |
|-------------------------|---|-------------------------------|
| PREPARED BY: <u>KCS</u> |  Rockwell International Energy Systems Group | PAGE NO. <u>28</u> OF |
| CHECKED BY: | | REPORT NO. <u>079TI000008</u> |
| DATE: <u>2-8-63</u> | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | No Inlet Header to S.G | REFERENCE | | |
|--------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0026-10-GEDA | | | |
| Design Temperature | 1065°F | | | |
| Design Pressure | 65 PSI | | | |
| Normal Operating Temperature | 1050°F | | | |
| Normal operating Pressure | 65 PSI | | | |
| Pipe O.D./schedule | 10.75"/sch. 40 | | | |
| Pipe Thickness x | 0.365" | | | |
| Pipe Material | SS 316 | | | |
| Insulation Type | 12" thick Cal. Silicate | | | |
| Weight of Pipe Lbs/Ft | 40.48 | | | |
| Weight of contents Lbs/ft | 29 (34.1) = 30.69 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4}(34.75^2 - 10.75^2) \times \frac{14}{144} = 83.38$ | | | |
| Total Weight Lbs/ft | 154.6 lbs/ft | | | |
| E_c^x | 28.3 | | | |
| Seismic Category | II | | | |


| | | |
|-------------------------|---|--------------------------|
| PREPARED BY: KCG |  | 29 PAGE NO |
| CHECKED BY: | | 07971000008 REPORT NO |
| DATE: 2-8-83 | | MODEL NO |

TABLE B-1
INPUT DATA

| SYSTEM | Na Inlet to Steam Generator | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0027, 0028 & 0029 - G-GEDA | | | |
| Design Temperature | 1055°F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1050°F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 6.625 / Sch. 40 | | | |
| Pipe Thickness | .28" | | | |
| Pipe Material | SS 316 | | | |
| Insulation Type | Calcium Silicate 12" thick | | | |
| Weight of Pipe LBS/FT | 18.97 | | | |
| Weight of contents LBS/ft | .9 x 12.51 = 11.26 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} \frac{(30.625^2 - 6.625^2)}{144} \times 14 = 68.3$ | | | |
| Total Weight LBS/ft | 98.5 lbs/ft | | | |
| E _c | 28.3 x 10 ⁶ | | | |
| Seismic Category | III | | | |


| | | | |
|-------------------------|---|---------------------------|-----------|
| PREPARED BY: <u>KEG</u> |  Rockwell International Energy Systems Group | 30 PAGE NO. | OF |
| CHECKED BY: | | 079TI000008 REPORT NO. | |
| DATE: <u>2-8-83</u> | | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | Na Inlet to Steam Generator | REFERENCE | | |
|--------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | Near Nozzle | | | |
| Design Temperature | 1055° F | | | |
| Design Pressure | 65 psi | | | |
| Normal Operating Temperature | 1050° F | | | |
| Normal Operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 12.75 / sch 80 | | | |
| Pipe Thickness | .687" | | | |
| Pipe Material | SS 316 | | | |
| Insulation Type | Cal. Sil. 12" thick | | | |
| Weight of Pipe LBS/FT | 88.51 | | | |
| Weight of Contents LBS/ft | 19 x 44 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} \left(\frac{36.75^2 - 12.75^2}{144} \right) \times 1.4 = 90.7$ | | | |
| Total Weight LBS/ft | 218.8 | | | |
| E _c | 28.3 x 10 ⁶ | | | |
| Seismic Category | II | | | |

Jim Moldenhauer
PREPARED BY:



Rockwell International
Energy Systems Group

31 PAGE NO. OF

CHECKED BY:


079TI000008
REPORT NO.

DATE:

2-2-83

MODEL NO.

Steam Generator Model



Jim Moldenhauer
PREPARED BY:



Rockwell International
Energy Systems Group

PAGE NO. 32 OF

REPORT NO. 079TI000008

CHECKED BY:

DATE: 3-8-83

APPENDIX I

MODEL NO.

TABLE 1.

MSG DATA FOR USE IN PIPING MODEL. SEE FIGURE 1.

| ELEMENT | NODES | OP (IN) | t (IN) | W _{METAL} (LB/IN) | W _{INS} (LB/IN) |
|--------------------|-------|---------|--------|----------------------------|-------------------------------|
| 1 SUP. CONE | 1 | 54.22 | 0.721 | 56.39 | 11.28 EST-12" THK L=36" |
| | 2 | | | | |
| 2 SUP. CONE | 2 | 30.94 | 0.721 | 45.26 | 13.50 (EST-12" THK) |
| | 3 | | | | |
| 3 REDUCER | 3 | 21.5 | 1.0 | 42.93 | 10.23 |
| | 4 | | | | |
| 4 TUGSHEET | 4 | 19.0 | 1.0 | 62.18 | 9.47 |
| | 5 | | | | |
| 5 STEAMHEAD | 5 | 12.81 | 1.0 | 31.17 | 7.71 |
| | 6 | | | | |
| 6 OUT. HDR. | 3 | 26.0 | 1.97 | 71.16 | 11.61 |
| | 7 | | | | |
| 7 No. OUT. NOZ. | 7 | 12.75 | 0.562 | 4.458 (47%) | 0.0 |
| | 8 | | | | |
| 8 OUT. HDR. | 7 | 26.0 | 1.97 | 71.16 | 11.61 |
| | 9 | | | | |
| 9 REDUCER | 9 | 21.0 | 0.86 | 35.47 | 10.08 |
| | 10 | | | | |
| 10 SHELL | 10 | 18.0 | 0.75 | 26.99 | 9.16 |
| | 11 | | | | |
| 11 SHELL | 11 | 18.0 | 0.75 | 26.99 | 9.16 |
| | 12 | | | | |
| 12 SHELL | 12 | 18.0 | 0.75 | 26.99 | 9.16 |
| | 13 | | | | |
| 13 SUP. RING | 13 | 18.0 | 0.75 | 26.99 | 9.16 |
| | 14 | | | | |
| 14 REDUCER | 14 | 21.0 | 0.86 | 35.47 | 10.08 |
| | 15 | | | | |



| | | |
|---------------------------------|---|---------------------------|
| Jim Moldenhauer PREPARED BY: |  Rockwell International Energy Systems Group | 33 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: 3-8-83 | APPENDIX 1 | MODEL NO. |

TABLE 1. (CONT'D)

| ELEMENT | NODES | OD (IN) | t (IN) | W _{METAL} (LB/IN) | W _{INS.} (LB/IN) |
|-------------------------------|-------|---------|--------|----------------------------|---------------------------|
| 15 IN. HDR | 15 | 26.0 | 1.97 | 71.89 | 11.61 |
| | 16 | | | | |
| 16 N ₂ IN. NOZ. | 16 | 12.75 | 0.562 | 5.786 (61%) | 1.89 (25%) |
| | 17 | | | | |
| 17 IN. HDR | 16 | 26.0 | 1.97 | 71.89 | 11.61 |
| | 18 | | | | |
| 18 ELBOW R=24.0 IN. | 18 | 24.0 | 1.0 | 32.70 | 11.00 |
| | 19 | | | | |
| 19 CROSS | 19 | 26.0 | 1.97 | 65.68 | 11.61 |
| | 20 | | | | |
| 20 REDUCER | 20 | 21.5 | 1.0 | 39.47 | 10.23 |
| | 21 | | | | |
| 21 TUBESHEET | 21 | 19.0 | 1.0 | 62.18 | 9.47 |
| | 22 | | | | |
| 22 STEAMHEAD | 22 | 12.81 | 1.0 | 23.81 | 7.71 |
| | 23 | | | | |


Notes:

- 1) $\rho_{STL} = 0.283 \text{ LB/IN}^3$
- 2) $\rho_{NA} = 0.032 \text{ LB/IN}^3$
- 3) $\rho_{INS} = 14.0 \text{ LB/FT}^3$ $t_{INS} = 12.0 \text{ INCHES}$

| | | |
|---------------|--|-------------------------|
| PREPARED BY: |  Rockwell International Energy Systems Group | 34 |
| CHECKED BY: | | PAGE NO. _____ OF _____ |
| DATE: 2-10-83 | | REPORT NO. 079TI000008 |
| | | MODEL NO. |

| ELEMENT | NODES' | TE _{1D} (°F) | TE ₂ (°F) | TE ₃ (°F) | TE _{1φ} (°F) ^φ | |
|-------------------------------|--------|--------------------------|-------------------------|-------------------------|---------------------------------------|--|
| 1 SUPPORT CONE | 1 | 225 | 201 | 226 | 210 | |
| | 2 | | | | | |
| 2 SUPPORT CONE | 2 | 435 | 381 | 492 | 420 | |
| | 3 | | | | | |
| 3 REDUCER | 3 | 470 | 420 | 600 | 455 | |
| | 4 | | | | | |
| 4 L. TUBESHEET | 4 | 450 | 400 | 600 | 435 | |
| | 5 | | | | | |
| 5 L. STEAMHEAD | 5 | 450 | 400 | 600 | 435 | |
| | 6 | | | | | |
| 6 OUT. HEADER | 3 | 587 | 550 | 600 | 572 | |
| | 7 | | | | | |
| 7 N ₂ OUT. NOZ. | 7 | 620 | 570 | 600 | 605 | |
| | 8 | | | | | |
| 8 OUT. HEADER | 7 | 625 | 575 | 600 | 610 | |
| | 9 | | | | | |
| 9 REDUCER | 9 | 640 | 585 | 600 | 625 | |
| | 10 | | | | | |
| 10 SHELL | 10 | 705 | 650 | 600 | 690 | |
| | 11 | | | | | |
| 11 SHELL | 11 | 865 | 770 | 600 | 850 | |
| | 12 | | | | | |
| 12 SHELL | 12 | 1010 | 890 | 600 | 995 | |
| | 13 | | | | | |
| 13 SHELL | 13 | 1050 | 940 | 600 | 1035 | |
| | 14 | | | | | |
| 14 REDUCER | 14 | 1055 | 942 | 600 | 1040 | |
| | 15 | | | | | |

TE_{1D} = DESIGN TEMPERATURE TE₃ = EXTENDED SHUTDOWN
 TE_{1φ} = OPERATING TEMPERATURE
 TE₂ = HOT LOCKUP

| | | | |
|--------------|--|---------------------------|----|
| PREPARED BY: |  Rockwell International Energy Systems Group | 35 PAGE NO. | OF |
| CHECKED BY: | | 079TI000008 REPORT NO. | |
| DATE: 2-9-83 | | MODEL NO. | |

| ELEMENT | NODES | TE1 (°F) ^p | TE2 (°F) | TE3 (°F) | TE1 (°F) ^φ | |
|-------------------------------|-------|--------------------------|-------------|-------------|--------------------------|--|
| 15 IN. HEADER | 15 | 1057 | 948 | 600 | 1042 | |
| | 16 | | | | | |
| 16 N _a IN. NOZ. | 16 | 1065 | 950 | 600 | 1050 | |
| | 17 | | | | | |
| 17 IN. HEADER | 16 | 1055 | 950 | 600 | 1040 | |
| | 18 | | | | | |
| 18 ELBOW | 18 | 1025 | 910 | 600 | 1010 | |
| | 19 | | | | | |
| 19 CROSS | 19 | 1020 | 905 | 600 | 1005 | |
| | 20 | | | | | |
| 20 REDUCER | 20 | 1020 | 902 | 600 | 1005 | |
| | 21 | | | | | |
| 21 U. TUESHEET | 21 | 1015 | 900 | 600 | 1000 | |
| | 22 | | | | | |
| 22 U. STEAMHEAD | 22 | 1015 | 900 | 600 | 1000 | |
| | 23 | | | | | |

MSG - SOLAR PIPING LOADS


| | | | |
|-----------------|--------------------------|--------|--------|
| TE1 (DESIGN) | FEEDWATER INLET & PIPING | 460°F | 436°F |
| | NA OUTLET & PIPING | 605°F | 610°F |
| | NA INLET & PIPING | 1050°F | 1065°F |
| | STEAM OUTLET & PIPING | 1000°F | 1015°F |

| | | | |
|---------------------|--------------------------|-------|--|
| TE2 (HOT LOCKUP) | FEEDWATER INLET-NOZZLE | 460°F | |
| | - PIPING | 400°F | |
| | NA OUTLET - AT NOZZLE | 570°F | |
| | - PIPING | 300°F | |
| | NA INLET - AT NOZZLE | 950°F | |
| | - PIPING | 950°F | |
| | STEAM OUTLET - AT NOZZLE | 900°F | |
| | - PIPING | 850°F | |

| | | | |
|-----------------------------|--------------------------|-------|-------------|
| TE3 (LONG TERM SHUTDOWN) | FEEDWATER INLET-NOZZLE | 600°F | |
| | - PIPING | 70°F | MSG @ 600°F |
| | NA OUTLET - AT NOZZLE | 600°F | |
| | - PIPING | 300°F | |
| | NA INLET - AT NOZZLE | 600°F | |
| | - PIPING | 600°F | |
| | STEAM OUTLET - AT NOZZLE | 600°F | |
| | - PIPING | 70°F | |


COMBINATIONS

- (20) DW + WIND₉₀
- (18) DW + WIND₃₀ + OBE
- (19) DW + TE1 + WIND₃₀ + OBE
- (29) DW + TE2 + WIND₃₀ + OBE
- (21) DW + TE2 + WIND₉₀
- (24) DW + WIND₃₀
- (30) DW + TE3 + WIND₃₀ + OBE
- (22) DW + TE3 + WIND₉₀


| | | |
|------------------|--|---------------------------|
| PREPARED BY: KCL |  Rockwell International Energy Systems Group | 37 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: 3-10-83 | | MODEL NO. |

Piping Analysis Load case details.


| Load Case No. | Title | Description |
|---------------|--|--|
| 1 | X-Direction 30 mph wind (Steam generator wind loads $P_w = 4.16 \text{ PSF}$) | Wind loads for: Steam piping = 6.7 lbs / ft Na Inlet piping = 11.0 lbs / ft Na Outlet piping = 6.7 lbs / ft All snubbers inactive. |
| 2 | Z-Direction 30 mph wind | wind loads same as for x-direction. |
| 3 | Maximum of X and Z Absolute 30 mph wind | Maximum values are selected (regardless of sign) from case 1 and 2 for each force and moment component. |
| 4 | Maximum of X and Z Absolute 90 mph wind | Same as case 3 except wind loads on piping are 9 times the values given above for 30 mph wind. |
| 5 | Deadweight | Total weights used for: 6" Steam piping: 85.5 lbs / ft 6" Na Inlet Piping: 98.5 lbs / ft 6" Na Outlet Piping: 53.4 lbs / ft |
| 6 | TE 1 (Thermal at the design temperature) | Design Temp. used: Steam piping: 1015°F Na Inlet Piping: 1065°F Na Outlet Piping: 610°F |

| | | |
|-------------------------|---|---------------------------|
| PREPARED BY: <i>KCS</i> |  Rockwell International Energy Systems Group | 38 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: <i>3-10-83</i> | | MODEL NO. |

| Load Case No. | Title | Description |
|---------------|---|---|
| 7 | TE2 (Thermal Overnight Shutdown) | Operating temp. used: Steam piping: 850°F Na Inlet piping: 950°F Na Outlet Piping: 300°F |
| 8 | TE3 (SG and Na Inlet at 600, Na outlet at 300 and steam piping at 70) | Operating temp. used: Steam piping: 70°F Na Inlet Piping: 600°F Na Outlet Piping: 300°F |
| 9 | OBE X- Direction at .4g. | } all snubbers active. |
| 10 | OBE Y- Direction at .2667g | |
| 11 | OBE Z-Direction at .4g. | |
| 12 | DWT (Sign) + TE1 (Sign) Direct combination | Algebraic summation of load cases 5 and 6 |
| 13 | DWT (Sign) + TE2 (Sign) Direct combination | Algebraic summation of load cases 5 and 7 |
| 14 | DWT (Sign) + TE3 (Sign) Direct combination | Algebraic summation of load cases 5 and 8 |
| 15 | Maximum of x-OBE (abs) and z-OBE (abs) | Maximum absolute value for each force and moment component from load cases 9 and 11. |

| | | |
|-------------------------|--|---------------------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 39 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: <u>2/10/83</u> | | MODEL NO. |


| Load case no. | Title | Description |
|---------------|--|---|
| 16 | $Y(\text{abs}) + \text{Maximum of } X(\text{abs})$ and $Z(\text{abs})$ call this "Total OBE" | Absolute summation of load cases 10 and 15. |
| 17 | Total OBE + wind load (30 MPH) | Absolute summation of load cases 3 and 16 |
| 18 | DWT + Total OBE + wind load (30 MPH) | Absolute summation of load cases 5 and 17. |
| 19 | (DWT + TE1) ABS + Total OBE + wind load (30 MPH) | Absolute summation of load cases 12 and 17 |
| 20 | DWT + 90 MPH wind | Absolute summation of load cases 5 and 4 |
| 21 | (DWT + TE2) ABS + 90 MPH WIND | Absolute summation of load cases 13 and 4 |
| 22 | (DWT + TE3) ABS + 90 MPH WIND | Absolute summation of load cases 4 and 14. |
| 23 | (DWT + TE1) Abs + 30 mph wind | Absolute summation of load cases 3 and 12 |
| 24 | DWT + 30 mph wind | Absolute summation of load cases 3 and 5. |
| 25 | DWT + 30 mph wind + TE2 | Absolute summation of loadcases 3 and 13 |
| 26 | DWT + 30 mph wind + TE2 + OBE | Absolute summation of loadcases 16 and 25 |

| | | |
|-------------------------|--|---------------------------|
| PREPARED BY: <i>KCG</i> |  Rockwell International Energy Systems Group | 40 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: <i>2/10/83</i> | | MODEL NO. |

| |
|--|
| |
|--|

| Load case no. | Title | Description |
|---------------|-------------------------------------|---|
| 27 | DWT + TE3 + 30 mph wind | Absolute summation of load cases 3 and 14 |
| 28 | DWT + TE3 + Total OBE + 30 mph wind | Absolute summation of load cases 16 and 27. |

| |
|--|
| |
|--|

| | | |
|------------------|---|-------------|
| PREPARED BY: KCL |  | 41 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 2-4-83 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

Calculation of minimum wall thickness for the Steam line.

$$t_m = \frac{P D_o}{2(S E^* + P y)} + A$$

$$P = 1590 \text{ psi}$$

$$S = 7200 \text{ psi @ } 1015^\circ \text{ F.}$$

$$y = .4$$

$$A = .0625'' \text{ (as per ASME)}$$

$$t_m = \frac{1590 D_o}{2(7200 + .4 \times 1590)} + .0625$$

$$= .101 D_o + .0625''$$

$$t_{\text{nominal}} = \frac{t_m}{.875} = .116 D_o + .071''$$

6" pipe $t_{\text{nominal}} = .840''$

10" pipe $t_{\text{nominal}} = 1.318''$

12" pipe $t_{\text{nominal}} = 1.463''$

steam piping: 6" pipe with 6" thick insulation $C_F = 1.2$

$$OD = 6.625 + 2(6) = 18.625"$$

From sheet 43

At 30 MPH: wind load = $1.2 \times \frac{18.625}{12} \times 1 \times 3.6 = 6.7 \text{ lbs/ft}$

At 90 MPH: wind load = $1.2 \times \frac{18.625}{12} \times 1 \times 32.1 = 59.8 \text{ lbs/ft}$

Na Inlet Piping: 6" pipe with 12" thick insulation

$$OD = 6.625 + 2(12) = 30.625"$$

At 30 MPH: wind load = $\frac{30.625}{12} \times 1 \times 3.6 \times 1.2 = 11.0 \text{ lbs/ft}$

At 90 MPH: wind load = $1.2 \times \frac{30.625}{12} \times 1 \times 32.1 = 98.3 \text{ lbs/ft}$

| Pipe | Dead wt. | Wind load | Ratio $\frac{\text{wind load}}{\text{dead wt}}$ |
|--------------|-------------|-------------|---|
| 6" steam | 85.5 lbs/ft | 6.7 30 MPH | .078 |
| | | 59.8 90 MPH | .699 |
| 6" Na Inlet | 98.5 lbs/ft | 11.0 30 MPH | .112 |
| | | 98.3 90 MPH | .998 |
| 6" Na Outlet | 53.4 lbs/ft | 6.7 30 MPH | .125 |
| | | 59.8 90 MPH | 1.12 |


WIND LOADING CALCULATIONS

$$\sigma_{JP} = 1.7 [T(2h/3)] [0.785 PF/\beta + S/(1 + .002C)]^{1/2}$$

$\beta = .01$

Reference 4.

| Height | V ₃₀ wind speed | q ₃₀ = .00256 V ₃₀ ² | K _z | T(2h/3) | 1.12(√K ₃₀) V ₃₀ /f f = 7 hz | P | .88 fh / V ₃₀ √K _h | h/c | F | S | σ _{JP} | G _F | q _F psf. |
|--------|-------------------------------|--|----------------|---------|--|------|--|-----------------------|------------------------|------|-----------------|----------------|------------------------|
| 70' | 90 MPH | 20.736 | 1.3 @ 70' | .16 | 1.12 × √1 × 90/7 = 14.4 | .025 | .88 × 7 × 70 / 90 × √1.3 = 4.2 | 70 / 18.625 = 3.76 | 3.2 × 10 ⁻⁴ | 1.07 | .28 | 1.19 | 32.1 |
| 460' | 90 MPH | 20.736 | 2.3 @ 460' | .13 | 1.12 × √1 × 90/7 = 14.4 | .025 | .88 × 7 × 460 / 90 × √2.3 = 20.76 | 70 / 30.625 = 2.3 | 10 ⁻⁴ | .77 | .19 | 1.02 | 32.1 |
| 460' | 30 MPH | 2.304 | 2.3 @ 460' | .13 | 1.12 × √1 × 30/7 = 4.8 | .018 | .88 × 7 × 460 / 30 × √2.3 = 62.3 | 3.76 | 10 ⁻⁴ | .77 | .19 | 1.02 | 5.4 |
| 70' | 30 MPH | 2.304 | 1.3 @ 70' | .16 | 4.8 | .018 | .88 × 7 × 70 / 30 × √1.3 = 12.6 | 3.76 | 10 ⁻⁴ | 1.07 | .28 | 1.19 | 3.6 |

| | | |
|---------------------------------|---|---------------------------|
| Jim Moldenhauer PREPARED BY: |  Rockwell International Energy Systems Group | 44 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: 2-3-83 | | MODEL NO. |

REVISED MSG WIND FORCE (ANSI B.1-1972).

$$F_w = \frac{P_w A}{144}$$

$$A = 42040 \text{ in}^2$$

$$P_w \text{ (PSF)} @ h=70 \text{ FT} \quad f=4.0 \text{ Hz}$$

$$C=3.8 \text{ FT}$$

FOR NORMAL OPERATION

$$F_w = \frac{(4.16)(42040)}{144}$$

$$= 1214.5 \text{ LB}$$

$$\frac{F_w}{D_w} = \frac{1214.5}{46493.9} = .0261 \text{ [EQUIVALENT G-LEVEL]}$$

FOR SURVIVAL CONDITION

$$F_w = \frac{(37.8)(42040)}{144}$$


$$= 11036 \text{ LB}$$

$$\frac{F_w}{D_w} = \frac{11036}{46493.9} = .237 \text{ [EQUIVALENT G-LEVEL]}$$

If use $g = .125$

- multiply wt. of Na Inlet line by $\frac{.112}{.125} = .896$
- " " " Steam line by $\frac{.078}{.125} = .624$
- " " " steam generator by $\frac{.0261}{.125} = .2088$
- " " " Na Inlet heater by $\frac{.081}{.125} = .65$

Since only one value of acceleration can be input in a NUPREP run, it was decided to use .125 g for wind loading cases. Therefore weights of other piping were adjusted as per above factors.

| | | | |
|------------------|---|---------------------------|-----------|
| PREPARED BY: KCG |  Rockwell International Energy Systems Group | 46 PAGE NO. | OF |
| CHECKED BY: | | 079TI000008 REPORT NO. | |
| DATE: 2-8-83 | | | MODEL NO. |

STEAM PIPING

Material : 2 1/4 Cr-1 Mo A 335 P 22

Design Temp. : 1015° F.

$$S_c = 15.0 \text{ ksi}$$

$$S_h @ 1015^\circ F = 7.2 \text{ ksi}$$

$$S_A = .9 (1.25 \times 15 + .25 \times 7.2) = 18.495 \text{ ksi}$$

$$S_h + S_A = 26.06 \text{ ksi}$$

FOR 90MPH WIND $S_h @ 850^\circ F = 14.4 \text{ ksi}$

Sodium Inlet Piping

Material : SS 316 A 312 TP 316.

Design Temp. : 1065° F

However allowables calculated at 1100° F.


$$S_c = 18.7 \text{ ksi}$$

$$S_h @ 1100^\circ F = 12.4 \text{ ksi}$$

$$S_A = .9 (1.25 \times 18.7 + .25 \times 12.4) = 23.8 \text{ ksi}$$

$$S_A + S_h = 36.2 \text{ ksi}$$

FOR 90 MPH WIND, $S_h @ 950^\circ F = 15.4 \text{ ksi}$

| | | |
|-------------------------|---|-------------|
| PREPARED BY: <i>KCJ</i> |  Rockwell International Energy Systems Group | 47 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <i>2-8-83</i> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

Na Outlet Piping

Material : Carbon Steel A106 Grade 'B'

Design temperature : 610° F.

$$S_c = 15 \text{ ksi}$$

$$S_h = 15 \text{ ksi}$$

$$\begin{aligned} S_A &= .9 (1.25 \times 15 + .25 \times 15) \\ &= 20.25 \text{ ksi} \end{aligned}$$

$$S_h + S_A = 35.25 \text{ ksi}$$


```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , OOO
13:43:09 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
13:48:09 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
13:48:09 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
13:48:09 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
13:48:09 IAT4401 LOCATE FOR STEP=G DD=FT12FOO1 DSN=$WW232.SOLAR.WINDD
13:48:09 IAT4402 UNIT=3350 ,VOL(S)=AVTSDA
13:48:09 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=$WW232.CARRIZO.MSG.DATA
13:48:09 IAT4402 UNIT=3350 ,VOL(S)=AVTSDA
13:48:09 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
13:48:09 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
13:48:10 USES CVTSOK 01 048884 D $WWO49.NUPIPE.LOAD
13:48:10 USES AVTSDA 01 048884 D $WW232.SOLAR.WINDD
13:48:10 IAT5200 JOB 2981 ($WW232E1) IN SETUP ON MAIN=C P=07 LOCAL
13:48:10 IAT5210 J=2981 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
13:48:10 IAT5210 J=2981 FT12FOO1 USING D AVTSDA ON 520 $WW232.SOLAR.WINDD
13:50:40 IAT2000 JOB 2981 $WW232E1 SELECTED L GRP=BIG
13:50:41 L R= $WW232E1 NEF995I $WW232E1 STARTED, 2/10/83,13.50.41 ASID=00024
13:50:42 L R= $WW232E1 IEF403I $WW232E1 - STARTED - TIME=13.50.41
13:52:19 L R= $WW232E1 +IH0002I STOP 1
13:52:20 L R= $WW232E1 IEF404I $WW232E1 - ENDED - TIME=13.52.20
13:52:20 L R= $WW232E1 NEF996I $WW232E1 ENDED, 2/10/83,B.U.= 1.4318 *0716935 ,3033-L3,JOB CC= 001
13:52:22 IAT5400 JOB 2981 ($WW232E1) IN BREAKDOWN
/ $WW232E1 JOB 'GURSAHANI LB30130340*0716935 005 5001007037', *
/ REGION=4500K,TIME=2,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RM206 00000300
/* THESE THREE ARE FOR XEROX OUTPUT 00000500
/*FORMAT PR,DDNAME=SYSMMSG,DEST=RM271PR3,FCB=JB10,COPIES=1 00000600
/*FORMAT PR,DDNAME=FT66FOO1,DEST=RM271PR3,FCB=JB10,COPIES=1 00000700
/*FORMAT PR,DDNAME=FT06FOO1,DEST=RM271PR3,FCB=JB10,COPIES=1 00000800
/* THESE THREE ARE FOR MICROFICHE OUTPUT 00001300
/*FORMAT PR,DDNAME=SYSMMSG,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001400
/*FORMAT PR,DDNAME=SYSPRINT,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001500
/*FORMAT PR,DDNAME=SYSUT2,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001600
/ EXEC ROCKPIPE,PROG=SMALL
/G.FT12FOO1 DD VOL=REF=$WW232.REFER,DISP=(,CATLG),
/ SPACE=(TRK,(20,20),RLSE),DCB=(RECFM=VBS,BLKSIZE=19069),
/ DSN=$WW232.SOLAR.WINDD
/G.SYSIN DD DSN=$WW232.CARRIZO.MSG.DATA,DISP=SHR
1 // $WW232E1 JOB 'GURSAHANI LB30130340*0716935 005 5001007037', *
// REGION=4500K,TIME=2,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
*** THESE THREE ARE FOR XEROX OUTPUT 00000500
*** THESE THREE ARE FOR MICROFICHE OUTPUT 00001300
2 // EXEC ROCKPIPE,PROG=SMALL
3 XXROCKPIPE PROC DSN='$WWO49.NUPIPE.LOAD',PROG=SMALL,C=10,
XX PROGA=SEVEN,B=19069,PROGE=OPT2,DSNE='$WWO49.ELTEMP.LOAD'
*** AL HROMJAK ROCKWELL INTERNATIONAL, ESG. COMNET 393-3318
*** FT50FOO1 FOR 7-SPECTRA NODE ACCELERATIONS.
*** IN BOTH STEPS, FT66 CONTAINS DIAGNOSTIC OUTPUT.
*** FT66FOO1 IN G STEP CONTAINS TIME SPENT IN MAJOR PROGRAM PHASES.
*** FT16FOO1 DUMMIED WHEN P STEP DELETED.
4 XXA EXEC PGM=&PROGA
*** THIS STEP READS THE 7 SPECTRA AND TRANSLATES THEM TO A NEW POINT
*** NEW SPECTRA WRITTEN ON FT01FOO1
5 XXSTEPLIB DD DSN=&DSN,DISP=SHR
6 XXFT01FOO1 DD UNIT=SYSDA,DSN=&&SPEC,SPACE=(TRK,(10),RLSE),DISP=(,PASS),
XX DCB=(RECFM=F,LRECL=80,BLKSIZE=80)
7 XXFT05FOO1 DD DDNAME=SYSIN
8 XXFT06FOO1 DD SYSOUT=*
9 XXFT66FOO1 DD DUMMY,DCB=(RECFM=VBA,BLKSIZE=2020)

```

PROGRAM INPUT DATA
 CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

| | | | | | | |
|---|----|-----|-------|--------|-------|------------|
| CONTROL | | | 2.0 | 1.0 | | |
| FLEXAN | 1 | 1 | 4.0 | | 1.0 | 1.0 |
| X-DIRECTION 30 MPH WIND | | | | | | |
| FLEXAN | 2 | 1 | 4.0 | | 3.0 | 1.0 |
| Z-DIRECTION 30 MPH WIND | | | | | | |
| MODFLEX | 3 | 1 2 | 1.0 | 1.0 | 3.0 | 1.0 |
| MAXIMUM OF X AND Z ABSOLUTE 30 MPH WIND | | | | | | |
| MODFLEX | 4 | 3 1 | 9.0 | 0.0 | 1.0 | 1.0 |
| MAXIMUM OF X AND Z ABSOLUTE 90 MPH WIND | | | | | | |
| ACCEL | | | .125 | .125 | | |
| XSECTN | 1 | | 54.22 | 0.721 | 169.6 | 29.9 |
| XSECTN | 2 | | 30.94 | 0.721 | 147.2 | 29.9 |
| XSECTN | 3 | | 21.5 | 1.0 | 121.1 | 29.9 0.0 |
| XSECTN | 4 | | 19.0 | 1.0 | 179.5 | 29.9 0.0 |
| XSECTN | 5 | | 12.81 | 1.0 | 77.3 | 29.9 0.0 |
| XSECTN | 6 | | 26.0 | 1.97 | 207.4 | 29.9 0.0 |
| XSECTN | 7 | | 12.75 | .562 | 10.8 | 29.9 0.0 |
| XSECTN | 8 | | 26.0 | 1.97 | 207.4 | 29.9 0.0 |
| XSECTN | 9 | | 21.0 | 0.86 | 114.1 | 29.9 0.0 |
| XSECTN | 10 | | 18.0 | 0.75 | 90.6 | 29.9 0.0 |
| XSECTN | 11 | | 18.0 | 0.75 | 90.6 | 29.9 0.0 |
| XSECTN | 12 | | 18.0 | 0.75 | 90.6 | 29.9 0.0 |
| XSECTN | 13 | | 18.0 | 0.75 | 90.6 | 29.9 0.0 |
| XSECTN | 14 | | 21.0 | 0.86 | 114.1 | 29.9 0.0 |
| XSECTN | 15 | | 26.0 | 1.97 | 209.2 | 29.9 0.0 |
| XSECTN | 16 | | 12.75 | .562 | 19.2 | 29.9 0.0 |
| XSECTN | 17 | | 26.0 | 1.97 | 209.2 | 29.9 0.0 |
| XSECTN | 18 | | 24.0 | 1.0 | 109.5 | 29.9 0.0 |
| XSECTN | 19 | | 26.0 | 1.97 | 193.7 | 29.9 0.0 |
| XSECTN | 20 | | 21.5 | 1.0 | 124.5 | 29.9 0.0 |
| XSECTN | 21 | | 19.0 | 1.0 | 179.5 | 29.9 0.0 |
| XSECTN | 22 | | 12.81 | 1.0 | 78.7 | 29.9 0.0 |
| XSECTN800 | 23 | | 12.75 | 0.562 | 10.4 | 299. 0.0 |
| XSECT1700 | 24 | | 12.75 | 0.562 | 18.0 | 299. 0.0 |
| XSECTN | 25 | | 6.625 | 0.864 | 53.4 | 29.9 1590. |
| XSECTN NA | 26 | | 6.625 | 0.864 | | 29.9 1590. |
| XSECTN NA | 27 | | 12.75 | 0.406 | 175. | 28.3 65. |
| XSECTN | 28 | | 6.625 | 0.280 | 88.3 | 28.3 65. |
| XSECTN NA | 29 | | 12.75 | 0.406 | 130. | 27.9 65. |
| XSECTN | 30 | | 6.625 | 0.280 | 53.4 | 27.9 65. |
| XSECTN | 31 | | 12.75 | 0.687 | 218.8 | 28.3 65. |
| XSECTN NA | 32 | | 6.625 | 0.280 | | 27.9 65. |
| XSECTN | 33 | | 12.75 | 0.687 | 218.8 | 27.9 65. |
| XSECTN | 34 | | 10.75 | 0.365 | 100.2 | 28.3 65. |
| OPVAL225 | 1 | 1 | 29.4 | .01198 | | |
| OPVAL435 | 1 | 2 | 28.4 | .03022 | | |
| OPVAL470 | 1 | 3 | 28.2 | .03344 | | |
| OPVAL450 | 1 | 4 | 28.3 | .03160 | | |
| OPVAL450 | 1 | 5 | 28.3 | .03160 | | |
| OPVAL620 | 1 | 6 | 27.2 | .04086 | | |
| OPVAL620 | 1 | 7 | 27.2 | .04086 | | |
| OPVAL625 | 1 | 8 | 27.2 | .04858 | | |
| OPVAL640 | 1 | 9 | 27.1 | .05012 | | |
| OPVAL705 | 1 | 10 | 26.6 | .05684 | | |
| OPVAL865 | 1 | 11 | 24.9 | .07422 | | |
| OPVAL | 1 | 12 | 22.7 | .09005 | | |
| OPVAL | 1 | 13 | 21.7 | .09465 | | |
| OPVAL | 1 | 14 | 21.6 | .09523 | | |

| | | | | | |
|------------|---|----|-------|--------|-------|
| OPVAL 1057 | 1 | 15 | 21.5 | .09546 | |
| OPVAL 1065 | 1 | 16 | 21.3 | .09638 | |
| OPVAL 1055 | 1 | 17 | 21.6 | .09523 | |
| OPVAL 1025 | 1 | 18 | 22.4 | .09178 | |
| OPVAL 1020 | 1 | 19 | 22.5 | .09120 | |
| OPVAL 1020 | 1 | 20 | 22.5 | .09120 | |
| OPVAL 1015 | 1 | 21 | 22.6 | .09063 | |
| OPVAL 1015 | 1 | 22 | 22.6 | .09063 | |
| OPVAL 800 | 1 | 23 | 273.0 | .04703 | |
| OPVAL 1065 | 1 | 24 | 213.0 | .09638 | |
| OPVAL 1015 | 1 | 25 | 22.60 | .09063 | 1590. |
| OPVAL NA | 1 | 26 | 22.74 | .09005 | 1590. |
| OPVAL NA | 1 | 27 | 22.4 | .12364 | 65. |
| OPVAL 1065 | 1 | 28 | 22.4 | .12364 | 65. |
| OPVAL NA | 1 | 29 | 25.61 | .04703 | 65. |
| OPVAL 610 | 1 | 30 | 25.61 | .04703 | 65. |
| OPVAL 201 | 2 | 1 | 29.5 | .00998 | |
| OPVAL 381 | 2 | 2 | 29.1 | .02533 | |
| OPVAL 420 | 2 | 3 | 28.5 | .02884 | |
| OPVAL 400 | 2 | 4 | 28.5 | .02700 | |
| OPVAL 400 | 2 | 5 | 28.5 | .02700 | |
| OPVAL 550 | 2 | 6 | 27.7 | .04110 | |
| OPVAL 570 | 2 | 7 | 27.6 | .04306 | |
| OPVAL 575 | 2 | 8 | 27.6 | .04355 | |
| OPVAL 585 | 2 | 9 | 27.5 | .04453 | |
| OPVAL 650 | 2 | 10 | 27.0 | .05115 | |
| OPVAL 770 | 2 | 11 | 26.0 | .06379 | |
| OPVAL 890 | 2 | 12 | 24.6 | .07699 | |
| OPVAL 940 | 2 | 13 | 23.9 | .08242 | |
| OPVAL 942 | 2 | 14 | 23.9 | .08264 | |
| OPVAL 948 | 2 | 15 | 23.8 | .08328 | |
| OPVAL 950 | 2 | 16 | 23.8 | .08350 | |
| OPVAL 950 | 2 | 17 | 23.8 | .08350 | |
| OPVAL 910 | 2 | 18 | 24.4 | .07918 | |
| OPVAL 905 | 2 | 19 | 24.4 | .07864 | |
| OPVAL 902 | 2 | 20 | 24.5 | .07832 | |
| OPVAL 900 | 2 | 21 | 24.5 | .07810 | |
| OPVAL 900 | 2 | 22 | 24.5 | .07810 | |
| OPVAL 570 | 2 | 23 | 276.0 | .04306 | |
| OPVAL 950 | 2 | 24 | 237.5 | .08350 | |
| OPVAL 850 | 2 | 25 | 25.1 | .07255 | 1590. |
| OPVAL NA | 2 | 26 | 22.74 | .09005 | 1590. |
| OPVAL NA | 2 | 27 | 23.2 | .10800 | 65. |
| OPVAL 950 | 2 | 28 | 23.2 | .10800 | 65. |
| OPVAL NA | 2 | 29 | 27.4 | .0182 | 65. |
| OPVAL 300 | 2 | 30 | 27.4 | .0182 | 65. |
| OPVAL 226 | 3 | 1 | 29.4 | .01206 | 65. |
| OPVAL 492 | 3 | 2 | 28.0 | .03546 | 65. |
| OPVAL 600 | 3 | 3 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 4 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 5 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 6 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 7 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 8 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 9 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 10 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 11 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 12 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 13 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 14 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 15 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 16 | 27.4 | .0460 | 65. |

| | | | | | | |
|-----------|------|------|---------|--------|---------|-------|
| OPVAL 600 | 3 | 17 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 18 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 19 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 20 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 21 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 22 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 23 | 274.0 | .0460 | | 65. |
| OPVAL 600 | 3 | 24 | 274.0 | .0460 | | 65. |
| OPVAL 70 | 3 | 25 | 29.9 | | | 1590. |
| OPVAL NA | 3 | 26 | 22.74 | | | 1590. |
| OPVAL NA | 3 | 27 | 25.6 | .0624 | | 65. |
| OPVAL 600 | 3 | 28 | 25.6 | .0624 | | 65. |
| OPVAL NA | 3 | 29 | 27.4 | .0182 | | 65. |
| OPVAL 300 | 3 | 30 | 27.4 | .0182 | | 65. |
| ANCHOR | | 1 | | | | |
| RUN | 1 | 2 | | 5.0 | 1.0 | 1.0 |
| RUN | 2 | 3 | | 1.489 | 2.0 | 2.0 |
| RUN | 3 | 4 | | -1.667 | 3.0 | 3.0 |
| RUN | 4 | 5 | | -.646 | 4.0 | 4.0 |
| RUN | 5 | 6 | | -1.896 | 5.0 | 5.0 |
| RUN | 3 | 7 | | 5.146 | 6.0 | 6.0 |
| TEE | 7 | 800 | | | | |
| RUN | 7 | 9 | | 1.417 | 8.0 | 8.0 |
| REDUCER | 9 | 10 | | 1.666 | 9.0 | 9.0 |
| RUN | 10 | 8001 | | 5.097 | 10.0 | 10.0 |
| RUN | 8001 | 8002 | | 5.097 | 10.0 | 10.0 |
| RUN | 8002 | 11 | | 5.097 | 10.0 | 10.0 |
| RUN | 11 | 8003 | | 5.083 | 11.0 | 11.0 |
| RUN | 8003 | 8004 | | 5.083 | 11.0 | 11.0 |
| RUN | 8004 | 12 | | 5.083 | 11.0 | 11.0 |
| RUN | 12 | 8005 | | 5.083 | 12.0 | 12.0 |
| RUN | 8005 | 8006 | | 5.083 | 12.0 | 12.0 |
| RUN | 8006 | 13 | | 5.083 | 12.0 | 12.0 |
| RESTRAINT | | 13 | 100000. | | 100000. | |
| RUN | 13 | 14 | | 0.667 | 13.0 | 13.0 |
| REDUCER | 14 | 15 | | 1.666 | 14.0 | 14.0 |
| RUN | 15 | 16 | | 1.417 | 15.0 | 15.0 |
| TEE | 16 | 1700 | | | | |
| RUN | 16 | 18 | | 5.563 | 17.0 | 17.0 |
| ELBOW | 18 | 19 | 24.0 | | 18.0 | 18.0 |
| RUN | 19 | 20 | -4.0 | | 19.0 | 19.0 |
| REDUCER | 20 | 21 | -1.0 | | 20.0 | 20.0 |
| RUN | 21 | 22 | -0.646 | | 21.0 | 21.0 |
| REDUCER | 22 | 23 | -1.333 | | 22.0 | 22.0 |
| RUN | 7 | 800 | 1.083 | | 23.0 | 23.0 |
| RUN | 800 | 8 | 0.958 | | 7.0 | 7.0 |
| RUN | 16 | 1700 | 1.083 | | 24.0 | 24.0 |
| RUN | 1700 | 17 | 1.709 | | 16.0 | 16.0 |
| RUN | 23 | 25 | -1.375 | | 25.0 | 25.0 |
| RUN | 25 | 105 | -1.500 | | 25.0 | 25.0 |
| RESTRAINT | | 105 | | 1.0 | | |
| CWEIGHT | | 105 | | 10.0 | | |
| RUN | 105 | 106 | -0.25 | | | |
| RESTRAINT | | 106 | | | 50000. | |
| CWEIGHT | | 106 | | 10.0 | | |
| RUN | 106 | 110 | -4.396 | | 25.0 | 25.0 |
| RUN | 110 | 115 | -1.5 | | | |
| RUN | 115 | 120 | -1.5 | | | |
| RUN | 120 | 122 | -1.00 | | | |
| SNUBBE | | 122 | | 2. | | |
| CWEIGHT | | 122 | | 15.0 | | |
| RUN | 122 | 123 | -0.25 | | | |

| | | | | | | | |
|-----------|-----|--------|-------|---------|--------|------|------|
| RESTRAINT | 123 | | | 1.0 | | | |
| CWEIGHT | 123 | | | 10.0 | | | |
| RUN | 123 | 125 | -1.25 | | | | |
| ELBOW | 125 | 130 | | | | | |
| RUN | 130 | 135 | | -1.5 | | | |
| SNUBBER | 135 | 2. | | | | | |
| CWEIGHT | 135 | | | 15.0 | | | |
| RUN | 135 | 138 | | -0.25 | | | |
| RESTRAINT | 138 | | | | 50000. | | |
| CWEIGHT | 138 | | | 10.0 | | | |
| RUN | 138 | 139 | | -18.031 | | | |
| RESTRAINT | 139 | | | | 50000. | | |
| CWEIGHT | 139 | | | 10.0 | | | |
| RUN | 139 | 140 | | -0.25 | | | |
| SNUBBER | 140 | 2. | | | | | |
| CWEIGHT | 140 | | | 15.0 | | | |
| RUN | 140 | 142 | | -2.875 | | | |
| RUN | 142 | 144 | | -3.297 | | | |
| ELBOW | 144 | 145 | | | | | |
| RUN | 145 | 148 | 1.5 | | | | |
| RESTRAINT | 148 | | | 1.0 | | | |
| CWEIGHT | 148 | | | 10.0 | | | |
| RUN | 148 | 150 | 3.0 | | | | |
| RUN | 150 | 155 | 1.0 | | | | |
| RUN | 155 | 160 | 1.0 | | | | |
| RUN | 160 | 162 | 1.75 | | | | |
| SNUBBER | 162 | | | 2. | | | |
| CWEIGHT | 162 | | | 15.0 | | | |
| RUN | 162 | 163 | 4.75 | | | | |
| RESTRAINT | 163 | | | 1.0 | | | |
| CWEIGHT | 163 | | | 10.0 | | | |
| RUN | 163 | 165 | 1.0 | | | | |
| ELBOW | 165 | 170 | | | | | |
| RUN | 170 | 172 | | -3.0 | | | |
| RESTRAINT | 172 | | | | 50000. | | |
| CWEIGHT | 172 | | | 10.0 | | | |
| RUN | 172 | 173 | | -3.0 | | | |
| RESTRAINT | 173 | 50000. | | | | | |
| CWEIGHT | 173 | | | 10.0 | | | |
| RUN | 173 | 175 | | -14.0 | | | |
| RESTRAINT | 175 | | | | 50000. | | |
| CWEIGHT | 175 | | | 10.0 | | | |
| RUN | 175 | 177 | | -2.422 | | | |
| RUN | 177 | 180 | | -3.781 | | | |
| ELBOW | 180 | 185 | | | | | |
| RUN | 185 | 190 | -2.0 | | | | |
| RUN | 190 | 195 | -4.0 | | | | |
| ANCHOR | 195 | -12.0 | | 17.417 | | | |
| RUN | 17 | 295 | 4.5 | | | 31.0 | 28.0 |
| REDUCER | 295 | 310 | .667 | | | 28.0 | |
| RUN | 310 | 320 | 2.0 | | | | |
| RUN | 320 | 330 | 2.0 | | | | |
| RUN | 330 | 335 | 1.041 | | | | |
| RESTRAINT | 335 | | | 1.0 | | | |
| RUN | 335 | 340 | 3.0 | | | | |
| ELBOW | 340 | 350 | | | | | |
| RUN | 350 | 360 | | -2.25 | | | |
| RESTRAINT | 360 | | | | 50000. | | |
| CWEIGHT | 360 | | | 10.0 | | | |
| RUN | 360 | 361 | | -0.25 | | | |
| SNUBBER | 361 | 2. | | | | | |
| CWEIGHT | 361 | | | 15.0 | | | |

| | | | | | | | | |
|-----------|------|------|--------|--------|--------|------|------|--|
| RUN | 361 | 365 | | -16.75 | | | | |
| RESTRAINT | | 365 | | | 50000. | | | |
| CWEIGHT | | 365 | | 10.0 | | | | |
| RUN | 365 | 369 | | -0.25 | | | | |
| SNUBBER | | 369 | 2. | | | | | |
| CWEIGHT | | 369 | | 10.0 | | | | |
| RUN | 369 | 370 | | -3.5 | | | | |
| ELBOW | 370 | 380 | | | | | | |
| RUN | 380 | 382 | -1.0 | | | | | |
| SNUBBER | | 382 | | 2. | | | | |
| CWEIGHT | | 382 | | 15.0 | | | | |
| RUN | 382 | 385 | -4.5 | | | | | |
| RESTRAINT | | 385 | | 1.0 | | | | |
| CWEIGHT | | 385 | | 10.0 | | | | |
| RUN | 385 | 390 | -5.5 | | | | | |
| ELBOW | 390 | 400 | | | | | | |
| RUN | 400 | 405 | | -1.25 | | | | |
| RESTRAINT | | 405 | 50000. | | | | | |
| CWEIGHT | | 405 | | 10.0 | | | | |
| RUN | 405 | 406 | | -.25 | | | | |
| RESTRAINT | | 406 | | | 50000. | | | |
| CWEIGHT | | 406 | | 10.0 | | | | |
| RUN | 406 | 408 | | -10.0 | | | | |
| SNUBBER | | 408 | 2. | | | | | |
| CWEIGHT | | 408 | | 15.0 | | | | |
| RUN | 408 | 410 | | -6.0 | | | | |
| RESTRAINT | | 410 | | | 50000. | | | |
| CWEIGHT | | 410 | | 10.0 | | | | |
| RUN | 410 | 420 | | -6.343 | | | | |
| ELBOW | 420 | 430 | | | | | | |
| RUN | 430 | 435 | 1.0 | | | | | |
| RESTRAINT | | 435 | | | 50000. | | | |
| CWEIGHT | | 435 | | 10.0 | | | | |
| RUN | 435 | 440 | 4.5 | | | | | |
| RUN | 440 | 450 | 5.5 | | | | | |
| ANCHOR | | 450 | 16.0 | 17.416 | | | | |
| RUN | 8 | 495 | 2.541 | | | 33.0 | 30.0 | |
| REDUCER | 495 | 510 | 1.416 | | | 30.0 | | |
| ELBOW | 510 | 520 | | | | | | |
| RUN | 520 | 530 | | | 4.0 | | | |
| ELBOW | 530 | 540 | | | | | | |
| RUN | 540 | 550 | 2.5 | | | | | |
| RUN | 550 | 560 | 2.0 | | | | | |
| RUN | 560 | 570 | 2.0 | | | | | |
| RUN | 570 | 575 | 1.0 | | | 30.0 | | |
| RESTRAINT | | 575 | | 1.0 | | | | |
| RUN | 575 | 580 | 1.5 | | | | | |
| ELBOW | 580 | 590 | | | | | | |
| RUN | 590 | 600 | | | -4.0 | | | |
| ELBOW | 600 | 610 | | | | | | |
| RUN | 610 | 620 | 2.25 | | | | | |
| RUN | 620 | 630 | 2.25 | | | | | |
| ANCHOR | | 630 | 19.5 | 11.635 | | | | |
| RUN | 450 | 1450 | | | 5.5 | 34.0 | 28.0 | |
| ELBOW | 1450 | 1460 | | | | | | |
| RUN | 1460 | 1465 | 4.75 | | | | | |
| RUN | 1465 | 1467 | 3.5 | | | | | |
| SNUBBER | | 1467 | | | 2. | | | |
| CWEIGHT | | 1467 | | 15.0 | | | | |
| RUN | 1467 | 1468 | 0.25 | | | | | |
| RES | IT | 1468 | | 50000. | | | | |
| CWE | | 1468 | | 10.0 | | | | |

| | | | | | |
|--|------|------|------|--------|------|
| RUN | 1468 | 1470 | 1.00 | | |
| ELBOW | 1470 | 1480 | | | |
| RUN | 1480 | 1485 | | 5.5 | |
| RUN | 1485 | 1490 | | 5.5 | |
| ELBOW | 1490 | 1495 | | | |
| RUN | 1495 | 1500 | -1.0 | | |
| RESTRAINT | | 1500 | | 50000. | |
| CWEIGHT | | 1500 | | 10.0 | |
| RUN | 1500 | 1502 | -2.5 | | |
| RUN | 1502 | 1503 | -2.5 | | |
| RUN | 1503 | 1505 | -3.5 | | |
| ELBOW | 1505 | 1510 | | | |
| RUN | 1510 | 1520 | | 5.5 | |
| ANCHOR | | 1520 | 16.0 | 17.416 | 22.0 |
| MASSPT | | 2 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 9 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 18 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 20 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 22 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 25 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 140 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 150 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 160 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 180 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 17 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 295 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 340 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 370 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 420 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 390 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 510 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 530 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 550 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 570 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 580 | 1.0 | 1.0 | 1.0 |
| MASSPT | | 600 | 1.0 | 1.0 | 1.0 |
| STRESS7 | | | | | |
| 9CASES | 1 | | | | |
| 10CASES | 2 | 3 | 4 | | |
| ALLDONE | | | | | |
| IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , OOO | | | | | |
| 13:59:39 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=\$WWO49.NUPIPE.LOAD | | | | | |
| 13:59:39 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | | | | |
| 13:59:39 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=\$WWO49.NUPIPE.LOAD | | | | | |
| 13:59:39 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | | | | |
| 13:59:39 IAT4401 LOCATE FOR STEP=G DD=FT11FOO1 DSN=\$WW232.SOLAR.WINDD | | | | | |
| 13:59:39 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA | | | | | |
| 13:59:39 IAT4401 LOCATE FOR STEP=G DD=FT12FOO1 DSN=\$WW232.SOLAR.WINDY | | | | | |
| 13:59:39 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA | | | | | |
| 13:59:39 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=\$WW232.CARRIZO.DEADWT.DATA | | | | | |
| 13:59:39 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA | | | | | |
| 13:59:39 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=\$WWO49.ELTEMP.LOAD | | | | | |
| 13:59:39 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | | | | |
| 13:59:40 USES CVTSOK D \$WWO49.NUPIPE.LOAD | | | | | |
| 13:59:40 USES AVTSOA D \$WW232.SOLAR.WINDD | | | | | |
| 13:59:40 IAT5200 JOB 3245 (\$WW232E2) IN SETUP ON MAIN=C P=03 LOCAL | | | | | |
| 13:59:40 IAT5210 J=3245 STEPLIB USING D CVTSOK ON 528 \$WWO49.NUPIPE.LOAD | | | | | |
| 13:59:40 IAT5210 J=3245 FT11FOO1 USING D AVTSOA ON 520 \$WW232.SOLAR.WINDD | | | | | |
| 13:59:44 IAT2000 JOB 3245 \$WW232E2 SELECTED L GRP=BIG | | | | | |
| 13:59:44 L R= \$WW232E2 NEF995I \$WW232E2 STARTED, 2/10/83,13.59.44 ASID=00012 | | | | | |
| 13:59:45 L R= \$WW232E2 IEF403I \$WW232E2 - STARTED - TIME=13.59.44 | | | | | |
| 14:00:59 L R= \$WW232E2 +IH0002I STOP 1 | | | | | |

55 079TI000008

```

14:01:00 L R= $WW232E2 IEF404I $WW232E2 - ENDED - TIME=14.01.00
14:01:00 L R= $WW232E2 NEF996I $WW232E2 ENDED, 2/10/83,B.U.= 1.1229 *0716935 ,3033-L3,JOB CC= 001
14:01:04 IAT5400 JOB 3245 ($WW232E2) IN BREAKDOWN
/$WW232E2 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RM206 00000300
/* THESE THREE ARE FOR XEROX OUTPUT 00000500
/*FORMAT PR,DDNAME=SYSMSG,DEST=RM271PR3,FCB=JB10,COPIES=1 00000600
/*FORMAT PR,DDNAME=FT66FOO1,DEST=RM271PR3,FCB=JB10,COPIES=1 00000700
/*FORMAT PR,DDNAME=FTO6FOO1,DEST=RM271PR3,FCB=JB10,COPIES=1 00000800
/* THESE THREE ARE FOR MICROFICHE OUTPUT 00001300
/*FORMAT PR,DDNAME=SYSMSG,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001400
/*FORMAT PR,DDNAME=SYSRINT,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001500
/*FORMAT PR,DDNAME=SYSUT2,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001600
/ EXEC ROCKPIPE,PROG=SMALL
/G.FT11FOO1 DD DSN=$WW232.SOLAR.WINDD,DISP=SHR
/G.FT12FOO1 DD VOL=REF=$WW232.REFER,DISP=(,CATLG),
/ SPACE=(TRK,(20,20),RLSE),DCB=(RECFM=VBS,BLKSIZE=19069),
/ DSN=$WW232.SOLAR.WINDY
/G.SYSIN DD DSN=$WW232.CARRIZO.DEADWT.DATA,DISP=SHR
1 // $WW232E2 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
// REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
*** THESE THREE ARE FOR XEROX OUTPUT 00000500
*** THESE THREE ARE FOR MICROFICHE OUTPUT 00001300
2 // EXEC ROCKPIPE,PROG=SMALL
3 XXROCKPIPE PROC DSN='$WVO49.NUPIE.LOAD',PROG=SMALL,C=10,
XX PRDGA=SEVEN,B=19069,PROGE=OPT2,DSNE='$WVO49.ELTEMP.LOAD'
*** AL HROMJAK ROCKWELL INTERNATIONAL, ESG. COMNET 393-3318
*** FT50FOO1 FOR 7-SPECTRA NODE ACCELERATIONS.
*** IN BOTH STEPS, FT66 CONTAINS DIAGNOSTIC OUTPUT.
*** FT66FOO1 IN G STEP CONTAINS TIME SPENT IN MAJOR PROGRAM PHASES.
*** FT16FOO1 DUMMIED WHEN P STEP DELETED.
*** FT17FOO1, FT18FOO1, FT19FOO1, FT20FOO1 ADDED FOR SNUBBER ITERATIONS
4 XXA EXEC PGM=&PROGA
*** THIS STEP READS THE 7 SPECTRA AND TRANSLATES THEM TO A NEW POINT
*** NEW SPECTRA WRITTEN ON FTO1FOO1
5 XXSTEPLIB DD DSN=&DSN,DISP=SHR
6 XXFTO1FOO1 DD UNIT=SYSDA,DSN=&&SPEC,SPACE=(TRK,(10),RLSE),DISP=(,PASS),
XX DCB=(RECFM=F,LRECL=80,BLKSIZE=80)
7 XXFTO5FOO1 DD DDNAME=SYSIN
8 XXFTO6FOO1 DD SYSOUT=*
9 XXFT66FOO1 DD DUMMY,DCB=(RECFM=VBA,BLKSIZE=2020)
10 XXG EXEC PGM=&PROG
*** THIS STEP EXECUTES ROCKPIPE. LOAD CASES, 7-SPECTRA (IF ANY), AND
*** GEOMETRY ARE READ FROM UNIT FT15'S 3 CONCATANATED DATA SETS. LOAD
*** CASES TO BE DELETED FROM PRINTING ARE DETECTED AND THE CASE NO.'S
*** MADE PLUS. ALL 3 FILES FROM FT15 ARE WRITTEN ON FT05 AS ONE FILE TO
*** BE READ BY NUPIE.
11 XXSTEPLIB DD DSN=&DSN,DISP=SHR
12 XXFTO1FOO1 DD UNIT=SYSDA,DCB=(RECFM=VBS,BLKSIZE=&B),
XX SPACE=(CYL,(&C,&C))
13 XXFTO2FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
14 XXFTO3FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
15 XXFTO4FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
16 XXFTO5FOO1 DD UNIT=SYSDA,SPACE=(80,(20000)),
XX DCB=(RECFM=FB,LRECL=80,BLKSIZE=19040)
17 XXFTO6FOO1 DD SYSOUT=*
18 XXFTO7FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
19 XXFTO8FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
20 XXFTO9FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
21 XXFT10FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
22 //G.FT11FOO1 DD DSN=$WW232.SOLAR.WINDD,DISP=SHR

```

PROGRAM INPUT DATA
 CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

| | | | | | | |
|---|-------|-------|--------|--------|------|-------|
| CONTROL | | 2.0 | 1.0 | | | 4.0 |
| FLEXAN | 1 1 | 4.0 | | 1.0 | 1.0 | |
| X-DIRECTION 30 MPH WIND | | | | | | |
| FLEXAN | 2 1 | 4.0 | | 3.0 | 1.0 | |
| Z-DIRECTION 30 MPH WIND | | | | | | |
| MODFLEX | 3 1 2 | 1.0 | 1.0 | 3.0 | 1.0 | |
| MAXIMUM OF X AND Z ABSOLUTE 30 MPH WIND | | | | | | |
| MODFLEX | 4 3 1 | 9.0 | 0.0 | 1.0 | 1.0 | |
| MAXIMUM OF X AND Z ABSOLUTE 90 MPH WIND | | | | | | |
| FLEXAN | 5 1 | 17.0 | | | 1.0 | |
| DEADWEIGHT | | | | | | |
| ACCEL | | .4 | .2667 | .4 | | |
| XSECTN | 1 | 54.22 | 0.721 | 812.0 | 29.9 | |
| XSECTN | 2 | 30.94 | 0.721 | 705.1 | 29.9 | |
| XSECTN | 3 | 21.5 | 1.0 | 580.1 | 29.9 | 0.0 |
| XSECTN | 4 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 |
| XSECTN | 5 | 12.81 | 1.0 | 370.3 | 29.9 | 0.0 |
| XSECTN | 6 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 |
| XSECTN | 7 | 12.75 | .562 | 51.7 | 29.9 | 0.0 |
| XSECTN | 8 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 |
| XSECTN | 9 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 |
| XSECTN | 10 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 11 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 12 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 13 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 14 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 |
| XSECTN | 15 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 |
| XSECTN | 16 | 12.75 | .562 | 92.1 | 29.9 | 0.0 |
| XSECTN | 17 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 |
| XSECTN | 18 | 24.0 | 1.0 | 524.4 | 29.9 | 0.0 |
| XSECTN | 19 | 26.0 | 1.97 | 927.5 | 29.9 | 0.0 |
| XSECTN | 20 | 21.5 | 1.0 | 596.4 | 29.9 | 0.0 |
| XSECTN | 21 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 |
| XSECTN | 22 | 12.81 | 1.0 | 376.9 | 29.9 | 0.0 |
| XSECTN800 | 23 | 12.75 | 0.562 | 51.7 | 299. | 0.0 |
| XSECT1700 | 24 | 12.75 | 0.562 | 89.8 | 299. | 0.0 |
| XSECTN | 25 | 6.625 | 0.864 | 85.5 | 29.9 | 1590. |
| XSECTN NA | 26 | 6.625 | 0.864 | | 29.9 | 1590. |
| XSECTN NA | 27 | 12.75 | 0.406 | 175. | 28.3 | 65. |
| XSECTN | 28 | 6.625 | 0.280 | 98.5 | 28.3 | 65. |
| XSECTN NA | 29 | 12.75 | 0.406 | 130. | 27.9 | 65. |
| XSECTN | 30 | 6.625 | 0.280 | 53.4 | 27.9 | 65. |
| XSECTN | 31 | 12.75 | 0.687 | 218.8 | 28.3 | 65. |
| XSECTN NA | 32 | 6.625 | 0.280 | | 27.9 | 65. |
| XSECTN | 33 | 12.75 | 0.687 | 218.8 | 27.9 | 65. |
| XSECTN | 34 | 10.75 | 0.365 | 154.6 | 28.3 | 65. |
| OPVAL225 | 1 1 | 29.4 | .01198 | | | |
| OPVAL435 | 1 2 | 28.4 | .03022 | | | |
| OPVAL470 | 1 3 | 28.2 | .03344 | | | |
| OPVAL450 | 1 4 | 28.3 | .03160 | | | |
| OPVAL450 | 1 5 | 28.3 | .03160 | | | |
| OPVAL620 | 1 6 | 27.2 | .04086 | | | |
| OPVAL620 | 1 7 | 27.2 | .04086 | | | |
| OPVAL625 | 1 8 | 27.2 | .04858 | | | |
| OPVAL640 | 1 9 | 27.1 | .05012 | | | |
| OPVAL705 | 1 10 | 26.6 | .05684 | | | |
| OPVAL865 | 1 11 | 24.9 | .07422 | | | |
| OPVAL1010 | 1 12 | 22.7 | .09005 | | | |

| | | | | | | |
|------------|---|----|-------|--------|-------|-----|
| OPVAL 1050 | 1 | 13 | 21.7 | .09465 | | |
| OPVAL 1055 | 1 | 14 | 21.6 | .09523 | | |
| OPVAL 1057 | 1 | 15 | 21.5 | .09546 | | |
| OPVAL 1065 | 1 | 16 | 21.3 | .09638 | | |
| OPVAL 1055 | 1 | 17 | 21.6 | .09523 | | |
| OPVAL 1025 | 1 | 18 | 22.4 | .09178 | | |
| OPVAL 1020 | 1 | 19 | 22.5 | .09120 | | |
| OPVAL 1020 | 1 | 20 | 22.5 | .09120 | | |
| OPVAL 1015 | 1 | 21 | 22.6 | .09063 | | |
| OPVAL 1015 | 1 | 22 | 22.6 | .09063 | | |
| OPVAL 800 | 1 | 23 | 273.0 | .04703 | | |
| OPVAL 1065 | 1 | 24 | 213.0 | .09638 | | |
| OPVAL 1015 | 1 | 25 | 22.60 | .09063 | 1590. | |
| OPVAL NA | 1 | 26 | 22.74 | .09005 | 1590. | |
| OPVAL NA | 1 | 27 | 22.4 | .12364 | 65. | |
| OPVAL 1065 | 1 | 28 | 22.4 | .12364 | 65. | |
| OPVAL NA | 1 | 29 | 25.61 | .04703 | 65. | |
| OPVAL 610 | 1 | 30 | 25.61 | .04703 | 65. | |
| OPVAL 201 | 2 | 1 | 29.5 | .00998 | | |
| OPVAL 381 | 2 | 2 | 29.1 | .02533 | | |
| OPVAL 420 | 2 | 3 | 28.5 | .02884 | | |
| OPVAL 400 | 2 | 4 | 28.5 | .02700 | | |
| OPVAL 400 | 2 | 5 | 28.5 | .02700 | | |
| OPVAL 550 | 2 | 6 | 27.7 | .04110 | | |
| OPVAL 570 | 2 | 7 | 27.6 | .04306 | | |
| OPVAL 575 | 2 | 8 | 27.6 | .04355 | | |
| OPVAL 585 | 2 | 9 | 27.5 | .04453 | | |
| OPVAL 650 | 2 | 10 | 27.0 | .05115 | | |
| OPVAL 770 | 2 | 11 | 26.0 | .06379 | | |
| OPVAL 890 | 2 | 12 | 24.6 | .07699 | | |
| OPVAL 940 | 2 | 13 | 23.9 | .08242 | | |
| OPVAL 942 | 2 | 14 | 23.9 | .08264 | | |
| OPVAL 948 | 2 | 15 | 23.8 | .08328 | | |
| OPVAL 950 | 2 | 16 | 23.8 | .08350 | | |
| OPVAL 950 | 2 | 17 | 23.8 | .08350 | | |
| OPVAL 910 | 2 | 18 | 24.4 | .07918 | | |
| OPVAL 905 | 2 | 19 | 24.4 | .07864 | | |
| OPVAL 902 | 2 | 20 | 24.5 | .07832 | | |
| OPVAL 900 | 2 | 21 | 24.5 | .07810 | | |
| OPVAL 900 | 2 | 22 | 24.5 | .07810 | | |
| OPVAL 570 | 2 | 23 | 276.0 | .04306 | | |
| OPVAL 950 | 2 | 24 | 237.5 | .08350 | | |
| OPVAL 850 | 2 | 25 | 25.1 | .07255 | 1590. | |
| OPVAL NA | 2 | 26 | 22.74 | .09005 | 1590. | |
| OPVAL NA | 2 | 27 | 23.2 | .10800 | 65. | |
| OPVAL 950 | 2 | 28 | 23.2 | .10800 | 65. | |
| OPVAL NA | 2 | 29 | 27.4 | .0182 | 65. | |
| OPVAL 300 | 2 | 30 | 27.4 | .0182 | 65. | |
| OPVAL 226 | 3 | 1 | 29.4 | .01206 | 65. | |
| OPVAL 492 | 3 | 2 | 28.0 | .03546 | 65. | |
| OPVAL 600 | 3 | 3 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 4 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 5 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 6 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 7 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 8 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 9 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 10 | 27.4 | .0460 | 65. | |
| OPVAL 600 | 3 | 11 | 27.4 | .0460 | 65. | |
| OPV | 0 | 3 | 12 | 27.4 | .0460 | 65. |
| OPV | 0 | 3 | 13 | 27.4 | .0460 | 65. |
| OPV | 0 | 3 | 14 | 27.4 | .0460 | 65. |

| | | | | | | |
|-----------|------|------|---------|--------|---------|-------|
| OPVAL 600 | 3 | 15 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 16 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 17 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 18 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 19 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 20 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 21 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 22 | 27.4 | .0460 | | 65. |
| OPVAL 600 | 3 | 23 | 274.0 | .0460 | | 65. |
| OPVAL 600 | 3 | 24 | 274.0 | .0460 | | 65. |
| OPVAL 70 | 3 | 25 | 29.9 | | | 1590. |
| OPVAL NA | 3 | 26 | 22.74 | | | 1590. |
| OPVAL NA | 3 | 27 | 25.6 | .0624 | | 65. |
| OPVAL 600 | 3 | 28 | 25.6 | .0624 | | 65. |
| OPVAL NA | 3 | 29 | 27.4 | .0182 | | 65. |
| OPVAL 300 | 3 | 30 | 27.4 | .0182 | | 65. |
| ANCHOR | | 1 | | | | |
| RUN * | 1 | 2 | | 5.0 | 1.0 | 1.0 |
| RUN | 2 | 3 | | 1.489 | 2.0 | 2.0 |
| RUN | 3 | 4 | | -1.667 | 3.0 | 3.0 |
| RUN | 4 | 5 | | -.646 | 4.0 | 4.0 |
| RUN | 5 | 6 | | -1.896 | 5.0 | 5.0 |
| RUN | 3 | 7 | | 5.146 | 6.0 | 6.0 |
| TEE | 7 | 800 | | | | |
| RUN | 7 | 9 | | 1.417 | 8.0 | 8.0 |
| REDUCER | 9 | 10 | | 1.666 | 9.0 | 9.0 |
| RUN | 10 | 8001 | | 5.097 | 10.0 | 10.0 |
| RUN | 8001 | 8002 | | 5.097 | 10.0 | 10.0 |
| RUN | 8002 | 11 | | 5.097 | 10.0 | 10.0 |
| RUN | 11 | 8003 | | 5.083 | 11.0 | 11.0 |
| RUN | 8003 | 8004 | | 5.083 | 11.0 | 11.0 |
| RUN | 8004 | 12 | | 5.083 | 11.0 | 11.0 |
| RUN | 12 | 8005 | | 5.083 | 12.0 | 12.0 |
| RUN | 8005 | 8006 | | 5.083 | 12.0 | 12.0 |
| RUN | 8006 | 13 | | 5.083 | 12.0 | 12.0 |
| RESTRAINT | | 13 | 100000. | | 100000. | |
| RUN | 13 | 14 | | 0.667 | 13.0 | 13.0 |
| REDUCER | 14 | 15 | | 1.666 | 14.0 | 14.0 |
| RUN | 15 | 16 | | 1.417 | 15.0 | 15.0 |
| TEE | 16 | 1700 | | | | |
| RUN | 16 | 18 | | 5.563 | 17.0 | 17.0 |
| ELBOW | 18 | 19 | 24.0 | | 18.0 | 18.0 |
| RUN | 19 | 20 | -4.0 | | 19.0 | 19.0 |
| REDUCER | 20 | 21 | -1.0 | | 20.0 | 20.0 |
| RUN | 21 | 22 | -0.646 | | 21.0 | 21.0 |
| REDUCER | 22 | 23 | -1.333 | | 22.0 | 22.0 |
| RUN | 7 | 800 | 1.083 | | 23.0 | 23.0 |
| RUN | 800 | 8 | 0.958 | | 7.0 | 7.0 |
| RUN | 16 | 1700 | 1.083 | | 24.0 | 24.0 |
| RUN | 1700 | 17 | 1.709 | | 16.0 | 16.0 |
| RUN | 23 | 25 | -1.375 | | 25.0 | 25.0 |
| RUN | 25 | 105 | -1.500 | | 25.0 | 25.0 |
| RESTRAINT | | 105 | | 1.0 | | |
| CWEIGHT | | 105 | | 10.0 | | |
| RUN | 105 | 106 | -0.25 | | | |
| RESTRAINT | | 106 | | | 50000. | |
| CWEIGHT | | 106 | | 10.0 | | |
| RUN | 106 | 110 | -4.396 | | 25.0 | 25.0 |
| RUN | 110 | 115 | -1.5 | | | |
| RUN | 115 | 120 | -1.5 | | | |
| RUN | 120 | 122 | -1.00 | | | |
| SNUBBER | | 122 | | 17000. | | |

| | | | | | | | |
|-----------|-----|-----|--------|---------|--------|------|------|
| CWEIGHT | | 122 | | 15.0 | | | |
| RUN | 122 | 123 | -0.25 | | | | |
| RESTRAINT | | 123 | | 1.0 | | | |
| CWEIGHT | | 123 | | 10.0 | | | |
| RUN | 123 | 125 | -1.25 | | | | |
| ELBOW | 125 | 130 | | | | | |
| RUN | 130 | 135 | | -1.5 | | | |
| SNUBBER | | 135 | 25000. | | | | |
| CWEIGHT | | 135 | | 15.0 | | | |
| RUN | 135 | 138 | | -0.25 | | | |
| RESTRAINT | | 138 | | | 50000. | | |
| CWEIGHT | | 138 | | 10.0 | | | |
| RUN | 138 | 139 | | -18.031 | | | |
| RESTRAINT | | 139 | | | 50000. | | |
| CWEIGHT | | 139 | | 10.0 | | | |
| RUN | 139 | 140 | | -0.25 | | | |
| SNUBBER | | 140 | 25000. | | | | |
| CWEIGHT | | 140 | | 15.0 | | | |
| RUN | 140 | 142 | | -2.875 | | | |
| RUN | 142 | 144 | | -3.297 | | | |
| ELBOW | 144 | 145 | | | | | |
| RUN | 145 | 148 | 1.5 | | | | |
| RESTRAINT | | 148 | | 1.0 | | | |
| CWEIGHT | | 148 | | 10.0 | | | |
| RUN | 148 | 150 | 3.0 | | | | |
| RUN | 150 | 155 | 1.0 | | | | |
| RUN | 155 | 160 | 1.0 | | | | |
| RUN | 160 | 162 | 1.75 | | | | |
| SNUBBER | | 162 | | 17000. | | | |
| CWEIGHT | | 162 | | 15.0 | | | |
| RUN | 162 | 163 | 4.75 | | | | |
| RESTRAINT | | 163 | | 1.0 | | | |
| CWEIGHT | | 163 | | 10.0 | | | |
| RUN | 163 | 165 | 1.0 | | | | |
| ELBOW | 165 | 170 | | | | | |
| RUN | 170 | 172 | | -3.0 | | | |
| RESTRAINT | | 172 | | | 50000. | | |
| CWEIGHT | | 172 | | 10.0 | | | |
| RUN | 172 | 173 | | -3.0 | | | |
| RESTRAINT | | 173 | 50000. | | | | |
| CWEIGHT | | 173 | | 10.0 | | | |
| RUN | 173 | 175 | | -14.0 | | | |
| RESTRAINT | | 175 | | | 50000. | | |
| CWEIGHT | | 175 | | 10.0 | | | |
| RUN | 175 | 177 | | -2.422 | | | |
| RUN | 177 | 180 | | -3.781 | | | |
| ELBOW | 180 | 185 | | | | | |
| RUN | 185 | 190 | -2.0 | | | | |
| RUN | 190 | 195 | -4.0 | | | | |
| ANCHOR | | 195 | -12.0 | 17.417 | | | |
| RUN | 17 | 295 | 4.5 | | | 31.0 | 28.0 |
| REDUCER | 295 | 310 | .667 | | | 28.0 | |
| RUN | 310 | 320 | 2.0 | | | | |
| RUN | 320 | 330 | 2.0 | | | | |
| RUN | 330 | 335 | 1.041 | | | | |
| RESTRAINT | | 335 | | 1.0 | | | |
| RUN | 335 | 340 | 3.0 | | | | |
| ELBOW | 340 | 350 | | | | | |
| RUN | 350 | 360 | | -2.25 | | | |
| RESTRAINT | | 360 | | | 50000. | | |
| CWEIGHT | | 360 | | 10.0 | | | |
| RUN | 360 | 361 | | -0.25 | | | |

| | | | | | | | | |
|-----------|------|--------|--------|--------|------|------|------|--|
| SNUBBER | 361 | 17000. | | | | | | |
| CWEIGHT | 361 | | 15.0 | | | | | |
| RUN | 361 | 365 | -16.75 | | | | | |
| RESTRAINT | | 365 | | 50000. | | | | |
| CWEIGHT | | 365 | 10.0 | | | | | |
| RUN | 365 | 369 | -0.25 | | | | | |
| SNUBBER | | 369 | 17000. | | | | | |
| CWEIGHT | | 369 | 10.0 | | | | | |
| RUN | 369 | 370 | -3.5 | | | | | |
| ELBOW | 370 | 380 | | | | | | |
| RUN | 380 | 382 | -1.0 | | | | | |
| SNUBBER | | 382 | 17000. | | | | | |
| CWEIGHT | | 382 | 15.0 | | | | | |
| RUN | 382 | 385 | -4.5 | | | | | |
| RESTRAINT | | 385 | 1.0 | | | | | |
| CWEIGHT | | 385 | 10.0 | | | | | |
| RUN | 385 | 390 | -5.5 | | | | | |
| ELBOW | 390 | 400 | | | | | | |
| RUN | 400 | 405 | -1.25 | | | | | |
| RESTRAINT | | 405 | 50000. | | | | | |
| CWEIGHT | | 405 | 10.0 | | | | | |
| RUN | 405 | 406 | -.25 | | | | | |
| RESTRAINT | | 406 | | 50000. | | | | |
| CWEIGHT | | 406 | 10.0 | | | | | |
| RUN | 406 | 408 | -10.0 | | | | | |
| SNUBBER | | 408 | 17000. | | | | | |
| CWEIGHT | | 408 | 15.0 | | | | | |
| RUN | 408 | 410 | -6.0 | | | | | |
| RESTRAINT | | 410 | | 50000. | | | | |
| CWEIGHT | | 410 | 10.0 | | | | | |
| RUN | 410 | 420 | -6.343 | | | | | |
| ELBOW | 420 | 430 | | | | | | |
| RUN | 430 | 435 | 1.0 | | | | | |
| RESTRAINT | | 435 | | 50000. | | | | |
| CWEIGHT | | 435 | 10.0 | | | | | |
| RUN | 435 | 440 | 4.5 | | | | | |
| RUN | 440 | 450 | 5.5 | | | | | |
| ANCHOR | | 450 | 16.0 | 17.416 | | | | |
| RUN | 8 | 495 | 2.541 | | 33.0 | 30.0 | | |
| REDUCER | 495 | 510 | 1.416 | | 30.0 | | | |
| ELBOW | 510 | 520 | | | | | | |
| RUN | 520 | 530 | | 4.0 | | | | |
| ELBOW | 530 | 540 | | | | | | |
| RUN | 540 | 550 | 2.5 | | | | | |
| RUN | 550 | 560 | 2.0 | | | | | |
| RUN | 560 | 570 | 2.0 | | | | | |
| RUN | 570 | 575 | 1.0 | | 30.0 | | | |
| RESTRAINT | | 575 | 1.0 | | | | | |
| RUN | 575 | 580 | 1.5 | | | | | |
| ELBOW | 580 | 590 | | | | | | |
| RUN | 590 | 600 | | -4.0 | | | | |
| ELBOW | 600 | 610 | | | | | | |
| RUN | 610 | 620 | 2.25 | | | | | |
| RUN | 620 | 630 | 2.25 | | | | | |
| ANCHOR | | 630 | 19.5 | 11.635 | | | | |
| RUN | 450 | 1450 | | | 5.5 | 34.0 | 28.0 | |
| ELBOW | 1450 | 1460 | | | | | | |
| RUN | 1460 | 1465 | 4.75 | | | | | |
| RUN | 1465 | 1467 | 3.5 | | | | | |
| SNUBBER | | 1467 | 17000. | | | | | |
| CWEIGHT | | 1467 | 15.0 | | | | | |
| RUN | 1467 | 1468 | 0.25 | | | | | |

| | | | | | |
|-----------|------|------|------|--------|------|
| RESTRAINT | 1468 | | | 50000. | |
| CWEIGHT | 1468 | | | 10.0 | |
| RUN | 1468 | 1470 | 1.00 | | |
| ELBOW | 1470 | 1480 | | | |
| RUN | 1480 | 1485 | | 5.5 | |
| RUN | 1485 | 1490 | | 5.5 | |
| ELBOW | 1490 | 1495 | | | |
| RUN | 1495 | 1500 | -1.0 | | |
| RESTRAINT | 1500 | | | 50000. | |
| CWEIGHT | 1500 | | | 10.0 | |
| RUN | 1500 | 1502 | -2.5 | | |
| RUN | 1502 | 1503 | -2.5 | | |
| RUN | 1503 | 1505 | -3.5 | | |
| ELBOW | 1505 | 1510 | | | |
| RUN | 1510 | 1520 | | 5.5 | |
| ANCHOR | 1520 | | 16.0 | 17.416 | 22.0 |
| MASSPT | 2 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 9 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 18 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 20 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 22 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 25 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 140 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 150 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 160 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 180 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 17 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 295 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 340 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 370 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 420 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 390 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 510 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 530 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 550 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 570 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 580 | 1.0 | 1.0 | 1.0 | 1.0 |
| MASSPT | 600 | 1.0 | 1.0 | 1.0 | 1.0 |
| STRESS7 | | | | | |
| 9CASES | 5 | 4 | | | |
| ALLDONE | | | | | |

079T1000008
62

02/10/83

ROCKPIPE - ROCKWELL INTERNATIONAL ENERGY SYSTEM'S GROUP VERSION OF NUPIPE

PAGE 52

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 3.188 SEC.

4 PREVIOUS CASES BEING READ FROM TAPE11

| ORIG NO. | DATE | CASE TITLE |
|----------|----------|---|
| 1 | 02/10/83 | X-DIRECTION 30 MPH WIND |
| 2 | 02/10/83 | Z-DIRECTION 30 MPH WIND |
| 3 | 02/10/83 | MAXIMUM OF X AND Z ABSOLUTE 30 MPH WIND |
| 4 | 02/10/83 | MAXIMUM OF X AND Z ABSOLUTE 90 MPH WIND |

079T1000008
63

02/10/83

ROCKPIPE - ROCKWELL INTERNATIONAL ENERGY SYSTEM'S GROUP VERSION OF NUPIPE

PAGE 53

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 3.502 SEC.

SAVING CASES ON TAPE12

| CASE NO. | DATE | CASE TITLE |
|----------|----------|---|
| 1 | 02/10/83 | X-DIRECTION 30 MPH WIND |
| 2 | 02/10/83 | Z-DIRECTION 30 MPH WIND |
| 3 | 02/10/83 | MAXIMUM OF X AND Z ABSOLUTE 30 MPH WIND |
| 4 | 02/10/83 | MAXIMUM OF X AND Z ABSOLUTE 90 MPH WIND |
| 5 | 02/10/83 | DEADWEIGHT |

079T1000008
64

02/10/83

ROCKPIPE - ROCKWELL INTERNATIONAL ENERGY SYSTEM'S GROUP VERSION OF NUPIPE

PAGE 54

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 3.922 SEC.

```
**** **      ****      ****      ****      ****
***** **      ***** ***** ***** *****
** * **      ** **      ** **      ** **      ** **
**      **      ** **      ****      ****      ****
** * **      *****      **      **      **
***** ***** ***** ***** ***** *****
**** ***** ** **      ****      ****      *****
```

079T1000008
65

02/10/83

ROCKPIPE - ROCKWELL INTERNATIONAL ENERGY SYSTEM'S GROUP VERSION OF NUPIPE

PAGE 55

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 3.959 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 1 | 1.000 | 35. | 811. | 0. | 35. |
| | 2 | 1.000 | 34. | 498. | 0. | 34. |
| RUN | 2 | 1.000 | 106. | 1562. | 0. | 106. |
| | 3 | 1.000 | 105. | 1302. | 0. | 105. |
| RUN | 3 | 1.000 | 0. | 51. | 0. | 0. |
| | 4 | 1.000 | 0. | 16. | 0. | 0. |
| RUN | 4 | 1.000 | 0. | 20. | 0. | 0. |
| | 5 | 1.000 | 0. | 10. | 0. | 0. |
| RUN | 5 | 1.000 | 0. | 24. | 0. | 0. |
| | 6 | 1.000 | 0. | 0. | 0. | 0. |
| RUN | 3 | 1.000 | 61. | 772. | 0. | 61. |
| | 7 | 1.119 | 58. | 381. | 0. | 58. |
| RUN | 7 | 1.119 | 5. | 312. | 0. | 5. |
| | 9 | 1.000 | 5. | 255. | 0. | 5. |
| REDUCE | 9 | 2.000 | 23. | 1246. | 0. | 23. |
| | 10 | 2.000 | 19. | 959. | 0. | 19. |
| RUN | 10 | 1.000 | 20. | 1000. | 0. | 20. |
| | 8001 | 1.000 | 8. | 367. | 0. | 8. |
| RUN | 8001 | 1.000 | 8. | 367. | 0. | 8. |
| | 8002 | 1.000 | 5. | 480. | 0. | 5. |
| RUN | 8002 | 1.000 | 5. | 480. | 0. | 5. |
| | 11 | 1.000 | 17. | 714. | 0. | 17. |
| RUN | 11 | 1.000 | 17. | 714. | 0. | 17. |
| | 8003 | 1.000 | 29. | 763. | 0. | 29. |
| RUN | 8003 | 1.000 | 29. | 763. | 0. | 29. |
| | 8004 | 1.000 | 41. | 681. | 0. | 41. |
| RUN | 8004 | 1.000 | 41. | 681. | 0. | 41. |
| | 12 | 1.000 | 53. | 767. | 0. | 53. |

66
079T1000008

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 3.976 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|--------------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 12 8005 | 1.000 1.000 | 53. 65. | 767. 1348. | 0. 0. | 53. 65. |
| RUN | 8005 8006 | 1.000 1.000 | 65. 77. | 1348. 2315. | 0. 0. | 65. 77. |
| RUN | 8006 13 | 1.000 1.000 | 77. 89. | 2315. 3580. | 0. 0. | 77. 89. |
| RUN | 13 14 | 1.000 1.000 | 89. 92. | 3580. 3197. | 0. 0. | 89. 92. |
| REDUCE | 14 15 | 2.000 2.000 | 88. 96. | 3068. 2172. | 0. 0. | 88. 96. |
| RUN | 15 16 | 1.000 1.119 | 20. 21. | 444. 296. | 0. 0. | 20. 21. |
| RUN | 16 18 | 1.119 1.000 | 1. 1. | 281. 112. | 0. 0. | 1. 1. |
| ELBOW | 18 19 | 2.809 2.809 | 6. 322. | 508. 446. | 0. 0. | 6. 322. |
| RUN | 19 20 | 1.000 1.000 | 71. 93. | 98. 108. | 0. 0. | 71. 93. |
| REDUCE | 20 21 | 2.000 2.000 | 378. 355. | 440. 404. | 0. 0. | 378. 355. |
| RUN | 21 22 | 1.000 1.000 | 307. 277. | 349. 315. | 0. 0. | 307. 277. |
| REDUCE | 22 23 | 2.000 2.000 | 965. 633. | 1097. 777. | 0. 0. | 965. 633. |
| RUN | 7 800 | 1.119 1.000 | 650. 531. | 1488. 1226. | 0. 0. | 650. 531. |
| RUN | 800 8 | 1.000 1.000 | 531. 368. | 1226. 852. | 0. 0. | 531. 368. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 3.993 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 16 | 1.119 | 246. | 1243. | 0. | 246. |
| | 1700 | 1.000 | 359. | 1203. | 0. | 359. |
| RUN | 1700 | 1.000 | 359. | 1203. | 0. | 359. |
| | 17 | 1.000 | 452. | 892. | 0. | 452. |
| RUN | 23 | 1.000 | 5100. | 5569. | 0. | 5100. |
| | 25 | 1.000 | 3762. | 4433. | 0. | 3762. |
| RUN | 25 | 1.000 | 3762. | 4433. | 0. | 3762. |
| | 105 | 1.000 | 3892. | 4891. | 0. | 3892. |
| RUN | 105 | 1.000 | 3892. | 4891. | 0. | 3892. |
| | 106 | 1.000 | 3834. | 4897. | 0. | 3834. |
| RUN | 106 | 1.000 | 3834. | 4897. | 0. | 3834. |
| | 110 | 1.000 | 3306. | 4312. | 0. | 3306. |
| RUN | 110 | 1.000 | 3306. | 4312. | 0. | 3306. |
| | 115 | 1.000 | 3327. | 4528. | 0. | 3327. |
| RUN | 115 | 1.000 | 3327. | 4528. | 0. | 3327. |
| | 120 | 1.000 | 3451. | 4861. | 0. | 3451. |
| RUN | 120 | 1.000 | 3451. | 4861. | 0. | 3451. |
| | 122 | 1.000 | 3591. | 5139. | 0. | 3591. |
| RUN | 122 | 1.000 | 3591. | 5139. | 0. | 3591. |
| | 123 | 1.000 | 3635. | 5218. | 0. | 3635. |
| | 125 | 1.000 | 3280. | 4933. | 0. | 3280. |
| ELBOW | 125 | 1.000 | 3280. | 4933. | 0. | 3280. |
| | 130 | 1.000 | 3304. | 4689. | 0. | 3304. |
| RUN | 130 | 1.000 | 3304. | 4689. | 0. | 3304. |
| | 135 | 1.000 | 3289. | 4325. | 0. | 3289. |
| RUN | 135 | 1.000 | 3289. | 4325. | 0. | 3289. |
| | 138 | 1.000 | 3285. | 4211. | 0. | 3285. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 4.010 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 138 | 1.000 | 3285. | 4211. | 0. | 3285. |
| | 139 | 1.000 | 3169. | 5317. | 0. | 3169. |
| RUN | 139 | 1.000 | 3169. | 5317. | 0. | 3169. |
| | 140 | 1.000 | 3174. | 5225. | 0. | 3174. |
| RUN | 140 | 1.000 | 3174. | 5225. | 0. | 3174. |
| | 142 | 1.000 | 3231. | 4236. | 0. | 3231. |
| RUN | 142 | 1.000 | 3231. | 4236. | 0. | 3231. |
| | 144 | 1.000 | 3282. | 3720. | 0. | 3282. |
| ELBOW | 144 | 1.000 | 3282. | 3720. | 0. | 3282. |
| | 145 | 1.000 | 3200. | 3782. | 0. | 3200. |
| RUN | 145 | 1.000 | 3200. | 3782. | 0. | 3200. |
| | 148 | 1.000 | 3634. | 4284. | 0. | 3634. |
| RUN | 148 | 1.000 | 3634. | 4284. | 0. | 3634. |
| | 150 | 1.000 | 3155. | 4172. | 0. | 3155. |
| RUN | 150 | 1.000 | 3155. | 4172. | 0. | 3155. |
| | 155 | 1.000 | 3087. | 4214. | 0. | 3087. |
| RUN | 155 | 1.000 | 3087. | 4214. | 0. | 3087. |
| | 160 | 1.000 | 3064. | 4290. | 0. | 3064. |
| RUN | 160 | 1.000 | 3064. | 4290. | 0. | 3064. |
| | 162 | 1.000 | 3133. | 4512. | 0. | 3133. |
| RUN | 162 | 1.000 | 3133. | 4512. | 0. | 3133. |
| | 163 | 1.000 | 4063. | 5893. | 0. | 4063. |
| RUN | 163 | 1.000 | 4063. | 5893. | 0. | 4063. |
| | 165 | 1.000 | 3754. | 5618. | 0. | 3754. |
| ELBOW | 165 | 1.000 | 3754. | 5618. | 0. | 3754. |
| | 170 | 1.000 | 3262. | 4608. | 0. | 3262. |
| RUN | 170 | 1.000 | 3262. | 4608. | 0. | 3262. |
| | 172 | 1.000 | 3307. | 4124. | 0. | 3307. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 4.026 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 172 | 1.000 | 3307. | 4124. | 0. | 3307. |
| | 173 | 1.000 | 3366. | 6994. | 0. | 3366. |
| RUN | 173 | 1.000 | 3366. | 6994. | 0. | 3366. |
| | 175 | 1.000 | 3085. | 3738. | 0. | 3085. |
| RUN | 175 | 1.000 | 3085. | 3738. | 0. | 3085. |
| | 177 | 1.000 | 3146. | 3829. | 0. | 3146. |
| RUN | 177 | 1.000 | 3146. | 3829. | 0. | 3146. |
| | 180 | 1.000 | 3223. | 3746. | 0. | 3223. |
| ELBOW | 180 | 1.000 | 3223. | 3746. | 0. | 3223. |
| | 185 | 1.000 | 3251. | 3582. | 0. | 3251. |
| RUN | 185 | 1.000 | 3251. | 3582. | 0. | 3251. |
| | 190 | 1.000 | 3196. | 3313. | 0. | 3196. |
| RUN | 190 | 1.000 | 3196. | 3313. | 0. | 3196. |
| | 195 | 1.000 | 3554. | 4384. | 0. | 3554. |
| RUN | 17 | 1.000 | 679. | 1046. | 0. | 679. |
| | 295 | 1.000 | 490. | 783. | 0. | 490. |
| REDUCE | 295 | 2.000 | 2888. | 6786. | 0. | 2888. |
| | 310 | 2.000 | 1802. | 5964. | 0. | 1802. |
| RUN | 310 | 1.000 | 1330. | 4104. | 0. | 1330. |
| | 320 | 1.000 | 1965. | 4995. | 0. | 1965. |
| RUN | 320 | 1.000 | 1965. | 4995. | 0. | 1965. |
| | 330 | 1.000 | 5025. | 7908. | 0. | 5025. |
| RUN | 330 | 1.000 | 5025. | 7908. | 0. | 5025. |
| | 335 | 1.000 | 6829. | 9514. | 0. | 6829. |
| RUN | 335 | 1.000 | 6829. | 9514. | 0. | 6829. |
| | 340 | 1.000 | 420. | 2717. | 0. | 420. |
| ELBOW | 340 | 2.267 | 445. | 4350. | 0. | 445. |
| | 350 | 2.267 | 3486. | 5257. | 0. | 3486. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 4.043 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 350 | 1.000 | 2209. | 3251. | 0. | 2209. |
| | 360 | 1.000 | 2001. | 3724. | 0. | 2001. |
| RUN | 360 | 1.000 | 2001. | 3724. | 0. | 2001. |
| | 361 | 1.000 | 1966. | 3749. | 0. | 1966. |
| RUN | 361 | 1.000 | 1966. | 3749. | 0. | 1966. |
| | 365 | 1.000 | 1133. | 5218. | 0. | 1133. |
| RUN | 365 | 1.000 | 1133. | 5218. | 0. | 1133. |
| | 369 | 1.000 | 1168. | 4870. | 0. | 1168. |
| RUN | 369 | 1.000 | 1168. | 4870. | 0. | 1168. |
| | 370 | 1.000 | 1550. | 2252. | 0. | 1550. |
| ELBOW | 370 | 2.267 | 2366. | 3560. | 0. | 2366. |
| | 380 | 2.267 | 1945. | 5341. | 0. | 1945. |
| RUN | 380 | 1.000 | 1302. | 3300. | 0. | 1302. |
| | 382 | 1.000 | 1161. | 3205. | 0. | 1161. |
| RUN | 382 | 1.000 | 1161. | 3205. | 0. | 1161. |
| | 385 | 1.000 | 3667. | 6163. | 0. | 3667. |
| RUN | 385 | 1.000 | 3667. | 6163. | 0. | 3667. |
| | 390 | 1.000 | 479. | 1730. | 0. | 479. |
| ELBOW | 390 | 2.267 | 545. | 2672. | 0. | 545. |
| | 400 | 2.267 | 1124. | 6452. | 0. | 1124. |
| RUN | 400 | 1.000 | 820. | 3954. | 0. | 820. |
| | 405 | 1.000 | 889. | 5557. | 0. | 889. |
| RUN | 405 | 1.000 | 889. | 5557. | 0. | 889. |
| | 406 | 1.000 | 875. | 5157. | 0. | 875. |
| RUN | 406 | 1.000 | 875. | 5157. | 0. | 875. |
| | 408 | 1.000 | 472. | 5698. | 0. | 472. |
| RUN | 408 | 1.000 | 472. | 5698. | 0. | 472. |
| | 410 | 1.000 | 818. | 6290. | 0. | 818. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 4.059 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 410 | 1.000 | 818. | 6290. | 0. | 818. |
| | 420 | 1.000 | 1141. | 2893. | 0. | 1141. |
| ELBOW | 420 | 2.267 | 1671. | 4649. | 0. | 1671. |
| | 430 | 2.267 | 2704. | 7676. | 0. | 2704. |
| RUN | 430 | 1.000 | 1749. | 4674. | 0. | 1749. |
| | 435 | 1.000 | 2494. | 5452. | 0. | 2494. |
| RUN | 435 | 1.000 | 2494. | 5452. | 0. | 2494. |
| | 440 | 1.000 | 807. | 2030. | 0. | 807. |
| RUN | 440 | 1.000 | 807. | 2030. | 0. | 807. |
| | 450 | 1.000 | 538. | 4826. | 0. | 538. |
| RUN | 8 | 1.000 | 609. | 1013. | 0. | 609. |
| | 495 | 1.000 | 403. | 476. | 0. | 403. |
| REDUCE | 495 | 2.000 | 1728. | 2710. | 0. | 1728. |
| | 510 | 2.000 | 1621. | 2828. | 0. | 1621. |
| ELBOW | 510 | 2.267 | 1786. | 3154. | 0. | 1786. |
| | 520 | 2.267 | 1378. | 2227. | 0. | 1378. |
| RUN | 520 | 1.000 | 969. | 1468. | 0. | 969. |
| | 530 | 1.000 | 733. | 1459. | 0. | 733. |
| ELBOW | 530 | 2.267 | 978. | 2210. | 0. | 978. |
| | 540 | 2.267 | 1249. | 2619. | 0. | 1249. |
| RUN | 540 | 1.000 | 893. | 1699. | 0. | 893. |
| | 550 | 1.000 | 958. | 1366. | 0. | 958. |
| RUN | 550 | 1.000 | 958. | 1366. | 0. | 958. |
| | 560 | 1.000 | 819. | 1313. | 0. | 819. |
| RUN | 560 | 1.000 | 819. | 1313. | 0. | 819. |
| | 570 | 1.000 | 743. | 1249. | 0. | 743. |
| RUN | 570 | 1.000 | 743. | 1249. | 0. | 743. |
| | 575 | 1.000 | 987. | 1721. | 0. | 987. |

02/10/83

ROCKPIPE - ROCKWELL INTERNATIONAL ENERGY SYSTEM'S GROUP VERSION OF NUPIPE

PAGE

62

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 4.076 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 575 | 1.000 | 987. | 1721. | 0. | 987. |
| | 580 | 1.000 | 794. | 1699. | 0. | 794. |
| ELBOW | 580 | 2.267 | 1081. | 2619. | 0. | 1081. |
| | 590 | 2.267 | 607. | 1964. | 0. | 607. |
| RUN | 590 | 1.000 | 516. | 1314. | 0. | 516. |
| | 600 | 1.000 | 611. | 1165. | 0. | 611. |
| ELBOW | 600 | 2.267 | 769. | 1711. | 0. | 769. |
| | 610 | 2.267 | 769. | 2186. | 0. | 769. |
| RUN | 610 | 1.000 | 611. | 1444. | 0. | 611. |
| | 620 | 1.000 | 685. | 1526. | 0. | 685. |
| RUN | 620 | 1.000 | 685. | 1526. | 0. | 685. |
| | 630 | 1.000 | 1146. | 3984. | 0. | 1146. |
| RUN | 450 | 1.000 | 2328. | 5736. | 0. | 2328. |
| | 1450 | 1.000 | 699. | 2333. | 0. | 699. |
| ELBOW | 1450 | 2.606 | 910. | 4104. | 0. | 910. |
| | 1460 | 2.606 | 1028. | 3591. | 0. | 1028. |
| RUN | 1460 | 1.000 | 760. | 2071. | 0. | 760. |
| | 1465 | 1.000 | 877. | 1425. | 0. | 877. |
| RUN | 1465 | 1.000 | 877. | 1425. | 0. | 877. |
| | 1467 | 1.000 | 701. | 2573. | 0. | 701. |
| RUN | 1467 | 1.000 | 701. | 2573. | 0. | 701. |
| | 1468 | 1.000 | 775. | 2719. | 0. | 775. |
| RUN | 1468 | 1.000 | 775. | 2719. | 0. | 775. |
| | 1470 | 1.000 | 869. | 2745. | 0. | 869. |
| ELBOW | 1470 | 2.606 | 1242. | 4909. | 0. | 1242. |
| | 1480 | 2.606 | 1302. | 4563. | 0. | 1302. |
| RUN | 1480 | 1.000 | 900. | 2568. | 0. | 900. |
| | 1485 | 1.000 | 1442. | 1852. | 0. | 1442. |

TABLE OF CONTENTS

| LOAD CASE NUMBER | TITLE | PAGE |
|---|----------------------|------|
| 5 | DEADWEIGHT | 37 |
| | CODE STRESS ANALYSIS | 54 |
| IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000 | | |
| 14:18:29 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=\$WWO49.NUPIPE.LOAD | | |
| 14:18:29 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | |
| 14:18:29 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=\$WWO49.NUPIPE.LOAD | | |
| 14:18:29 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | |
| 14:18:29 IAT4401 LOCATE FOR STEP=G DD=FT11FOO1 DSN=\$WW232.SOLAR.WINDY | | |
| 14:18:29 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA | | |
| 14:18:29 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=\$WW232.CARRIZO.TOTAL.DATA | | |
| 14:18:29 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA | | |
| 14:18:29 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=\$WWO49.ELTEMP.LOAD | | |
| 14:18:29 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | |
| 14:18:30 USES CVTSOK D \$WWO49.NUPIPE.LOAD | | |
| 14:18:30 USES AVTSOA D \$WW232.SOLAR.WINDY | | |
| 14:18:30 IAT5200 JOB 3592 (\$WW232E3) IN SETUP ON MAIN=C P=03 LOCAL | | |
| 14:18:30 IAT5210 J=3592 STEPLIB USING D CVTSOK ON 528 \$WWO49.NUPIPE.LOAD | | |
| 14:18:30 IAT5210 J=3592 FT11FOO1 USING D AVTSOA ON 520 \$WW232.SOLAR.WINDY | | |
| 14:20:15 IAT2000 JOB 3592 \$WW232E3 SELECTED L GRP=BIG | | |
| 14:20:16 L R= \$WW232E3 NEF995I \$WW232E3 STARTED, 2/10/83,14.20.16 ASID=00012 | | |
| 14:20:16 L R= \$WW232E3 IEF403I \$WW232E3 - STARTED - TIME=14.20.16 | | |
| 14:27:45 L R= \$WW232E3 +IH0002I STOP 1 | | |
| 14:27:48 L R= \$WW232E3 IEF404I \$WW232E3 - ENDED - TIME=14.27.46 | | |
| 14:27:48 L R= \$WW232E3 NEF996I \$WW232E3 ENDED, 2/10/83,B.U.= 5.7812 *0716935 ,3033-L3,JOB CC= 001 | | |
| 14:27:52 IAT5400 JOB 3592 (\$WW232E3) IN BREAKDOWN | | |
| /\$WW232E3 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', * | | |
| / REGION=4500K,TIME=5,MSGCLASS=T,MSGLEVEL=1,NOTIFY=\$WW232 | | |
| /*MAIN ORG=RM206 00000300 | | |
| /* THESE THREE ARE FOR XEROX OUTPUT 00000500 | | |
| /*FORMAT PR,DDNAME=SYSMMSG,DEST=RM271PR3,FCB=JB10,COPIES=1 00000600 | | |
| /*FORMAT PR,DDNAME=FT66FOO1,DEST=RM271PR3,FCB=JB10,COPIES=1 00000700 | | |
| /*FORMAT PR,DDNAME=FT06FOO1,DEST=RM271PR3,FCB=JB10,COPIES=1 00000800 | | |
| /* THESE THREE ARE FOR MICROFICHE OUTPUT 00001300 | | |
| /*FORMAT PR,DDNAME=SYSMMSG,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001400 | | |
| /*FORMAT PR,DDNAME=SYSPRINT,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001500 | | |
| /*FORMAT PR,DDNAME=SYSUT2,DEST=RMOO1PR5,FORMS=FICHE,COPIES=1 00001600 | | |
| / EXEC ROCKPIPE,PROG=SMALL | | |
| /G.FT11FOO1 DD DSN=\$WW232.SOLAR.WINDY,DISP=SHR | | |
| /G.SYSIN DD DSN=\$WW232.CARRIZO.TOTAL.DATA,DISP=SHR | | |
| 1 // \$WW232E3 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', * | | |
| // REGION=4500K,TIME=5,MSGCLASS=T,MSGLEVEL=1,NOTIFY=\$WW232 | | |
| *** THESE THREE ARE FOR XEROX OUTPUT 00000500 | | |
| *** THESE THREE ARE FOR MICROFICHE OUTPUT 00001300 | | |
| 2 // EXEC ROCKPIPE,PROG=SMALL | | |
| 3 XXROCKPIPE PROC DSN='\$WWO49.NUPIPE.LOAD',PROG=SMALL,C=10, | | |
| XX PROGA=SEVEN,B=19069,PROGE=OPT2,DSNE='\$WWO49.ELTEMP.LOAD' | | |
| *** AL HROMJAK ROCKWELL INTERNATIONAL, ESG. COMNET 393-3318 | | |

PROGRAM INPUT DATA
 CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

| | | | | | | |
|---|----|-------|------|-------|--|-----|
| CONTROL | | | 2.0 | 1.0 | | 5.0 |
| FLEXAN | 1 | 1 | 4.0 | | | 1.0 |
| X-DIRECTION 30 MPH WIND | | | | | | |
| FLEXAN | 2 | 1 | 4.0 | | | 3.0 |
| Z-DIRECTION 30 MPH WIND | | | | | | |
| MODFLEX | 3 | 1 2 | 1.0 | 1.0 | | 3.0 |
| MAXIMUM OF X AND Z ABSOLUTE 30 MPH WIND | | | | | | |
| MODFLEX | 4 | 3 1 | 9.0 | 0.0 | | 1.0 |
| MAXIMUM OF X AND Z ABSOLUTE 90 MPH WIND | | | | | | |
| FLEXAN | 5 | 1 | 17.0 | | | |
| DEADWEIGHT | | | | | | |
| FLEXAN | 6 | 1 | 2.0 | | | |
| TE1 (THERMAL AT THE DESIGN TEMPERATURE) | | | | | | |
| FLEXAN | 7 | 2 | 2.0 | | | |
| TE2 (THERMAL OVERNIGHT SHUTDOWN) | | | | | | |
| FLEXAN | 8 | 3 | 2.0 | | | |
| TE3 (SG AND NA INLET AT 600, NA OUTLET AT 300 AND STEAM PIPING AT 70) | | | | | | |
| FLEXAN | 9 | 1 | 4.0 | | | 1.0 |
| OBE X - DIRECTION AT .4G | | | | | | |
| FLEXAN | 10 | 1 | 4.0 | | | 2.0 |
| OBE Y - DIRECTION AT .2667G | | | | | | |
| FLEXAN | 11 | 1 | 4.0 | | | 3.0 |
| OBE Z - DIRECTION AT .4G | | | | | | |
| MODFLEX | 12 | 5 6 | 1.0 | 1.0 | | |
| DWT(SIGN) + TE1(SIGN) DIRECT COMBINATION | | | | | | |
| MODFLEX | 13 | 5 7 | 1.0 | 1.0 | | |
| DWT(SIGN) + TE2(SIGN) DIRECT COMBINATION | | | | | | |
| MODFLEX | 14 | 5 8 | 1.0 | 1.0 | | |
| DWT(SIGN) + TE3(SIGN) DIRECT COMBINATION | | | | | | |
| MODFLEX | 15 | 9 11 | 1.0 | 1.0 | | 3.0 |
| MAXIMUM OF X-OBE(ABS) AND Z-OBE(ABS) | | | | | | |
| MODFLEX | 16 | 10 15 | 1.0 | 1.0 | | 1.0 |
| Y(ABS) + MAXIMUM OF X(ABS) AND Z(ABS) CALL THIS "TOTAL OBE" | | | | | | |
| MODFLEX | 17 | 3 16 | 1.0 | 1.0 | | 1.0 |
| TOTAL OBE + WIND LOAD (30MPH) | | | | | | |
| MODFLEX | 18 | 5 17 | 1.0 | 1.0 | | 1.0 |
| DWT + TOTAL OBE + WIND LOAD (30MPH) | | | | | | |
| MODFLEX | 19 | 12 17 | 1.0 | 1.0 | | 1.0 |
| (DWT + TE1)ABS + TOTAL OBE + WIND LOAD (30MPH) | | | | | | |
| MODFLEX | 20 | 5 4 | 1.0 | 1.0 | | 1.0 |
| DWT + 90MPH WIND | | | | | | |
| MODFLEX | 21 | 13 4 | 1.0 | 1.0 | | 1.0 |
| (DWT + TE2)ABS + 90MPH WIND | | | | | | |
| MODFLEX | 22 | 14 4 | 1.0 | 1.0 | | 1.0 |
| (DWT + TE3)ABS + 90MPH WIND | | | | | | |
| MODFLEX | 23 | 12 3 | 1.0 | 1.0 | | 1.0 |
| (DWT + TE1)ABS + 30MPH WIND | | | | | | |
| MODFLEX | 24 | 5 3 | 1.0 | 1.0 | | 1.0 |
| DWT + 30MPH WIND | | | | | | |
| MODFLEX | 25 | 13 3 | 1.0 | 1.0 | | 1.0 |
| DWT + 30MPH WIND + TE2 | | | | | | |
| MODFLEX | 26 | 25 16 | 1.0 | 1.0 | | 1.0 |
| DWT + 30MPH WIND + TE2 + OBE | | | | | | |
| MODFLEX | 27 | 14 3 | 1.0 | 1.0 | | 1.0 |
| DWT + TE3 + 30PMH WIND | | | | | | |
| MODFLEX | 28 | 16 27 | 1.0 | 1.0 | | 1.0 |
| DWT + TOTAL OBE + 30MPH WIND | | | | | | |
| ACCEL | | | .4 | .2667 | | .4 |

| | | | | | | |
|-----------|----|-------|-------|--------|------|-------|
| XSECTN | 1 | 54.22 | 0.721 | 812.0 | 29.9 | |
| XSECTN | 2 | 30.94 | 0.721 | 705.1 | 29.9 | |
| XSECTN | 3 | 21.5 | 1.0 | 580.1 | 29.9 | 0.0 |
| XSECTN | 4 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 |
| XSECTN | 5 | 12.81 | 1.0 | 370.3 | 29.9 | 0.0 |
| XSECTN | 6 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 |
| XSECTN | 7 | 12.75 | .562 | 51.7 | 29.9 | 0.0 |
| XSECTN | 8 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 |
| XSECTN | 9 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 |
| XSECTN | 10 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 11 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 12 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 13 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 |
| XSECTN | 14 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 |
| XSECTN | 15 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 |
| XSECTN | 16 | 12.75 | .562 | 92.1 | 29.9 | 0.0 |
| XSECTN | 17 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 |
| XSECTN | 18 | 24.0 | 1.0 | 524.4 | 29.9 | 0.0 |
| XSECTN | 19 | 26.0 | 1.97 | 927.5 | 29.9 | 0.0 |
| XSECTN | 20 | 21.5 | 1.0 | 596.4 | 29.9 | 0.0 |
| XSECTN | 21 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 |
| XSECTN | 22 | 12.81 | 1.0 | 376.9 | 29.9 | 0.0 |
| XSECTN800 | 23 | 12.75 | 0.562 | 51.7 | 299. | 0.0 |
| XSECT1700 | 24 | 12.75 | 0.562 | 89.8 | 299. | 0.0 |
| XSECTN | 25 | 6.625 | 0.864 | 85.5 | 29.9 | 1590. |
| XSECTN NA | 26 | 6.625 | 0.864 | | 29.9 | 1590. |
| XSECTN NA | 27 | 12.75 | 0.406 | 175. | 28.3 | 65. |
| XSECTN | 28 | 6.625 | 0.280 | 98.5 | 28.3 | 65. |
| XSECTN NA | 29 | 12.75 | 0.406 | 130. | 27.9 | 65. |
| XSECTN | 30 | 6.625 | 0.280 | 53.4 | 27.9 | 65. |
| XSECTN | 31 | 12.75 | 0.687 | 218.8 | 28.3 | 65. |
| XSECTN NA | 32 | 6.625 | 0.280 | | 27.9 | 65. |
| XSECTN | 33 | 12.75 | 0.687 | 218.8 | 27.9 | 65. |
| XSECTN | 34 | 10.75 | 0.365 | 154.6 | 28.3 | 65. |
| OPVAL225 | 1 | 1 | 29.4 | .01198 | | |
| OPVAL435 | 1 | 2 | 28.4 | .03022 | | |
| OPVAL470 | 1 | 3 | 28.2 | .03344 | | |
| OPVAL450 | 1 | 4 | 28.3 | .03160 | | |
| OPVAL450 | 1 | 5 | 28.3 | .03160 | | |
| OPVAL587 | 1 | 6 | 27.5 | .04473 | | |
| OPVAL620 | 1 | 7 | 27.2 | .04086 | | |
| OPVAL625 | 1 | 8 | 27.2 | .04858 | | |
| OPVAL640 | 1 | 9 | 27.1 | .05012 | | |
| OPVAL705 | 1 | 10 | 26.6 | .05684 | | |
| OPVAL865 | 1 | 11 | 24.9 | .07422 | | |
| OPVAL1010 | 1 | 12 | 22.7 | .09005 | | |
| OPVAL1050 | 1 | 13 | 21.7 | .09465 | | |
| OPVAL1055 | 1 | 14 | 21.6 | .09523 | | |
| OPVAL1057 | 1 | 15 | 21.5 | .09546 | | |
| OPVAL1065 | 1 | 16 | 21.3 | .09638 | | |
| OPVAL1055 | 1 | 17 | 21.6 | .09523 | | |
| OPVAL1025 | 1 | 18 | 22.4 | .09178 | | |
| OPVAL1020 | 1 | 19 | 22.5 | .09120 | | |
| OPVAL1020 | 1 | 20 | 22.5 | .09120 | | |
| OPVAL1015 | 1 | 21 | 22.6 | .09063 | | |
| OPVAL1015 | 1 | 22 | 22.6 | .09063 | | |
| OPVAL800 | 1 | 23 | 273.0 | .04703 | | |
| OPVAL1065 | 1 | 24 | 213.0 | .09638 | | |
| OPVAL1015 | 1 | 25 | 22.60 | .09063 | | 1590. |
| OPVAL NA | 1 | 26 | 22.74 | .09005 | | 1590. |
| OPVAL NA | 1 | 27 | 22.4 | .12364 | | 65. |
| OPVAL1065 | 1 | 28 | 22.4 | .12364 | | 65. |

| | | | | | |
|-----------|---|----|-------|--------|-------|
| OPVAL NA | 1 | 29 | 25.61 | .04703 | 65. |
| OPVAL 610 | 1 | 30 | 25.61 | .04703 | 65. |
| OPVAL201 | 2 | 1 | 29.5 | .00998 | |
| OPVAL381 | 2 | 2 | 29.1 | .02533 | |
| OPVAL420 | 2 | 3 | 28.5 | .02884 | |
| OPVAL400 | 2 | 4 | 28.5 | .02700 | |
| OPVAL400 | 2 | 5 | 28.5 | .02700 | |
| OPVAL550 | 2 | 6 | 27.7 | .04110 | |
| OPVAL570 | 2 | 7 | 27.6 | .04306 | |
| OPVAL575 | 2 | 8 | 27.6 | .04355 | |
| OPVAL585 | 2 | 9 | 27.5 | .04453 | |
| OPVAL650 | 2 | 10 | 27.0 | .05115 | |
| OPVAL770 | 2 | 11 | 26.0 | .06379 | |
| OPVAL890 | 2 | 12 | 24.6 | .07699 | |
| OPVAL940 | 2 | 13 | 23.9 | .08242 | |
| OPVAL942 | 2 | 14 | 23.9 | .08264 | |
| OPVAL948 | 2 | 15 | 23.8 | .08328 | |
| OPVAL950 | 2 | 16 | 23.8 | .08350 | |
| OPVAL950 | 2 | 17 | 23.8 | .08350 | |
| OPVAL910 | 2 | 18 | 24.4 | .07918 | |
| OPVAL905 | 2 | 19 | 24.4 | .07864 | |
| OPVAL902 | 2 | 20 | 24.5 | .07832 | |
| OPVAL900 | 2 | 21 | 24.5 | .07810 | |
| OPVAL900 | 2 | 22 | 24.5 | .07810 | |
| OPVAL570 | 2 | 23 | 276.0 | .04306 | |
| OPVAL950 | 2 | 24 | 237.5 | .08350 | |
| OPVAL850 | 2 | 25 | 25.1 | .07255 | 1590. |
| OPVAL NA | 2 | 26 | 22.74 | .09005 | 1590. |
| OPVAL NA | 2 | 27 | 23.2 | .10800 | 65. |
| OPVAL950 | 2 | 28 | 23.2 | .10800 | 65. |
| OPVAL NA | 2 | 29 | 27.4 | .0182 | 65. |
| OPVAL 300 | 2 | 30 | 27.4 | .0182 | 65. |
| OPVAL 226 | 3 | 1 | 29.4 | .01206 | 65. |
| OPVAL 492 | 3 | 2 | 28.0 | .03546 | 65. |
| OPVAL 600 | 3 | 3 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 4 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 5 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 6 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 7 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 8 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 9 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 10 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 11 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 12 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 13 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 14 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 15 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 16 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 17 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 18 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 19 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 20 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 21 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 22 | 27.4 | .0460 | 65. |
| OPVAL 600 | 3 | 23 | 274.0 | .0460 | 65. |
| OPVAL 600 | 3 | 24 | 274.0 | .0460 | 65. |
| OPVAL 70 | 3 | 25 | 29.9 | | 1590. |
| OPVAL NA | 3 | 26 | 22.74 | | 1590. |
| OPVAL NA | 3 | 27 | 25.6 | .0624 | 65. |
| OPVAL | 3 | 28 | 25.6 | .0624 | 65. |
| OPVAL | 3 | 29 | 27.4 | .0182 | |
| OPVAL | 3 | 30 | 27.4 | .0182 | |

| | | | | | | |
|-----------|------|------|---------|---------|------|--|
| ANCHOR | | 1 | | | | |
| RUN | 1 | 2 | 5.0 | 1.0 | 1.0 | |
| RUN | 2 | 3 | 1.489 | 2.0 | 2.0 | |
| RUN | 3 | 4 | -1.667 | 3.0 | 3.0 | |
| RUN | 4 | 5 | -.646 | 4.0 | 4.0 | |
| RUN | 5 | 6 | -1.896 | 5.0 | 5.0 | |
| RUN | 3 | 7 | 5.146 | 6.0 | 6.0 | |
| TEE | 7 | 800 | | | | |
| RUN | 7 | 9 | 1.417 | 8.0 | 8.0 | |
| REDUCER | 9 | 10 | 1.666 | 9.0 | 9.0 | |
| RUN | 10 | 8001 | 5.097 | 10.0 | 10.0 | |
| RUN | 8001 | 8002 | 5.097 | 10.0 | 10.0 | |
| RUN | 8002 | 11 | 5.097 | 10.0 | 10.0 | |
| RUN | 11 | 8003 | 5.083 | 11.0 | 11.0 | |
| RUN | 8003 | 8004 | 5.083 | 11.0 | 11.0 | |
| RUN | 8004 | 12 | 5.083 | 11.0 | 11.0 | |
| RUN | 12 | 8005 | 5.083 | 12.0 | 12.0 | |
| RUN | 8005 | 8006 | 5.083 | 12.0 | 12.0 | |
| RUN | 8006 | 13 | 5.083 | 12.0 | 12.0 | |
| RESTRAINT | | 13 | 100000. | 100000. | | |
| RUN | 13 | 14 | 0.667 | 13.0 | 13.0 | |
| REDUCER | 14 | 15 | 1.666 | 14.0 | 14.0 | |
| RUN | 15 | 16 | 1.417 | 15.0 | 15.0 | |
| TEE | 16 | 1700 | | | | |
| RUN | 16 | 18 | 5.563 | 17.0 | 17.0 | |
| ELBOW | 18 | 19 | 24.0 | 18.0 | 18.0 | |
| RUN | 19 | 20 | -4.0 | 19.0 | 19.0 | |
| REDUCER | 20 | 21 | -1.0 | 20.0 | 20.0 | |
| RUN | 21 | 22 | -0.646 | 21.0 | 21.0 | |
| REDUCER | 22 | 23 | -1.333 | 22.0 | 22.0 | |
| RUN | 7 | 800 | 1.083 | 23.0 | 23.0 | |
| RUN | 800 | 8 | 0.958 | 7.0 | 7.0 | |
| RUN | 16 | 1700 | 1.083 | 24.0 | 24.0 | |
| RUN | 1700 | 17 | 1.709 | 16.0 | 16.0 | |
| RUN | 23 | 25 | -1.375 | 25.0 | 25.0 | |
| RUN | 25 | 105 | -1.500 | 25.0 | 25.0 | |
| RESTRAINT | | 105 | 1.0 | | | |
| CWEIGHT | | 105 | 10.0 | | | |
| RUN | 105 | 106 | -0.25 | | | |
| RESTRAINT | | 106 | 50000. | | | |
| CWEIGHT | | 106 | 10.0 | | | |
| RUN | 106 | 110 | -4.396 | 25.0 | 25.0 | |
| RUN | 110 | 115 | -1.5 | | | |
| RUN | 115 | 120 | -1.5 | | | |
| RUN | 120 | 122 | -1.00 | | | |
| SNUBBER | | 122 | 17000. | | | |
| CWEIGHT | | 122 | 15.0 | | | |
| RUN | 122 | 123 | -0.25 | | | |
| RESTRAINT | | 123 | 1.0 | | | |
| CWEIGHT | | 123 | 10.0 | | | |
| RUN | 123 | 125 | -1.25 | | | |
| ELBOW | | 125 | 130 | | | |
| RUN | 130 | 135 | -1.5 | | | |
| SNUBBER | | 135 | 25000. | | | |
| CWEIGHT | | 135 | 15.0 | | | |
| RUN | 135 | 138 | -0.25 | | | |
| RESTRAINT | | 138 | 50000. | | | |
| CWEIGHT | | 138 | 10.0 | | | |
| RUN | 138 | 139 | -18.031 | | | |
| RESTRAINT | | 139 | 50000. | | | |
| CWEIGHT | | 139 | 10.0 | | | |
| RUN | 139 | 140 | -0.25 | | | |

| | | | | | | | | |
|-----------|-----|--------|--------|--------|--------|------|--|--|
| SNUBBER | 140 | 25000. | | | | | | |
| CWEIGHT | 140 | | | 15.0 | | | | |
| RUN | 140 | 142 | | -2.875 | | | | |
| RUN | 142 | 144 | | -3.297 | | | | |
| ELBOW | 144 | 145 | | | | | | |
| RUN | 145 | 148 | 1.5 | | | | | |
| RESTRAINT | | 148 | | 1.0 | | | | |
| CWEIGHT | | 148 | | 10.0 | | | | |
| RUN | 148 | 150 | 3.0 | | | | | |
| RUN | 150 | 155 | 1.0 | | | | | |
| RUN | 155 | 160 | 1.0 | | | | | |
| RUN | 160 | 162 | 1.75 | | | | | |
| SNUBBER | | 162 | | 17000. | | | | |
| CWEIGHT | | 162 | | 15.0 | | | | |
| RUN | 162 | 163 | 4.75 | | | | | |
| RESTRAINT | | 163 | | 1.0 | | | | |
| CWEIGHT | | 163 | | 10.0 | | | | |
| RUN | 163 | 165 | 1.0 | | | | | |
| ELBOW | 165 | 170 | | | | | | |
| RUN | 170 | 172 | | -3.0 | | | | |
| RESTRAINT | | 172 | | | 50000. | | | |
| CWEIGHT | | 172 | | 10.0 | | | | |
| RUN | 172 | 173 | | -3.0 | | | | |
| RESTRAINT | | 173 | 50000. | | | | | |
| CWEIGHT | | 173 | | 10.0 | | | | |
| RUN | 173 | 175 | | -14.0 | | | | |
| RESTRAINT | | 175 | | | 50000. | | | |
| CWEIGHT | | 175 | | 10.0 | | | | |
| RUN | 175 | 177 | | -2.422 | | | | |
| RUN | 177 | 180 | | -3.781 | | | | |
| ELBOW | 180 | 185 | | | | | | |
| RUN | 185 | 190 | -2.0 | | | | | |
| RUN | 190 | 195 | -4.0 | | | | | |
| ANCHOR | | 195 | -12.0 | 17.417 | | | | |
| RUN | 17 | 295 | 4.5 | | 31.0 | 28.0 | | |
| REDUCER | 295 | 310 | .667 | | 28.0 | | | |
| RUN | 310 | 320 | 2.0 | | | | | |
| RUN | 320 | 330 | 2.0 | | | | | |
| RUN | 330 | 335 | 1.041 | | | | | |
| RESTRAINT | | 335 | | 1.0 | | | | |
| RUN | 335 | 340 | 3.0 | | | | | |
| ELBOW | 340 | 350 | | | | | | |
| RUN | 350 | 360 | | -2.25 | | | | |
| RESTRAINT | | 360 | | | 50000. | | | |
| CWEIGHT | | 360 | | 10.0 | | | | |
| RUN | 360 | 361 | | -0.25 | | | | |
| SNUBBER | | 361 | 17000. | | | | | |
| CWEIGHT | | 361 | | 15.0 | | | | |
| RUN | 361 | 365 | | -16.75 | | | | |
| RESTRAINT | | 365 | | | 50000. | | | |
| CWEIGHT | | 365 | | 10.0 | | | | |
| RUN | 365 | 369 | | -0.25 | | | | |
| SNUBBER | | 369 | 17000. | | | | | |
| CWEIGHT | | 369 | | 10.0 | | | | |
| RUN | 369 | 370 | | -3.5 | | | | |
| ELBOW | 370 | 380 | | | | | | |
| RUN | 380 | 382 | -1.0 | | | | | |
| SNUBBER | | 382 | | 17000. | | | | |
| CWEIGHT | | 382 | | 15.0 | | | | |
| RUN | 382 | 385 | -4.5 | | | | | |
| RESTRAINT | | 385 | | 1.0 | | | | |
| CWEIGHT | | 385 | | 10.0 | | | | |

| | | | | | | | | |
|-----------|------|------|--------|--------|--------|------|------|--|
| RUN | 385 | 390 | -5.5 | | | | | |
| ELBOW | 390 | 400 | | | | | | |
| RUN | 400 | 405 | | -1.25 | | | | |
| RESTRAINT | | 405 | 50000. | | | | | |
| CWEIGHT | | 405 | | 10.0 | | | | |
| RUN | 405 | 406 | | -.25 | | | | |
| RESTRAINT | | 406 | | | 50000. | | | |
| CWEIGHT | | 406 | | 10.0 | | | | |
| RUN | 406 | 408 | | -10.0 | | | | |
| SNUBBER | | 408 | 17000. | | | | | |
| CWEIGHT | | 408 | | 15.0 | | | | |
| RUN | 408 | 410 | | -6.0 | | | | |
| RESTRAINT | | 410 | | | 50000. | | | |
| CWEIGHT | | 410 | | 10.0 | | | | |
| RUN | 410 | 420 | | -6.343 | | | | |
| ELBOW | 420 | 430 | | | | | | |
| RUN | 430 | 435 | 1.0 | | | | | |
| RESTRAINT | | 435 | | | 50000. | | | |
| CWEIGHT | | 435 | | 10.0 | | | | |
| RUN | 435 | 440 | 4.5 | | | | | |
| RUN | 440 | 450 | 5.5 | | | | | |
| ANCHOR | | 450 | 16.0 | 17.416 | | | | |
| RUN | 8 | 495 | 2.541 | | | 33.0 | 30.0 | |
| REDUCER | 495 | 510 | 1.416 | | | 30.0 | | |
| ELBOW | 510 | 520 | | | | | | |
| RUN | 520 | 530 | | | 4.0 | | | |
| ELBOW | 530 | 540 | | | | | | |
| RUN | 540 | 550 | 2.5 | | | | | |
| RUN | 550 | 560 | 2.0 | | | | | |
| RUN | 560 | 570 | 2.0 | | | | | |
| RUN | 570 | 575 | 1.0 | | | 30.0 | | |
| RESTRAINT | | 575 | | 1.0 | | | | |
| RUN | 575 | 580 | 1.5 | | | | | |
| ELBOW | 580 | 590 | | | | | | |
| RUN | 590 | 600 | | | | -4.0 | | |
| ELBOW | 600 | 610 | | | | | | |
| RUN | 610 | 620 | 2.25 | | | | | |
| RUN | 620 | 630 | 2.25 | | | | | |
| ANCHOR | | 630 | 19.5 | 11.635 | | | | |
| RUN | 450 | 1450 | | | 5.5 | 34.0 | 28.0 | |
| ELBOW | 1450 | 1460 | | | | | | |
| RUN | 1460 | 1465 | 4.75 | | | | | |
| RUN | 1465 | 1467 | 3.5 | | | | | |
| SNUBBER | | 1467 | | | 17000. | | | |
| CWEIGHT | | 1467 | | 15.0 | | | | |
| RUN | 1467 | 1468 | 0.25 | | | | | |
| RESTRAINT | | 1468 | | | 50000. | | | |
| CWEIGHT | | 1468 | | 10.0 | | | | |
| RUN | 1468 | 1470 | 1.00 | | | | | |
| ELBOW | 1470 | 1480 | | | | | | |
| RUN | 1480 | 1485 | | | 5.5 | | | |
| RUN | 1485 | 1490 | | | 5.5 | | | |
| ELBOW | 1490 | 1495 | | | | | | |
| RUN | 1495 | 1500 | -1.0 | | | | | |
| RESTRAINT | | 1500 | | | 50000. | | | |
| CWEIGHT | | 1500 | | 10.0 | | | | |
| RUN | 1500 | 1502 | -2.5 | | | | | |
| RUN | 1502 | 1503 | -2.5 | | | | | |
| RUN | 1503 | 1505 | -3.5 | | | | | |
| ELBOW | 1505 | 1510 | | | | | | |
| RUN | 1510 | 1520 | | | 5.5 | | | |
| ANCHOR | | 1520 | 16.0 | 17.416 | 22.0 | | | |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.444 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 1 | 1.000 | 113. | 1520. | 230. | 343. |
| | 2 | 1.000 | 78. | 983. | 160. | 238. |
| RUN | 2 | 1.000 | 244. | 3081. | 523. | 767. |
| | 3 | 1.000 | 214. | 2633. | 456. | 670. |
| RUN | 3 | 1.000 | 6. | 92. | 0. | 6. |
| | 4 | 1.000 | 2. | 28. | 0. | 2. |
| RUN | 4 | 1.000 | 2. | 37. | 0. | 2. |
| | 5 | 1.000 | 1. | 19. | 0. | 1. |
| RUN | 5 | 1.000 | 3. | 44. | 0. | 3. |
| | 6 | 1.000 | 0. | 0. | 0. | 0. |
| RUN | 3 | 1.000 | 126. | 1558. | 271. | 397. |
| | 7 | 1.119 | 82. | 885. | 239. | 320. |
| RUN | 7 | 1.119 | 37. | 826. | 201. | 238. |
| | 9 | 1.000 | 30. | 693. | 164. | 194. |
| REDUCE | 9 | 2.000 | 148. | 3388. | 1070. | 1218. |
| | 10 | 2.000 | 114. | 2698. | 952. | 1065. |
| RUN | 10 | 1.000 | 118. | 2811. | 744. | 862. |
| | 8001 | 1.000 | 45. | 958. | 461. | 507. |
| RUN | 8001 | 1.000 | 45. | 958. | 461. | 507. |
| | 8002 | 1.000 | 58. | 508. | 179. | 236. |
| RUN | 8002 | 1.000 | 58. | 508. | 179. | 236. |
| | 11 | 1.000 | 90. | 1441. | 118. | 208. |
| RUN | 11 | 1.000 | 90. | 1441. | 119. | 209. |
| | 8003 | 1.000 | 97. | 1920. | 386. | 483. |
| RUN | 8003 | 1.000 | 97. | 1920. | 386. | 483. |
| | 8004 | 1.000 | 87. | 1949. | 668. | 755. |
| RUN | 8004 | 1.000 | 87. | 1949. | 668. | 755. |
| | 12 | 1.000 | 126. | 1593. | 950. | 1076. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.462 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 12 | 1.000 | 126. | 1593. | 950. | 1076. |
| | 8005 | 1.000 | 207. | 847. | 1232. | 1439. |
| RUN | 8005 | 1.000 | 207. | 847. | 1232. | 1439. |
| | 8006 | 1.000 | 323. | 1016. | 1513. | 1837. |
| RUN | 8006 | 1.000 | 323. | 1016. | 1513. | 1837. |
| | 13 | 1.000 | 471. | 2867. | 1795. | 2266. |
| RUN | 13 | 1.000 | 471. | 2867. | 1795. | 2266. |
| | 14 | 1.000 | 431. | 2552. | 1812. | 2243. |
| REDUCE | 14 | 2.000 | 414. | 2449. | 2318. | 2732. |
| | 15 | 2.000 | 321. | 1734. | 2371. | 2692. |
| RUN | 15 | 1.000 | 66. | 354. | 364. | 429. |
| | 16 | 1.119 | 50. | 244. | 415. | 465. |
| RUN | 16 | 1.119 | 32. | 262. | 446. | 478. |
| | 18 | 1.000 | 13. | 107. | 417. | 430. |
| ELBOW | 18 | 2.809 | 61. | 484. | 2519. | 2580. |
| | 19 | 2.809 | 332. | 542. | 2293. | 2625. |
| RUN | 19 | 1.000 | 73. | 120. | 380. | 453. |
| | 20 | 1.000 | 94. | 132. | 332. | 426. |
| REDUCE | 20 | 2.000 | 383. | 535. | 1796. | 2179. |
| | 21 | 2.000 | 359. | 492. | 1666. | 2025. |
| RUN | 21 | 1.000 | 310. | 425. | 1081. | 1391. |
| | 22 | 1.000 | 279. | 379. | 1026. | 1306. |
| REDUCE | 22 | 2.000 | 974. | 1322. | 4768. | 5742. |
| | 23 | 2.000 | 635. | 841. | 4249. | 4884. |
| RUN | 7 | 1.119 | 658. | 1054. | 1415. | 2073. |
| | 800 | 1.000 | 538. | 873. | 1381. | 1920. |
| RUN | 800 | 1.000 | 538. | 873. | 1386. | 1925. |
| | 8 | 1.000 | 374. | 621. | 1357. | 1732. |

079T1000008
84

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.479 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 16 | 1.119 | 282. | 943. | 1543. | 1824. |
| | 1700 | 1.000 | 386. | 991. | 1432. | 1818. |
| RUN | 1700 | 1.000 | 386. | 991. | 1432. | 1818. |
| | 17 | 1.000 | 472. | 912. | 1257. | 1729. |
| RUN | 23 | 1.000 | 5108. | 5775. | 9468. | 14577. |
| | 25 | 1.000 | 3780. | 3975. | 8273. | 12053. |
| RUN | 25 | 1.000 | 3780. | 3975. | 8273. | 12053. |
| | 105 | 1.000 | 3935. | 4542. | 6969. | 10905. |
| RUN | 105 | 1.000 | 3935. | 4542. | 6969. | 10905. |
| | 106 | 1.000 | 3883. | 4598. | 6752. | 10635. |
| RUN | 106 | 1.000 | 3883. | 4598. | 6752. | 10635. |
| | 110 | 1.000 | 3416. | 3809. | 2937. | 6353. |
| RUN | 110 | 1.000 | 3416. | 3809. | 2937. | 6353. |
| | 115 | 1.000 | 3460. | 3946. | 1635. | 5095. |
| RUN | 115 | 1.000 | 3460. | 3946. | 1635. | 5095. |
| | 120 | 1.000 | 3607. | 4257. | 333. | 3941. |
| RUN | 120 | 1.000 | 3607. | 4257. | 333. | 3941. |
| | 122 | 1.000 | 3762. | 4540. | 743. | 4505. |
| RUN | 122 | 1.000 | 3762. | 4540. | 743. | 4505. |
| | 123 | 1.000 | 3810. | 4522. | 945. | 4755. |
| RUN | 123 | 1.000 | 3810. | 4522. | 945. | 4755. |
| | 125 | 1.000 | 3463. | 4047. | 1351. | 4814. |
| ELBOW | 125 | 1.000 | 3463. | 4047. | 1351. | 4814. |
| | 130 | 1.000 | 3458. | 3802. | 2094. | 5552. |
| RUN | 130 | 1.000 | 3458. | 3802. | 2094. | 5552. |
| | 135 | 1.000 | 3404. | 3908. | 2228. | 5633. |
| RUN | 135 | 1.000 | 3404. | 3908. | 2228. | 5633. |
| | 138 | 1.000 | 3387. | 3845. | 2273. | 5660. |
| RUN | 138 | 1.000 | 3387. | 3845. | 2273. | 5660. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.497 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 138 | 1.000 | 3387. | 3845. | 2273. | 5660. |
| | 139 | 1.000 | 3388. | 4303. | 5570. | 8958. |
| RUN | 139 | 1.000 | 3388. | 4303. | 5570. | 8958. |
| | 140 | 1.000 | 3383. | 4275. | 5618. | 9000. |
| RUN | 140 | 1.000 | 3383. | 4275. | 5618. | 9000. |
| | 142 | 1.000 | 3340. | 3632. | 6160. | 9500. |
| RUN | 142 | 1.000 | 3340. | 3632. | 6160. | 9500. |
| | 144 | 1.000 | 3307. | 3970. | 6641. | 9948. |
| ELBOW | 144 | 1.000 | 3307. | 3970. | 6641. | 9948. |
| | 145 | 1.000 | 3216. | 3954. | 6133. | 9349. |
| RUN | 145 | 1.000 | 3216. | 3954. | 6133. | 9349. |
| | 148 | 1.000 | 3653. | 4354. | 5483. | 9136. |
| RUN | 148 | 1.000 | 3653. | 4354. | 5483. | 9136. |
| | 150 | 1.000 | 3242. | 3840. | 2999. | 6241. |
| RUN | 150 | 1.000 | 3242. | 3840. | 2999. | 6241. |
| | 155 | 1.000 | 3200. | 3845. | 2187. | 5387. |
| RUN | 155 | 1.000 | 3200. | 3845. | 2187. | 5387. |
| | 160 | 1.000 | 3196. | 3885. | 1374. | 4570. |
| RUN | 160 | 1.000 | 3196. | 3885. | 1374. | 4570. |
| | 162 | 1.000 | 3274. | 4047. | 363. | 3638. |
| RUN | 162 | 1.000 | 3274. | 4047. | 363. | 3638. |
| | 163 | 1.000 | 4259. | 4789. | 4477. | 8736. |
| RUN | 163 | 1.000 | 4259. | 4789. | 4477. | 8736. |
| | 165 | 1.000 | 3953. | 4499. | 4694. | 8647. |
| ELBOW | 165 | 1.000 | 3953. | 4499. | 4694. | 8647. |
| | 170 | 1.000 | 3407. | 3898. | 5202. | 8608. |
| RUN | 170 | 1.000 | 3407. | 3898. | 5202. | 8608. |
| | 172 | 1.000 | 3388. | 3688. | 4777. | 8165. |
| RUN | 172 | 1.000 | 3388. | 3688. | 4777. | 8165. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.515 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 172 | 1.000 | 3388. | 3688. | 4777. | 9165. |
| | 173 | 1.000 | 3768. | 4768. | 4210. | 7978. |
| RUN | 173 | 1.000 | 3768. | 4768. | 4210. | 7978. |
| | 175 | 1.000 | 3154. | 3907. | 2109. | 5264. |
| RUN | 175 | 1.000 | 3154. | 3907. | 2109. | 5264. |
| | 177 | 1.000 | 3219. | 3890. | 1844. | 5063. |
| RUN | 177 | 1.000 | 3219. | 3890. | 1844. | 5063. |
| | 180 | 1.000 | 3275. | 3734. | 1511. | 4787. |
| ELBOW | 180 | 1.000 | 3275. | 3734. | 1511. | 4787. |
| | 185 | 1.000 | 3280. | 3706. | 1344. | 4624. |
| RUN | 185 | 1.000 | 3280. | 3706. | 1344. | 4624. |
| | 190 | 1.000 | 3205. | 3551. | 1608. | 4813. |
| RUN | 190 | 1.000 | 3205. | 3551. | 1608. | 4813. |
| | 195 | 1.000 | 3613. | 5477. | 5072. | 8684. |
| RUN | 17 | 1.000 | 695. | 1063. | 975. | 1671. |
| | 295 | 1.000 | 510. | 733. | 621. | 1131. |
| REDUCE | 295 | 2.000 | 3161. | 6120. | 11010. | 14171. |
| | 310 | 2.000 | 2105. | 4932. | 10078. | 12183. |
| RUN | 310 | 1.000 | 1532. | 3416. | 5039. | 6571. |
| | 320 | 1.000 | 2177. | 3783. | 3641. | 5818. |
| RUN | 320 | 1.000 | 2177. | 3783. | 3641. | 5818. |
| | 330 | 1.000 | 5238. | 6495. | 2243. | 7481. |
| RUN | 330 | 1.000 | 5238. | 6495. | 2243. | 7481. |
| | 335 | 1.000 | 7047. | 8176. | 1515. | 8563. |
| RUN | 335 | 1.000 | 7047. | 8176. | 1515. | 8563. |
| | 340 | 1.000 | 673. | 1612. | 561. | 1234. |
| ELBOW | 340 | 2.267 | 875. | 2472. | 1271. | 2146. |
| | 350 | 2.267 | 3672. | 4477. | 2420. | 6092. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.532 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 350 | 1.000 | 2318. | 2792. | 1068. | 3386. |
| | 360 | 1.000 | 2132. | 3107. | 1255. | 3388. |
| RUN | 360 | 1.000 | 2132. | 3107. | 1255. | 3388. |
| | 361 | 1.000 | 2131. | 3162. | 1287. | 3417. |
| RUN | 361 | 1.000 | 2131. | 3162. | 1287. | 3417. |
| | 365 | 1.000 | 1527. | 2538. | 3664. | 5191. |
| RUN | 365 | 1.000 | 1527. | 2538. | 3664. | 5191. |
| | 369 | 1.000 | 1525. | 2407. | 3704. | 5229. |
| RUN | 369 | 1.000 | 1525. | 2407. | 3704. | 5229. |
| | 370 | 1.000 | 1609. | 2082. | 4143. | 5752. |
| ELBOW | 370 | 2.267 | 2465. | 3270. | 9391. | 11856. |
| | 380 | 2.267 | 2262. | 3255. | 8469. | 10731. |
| RUN | 380 | 1.000 | 1489. | 2073. | 3736. | 5225. |
| | 382 | 1.000 | 1348. | 2092. | 3561. | 4909. |
| RUN | 382 | 1.000 | 1348. | 2092. | 3561. | 4909. |
| | 385 | 1.000 | 3813. | 4736. | 825. | 4638. |
| RUN | 385 | 1.000 | 3813. | 4736. | 825. | 4638. |
| | 390 | 1.000 | 600. | 1088. | 2942. | 3542. |
| ELBOW | 390 | 2.267 | 751. | 1581. | 6668. | 7419. |
| | 400 | 2.267 | 1709. | 2429. | 7593. | 9303. |
| RUN | 400 | 1.000 | 1164. | 1587. | 3350. | 4514. |
| | 405 | 1.000 | 1406. | 2118. | 3270. | 4676. |
| RUN | 405 | 1.000 | 1406. | 2118. | 3270. | 4676. |
| | 406 | 1.000 | 1347. | 1999. | 3241. | 4588. |
| RUN | 406 | 1.000 | 1347. | 1999. | 3241. | 4588. |
| | 408 | 1.000 | 1049. | 1727. | 2059. | 3108. |
| RUN | 408 | 1.000 | 1049. | 1727. | 2059. | 3108. |
| | 410 | 1.000 | 1349. | 3173. | 1950. | 3299. |

88
079T1000008

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.550 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 410 | 1.000 | 1349. | 3173. | 1950. | 3299. |
| | 420 | 1.000 | 1322. | 1871. | 1909. | 3231. |
| ELBOW | 420 | 2.267 | 1978. | 2912. | 4327. | 6305. |
| | 430 | 2.267 | 3226. | 4600. | 3372. | 6599. |
| RUN | 430 | 1.000 | 2056. | 2864. | 1488. | 3544. |
| | 435 | 1.000 | 2803. | 3853. | 1453. | 4255. |
| RUN | 435 | 1.000 | 2803. | 3853. | 1453. | 4255. |
| | 440 | 1.000 | 920. | 1258. | 517. | 1437. |
| RUN | 440 | 1.000 | 920. | 1258. | 517. | 1437. |
| | 450 | 1.000 | 926. | 2620. | 739. | 1665. |
| RUN | 8 | 1.000 | 614. | 820. | 1123. | 1737. |
| | 495 | 1.000 | 404. | 488. | 1062. | 1466. |
| REDUCE | 495 | 2.000 | 1743. | 2867. | 18833. | 20576. |
| | 510 | 2.000 | 1635. | 2653. | 18556. | 20191. |
| ELBOW | 510 | 2.267 | 1802. | 2955. | 21029. | 22831. |
| | 520 | 2.267 | 1394. | 2288. | 14187. | 15582. |
| RUN | 520 | 1.000 | 979. | 1504. | 6259. | 7238. |
| | 530 | 1.000 | 751. | 1056. | 3757. | 4508. |
| ELBOW | 530 | 2.267 | 1007. | 1527. | 8516. | 9523. |
| | 540 | 2.267 | 1275. | 1809. | 15109. | 16384. |
| RUN | 540 | 1.000 | 908. | 1223. | 6666. | 7574. |
| | 550 | 1.000 | 965. | 1317. | 6913. | 7879. |
| RUN | 550 | 1.000 | 965. | 1317. | 6913. | 7879. |
| | 560 | 1.000 | 827. | 1217. | 7231. | 8058. |
| RUN | 560 | 1.000 | 827. | 1217. | 7231. | 8058. |
| | 570 | 1.000 | 751. | 1171. | 7581. | 8332. |
| RUN | 570 | 1.000 | 751. | 1171. | 7581. | 8332. |
| | 575 | 1.000 | 996. | 1456. | 7767. | 8763. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.568 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 575 | 1.000 | 996. | 1456. | 7767. | 8763. |
| | 580 | 1.000 | 811. | 1316. | 7911. | 8722. |
| ELBOW | 580 | 2.267 | 1109. | 1968. | 17931. | 19040. |
| | 590 | 2.267 | 662. | 1375. | 11753. | 12416. |
| RUN | 590 | 1.000 | 548. | 967. | 5185. | 5733. |
| | 600 | 1.000 | 624. | 1099. | 4680. | 5304. |
| ELBOW | 600 | 2.267 | 791. | 1599. | 10609. | 11400. |
| | 610 | 2.267 | 811. | 1889. | 16872. | 17684. |
| RUN | 610 | 1.000 | 636. | 1270. | 7444. | 8079. |
| | 620 | 1.000 | 706. | 1373. | 7252. | 7958. |
| RUN | 620 | 1.000 | 706. | 1373. | 7252. | 7958. |
| | 630 | 1.000 | 1218. | 2660. | 7007. | 8225. |
| RUN | 450 | 1.000 | 2367. | 4299. | 8054. | 10421. |
| | 1450 | 1.000 | 764. | 1085. | 8054. | 8818. |
| ELBOW | 1450 | 2.606 | 1037. | 1663. | 20993. | 22030. |
| | 1460 | 2.606 | 1098. | 1772. | 15512. | 16610. |
| RUN | 1460 | 1.000 | 795. | 1140. | 5951. | 6747. |
| | 1465 | 1.000 | 881. | 1039. | 64. | 945. |
| RUN | 1465 | 1.000 | 881. | 1039. | 64. | 945. |
| | 1467 | 1.000 | 783. | 950. | 5824. | 6608. |
| RUN | 1467 | 1.000 | 783. | 950. | 5824. | 6608. |
| | 1468 | 1.000 | 845. | 1092. | 6245. | 7090. |
| RUN | 1468 | 1.000 | 845. | 1092. | 6245. | 7090. |
| | 1470 | 1.000 | 921. | 1110. | 5824. | 6746. |
| ELBOW | 1470 | 2.606 | 1344. | 1712. | 15181. | 16525. |
| | 1480 | 2.606 | 1378. | 2218. | 20662. | 22040. |
| RUN | 1480 | 1.000 | 939. | 1368. | 7927. | 8866. |
| | 1485 | 1.000 | 1443. | 1793. | 7927. | 9371. |

CARRIZO MSG PLUS STEAM PIPING PLUS NA INLET AND OUTLET

ELAPSED CPU = 17.584 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 1485 | 1.000 | 1443. | 1793. | 7927. | 9371. |
| | 1490 | 1.000 | 940. | 1235. | 7927. | 8867. |
| ELBOW | 1490 | 2.606 | 1380. | 1957. | 20662. | 22042. |
| | 1495 | 2.606 | 1353. | 2182. | 15181. | 16534. |
| RUN | 1495 | 1.000 | 926. | 1350. | 5824. | 6750. |
| | 1500 | 1.000 | 849. | 1266. | 6245. | 7094. |
| RUN | 1500 | 1.000 | 849. | 1266. | 6245. | 7094. |
| | 1502 | 1.000 | 761. | 1104. | 2039. | 2800. |
| RUN | 1502 | 1.000 | 761. | 1104. | 2039. | 2800. |
| | 1503 | 1.000 | 915. | 1138. | 2166. | 3081. |
| RUN | 1503 | 1.000 | 915. | 1138. | 2166. | 3081. |
| | 1505 | 1.000 | 790. | 1132. | 5952. | 6741. |
| ELBOW | 1505 | 2.606 | 1087. | 1756. | 15513. | 16600. |
| | 1510 | 2.606 | 1034. | 1734. | 20994. | 22028. |
| RUN | 1510 | 1.000 | 763. | 1121. | 8054. | 8817. |
| | 1520 | 1.000 | 2364. | 4287. | 8054. | 10419. |
| REPORT | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000
08:35:52 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
08:35:52 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
08:35:52 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
08:35:52 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
08:35:52 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=$WW232.CARRIZO.DISPLACE.DATA
08:35:52 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
08:35:52 IAT4401 LOCATE FOR STEP=G DD=FT69FOO1 DSN=$WWO49.ROCKPIPE.USERS
08:35:52 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
08:35:52 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
08:35:52 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
08:35:53 USES CVTSOK 01 093128 D $WWO49.NUPIPE.LOAD
08:35:53 USES AVTSOA 01 093128 D $WW232.CARRIZO.DISPLACE.DATA
08:35:53 IAT5200 JOB 2507 ($WW232T1) IN SETUP ON MAIN=C P=03 LOCAL
08:35:53 IAT5210 J=2507 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
08:35:53 IAT5210 J=2507 FT15FOO1 USING D AVTSOA ON 520 $WW232.CARRIZO.DISPLACE.DATA
08:35:58 IAT2000 JOB 2507 $WW232T1 SELECTED C GRP=BIG
08:36:00 C R= $WW232T1 NEF995I $WW232T1 STARTED, 3/09/83,08.35.56 ASID=00081
08:36:00 C R= $WW232T1 IEF403I $WW232T1 - STARTED - TIME=08.35.56
08:36:49 C R= $WW232T1 +IH0002I STOP 1
08:36:50 C R= $WW232T1 IEF404I $WW232T1 - ENDED - TIME=08.36.47
08:36:50 C R= $WW232T1 NEF996I $WW232T1 ENDED, 3/09/83,B.U.= .9776 *0716935 ,3081-C3,JOB CC= 001
08:36:52 IAT5400 JOB 2507 ($WW232T1) IN BREAKDOWN
/$WW232T1 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RMO05 00000300
/ EXEC ROCKPIPE,PROG=SMALL
/G.SYSIN DD DSN=$WW232.CARRIZO.DISPLACE.DATA,DISP=SHR
1 // $WW232T1 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
// REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
2 // EXEC ROCKPIPE,PROG=SMALL
3 XXROCKPIPE PROC DSN='$WWO49.NUPIPE.LOAD',PROG=SMALL,C=10,
XX PROGA=SEVEN,B=19069,PROGE=OPT2,DSNE='$WWO49.ELTEMP.LOAD',
XX USERS='$WWO49.ROCKPIPE.USERS'
*** AL HROMJAK ROCKWELL INTERNATIONAL, ESG. COMNET 393-3318
*** FT50FOO1 FOR 7-SPECTRA NODE ACCELERATIONS.
*** IN BOTH STEPS, FT66 CONTAINS DIAGNOSTIC OUTPUT.
*** FT66FOO1 IN G STEP CONTAINS TIME SPENT IN MAJOR PROGRAM PHASES.
*** FT16FOO1 DUMMIED WHEN P STEP DELETED.
*** FT17FOO1, FT18FOO1, FT19FOO1, FT20FOO1 ADDED FOR SNUBBER ITERATIONS
4 XXA EXEC PGM=&PROGA
*** THIS STEP READS THE 7 SPECTRA AND TRANSLATES THEM TO A NEW POINT
*** NEW SPECTRA WRITTEN ON FTO1FOO1
5 XXSTEPLIB DD DSN=&DSN,DISP=SHR
6 XXFTO1FOO1 DD UNIT=SYSDA,DSN=&&SPEC,SPACE=(TRK,(10),RLSE),DISP=(,PASS),
XX DCB=(RECFM=F,LRECL=80,BLKSIZE=80)
7 XXFTO5FOO1 DD DDNAME=SYSIN
8 XXFTO6FOO1 DD SYSOUT=*
9 XXFT66FOO1 DD DUMMY,DCB=(RECFM=VBA,BLKSIZE=2020)
10 XXG EXEC PGM=&PROG
*** THIS STEP EXECUTES ROCKPIPE. LOAD CASES, 7-SPECTRA (IF ANY), AND
*** GEOMETRY ARE READ FROM UNIT FT15'S 3 CONCATANATED DATA SETS. LOAD
*** CASES TO BE DELETED FROM PRINTING ARE DETECTED AND THE CASE NO.'S
*** MADE PLUS. ALL 3 FILES FROM FT15 ARE WRITTEN ON FTO5 AS ONE FILE TO
*** BE READ BY NUPIPE.
11 XXSTEPLIB DD DSN=&DSN,DISP=SHR
12 XXFTO1FOO1 DD UNIT=SYSDA,DCB=(RECFM=VBS,BLKSIZE=&B),
XX SPACE=(CYL,(&C,&C))
13 XXFTO2FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
14 **FTO3FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
15 FTO4FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&

```

ORIGINAL INPUT BY GURSAHANI ON 03/09/83 AT 08:36:12 WITH PRIORITY 3
 CARRIZO RUN FOR DETERMINING SG NOZZLE MOVEMENTS

| | | | | | | | | | |
|---|----|-------|-------|--------|------|-------|--|--|----|
| CONTROL | | | 2.0 | | | | | | 1 |
| FLEXAN | 1 | 1 | 2.0 | | | | | | 2 |
| TE1 (THERMAL AT THE DESIGN TEMPERATURE) | | | | | | | | | 3 |
| FLEXAN | 2 | 2 | 2.0 | | | | | | 4 |
| TE2 (THERMAL OVERNIGHT SHUTDOWN) | | | | | | | | | 5 |
| FLEXAN | 3 | 3 | 2.0 | | | | | | 6 |
| TE3 (SG AND NA INLET AT 600, NA OUTLET AT 300 AND STEAM PIPING AT 70) | | | | | | | | | 7 |
| XSECTN | 1 | 54.22 | 0.721 | 812.0 | 29.9 | | | | 8 |
| XSECTN | 2 | 30.94 | 0.721 | 705.1 | 29.9 | | | | 9 |
| XSECTN | 3 | 21.5 | 1.0 | 580.1 | 29.9 | 0.0 | | | 10 |
| XSECTN | 4 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 | | | 11 |
| XSECTN | 5 | 12.81 | 1.0 | 370.3 | 29.9 | 0.0 | | | 12 |
| XSECTN | 6 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 | | | 13 |
| XSECTN | 7 | 12.75 | .562 | 51.7 | 29.9 | 0.0 | | | 14 |
| XSECTN | 8 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 | | | 15 |
| XSECTN | 9 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 | | | 16 |
| XSECTN | 10 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 17 |
| XSECTN | 11 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 18 |
| XSECTN | 12 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 19 |
| XSECTN | 13 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 20 |
| XSECTN | 14 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 | | | 21 |
| XSECTN | 15 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 | | | 22 |
| XSECTN | 16 | 12.75 | .562 | 92.1 | 29.9 | 0.0 | | | 23 |
| XSECTN | 17 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 | | | 24 |
| XSECTN | 18 | 24.0 | 1.0 | 524.4 | 29.9 | 0.0 | | | 25 |
| XSECTN | 19 | 26.0 | 1.97 | 927.5 | 29.9 | 0.0 | | | 26 |
| XSECTN | 20 | 21.5 | 1.0 | 596.4 | 29.9 | 0.0 | | | 27 |
| XSECTN | 21 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 | | | 28 |
| XSECTN | 22 | 12.81 | 1.0 | 376.9 | 29.9 | 0.0 | | | 29 |
| XSECTN800 | 23 | 12.75 | 0.562 | 51.7 | 299. | 0.0 | | | 30 |
| XSECT1700 | 24 | 12.75 | 0.562 | 89.8 | 299. | 0.0 | | | 31 |
| XSECTN | 25 | 6.625 | 0.864 | 85.5 | 29.9 | 1590. | | | 32 |
| XSECTN NA | 26 | 6.625 | 0.864 | | 29.9 | 1590. | | | 33 |
| XSECTN NA | 27 | 12.75 | 0.406 | 175. | 28.3 | 65. | | | 34 |
| XSECTN | 28 | 6.625 | 0.280 | 98.5 | 28.3 | 65. | | | 35 |
| XSECTN NA | 29 | 12.75 | 0.406 | 130. | 27.9 | 65. | | | 36 |
| XSECTN | 30 | 6.625 | 0.280 | 53.4 | 27.9 | 65. | | | 37 |
| XSECTN | 31 | 12.75 | 0.687 | 218.8 | 28.3 | 85. | | | 38 |
| XSECTN NA | 32 | 6.625 | 0.280 | | 27.9 | 65. | | | 39 |
| XSECTN | 33 | 12.75 | 0.687 | 218.8 | 27.9 | 65. | | | 40 |
| XSECTN | 34 | 10.75 | 0.365 | 154.6 | 28.3 | 65. | | | 41 |
| OPVAL225 | 1 | 1 | 29.4 | .01198 | | | | | 42 |
| OPVAL435 | 1 | 2 | 28.4 | .03022 | | | | | 43 |
| OPVAL470 | 1 | 3 | 28.2 | .03344 | | | | | 44 |
| OPVAL450 | 1 | 4 | 28.3 | .03160 | | | | | 45 |
| OPVAL450 | 1 | 5 | 28.3 | .03160 | | | | | 46 |
| OPVAL587 | 1 | 6 | 27.5 | .04473 | | | | | 47 |
| OPVAL620 | 1 | 7 | 27.2 | .04086 | | | | | 48 |
| OPVAL625 | 1 | 8 | 27.2 | .04858 | | | | | 49 |
| OPVAL640 | 1 | 9 | 27.1 | .05012 | | | | | 50 |
| OPVAL705 | 1 | 10 | 26.6 | .05684 | | | | | 51 |
| OPVAL865 | 1 | 11 | 24.9 | .07422 | | | | | 52 |
| OPVAL1010 | 1 | 12 | 22.7 | .09005 | | | | | 53 |
| OPVAL1050 | 1 | 13 | 21.7 | .09465 | | | | | 54 |
| OPVAL1055 | 1 | 14 | 21.6 | .09523 | | | | | 55 |
| OPVAL1057 | 1 | 15 | 21.5 | .09546 | | | | | 56 |
| OPVAL1065 | 1 | 16 | 21.3 | .09638 | | | | | 57 |
| OPVAL1055 | 1 | 17 | 21.6 | .09523 | | | | | 58 |
| | | | | | | | | | 59 |

| | | | | | | |
|------------|---|----|-------|--------|-------|-----|
| OPVAL 1025 | 1 | 18 | 22.4 | .09178 | | 60 |
| OPVAL 1020 | 1 | 19 | 22.5 | .09120 | | 61 |
| OPVAL 1020 | 1 | 20 | 22.5 | .09120 | | 62 |
| OPVAL 1015 | 1 | 21 | 22.6 | .09063 | | 63 |
| OPVAL 1015 | 1 | 22 | 22.6 | .09063 | | 64 |
| OPVAL 800 | 1 | 23 | 273.0 | .04703 | | 65 |
| OPVAL 1065 | 1 | 24 | 213.0 | .09638 | | 66 |
| OPVAL 1015 | 1 | 25 | 22.60 | .09063 | 1590. | 67 |
| OPVAL NA | 1 | 26 | 22.74 | .09005 | 1590. | 68 |
| OPVAL NA | 1 | 27 | 22.4 | .12364 | 65. | 69 |
| OPVAL 1065 | 1 | 28 | 22.4 | .12364 | 65. | 70 |
| OPVAL NA | 1 | 29 | 25.61 | .04703 | 65. | 71 |
| OPVAL 610 | 1 | 30 | 25.61 | .04703 | 65. | 72 |
| OPVAL 201 | 2 | 1 | 29.5 | .00998 | | 73 |
| OPVAL 381 | 2 | 2 | 29.1 | .02533 | | 74 |
| OPVAL 420 | 2 | 3 | 28.5 | .02884 | | 75 |
| OPVAL 400 | 2 | 4 | 28.5 | .02700 | | 76 |
| OPVAL 400 | 2 | 5 | 28.5 | .02700 | | 77 |
| OPVAL 550 | 2 | 6 | 27.7 | .04110 | | 78 |
| OPVAL 570 | 2 | 7 | 27.6 | .04306 | | 79 |
| OPVAL 575 | 2 | 8 | 27.6 | .04355 | | 80 |
| OPVAL 585 | 2 | 9 | 27.5 | .04453 | | 81 |
| OPVAL 650 | 2 | 10 | 27.0 | .05115 | | 82 |
| OPVAL 770 | 2 | 11 | 26.0 | .06379 | | 83 |
| OPVAL 890 | 2 | 12 | 24.6 | .07699 | | 84 |
| OPVAL 940 | 2 | 13 | 23.9 | .08242 | | 85 |
| OPVAL 942 | 2 | 14 | 23.9 | .08264 | | 86 |
| OPVAL 948 | 2 | 15 | 23.8 | .08328 | | 87 |
| OPVAL 950 | 2 | 16 | 23.8 | .08350 | | 88 |
| OPVAL 950 | 2 | 17 | 23.8 | .08350 | | 89 |
| OPVAL 910 | 2 | 18 | 24.4 | .07918 | | 90 |
| OPVAL 905 | 2 | 19 | 24.4 | .07864 | | 91 |
| OPVAL 902 | 2 | 20 | 24.5 | .07832 | | 92 |
| OPVAL 900 | 2 | 21 | 24.5 | .07810 | | 93 |
| OPVAL 900 | 2 | 22 | 24.5 | .07810 | | 94 |
| OPVAL 570 | 2 | 23 | 276.0 | .04306 | | 95 |
| OPVAL 950 | 2 | 24 | 237.5 | .08350 | | 96 |
| OPVAL 850 | 2 | 25 | 25.1 | .07255 | 1590. | 97 |
| OPVAL NA | 2 | 26 | 22.74 | .09005 | 1590. | 98 |
| OPVAL NA | 2 | 27 | 23.2 | .10800 | 65. | 99 |
| OPVAL 950 | 2 | 28 | 23.2 | .10800 | 65. | 100 |
| OPVAL NA | 2 | 29 | 27.4 | .0182 | 65. | 101 |
| OPVAL 300 | 2 | 30 | 27.4 | .0182 | 65. | 102 |
| OPVAL 226 | 3 | 1 | 29.4 | .01208 | 65. | 103 |
| OPVAL 492 | 3 | 2 | 28.0 | .03546 | 65. | 104 |
| OPVAL 600 | 3 | 3 | 27.4 | .0460 | 65. | 105 |
| OPVAL 600 | 3 | 4 | 27.4 | .0460 | 65. | 106 |
| OPVAL 600 | 3 | 5 | 27.4 | .0460 | 65. | 107 |
| OPVAL 600 | 3 | 6 | 27.4 | .0460 | 65. | 108 |
| OPVAL 600 | 3 | 7 | 27.4 | .0460 | 65. | 109 |
| OPVAL 600 | 3 | 8 | 27.4 | .0460 | 65. | 110 |
| OPVAL 600 | 3 | 9 | 27.4 | .0460 | 65. | 111 |
| OPVAL 600 | 3 | 10 | 27.4 | .0460 | 65. | 112 |
| OPVAL 600 | 3 | 11 | 27.4 | .0460 | 65. | 113 |
| OPVAL 600 | 3 | 12 | 27.4 | .0460 | 65. | 114 |
| OPVAL 600 | 3 | 13 | 27.4 | .0460 | 65. | 115 |
| OPVAL 600 | 3 | 14 | 27.4 | .0460 | 65. | 116 |
| OPVAL 600 | 3 | 15 | 27.4 | .0460 | 65. | 117 |
| OPVAL 600 | 3 | 16 | 27.4 | .0460 | 65. | 118 |
| OPVAL 600 | 3 | 17 | 27.4 | .0460 | 65. | 119 |
| OPVA | 3 | 18 | 27.4 | .0460 | 65. | 120 |
| OPVA | 3 | 19 | 27.4 | .0460 | | 121 |

| | | | | | | | |
|-----------|------|------|---------|--------|---------|-------|-----|
| OPVAL 600 | 3 | 20 | 27.4 | .0460 | | 65. | 122 |
| OPVAL 600 | 3 | 21 | 27.4 | .0460 | | 65. | 123 |
| OPVAL 600 | 3 | 22 | 27.4 | .0460 | | 65. | 124 |
| OPVAL 600 | 3 | 23 | 274.0 | .0460 | | 65. | 125 |
| OPVAL 600 | 3 | 24 | 274.0 | .0460 | | | 126 |
| OPVAL 70 | 3 | 25 | 29.9 | | | 1590. | 127 |
| OPVAL NA | 3 | 26 | 22.74 | | | 1590. | 128 |
| OPVAL NA | 3 | 27 | 25.6 | .0624 | | 65. | 129 |
| OPVAL 600 | 3 | 28 | 25.6 | .0624 | | 65. | 130 |
| OPVAL NA | 3 | 29 | 27.4 | .0182 | | 65. | 131 |
| OPVAL 300 | 3 | 30 | 27.4 | .0182 | | 65. | 132 |
| ANCHOR | | 1 | | | | | 133 |
| RUN | 1 | 2 | | 5.0 | 1.0 | 1.0 | 134 |
| RUN | 2 | 3 | | 1.489 | 2.0 | 2.0 | 135 |
| RUN | 3 | 4 | | -1.667 | 3.0 | 3.0 | 136 |
| RUN | 4 | 5 | | -.646 | 4.0 | 4.0 | 137 |
| RUN | 5 | 6 | | -1.896 | 5.0 | 5.0 | 138 |
| RUN | 3 | 7 | | 5.146 | 6.0 | 6.0 | 139 |
| TEE | 7 | 800 | | | | | 140 |
| RUN | 7 | 9 | | 1.417 | 8.0 | 8.0 | 141 |
| REDUCER | 9 | 10 | | 1.666 | 9.0 | 9.0 | 142 |
| RUN | 10 | 11 | | 15.291 | 10.0 | 10.0 | 143 |
| RUN | 11 | 12 | | 15.250 | 11.0 | 11.0 | 144 |
| RUN | 12 | 13 | | 15.250 | 12.0 | 12.0 | 145 |
| RESTRAINT | | 13 | 100000. | | 100000. | | 146 |
| RUN | 13 | 14 | | 0.667 | 13.0 | 13.0 | 147 |
| REDUCER | 14 | 15 | | 1.666 | 14.0 | 14.0 | 148 |
| RUN | 15 | 16 | | 1.417 | 15.0 | 15.0 | 149 |
| TEE | 16 | 1700 | | | | | 150 |
| RUN | 16 | 18 | | 5.563 | 17.0 | 17.0 | 151 |
| ELBOW | 18 | 19 | 24.0 | | 18.0 | 18.0 | 152 |
| RUN | 19 | 20 | -4.0 | | 19.0 | 19.0 | 153 |
| REDUCER | 20 | 21 | -1.0 | | 20.0 | 20.0 | 154 |
| RUN | 21 | 22 | -0.646 | | 21.0 | 21.0 | 155 |
| REDUCER | 22 | 23 | -1.333 | | 22.0 | 22.0 | 156 |
| RUN | 7 | 800 | 1.083 | | 23.0 | 23.0 | 157 |
| RUN | 800 | 8 | 0.958 | | 7.0 | 7.0 | 158 |
| RUN | 16 | 1700 | 1.083 | | 24.0 | 24.0 | 159 |
| RUN | 1700 | 17 | 1.709 | | 16.0 | 16.0 | 160 |
| STRESS7 | | | | | | | 161 |
| 10CASES | 1 | 2 | 3 | | | | 162 |
| ALLDONE | | | | | | | 163 |

| MEMBER | END | FORCES (LBS) | | | MOMENTS (IN-LBS) | | | DEFLECTIONS (IN) | | | ROTATIONS (RAD) | | |
|--------|------|--------------|-----|----|------------------|----|-----|------------------|-------|-----|-----------------|-----|---------|
| | | FX | FY | FZ | MX | MY | MZ | DX | DY | DZ | RX | RY | RZ |
| RUN | 16 | 0. | -0. | 0. | 0. | 0. | -0. | -0.000 | 4.219 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 18 | -0. | 0. | 0. | 0. | 0. | -0. | -0.000 | 4.558 | 0.0 | 0.0 | 0.0 | 0.0000 |
| ELBOW | 18 | 0. | -0. | 0. | 0. | 0. | 0. | -0.000 | 4.558 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 8001 | -0. | 0. | 0. | 0. | 0. | -0. | -0.054 | 4.688 | 0.0 | 0.0 | 0.0 | 0.0000 |
| ELBOW | 8001 | -0. | -0. | 0. | 0. | 0. | 0. | -0.054 | 4.688 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 19 | 0. | 0. | 0. | 0. | 0. | -0. | -0.184 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 19 | 0. | -0. | 0. | 0. | 0. | 0. | -0.184 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 20 | -0. | 0. | 0. | 0. | 0. | -0. | -0.366 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| REDUCE | 20 | 0. | -0. | 0. | 0. | 0. | 0. | -0.366 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 21 | -0. | 0. | 0. | 0. | 0. | 0. | -0.457 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 21 | 0. | -0. | 0. | 0. | 0. | 0. | -0.457 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 22 | 0. | 0. | 0. | 0. | 0. | 0. | -0.516 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| REDUCE | 22 | -0. | -0. | 0. | 0. | 0. | 0. | -0.516 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 23 | 0. | 0. | 0. | 0. | 0. | 0. | -0.637 | 4.742 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 7 | 0. | 0. | 0. | 0. | 0. | 0. | 0.000 | 0.335 | 0.0 | 0.0 | 0.0 | -0.0000 |
| | 800 | -0. | -0. | 0. | 0. | 0. | -0. | 0.051 | 0.335 | 0.0 | 0.0 | 0.0 | -0.0000 |
| RUN | 800 | -0. | 0. | 0. | 0. | 0. | -0. | 0.051 | 0.335 | 0.0 | 0.0 | 0.0 | -0.0000 |
| | 8 | 0. | -0. | 0. | 0. | 0. | 0. | 0.090 | 0.335 | 0.0 | 0.0 | 0.0 | -0.0000 |
| RUN | 16 | 0. | -0. | 0. | 0. | 0. | -0. | -0.000 | 4.219 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 1700 | -0. | 0. | 0. | 0. | 0. | -0. | 0.104 | 4.219 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 1700 | -0. | -0. | 0. | 0. | 0. | 0. | 0.104 | 4.219 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 17 | 0. | 0. | 0. | 0. | 0. | -0. | 0.269 | 4.219 | 0.0 | 0.0 | 0.0 | 0.0000 |

079T1000008
96

| MEMBER | END | FORCES (LBS) | | | MX | MOMENTS (IN-LBS) | | | DEFLECTIONS (IN) | | | ROTATIONS (RAD) | | |
|--------|------|--------------|-----|----|----|------------------|-----|--------|------------------|-----|-----|-----------------|---------|--|
| | | FX | FY | FZ | | MY | MZ | DX | DY | DZ | RX | RY | RZ | |
| RUN | 16 | 0. | -0. | 0. | 0. | 0. | -0. | -0.000 | 3.675 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 18 | -0. | 0. | 0. | 0. | 0. | -0. | -0.000 | 3.972 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| ELBOW | 18 | 0. | -0. | 0. | 0. | 0. | 0. | -0.000 | 3.972 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 8001 | -0. | 0. | 0. | 0. | 0. | -0. | -0.046 | 4.084 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| ELBOW | 8001 | 0. | -0. | 0. | 0. | 0. | 0. | -0.046 | 4.084 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 19 | -0. | 0. | 0. | 0. | 0. | -0. | -0.158 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| RUN | 19 | 0. | -0. | 0. | 0. | 0. | 0. | -0.158 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 20 | -0. | 0. | 0. | 0. | 0. | -0. | -0.316 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| REDUCE | 20 | 0. | -0. | 0. | 0. | 0. | 0. | -0.316 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 21 | -0. | 0. | 0. | 0. | 0. | 0. | -0.394 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| RUN | 21 | 0. | -0. | 0. | 0. | 0. | 0. | -0.394 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 22 | -0. | 0. | 0. | 0. | 0. | 0. | -0.444 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| REDUCE | 22 | -0. | -0. | 0. | 0. | 0. | 0. | -0.444 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 23 | 0. | 0. | 0. | 0. | 0. | 0. | -0.549 | 4.131 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| RUN | 7 | 0. | -0. | 0. | 0. | 0. | -0. | 0.000 | 0.299 | 0.0 | 0.0 | 0.0 | -0.0000 | |
| | 800 | -0. | 0. | 0. | 0. | 0. | -0. | 0.047 | 0.299 | 0.0 | 0.0 | 0.0 | -0.0000 | |
| RUN | 800 | -0. | -0. | 0. | 0. | 0. | 0. | 0.047 | 0.299 | 0.0 | 0.0 | 0.0 | -0.0000 | |
| | 8 | 0. | 0. | 0. | 0. | 0. | -0. | 0.088 | 0.299 | 0.0 | 0.0 | 0.0 | -0.0000 | |
| RUN | 16 | -0. | -0. | 0. | 0. | 0. | -0. | -0.000 | 3.675 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 1700 | 0. | 0. | 0. | 0. | 0. | -0. | 0.090 | 3.675 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| RUN | 1700 | -0. | -0. | 0. | 0. | 0. | -0. | 0.090 | 3.675 | 0.0 | 0.0 | 0.0 | 0.0000 | |
| | 17 | 0. | 0. | 0. | 0. | 0. | -0. | 0.233 | 3.675 | 0.0 | 0.0 | 0.0 | 0.0000 | |

| MEMBER | END | FORCES (LBS) | | | MOMENTS (IN-LBS) | | | DEFLECTIONS (IN) | | | ROTATIONS (RAD) | | |
|--------|------|--------------|-----|----|------------------|----|-----|------------------|-------|-----|-----------------|-----|---------|
| | | FX | FY | FZ | MX | MY | MZ | DX | DY | DZ | RX | RY | RZ |
| RUN | 16 | 0. | 0. | 0. | 0. | 0. | -0. | -0.000 | 2.771 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 18 | -0. | -0. | 0. | 0. | 0. | -0. | -0.000 | 2.934 | 0.0 | 0.0 | 0.0 | 0.0000 |
| ELBOW | 18 | 0. | -0. | 0. | 0. | 0. | 0. | -0.000 | 2.934 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 8001 | -0. | 0. | 0. | 0. | 0. | -0. | -0.027 | 2.999 | 0.0 | 0.0 | 0.0 | 0.0000 |
| ELBOW | 8001 | -0. | -0. | 0. | 0. | 0. | 0. | -0.027 | 2.999 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 19 | 0. | 0. | 0. | 0. | 0. | -0. | -0.092 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 19 | 0. | -0. | 0. | 0. | 0. | 0. | -0.092 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 20 | -0. | 0. | 0. | 0. | 0. | -0. | -0.184 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| REDUCE | 20 | 0. | -0. | 0. | 0. | 0. | 0. | -0.184 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 21 | -0. | 0. | 0. | 0. | 0. | -0. | -0.230 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 21 | 0. | -0. | 0. | 0. | 0. | 0. | -0.230 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 22 | -0. | 0. | 0. | 0. | 0. | 0. | -0.260 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| REDUCE | 22 | -0. | -0. | 0. | 0. | 0. | 0. | -0.260 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 23 | 0. | 0. | 0. | 0. | 0. | 0. | -0.321 | 3.026 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 7 | 0. | -0. | 0. | 0. | 0. | -0. | 0.000 | 0.350 | 0.0 | 0.0 | 0.0 | -0.0000 |
| | 800 | -0. | 0. | 0. | 0. | 0. | 0. | 0.050 | 0.350 | 0.0 | 0.0 | 0.0 | -0.0000 |
| RUN | 800 | -0. | -0. | 0. | 0. | 0. | 0. | 0.050 | 0.350 | 0.0 | 0.0 | 0.0 | -0.0000 |
| | 8 | 0. | 0. | 0. | 0. | 0. | -0. | 0.094 | 0.350 | 0.0 | 0.0 | 0.0 | -0.0000 |
| RUN | 16 | -0. | -0. | 0. | 0. | 0. | 0. | -0.000 | 2.771 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 1700 | 0. | 0. | 0. | 0. | 0. | -0. | 0.050 | 2.771 | 0.0 | 0.0 | 0.0 | 0.0000 |
| RUN | 1700 | -0. | -0. | 0. | 0. | 0. | -0. | 0.050 | 2.771 | 0.0 | 0.0 | 0.0 | 0.0000 |
| | 17 | 0. | 0. | 0. | 0. | 0. | -0. | 0.128 | 2.771 | 0.0 | 0.0 | 0.0 | 0.0000 |

079T1000008
98

| ***** | | | |
|---|--|---------|-------------|
| * JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL * | | | |
| ***** | | | |
| | // \$WW232B1 JOB 'GURSAHANI LB30731160*0716935 | 4444449 | , *00000100 |
| | // TIME=(02.00), REGION=1500K, NOTIFY=\$WW232, MSGCLASS=A, MSGLEVEL=1 | | 00000200 |
| | // *MAIN ORG=RMO05 | | 00000300 |
| | /* THIS IS DATASET \$WW232.PRINT.EDIT.CNTL | | 00000400 |
| | /* THESE THREE ARE FOR XEROX OUTPUT | | 00000500 |
| | /* *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO06PR3, FCB=JB10, COPIES=1 | | 00000600 |
| | /* *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO06PR3, FCB=JB10, COPIES=1 | | 00000700 |
| | /* *FORMAT PR, DDNAME=SYSUT2, DEST=RMO06PR3, FCB=JB10, COPIES=1 | | 00000800 |
| | /* THESE THREE ARE FOR NORMAL OUTPUT | | 00000900 |
| | /* /* *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO05, COPIES=1 | | 00001000 |
| | /* /* *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO05, COPIES=1 | | 00001100 |
| | /* /* *FORMAT PR, DDNAME=SYSUT2, DEST=RMO05, COPIES=1 | | 00001200 |
| | /* THESE THREE ARE FOR MICROFICHE OUTPUT | | 00001300 |
| | /* /* *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001400 |
| | /* /* *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001500 |
| | /* /* *FORMAT PR, DDNAME=SYSUT2, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001600 |
| | // EXEC PGM=IEBGENER | | 00001700 |
| | // SYSPRINT DD SYSOUT=A | | 00001800 |
| | // SYSIN DD DUMMY | | 00001900 |
| | // SYSUT1 DD DSN=\$WW232.AAS1.CLASS.T.DATA, DISP=SHR | | 00002000 |
| | // SYSUT2 DD SYSOUT=A, DCB=(RECFM=FBA, LRECL=133, BLKSIZE=1330) | | 00002100 |
| 1 | // \$WW232B1 JOB 'GURSAHANI LB30731160*0716935 | 4444449 | , *00000100 |
| | // TIME=(02.00), REGION=1500K, NOTIFY=\$WW232, MSGCLASS=A, MSGLEVEL=1 | | 00000200 |
| | *** THIS IS DATASET \$WW232.PRINT.EDIT.CNTL | | 00000400 |
| | *** THESE THREE ARE FOR XEROX OUTPUT | | 00000500 |
| | *** THESE THREE ARE FOR NORMAL OUTPUT | | 00000900 |
| | *** /* *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO05, COPIES=1 | | 00001000 |
| | *** /* *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO05, COPIES=1 | | 00001100 |
| | *** /* *FORMAT PR, DDNAME=SYSUT2, DEST=RMO05, COPIES=1 | | 00001200 |
| | *** THESE THREE ARE FOR MICROFICHE OUTPUT | | 00001300 |
| | *** /* *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001400 |
| | *** /* *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001500 |
| | *** /* *FORMAT PR, DDNAME=SYSUT2, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001600 |
| 2 | // EXEC PGM=IEBGENER | | 00001700 |
| 3 | // SYSPRINT DD SYSOUT=A | | 00001800 |
| 4 | // SYSIN DD DUMMY | | 00001900 |
| 5 | // SYSUT1 DD DSN=\$WW232.AAS1.CLASS.T.DATA, DISP=SHR | | 00002000 |
| 6 | // SYSUT2 DD SYSOUT=A, DCB=(RECFM=FBA, LRECL=133, BLKSIZE=1330) | | 00002100 |

* JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG *

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000
11:05:15 IAT4401 LOCATE FOR STEP= DD=SYSUT1 DSN=\$WW232.N1.DATA
11:05:15 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
11:05:15 IAT4401 LOCATE FOR STEP= DD=SYSUT1 DSN=\$WW232.N2.DATA
11:05:15 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
11:05:15 USES AVTSOA D \$WW232.N1.DATA
11:05:16 IAT5200 JOB 1343 (\$WW232P2) IN SETUP ON MAIN=L P=09 LOCAL
11:05:16 IAT5210 J=1343 SYSUT1 USING D AVTSOA ON 520 \$WW232.N1.DATA
11:05:56 IAT2000 JOB 1343 \$WW232P2 SELECTED I GRP=JS3BATCH
11:05:57 I R= \$WW232P2 NEF995I \$WW232P2 STARTED, 4/05/83,11.03.29 ASID=00038
11:05:57 I R= \$WW232P2 IEF403I \$WW232P2 - STARTED - TIME=11.03.29
11:06:04 I R= \$WW232P2 IEF404I \$WW232P2 - ENDED - TIME=11.03.36
11:06:04 I R= \$WW232P2 NEF996I \$WW232P2 ENDED, 4/05/83,B.U.= .0498 *0716935 ,3081-13,JOB CC= 000
11:06:05 IAT5400 JOB 1343 (\$WW232P2) IN BREAKDOWN

079T1000008
100

 * JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL *

```

//$WW232P2 JOB 'GURSAHANI LB30731160*0716935          4444449      ', *00000100
// TIME=(02.00),REGION=1500K,NOTIFY=$WW232.MSGCLASS=A,MSGLEVEL=1      00000200
// *MAIN ORG=RMO05                                                    00000300
// * THIS IS DATASET $WW232.PRINT.EDIT.CNTL                            00000400
// * THESE THREE ARE FOR XEROX OUTPUT                                  00000500
// *FORMAT PR,DDNAME=SYSMMSG,DEST=RM271PR3,FCB=JB10,COPIES=1          00000600
// *FORMAT PR,DDNAME=SYSPRINT,DEST=RM271PR3,FCB=JB10,COPIES=1        00000700
// *FORMAT PR,DDNAME=SYSUT2,DEST=RM271PR3,FCB=JB10,COPIES=1          00000800
// * THESE THREE ARE FOR NORMAL OUTPUT                                00000900
// * // *FORMAT PR,DDNAME=SYSMMSG,DEST=RMO05,COPIES=1                  00001000
// * // *FORMAT PR,DDNAME=SYSPRINT,DEST=RMO05,COPIES=1                  00001100
// * // *FORMAT PR,DDNAME=SYSUT2,DEST=RMO05,COPIES=1                  00001200
// * THESE THREE ARE FOR MICROFICHE OUTPUT                            00001300
// * // *FORMAT PR,DDNAME=SYSMMSG,DEST=RMO01PR5,FORMS=FICHE,COPIES=1  00001400
// * // *FORMAT PR,DDNAME=SYSPRINT,DEST=RMO01PR5,FORMS=FICHE,COPIES=1 00001500
// * // *FORMAT PR,DDNAME=SYSUT2,DEST=RMO01PR5,FORMS=FICHE,COPIES=1  00001600
// EXEC PGM=IEBGENER                                                  00001700
// SYSPRINT DD SYSOUT=A                                              00001800
// SYSIN DD DUMMY                                                    00001900
// SYSUT1 DD DSN=$WW232.N1.DATA,DISP=SHR                             00002000
// DD DSN=$WW232.N2.DATA,DISP=SHR                                    00002100
// SYSUT2 DD SYSOUT=A,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=1330)         00002300
1 // $WW232P2 JOB 'GURSAHANI LB30731160*0716935          4444449      ', *00000100
// TIME=(02.00),REGION=1500K,NOTIFY=$WW232.MSGCLASS=A,MSGLEVEL=1      00000200
*** THIS IS DATASET $WW232.PRINT.EDIT.CNTL                            00000400
*** THESE THREE ARE FOR XEROX OUTPUT                                  00000500
*** THESE THREE ARE FOR NORMAL OUTPUT                                00000900
*** // *FORMAT PR,DDNAME=SYSMMSG,DEST=RMO05,COPIES=1                  00001000
*** // *FORMAT PR,DDNAME=SYSPRINT,DEST=RMO05,COPIES=1                  00001100
*** // *FORMAT PR,DDNAME=SYSUT2,DEST=RMO05,COPIES=1                  00001200
*** THESE THREE ARE FOR MICROFICHE OUTPUT                            00001300
*** // *FORMAT PR,DDNAME=SYSMMSG,DEST=RMO01PR5,FORMS=FICHE,COPIES=1  00001400
*** // *FORMAT PR,DDNAME=SYSPRINT,DEST=RMO01PR5,FORMS=FICHE,COPIES=1 00001500
*** // *FORMAT PR,DDNAME=SYSUT2,DEST=RMO01PR5,FORMS=FICHE,COPIES=1  00001600
2 // EXEC PGM=IEBGENER                                                  00001700
3 // SYSPRINT DD SYSOUT=A                                              00001800
4 // SYSIN DD DUMMY                                                    00001900
5 // SYSUT1 DD DSN=$WW232.N1.DATA,DISP=SHR                             00002000
6 // DD DSN=$WW232.N2.DATA,DISP=SHR                                    00002100
7 // SYSUT2 DD SYSOUT=A,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=1330)         00002300

```

079T1000008
101

* SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG SYMSG *

IEF236I ALLOC. FOR \$WW232P2
IEF237I JES3 ALLOCATED TO SYSPRINT
IEF237I DMY ALLOCATED TO SYSIN
IEF237I 520 ALLOCATED TO SYSUT1
IEF237I 520 ALLOCATED TO
IEF237I 520 ALLOCATED TO SYS00141
IEF237I JES3 ALLOCATED TO SYSUT2

IEF142I \$WW232P2 - STEP WAS EXECUTED - COND CODE 0000
IEF285I SYSPRINT SYSOUT
IEF285I \$WW232.N1.DATA KEPT
IEF285I VOL SER NOS= AVTSOA.
IEF285I \$WW232.N2.DATA KEPT
IEF285I VOL SER NOS= AVTSOA.
IEF285I SYSCTLG.VAVTSOA KEPT
IEF285I VOL SER NOS= AVTSOA.

IEF285I SYSUT2 SYSOUT
IEF373I STEP / / START 83095.1103
IEF374I STEP / / STOP 83095.1103 CPU OMIN 00.13SEC SRB OMIN 00.01SEC VIRT 80K SYS 172K

NEF980I *****
NEF981I * STEP= ,CPU= .0022MIN,I/O BU= .0044,BILLING UNITS= .0498, CC=0000 *
NEF982I *
NEF983I * I/O COUNTS 520= 6, 520= 4, 520= 0, *
NEF980I *****

IEF375I JOB /\$WW232P2/ START 83095.1103
IEF376I JOB /\$WW232P2/ STOP 83095.1103 CPU OMIN 00.13SEC SRB OMIN 00.01SEC
NEF980I *****
NEF991I * \$WW232P2 ENDED,CPU= .0022MIN,I/O BU= .0044,BILLING UNITS= .0498,SERV LEVEL=3.00 *
NEF992I * TOD= 11.03.36,DATE= 4/05/83,MACHINE=3081-13,V52 RELEASE=03.8,SYSRES=A2MVSI *
NEF980I *****

079T100008
102

```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000
09:22:41 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
09:22:41 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:22:41 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
09:22:41 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:22:41 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=$WW232.CARRIZO.TURBIN.STEAM.DATA
09:22:41 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
09:22:41 IAT4401 LOCATE FOR STEP=G DD=FT69FOO1 DSN=$WWO49.ROCKPIPE.USERS
09:22:41 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:22:41 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
09:22:41 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:22:42 USES CVTSOK 01 017402 D $WWO49.NUPIPE.LOAD
09:22:42 USES AVTSOA 01 017402 D $WW232.CARRIZO.TURBIN.STEAM.DATA
09:22:42 IAT5200 JOB 3422 ($WW232T2) IN SETUP ON MAIN=C P=03 LOCAL
09:22:42 IAT5210 J=3422 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
09:22:42 IAT5210 J=3422 FT15FOO1 USING D AVTSOA ON 520 $WW232.CARRIZO.TURBIN.STEAM.DATA
09:22:48 IAT2000 JOB 3422 $WW232T2 SELECTED C GRP=BIG
09:22:49 C R= $WW232T2 NEF995I $WW232T2 STARTED, 3/09/83,09.22.46 ASID=00077
09:22:49 C R= $WW232T2 IEF403I $WW232T2 - STARTED - TIME=09.22.46
09:25:57 C R= $WW232T2 +IH0002I STOP 1
09:25:57 C R= $WW232T2 IEF404I $WW232T2 - ENDED - TIME=09.25.54
09:25:57 C R= $WW232T2 NEF996I $WW232T2 ENDED, 3/09/83,B.U.= 4.9709 *0716935 ,3081-C3,JOB CC= 001
09:25:58 IAT5400 JOB 3422 ($WW232T2) IN BREAKDOWN
/$WW232T2 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RMO05 00000300
/ EXEC ROCKPIPE,PROG=SMALL
/G.SYSIN DD DSN=$WW232.CARRIZO.TURBIN.STEAM.DATA,DISP=SHR
1 // $WW232T2 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
// REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
2 // EXEC ROCKPIPE,PROG=SMALL

```

079T1000008
103

ORIGINAL INPUT BY GURSAHANI ON 03/09/83 AT 09:23:03 WITH PRIORITY 3
 CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE PLUS NA INLET AND OUTLET

| | | | | | | | | | | |
|---|----|-------|-------|--------|------|-------|--|--|--|----|
| CONTROL | | 2.0 | 1.0 | | | | | | | 1 |
| FLEXAN | 1 | 1 | 2.0 | | | | | | | 2 |
| TE1 (THERMAL AT THE DESIGN TEMPERATURE NORMAL) | | | | | | | | | | 3 |
| FLEXAN | -2 | 2 | 2.0 | | | | | | | 4 |
| TE1 (THERMAL AT THE DESIGN TEMPERATURE SG 1 DOWN) | | | | | | | | | | 5 |
| FLEXAN | -3 | 3 | 2.0 | | | | | | | 6 |
| TE1 (THERMAL AT THE DESIGN TEMPERATURE SG 2 DOWN) | | | | | | | | | | 7 |
| FLEXAN | -4 | 4 | 2.0 | | | | | | | 8 |
| TE1 (THERMAL AT THE DESIGN TEMPERATURE SG 3 DOWN) | | | | | | | | | | 9 |
| FLEXAN | -5 | 5 | 2.0 | | | | | | | 10 |
| TE2 (THERMAL OVERNIGHT SHUTDOWN ,NORMAL) | | | | | | | | | | 11 |
| FLEXAN | -6 | 6 | 2.0 | | | | | | | 12 |
| TE2 (THERMAL OVERNIGHT SHUTDOWN ,SG 1 DOWN) | | | | | | | | | | 13 |
| FLEXAN | -7 | 7 | 2.0 | | | | | | | 14 |
| TE2 (THERMAL OVERNIGHT SHUTDOWN ,SG 2 DOWN) | | | | | | | | | | 15 |
| FLEXAN | -8 | 8 | 2.0 | | | | | | | 16 |
| TE2 (THERMAL OVERNIGHT SHUTDOWN ,SG 3 DOWN) | | | | | | | | | | 17 |
| FLEXAN | -9 | 9 | 2.0 | | | | | | | 18 |
| TE3 (SG AND NA INLET AT 600, NA OUTLET AT 300 AND STEAM PIPING AT 70) | | | | | | | | | | 19 |
| FLEXAN | 10 | 1 | 17.0 | | | | | | | 20 |
| DEADWEIGHT | | | | | | | | | | 21 |
| XSECTN | 1 | 54.22 | 0.721 | 812.0 | 29.9 | | | | | 22 |
| XSECTN | 2 | 30.94 | 0.721 | 705.1 | 29.9 | | | | | 23 |
| XSECTN | 3 | 21.5 | 1.0 | 580.1 | 29.9 | 0.0 | | | | 24 |
| XSECTN | 4 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 | | | | 25 |
| XSECTN | 5 | 12.81 | 1.0 | 370.3 | 29.9 | 0.0 | | | | 26 |
| XSECTN | 6 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 | | | | 27 |
| XSECTN | 7 | 12.75 | .562 | 51.7 | 29.9 | 0.0 | | | | 28 |
| XSECTN | 8 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 | | | | 29 |
| XSECTN | 9 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 | | | | 30 |
| XSECTN | 10 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | | 31 |
| XSECTN | 11 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | | 32 |
| XSECTN | 12 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | | 33 |
| XSECTN | 13 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | | 34 |
| XSECTN | 14 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 | | | | 35 |
| XSECTN | 15 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 | | | | 36 |
| XSECTN | 16 | 12.75 | .562 | 92.1 | 29.9 | 0.0 | | | | 37 |
| XSECTN | 17 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 | | | | 38 |
| XSECTN | 18 | 24.0 | 1.0 | 524.4 | 29.9 | 0.0 | | | | 39 |
| XSECTN | 19 | 26.0 | 1.97 | 927.5 | 29.9 | 0.0 | | | | 40 |
| XSECTN | 20 | 21.5 | 1.0 | 596.4 | 29.9 | 0.0 | | | | 41 |
| XSECTN | 21 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 | | | | 42 |
| XSECTN | 22 | 12.81 | 1.0 | 376.9 | 29.9 | 0.0 | | | | 43 |
| XSECTN800 | 23 | 12.75 | 0.562 | 51.7 | 299. | 0.0 | | | | 44 |
| XSECT1700 | 24 | 12.75 | 0.562 | 89.8 | 299. | 0.0 | | | | 45 |
| XSECTN | 25 | 6.625 | 0.864 | 85.5 | 29.9 | 1590. | | | | 46 |
| XSECTN NA | 26 | 6.625 | 0.864 | | 29.9 | 1590. | | | | 47 |
| XSECTN NA | 27 | 12.75 | 0.406 | 175. | 28.3 | 65. | | | | 48 |
| XSECTN | 28 | 6.625 | 0.280 | 98.5 | 28.3 | 65. | | | | 49 |
| XSECTN NA | 29 | 12.75 | 0.406 | 130. | 27.9 | 65. | | | | 50 |
| XSECTN | 30 | 6.625 | 0.280 | 53.4 | 27.9 | 65. | | | | 51 |
| XSECTN | 31 | 12.75 | 0.687 | 218.8 | 28.3 | 65. | | | | 52 |
| XSECTN NA | 32 | 6.625 | 0.280 | | 27.9 | 65. | | | | 53 |
| XSECTN | 33 | 12.75 | 0.687 | 218.8 | 27.9 | 65. | | | | 54 |
| XSECTN | 34 | 10.75 | 0.365 | 154.6 | 28.3 | 65. | | | | 55 |
| XSEC | 35 | 10.75 | 1.40 | 199.1 | 28.3 | | | | | 56 |
| OPVA | 1 | 1 | 29.4 | .01198 | | | | | | 57 |
| OPVA | 1 | 2 | 28.4 | .03022 | | | | | | 58 |

| | | | | | | |
|-----------|---|----|-------|--------|-------|-----|
| OPVAL470 | 1 | 3 | 28.2 | .03344 | | 60 |
| OPVAL450 | 1 | 4 | 28.3 | .03160 | | 61 |
| OPVAL450 | 1 | 5 | 28.3 | .03160 | | 62 |
| OPVAL587 | 1 | 6 | 27.5 | .04473 | | 63 |
| OPVAL620 | 1 | 7 | 27.2 | .04086 | | 64 |
| OPVAL625 | 1 | 8 | 27.2 | .04858 | | 65 |
| OPVAL640 | 1 | 9 | 27.1 | .05012 | | 66 |
| OPVAL705 | 1 | 10 | 26.6 | .05684 | | 67 |
| OPVAL865 | 1 | 11 | 24.9 | .07422 | | 68 |
| OPVAL1010 | 1 | 12 | 22.7 | .09005 | | 69 |
| OPVAL1050 | 1 | 13 | 21.7 | .09465 | | 70 |
| OPVAL1055 | 1 | 14 | 21.6 | .09523 | | 71 |
| OPVAL1057 | 1 | 15 | 21.5 | .09546 | | 72 |
| OPVAL1065 | 1 | 16 | 21.3 | .09638 | | 73 |
| OPVAL1055 | 1 | 17 | 21.6 | .09523 | | 74 |
| OPVAL1025 | 1 | 18 | 22.4 | .09178 | | 75 |
| OPVAL1020 | 1 | 19 | 22.5 | .09120 | | 76 |
| OPVAL1020 | 1 | 20 | 22.5 | .09120 | | 77 |
| OPVAL1015 | 1 | 21 | 22.6 | .09063 | | 78 |
| OPVAL1015 | 1 | 22 | 22.6 | .09063 | | 79 |
| OPVAL800 | 1 | 23 | 273.0 | .04703 | | 80 |
| OPVAL1065 | 1 | 24 | 213.0 | .09638 | | 81 |
| OPVAL1015 | 1 | 25 | 22.60 | .09063 | 1590. | 82 |
| OPVAL NA | 1 | 26 | 22.74 | .09005 | 1590. | 83 |
| OPVAL NA | 1 | 27 | 22.4 | .12364 | 65. | 84 |
| OPVAL1065 | 1 | 28 | 22.4 | .12364 | 65. | 85 |
| OPVAL NA | 1 | 29 | 25.61 | .04703 | 65. | 86 |
| OPVAL 610 | 1 | 30 | 25.61 | .04703 | 65. | 87 |
| OPVAL1015 | 1 | 31 | 22.60 | .09063 | 1590. | 88 |
| OPVAL1015 | 1 | 32 | 22.60 | .09063 | 1590. | 89 |
| OPVAL1015 | 1 | 33 | 22.60 | .09063 | 1590. | 90 |
| OPVAL225 | 2 | 1 | 29.4 | .01198 | | 91 |
| OPVAL435 | 2 | 2 | 28.4 | .03022 | | 92 |
| OPVAL470 | 2 | 3 | 28.2 | .03344 | | 93 |
| OPVAL450 | 2 | 4 | 28.3 | .03160 | | 94 |
| OPVAL450 | 2 | 5 | 28.3 | .03160 | | 95 |
| OPVAL587 | 2 | 6 | 27.5 | .04473 | | 96 |
| OPVAL620 | 2 | 7 | 27.2 | .04086 | | 97 |
| OPVAL625 | 2 | 8 | 27.2 | .04858 | | 98 |
| OPVAL640 | 2 | 9 | 27.1 | .05012 | | 99 |
| OPVAL705 | 2 | 10 | 26.6 | .05684 | | 100 |
| OPVAL865 | 2 | 11 | 24.9 | .07422 | | 101 |
| OPVAL1010 | 2 | 12 | 22.7 | .09005 | | 102 |
| OPVAL1050 | 2 | 13 | 21.7 | .09465 | | 103 |
| OPVAL1055 | 2 | 14 | 21.6 | .09523 | | 104 |
| OPVAL1057 | 2 | 15 | 21.5 | .09546 | | 105 |
| OPVAL1065 | 2 | 16 | 21.3 | .09638 | | 106 |
| OPVAL1055 | 2 | 17 | 21.6 | .09523 | | 107 |
| OPVAL1025 | 2 | 18 | 22.4 | .09178 | | 108 |
| OPVAL1020 | 2 | 19 | 22.5 | .09120 | | 109 |
| OPVAL1020 | 2 | 20 | 22.5 | .09120 | | 110 |
| OPVAL1015 | 2 | 21 | 22.6 | .09063 | | 111 |
| OPVAL1015 | 2 | 22 | 22.6 | .09063 | | 112 |
| OPVAL800 | 2 | 23 | 273.0 | .04703 | | 113 |
| OPVAL1065 | 2 | 24 | 213.0 | .09638 | | 114 |
| OPVAL1015 | 2 | 25 | 22.60 | .09063 | 1590. | 115 |
| OPVAL NA | 2 | 26 | 22.74 | .09005 | 1590. | 116 |
| OPVAL NA | 2 | 27 | 22.4 | .12364 | 65. | 117 |
| OPVAL1065 | 2 | 28 | 22.4 | .12364 | 65. | 118 |
| OPVAL NA | 2 | 29 | 25.61 | .04703 | 65. | 119 |
| OPVAL 610 | 2 | 30 | 25.61 | .04703 | 65. | 120 |
| OPVAL1015 | 2 | 31 | 22.60 | .09063 | 1590. | 121 |

| | | | | | | |
|------------|---|----|-------|--------|-------|-----|
| OPVAL 1015 | 2 | 32 | 22.60 | .09063 | 1590. | 122 |
| OPVAL 600 | 2 | 33 | 27.4 | .04600 | | 123 |
| OPVAL225 | 3 | 1 | 29.4 | .01198 | | 124 |
| OPVAL435 | 3 | 2 | 28.4 | .03022 | | 125 |
| OPVAL470 | 3 | 3 | 28.2 | .03344 | | 126 |
| OPVAL450 | 3 | 4 | 28.3 | .03160 | | 127 |
| OPVAL450 | 3 | 5 | 28.3 | .03160 | | 128 |
| OPVAL587 | 3 | 6 | 27.5 | .04473 | | 129 |
| OPVAL620 | 3 | 7 | 27.2 | .04086 | | 130 |
| OPVAL625 | 3 | 8 | 27.2 | .04858 | | 131 |
| OPVAL640 | 3 | 9 | 27.1 | .05012 | | 132 |
| OPVAL705 | 3 | 10 | 26.6 | .05684 | | 133 |
| OPVAL865 | 3 | 11 | 24.9 | .07422 | | 134 |
| OPVAL 1010 | 3 | 12 | 22.7 | .09005 | | 135 |
| OPVAL 1050 | 3 | 13 | 21.7 | .09465 | | 136 |
| OPVAL 1055 | 3 | 14 | 21.6 | .09523 | | 137 |
| OPVAL 1057 | 3 | 15 | 21.5 | .09546 | | 138 |
| OPVAL 1065 | 3 | 16 | 21.3 | .09638 | | 139 |
| OPVAL 1055 | 3 | 17 | 21.6 | .09523 | | 140 |
| OPVAL 1025 | 3 | 18 | 22.4 | .09178 | | 141 |
| OPVAL 1020 | 3 | 19 | 22.5 | .09120 | | 142 |
| OPVAL 1020 | 3 | 20 | 22.5 | .09120 | | 143 |
| OPVAL 1015 | 3 | 21 | 22.6 | .09063 | | 144 |
| OPVAL 1015 | 3 | 22 | 22.6 | .09063 | | 145 |
| OPVAL800 | 3 | 23 | 273.0 | .04703 | | 146 |
| OPVAL 1065 | 3 | 24 | 213.0 | .09638 | | 147 |
| OPVAL 1015 | 3 | 25 | 22.60 | .09063 | 1590. | 148 |
| OPVAL NA | 3 | 26 | 22.74 | .09005 | 1590. | 149 |
| OPVAL NA | 3 | 27 | 22.4 | .12364 | 65. | 150 |
| OPVAL 1065 | 3 | 28 | 22.4 | .12364 | 65. | 151 |
| OPVAL NA | 3 | 29 | 25.61 | .04703 | 65. | 152 |
| OPVAL 610 | 3 | 30 | 25.61 | .04703 | 65. | 153 |
| OPVAL 1015 | 3 | 31 | 22.60 | .09063 | 1590. | 154 |
| OPVAL 600 | 3 | 32 | 27.4 | .0460 | | 155 |
| OPVAL 1015 | 3 | 33 | 22.60 | .09063 | 1590. | 156 |
| OPVAL225 | 4 | 1 | 29.4 | .01198 | | 157 |
| OPVAL435 | 4 | 2 | 28.4 | .03022 | | 158 |
| OPVAL470 | 4 | 3 | 28.2 | .03344 | | 159 |
| OPVAL450 | 4 | 4 | 28.3 | .03160 | | 160 |
| OPVAL450 | 4 | 5 | 28.3 | .03160 | | 161 |
| OPVAL587 | 4 | 6 | 27.5 | .04473 | | 162 |
| OPVAL620 | 4 | 7 | 27.2 | .04086 | | 163 |
| OPVAL625 | 4 | 8 | 27.2 | .04858 | | 164 |
| OPVAL640 | 4 | 9 | 27.1 | .05012 | | 165 |
| OPVAL705 | 4 | 10 | 26.6 | .05684 | | 166 |
| OPVAL865 | 4 | 11 | 24.9 | .07422 | | 167 |
| OPVAL 1010 | 4 | 12 | 22.7 | .09005 | | 168 |
| OPVAL 1050 | 4 | 13 | 21.7 | .09465 | | 169 |
| OPVAL 1055 | 4 | 14 | 21.6 | .09523 | | 170 |
| OPVAL 1057 | 4 | 15 | 21.5 | .09546 | | 171 |
| OPVAL 1065 | 4 | 16 | 21.3 | .09638 | | 172 |
| OPVAL 1055 | 4 | 17 | 21.6 | .09523 | | 173 |
| OPVAL 1025 | 4 | 18 | 22.4 | .09178 | | 174 |
| OPVAL 1020 | 4 | 19 | 22.5 | .09120 | | 175 |
| OPVAL 1020 | 4 | 20 | 22.5 | .09120 | | 176 |
| OPVAL 1015 | 4 | 21 | 22.6 | .09063 | | 177 |
| OPVAL 1015 | 4 | 22 | 22.6 | .09063 | | 178 |
| OPVAL800 | 4 | 23 | 273.0 | .04703 | | 179 |
| OPVAL 1065 | 4 | 24 | 213.0 | .09638 | | 180 |
| OPVAL 1015 | 4 | 25 | 22.60 | .09063 | 1590. | 181 |
| OPVAL I | 4 | 26 | 22.74 | .09005 | 15 | 182 |
| OPVAL I | 4 | 27 | 22.4 | .12364 | | 183 |

| | | | | | | |
|-----------|---|----|-------|--------|-------|-----|
| OPVAL1065 | 4 | 28 | 22.4 | .12364 | 65. | 184 |
| OPVAL NA | 4 | 29 | 25.61 | .04703 | 65. | 185 |
| OPVAL 610 | 4 | 30 | 25.61 | .04703 | 65. | 186 |
| OPVAL 600 | 4 | 31 | 27.4 | .0460 | | 187 |
| OPVAL1015 | 4 | 32 | 22.60 | .09063 | 1590. | 188 |
| OPVAL1015 | 4 | 33 | 22.60 | .09063 | 1590. | 189 |
| OPVAL201 | 5 | 1 | 29.5 | .00998 | | 190 |
| OPVAL381 | 5 | 2 | 29.1 | .02533 | | 191 |
| OPVAL420 | 5 | 3 | 28.5 | .02884 | | 192 |
| OPVAL400 | 5 | 4 | 28.5 | .02700 | | 193 |
| OPVAL400 | 5 | 5 | 28.5 | .02700 | | 194 |
| OPVAL550 | 5 | 6 | 27.7 | .04110 | | 195 |
| OPVAL570 | 5 | 7 | 27.6 | .04306 | | 196 |
| OPVAL575 | 5 | 8 | 27.6 | .04355 | | 197 |
| OPVAL585 | 5 | 9 | 27.5 | .04453 | | 198 |
| OPVAL650 | 5 | 10 | 27.0 | .05115 | | 199 |
| OPVAL770 | 5 | 11 | 26.0 | .06379 | | 200 |
| OPVAL890 | 5 | 12 | 24.6 | .07699 | | 201 |
| OPVAL940 | 5 | 13 | 23.9 | .08242 | | 202 |
| OPVAL942 | 5 | 14 | 23.9 | .08264 | | 203 |
| OPVAL948 | 5 | 15 | 23.8 | .08328 | | 204 |
| OPVAL950 | 5 | 16 | 23.8 | .08350 | | 205 |
| OPVAL950 | 5 | 17 | 23.8 | .08350 | | 206 |
| OPVAL910 | 5 | 18 | 24.4 | .07918 | | 207 |
| OPVAL905 | 5 | 19 | 24.4 | .07864 | | 208 |
| OPVAL902 | 5 | 20 | 24.5 | .07832 | | 209 |
| OPVAL900 | 5 | 21 | 24.5 | .07810 | | 210 |
| OPVAL900 | 5 | 22 | 24.5 | .07810 | | 211 |
| OPVAL570 | 5 | 23 | 276.0 | .04306 | | 212 |
| OPVAL950 | 5 | 24 | 237.5 | .08350 | | 213 |
| OPVAL850 | 5 | 25 | 25.1 | .07255 | 1590. | 214 |
| OPVAL NA | 5 | 26 | 22.74 | .09005 | 1590. | 215 |
| OPVAL NA | 5 | 27 | 23.2 | .10800 | 65. | 216 |
| OPVAL950 | 5 | 28 | 23.2 | .10800 | 65. | 217 |
| OPVAL NA | 5 | 29 | 27.4 | .0182 | 65. | 218 |
| OPVAL 300 | 5 | 30 | 27.4 | .0182 | 65. | 219 |
| OPVAL850 | 5 | 31 | 25.1 | .07255 | 1590. | 220 |
| OPVAL850 | 5 | 32 | 25.1 | .07255 | 1590. | 221 |
| OPVAL850 | 5 | 33 | 25.1 | .07255 | 1590. | 222 |
| OPVAL201 | 6 | 1 | 29.5 | .00998 | | 223 |
| OPVAL381 | 6 | 2 | 29.1 | .02533 | | 224 |
| OPVAL420 | 6 | 3 | 28.5 | .02884 | | 225 |
| OPVAL400 | 6 | 4 | 28.5 | .02700 | | 226 |
| OPVAL400 | 6 | 5 | 28.5 | .02700 | | 227 |
| OPVAL550 | 6 | 6 | 27.7 | .04110 | | 228 |
| OPVAL570 | 6 | 7 | 27.6 | .04306 | | 229 |
| OPVAL575 | 6 | 8 | 27.6 | .04355 | | 230 |
| OPVAL585 | 6 | 9 | 27.5 | .04453 | | 231 |
| OPVAL650 | 6 | 10 | 27.0 | .05115 | | 232 |
| OPVAL770 | 6 | 11 | 26.0 | .06379 | | 233 |
| OPVAL890 | 6 | 12 | 24.6 | .07699 | | 234 |
| OPVAL940 | 6 | 13 | 23.9 | .08242 | | 235 |
| OPVAL942 | 6 | 14 | 23.9 | .08264 | | 236 |
| OPVAL948 | 6 | 15 | 23.8 | .08328 | | 237 |
| OPVAL950 | 6 | 16 | 23.8 | .08350 | | 238 |
| OPVAL950 | 6 | 17 | 23.8 | .08350 | | 239 |
| OPVAL910 | 6 | 18 | 24.4 | .07918 | | 240 |
| OPVAL905 | 6 | 19 | 24.4 | .07864 | | 241 |
| OPVAL902 | 6 | 20 | 24.5 | .07832 | | 242 |
| OPVAL900 | 6 | 21 | 24.5 | .07810 | | 243 |
| OPVAL900 | 6 | 22 | 24.5 | .07810 | | 244 |
| OPVAL570 | 6 | 23 | 276.0 | .04306 | | 245 |

| | | | | | | |
|-----------|---|----|-------|--------|-------|-----|
| OPVAL950 | 6 | 24 | 237.5 | .08350 | | 246 |
| OPVAL850 | 6 | 25 | 25.1 | .07255 | 1590. | 247 |
| OPVAL NA | 6 | 26 | 22.74 | .09005 | 1590. | 248 |
| OPVAL NA | 6 | 27 | 23.2 | .10800 | 65. | 249 |
| OPVAL950 | 6 | 28 | 23.2 | .10800 | 65. | 250 |
| OPVAL NA | 6 | 29 | 27.4 | .0182 | 65. | 251 |
| OPVAL 300 | 6 | 30 | 27.4 | .0182 | 65. | 252 |
| OPVAL850 | 6 | 31 | 25.1 | .07255 | 1590. | 253 |
| OPVAL850 | 6 | 32 | 25.1 | .07255 | 1590. | 254 |
| OPVAL600 | 6 | 33 | 27.4 | .04600 | | 255 |
| OPVAL201 | 7 | 1 | 29.5 | .00998 | | 256 |
| OPVAL381 | 7 | 2 | 29.1 | .02533 | | 257 |
| OPVAL420 | 7 | 3 | 28.5 | .02884 | | 258 |
| OPVAL400 | 7 | 4 | 28.5 | .02700 | | 259 |
| OPVAL400 | 7 | 5 | 28.5 | .02700 | | 260 |
| OPVAL550 | 7 | 6 | 27.7 | .04110 | | 261 |
| OPVAL570 | 7 | 7 | 27.6 | .04306 | | 262 |
| OPVAL575 | 7 | 8 | 27.6 | .04355 | | 263 |
| OPVAL585 | 7 | 9 | 27.5 | .04453 | | 264 |
| OPVAL650 | 7 | 10 | 27.0 | .05115 | | 265 |
| OPVAL770 | 7 | 11 | 26.0 | .06379 | | 266 |
| OPVAL890 | 7 | 12 | 24.6 | .07699 | | 267 |
| OPVAL940 | 7 | 13 | 23.9 | .08242 | | 268 |
| OPVAL942 | 7 | 14 | 23.9 | .08264 | | 269 |
| OPVAL948 | 7 | 15 | 23.8 | .08328 | | 270 |
| OPVAL950 | 7 | 16 | 23.8 | .08350 | | 271 |
| OPVAL950 | 7 | 17 | 23.8 | .08350 | | 272 |
| OPVAL910 | 7 | 18 | 24.4 | .07918 | | 273 |
| OPVAL905 | 7 | 19 | 24.4 | .07864 | | 274 |
| OPVAL902 | 7 | 20 | 24.5 | .07832 | | 275 |
| OPVAL900 | 7 | 21 | 24.5 | .07810 | | 276 |
| OPVAL900 | 7 | 22 | 24.5 | .07810 | | 277 |
| OPVAL570 | 7 | 23 | 276.0 | .04306 | | 278 |
| OPVAL950 | 7 | 24 | 237.5 | .08350 | | 279 |
| OPVAL850 | 7 | 25 | 25.1 | .07255 | 1590. | 280 |
| OPVAL NA | 7 | 26 | 22.74 | .09005 | 1590. | 281 |
| OPVAL NA | 7 | 27 | 23.2 | .10800 | 65. | 282 |
| OPVAL950 | 7 | 28 | 23.2 | .10800 | 65. | 283 |
| OPVAL NA | 7 | 29 | 27.4 | .0182 | 65. | 284 |
| OPVAL 300 | 7 | 30 | 27.4 | .0182 | 65. | 285 |
| OPVAL850 | 7 | 31 | 25.1 | .07255 | 1590. | 286 |
| OPVAL600 | 7 | 32 | 27.4 | .04600 | | 287 |
| OPVAL850 | 7 | 33 | 25.1 | .07255 | 1590. | 288 |
| OPVAL201 | 8 | 1 | 29.5 | .00998 | | 289 |
| OPVAL381 | 8 | 2 | 29.1 | .02533 | | 290 |
| OPVAL420 | 8 | 3 | 28.5 | .02884 | | 291 |
| OPVAL400 | 8 | 4 | 28.5 | .02700 | | 292 |
| OPVAL400 | 8 | 5 | 28.5 | .02700 | | 293 |
| OPVAL550 | 8 | 6 | 27.7 | .04110 | | 294 |
| OPVAL570 | 8 | 7 | 27.6 | .04306 | | 295 |
| OPVAL575 | 8 | 8 | 27.6 | .04355 | | 296 |
| OPVAL585 | 8 | 9 | 27.5 | .04453 | | 297 |
| OPVAL650 | 8 | 10 | 27.0 | .05115 | | 298 |
| OPVAL770 | 8 | 11 | 26.0 | .06379 | | 299 |
| OPVAL890 | 8 | 12 | 24.6 | .07699 | | 300 |
| OPVAL940 | 8 | 13 | 23.9 | .08242 | | 301 |
| OPVAL942 | 8 | 14 | 23.9 | .08264 | | 302 |
| OPVAL948 | 8 | 15 | 23.8 | .08328 | | 303 |
| OPVAL950 | 8 | 16 | 23.8 | .08350 | | 304 |
| OPVAL950 | 8 | 17 | 23.8 | .08350 | | 305 |
| OPVAL910 | 8 | 18 | 24.4 | .07918 | | 306 |
| OPVAL905 | 8 | 19 | 24.4 | .07864 | | 307 |

| | | | | | | | | | |
|-----------|---|------------|--------|--------|-------|------|------|--|-----|
| OPVAL902 | 8 | 20 | 24.5 | .07832 | | | | | 308 |
| OPVAL900 | 8 | 21 | 24.5 | .07810 | | | | | 309 |
| OPVAL900 | 8 | 22 | 24.5 | .07810 | | | | | 310 |
| OPVAL570 | 8 | 23 | 276.0 | .04306 | | | | | 311 |
| OPVAL950 | 8 | 24 | 237.5 | .08350 | | | | | 312 |
| OPVAL850 | 8 | 25 | 25.1 | .07255 | 1590. | | | | 313 |
| OPVAL NA | 8 | 26 | 22.74 | .09005 | 1590. | | | | 314 |
| OPVAL NA | 8 | 27 | 23.2 | .10800 | 65. | | | | 315 |
| OPVAL950 | 8 | 28 | 23.2 | .10800 | 65. | | | | 316 |
| OPVAL NA | 8 | 29 | 27.4 | .0182 | 65. | | | | 317 |
| OPVAL 300 | 8 | 30 | 27.4 | .0182 | 65. | | | | 318 |
| OPVAL 600 | 8 | 31 | 27.4 | .0460 | | | | | 319 |
| OPVAL850 | 8 | 32 | 25.1 | .07255 | 1590. | | | | 320 |
| OPVAL850 | 8 | 33 | 25.1 | .07255 | 1590. | | | | 321 |
| OPVAL 226 | 9 | 1 | 29.4 | .01206 | 65. | | | | 322 |
| OPVAL 492 | 9 | 2 | 28.0 | .03546 | 65. | | | | 323 |
| OPVAL 600 | 9 | 3 | 27.4 | .0460 | 65. | | | | 324 |
| OPVAL 600 | 9 | 4 | 27.4 | .0460 | 65. | | | | 325 |
| OPVAL 600 | 9 | 5 | 27.4 | .0460 | 65. | | | | 326 |
| OPVAL 600 | 9 | 6 | 27.4 | .0460 | 65. | | | | 327 |
| OPVAL 600 | 9 | 7 | 27.4 | .0460 | 65. | | | | 328 |
| OPVAL 600 | 9 | 8 | 27.4 | .0460 | 65. | | | | 329 |
| OPVAL 600 | 9 | 9 | 27.4 | .0460 | 65. | | | | 330 |
| OPVAL 600 | 9 | 10 | 27.4 | .0460 | 65. | | | | 331 |
| OPVAL 600 | 9 | 11 | 27.4 | .0460 | 65. | | | | 332 |
| OPVAL 600 | 9 | 12 | 27.4 | .0460 | 65. | | | | 333 |
| OPVAL 600 | 9 | 13 | 27.4 | .0460 | 65. | | | | 334 |
| OPVAL 600 | 9 | 14 | 27.4 | .0460 | 65. | | | | 335 |
| OPVAL 600 | 9 | 15 | 27.4 | .0460 | 65. | | | | 336 |
| OPVAL 600 | 9 | 16 | 27.4 | .0460 | 65. | | | | 337 |
| OPVAL 600 | 9 | 17 | 27.4 | .0460 | 65. | | | | 338 |
| OPVAL 600 | 9 | 18 | 27.4 | .0460 | 65. | | | | 339 |
| OPVAL 600 | 9 | 19 | 27.4 | .0460 | 65. | | | | 340 |
| OPVAL 600 | 9 | 20 | 27.4 | .0460 | 65. | | | | 341 |
| OPVAL 600 | 9 | 21 | 27.4 | .0460 | 65. | | | | 342 |
| OPVAL 600 | 9 | 22 | 27.4 | .0460 | 65. | | | | 343 |
| OPVAL 600 | 9 | 23 | 274.0 | .0460 | 65. | | | | 344 |
| OPVAL 600 | 9 | 24 | 274.0 | .0460 | | | | | 345 |
| OPVAL 70 | 9 | 25 | 29.9 | | 1590. | | | | 346 |
| OPVAL NA | 9 | 26 | 22.74 | | 1590. | | | | 347 |
| OPVAL NA | 9 | 27 | 25.6 | .0624 | 65. | | | | 348 |
| OPVAL 600 | 9 | 28 | 25.6 | .0624 | 65. | | | | 349 |
| OPVAL NA | 9 | 29 | 27.4 | .0182 | 65. | | | | 350 |
| OPVAL 300 | 9 | 30 | 27.4 | .0182 | 65. | | | | 351 |
| OPVAL 70 | 9 | 31 | 29.9 | | 1590. | | | | 352 |
| OPVAL 70 | 9 | 32 | 29.9 | | 1590. | | | | 353 |
| OPVAL 70 | 9 | 33 | 29.9 | | 1590. | | | | 354 |
| ANCHOR | | 7300 | -94.75 | 19.917 | 27.5 | | | | 355 |
| RUN | | 7300 7295 | | -2.0 | | 35.0 | 25.0 | | 356 |
| ELBOW | | -7295 7290 | | | | | | | 357 |
| RUN | | 7290 7287 | 3.0 | | | | | | 358 |
| ELBOW | | -7287 7286 | | | | | | | 359 |
| RUN | | 7286 7285 | 4.0 | -4.0 | | | | | 360 |
| ELBOW | | -7285 7284 | | | | | | | 361 |
| RUN | | 7284 7283 | 1.25 | | | | | | 362 |
| RESTRAINT | | 7283 | | 1.0 | | | | | 363 |
| RUN | | 7283 7282 | 1.00 | | | | | | 364 |
| VALVE | | 7282 7280 | 1.0 | | | | | | 365 |
| CWEIGHT | | 7280 | | 1500. | | | | | 366 |
| VALVE | | 7280 7275 | 1.0 | | | | | | 367 |
| RUN | | 7275 7270 | 2.0 | | | | | | 368 |
| ELBOW | | -7270 7265 | | | | | | | 369 |

| | | | | | | | | | |
|-----------|-------|------|--------|--------|--|--------|------|------|-----|
| RUN | 7265 | 7260 | 9.75 | | | -9.75 | | | 370 |
| RESTRAINT | | 7260 | | 1.0 | | | | | 371 |
| ELBOW | -7260 | 7255 | | | | | | | 372 |
| RUN | 7255 | 7250 | 25.75 | | | | | | 373 |
| RESTRAINT | | 7250 | | 1.0 | | | | | 374 |
| ELBOW | -7250 | 7245 | | | | | | | 375 |
| RUN | 7245 | 7240 | | 3.5 | | -17.75 | | | 376 |
| ELBOW | -7240 | 7235 | | | | | | | 377 |
| RESTRAINT | | 7235 | | 1.0 | | | | | 378 |
| RUN | 7235 | 7230 | 6.292 | | | | | | 379 |
| RUN | 7230 | 7220 | 0.708 | | | | | | 380 |
| TEE | 7220 | 7225 | | | | | | | 381 |
| RUN | 7220 | 7225 | | | | 0.667 | 25.0 | 31.0 | 382 |
| RUN | 7225 | 215 | | | | 11.333 | | | 383 |
| RUN | 215 | 213 | | | | 10.000 | | | 384 |
| RESTRAINT | | 213 | | 1.0 | | | | | 385 |
| RUN | 213 | 211 | | | | 11.0 | | | 386 |
| RUN | 211 | 209 | | | | 11.0 | | | 387 |
| RESTRAINT | | 209 | | 1.0 | | | | | 388 |
| ELBOW | -209 | 208 | | | | | | | 389 |
| RUN | 208 | 207 | 5.0 | | | | | | 390 |
| ELBOW | -207 | 206 | | | | | | | 391 |
| RUN | 206 | 205 | | | | -16.0 | | | 392 |
| RESTRAINT | | 205 | | 1.0 | | | | | 393 |
| ELBOW | -205 | 204 | | | | | | | 394 |
| RUN | 204 | 203 | 16.5 | | | | | | 395 |
| ELBOW | -203 | 202 | | | | | | | 396 |
| RESTRAINT | | 202 | | 1.0 | | | | | 397 |
| RUN | 202 | 200 | | | | 16.0 | | | 398 |
| ELBOW | -200 | 198 | | | | | | | 399 |
| RUN | 198 | 195 | 5.5 | | | | | | 400 |
| RESTRAINT | | 195 | | 50000. | | 50000. | | | 401 |
| RUN | 195 | 190 | 6.0 | | | | | | 402 |
| ELBOW | -190 | 180 | | | | | | | 403 |
| RUN | 180 | 178 | | 2.0 | | | | | 404 |
| RESTRAINT | | 178 | 50000. | | | | | | 405 |
| RUN | 178 | 177 | | 1.781 | | | | | 406 |
| RUN | 177 | 175 | | 2.422 | | | | | 407 |
| RESTRAINT | | 175 | | | | 50000. | | | 408 |
| CWEIGHT | | 175 | | 10.0 | | | | | 409 |
| RUN | 175 | 173 | | 14.0 | | | | | 410 |
| RESTRAINT | | 173 | 50000. | | | | | | 411 |
| CWEIGHT | | 173 | | 10.0 | | | | | 412 |
| RUN | 173 | 172 | | 3.0 | | | | | 413 |
| RESTRAINT | | 172 | | | | 50000. | | | 414 |
| CWEIGHT | | 172 | | 10.0 | | | | | 415 |
| RUN | 172 | 170 | | 3.0 | | | | | 416 |
| ELBOW | -170 | 165 | | | | | | | 417 |
| RUN | 165 | 163 | -1.0 | | | | | | 418 |
| RESTRAINT | | 163 | | 1.0 | | | | | 419 |
| CWEIGHT | | 163 | | 10.0 | | | | | 420 |
| RUN | 163 | 162 | -4.75 | | | | | | 421 |
| SNUBBER | | 162 | | 17000. | | | | | 422 |
| CWEIGHT | | 162 | | 15.0 | | | | | 423 |
| RUN | 162 | 148 | -6.75 | | | | | | 424 |
| RESTRAINT | | 148 | | 1.0 | | | | | 425 |
| CWEIGHT | | 148 | | 10.0 | | | | | 426 |
| RUN | 148 | 145 | -1.5 | | | | | | 427 |
| ELBOW | -145 | 144 | | | | | | | 428 |
| RUN | 144 | 140 | | 6.172 | | | | | 429 |
| SNUBBER | | 140 | 25000. | | | | | | 430 |
| CWEIGHT | | 140 | | 15.0 | | | | | 431 |

| | | | | | | | | | |
|-----------|-------|------|--------|--------|--------|------|--|--|-----|
| RUN | 140 | 139 | | 0.25 | | | | | 432 |
| RESTRAINT | | 139 | | | 50000. | | | | 433 |
| CWEIGHT | | 139 | | 10.0 | | | | | 434 |
| RUN | 139 | 138 | | 18.031 | | | | | 435 |
| RESTRAINT | | 138 | | | 50000. | | | | 436 |
| CWEIGHT | | 138 | | 10.0 | | | | | 437 |
| RUN | 138 | 135 | | 0.25 | | | | | 438 |
| SNUBBER | | 135 | 25000. | | | | | | 439 |
| CWEIGHT | | 135 | | 15.0 | | | | | 440 |
| RUN | 135 | 130 | | 1.5 | | | | | 441 |
| ELBOW | - | 130 | 125 | | | | | | 442 |
| RUN | 125 | 123 | 1.25 | | | | | | 443 |
| RESTRAINT | | 123 | | 1.0 | | | | | 444 |
| CWEIGHT | | 123 | | 10.0 | | | | | 445 |
| RUN | 123 | 122 | 0.25 | | | | | | 446 |
| SNUBBER | | 122 | | 17000. | | | | | 447 |
| CWEIGHT | | 122 | | 15.0 | | | | | 448 |
| RUN | 122 | 106 | 8.396 | | | | | | 449 |
| RESTRAINT | | 106 | | | 50000. | | | | 450 |
| CWEIGHT | | 106 | | 10.0 | | | | | 451 |
| RUN | 106 | 105 | 0.25 | | | | | | 452 |
| RESTRAINT | | 105 | | 1.0 | | | | | 453 |
| CWEIGHT | | 105 | | 10.0 | | | | | 454 |
| RUN | 105 | 25 | 1.5 | | | | | | 455 |
| RUN | 25 | 23 | 1.375 | | | | | | 456 |
| ANCHOR | | 23 | | | | | | | 457 |
| STDISPL | 1 | 23 | -.637 | 4.742 | | | | | 458 |
| STDISPL | 2 | 23 | -.637 | 4.742 | | | | | 459 |
| STDISPL | 3 | 23 | -.637 | 4.742 | | | | | 460 |
| STDISPL | 4 | 23 | | | | | | | 461 |
| STDISPL | 5 | 23 | -.549 | 4.131 | | | | | 462 |
| STDISPL | 6 | 23 | -.549 | 4.131 | | | | | 463 |
| STDISPL | 7 | 23 | -.549 | 4.131 | | | | | 464 |
| STDISPL | 8 | 23 | | | | | | | 465 |
| STDISPL | 9 | 23 | -.321 | 3.026 | | | | | 466 |
| RUN | 7220 | 2215 | 0.708 | | 35.0 | 25.0 | | | 467 |
| RUN | 2215 | 2212 | 3.583 | | | | | | 468 |
| RESTRAINT | | 2212 | | 1.0 | | | | | 469 |
| RUN | 2212 | 2210 | 0.708 | | | | | | 470 |
| TEE | | 2210 | 2212 | | | | | | 471 |
| RUN | 2210 | 2207 | | | 0.708 | 32.0 | | | 472 |
| REDUCER | 2207 | 2206 | | | 0.583 | 25.0 | | | 473 |
| RUN | 2206 | 2205 | | | 22.709 | | | | 474 |
| RESTRAINT | | 2205 | | 1.0 | | | | | 475 |
| ELBOW | -2205 | 2204 | | | | | | | 476 |
| RUN | 2204 | 2203 | 2.0 | | | | | | 477 |
| ELBOW | -2203 | 2202 | | | | | | | 478 |
| RUN | 2202 | 2201 | | | -21.5 | | | | 479 |
| RESTRAINT | | 2201 | | 1.0 | | | | | 480 |
| ELBOW | -2201 | 2200 | | | | | | | 481 |
| RUN | 2200 | 2199 | 17.5 | | | | | | 482 |
| ELBOW | -2199 | 2198 | | | | | | | 483 |
| RESTRAINT | | 2198 | | 1.0 | | | | | 484 |
| RUN | 2198 | 2197 | | | 19.5 | | | | 485 |
| ELBOW | -2197 | 2196 | | | | | | | 486 |
| RUN | 2196 | 2195 | 2.5 | | | | | | 487 |
| RESTRAINT | | 2195 | | 50000. | 50000. | | | | 488 |
| RUN | 2195 | 2190 | 6.0 | | | | | | 489 |
| ELBOW | -2190 | 2180 | | | | | | | 490 |
| RUN | 2180 | 2178 | | 2.0 | | | | | 491 |
| RESTRAINT | | 2178 | 50000. | | | | | | 492 |
| RUN | 2178 | 2177 | | 1.781 | | | | | 493 |

| | | | | | | | | |
|-----------|-------|------|--------|--------|--------|------|-----|-----|
| RUN | 2177 | 2175 | | 2.422 | | 494 | | |
| RESTRAINT | | 2175 | | | 50000. | 495 | | |
| CWEIGHT | | 2175 | | 10.0 | | 496 | | |
| RUN | 2175 | 2173 | | 14.0 | | 497 | | |
| RESTRAINT | | 2173 | 50000. | | | 498 | | |
| CWEIGHT | | 2173 | | 10.0 | | 499 | | |
| RUN | 2173 | 2172 | | 3.0 | | 500 | | |
| RESTRAINT | | 2172 | | | 50000. | 501 | | |
| CWEIGHT | | 2172 | | 10.0 | | 502 | | |
| RUN | 2172 | 2170 | | 3.0 | | 503 | | |
| ELBOW | -2170 | 2165 | | | | 504 | | |
| RUN | 2165 | 2163 | -1.0 | | | 505 | | |
| RESTRAINT | | 2163 | | 1.0 | | 506 | | |
| CWEIGHT | | 2163 | | 10.0 | | 507 | | |
| RUN | 2163 | 2162 | -4.75 | | | 508 | | |
| SNUBBER | | 2162 | | 17000. | | 509 | | |
| CWEIGHT | | 2162 | | 15.0 | | 510 | | |
| RUN | 2162 | 2148 | -6.75 | | | 511 | | |
| RESTRAINT | | 2148 | | 1.0 | | 512 | | |
| CWEIGHT | | 2148 | | 10.0 | | 513 | | |
| RUN | 2148 | 2145 | -1.5 | | | 514 | | |
| ELBOW | -2145 | 2144 | | | | 515 | | |
| RUN | 2144 | 2140 | | 6.172 | | 516 | | |
| SNUBBER | | 2140 | 25000. | | | 517 | | |
| CWEIGHT | | 2140 | | 15.0 | | 518 | | |
| RUN | 2140 | 2139 | | 0.25 | | 519 | | |
| RESTRAINT | | 2139 | | | 50000. | 520 | | |
| CWEIGHT | | 2139 | | 10.0 | | 521 | | |
| RUN | 2139 | 2138 | | 18.031 | | 522 | | |
| RESTRAINT | | 2138 | | | 50000. | 523 | | |
| CWEIGHT | | 2138 | | 10.0 | | 524 | | |
| RUN | 2138 | 2135 | | 0.25 | | 525 | | |
| SNUBBER | | 2135 | 25000. | | | 526 | | |
| CWEIGHT | | 2135 | | 15.0 | | 527 | | |
| RUN | 2135 | 2130 | | 1.5 | | 528 | | |
| ELBOW | -2130 | 2125 | | | | 529 | | |
| RUN | 2125 | 2123 | 1.25 | | | 530 | | |
| RESTRAINT | | 2123 | | 1.0 | | 531 | | |
| CWEIGHT | | 2123 | | 10.0 | | 532 | | |
| RUN | 2123 | 2122 | 0.25 | | | 533 | | |
| SNUBBER | | 2122 | | 17000. | | 534 | | |
| CWEIGHT | | 2122 | | 15.0 | | 535 | | |
| RUN | 2122 | 2106 | 8.396 | | | 536 | | |
| RESTRAINT | | 2106 | | | 50000. | 537 | | |
| CWEIGHT | | 2106 | | 10.0 | | 538 | | |
| RUN | 2106 | 2105 | 0.25 | | | 539 | | |
| RESTRAINT | | 2105 | | 1.0 | | 540 | | |
| CWEIGHT | | 2105 | | 10.0 | | 541 | | |
| RUN | 2105 | 2025 | 1.5 | | | 542 | | |
| RUN | 2025 | 2023 | 1.375 | | | 543 | | |
| ANCHOR | | 2023 | | | | 544 | | |
| STDISPL | 1 | 2023 | -.637 | 4.742 | | 545 | | |
| STDISPL | 2 | 2023 | -.637 | 4.742 | | 546 | | |
| STDISPL | 3 | 2023 | | | | 547 | | |
| STDISPL | 4 | 2023 | -.637 | 4.742 | | 548 | | |
| STDISPL | 5 | 2023 | -.549 | 4.131 | | 549 | | |
| STDISPL | 6 | 2023 | -.549 | 4.131 | | 550 | | |
| STDISPL | 7 | 2023 | | | | 551 | | |
| STDISPL | 8 | 2023 | -.549 | 4.131 | | 552 | | |
| STDISPL | 9 | 2023 | -.321 | 3.026 | | 553 | | |
| RUN | 210 | 2211 | | | -0.708 | 35.0 | 33. | 554 |
| REDUCER | 211 | 3230 | | | -0.583 | 25.0 | | 555 |

| | | | | | | | |
|-----------|-------|------|--------|--------|---------|--|-----|
| RUN | 3230 | 3225 | | | -14.709 | | 556 |
| RESTRAINT | | 3225 | | 1.0 | | | 557 |
| ELBOW | -3225 | 3220 | | | | | 558 |
| RUN | 3220 | 3215 | 16.5 | | | | 559 |
| ELBOW | -3215 | 3210 | | | | | 560 |
| RESTRAINT | | 3210 | | 1.0 | | | 561 |
| RUN | 3210 | 3205 | | | 16.0 | | 562 |
| ELBOW | -3205 | 3200 | | | | | 563 |
| RUN | 3200 | 3195 | 5.5 | | | | 564 |
| RESTRAINT | | 3195 | | 50000. | 50000. | | 565 |
| RUN | 3195 | 3190 | 6.0 | | | | 566 |
| ELBOW | -3190 | 3180 | | | | | 567 |
| RUN | 3180 | 3178 | | 2.0 | | | 568 |
| RESTRAINT | | 3178 | 50000. | | | | 569 |
| RUN | 3178 | 3177 | | 1.781 | | | 570 |
| RUN | 3177 | 3175 | | 2.422 | | | 571 |
| RESTRAINT | | 3175 | | | 50000. | | 572 |
| CWEIGHT | | 3175 | | 10.0 | | | 573 |
| RUN | 3175 | 3173 | | 14.0 | | | 574 |
| RESTRAINT | | 3173 | 50000. | | | | 575 |
| CWEIGHT | | 3173 | | 10.0 | | | 576 |
| RUN | 3173 | 3172 | | 3.0 | | | 577 |
| RESTRAINT | | 3172 | | | 50000. | | 578 |
| CWEIGHT | | 3172 | | 10.0 | | | 579 |
| RUN | 3172 | 3170 | | 3.0 | | | 580 |
| ELBOW | -3170 | 3165 | | | | | 581 |
| RUN | 3165 | 3163 | -1.0 | | | | 582 |
| RESTRAINT | | 3163 | | 1.0 | | | 583 |
| CWEIGHT | | 3163 | | 10.0 | | | 584 |
| RUN | 3163 | 3162 | -4.75 | | | | 585 |
| SNUBBER | | 3162 | | 17000. | | | 586 |
| CWEIGHT | | 3162 | | 15.0 | | | 587 |
| RUN | 3162 | 3148 | -6.75 | | | | 588 |
| RESTRAINT | | 3148 | | 1.0 | | | 589 |
| CWEIGHT | | 3148 | | 10.0 | | | 590 |
| RUN | 3148 | 3145 | -1.5 | | | | 591 |
| ELBOW | -3145 | 3144 | | | | | 592 |
| RUN | 3144 | 3140 | | 6.172 | | | 593 |
| SNUBBER | | 3140 | 25000. | | | | 594 |
| CWEIGHT | | 3140 | | 15.0 | | | 595 |
| RUN | 3140 | 3139 | | 0.25 | | | 596 |
| RESTRAINT | | 3139 | | | 50000. | | 597 |
| CWEIGHT | | 3139 | | 10.0 | | | 598 |
| RUN | 3139 | 3138 | | 18.031 | | | 599 |
| RESTRAINT | | 3138 | | | 50000. | | 600 |
| CWEIGHT | | 3138 | | 10.0 | | | 601 |
| RUN | 3138 | 3135 | | 0.25 | | | 602 |
| SNUBBER | | 3135 | 25000. | | | | 603 |
| CWEIGHT | | 3135 | | 15.0 | | | 604 |
| RUN | 3135 | 3130 | | 1.5 | | | 605 |
| ELBOW | -3130 | 3125 | | | | | 606 |
| RUN | 3125 | 3123 | 1.25 | | | | 607 |
| RESTRAINT | | 3123 | | 1.0 | | | 608 |
| CWEIGHT | | 3123 | | 10.0 | | | 609 |
| RUN | 3123 | 3122 | 0.25 | | | | 610 |
| SNUBBER | | 3122 | | 17000. | | | 611 |
| CWEIGHT | | 3122 | | 15.0 | | | 612 |
| RUN | 3122 | 3106 | 8.396 | | | | 613 |
| RESTRAINT | | 3106 | | | 50000. | | 614 |
| CWEIGHT | | 3106 | | 10.0 | | | 615 |
| RUN | 3106 | 3105 | 0.25 | | | | 616 |
| RESTRAINT | | 3105 | | 1.0 | | | 617 |

NUPIPE-IIM - NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.4

CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE PLUS NA INLET AND OUTLET

TABLE B-1

INTERFACE LOAD SUMMARY

NODE NO. 23

| LOAD CASE | TRANSLATIONAL FORCE (KIP) | | | ROTATIONAL FORCE (IN-KIP) | | |
|-----------|---------------------------|------------|------------|---------------------------|------------|--------|
| | FX | FY | FZ | MX | MY | MZ |
| 1 | 5.922D-02 | -4.381D-02 | 2.695D-03 | -.4295 | 1.767D-02 | 15.48 |
| 2 | 5.916D-02 | -4.319D-02 | 2.190D-03 | -.3473 | 1.512D-02 | 15.41 |
| 3 | 5.952D-02 | -4.643D-02 | 2.390D-03 | -.3798 | 1.617D-02 | 15.81 |
| 4 | -.2727 | 1.140 | 5.072D-03 | -.8753 | 3.984D-02 | -156.1 |
| 5 | 9.130D-02 | -.1860 | 2.246D-03 | -.3711 | 1.696D-02 | 34.58 |
| 6 | 9.129D-02 | -.1858 | 1.912D-03 | -.3146 | 1.494D-02 | 34.57 |
| 7 | 9.173D-02 | -.1898 | 2.045D-03 | -.3370 | 1.577D-02 | 35.06 |
| 8 | -.2730 | 1.142 | 3.847D-03 | -.6623 | 3.076D-02 | -156.4 |
| 9 | .4106 | -1.585 | -4.608D-04 | 8.043D-02 | -4.780D-03 | 223.1 |
| 10 | -3.979D-02 | -.3135 | -2.220D-04 | 1.205D-02 | -2.514D-03 | 2.485 |

NOTE: 1) FORCES ARE THOSE IMPOSED ON THE INTERFACE IN THE LOCAL COORDINATE SYSTEM OF THE CONNECTING ELEMENT

NUPIPE-IIM - NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.4

CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE PLUS NA INLET AND OUTLET

TABLE B-1

INTERFACE LOAD SUMMARY

NODE NO. 2023

| LOAD CASE | TRANSLATIONAL FORCE (KIP) | | | ROTATIONAL FORCE (IN-KIP) | | |
|--------------|---------------------------|------------|------------|---------------------------|------------|--------|
| | FX | FY | FZ | MX | MY | MZ |
| 1 | 5.886D-02 | -3.589D-02 | 1.075D-02 | -1.730 | 6.257D-02 | 14.54 |
| 2 | 5.945D-02 | -4.120D-02 | 1.014D-02 | -1.630 | 5.979D-02 | 15.20 |
| 3 | -.2741 | 1.156 | 1.184D-02 | -2.052 | 8.991D-02 | -158.1 |
| 4 | 5.908D-02 | -3.757D-02 | 1.057D-02 | -1.701 | 6.189D-02 | 14.75 |
| 5 | 9.085D-02 | -.1785 | 9.049D-03 | -1.515 | 6.050D-02 | 33.68 |
| 6 | 9.161D-02 | -.1854 | 8.600D-03 | -1.439 | 5.793D-02 | 34.54 |
| 7 | -.2741 | 1.156 | 9.757D-03 | -1.690 | 7.446D-02 | -158.0 |
| 8 | 9.122D-02 | -.1817 | 8.950D-03 | -1.498 | 6.004D-02 | 34.08 |
| 9 | .4102 | -1.581 | -4.371D-04 | 7.684D-02 | -4.361D-03 | 222.6 |
| 10 | -3.950D-02 | -.3286 | 1.639D-04 | -9.709D-03 | 1.856D-03 | 2.639 |

NOTE: 1) FORCES ARE THOSE IMPDSED ON THE INTERFACE IN THE LOCAL COORDINATE SYSTEM OF THE CONNECTING ELEMENT

NUPIPE-IIM - NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.4

CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE PLUS NA INLET AND OUTLET

TABLE B-1

INTERFACE LOAD SUMMARY

NODE NO. 3023

| LOAD CASE | TRANSLATIONAL FORCE (KIP) | | | ROTATIONAL FORCE (IN-KIP) | | |
|--------------|---------------------------|------------|------------|---------------------------|------------|--------|
| | FX | FY | FZ | MX | MY | MZ |
| 1 | 5.677D-02 | -1.065D-02 | 1.523D-02 | -2.453 | 8.791D-02 | 11.44 |
| 2 | -.2778 | 1.194 | 1.496D-02 | -2.594 | .1130 | -162.8 |
| 3 | 5.717D-02 | -1.336D-02 | 1.502D-02 | -2.417 | 8.770D-02 | 11.79 |
| 4 | 5.663D-02 | -8.488D-03 | 1.500D-02 | -2.414 | 8.721D-02 | 11.18 |
| 5 | 8.907D-02 | -.1578 | 1.283D-02 | -2.150 | 8.479D-02 | 31.13 |
| 6 | -.2773 | 1.188 | 1.251D-02 | -2.169 | 9.471D-02 | -162.0 |
| 7 | 8.972D-02 | -.1634 | 1.266D-02 | -2.121 | 8.421D-02 | 31.83 |
| 8 | 8.900D-02 | -.1568 | 1.272D-02 | -2.130 | 8.444D-02 | 31.01 |
| 9 | .4122 | -1.598 | -3.448D-04 | 6.086D-02 | -3.366D-03 | 224.8 |
| 10 | -3.973D-02 | -.3164 | -2.836D-04 | 1.414D-02 | -3.211D-03 | 2.515 |

NOTE: 1) FORCES ARE THOSE IMPOSED ON THE INTERFACE IN THE LOCAL COORDINATE SYSTEM OF THE CONNECTING ELEMENT

NUPIPE-IIM - NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.4

CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE PLUS NA INLET AND OUTLET

TABLE B-1
INTERFACE LOAD SUMMARY

NODE NO. 2210

| LOAD CASE | TRANSLATIONAL FORCE (KIP) | | | ROTATIONAL FORCE (IN-KIP) | | |
|--------------|---------------------------|------------|------------|---------------------------|--------|--------|
| | FX | FY | FZ | MX | MY | MZ |
| 1 | -.5623 | -6.005D-02 | -1.397 | 8.322 | 58.68 | -22.17 |
| 2 | -.6562 | -1.062D-02 | -1.373 | 17.11 | 43.89 | -20.07 |
| 3 | -.4778 | -8.063D-02 | -1.489 | 11.22 | 80.08 | -23.72 |
| 4 | -.4832 | -6.354D-02 | -1.471 | 8.734 | 76.05 | -21.49 |
| 5 | -.4968 | -5.641D-02 | -1.236 | 5.796 | 51.65 | -19.83 |
| 6 | -.5263 | 2.267D-03 | -1.177 | 14.92 | 42.11 | -16.35 |
| 7 | -.4518 | -8.045D-02 | -1.287 | 9.287 | 63.30 | -21.68 |
| 8 | -.4503 | -6.013D-02 | -1.278 | 6.399 | 61.59 | -18.96 |
| 9 | 5.162D-03 | -3.515D-02 | 1.738D-02 | -16.38 | -.4662 | -2.467 |
| 10 | -2.249D-03 | -.8066 | -5.067D-03 | 2.486 | .4220 | -17.49 |

NOTE: 1) FORCES ARE THOSE IMPOSED ON THE INTERFACE IN THE LOCAL COORDINATE SYSTEM OF THE CONNECTING ELEMENT

079T1000008
118

NUPIPE-IIM - NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.4

CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE PLUS NA INLET AND OUTLET

TABLE B-1
INTERFACE LOAD SUMMARY

NODE NO. 7220

| LOAD CASE | TRANSLATIONAL FORCE (KIP) | | | ROTATIONAL FORCE (IN-KIP) | | |
|--------------|---------------------------|------------|------------|---------------------------|--------|--------|
| | FX | FY | FZ | MX | MY | MZ |
| 1 | -2.243 | -.1079 | .8681 | -22.02 | -154.0 | -20.69 |
| 2 | -2.237 | -7.341D-02 | .9066 | -18.62 | -166.1 | -28.99 |
| 3 | -2.295 | -7.833D-02 | .9508 | -31.83 | -151.2 | -26.37 |
| 4 | -2.348 | -.1189 | .7558 | -19.60 | -131.4 | -22.54 |
| 5 | -1.984 | -.1026 | .7666 | -19.08 | -136.5 | -16.33 |
| 6 | -1.938 | -6.188D-02 | .7639 | -14.24 | -143.1 | -24.92 |
| 7 | -1.983 | -6.463D-02 | .8075 | -30.32 | -129.9 | -21.82 |
| 8 | -2.047 | -.1165 | .7006 | -15.90 | -123.9 | -18.91 |
| 9 | 2.919D-02 | -7.471D-02 | -8.104D-03 | 4.054 | 2.572 | 20.90 |
| 10 | -5.365D-03 | .8803 | 2.168D-03 | -11.99 | .1985 | 35.80 |

NOTE: 1) FORCES ARE THOSE IMPOSED ON THE INTERFACE IN THE LOCAL COORDINATE SYSTEM OF THE CONNECTING ELEMENT

NUPIPE-IIM - NUCLEAR SERVICES CORPORATION PIPING ANALYSIS PROGRAM - VERSION 1.4

CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE PLUS NA INLET AND OUTLET

TABLE B-1

INTERFACE LOAD SUMMARY

NODE NO. 7300

| LOAD CASE | TRANSLATIONAL FORCE (KIP) | | | ROTATIONAL FORCE (IN-KIP) | | |
|--------------|---------------------------|------------|------------|---------------------------|--------|--------|
| | FX | FY | FZ | MX | MY | MZ |
| 1 | .1215 | -2.672 | .7313 | -91.36 | -78.02 | -185.9 |
| 2 | 8.825D-02 | -2.673 | .7337 | -80.64 | -64.22 | -172.1 |
| 3 | 9.848D-02 | -2.735 | .7901 | -74.73 | -79.34 | -178.8 |
| 4 | 9.833D-02 | -2.683 | .8348 | -57.58 | -85.05 | -177.2 |
| 5 | .1188 | -2.365 | .6455 | -81.52 | -70.69 | -169.4 |
| 6 | 7.990D-02 | -2.323 | .6217 | -78.69 | -52.92 | -150.8 |
| 7 | 8.933D-02 | -2.372 | .6721 | -71.54 | -69.67 | -156.4 |
| 8 | 8.999D-02 | -2.357 | .7095 | -59.41 | -76.51 | -157.0 |
| 9 | .1159 | 3.544D-02 | -4.073D-03 | 3.981 | -17.49 | -49.05 |
| 10 | .1143 | -6.061D-03 | 3.372D-03 | .3700 | 14.13 | 14.85 |

NOTE: 1) FORCES ARE THOSE IMPOSED ON THE INTERFACE IN THE LOCAL COORDINATE SYSTEM OF THE CONNECTING ELEMENT

E B-6

/03/09/83

079T1000008
120

ORIGINAL INPUT BY GURSAHANI ON 04/04/83 AT 10:53:13 WITH PRIORITY 3
 CARRIZO MSG PLUS STEAM PIPING UPTO TURBINE ~~XXXXXXXXXXXXXXXXXXXX~~

| | | | | | | | | | |
|---|----|-------|-------|--------|------|-------|--|--|----|
| CONTROL | | 2.0 | 1.0 | | | | | | 1 |
| FLEXAN | 1 | 1 | 2.0 | | | | | | 2 |
| TE1 (THERMAL AT THE DESIGN TEMPERATURE) | | | | | | | | | 3 |
| FLEXAN | 2 | 2 | 2.0 | | | | | | 4 |
| TE2 (OVERNIGHT SHUTDOWN) | | | | | | | | | 5 |
| FLEXAN | 3 | 3 | 2.0 | | | | | | 6 |
| TE3 (LONG TERM SHUTDOWN) | | | | | | | | | 7 |
| XSECTN | 1 | 54.22 | 0.721 | 812.0 | 29.9 | | | | 8 |
| XSECTN | 2 | 30.94 | 0.721 | 705.1 | 29.9 | | | | 9 |
| XSECTN | 3 | 21.5 | 1.0 | 580.1 | 29.9 | 0.0 | | | 10 |
| XSECTN | 4 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 | | | 11 |
| XSECTN | 5 | 12.81 | 1.0 | 370.3 | 29.9 | 0.0 | | | 12 |
| XSECTN | 6 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 | | | 13 |
| XSECTN | 7 | 12.75 | .562 | 51.7 | 29.9 | 0.0 | | | 14 |
| XSECTN | 8 | 26.0 | 1.97 | 993.2 | 29.9 | 0.0 | | | 15 |
| XSECTN | 9 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 | | | 16 |
| XSECTN | 10 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 17 |
| XSECTN | 11 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 18 |
| XSECTN | 12 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 19 |
| XSECTN | 13 | 18.0 | 0.75 | 433.8 | 29.9 | 0.0 | | | 20 |
| XSECTN | 14 | 21.0 | 0.86 | 546.6 | 29.9 | 0.0 | | | 21 |
| XSECTN | 15 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 | | | 22 |
| XSECTN | 16 | 12.75 | .562 | 92.1 | 29.9 | 0.0 | | | 23 |
| XSECTN | 17 | 26.0 | 1.97 | 1002.0 | 29.9 | 0.0 | | | 24 |
| XSECTN | 18 | 24.0 | 1.0 | 524.4 | 29.9 | 0.0 | | | 25 |
| XSECTN | 19 | 26.0 | 1.97 | 927.5 | 29.9 | 0.0 | | | 26 |
| XSECTN | 20 | 21.5 | 1.0 | 596.4 | 29.9 | 0.0 | | | 27 |
| XSECTN | 21 | 19.0 | 1.0 | 859.8 | 29.9 | 0.0 | | | 28 |
| XSECTN | 22 | 12.81 | 1.0 | 376.9 | 29.9 | 0.0 | | | 29 |
| XSECTN800 | 23 | 12.75 | 0.562 | 51.7 | 299. | 0.0 | | | 30 |
| XSECT1700 | 24 | 12.75 | 0.562 | 89.8 | 299. | 0.0 | | | 31 |
| XSECTN | 25 | 6.625 | 0.864 | 85.5 | 29.9 | 1590. | | | 32 |
| XSECTN NA | 26 | 6.625 | 0.864 | | 29.9 | 1590. | | | 33 |
| XSECTN NA | 27 | 12.75 | 0.406 | 175. | 28.3 | 65. | | | 34 |
| XSECTN | 28 | 6.625 | 0.280 | 98.5 | 28.3 | 65. | | | 35 |
| XSECTN NA | 29 | 12.75 | 0.406 | 130. | 27.9 | 65. | | | 36 |
| XSECTN | 30 | 6.625 | 0.280 | 53.4 | 27.9 | 65. | | | 37 |
| XSECTN | 31 | 12.75 | 0.687 | 218.8 | 28.3 | 65. | | | 38 |
| XSECTN NA | 32 | 6.625 | 0.280 | | 27.9 | 65. | | | 39 |
| XSECTN | 33 | 12.75 | 0.687 | 218.8 | 27.9 | 65. | | | 40 |
| XSECTN | 34 | 10.75 | 0.365 | 154.6 | 28.3 | 65. | | | 41 |
| XSECTN | 35 | 10.75 | 1.40 | 199.1 | 28.3 | 1590. | | | 42 |
| OPVAL225 | 1 | 1 | 29.4 | .01198 | | | | | 43 |
| OPVAL435 | 1 | 2 | 28.4 | .03022 | | | | | 44 |
| OPVAL470 | 1 | 3 | 28.2 | .03344 | | | | | 45 |
| OPVAL450 | 1 | 4 | 28.3 | .03160 | | | | | 46 |
| OPVAL450 | 1 | 5 | 28.3 | .03160 | | | | | 47 |
| OPVAL587 | 1 | 6 | 27.5 | .04473 | | | | | 48 |
| OPVAL620 | 1 | 7 | 27.2 | .04086 | | | | | 49 |
| OPVAL625 | 1 | 8 | 27.2 | .04858 | | | | | 50 |
| OPVAL640 | 1 | 9 | 27.1 | .05012 | | | | | 51 |
| OPVAL705 | 1 | 10 | 26.6 | .05684 | | | | | 52 |
| OPVAL865 | 1 | 11 | 24.9 | .07422 | | | | | 53 |
| OPVAL1010 | 1 | 12 | 22.7 | .09005 | | | | | 54 |
| OPVAL1050 | 1 | 13 | 21.7 | .09465 | | | | | 55 |
| OPVAL1055 | 1 | 14 | 21.6 | .09523 | | | | | 56 |
| OPVAL1057 | 1 | 15 | 21.5 | .09546 | | | | | 57 |
| OPVAL1065 | 1 | 16 | 21.3 | .09638 | | | | | 58 |
| | | | | | | | | | 59 |

| | | | | | | |
|------------|---|----|-------|--------|-------|-----|
| OPVAL 1055 | 1 | 17 | 21.6 | .09523 | | 60 |
| OPVAL 1025 | 1 | 18 | 22.4 | .09178 | | 61 |
| OPVAL 1020 | 1 | 19 | 22.5 | .09120 | | 62 |
| OPVAL 1020 | 1 | 20 | 22.5 | .09120 | | 63 |
| OPVAL 1015 | 1 | 21 | 22.6 | .09063 | | 64 |
| OPVAL 1015 | 1 | 22 | 22.6 | .09063 | | 65 |
| OPVAL 800 | 1 | 23 | 273.0 | .04703 | | 66 |
| OPVAL 1065 | 1 | 24 | 213.0 | .09638 | | 67 |
| OPVAL 1015 | 1 | 25 | 22.60 | .09063 | 1590. | 68 |
| OPVAL NA | 1 | 26 | 22.74 | .09005 | 1590. | 69 |
| OPVAL NA | 1 | 27 | 22.4 | .12364 | 65. | 70 |
| OPVAL 1065 | 1 | 28 | 22.4 | .12364 | 65. | 71 |
| OPVAL NA | 1 | 29 | 25.61 | .04703 | 65. | 72 |
| OPVAL 610 | 1 | 30 | 25.61 | .04703 | 65. | 73 |
| OPVAL 1015 | 1 | 31 | 22.60 | .09063 | 1590. | 74 |
| OPVAL 1015 | 1 | 32 | 22.60 | .09063 | 1590. | 75 |
| OPVAL 1015 | 1 | 33 | 22.60 | .09063 | 1590. | 76 |
| OPVAL 201 | 2 | 1 | 29.5 | .00998 | | 77 |
| OPVAL 381 | 2 | 2 | 29.1 | .02533 | | 78 |
| OPVAL 420 | 2 | 3 | 28.5 | .02884 | | 79 |
| OPVAL 400 | 2 | 4 | 28.5 | .02700 | | 80 |
| OPVAL 400 | 2 | 5 | 28.5 | .02700 | | 81 |
| OPVAL 550 | 2 | 6 | 27.7 | .04110 | | 82 |
| OPVAL 570 | 2 | 7 | 27.6 | .04306 | | 83 |
| OPVAL 575 | 2 | 8 | 27.6 | .04355 | | 84 |
| OPVAL 585 | 2 | 9 | 27.5 | .04453 | | 85 |
| OPVAL 650 | 2 | 10 | 27.0 | .05115 | | 86 |
| OPVAL 770 | 2 | 11 | 26.0 | .06379 | | 87 |
| OPVAL 890 | 2 | 12 | 24.6 | .07699 | | 88 |
| OPVAL 940 | 2 | 13 | 23.9 | .08242 | | 89 |
| OPVAL 942 | 2 | 14 | 23.9 | .08264 | | 90 |
| OPVAL 948 | 2 | 15 | 23.8 | .08328 | | 91 |
| OPVAL 950 | 2 | 16 | 23.8 | .08350 | | 92 |
| OPVAL 950 | 2 | 17 | 23.8 | .08350 | | 93 |
| OPVAL 910 | 2 | 18 | 24.4 | .07918 | | 94 |
| OPVAL 905 | 2 | 19 | 24.4 | .07864 | | 95 |
| OPVAL 902 | 2 | 20 | 24.5 | .07832 | | 96 |
| OPVAL 900 | 2 | 21 | 24.5 | .07810 | | 97 |
| OPVAL 900 | 2 | 22 | 24.5 | .07810 | | 98 |
| OPVAL 570 | 2 | 23 | 276.0 | .04306 | | 99 |
| OPVAL 950 | 2 | 24 | 237.5 | .08350 | | 100 |
| OPVAL 850 | 2 | 25 | 25.1 | .07255 | 1590. | 101 |
| OPVAL NA | 2 | 26 | 22.74 | .09005 | 1590. | 102 |
| OPVAL NA | 2 | 27 | 23.2 | .10800 | 65. | 103 |
| OPVAL 950 | 2 | 28 | 23.2 | .10800 | 65. | 104 |
| OPVAL NA | 2 | 29 | 27.4 | .0182 | 65. | 105 |
| OPVAL 300 | 2 | 30 | 27.4 | .0182 | 65. | 106 |
| OPVAL 850 | 2 | 31 | 25.1 | .07255 | 1590. | 107 |
| OPVAL 850 | 2 | 32 | 25.1 | .07255 | 1590. | 108 |
| OPVAL 850 | 2 | 33 | 25.1 | .07255 | 1590. | 109 |
| OPVAL 226 | 3 | 1 | 29.4 | .01206 | 65. | 110 |
| OPVAL 492 | 3 | 2 | 28.0 | .03546 | 65. | 111 |
| OPVAL 600 | 3 | 3 | 27.4 | .0460 | 65. | 112 |
| OPVAL 600 | 3 | 4 | 27.4 | .0460 | 65. | 113 |
| OPVAL 600 | 3 | 5 | 27.4 | .0460 | 65. | 114 |
| OPVAL 600 | 3 | 6 | 27.4 | .0460 | 65. | 115 |
| OPVAL 600 | 3 | 7 | 27.4 | .0460 | 65. | 116 |
| OPVAL 600 | 3 | 8 | 27.4 | .0460 | 65. | 117 |
| OPVAL 600 | 3 | 9 | 27.4 | .0460 | 65. | 118 |
| OPVAL 600 | 3 | 10 | 27.4 | .0460 | 65. | 119 |
| OPVAL | 3 | 11 | 27.4 | .0460 | 65. | 120 |
| OPVAL | 3 | 12 | 27.4 | .0460 | 65. | 121 |

| | | | | | | | | | | |
|-----------|-------|------|--------|-------|--------|------|--------|------|-------|-----|
| OPVAL 600 | 3 | 13 | 27.4 | .0460 | | | | | 65. | 122 |
| OPVAL 600 | 3 | 14 | 27.4 | .0460 | | | | | 65. | 123 |
| OPVAL 600 | 3 | 15 | 27.4 | .0460 | | | | | 65. | 124 |
| OPVAL 600 | 3 | 16 | 27.4 | .0460 | | | | | 65. | 125 |
| OPVAL 600 | 3 | 17 | 27.4 | .0460 | | | | | 65. | 126 |
| OPVAL 600 | 3 | 18 | 27.4 | .0460 | | | | | 65. | 127 |
| OPVAL 600 | 3 | 19 | 27.4 | .0460 | | | | | 65. | 128 |
| OPVAL 600 | 3 | 20 | 27.4 | .0460 | | | | | 65. | 129 |
| OPVAL 600 | 3 | 21 | 27.4 | .0460 | | | | | 65. | 130 |
| OPVAL 600 | 3 | 22 | 27.4 | .0460 | | | | | 65. | 131 |
| OPVAL 600 | 3 | 23 | 274.0 | .0460 | | | | | 65. | 132 |
| OPVAL 600 | 3 | 24 | 274.0 | .0460 | | | | | 65. | 133 |
| OPVAL 70 | 3 | 25 | 29.9 | | | | | | 1590. | 134 |
| OPVAL NA | 3 | 26 | 22.74 | | | | | | 1590. | 135 |
| OPVAL NA | 3 | 27 | 25.6 | .0624 | | | | | 65. | 136 |
| OPVAL 600 | 3 | 28 | 25.6 | .0624 | | | | | 65. | 137 |
| OPVAL NA | 3 | 29 | 27.4 | .0182 | | | | | 65. | 138 |
| OPVAL 300 | 3 | 30 | 27.4 | .0182 | | | | | 65. | 139 |
| OPVAL 70 | 3 | 31 | 29.9 | | | | | | 1590. | 140 |
| OPVAL 70 | 3 | 32 | 29.9 | | | | | | 1590. | 141 |
| OPVAL 70 | 3 | 33 | 29.9 | | | | | | 1590. | 142 |
| ANCHOR | | 7300 | -94.75 | | 19.917 | | 27.5 | | | 143 |
| RUN | 7300 | 7295 | | | -2.0 | | 35.0 | 25.0 | | 144 |
| ELBOW | -7295 | 7290 | | | | | | | | 145 |
| RUN | 7290 | 7287 | 3.0 | | | | | | | 146 |
| ELBOW | -7287 | 7286 | 30.0 | | | | | | | 147 |
| RUN | 7286 | 7285 | 4.0 | | -4.0 | | | | | 148 |
| ELBOW | -7285 | 7284 | | | | | | | | 149 |
| RUN | 7284 | 7283 | 1.25 | | | | | | | 150 |
| RESTRAINT | | 7283 | | 1.0 | | | | | | 151 |
| RUN | 7283 | 7282 | 1.00 | | | | | | | 152 |
| VALVE | 7282 | 7280 | 1.0 | | | | | | | 153 |
| CWEIGHT | | 7280 | | | 1500. | | | | | 154 |
| VALVE | 7280 | 7275 | 1.0 | | | | | | | 155 |
| RUN | 7275 | 7273 | 1.0 | | | | | | | 156 |
| RUN | 7273 | 7270 | 1.0 | | | | | | | 157 |
| ELBOW | -7270 | 7265 | | | | | | | | 158 |
| RUN | 7265 | 7263 | 6.75 | | | | -6.75 | | | 159 |
| RESTRAINT | | 7263 | | 1.0 | | | | | | 160 |
| RUN | 7263 | 7260 | 3.0 | | | | -3.0 | | | 161 |
| ELBOW | -7260 | 7255 | 30.0 | | | | | | | 162 |
| RUN | 7255 | 7253 | 23.00 | | | | | | | 163 |
| RESTRAINT | | 7253 | | 1.0 | | | | | | 164 |
| RUN | 7253 | 7250 | 2.75 | | | | | | | 165 |
| ELBOW | -7250 | 7245 | 30.0 | | | | | | | 166 |
| RUN | 7245 | 7240 | | 3.5 | | | -17.75 | | | 167 |
| ELBOW | -7240 | 7235 | 30.0 | | | | | | | 168 |
| RUN | 7235 | 7230 | 2.292 | | | | | | | 169 |
| RUN | 7230 | 7220 | 0.708 | | | | | | | 170 |
| TEE | 7220 | 7228 | | | | | | | | 171 |
| RUN | 7220 | 7228 | | | 0.667 | 25.0 | 31.0 | | | 172 |
| RUN | 7228 | 215 | | | 11.333 | | | | | 173 |
| RUN | 215 | 213 | | | 10.000 | | | | | 174 |
| RESTRAINT | | 213 | | 1.0 | | | | | | 175 |
| RUN | 213 | 212 | | | 5.0 | | | | | 176 |
| RUN | 212 | 211 | | | 6.0 | | | | | 177 |
| RUN | 211 | 210 | | | 11.0 | | | | | 178 |
| ELBOW | -210 | 209 | 30.0 | | | | | | | 179 |
| RUN | 209 | 208 | 3.0 | | | | | | | 180 |
| RESTRAINT | | 208 | | 1.0 | | | | | | 181 |
| RUN | 208 | 207 | 3.0 | | | | | | | 182 |
| ELBOW | -207 | 206 | 30.0 | | | | | | | 183 |

ASME SECTION III CLASS 2 OR ANSI B31.1.8 STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 7300 | 1.000 | 3052. | 3052. | 2550. | 5602. |
| | 7295 | 1.000 | 3052. | 3052. | 2189. | 5241. |
| ELBOW | 7295 | 1.000 | 3052. | 3052. | 2189. | 5241. |
| | 7290 | 1.000 | 3052. | 3052. | 1614. | 4666. |
| RUN | 7290 | 1.000 | 3052. | 3052. | 1614. | 4666. |
| | 7287 | 1.000 | 3052. | 3052. | 1636. | 4689. |
| ELBOW | 7287 | 1.000 | 3052. | 3052. | 1636. | 4689. |
| | 7286 | 1.000 | 3052. | 3052. | 1417. | 4469. |
| RUN | 7286 | 1.000 | 3052. | 3052. | 1417. | 4469. |
| | 7285 | 1.000 | 3052. | 3052. | 1278. | 4331. |
| ELBOW | 7285 | 1.000 | 3052. | 3052. | 1278. | 4331. |
| | 7284 | 1.000 | 3052. | 3052. | 1455. | 4507. |
| RUN | 7284 | 1.000 | 3052. | 3052. | 1455. | 4507. |
| | 7283 | 1.000 | 3052. | 3052. | 1558. | 4611. |
| RUN | 7283 | 1.000 | 3052. | 3052. | 1558. | 4611. |
| | 7282 | 1.000 | 3052. | 3052. | 1700. | 4752. |
| RUN | 7275 | 1.000 | 3052. | 3052. | 1984. | 5036. |
| | 7273 | 1.000 | 3052. | 3052. | 2127. | 5179. |
| RUN | 7273 | 1.000 | 3052. | 3052. | 2127. | 5179. |
| | 7270 | 1.000 | 3052. | 3052. | 2196. | 5248. |
| ELBOW | 7270 | 1.000 | 3052. | 3052. | 2196. | 5248. |
| | 7265 | 1.000 | 3052. | 3052. | 2159. | 5211. |
| RUN | 7265 | 1.000 | 3052. | 3052. | 2159. | 5211. |
| | 7263 | 1.000 | 3052. | 3052. | 718. | 3770. |
| RUN | 7263 | 1.000 | 3052. | 3052. | 718. | 3770. |
| | 7260 | 1.000 | 3052. | 3052. | 1026. | 4078. |
| ELBOW | 7260 | 1.000 | 3052. | 3052. | 1026. | 4078. |
| | 7255 | 1.000 | 3052. | 3052. | 1106. | 4158. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 7255 | 1.000 | 3052. | 3052. | 1106. | 4158. |
| | 7253 | 1.000 | 3052. | 3052. | 2646. | 5698. |
| RUN | 7253 | 1.000 | 3052. | 3052. | 2646. | 5698. |
| | 7250 | 1.000 | 3052. | 3052. | 2680. | 5733. |
| ELBOW | 7250 | 1.000 | 3052. | 3052. | 2680. | 5733. |
| | 7245 | 1.000 | 3052. | 3052. | 1906. | 4958. |
| RUN | 7245 | 1.000 | 3052. | 3052. | 1906. | 4958. |
| | 7240 | 1.000 | 3052. | 3052. | 4305. | 7357. |
| ELBOW | 7240 | 1.000 | 3052. | 3052. | 4305. | 7357. |
| | 7235 | 1.000 | 3052. | 3052. | 5092. | 8144. |
| RUN | 7235 | 1.000 | 3052. | 3052. | 5092. | 8144. |
| | 7230 | 1.000 | 3052. | 3052. | 5122. | 8174. |
| RUN | 7230 | 1.000 | 3052. | 3052. | 5122. | 8174. |
| | 7220 | 1.000 | 3052. | 3052. | 5019. | 8072. |
| RUN | 7220 | 1.000 | 3048. | 3048. | 9177. | 12225. |
| | 7228 | 1.000 | 3048. | 3048. | 8935. | 11983. |
| RUN | 7228 | 1.000 | 3048. | 3048. | 8935. | 11983. |
| | 215 | 1.000 | 3048. | 3048. | 4814. | 7862. |
| RUN | 215 | 1.000 | 3048. | 3048. | 4814. | 7862. |
| | 213 | 1.000 | 3048. | 3048. | 1193. | 4241. |
| RUN | 213 | 1.000 | 3048. | 3048. | 1193. | 4241. |
| | 212 | 1.000 | 3048. | 3048. | 687. | 3735. |
| RUN | 212 | 1.000 | 3048. | 3048. | 687. | 3735. |
| | 211 | 1.000 | 3048. | 3048. | 2840. | 5888. |
| RUN | 211 | 1.000 | 3048. | 3048. | 2840. | 5888. |
| | 210 | 1.000 | 3048. | 3048. | 5927. | 8975. |
| ELBOW | 210 | 1.000 | 3048. | 3048. | 5927. | 8975. |
| | 209 | 1.000 | 3048. | 3048. | 6410. | 9458. |

079T1000008
 126

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 209 | 1.000 | 3048. | 3048. | 6410. | 9458. |
| | 208 | 1.000 | 3048. | 3048. | 6325. | 9373. |
| RUN | 208 | 1.000 | 3048. | 3048. | 6325. | 9373. |
| | 207 | 1.000 | 3048. | 3048. | 6240. | 9287. |
| ELBOW | 207 | 1.000 | 3048. | 3048. | 6240. | 9287. |
| | 206 | 1.000 | 3048. | 3048. | 4905. | 7952. |
| RUN | 206 | 1.000 | 3048. | 3048. | 4905. | 7952. |
| | 197 | 1.000 | 3048. | 3048. | 1098. | 4146. |
| RUN | 197 | 1.000 | 3048. | 3048. | 1098. | 4146. |
| | 205 | 1.000 | 3048. | 3048. | 919. | 3967. |
| ELBOW | 205 | 1.000 | 3048. | 3048. | 919. | 3967. |
| | 204 | 1.000 | 3048. | 3048. | 470. | 3518. |
| RUN | 204 | 1.000 | 3048. | 3048. | 470. | 3518. |
| | 203 | 1.000 | 3048. | 3048. | 2908. | 5956. |
| ELBOW | 203 | 1.000 | 3048. | 3048. | 2908. | 5956. |
| | 202 | 1.000 | 3048. | 3048. | 2424. | 5472. |
| RUN | 202 | 1.000 | 3048. | 3048. | 2424. | 5472. |
| | 201 | 1.000 | 3048. | 3048. | 1879. | 4927. |
| RUN | 201 | 1.000 | 3048. | 3048. | 1879. | 4927. |
| | 200 | 1.000 | 3048. | 3048. | 1582. | 4630. |
| ELBOW | 200 | 1.000 | 3048. | 3048. | 1582. | 4630. |
| | 198 | 1.000 | 3048. | 3048. | 2065. | 5113. |
| RUN | 198 | 1.000 | 3048. | 3048. | 2065. | 5113. |
| | 195 | 1.000 | 3048. | 3048. | 1554. | 4602. |
| RUN | 195 | 1.000 | 3048. | 3048. | 1554. | 4602. |
| RUN | 7220 | 1.000 | 3052. | 3052. | 2991. | 6043. |
| | 2225 | 1.000 | 3052. | 3052. | 2862. | 5914. |
| RUN | 2225 | 1.000 | 3052. | 3052. | 2862. | 5914. |
| | 2224 | 1.000 | 3052. | 3052. | 2406. | 5459. |

079T1000008
 127

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 2224 | 1.000 | 3052. | 3052. | 2406. | 5459. |
| | 2222 | 1.000 | 3052. | 3052. | 2027. | 5079. |
| RUN | 2222 | 1.000 | 3052. | 3052. | 2027. | 5079. |
| | 2220 | 1.000 | 3052. | 3052. | 1898. | 4951. |
| RUN | 2220 | 1.000 | 3048. | 3048. | 12364. | 15412. |
| | 2217 | 1.000 | 3048. | 3048. | 11757. | 14805. |
| RUN | 2217 | 1.000 | 3048. | 3048. | 11757. | 14805. |
| | 2216 | 1.000 | 3048. | 3048. | 11257. | 14305. |
| RUN | 2216 | 1.000 | 3048. | 3048. | 11257. | 14305. |
| | 2210 | 1.000 | 3048. | 3048. | 5679. | 8727. |
| | 2205 | 1.000 | 3048. | 3048. | 6107. | 9155. |
| ELBOW | 2205 | 1.000 | 3048. | 3048. | 6107. | 9155. |
| | 2204 | 1.000 | 3048. | 3048. | 8896. | 11944. |
| RUN | 2204 | 1.000 | 3048. | 3048. | 8896. | 11944. |
| | 6203 | 1.000 | 3048. | 3048. | 9026. | 12074. |
| RUN | 6203 | 1.000 | 3048. | 3048. | 9026. | 12074. |
| | 2203 | 1.000 | 3048. | 3048. | 9156. | 12204. |
| | 2202 | 1.000 | 3048. | 3048. | 7662. | 10710. |
| RUN | 2202 | 1.000 | 3048. | 3048. | 7662. | 10710. |
| | 2209 | 1.000 | 3048. | 3048. | 6079. | 9127. |
| RUN | 2209 | 1.000 | 3048. | 3048. | 6079. | 9127. |
| | 2201 | 1.000 | 3048. | 3048. | 6508. | 9556. |
| ELBOW | 2201 | 1.000 | 3048. | 3048. | 6508. | 9556. |
| | 2200 | 1.000 | 3048. | 3048. | 7998. | 11046. |
| RUN | 2199 | 1.000 | 3048. | 3048. | 4996. | 8044. |

ASME SECTION III CLASS 2 OR ANSI B31.1.8 STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| ELBOW | 2199 | 1.000 | 3048. | 3048. | 4996. | 8044. |
| | 2198 | 1.000 | 3048. | 3048. | 2203. | 5250. |
| RUN | 2198 | 1.000 | 3048. | 3048. | 2203. | 5250. |
| | 2207 | 1.000 | 3048. | 3048. | 1775. | 4823. |
| RUN | 2207 | 1.000 | 3048. | 3048. | 1775. | 4823. |
| | 2197 | 1.000 | 3048. | 3048. | 10244. | 13292. |
| ELBOW | 2197 | 1.000 | 3048. | 3048. | 10244. | 13292. |
| | 2195 | 1.000 | 3048. | 3048. | 13042. | 16090. |
| RUN | 2220 | 1.000 | 3052. | 3052. | 887. | 3939. |
| | 2221 | 1.000 | 3052. | 3052. | 971. | 4023. |
| REDUCE | 2221 | 2.000 | 3048. | 3048. | 8760. | 11808. |
| | 3230 | 2.000 | 3048. | 3048. | 9389. | 12437. |
| ELBOW | 3230 | 1.000 | 3048. | 3048. | 4695. | 7743. |
| | 3228 | 1.000 | 3048. | 3048. | 3910. | 6958. |
| RUN | 3228 | 1.000 | 3048. | 3048. | 3910. | 6958. |
| | 3225 | 1.000 | 3048. | 3048. | 10924. | 13972. |
| ELBOW | 3225 | 1.000 | 3048. | 3048. | 10924. | 13972. |
| | 3220 | 1.000 | 3048. | 3048. | 11691. | 14739. |
| RUN | 3220 | 1.000 | 3048. | 3048. | 11691. | 14739. |
| | 3215 | 1.000 | 3048. | 3048. | 5704. | 8752. |
| ELBOW | 3215 | 1.000 | 3048. | 3048. | 5704. | 8752. |
| | 3210 | 1.000 | 3048. | 3048. | 2146. | 5194. |
| RUN | 3210 | 1.000 | 3048. | 3048. | 2146. | 5194. |
| | 3208 | 1.000 | 3048. | 3048. | 2579. | 5627. |
| RUN | 3208 | 1.000 | 3048. | 3048. | 2579. | 5627. |
| | 3207 | 1.000 | 3048. | 3048. | 6110. | 9158. |
| RUN | 3207 | 1.000 | 3048. | 3048. | 6110. | 9158. |
| | 3205 | 1.000 | 3048. | 3048. | 12618. | 15666. |

079T1000008
129

30 MW SOLAR CAPSIZO PLANT
MAIN STEAM PIPE DESIGN CONDITION
JSG 11-1-82

John Gagan
11/09/82
079TI000008
131

T-G INLET MAX OPERATING PRESSURE 1450 PSIG, 1465 PSIA
1000°F
1491.2 H

MAIN STEAM LINE PRESSURE DROP 50 PSI
TEMPERATURE DROP 3°F

STEAM GENERATOR OUTLET
MAX OPERATING PRESSURE 1500 PSIG, 1515 PSIA
1003°F
1491.3 H

MAIN STEAM PIPE DESIGN

MAX OPERATING PRESSURE + 5% MARGIN BELOW
SAFETY VALVE SET PRESSURE

$$1500 + 75 = 1575 \text{ PSIG}$$

STEAM GENERATOR OUTLET SAFETY VALVE SETTING 1575 PSIG

MAX OPERATING TEMPERATURE 1003°F

1500 SPECIAL CLASS VALVE PER B16.34-81 AT 1575 PSIG
ALLOWABLE = 1011°F
∴ DESIGN = 1010°F

DESIGN 1575 PSIG
1010°F
(USE SPECIAL CLASS 1500 VALVE)

1015°F
DESIGN

TABLE 1
LIST OF MATERIAL SPECIFICATIONS
 Applicable ASTM Specifications

| Group 1 Materials | | | | | | | | | | | |
|--------------------|--------------------------------|-----------------------|--------|-------------------------------------|--------|--|------------|--|-------------------------|--|------------|
| Material Group No. | Nominal Designation Steel | Forgings | | Castings | | Plates | | Bars and Shapes | | Tubular Products | |
| | | Spec.-Grade | Notes | Spec.-Grade | Notes | Spec.-Grade | Notes | Spec.-Grade | Notes | Spec.-Grade | Notes |
| 1.1 | Carbon | A 105 A 350-LF2 | (1)(3) | A 216-WCB | (1) | A 515-70 A 516-70 | (1) (1) | A 105 A 350-LF2 A 675-70 A 696 Gr.B | (1)(3) (1)(8)(5) | A 672-B70 A 672-C70 | |
| 1.2 | C-Mn-Si Carbon | | | A 216-WCC | (1) | A 537 Cl.1 | | | | A 106-C | (1) |
| 1.3 | 2-1/2 Ni 3-1/2 Ni Carbon | A 350-LF3 | | A 352-LC2 A 352-LC3 A 352-LCB | | A 203-B A 203-E A 515-65 A 516-65 | | A 350-LF3 A 675-65 | (1)(8)(5) | A 672-B65 A 672-C65 | |
| 1.4 | 2-1/2 Ni 3-1/2 Ni Carbon | A 350-LF1 | | | | A 203-A A 203-D A 515-60 A 516-60 | (1) | A 675-60 A 350-LF1 A 696 Gr.C | (1)(5) | A 106-B A 672-B60 A 672-C60 A 691-CM70 | (1) |
| 1.5 | C-1/2 Mo | A 182-F1 | (2) | A 217-WC1 A 352-LC1 | (2)(4) | A 204-A A 204-B | (2) (2) | A 182-F1 | (2) | | |
| 1.6 | C-1/2 Mo | | | | | | | | | A 335-P1 A 369-FP1 | (2) (2) |
| | 1/2 Cr-1/2 Mo | | | | | A 387-2 Cl.1 A 387-2 Cl.2 | | | | A 691-1/2 CR | |
| 1.7 | 1 Cr-1/2 Mo C-1/2 Mo | | | | | A 387-12 Cl.1 A 204-C | (2) | | | A 691-CM75 | |
| | 1/2 Cr-1/2 Mo | A 182-F2 | | | | | | A 182-F2 | | | |
| | Ni-Cr-1/2 Mo | | | A 217-WC4 | (4) | | | | | | |
| 1.8 | Ni-Cr-1 Mo 1 Cr-1/2 Mo | | | A 217-WC5 | (4) | A 387-12 Cl.2 | | | | A 691-1 CR A 335-P12 A 369-FP12 | (4) |
| | 1-1/4 Cr-1/2 Mo | | | | | A 387-11 Cl.1 | | | | A 691-1-1/4 CR A 335-P11 A 369-FP11 | |
| | 2-1/4 Cr-1 Mo | | | | | A 387-22 Cl.1 | | | | A 691-2-1/4 CR A 335-P22 A 369-FP22 | |
| 1.9 | 1 Cr-1/2 Mo | A 182-F12 | (4) | | | | | A 182-F12 | (4) | | |
| | 1-1/4 Cr-1/2 Mo | A 182-F11 | (4) | A 217-WC6 | (4) | A 387-11 Cl.2 | | A 182-F11 A 739-B11 | (4) | | |
| 1.10 | 2-1/4 Cr-1 Mo | A 182-F22 | | A 217-WC9 | (4) | A 387-22 Cl.2 | | A 182-F22 A 739-B22 | | | |
| 1.11 | 3 Cr-1 Mo | A 182-F21 | | | | A 387-21 Cl.2 | | A 182-F21 | | | |
| | Mn-1/2 Mo | | | | | A 302-A & B A 302-C & D | (2) (2) | | | | |
| 1.12 | Mn-Si 5 Cr-1/2 Mo | | | | | A 537 Cl.2 A 387-5 Cl.1 A 387-5 Cl.2 | | | | A 691-5 CR A 335-P5 A 335-P5b A 369-FP5 | |
| 1.13 | 5 Cr-1/2 Mo | A 182-F5a A 182-F5 | | A 217-C5 | (4) | | | A 182-F5a A 182-F5 | | | |
| 1.14 | 9 Cr-1 Mo | A 182-F9 | | A 217-C12 | (4) | | | A 182-F9 | | | |

See Notes on p. 21.

AMERICAN NATIONAL STANDARD
 VALVES - FLANGED AND BUTTWELDING END

ANSI B16.34-1981

07911000008
 132

TABLE 2-1.10
RATINGS FOR GROUP 1.10 MATERIALS

A 182-F22(c) A 217-WC9(j) A 387-22 Cl.2(c) A 739-B22(c)

NOTES:

(c) Permissible, but not recommended for prolonged usage above about 1100° F.

(j) Not to be used over 1100° F.

TABLE 2-1.10A - STANDARD CLASS VALVES - FLANGED AND BUTTWELDING END

| Temperature, °F | Working Pressure by Classes, psig | | | | | | | |
|-----------------|-----------------------------------|-----|------|------|------|------|------|-------|
| | 150 | 300 | 400 | 600 | 900 | 1500 | 2500 | 4500 |
| -20 to 100 | 290 | 750 | 1000 | 1500 | 2250 | 3750 | 6250 | 11250 |
| 200 | 260 | 715 | 955 | 1430 | 2150 | 3580 | 5965 | 10740 |
| 300 | 230 | 675 | 905 | 1355 | 2030 | 3385 | 5640 | 10150 |
| 400 | 200 | 650 | 865 | 1295 | 1945 | 3240 | 5400 | 9720 |
| 500 | 170 | 640 | 855 | 1280 | 1920 | 3200 | 5330 | 9595 |
| 600 | 140 | 605 | 805 | 1210 | 1815 | 3025 | 5040 | 9070 |
| 650 | 125 | 590 | 785 | 1175 | 1765 | 2940 | 4905 | 8825 |
| 700 | 110 | 570 | 755 | 1135 | 1705 | 2840 | 4730 | 8515 |
| 750 | 95 | 530 | 710 | 1065 | 1595 | 2660 | 4430 | 7970 |
| 800 | 80 | 510 | 675 | 1015 | 1525 | 2540 | 4230 | 7610 |
| 850 | 65 | 485 | 650 | 975 | 1460 | 2435 | 4060 | 7305 |
| 900 | 50 | 450 | 600 | 900 | 1350 | 2245 | 3745 | 6740 |
| 950 | 35 | 380 | 505 | 755 | 1130 | 1885 | 3145 | 5660 |
| 1000 | 20 | 270 | 355 | 535 | 805 | 1340 | 2230 | 4010 |
| 1050 | 20(1) | 200 | 265 | 400 | 595 | 995 | 1660 | 2985 |
| 1100 | 20(1) | 115 | 150 | 225 | 340 | 565 | 945 | 1700 |
| 1150 | 20(1) | 105 | 140 | 205 | 310 | 515 | 860 | 1545 |
| 1200 | 20(1) | 55 | 75 | 110 | 165 | 275 | 460 | 825 |

NOTE:

(1) For welding end valves only. Flanged end ratings terminate at 1000° F.

TABLE 2-1.10B - SPECIAL CLASS BUTTWELDING END VALVES ONLY

| Temperature, °F | Working Pressure by Classes, psig | | | | | | | |
|-----------------|-----------------------------------|-----|------|------|------|------|------|-------|
| | 150 | 300 | 400 | 600 | 900 | 1500 | 2500 | 4500 |
| -20 to 100 | 290 | 750 | 1000 | 1500 | 2250 | 3750 | 6250 | 11250 |
| 200 | 290 | 750 | 1000 | 1500 | 2250 | 3750 | 6250 | 11250 |
| 300 | 290 | 750 | 1000 | 1500 | 2250 | 3750 | 6250 | 11250 |
| 400 | 290 | 750 | 1000 | 1500 | 2250 | 3750 | 6250 | 11250 |
| 500 | 285 | 740 | 985 | 1475 | 2210 | 3685 | 6145 | 11060 |
| 600 | 285 | 740 | 985 | 1475 | 2210 | 3685 | 6145 | 11060 |
| 650 | 285 | 740 | 985 | 1475 | 2210 | 3685 | 6145 | 11060 |
| 700 | 280 | 735 | 980 | 1465 | 2200 | 3665 | 6110 | 10995 |
| 750 | 280 | 730 | 970 | 1460 | 2185 | 3645 | 6070 | 10930 |
| 800 | 275 | 720 | 960 | 1440 | 2160 | 3600 | 6000 | 10800 |
| 850 | 260 | 680 | 905 | 1355 | 2030 | 3385 | 5645 | 10160 |
| 900 | 230 | 600 | 800 | 1200 | 1800 | 3000 | 5000 | 9000 |
| 950 | 180 | 470 | 630 | 945 | 1415 | 2360 | 3930 | 7070 |
| 1000 | 130 | 335 | 445 | 670 | 1005 | 1670 | 2785 | 5015 |
| 1050 | 95 | 250 | 330 | 500 | 745 | 1245 | 2070 | 3730 |
| 1100 | 55 | 140 | 190 | 265 | 425 | 710 | 1180 | 2120 |
| 1150 | 50 | 130 | 170 | 260 | 385 | 645 | 1070 | 1930 |
| 1200 | 25 | 70 | 90 | 140 | 205 | 345 | 570 | 1030 |

Steam Piping for 30MW Solar

MADE BY RNDrumy DATE 10/22/82 CHECKED BY _____

APPROVED BY _____

Valves are ANST 2500 lb class

| valve size | valve weight (lb) | actuator weight | notes |
|------------|-------------------|-----------------|-----------------------------|
| 2 | | | gate valves |
| 2½ | 100 | | |
| 3 | 170 | | |
| 4 | 335 | | |
| 6 | 840 | | |
| 8 | 1440 | | |
| 10 | 2490 | | |
| 2 | | n.g. | check valves - tilting disk |
| 2½ | | | |
| 3 | 425 | | |
| 4 | 450 | | |
| 6 | 600 | | |
| 8 | 1200 | | |
| 10 | 2100 | | |
| 2 | | | stop check valves y pattern |
| 2½ | 175 | | |
| 3 | 405 | | |
| 4 | 600 | | |
| 6 | 980 | | |
| 8 | 1700 | | |
| 10 | 3500 | | |

based on Crane Valve catalog

SUBJECT _____

MADE BY RMDruy DATE 11/3/82 CHECKED BY _____ APPROVED BY _____

For steam at 1575 psig and 1010°F $v = 0.5166 \text{ ft}^3/\text{lbm}$

Main Steam Header $W = 269730 \text{ lb/hr}$ of steam

10" pipe velocity = 112 ft/sec $\Delta p = 5.56 \text{ psi/100ft}$ of pipe
 8" 176 17.1

Steam Line from Sodium Heat Exchanger $W = 89910 \text{ lb/hr}$

6" pipe velocity = 101 ft/sec $\Delta p = 7.35 \text{ psi/100ft}$ of pipe
 4" 238 63.1

Insulation Weight for Steam Piping
 assumes 14 lb/ft^3 Calcium Silicate with $0.016''$ smooth
 aluminum finish

| nominal pipe size | Insulation Thickness | lb/ft of pipe |
|-------------------|----------------------|---------------|
| 2 | 5.0 | 12.0 |
| 2½ | 5.0 | 12.8 |
| 3 | 5.5 | 16.0 |
| 4 | 6.0 | 20.2 |
| 6 | 6.0 | 24.2 |
| 8 | 6.5 | 31.3 |
| 10 | 7.0 | 39.4 |

Use 1500 lb. Special Class valves or 2500 lb Standard Class
 valves

Pipe Sizing for Main Steam Lines -- 30MW Solar

MADE BY RVDrury DATE 1/1/82

CHECKED BY _____

APPROVED BY _____

Main Steam Header

269730 lb/hr of steam

$P = 1515 \text{ psia}$

$T = 1003^\circ \text{F}$

$v = 0.5352 \text{ ft}^3/\text{lb}$

for 10" pipe steam velocity = 133 ft/sec

$\Delta P_{100} = 8.836 \text{ psi}/100\text{ft}$

8" pipe steam velocity = 16 ft/sec

$\Delta P_{100} = 27.221$

Steam Line from Sodium Heat Exchanger

89910 lb/hr of steam

for 6" pipe steam velocity = 101.5 ft/sec

$\Delta P_{100} = 12.60 \text{ psi}/100\text{ft}$

4" pipe steam velocity = 214.6 ft/sec

$\Delta P_{100} = 106.59 \text{ psi}/100\text{ft}$

Insulation Weight for Steam Piping

based on 14 lb/ft³ Calcium Silicate with 0.016 smooth aluminum finish

| nominal pipe size | Insulation Thickness | lb/ft of pipe |
|-------------------|----------------------|---------------|
| 2 | 5.0 | 12.0 |
| 2½ | 5.0 | 12.8 |
| 3 | 5.5 | 16.0 |
| 4 | 6.0 | 20.2 |
| 6 | 6.0 | 24.2 |
| 8 | 6.5 | 31.3 |
| 10 | 7.0 | 39.4 |

Thickness based on proposed Potrero 7 Standard

Main Steam Piping for 30MW Solar

by P. Drury DATE 11/3/82 CHECKED BY _____ APPROVED BY _____

Design Conditions: 1575 psig
 1010 °F

Piping Material: 2 1/4 Cr-1 Mo seamless pipe, ANSI A 335
 Grade P22. Supplementary requirements
 S1 to S4 and full ultrasonic test on pipe
 2 1/2" and over.

Maximum allowable stress = 7400 psi

Allowable stress reduced to 0.9 due to cyclic loading
 of pipe (>10,000 cycles over 30 year plant life, both thermal,
 pressure, and dead load)

Allowable stress = 6660 psi

Corrosion allowance = 0.0625" (1/16")

$\gamma = 0.4$

$$t_{min} = \frac{P D_o}{2(SE + P\gamma)} + A$$

= 0.1080 D_o + 0.0625

$$t_{reqd} = \frac{t_{min}}{0.875}$$

| nominal pipe size | D _o | minimum wall (in) | required nominal wall (in) | use | id | flow area (in ²) |
|----------------------|----------------|----------------------|----------------------------------|--------------|-------|---------------------------------|
| 2 | 2.375 | 0.319 | 0.365 | XXS | 1.503 | 1.774 |
| 2 1/2 | 2.875 | 0.373 | 0.426 | XXS | 1.771 | 2.464 |
| 3 | 3.500 | 0.441 | 0.504 | XXS | 2.300 | 4.15 |
| 4 | 4.500 | 0.549 | 0.627 | XXS | 3.152 | 7.80 |
| 6 | 6.625 | 0.778 | 0.889 | fabricated * | 4.846 | 18.45 |
| 8 | 8.625 | 0.994 | 1.136 | fabricated | 6.353 | 31.69 |
| 10 | 10.750 | 1.224 | 1.400 | fabricated | 7.953 | 49.67 |

* = standard pipe size and wall exists heavier than this

GENERAL COMPUTATION SHEET

Stream Piping for 30 MW Solar Plant

079TI000008
138

RM Drury DATE 1/1/82

CHECKED BY

APPROVED BY

Design Conditions: 1575 psig
1050°F

Piping Material 2 1/4 Cr-1 Mo seamless pipe ANSI A335, Grade P22. Supplementary requirements S1 to S4 and full ultrasonic test on pipe 2 1/2" and over

Maximum allowable stress = 5800 psi at 1050°F

Allowable stress reduced to 0.9 due to thermal cycling (> 10,000 cycles over 30 year plant life)

Allowable stress = 5220 psi

Corrosion allowance = 0.0625

$\gamma = 0.4$

$$t_{min} = \frac{PD_0}{2(SE + Py)} + A$$

$$= 0.135 D_0 + 0.0625$$


$$t_{corr} = \frac{t_{min}}{0.875}$$

| Nominal Pipe Size | O D | minimum wall (in) | minimum nominal wall (in) | notes | ID | flow area (in ²) |
|-------------------|--------|-------------------|---------------------------|-------------|-------|------------------------------|
| 2 | 2.375 | 0.382 | 0.437 | XXS pipe | 1.503 | 1.774 |
| 2 1/2 | 2.875 | 0.450 | 0.514 | XXS pipe | 1.771 | 2.46 |
| 3 | 3.500 | 0.534 | 0.610 | fabricated* | 2.280 | 5.54 |
| 4 | 4.500 | 0.668 | 0.764 | fabricated* | 2.972 | 8.97 |
| 6 | 6.625 | 0.954 | 1.091 | fabricated* | 4.443 | 18.97 |
| 8 | 8.625 | 1.224 | 1.398 | fabricated | 5.829 | 26.69 |
| 10 | 10.750 | 1.510 | 1.725 | fabricated | 7.300 | 31.65 |

* A standard pipe wall thickness is listed in excess of the minimum nominal wall. Cost should be considered as it will probably be specially fabricated in either case.



APPENDIX 6.2
INPUT AND OUTPUT DATA FOR STEAM GENERATOR
PUMP DISCHARGE AND CONNECTED PIPING



| REVISIONS | | | |
|-----------|-------------|------|----------|
| LTR | DESCRIPTION | DATE | APPROVED |
| | | | |

FIGURE 3

| | | | | | |
|-----------|--|--------|--|--|----------------------|
| DR BY KCG | | 7-4-83 | | Rockwell International Corporation Atomics International Division | |
| CHK BY | | | | | |
| M & P | | | | SIZE B | CODE IDENT NO. 09974 |
| STRESS | | | | SCALE | DRAWING NO. |
| | | | | SHEET 1 OF 1 | |


| | | |
|------------------|--|-------------|
| PREPARED BY: KCG |  Rockwell International Energy Systems Group | 141 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 2/24/85 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | T-1 Cold Tank Inlet | REFERENCE | | |
|---------------------------------------|----------------------------|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0033-10-HBDA | | | |
| Design Temperature | 650° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 10.75 / Sch 40 | | | |
| Pipe Thickness x | 0.365 | | | |
| Pipe Material | CS | | | |
| Insulation Type | | | | |
| Weight of Pipe Lbs / Ft | 40.48 | | | |
| Weight of contents Lbs / Ft | 0.9 x 34.1 = 30.69 | | | |
| Weight of Insulation Lbs / Ft | - | | | |
| Total Weight ^x Lbs / Ft | 71.2 | | | |
| E _c ^x | 27.9 x 10 ⁶ psi | | | |
| Seismic Category | I | | | |


| | | |
|-------------------------|--|-------------|
| PREPARED BY: <u>KCS</u> |  Rockwell International Energy Systems Group | 142 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <u>7/24/83</u> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | Steam Generator Pump Discharge | REFERENCE | | |
|-------------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0026-10-GCDA 0083-10-GCDA 0084-10-GCDA | | | |
| Design Temperature | 1100° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1100° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 10.75" / sch. 40 | | | |
| Pipe Thickness x | 0.365" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | Cal. Silicate 6" thick | | | |
| Weight of Pipe LBS/FT | 40.48 lbs / ft | | | |
| Weight of Contents LBS/ft | 0.9 x 34.1 = 30.69 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} (22.75^2 - 10.75^2) \frac{14}{144}$ = 30.7 | | | |
| Total Weight ^x LBS/ft | 101.9 lbs / ft. | | | |
| E _c ^x | 28.3 x 10 ⁶ psi | | | |
| Seismic Category | II | | | |


| | | |
|-------------------------|--|-------------|
| PREPARED BY: <i>KCS</i> |  Rockwell International Energy Systems Group | 143 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <i>3/24/83</i> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | Steam Gen. Pump Discharge Emergency Drain | REFERENCE | | |
|--------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 003B-8-GEDA | | | |
| Design Temperature | 1100° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1055° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 8.625 / sch 40 | | | |
| Pipe Thickness x | 0.322 | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe LBS/FT | 28.55 | | | |
| Weight of contents LBS/ft | 19 x 21.69 = 19.5 | | | |
| Weight of Insulation LBS/ft | - | | | |
| Total Weight LBS/ft | 48.1 | | | |
| E_e^x | 28.3×10^6 psi | | | |
| Seismic Category | I | | | |



| | | |
|-------------------------|--|-------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 144 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <u>2/24/82</u> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | By pass | REFERENCE | | |
|--------------------------------|------------------------|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0095-4-HBDA | | | |
| Design Temperature | 610°F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610°F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 4.5/sch 40 | | | |
| Pipe Thickness x | 0.237 | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | | | | |
| Weight of Pipe LBS/FT | 10.79 | | | |
| Weight of contents LBS/ft | 5.51 x .9 = 4.96 | | | |
| Weight of Insulation LBS/ft | - | | | |
| Total Weight LBS/ft | 15.7 | | | |
| E_e^x | 28.3×10^6 psi | | | |
| Seismic Category | <u>III</u> | | | |




| | |
|--|------------------------|
| PREPARED BY: KCR | DATE: 2/24/83 |
| CHECKED BY: | |
|  Rockwell International Energy Systems Group | |
| MODEL NO. | REPORT NO. 079T1000008 |
| PAGE NO. 145 | OF |

TABLE B-2
THERMAL OPERATION MODES

| Mode Number | Type | Description | Temp. OF | Applicable Section | | Ex 10 ⁶ Psi | $\alpha \Delta T$ in/ft. | |
|-------------|------|------------------|-------------|--------------------|-----------|---------------------------|-----------------------------|---------|
| | | | | XNDF | From Node | | | To Node |
| I | N | Normal operating | 1 | 1100 | 5 | 30 | 21.8 | .1284 |
| | | | 2 | } | 30 | 85 | } | } |
| | | | 3 | | 85 | 140 | | |
| | | | 4 | } | 140 | 165 | } | } |
| | | | 5 | | 85 | 390 | | |
| | | | 6 | | 400 | 230 | | |
| | | | 7 | } | 140 | 230 | } | } |
| | | | 8 | | 230 | 460 | | |
| | | | 9 | 650 | 460 | 680 | 25.25 | .05115 |
| | | | 10 | } | 460 | 485 | } | } |
| | | | 11 | | 485 | 500-530 | | |
| | | | 12 | 530 | 550 | | | |
| | | | 13 | 400 | 485 | 565-530 | 27.0 | .0270 |
| | | | | | | | | |
| | | | | | | | | |

Notes:

- N = Normal Operating Condition
- U = Upset Operating Condition
- T = Testing Condition
- E = Emergency condition
- F = Faulted Condition
- D = Design Condition


| | | |
|-------------------------|---|--------------------------------|
| PREPARED BY: <u>KC9</u> |  | 147 |
| CHECKED BY: | | PAGE NO. <u>079TI000008</u> OF |
| DATE: <u>2/24/83</u> | | REPORT NO. |
| | | MODEL NO. |

TABLE B-2
THERMAL OPERATION MODES

| Mode Number | Type | Description | Temp. °F | Applicable Section | | Ex 10 ⁶ Psi | α ΔT in./ft. | |
|-------------|------|--|-------------|--------------------|-----------|---------------------------|-----------------|---------|
| | | | | XNOP | From Node | | | To Node |
| 2 | | Pump 2B down. line at ambient | 1 | 1100 | 5 | 30 | 21.8 | .1284 |
| | | | 2 | 1100 | 30 | 85 | 21.8 | .1284 |
| | | | 3 | 70 | 85 | 140 | 28.3 | 0 |
| | | | 4 | 70 | 140 | 165 | 28.3 | 0 |
| | | | 5 | 1100 | 85 | 390 | 21.8 | .1284 |
| | | | 6 | 400 | 30 | 230 | 26.6 | .0380 |
| | | | 7 | ↵ | 140 | 230 | ↵ | ↵ |
| | | | 8 | ↓ | 230 | 460 | ↓ | ↓ |
| | | | 9 | 650 | 460 | 680 | 25.25 | .05115 |
| | | | 10 | ↵ | 460 | 485 | ↵ | ↵ |
| | | | 11 | ↵ | 485 | 500-530 | ↵ | ↵ |
| | | | 12 | ↓ | 530 | 550 | ↓ | ↓ |
| | | | 13 | 400 | 485 | 565-530 | 27.0 | .0270 |
| | | | | | | | | |
| | | | | | | | | |

Notes:

- N = Normal Operating Condition
- U = Upset Operating Condition
- T = Testing Condition
- E = Emergency condition
- F = Faulted Condition
- D = Design Condition


| | | |
|-------------------------|--|-------------|
| PREPARED BY: <i>KCS</i> |  | 148 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <i>2/24/83</i> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-2
THERMAL OPERATION MODES

| Mode Number | Type | Description | XNOP | Temp. OF | Applicable Section | | Ex 10 ⁶ Psi | $\alpha \Delta T$ in/ft. |
|-------------|------|---------------------------|------|-------------|--------------------|---------|---------------------------------|-----------------------------|
| | | | | | From Node | To Node | | |
| 3 | F | Hot drain thru both loops | 1 | 1100 | 5 | 30 | 21.8 | .1284 |
| | | | 2 | 400 | 30 | 85 | 26.6 | .0380 |
| | | | 3 | 400 | 85 | 140 | 26.6 | .0380 |
| | | | 4 | 1100 | 140 | 165 | 21.8 | .1284 |
| | | | 5 | 400 | 85 | 390 | 26.6 | .0380 |
| | | | 6 | 1100 | 30 | 230 | 26.6 ^{21.8} | .1284 |
| | | | 7 | | 140 | 230 | | |
| | | | 8 | | 230 | 460 | | |
| | | | 9 | | 460 | 680 | 23.4 | .1004 |
| | | | 10 | 650 | 460 | 485 | 25.25 | .05115 |
| | | | 11 | | 485 | 500-530 | | |
| | | | 12 | | 530 | 550 | | |
| | | | 13 | 400 | 485 | 565-530 | 27.0 | .0270 |
| | | | | | | | | |
| | | | | | | | | |

Notes:

- N = Normal Operating Condition
- U = Upset Operating Condition
- T = Testing Condition
- E = Emergency condition
- F = Faulted Condition
- D = Design Condition

TABLE B-2
THERMAL OPERATION MODES

| Mode Number | Type | Description | Temp. OF | Applicable Section | | EX 10 ⁶ Psi | α ΔT in/ft. | |
|-------------|------|--|-------------|--------------------|---------|---------------------------|----------------|--------|
| | | | | From Node | To Node | | | |
| 4 | F | Hot drain thru one loop V-022 B Closed | 1 | 1100 | 5 | 30 | 21.8 | .1284 |
| | | | 2 | 400 | 30 | 85 | 26.6 | .0380 |
| | | | 3 | ↙ | 85 | 140 | ↙ | ↙ |
| | | | 4 | ↘ | 140 | 165 | ↘ | ↘ |
| | | | 5 | ↓ | 85 | 390 | ↓ | ↓ |
| | | | 6 | 1100 | 30 | 230 | 21.8 | .1284 |
| | | | 7 | 400 | 140 | 230 | 26.6 | .0380 |
| | | | 8 | 1100 | 230 | 460 | 21.8 | .1284 |
| | | | 9 | 1100 | 460 | 680 | 23.4 | .1004 |
| | | | 10 | 650 | 460 | 485 | 25.25 | .05115 |
| | | | 11 | ↙ | 485 | 500-530 | ↙ | ↙ |
| | | | 12 | ↓ | 530 | 550 | ↓ | ↓ |
| | | | 13 | 450 | 485 | 565-530 | 27.0 | .0270 |
| | | | | | | | | |
| | | | | | | | | |

Notes:

- N = Normal Operating Condition
- U = Upset Operating Condition
- T = Testing Condition
- E = Emergency condition
- F = Faulted Condition
- D = Design Condition


| | | |
|-------------------------|--|----------------------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 150 |
| CHECKED BY: | | PAGE NO. OF 079TI000008 |
| DATE: <u>3/24/83</u> | | REPORT NO. 1 |
| | | MODEL NO. |

TABLE B-2
THERMAL OPERATION MODES

| Mode Number | Type | Description | XNOP | Temp. OF | Applicable Section | | EX 10 ⁶ psi | $\alpha \Delta T$ in/ft. |
|-------------|------|--|------|----------|--------------------|---------|------------------------|--------------------------|
| | | | | | From Node | To Node | | |
| 5 | F | Hot drain thru one loop V-022 A closed | 1 | 400 | 5 | 30 | 26.6 | .0380 |
| | | | 2 | ↓ | 30 | 85 | ↓ | ↓ |
| | | | 3 | | 85 | 140 | | |
| | | | 4 | 1100 | 140 | 165 | 21.8 | .1284 |
| | | | 5 | 400 | 85 | 390 | 26.6 | .0380 |
| | | | 6 | 400 | 30 | 230 | 26.6 | .0380 |
| | | | 7 | 1100 | 140 | 230 | 21.8 | .1284 |
| | | | 8 | 1100 | 230 | 460 | 21.8 | .1284 |
| | | | 9 | 1100 | 460 | 680 | 23.4 | .1004 |
| | | | 10 | 650 | 460 | 485 | 25.3 | .05115 |
| | | | 11 | ↓ | 485 | 500-530 | ↓ | ↓ |
| | | | 12 | | 530 | 550 | | |
| | | | 13 | 450 | 485 | 565-530 | 27.0 | .0270 |
| | | | | | | | | |
| | | | | | | | | |

Notes:

- N = Normal Operating Condition
- U = Upset Operating Condition
- T = Testing Condition
- E = Emergency condition
- F = Faulted Condition
- D = Design Condition

TABLE B-2
THERMAL OPERATION MODES

| Mode Number | Type | Description | XNOP | Temp. OF | Applicable Section | | Ex 10 ⁶ psi | α ΔT in/ft. |
|-------------|------|----------------------------------|------|----------|--------------------|---------|------------------------|-------------|
| | | | | | From Node | To Node | | |
| 6 | | Startup Valve FV040 & FV018 open | 1 | 1100 | 5 | 30 | 21.8 | .0380 |
| | | | 2 | ↙ | 30 | 85 | ↙ | ↙ |
| | | | 3 | ↙ | 85 | 140 | ↙ | ↙ |
| | | | 4 | ↙ | 140 | 165 | ↙ | ↙ |
| | | | 5 | ↓ | 85 | 390 | ↓ | ↓ |
| | | | 6 | 400 | 30 | 230 | 26.6 | .0380 |
| | | | 7 | ↙ | 140 | 230 | ↙ | ↙ |
| | | | 8 | ↓ | 230 | 460 | ↓ | ↓ |
| | | | 9 | 650 | 460 | 680 | 25.25 | .05115 |
| | | | 10 | ↙ | 460 | 485 | ↙ | ↙ |
| | | | 11 | ↙ | 485 | 500-530 | ↙ | ↙ |
| | | | 12 | ↙ | 530 | 550 | ↙ | ↙ |
| | | | 13 | ↓ | 485 | 565-530 | ↓ | ↓ |
| | | | | | | | | |
| | | | | | | | | |

Notes:

- N = Normal Operating Condition
- U = Upset Operating Condition
- T = Testing Condition
- E = Emergency condition
- F = Faulted Condition
- D = Design Condition

TABLE B-2
THERMAL OPERATION MODES

| Mode Number | Type | Description | Temp. of | Applicable Section | | EX 10 ⁶ psi | α ΔT in/ft. | | |
|-------------|------|-------------|----------|--------------------|---------|------------------------|-------------|-------|--------|
| | | | | From Node | To Node | | | | |
| 7 | N | | 1100 | 5 | 30 | 21.8 | .1284 | | |
| | | | | 30 | 85 | | | | |
| | | | | 85 | 140 | | | | |
| | | | | 140 | 165 | | | | |
| | | | | 85 | 390 | | | | |
| | | | | 650 | 30 | 230 | 25.15 | .0687 | |
| | | | | | 140 | 230 | | | |
| | | | | | 230 | 460 | | | |
| | | | | | 650 | 460 | 680 | 25.25 | .05115 |
| | | | | | | 460 | 485 | | |
| | | | | | | 485 | 500-530 | | |
| | | | | | | 530 | 550 | | |
| | | | | | 400 | 485 | 565-530 | 27.0 | .0270 |

Notes:

- N = Normal Operating Condition
- U = Upset Operating Condition
- T = Testing Condition
- E = Emergency condition
- F = Faulted Condition
- D = Design Condition

Calculation of Thermal Nozzle Movements
Cold Sodium Storage Tank

KC9
3/25/83
at

079TI000008
153

Node point 680.

Temperature : 610°F .


Material = Carbon Steel.


$$\Delta_y = \frac{4.703}{100} \times 50 = 2.352'' \uparrow$$

$$\begin{aligned} \Delta_{\text{radial}} &= \frac{4.703}{100} \times 18.25 \\ &= .858'' \end{aligned}$$

$$\Delta_x = .858 \cos 48^{\circ} = .574''$$

$$\Delta_z = .858 \sin 48^{\circ} = .638''$$



| | | |
|-------------------------|--|-------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 154 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <u>4/5/83</u> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

Calculation of Allowable Stress.

SS 304. At 1100° F.

$$S_c = 18.7 \text{ ksi}$$

$$S_h = 7.7 \text{ ksi.}$$

$$S_A = f (1.25 S_c + 0.25 S_h) \quad (1) \text{ of } 102.3.2 \text{ ANSE B31.1}$$

$$f = 1 \quad \text{since no. of cycles} < 7000$$

$$S_A = 1 (1.25 \times 18.7 + 0.25 \times 7.7) \\ = 25.3 \text{ ksi.}$$

SA 53 GR. B Carbon Steel

$$S_c = 15.0 \text{ ksi.}$$

$$S_h @ 650^\circ F = 15 \text{ ksi}$$

$$S_A = (1.25 + 0.25) 15 = 22.5 \text{ ksi.}$$

Lines 0033-10-HBDA AND 0095-4-HBDA (Nodes 460 Thru 680 are carbon steel, Rest are SS304.

* JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG JESMSG *

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000
16:45:08 IAT4401 LOCATE FOR STEP= DD=SYSUT1 DSN=\$WW232.N1.DATA
16:45:08 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
16:45:08 IAT4401 LOCATE FOR STEP= DD=SYSUT1 DSN=\$WW232.N2.DATA
16:45:08 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
16:45:11 USES AVTSOA D \$WW232.N1.DATA
16:45:13 IAT5200 JOB 0277 (\$WW232P3) IN SETUP ON MAIN=L P=09 LOCAL
16:45:13 IAT5210 J=0277 SYSUT1 USING D AVTSOA ON 520 \$WW232.N1.DATA
16:45:27 IAT2000 JOB 0277 \$WW232P3 SELECTED C GRP=JS3BATCH
16:45:28 C R= \$WW232P3 NEF995I \$WW232P3 STARTED, 4/05/83,16.43.21 ASID=00039
16:45:28 C R= \$WW232P3 IEF403I \$WW232P3 - STARTED - TIME=16.43.21
16:45:33 C R= \$WW232P3 IEF404I \$WW232P3 - ENDED - TIME=16.43.27
16:45:33 C R= \$WW232P3 NEF996I \$WW232P3 ENDED, 4/05/83,B.U.= .0489 *0716935 ,3081-C3,JOB CC= 000
16:45:34 IAT5400 JOB 0277 (\$WW232P3) IN BREAKDOWN

079T1000008
155

| | | | |
|--|---|---------|------------|
| ***** | | | |
| * JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL JESJCL * | | | |
| ***** | | | |
| | // \$WW232P3 JOB 'GURSAHANI LB30731160*0716935 | 4444449 | , *0000100 |
| | // TIME=(02,00), REGION=1500K, NOTIFY=\$WW232, MSGCLASS=A, MSGLEVEL=1 | | 00000200 |
| | // *MAIN ORG=RMO05 | | 00000300 |
| | // * THIS IS DATASET \$WW232.PRINT.EDIT.CNTL | | 00000400 |
| | // * THESE THREE ARE FOR XEROX OUTPUT | | 00000500 |
| | // *FORMAT PR, DDNAME=SYSMMSG, DEST=RM271PR3, FCB=JB10, COPIES=1 | | 00000600 |
| | // *FORMAT PR, DDNAME=SYSPRINT, DEST=RM271PR3, FCB=JB10, COPIES=1 | | 00000700 |
| | // *FORMAT PR, DDNAME=SYSUT2, DEST=RM271PR3, FCB=JB10, COPIES=1 | | 00000800 |
| | // * THESE THREE ARE FOR NORMAL OUTPUT | | 00000900 |
| | // * // *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO05, COPIES=1 | | 00001000 |
| | // * // *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO05, COPIES=1 | | 00001100 |
| | // * // *FORMAT PR, DDNAME=SYSUT2, DEST=RMO05, COPIES=1 | | 00001200 |
| | // * THESE THREE ARE FOR MICROFICHE OUTPUT | | 00001300 |
| | // * // *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001400 |
| | // * // *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001500 |
| | // * // *FORMAT PR, DDNAME=SYSUT2, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001600 |
| | // EXEC PGM=IEBGENER | | 00001700 |
| | // SYSPRINT DD SYSOUT=A | | 00001800 |
| | // SYSIN DD DUMMY | | 00001900 |
| | // SYSUT1 DD DSN=\$WW232.N1.DATA, DISP=SHR | | 00002000 |
| | // DD DSN=\$WW232.N2.DATA, DISP=SHR | | 00002100 |
| | // SYSUT2 DD SYSOUT=A, DCB=(RECFM=FBA, LRECL=133, BLKSIZE=1330) | | 00002200 |
| 1 | // \$WW232P3 JOB 'GURSAHANI LB30731160*0716935 | 4444449 | , *0000100 |
| | // TIME=(02,00), REGION=1500K, NOTIFY=\$WW232, MSGCLASS=A, MSGLEVEL=1 | | 00000200 |
| | *** THIS IS DATASET \$WW232.PRINT.EDIT.CNTL | | 00000400 |
| | *** THESE THREE ARE FOR XEROX OUTPUT | | 00000500 |
| | *** THESE THREE ARE FOR NORMAL OUTPUT | | 00000900 |
| | *** // *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO05, COPIES=1 | | 00001000 |
| | *** // *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO05, COPIES=1 | | 00001100 |
| | *** // *FORMAT PR, DDNAME=SYSUT2, DEST=RMO05, COPIES=1 | | 00001200 |
| | *** THESE THREE ARE FOR MICROFICHE OUTPUT | | 00001300 |
| | *** // *FORMAT PR, DDNAME=SYSMMSG, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001400 |
| | *** // *FORMAT PR, DDNAME=SYSPRINT, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001500 |
| | *** // *FORMAT PR, DDNAME=SYSUT2, DEST=RMO01PR5, FORMS=FICHE, COPIES=1 | | 00001600 |
| 2 | // EXEC PGM=IEBGENER | | 00001700 |
| 3 | // SYSPRINT DD SYSOUT=A | | 00001800 |
| 4 | // SYSIN DD DUMMY | | 00001900 |
| 5 | // SYSUT1 DD DSN=\$WW232.N1.DATA, DISP=SHR | | 00002000 |
| 6 | // DD DSN=\$WW232.N2.DATA, DISP=SHR | | 00002100 |
| 7 | // SYSUT2 DD SYSOUT=A, DCB=(RECFM=FBA, LRECL=133, BLKSIZE=1330) | | 00002200 |

```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000
14:05:51 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
14:05:51 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
14:05:51 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
14:05:51 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
14:05:51 IAT4401 LOCATE FOR STEP=G DD=FT15FO01 DSN=$WW232.CARRIZO.SGPUMP.DISCHARG.DATA
14:05:51 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
14:05:51 IAT4401 LOCATE FOR STEP=G DD=FT69FO01 DSN=$WWO49.ROCKPIPE.USERS
14:05:51 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
14:05:51 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
14:05:51 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
14:05:52 USES: CVTSOK D $WWO49.NUPIPE.LOAD
14:05:52 USES AVTSOA D $WW232.CARRIZO.SGPUMP.DISCHARG.DATA
14:05:52 IAT5200 JOB 2372 ($WW232B1) IN SETUP ON MAIN=C P=03 LOCAL
14:05:52 IAT5210 J=2372 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
14:05:52 IAT5210 J=2372 FT15FO01 USING D AVTSOA ON 520 $WW232.CARRIZO.SGPUMP.DISCHARG.DATA
14:05:56 IAT2000 JOB 2372 $WW232B1 SELECTED I GRP=BIG
14:05:57 I R= $WW232B1 NEF995I $WW232B1 STARTED, 3/30/83,14.03.22 ASID=00050
14:05:57 I R= $WW232B1 IEF403I $WW232B1 - STARTED - TIME=14.03.22
14:07:17 I R= $WW232B1 +IH0002I STOP 1
14:07:18 I R= $WW232B1 IEF404I $WW232B1 - ENDED - TIME=14.04.42
14:07:18 I R= $WW232B1 NEF996I $WW232B1 ENDED, 3/30/83,B.U.= 4.3540 *0716935 ,3081-I3,JOB CC= 001
14:07:19 IAT5400 JOB 2372 ($WW232B1) IN BREAKDOWN
/$WW232B1 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RMO05 00000300
/ EXEC ROCKPIPE,PROG=SMALL
/G.SYSIN DD DSN=$WW232.CARRIZO.SGPUMP.DISCHARG.DATA,DISP=SHR
1 // $WW232B1 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
// REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
2 // EXEC ROCKPIPE,PROG=SMALL
3 XXROCKPIPE PROC DSN='$WWO49.NUPIPE.LOAD',PROG=SMALL,C=10,
XX PROGA=SEVEN,B=19069,PROGE=OPT2,DSNE='$WWO49.ELTEMP.LOAD',
XX USERS='$WWO49.ROCKPIPE.USERS'

```

079TI000008
157

ORIGINAL INPUT BY GURSAHANI ON 03/30/83 AT 14:03:28 WITH PRIORITY 3

| | | | | | | | |
|--|---|----|-------|--------|-------|------|------|
| STEAM GENERATOR PUMP DISCHARGE AND CONNECTED PIPING | | | | | | | 1 |
| CONTROL | | | 2.0 | | | | 2 |
| FLEXAN | 1 | 1 | 2.0 | | | | 3 |
| NORMAL OPERATING WITH BOTH PUMPS ON | | | | | | | 4 |
| FLEXAN | 2 | 2 | 2.0 | | | | 5 |
| PUMP 2B DOWN LINE AT AMBIENT | | | | | | | 6 |
| FLEXAN | 3 | 3 | 2.0 | | | | 7 |
| HOT DRAIN THRU BOTH LOOPS | | | | | | | 8 |
| FLEXAN | 4 | 4 | 2.0 | | | | 9 |
| HOT DRAIN THRU ONE LOOP V-022B CLOSED | | | | | | | 10 |
| FLEXAN | 5 | 5 | 2.0 | | | | 11 |
| HOT DRAIN THRU ONE LOOP V-022A CLOSED | | | | | | | 12 |
| FLEXAN | 6 | 6 | 2.0 | | | | 13 |
| STARTING VALVE FCV040 AND FCV 018 OPEN | | | | | | | 14 |
| FLEXAN | 7 | 7 | 2.0 | | | | 15 |
| NORMAL OPERATING WITH BOTH PUMPS ON , EMERGENCY OUTLET LINES AT 650F | | | | | | | 16 |
| XSECTN | 1 | | 12.75 | .375 | 93.7 | 28.3 | 67.0 |
| XSECTN | 2 | | 10.75 | .365 | 101.9 | 28.3 | 67.0 |
| XSECTN | 3 | | 10.75 | .365 | 71.2 | 28.3 | 67.0 |
| XSECTN | 4 | | 8.625 | .322 | 48.1 | 28.3 | 67.0 |
| XSECTN | 5 | | 4.5 | .237 | 15.7 | 28.3 | 67.0 |
| OPVAL | 1 | 1 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 1 | 2 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 1 | 3 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 1 | 4 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 1 | 5 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 1 | 6 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 1 | 7 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 1 | 8 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 1 | 9 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 1 | 10 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 1 | 11 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 1 | 12 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 1 | 13 | 27.0 | .0270 | | | 67.0 |
| OPVAL | 2 | 1 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 2 | 2 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 2 | 3 | 28.3 | | | | 67.0 |
| OPVAL | 2 | 4 | 28.3 | | | | 67.0 |
| OPVAL | 2 | 5 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 2 | 6 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 2 | 7 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 2 | 8 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 2 | 9 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 2 | 10 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 2 | 11 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 2 | 12 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 2 | 13 | 27.0 | .0270 | | | 67.0 |
| OPVAL | 3 | 1 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 3 | 2 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 3 | 3 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 3 | 4 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 3 | 5 | 26.6 | .0380 | | | 67.0 |
| OPVAL | 3 | 6 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 3 | 7 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 3 | 8 | 21.8 | .1284 | | | 67.0 |
| OPVAL | 3 | 9 | 23.4 | .1004 | | | 67.0 |
| OPVAL | 3 | 10 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 3 | 11 | 25.25 | .05115 | | | 67.0 |
| OPVAL | 3 | 12 | 25.25 | .05115 | | | 67.0 |

| | | | | | | | |
|---------|---|----|--------|---------|-----|---------|-----|
| OPVAL | 3 | 13 | 27.0 | .0270 | | 67.0 | 60 |
| OPVAL | 4 | 1 | 21.8 | .1284 | | 67.0 | 61 |
| OPVAL | 4 | 2 | 26.6 | .0380 | | 67.0 | 62 |
| OPVAL | 4 | 3 | 26.6 | .0380 | | 67.0 | 63 |
| OPVAL | 4 | 4 | 26.6 | .0380 | | 67.0 | 64 |
| OPVAL | 4 | 5 | 26.6 | .0380 | | 67.0 | 65 |
| OPVAL | 4 | 6 | 21.8 | .1284 | | 67.0 | 66 |
| OPVAL | 4 | 7 | 26.6 | .0380 | | 67.0 | 67 |
| OPVAL | 4 | 8 | 21.8 | .1284 | | 67.0 | 68 |
| OPVAL | 4 | 9 | 23.4 | .1004 | | 67.0 | 69 |
| OPVAL | 4 | 10 | 25.25 | .05115 | | 67.0 | 70 |
| OPVAL | 4 | 11 | 25.25 | .05115 | | 67.0 | 71 |
| OPVAL | 4 | 12 | 25.25 | .05115 | | 67.0 | 72 |
| OPVAL | 4 | 13 | 27.0 | .0270 | | 67.0 | 73 |
| OPVAL | 5 | 1 | 26.6 | .0380 | | 67.0 | 74 |
| OPVAL | 5 | 2 | 26.6 | .0380 | | 67.0 | 75 |
| OPVAL | 5 | 3 | 26.6 | .0380 | | 67.0 | 76 |
| OPVAL | 5 | 4 | 21.8 | .1284 | | 67.0 | 77 |
| OPVAL | 5 | 5 | 26.6 | .0380 | | 67.0 | 78 |
| OPVAL | 5 | 6 | 26.6 | .0380 | | 67.0 | 79 |
| OPVAL | 5 | 7 | 21.8 | .1284 | | 67.0 | 80 |
| OPVAL | 5 | 8 | 21.8 | .1284 | | 67.0 | 81 |
| OPVAL | 5 | 9 | 23.4 | .1004 | | 67.0 | 82 |
| OPVAL | 5 | 10 | 25.25 | .05115 | | 67.0 | 83 |
| OPVAL | 5 | 11 | 25.25 | .05115 | | 67.0 | 84 |
| OPVAL | 5 | 12 | 25.25 | .05115 | | 67.0 | 85 |
| OPVAL | 5 | 13 | 27.0 | .0270 | | 67.0 | 86 |
| OPVAL | 6 | 1 | 21.8 | .1284 | | 67.0 | 87 |
| OPVAL | 6 | 2 | 21.8 | .1284 | | 67.0 | 88 |
| OPVAL | 6 | 3 | 21.8 | .1284 | | 67.0 | 89 |
| OPVAL | 6 | 4 | 21.8 | .1284 | | 67.0 | 90 |
| OPVAL | 6 | 5 | 21.8 | .1284 | | 67.0 | 91 |
| OPVAL | 6 | 6 | 26.6 | .0380 | | 67.0 | 92 |
| OPVAL | 6 | 7 | 26.6 | .0380 | | 67.0 | 93 |
| OPVAL | 6 | 8 | 26.6 | .0380 | | 67.0 | 94 |
| OPVAL | 6 | 9 | 25.25 | .05115 | | 67.0 | 95 |
| OPVAL | 6 | 10 | 25.25 | .05115 | | 67.0 | 96 |
| OPVAL | 6 | 11 | 25.25 | .05115 | | 67.0 | 97 |
| OPVAL | 6 | 12 | 25.25 | .05115 | | 67.0 | 98 |
| OPVAL | 6 | 13 | 25.25 | .05115 | | 67.0 | 99 |
| OPVAL | 7 | 1 | 21.8 | .1284 | | 67.0 | 100 |
| OPVAL | 7 | 2 | 21.8 | .1284 | | 67.0 | 101 |
| OPVAL | 7 | 3 | 21.8 | .1284 | | 67.0 | 102 |
| OPVAL | 7 | 4 | 21.8 | .1284 | | 67.0 | 103 |
| OPVAL | 7 | 5 | 21.8 | .1284 | | 67.0 | 104 |
| OPVAL | 7 | 6 | 25.15 | .0687 | | 67.0 | 105 |
| OPVAL | 7 | 7 | 25.15 | .0687 | | 67.0 | 106 |
| OPVAL | 7 | 8 | 25.15 | .0687 | | 67.0 | 107 |
| OPVAL | 7 | 9 | 25.25 | .05115 | | 67.0 | 108 |
| OPVAL | 7 | 10 | 25.25 | .05115 | | 67.0 | 109 |
| OPVAL | 7 | 11 | 25.25 | .05115 | | 67.0 | 110 |
| OPVAL | 7 | 12 | 25.25 | .05115 | | 67.0 | 111 |
| OPVAL | 7 | 13 | 27.0 | .0270 | | 67.0 | 112 |
| ANCHOR | | 5 | -1.833 | 993.042 | 0.0 | | 113 |
| STDISPL | 1 | 5 | -.28 | -1.66 | | | 114 |
| STDISPL | 2 | 5 | -.28 | -1.66 | | | 115 |
| STDISPL | 3 | 5 | -.28 | -1.66 | | | 116 |
| STDISPL | 4 | 5 | -.28 | -1.66 | | | 117 |
| STDISPL | 5 | 5 | | | | | 118 |
| STDISPL | 6 | 5 | -.28 | -1.66 | | | 119 |
| STDISPL | 7 | 5 | -.28 | -1.66 | | | 120 |
| RUN | 5 | 10 | -2.167 | | | 2.0 1.0 | 121 |

| | | | | | | | | | |
|---------|---|-----|-----|--------|---------|---------|-----|-----|-----|
| ELBOW | - | 10 | 15 | | | | | | 122 |
| RUN | | 15 | 18 | | 12.609 | | | | 123 |
| RUN | | 18 | 20 | | 12.609 | | | | 124 |
| ELBOW | - | 20 | 25 | | | | | | 125 |
| RUN | | 25 | 30 | | | -1.958 | | | 126 |
| TEE | | 30 | 170 | | | | | | 127 |
| RUN | | 30 | 35 | | | -0.708 | 2.0 | | 128 |
| RUN | | 35 | 40 | | | -1.834 | | | 129 |
| VALVE | | 40 | 45 | | | -1.0 | | | 130 |
| VALVE | | 45 | 50 | | | -1.0 | | | 131 |
| RUN | | 50 | 55 | | | -4.5 | | | 132 |
| ELBOW | - | 55 | 60 | | | | | | 133 |
| RUN | | 60 | 65 | 4.5 | | | | | 134 |
| ELBOW | - | 65 | 70 | | | | | | 135 |
| RUN | | 70 | 75 | | | 5.0 | | | 136 |
| ELBOW | - | 75 | 80 | | | | | | 137 |
| RUN | | 80 | 85 | 3.0 | | | | | 138 |
| TEE | | 85 | 295 | | | | | | 139 |
| RUN | | 85 | 90 | 3.0 | | | 3.0 | | 140 |
| ELBOW | - | 90 | 95 | | | | | | 141 |
| RUN | | 95 | 100 | | | -5.0 | | | 142 |
| ELBOW | - | 100 | 105 | | | | | | 143 |
| RUN | | 105 | 110 | 4.5 | | | | | 144 |
| ELBOW | - | 110 | 115 | | | | | | 145 |
| RUN | | 115 | 120 | | | 4.5 | | | 146 |
| VALVE | | 120 | 125 | | | 1.0 | | | 147 |
| VALVE | | 125 | 130 | | | 1.0 | | | 148 |
| RUN | | 130 | 135 | | | 1.834 | | | 149 |
| RUN | | 135 | 140 | | | 0.708 | | | 150 |
| TEE | | 140 | 290 | | | | | | 151 |
| RUN | | 140 | 145 | | | 1.958 | 4.0 | | 152 |
| ELBOW | - | 145 | 150 | | | | | | 153 |
| RUN | | 150 | 153 | | | -12.609 | | | 154 |
| RUN | | 153 | 155 | | | -12.609 | | | 155 |
| ELBOW | - | 155 | 160 | | | | | | 156 |
| RUN | | 160 | 165 | -2.167 | | | | | 157 |
| ANCHOR | | 165 | 165 | 8.833 | 993.042 | | | | 158 |
| STDISPL | 1 | 165 | | .28 | -1.66 | | | | 159 |
| STDISPL | 2 | 165 | | | | | | | 160 |
| STDISPL | 3 | 165 | | .28 | -1.66 | | | | 161 |
| STDISPL | 4 | 165 | | | | | | | 162 |
| STDISPL | 5 | 165 | | .28 | -1.66 | | | | 163 |
| STDISPL | 6 | 165 | | .28 | -1.66 | | | | 164 |
| STDISPL | 7 | 165 | | .28 | -1.66 | | | | 165 |
| RUN | | 30 | 170 | -1.667 | | | 4.0 | 6.0 | 166 |
| RUN | | 170 | 175 | -3.333 | | | | | 167 |
| ELBOW | - | 175 | 180 | | | | | | 168 |
| RUN | | 180 | 185 | | | -6.0 | | | 169 |
| VALVE | | 185 | 190 | | | -1.0 | | | 170 |
| VALVE | | 190 | 195 | | | -1.0 | | | 171 |
| RUN | | 195 | 200 | | | -11.0 | | | 172 |
| ELBOW | - | 200 | 205 | | | | | | 173 |
| RUN | | 205 | 210 | 7.25 | | | | | 174 |
| RUN | | 210 | 215 | 7.25 | | | | | 175 |
| ELBOW | - | 215 | 220 | | | | | | 176 |
| RUN | | 220 | 225 | | 5.156 | | | | 177 |
| RUN | | 225 | 230 | | .583 | | | | 178 |
| TEE | | 230 | 240 | | | | | | 179 |
| RUN | | 230 | 240 | .583 | | | 7.0 | | 180 |
| RUN | | 240 | 245 | 9.417 | | | | | 181 |
| ELBOW | | 245 | 250 | | | | | | 182 |
| RUN | | 250 | 255 | | | 11.0 | | | 183 |

| | | | | | | | | | |
|---------|-------|-----|------|----------|---------|-----|-----|--|-----|
| VALVE | 255 | 260 | | | 1.0 | | | | 184 |
| VALVE | 260 | 265 | | | 1.0 | | | | 185 |
| RUN | 265 | 270 | | | 6.0 | | | | 186 |
| ELBOW | - 270 | 275 | | | | | | | 187 |
| RUN | 275 | 280 | | -5.739 | | | | | 188 |
| ELBOW | - 280 | 285 | | | | | | | 189 |
| RUN | 285 | 290 | | -4.833 | | | | | 190 |
| RUN | 290 | 140 | | -.667 | | | | | 191 |
| RUN | 85 | 295 | | | -.708 | 2.0 | 5.0 | | 192 |
| RUN | 295 | 300 | | | -8.292 | | | | 193 |
| ELBOW | - 300 | 305 | | | | | | | 194 |
| RUN | 305 | 310 | | 9.75 | | | | | 195 |
| ELBOW | - 310 | 315 | | | | | | | 196 |
| RUN | 315 | 320 | | 17.913 | | | | | 197 |
| RUN | 320 | 325 | | 17.913 | | | | | 198 |
| RUN | 325 | 330 | | 17.913 | | | | | 199 |
| ELBOW | - 330 | 335 | | | | | | | 200 |
| RUN | 335 | 340 | | | 7.0 | | | | 201 |
| RUN | 340 | 345 | | | 7.333 | | | | 202 |
| ELBOW | - 345 | 350 | | | | | | | 203 |
| RUN | 350 | 355 | | 5.75 | | | | | 204 |
| ELBOW | - 355 | 360 | | | | | | | 205 |
| RUN | 360 | 365 | | -17.913 | | | | | 206 |
| RUN | 365 | 370 | | -17.913 | | | | | 207 |
| RUN | 370 | 375 | | -17.913 | | | | | 208 |
| ELBOW | - 375 | 380 | | | | | | | 209 |
| RUN | 380 | 390 | | | -6.0 | | | | 210 |
| ANCHOR | | 390 | 19.0 | 1018.260 | -6.667 | | | | 211 |
| RUN | 230 | 235 | | .583 | | 4.0 | 8.0 | | 212 |
| RUN | 235 | 395 | | 5.417 | | | | | 213 |
| ELBOW | - 395 | 400 | | | | | | | 214 |
| RUN | 400 | 405 | | | -6.25 | | | | 215 |
| RUN | 405 | 410 | | | -6.25 | | | | 216 |
| ELBOW | - 410 | 415 | | | | | | | 217 |
| RUN | 415 | 420 | | 9.0 | | | | | 218 |
| RUN | 420 | 425 | | 9.0 | | | | | 219 |
| ELBOW | - 425 | 430 | | | | | | | 220 |
| RUN | 430 | 435 | | | -12.0 | | | | 221 |
| RUN | 435 | 440 | | | -11.542 | | | | 222 |
| VALVE | 440 | 445 | | | -1.5 | | | | 223 |
| VALVE | 445 | 450 | | | -1.5 | | | | 224 |
| RUN | 450 | 455 | | | -5.333 | | | | 225 |
| RUN | 455 | 460 | | | -.867 | | | | 226 |
| TEE | 460 | 455 | | | | | | | 227 |
| RUN | 460 | 615 | | .708 | | 3.0 | 9.0 | | 228 |
| RUN | 615 | 620 | | 20.292 | | | | | 229 |
| RUN | 620 | 625 | | 21.0 | | | | | 230 |
| ELBOW | - 625 | 630 | | | | | | | 231 |
| RUN | 630 | 635 | | | -8.0 | | | | 232 |
| RUN | 635 | 640 | | | -8.0 | | | | 233 |
| ELBOW | - 640 | 645 | | | | | | | 234 |
| RUN | 645 | 650 | | -9.0 | | | | | 235 |
| ELBOW | - 650 | 655 | | | | | | | 236 |
| RUN | 655 | 660 | | | -7.0 | | | | 237 |
| RUN | 660 | 665 | | | -7.0 | | | | 238 |
| ELBOW | - 665 | 670 | | | | | | | 239 |
| RUN | 670 | 675 | | | -11.0 | | | | 240 |
| RUN | 675 | 680 | | | -11.0 | | | | 241 |
| ANCHOR | | 680 | 15.5 | 1050.0 | -96.0 | | | | 242 |
| STDISPL | 1 | 680 | .574 | 2.352 | .638 | | | | 243 |
| STDISPL | 2 | 680 | .574 | 2.352 | .638 | | | | 244 |
| STDISPL | 3 | 680 | .574 | 2.352 | .638 | | | | 245 |

ASME SECTION III CLASS 2 DR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 5 | 1.000 | 493. | 493. | 3047. | 3540. |
| | 10 | 1.000 | 493. | 493. | 2979. | 3473. |
| ELBOW | 10 | 2.606 | 493. | 493. | 7765. | 8259. |
| | 15 | 2.606 | 493. | 493. | 7014. | 7507. |
| RUN | 15 | 1.000 | 493. | 493. | 2691. | 3184. |
| | 18 | 1.000 | 493. | 493. | 1455. | 1948. |
| RUN | 18 | 1.000 | 493. | 493. | 1455. | 1948. |
| | 20 | 1.000 | 493. | 493. | 2711. | 3204. |
| ELBOW | 20 | 2.606 | 493. | 493. | 7068. | 7560. |
| | 25 | 2.606 | 493. | 493. | 6786. | 7279. |
| RUN | 25 | 1.000 | 493. | 493. | 2603. | 3097. |
| | 30 | 1.969 | 493. | 493. | 4785. | 5278. |
| RUN | 30 | 1.969 | 493. | 493. | 4860. | 5353. |
| | 35 | 1.000 | 493. | 493. | 2331. | 2824. |
| RUN | 35 | 1.000 | 493. | 493. | 2331. | 2824. |
| | 40 | 1.000 | 493. | 493. | 2069. | 2562. |
| RUN | 50 | 1.000 | 493. | 493. | 1986. | 2479. |
| | 55 | 1.000 | 493. | 493. | 2336. | 2829. |
| ELBOW | 55 | 2.606 | 493. | 493. | 6088. | 6581. |
| | 60 | 2.606 | 493. | 493. | 5867. | 6360. |
| RUN | 60 | 1.000 | 493. | 493. | 2251. | 2744. |
| | 65 | 1.000 | 493. | 493. | 1811. | 2304. |
| ELBOW | 65 | 2.606 | 493. | 493. | 4720. | 5214. |
| | 70 | 2.606 | 493. | 493. | 3191. | 3684. |
| RUN | 70 | 1.000 | 493. | 493. | 1224. | 1718. |
| | 75 | 1.000 | 493. | 493. | 577. | 1071. |
| ELBOW | 75 | 2.606 | 493. | 493. | 1505. | 1998. |
| | 80 | 2.606 | 493. | 493. | 1483. | 1976. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 80 | 1.000 | 493. | 493. | 569. | 1062. |
| | 85 | 1.969 | 493. | 493. | 2091. | 2584. |
| RUN | 85 | 1.969 | 493. | 493. | 2226. | 2719. |
| | 90 | 1.000 | 493. | 493. | 775. | 1268. |
| ELBOW | 90 | 2.606 | 493. | 493. | 2019. | 2512. |
| | 95 | 2.606 | 493. | 493. | 1748. | 2241. |
| RUN | 95 | 1.000 | 493. | 493. | 670. | 1164. |
| | 100 | 1.000 | 493. | 493. | 1290. | 1783. |
| ELBOW | 100 | 2.606 | 493. | 493. | 3361. | 3855. |
| | 105 | 2.606 | 493. | 493. | 4716. | 5210. |
| RUN | 105 | 1.000 | 493. | 493. | 1809. | 2303. |
| | 110 | 1.000 | 493. | 493. | 2126. | 2619. |
| ELBOW | 110 | 2.606 | 493. | 493. | 5541. | 6034. |
| | 115 | 2.606 | 493. | 493. | 5458. | 5951. |
| RUN | 115 | 1.000 | 493. | 493. | 2094. | 2587. |
| | 120 | 1.000 | 493. | 493. | 1596. | 2089. |
| RUN | 130 | 1.000 | 493. | 493. | 1638. | 2132. |
| | 135 | 1.000 | 493. | 493. | 1916. | 2409. |
| RUN | 135 | 1.000 | 493. | 493. | 1916. | 2409. |
| | 140 | 1.969 | 493. | 493. | 4092. | 4585. |
| RUN | 140 | 1.969 | 493. | 493. | 4018. | 4511. |
| | 145 | 1.000 | 493. | 493. | 2217. | 2710. |
| ELBOW | 145 | 2.606 | 493. | 493. | 5778. | 6271. |
| | 150 | 2.606 | 493. | 493. | 6302. | 6795. |
| RUN | 150 | 1.000 | 493. | 493. | 2418. | 2911. |
| | 153 | 1.000 | 493. | 493. | 1362. | 1855. |
| RUN | 153 | 1.000 | 493. | 493. | 1362. | 1855. |
| | 155 | 1.000 | 493. | 493. | 2461. | 2955. |

079T1000008
164

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| ELBOW | 155 | 2.606 | 493. | 493. | 6416. | 6909. |
| | 160 | 2.606 | 493. | 493. | 6784. | 7278. |
| RUN | 160 | 1.000 | 493. | 493. | 2603. | 3096. |
| | 165 | 1.000 | 493. | 493. | 2601. | 3094. |
| RUN | 30 | 1.969 | 449. | 449. | 2452. | 2900. |
| | 170 | 1.000 | 449. | 449. | 1392. | 1841. |
| RUN | 170 | 1.000 | 449. | 449. | 1392. | 1841. |
| | 175 | 1.000 | 449. | 449. | 1326. | 1775. |
| ELBOW | 175 | 2.440 | 449. | 449. | 3235. | 3684. |
| | 180 | 2.440 | 449. | 449. | 3018. | 3467. |
| RUN | 180 | 1.000 | 449. | 449. | 1237. | 1686. |
| | 185 | 1.000 | 449. | 449. | 913. | 1362. |
| RUN | 195 | 1.000 | 449. | 449. | 866. | 1314. |
| | 200 | 1.000 | 449. | 449. | 1171. | 1619. |
| ELBOW | 200 | 2.440 | 449. | 449. | 2856. | 3305. |
| | 205 | 2.440 | 449. | 449. | 2692. | 3141. |
| RUN | 205 | 1.000 | 449. | 449. | 1104. | 1552. |
| | 210 | 1.000 | 449. | 449. | 994. | 1443. |
| RUN | 210 | 1.000 | 449. | 449. | 994. | 1443. |
| | 215 | 1.000 | 449. | 449. | 1390. | 1838. |
| ELBOW | 215 | 2.440 | 449. | 449. | 3390. | 3839. |
| | 220 | 2.440 | 449. | 449. | 3626. | 4075. |
| RUN | 220 | 1.000 | 449. | 449. | 1486. | 1935. |
| | 225 | 1.000 | 449. | 449. | 1431. | 1880. |
| RUN | 225 | 1.000 | 449. | 449. | 1431. | 1880. |
| | 230 | 1.844 | 449. | 449. | 2672. | 3121. |
| RUN | 230 | 1.844 | 449. | 449. | 6256. | 6705. |
| | 240 | 1.000 | 449. | 449. | 3235. | 3683. |

079T1000008
165

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 240 | 1.000 | 449. | 449. | 3235. | 3683. |
| | 245 | 1.000 | 449. | 449. | 1213. | 1661. |
| ELBOW | 245 | 2.440 | 449. | 449. | 2959. | 3407. |
| | 250 | 2.440 | 449. | 449. | 2239. | 2687. |
| RUN | 250 | 1.000 | 449. | 449. | 918. | 1366. |
| | 255 | 1.000 | 449. | 449. | 866. | 1315. |
| RUN | 265 | 1.000 | 449. | 449. | 1139. | 1588. |
| | 270 | 1.000 | 449. | 449. | 1843. | 2291. |
| ELBOW | 270 | 2.440 | 449. | 449. | 4496. | 4945. |
| | 275 | 2.440 | 449. | 449. | 4574. | 5023. |
| RUN | 275 | 1.000 | 449. | 449. | 1875. | 2323. |
| | 280 | 1.000 | 449. | 449. | 1854. | 2302. |
| ELBOW | 280 | 2.440 | 449. | 449. | 4523. | 4972. |
| | 285 | 2.440 | 449. | 449. | 4137. | 4586. |
| RUN | 285 | 1.000 | 449. | 449. | 1696. | 2144. |
| | 290 | 1.000 | 449. | 449. | 1016. | 1464. |
| RUN | 290 | 1.000 | 449. | 449. | 1016. | 1464. |
| | 140 | 1.969 | 449. | 449. | 1578. | 2027. |
| RUN | 85 | 1.969 | 493. | 493. | 4492. | 4985. |
| | 295 | 1.000 | 493. | 493. | 2273. | 2766. |
| RUN | 295 | 1.000 | 493. | 493. | 2273. | 2766. |
| | 300 | 1.000 | 493. | 493. | 2371. | 2864. |
| ELBOW | 300 | 2.606 | 493. | 493. | 6179. | 6672. |
| | 305 | 2.606 | 493. | 493. | 5938. | 6432. |
| RUN | 305 | 1.000 | 493. | 493. | 2278. | 2772. |
| | 310 | 1.000 | 493. | 493. | 1559. | 2053. |
| ELBOW | 310 | 2.606 | 493. | 493. | 4064. | 4557. |
| | 315 | 2.606 | 493. | 493. | 3869. | 4362. |

079T1000008
 166

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 315 | 1.000 | 493. | 493. | 1484. | 1978. |
| | 320 | 1.000 | 493. | 493. | 1123. | 1616. |
| RUN | 320 | 1.000 | 493. | 493. | 1123. | 1616. |
| | 325 | 1.000 | 493. | 493. | 1164. | 1658. |
| RUN | 325 | 1.000 | 493. | 493. | 1164. | 1658. |
| | 330 | 1.000 | 493. | 493. | 1535. | 2028. |
| ELBOW | 330 | 2.606 | 493. | 493. | 4001. | 4494. |
| | 335 | 2.606 | 493. | 493. | 3669. | 4162. |
| RUN | 335 | 1.000 | 493. | 493. | 1408. | 1901. |
| | 340 | 1.000 | 493. | 493. | 944. | 1437. |
| RUN | 340 | 1.000 | 493. | 493. | 944. | 1437. |
| | 345 | 1.000 | 493. | 493. | 1230. | 1723. |
| ELBOW | 345 | 2.606 | 493. | 493. | 3205. | 3699. |
| | 350 | 2.606 | 493. | 493. | 3253. | 3747. |
| RUN | 350 | 1.000 | 493. | 493. | 1248. | 1742. |
| | 355 | 1.000 | 493. | 493. | 1093. | 1586. |
| ELBOW | 355 | 2.606 | 493. | 493. | 2849. | 3342. |
| | 360 | 2.606 | 493. | 493. | 3023. | 3516. |
| RUN | 360 | 1.000 | 493. | 493. | 1160. | 1653. |
| | 365 | 1.000 | 493. | 493. | 1240. | 1734. |
| RUN | 365 | 1.000 | 493. | 493. | 1240. | 1734. |
| | 370 | 1.000 | 493. | 493. | 1635. | 2129. |
| RUN | 370 | 1.000 | 493. | 493. | 1635. | 2129. |
| | 375 | 1.000 | 493. | 493. | 2041. | 2535. |
| ELBOW | 375 | 2.606 | 493. | 493. | 5321. | 5814. |
| | 380 | 2.606 | 493. | 493. | 5024. | 5517. |
| RUN | 380 | 1.000 | 493. | 493. | 1927. | 2421. |
| | 390 | 1.000 | 493. | 493. | 1780. | 2273. |

079T1000008
 167

ASME SECTION III CLASS 2 OR ANSI B31.1.8 STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 230 | 1.844 | 449. | 449. | 3659. | 4107. |
| | 235 | 1.000 | 449. | 449. | 1998. | 2446. |
| RUN | 235 | 1.000 | 449. | 449. | 1998. | 2446. |
| | 395 | 1.000 | 449. | 449. | 2982. | 3431. |
| ELBOW | 395 | 2.440 | 449. | 449. | 7276. | 7725. |
| | 400 | 2.440 | 449. | 449. | 8111. | 8560. |
| RUN | 400 | 1.000 | 449. | 449. | 3324. | 3773. |
| | 405 | 1.000 | 449. | 449. | 3458. | 3906. |
| RUN | 405 | 1.000 | 449. | 449. | 3458. | 3906. |
| | 410 | 1.000 | 449. | 449. | 3857. | 4306. |
| ELBOW | 410 | 2.440 | 449. | 449. | 9411. | 9859. |
| | 415 | 2.440 | 449. | 449. | 8591. | 9039. |
| RUN | 415 | 1.000 | 449. | 449. | 3521. | 3970. |
| | 420 | 1.000 | 449. | 449. | 876. | 1325. |
| RUN | 420 | 1.000 | 449. | 449. | 876. | 1325. |
| | 425 | 1.000 | 449. | 449. | 3857. | 4305. |
| ELBOW | 425 | 2.440 | 449. | 449. | 9410. | 9858. |
| | 430 | 2.440 | 449. | 449. | 10101. | 10550. |
| RUN | 430 | 1.000 | 449. | 449. | 4140. | 4589. |
| | 435 | 1.000 | 449. | 449. | 2756. | 3205. |
| RUN | 435 | 1.000 | 449. | 449. | 2756. | 3205. |
| | 440 | 1.000 | 449. | 449. | 2662. | 3111. |
| RUN | 450 | 1.000 | 449. | 449. | 2924. | 3372. |
| | 455 | 1.000 | 449. | 449. | 3573. | 4022. |
| RUN | 455 | 1.000 | 449. | 449. | 3573. | 4022. |
| | 460 | 1.969 | 449. | 449. | 6368. | 6817. |
| RUN | 460 | 1.969 | 493. | 493. | 7415. | 7908. |
| | 615 | 1.000 | 493. | 493. | 3680. | 4174. |

079T1000008
 168

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 615 | 1.000 | 493. | 493. | 3680. | 4174. |
| | 620 | 1.000 | 493. | 493. | 1241. | 1734. |
| RUN | 620 | 1.000 | 493. | 493. | 1241. | 1734. |
| | 625 | 1.000 | 493. | 493. | 1322. | 1816. |
| ELBOW | 625 | 2.606 | 493. | 493. | 3446. | 3940. |
| | 630 | 2.606 | 493. | 493. | 3738. | 4231. |
| RUN | 630 | 1.000 | 493. | 493. | 1434. | 1927. |
| | 635 | 1.000 | 493. | 493. | 1250. | 1744. |
| RUN | 635 | 1.000 | 493. | 493. | 1250. | 1744. |
| | 640 | 1.000 | 493. | 493. | 1069. | 1563. |
| ELBOW | 640 | 2.606 | 493. | 493. | 2787. | 3281. |
| | 645 | 2.606 | 493. | 493. | 2588. | 3082. |
| RUN | 645 | 1.000 | 493. | 493. | 993. | 1486. |
| | 650 | 1.000 | 493. | 493. | 1152. | 1646. |
| ELBOW | 650 | 2.606 | 493. | 493. | 3003. | 3497. |
| | 655 | 2.606 | 493. | 493. | 3172. | 3665. |
| RUN | 655 | 1.000 | 493. | 493. | 1217. | 1710. |
| | 660 | 1.000 | 493. | 493. | 1101. | 1594. |
| RUN | 660 | 1.000 | 493. | 493. | 1101. | 1594. |
| | 665 | 1.000 | 493. | 493. | 998. | 1491. |
| ELBOW | 665 | 2.606 | 493. | 493. | 2600. | 3093. |
| | 670 | 2.606 | 493. | 493. | 2345. | 2839. |
| RUN | 670 | 1.000 | 493. | 493. | 900. | 1393. |
| | 675 | 1.000 | 493. | 493. | 1134. | 1628. |
| RUN | 675 | 1.000 | 493. | 493. | 1134. | 1628. |
| | 680 | 1.000 | 493. | 493. | 2293. | 2786. |
| RUN | 460 | 1.969 | 493. | 493. | 3557. | 4051. |
| | 465 | 1.000 | 493. | 493. | 1731. | 2224. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ.8 PSI | OCCASIONAL STRESS EQ.9 PSI | EXPANSION STRESS EQ.10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ.11 PSI |
|--------|------|------------------------------|------------------------------------|-------------------------------------|-------------------------------------|--|
| RUN | 465 | 1.000 | 493. | 493. | 1731. | 2224. |
| | 470 | 1.000 | 493. | 493. | 1670. | 2163. |
| RUN | 470 | 1.000 | 493. | 493. | 1670. | 2163. |
| | 475 | 1.000 | 493. | 493. | 1598. | 2092. |
| RUN | 475 | 1.000 | 493. | 493. | 1598. | 2092. |
| | 480 | 1.000 | 493. | 493. | 1530. | 2024. |
| RUN | 480 | 1.000 | 493. | 493. | 1530. | 2024. |
| | 485 | 1.000 | 493. | 493. | 1365. | 1859. |
| RUN | 485 | 1.000 | 493. | 493. | 1104. | 1597. |
| | 490 | 1.000 | 493. | 493. | 817. | 1310. |
| ELBOW | 490 | 2.606 | 493. | 493. | 2129. | 2622. |
| | 495 | 2.606 | 493. | 493. | 1922. | 2416. |
| RUN | 495 | 1.000 | 493. | 493. | 737. | 1231. |
| | 500 | 1.000 | 493. | 493. | 719. | 1213. |
| REDUCE | 500 | 2.000 | 493. | 493. | 1439. | 1932. |
| | 505 | 2.000 | 493. | 493. | 1439. | 1932. |
| REDUCE | 515 | 2.000 | 493. | 493. | 1474. | 1967. |
| | 520 | 2.000 | 493. | 493. | 1492. | 1985. |
| ELBOW | 520 | 2.606 | 493. | 493. | 1944. | 2437. |
| | 525 | 2.606 | 493. | 493. | 1963. | 2456. |
| RUN | 525 | 1.000 | 493. | 493. | 753. | 1246. |
| | 530 | 1.000 | 493. | 493. | 1092. | 1585. |
| RUN | 530 | 1.000 | 493. | 493. | 1685. | 2178. |
| | 535 | 1.000 | 493. | 493. | 1549. | 2042. |
| RUN | 545 | 1.000 | 493. | 493. | 1274. | 1767. |
| | 550 | 1.000 | 493. | 493. | 1218. | 1711. |
| BRANCH | 485 | 1.000 | 318. | 318. | 3180. | 3498. |
| | 555 | 1.000 | 318. | 318. | 4510. | 4828. |

079T1000008
170

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| ELBOW | 555 | 1.953 | 318. | 318. | 8809. | 9127. |
| | 560 | 1.953 | 318. | 318. | 7467. | 7785. |
| RUN | 560 | 1.000 | 318. | 318. | 3823. | 4141. |
| | 565 | 1.000 | 318. | 318. | 754. | 1072. |
| RUN | 575 | 1.000 | 318. | 318. | 2406. | 2724. |
| | 580 | 1.000 | 318. | 318. | 4762. | 5080. |
| ELBOW | 580 | 1.953 | 318. | 318. | 9302. | 9620. |
| | 585 | 1.953 | 318. | 318. | 10536. | 10854. |
| RUN | 585 | 1.000 | 318. | 318. | 5394. | 5712. |
| | 590 | 1.000 | 318. | 318. | 3746. | 4065. |
| RUN | 600 | 1.000 | 318. | 318. | 1593. | 1911. |
| | 605 | 1.000 | 318. | 318. | 2471. | 2789. |
| ELBOW | 605 | 1.953 | 318. | 318. | 4826. | 5144. |
| | 610 | 1.953 | 318. | 318. | 4165. | 4483. |
| RUN | 610 | 1.000 | 318. | 318. | 2132. | 2450. |
| | 530 | 1.000 | 318. | 318. | 6892. | 7210. |

REPORT

079T1000008
 171



APPENDIX 6.3
INPUT AND OUTPUT DATA FOR SG PUMP SUCTION PIPING



Rockwell International
Energy Systems Group

173
PAGE NO.

079TT1000008
REPORT NO.

MODEL NO.

SARRIZO PLAINS UNIT 1

PREPARED BY: KCG

CHECKED BY:

DATE: 4-4-83




FIGURE 4


| | | |
|-------------------------|--|-------------|
| PREPARED BY: <u>KCG</u> |  | 174 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <u>4/5/83</u> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | SG Pump Suction | REFERENCE | | |
|-------------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0081-20-HCDA 0082-20-HCDA 0025-20-HCDA | | | |
| Design Temperature | 1100°F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1055°F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 20" /sch. 20 | | | |
| Pipe Thickness x | 0.375" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe Lbs/ft | 78.6 | | | |
| Weight of contents Lbs/ft | 9 x 126 = 113.4 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (32^2 - 20^2) \times \frac{14}{144} = 47.6$ | | | |
| Total Weight ^x Lbs/ft | 239.6 | | | |
| E _c ^x | 28.3 x 10 ⁶ psi | | | |
| Seismic Category | II | | | |

```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000
11:16:47 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
11:16:47 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
11:16:47 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
11:16:47 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
11:16:47 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=$WW232.CARRIZO.SUCTION.DATA
11:16:47 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
11:16:47 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
11:16:47 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
11:16:48 USES CVTSOK 01 026492 D $WWO49.NUPIPE.LOAD
11:16:48 USES AVTSOA 01 026492 D $WW232.CARRIZO.SUCTION.DATA
11:16:48 IAT5200 JOB 0931 ($WW232C3) IN SETUP ON MAIN=C P=07 LOCAL
11:16:48 IAT5210 J=0931 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
11:16:48 IAT5210 J=0931 FT15FOO1 USING D AVTSOA ON 520 $WW232.CARRIZO.SUCTION.DATA
12:05:08 IAT2000 JOB 0931 $WW232C3 SELECTED I GRP=BIG
12:05:09 I R= $WW232C3 NEF9951 $WW232C3 STARTED, 2/17/83,12.06.23 ASID=00048
12:05:09 I R= $WW232C3 IEF4031 $WW232C3 - STARTED - TIME=12.06.23
12:05:55 I R= $WW232C3 +IH00021 STOP 1
12:05:56 I R= $WW232C3 IEF4041 $WW232C3 - ENDED - TIME=12.07.10
12:05:56 I R= $WW232C3 NEF9961 $WW232C3 ENDED, 2/17/83,B.U.= .9755 *0716935 ,3081-I3.JOB CC= 001
12:05:57 IAT5400 JOB 0931 ($WW232C3) IN BREAKDOWN
/$WW232C3 JOB 'GURSAHANI LB30130340*0716935 005 5001007037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RMO05 00000300
/ EXEC ROCKPIPE,PROG=SMALL
/G.SYSIN DD DSN=$WW232.CARRIZO.SUCTION.DATA,DISP=SHR
1 // $WW232C3 JOB 'GURSAHANI LB30130340*0716935 005 5001007037', *
// REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
.2 // EXEC ROCKPIPE,PROG=SMALL
3 XXROCKPIPE PROC DSN='$WWO49.NUPIPE.LOAD',PROG=SMALL,C=10,
XX PROGA=SEVEN,B=19069,PROGE=OPT2,DSNE='$WWO49.ELTEMP.LOAD'
*** AL HROMJAK ROCKWELL INTERNATIONAL, ESG. COMNET 393-3318
*** FT50FOO1 FOR 7-SPECTRA NODE ACCELERATIONS.
*** IN BOTH STEPS, FT66 CONTAINS DIAGNOSTIC OUTPUT.
*** FT66FOO1 IN G STEP CONTAINS TIME SPENT IN MAJOR PROGRAM PHASES.
*** FT16FOO1 DUMMIED WHEN P STEP DELETED.
*** FT17FOO1, FT18FOO1, FT19FOO1, FT20FOO1 ADDED FOR SNUBBER ITERATIONS
4 XXA EXEC PGM=&PROGA
*** THIS STEP READS THE 7 SPECTRA AND TRANSLATES THEM TO A NEW POINT
*** NEW SPECTRA WRITTEN ON FTO1FOO1
5 XXSTEPLIB DD DSN=&DSN,DISP=SHR
6 XXFTO1FOO1 DD UNIT=SYSDA,DSN=&&SPEC,SPACE=(TRK,(10),RLSE),DISP=(,PASS),
XX DCB=(RECFM=F,LRECL=80,BLKSIZE=80)
7 XXFTO5FOO1 DD DDNAME=SYSIN
8 XXFTO6FOO1 DD SYSOUT=*
9 XXFT66FOO1 DD DUMMY,DCB=(RECFM=VBA,BLKSIZE=2020)
10 XXG EXEC PGM=&PROG
*** THIS STEP EXECUTES ROCKPIPE. LOAD CASES, 7-SPECTRA (IF ANY), AND
*** GEOMETRY ARE READ FROM UNIT FT15'S 3 CONCATANATED DATA SETS. LOAD
*** CASES TO BE DELETED FROM PRINTING ARE DETECTED AND THE CASE NO.'S
*** MADE PLUS. ALL 3 FILES FROM FT15 ARE WRITTEN ON FT05 AS ONE FILE TO
*** BE READ BY NUPIPE.
11 XXSTEPLIB DD DSN=&DSN,DISP=SHR
12 XXFTO1FOO1 DD UNIT=SYSDA,DCB=(RECFM=VBS,BLKSIZE=88),
XX SPACE=(CYL,(&C,&C))
13 XXFTO2FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
14 XXFTO3FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
15 XXFTO4FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
16 XXFTO5FOO1 DD UNIT=SYSDA,SPACE=(80,(20000)),
XX DCB=(RECFM=FB,LRECL=80,BLKSIZE=19040)
17 XXFTO6FOO1 DD SYSOUT=*

```

PROGRAM INPUT DATA
CARRIZO SG PUMP SUCTION

| | | | | | | | |
|--|-----|-----|-------|--------|--------|------|-----|
| CONTROL | | | 2.0 | | 1.0 | | |
| FLEXAN | 1 | 1 | 2.0 | | | | |
| THERMAL AT 1100F | | | | | | | |
| FLEXAN | 2 | 2 | 2.0 | | | | |
| THERMAL WITH ONE PUMP DOWN AND LINE AT 400F | | | | | | | |
| FLEXAN | 3 | 3 | 2.0 | | | | |
| THERMAL WITH ONE PUMP DOWN AND LINE AT AMBIENT | | | | | | | |
| XSECTN | 1 | | 20.00 | 0.375 | 240.0 | 28.3 | 65. |
| XSECTN | 2 | | 20.00 | 0.500 | 240.0 | 28.3 | 65. |
| OPVAL 1100 | 1 | 1 | 22.2 | .1284 | | | 65. |
| OPVAL 1100 | 1 | 2 | 22.2 | .1284 | | | 65. |
| OPVAL 1100 | 1 | 3 | 22.2 | .1284 | | | 65. |
| OPVAL 1100 | 2 | 1 | 22.2 | .1284 | | | 65. |
| OPVAL 400 | 2 | 2 | 26.6 | .0380 | | | 65. |
| OPVAL 1100 | 2 | 3 | 22.2 | .1284 | | | 65. |
| OPVAL 1100 | 3 | 1 | 22.2 | .1284 | | | 65. |
| OPVAL 70 | 3 | 2 | 28.3 | | | | 65. |
| OPVAL 1100 | 3 | 3 | 22.2 | .1284 | | | 65. |
| ANCHOR | | 5 | | | | | |
| DUMMY | 5 | 10 | | -1.0 | | 1.0 | 1.0 |
| ELBOW | 5 | 10 | | | | 1.0 | 1.0 |
| DUMMY | 5 | 10 | 1.0 | | | | |
| DUMMY | 10 | 15 | 1.0 | | | | |
| ELBOW | 10 | 15 | | | | | |
| DUMMY | 10 | 15 | | 1.0 | | | |
| RUN | 15 | 20 | | 5.5 | | | |
| RUN | 20 | 25 | | 8.0 | | | |
| ELBOW | 25 | 30 | | | | | |
| RUN | 30 | 35 | 6.0 | | | | |
| ELBOW | 35 | 40 | | | | | |
| RUN | 40 | 45 | | | 15.5 | | |
| ELBOW | 45 | 50 | | | | | |
| RUN | 50 | 55 | 9.0 | | | | |
| ELBOW | 55 | 60 | | | | | |
| RUN | 60 | 65 | | | -6.708 | | |
| RUN | 65 | 70 | | | -1.0 | | |
| RUN | 70 | 75 | | | -1.0 | | |
| RUN | 75 | 79 | | | -3.0 | | |
| ELBOW | 79 | 80 | | | | | |
| GRUN | 80 | 81 | 2.0 | | -2.0 | | |
| VALVE | 81 | 82 | 0.5 | | -0.5 | | |
| CWEIGHT | | 82 | | 2000.0 | | | |
| VALVE | 82 | 83 | 0.5 | | -0.5 | | |
| GRUN | 83 | 84 | 2.0 | | -2.0 | | |
| ELBOW | 84 | 85 | | | | | |
| GRUN | 85 | 90 | | | -2.292 | | |
| TEE | 90 | 180 | | | | | |
| RUN | 90 | 180 | 6.0 | | | | 3.0 |
| RUN | 180 | 190 | 1.0 | | | 2.0 | |
| ANCHOR | | 190 | 32.0 | 13.5 | -3.5 | | |
| RUN | 90 | 92 | | | -2.292 | 1.0 | 2.0 |
| ELBOW | 92 | 93 | | | | | |
| RUN | 93 | 94 | -2.0 | | -2.0 | | |
| VALVE | 94 | 95 | -0.5 | | -0.5 | | |
| CWEIGHT | | 95 | | 2000.0 | | | |
| VALVE | 95 | 96 | -0.5 | | -0.5 | | |
| RUN | 96 | 97 | -2.0 | | -2.0 | | |
| ELBOW | 97 | 98 | | | | | |

CARRIZO SG PUMP SUCTION

ELAPSED CPU = 2.304 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| ELBOW | 5 | 3.768 | 867. | 867. | 9571. | 10437. |
| | 10 | 3.768 | 867. | 867. | 16121. | 16988. |
| ELBOW | 10 | 3.768 | 867. | 867. | 16121. | 16988. |
| | 15 | 3.768 | 867. | 867. | 14038. | 14904. |
| RUN | 15 | 1.000 | 867. | 867. | 3725. | 4592. |
| | 20 | 1.000 | 867. | 867. | 2018. | 2885. |
| RUN | 20 | 1.000 | 867. | 867. | 2018. | 2885. |
| | 25 | 1.000 | 867. | 867. | 3282. | 4149. |
| ELBOW | 25 | 3.768 | 867. | 867. | 12368. | 13234. |
| | 30 | 3.768 | 867. | 867. | 15336. | 16203. |
| RUN | 30 | 1.000 | 867. | 867. | 4070. | 4936. |
| | 35 | 1.000 | 867. | 867. | 3960. | 4826. |
| ELBOW | 35 | 3.768 | 867. | 867. | 14922. | 15788. |
| | 40 | 3.768 | 867. | 867. | 10751. | 11617. |
| RUN | 40 | 1.000 | 867. | 867. | 2853. | 3720. |
| | 45 | 1.000 | 867. | 867. | 5089. | 5956. |
| ELBOW | 45 | 3.768 | 867. | 867. | 19177. | 20044. |
| | 50 | 3.768 | 867. | 867. | 22303. | 23170. |
| RUN | 50 | 1.000 | 867. | 867. | 5918. | 6785. |
| | 55 | 1.000 | 867. | 867. | 5340. | 6207. |
| ELBOW | 55 | 3.768 | 867. | 867. | 20124. | 20990. |
| | 60 | 3.768 | 867. | 867. | 13879. | 14746. |
| RUN | 60 | 1.000 | 867. | 867. | 3683. | 4550. |
| | 65 | 1.000 | 867. | 867. | 1469. | 2336. |
| RUN | 65 | 1.000 | 867. | 867. | 1469. | 2336. |
| | 70 | 1.000 | 867. | 867. | 1019. | 1886. |
| RUN | 70 | 1.000 | 867. | 867. | 1019. | 1886. |
| | 75 | 1.000 | 867. | 867. | 748. | 1614. |

CARRIZO SG PUMP SUCTION

ELAPSED CPU = 2.314 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 75 | 1.000 | 867. | 867. | 748. | 1614. |
| | 79 | 1.000 | 867. | 867. | 1228. | 2095. |
| ELBOW | 79 | 3.768 | 867. | 867. | 4627. | 5494. |
| | 80 | 3.768 | 867. | 867. | 8095. | 8962. |
| GRUN | 80 | 1.800 | 867. | 867. | 3867. | 4733. |
| | 81 | 1.800 | 867. | 867. | 5294. | 6161. |
| GRUN | 83 | 1.800 | 867. | 867. | 6470. | 7337. |
| | 84 | 1.800 | 867. | 867. | 7992. | 8858. |
| ELBOW | 84 | 3.768 | 867. | 867. | 16731. | 17598. |
| | 85 | 3.768 | 867. | 867. | 20727. | 21594. |
| GRUN | 85 | 1.800 | 867. | 867. | 9901. | 10767. |
| | 90 | 2.956 | 867. | 867. | 18300. | 19167. |
| RUN | 90 | 2.956 | 867. | 867. | 4861. | 5728. |
| | 180 | 1.000 | 867. | 867. | 4186. | 5053. |
| RUN | 180 | 1.000 | 650. | 650. | 3180. | 3830. |
| | 190 | 1.000 | 650. | 650. | 3507. | 4157. |
| RUN | 90 | 2.956 | 867. | 867. | 18300. | 19167. |
| | 92 | 1.000 | 867. | 867. | 5500. | 6367. |
| ELBOW | 92 | 3.768 | 867. | 867. | 20727. | 21594. |
| | 93 | 3.768 | 867. | 867. | 16731. | 17598. |
| RUN | 93 | 1.000 | 867. | 867. | 4440. | 5306. |
| | 94 | 1.000 | 867. | 867. | 3595. | 4461. |
| RUN | 96 | 1.000 | 867. | 867. | 2941. | 3808. |
| | 97 | 1.000 | 867. | 867. | 2148. | 3015. |
| ELBOW | 97 | 3.768 | 867. | 867. | 8095. | 8962. |
| | 98 | 3.768 | 867. | 867. | 4627. | 5494. |
| RUN | 98 | 1.000 | 867. | 867. | 1228. | 2095. |
| | 100 | 1.000 | 867. | 867. | 732. | 1598. |

079T1000008
179

02/17/83

ROCKPIPE - ROCKWELL INTERNATIONAL ENERGY SYSTEM'S GROUP VERSION OF NUPIPE

PAGE

37

CARRIZO SG PUMP SUCTION

ELAPSED CPU =

2.326 SEC.

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 100 | 1.000 | 867. | 867. | 732. | 1598. |
| | 105 | 1.000 | 867. | 867. | 980. | 1846. |
| RUN | 105 | 1.000 | 867. | 867. | 980. | 1846. |
| | 110 | 1.000 | 867. | 867. | 1416. | 2282. |
| RUN | 110 | 1.000 | 867. | 867. | 1416. | 2282. |
| | 115 | 1.000 | 867. | 867. | 3633. | 4499. |
| ELBOW | 115 | 3.768 | 867. | 867. | 13690. | 14556. |
| | 120 | 3.768 | 867. | 867. | 20044. | 20911. |
| RUN | 120 | 1.000 | 867. | 867. | 5319. | 6186. |
| | 125 | 1.000 | 867. | 867. | 5605. | 6472. |
| RUN | 125 | 1.000 | 867. | 867. | 5605. | 6472. |
| | 130 | 1.000 | 867. | 867. | 5918. | 6785. |
| ELBOW | 130 | 3.768 | 867. | 867. | 22303. | 23170. |
| | 135 | 3.768 | 867. | 867. | 19177. | 20044. |
| RUN | 135 | 1.000 | 867. | 867. | 5089. | 5956. |
| | 140 | 1.000 | 867. | 867. | 2853. | 3720. |
| ELBOW | 140 | 3.768 | 867. | 867. | 10751. | 11617. |
| | 145 | 3.768 | 867. | 867. | 14922. | 15788. |
| RUN | 145 | 1.000 | 867. | 867. | 3960. | 4826. |
| | 150 | 1.000 | 867. | 867. | 4070. | 4936. |
| ELBOW | 150 | 3.768 | 867. | 867. | 15336. | 16203. |
| | 155 | 3.768 | 867. | 867. | 12368. | 13234. |
| RUN | 155 | 1.000 | 867. | 867. | 3282. | 4149. |
| | 160 | 1.000 | 867. | 867. | 2013. | 2880. |
| RUN | 160 | 1.000 | 867. | 867. | 2013. | 2880. |
| | 165 | 1.000 | 867. | 867. | 3725. | 4592. |
| ELBOW | 165 | 3.768 | 867. | 867. | 14038. | 14904. |
| | 170 | 3.768 | 867. | 867. | 16121. | 16988. |



APPENDIX 6.4
INPUT AND OUTPUT DATA FOR NA PIPING TO AND FROM RECEIVER
(LOWER AND UPPER MANIFOLD)


| | | |
|-------------------------|---|-------------------------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 185 |
| CHECKED BY: | | PAGE NO. <u>1</u> OF <u>1</u> |
| DATE: <u>4-4-83</u> | | REPORT NO. <u>079TI000008</u> |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | No Outlet from Receiver | REFERENCE | | |
|--------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0022-14-HCDA | | | |
| Design Temperature | 1100°F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1055°F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 14" / std. | | | |
| Pipe Thickness x | 0.375" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | Cal. Silicate 12" thick | | | |
| Weight of Pipe Lbs/ft | 55 | | | |
| Weight of contents Lbs/ft | 0.9 x 59.7 = 53.7 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (38^2 - 14^2) \times \frac{14}{144} = 95.3$ | | | |
| Total Weight Lbs/ft | 204 lbs/ft | | | |
| E ^x | 28.3 x 10 ⁶ psi | | | |
| Seismic Category | II | | | |


| | | |
|-------------------------|--|---|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 186 |
| CHECKED BY: | | PAGE NO. <u> </u> OF <u> </u> |
| DATE: <u>4-4-83</u> | | REPORT NO. <u>079TI000008</u> |
| | | MODEL NO. <u> </u> |

TABLE B-1
INPUT DATA

| SYSTEM | Na Outlet | REFERENCE | | |
|--------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0023-12-HCDA | | | |
| Design Temperature | 1100° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1055° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 12.75" / sch 40S | | | |
| Pipe Thickness x | 0.375" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | 12" thick Cal. Silicate | | | |
| Weight of Pipe Lbs/ft | 49.56 | | | |
| Weight of contents Lbs/ft | 9 x 49.0 = 44.1 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (36.75^2 - 12.75^2) \frac{14}{144} = 90.71$ | | | |
| Total Weight Lbs/ft | 184.4 lbs/ft. | | | |
| E_c^x | 28.3×10^6 psi | | | |
| Seismic Category | II | | | |


| | | |
|-------------------------|---|--------------------------------|
| PREPARED BY: <u>KCS</u> |  Rockwell International Energy Systems Group | 187 |
| CHECKED BY: | | PAGE NO. <u>1</u> OF <u>02</u> |
| DATE: <u>4-4-83</u> | | REPORT NO. <u>079TI000008</u> |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | No outlet from the Receiver | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0018 thru 0021-6-HCDA | | | |
| Design Temperature | 1100°F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1055°F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 6.625"/Sch. 40 | | | |
| Pipe Thickness x | 0.280" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | 12" thick Cal. Silicate | | | |
| Weight of Pipe LBS/ft | 18.97 | | | |
| Weight of contents LBS/ft | 9 x 12.51 = 11.26 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} (30.625^2 - 6.625^2) \frac{14}{194} = 68.26$ | | | |
| Total Weight LBS/ft | 98.5 lbs/ft | | | |
| E _e | 28.3 x 10 ⁶ psi | | | |
| Seismic Category | II | | | |


| | | | |
|-------------------------|---|---------------------------|-----------|
| PREPARED BY: <u>RCG</u> |  Rockwell International Energy Systems Group | 188 PAGE NO. | OF |
| CHECKED BY: | | 079TI000008 REPORT NO. | |
| DATE: <u>2/18/83</u> | | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | INLET HEADER FOR RECEIVER | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0003-14-HCDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 14.0" / sch 20 | | | |
| Pipe Thickness x | .375" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe LBS/FT | 55.0 | | | |
| Weight of contents LBS/ft | .9 x 59.7 = 53.7 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} (38^2 - 12^2) \frac{14}{144} = 95.3$ | | | |
| Total Weight LBS/ft | 204.0 | | | |
| E _c | 28.3 x 10 ⁶ psi | | | |
| Seismic Category | <u>III</u> | | | |


| | | |
|-------------------------|---|---------------------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 189 PAGE NO. - OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: <u>2/18/83</u> | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | No Lines to Receiver | REFERENCE | | |
|--------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0004 - G - HCDA THRU 0011 - G - HCDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal Operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 6.625" / sch. 40 | | | |
| Pipe Thickness x | 0.280" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe LBS/FT | 18.97 | | | |
| Weight of Contents LBS/ft | .9 x 12.51 = 11.26 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} (18.625^2 - 6.625^2) \frac{14}{144}$ = 23.14 | | | |
| Total Weight LBS/ft | 53.4 lbs/ft | | | |
| E_e | 28.3×10^6 psi | | | |
| Seismic Category | II | | | |



| | | |
|------------------|---|-------------|
| PREPARED BY: KCG |  | 190 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 2/18/83 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | Receiver Bypass | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0012-4-1+CDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal Operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 4.5" / sch 40 | | | |
| Pipe Thickness | 0.237" | | | |
| Pipe Material | SS304 | | | |
| Insulation Type | | | | |
| Weight of Pipe Lbs/Ft | 10.79 | | | |
| Weight of contents Lbs/ft | .9 x 5.51 = 4.96 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (10.5^2 - 4.5^2) \frac{14}{100} = 19.24$ | | | |
| Total Weight Lbs/ft | 35.0 | | | |
| E _c | 28.3 x 10 ⁶ psi | | | |
| Seismic Category | LT | | | |

| | | |
|------------------|---|-------------|
| PREPARED BY: KCL |  Rockwell International Energy Systems Group | 191 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 3/18/83 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

Weldolet SIF:

14" x 6" weldolet


$$h = 3.3 \frac{\bar{T}}{r_2} \quad (\text{from Bonney Forge Catalogue})$$

$$\begin{aligned} \bar{T} &= \text{nominal wall thickness of run pipe} \\ &= .375" \end{aligned}$$

$$\begin{aligned} r_2 &= \text{mean radius of run pipe} \\ &= \frac{14 - .375}{2} = 6.18125" \end{aligned}$$

$$h = \frac{3.3 \times .375}{6.18125} = .182$$

$$\begin{aligned} z &= \frac{.9}{h^{2/3}} = \frac{.9}{(.182)^{2/3}} \\ &= 2.806 \end{aligned}$$

| | | |
|------------------|---|-------------|
| PREPARED BY: KCC |  | 192 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 2/18/83 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

Allowable stress for SA-312, TP304 stainless steel
 For piping in and out of Receiver

$$S_A = f (1.25 S_c + 0.25 S_h)$$

f is a function equivalent full temperature cycles.

$$N = N_E + \alpha_1^5 N_1 + \alpha_2^5 N_2$$

$$N_E = \text{cycles corresponding to } 1100^\circ\text{F to } 70^\circ\text{F}$$

$$= 30 \text{ (assumed)}$$

$$N_1 = 22,000 \text{ cycles}$$

$$N_2 = 28,000 \text{ cycles}$$

$$\Delta T_E = 1100^\circ - 70 = 1030^\circ\text{F}$$

$$\Delta T_1 = 1100^\circ - 400^\circ = 700^\circ\text{F}$$

$$\Delta T_2 = 1100^\circ - 610^\circ = 490^\circ\text{F}$$


$$N = 30 + \left(\frac{\Delta T_1}{\Delta T_E}\right)^5 22000 + \left(\frac{\Delta T_2}{\Delta T_E}\right)^5 28000$$

$$= 30 + \left(\frac{700}{1030}\right)^5 \cdot 22000 + \left(\frac{490}{1030}\right)^5 \cdot 28000$$

$$= 30 + 3190 + 683$$

$$= 3903 < 7000 \text{ cycles}$$

Therefore $f = 1.0$.

| | | |
|------------------|---|---------------------------|
| PREPARED BY: KCG |  Rockwell International Energy Systems Group | 193 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: 2/18/83 | | MODEL NO. |

$$S_c = 18.7 \text{ ksi}$$

$$S_h @ 1100^\circ\text{F} = 8.8 \text{ ksi}$$

$$S_A = 1.0 (1.25 \times 18.7 + 0.25 \times 8.8)$$

$$= 25.575 \text{ ksi}$$

$$S_h + S_A = 34.375 \text{ ksi}$$

$$S_h @ 610^\circ\text{F} = 11.36 \text{ ksi}$$

$$S_A = 1.0 (1.25 \times 18.7 + 0.25 \times 11.36)$$

$$= 26.215 \text{ psi}$$

```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , OOO
11:52:47 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
11:52:47 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
11:52:47 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
11:52:47 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
11:52:47 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=$WW232.CARRIZO.UPPER.LOWER.MANIFOLD.DATA
11:52:47 IAT4402 UNIT=3350 ,VOL(S)=AVTSDA
11:52:47 IAT4401 LOCATE FOR STEP=G DD=FT69FOO1 DSN=$WWO49.ROCKPIPE.USERS
11:52:47 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
11:52:47 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
11:52:47 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
11:52:48 USES CVTSOK 08 015920 D $WWO49.NUPIPE.LOAD
11:52:48 USES AVTSDA 08 015920 D $WW232.CARRIZO.UPPER.LOWER.MANIFOLD.DATA
11:52:48 IAT5200 JOB 2381 ($WW232U1) IN SETUP ON MAIN=C P=03 LOCAL
11:52:48 IAT5210 J=2381 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
11:52:48 IAT5210 J=2381 FT15FOO1 USING D AVTSDA ON 520 $WW232.CARRIZO.UPPER.LOWER.MANIFOLD.DATA
11:52:52 IAT2000 JOB 2381 $WW232U1 SELECTED C GRP=8IG
11:52:53 C R= $WW232U1 NEF995I $WW232U1 STARTED, 4/14/83,11.50.46 ASID=00071
11:52:53 C R= $WW232U1 IEF403I $WW232U1 - STARTED - TIME=11.50.46
11:54:09 C R= $WW232U1 +IH0002I STOP 1
11:54:09 C R= $WW232U1 IEF404I $WW232U1 - ENDED - TIME=11.52.02
11:54:09 C R= $WW232U1 NEF996I $WW232U1 ENDED, 4/14/83,B.U.= 1.4253 *0716935 ,3081-C3,JOB CC= 001
11:54:10 IAT5400 JOB 2381 ($WW232U1) IN BREAKDOWN
/$WW232U1 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RMO05 00000300
/ EXEC ROCKPIPE,PROG=SMALL
/G.SYSIN DD DSN=$WW232.CARRIZO.UPPER.LOWER.MANIFOLD.DATA,DISP=SHR
1 // $WW232U1 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
// REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
2 // EXEC ROCKPIPE,PROG=SMALL
3 XXROCKPIPE PROC DSN='$WWO49.NUPIPE.LOAD',PROG=SMALL,C=10,
XX PROGA=SEVEN,B=19069,PROGE=OPT2,DSNE='$WWO49.ELTEMP.LOAD',
XX USERS='$WWO49.ROCKPIPE.USERS'
*** AL HROMJAK ROCKWELL INTERNATIONAL, ESG. COMNET 393-3318
*** FT50FOO1 FOR 7-SPECTRA NODE ACCELERATIONS.
*** IN BOTH STEPS, FT66 CONTAINS DIAGNOSTIC OUTPUT.
*** FT66FOO1 IN G STEP CONTAINS TIME SPENT IN MAJOR PROGRAM PHASES.
*** FT16FOO1 DUMMIED WHEN P STEP DELETED.
*** FT17FOO1, FT18FOO1, FT19FOO1, FT20FOO1 ADDED FOR SNUBBER ITERATIONS
4 XXA EXEC PGM=&PROGA
*** THIS STEP READS THE 7 SPECTRA AND TRANSLATES THEM TO A NEW POINT
*** NEW SPECTRA WRITTEN ON FTO1FOO1
5 XXSTEPLIB DD DSN=&DSN,DISP=SHR
6 XXFTO1FOO1 DD UNIT=SYSDA,DSN=&&SPEC,SPACE=(TRK,(10),RLSE),DISP=(,PASS),
XX DCB=(RECFM=F,LRECL=80,BLKSIZE=80)
7 XXFTO5FOO1 DD DDNAME=SYSIN
8 XXFTO6FOO1 DD SYSOUT=*
9 XXFT66FOO1 DD DUMMY,DCB=(RECFM=VBA,BLKSIZE=2020)
10 XXG EXEC PGM=&PROG
*** THIS STEP EXECUTES ROCKPIPE. LOAD CASES, 7-SPECTRA (IF ANY), AND
*** GEOMETRY ARE READ FROM UNIT FT15'S 3 CONCATANATED DATA SETS. LOAD
*** CASES TO BE DELETED FROM PRINTING ARE DETECTED AND THE CASE NO.'S
*** MADE PLUS. ALL 3 FILES FROM FT15 ARE WRITTEN ON FTO5 AS ONE FILE TO
*** BE READ BY NUPIPE.
11 XXSTEPLIB DD DSN=&DSN,DISP=SHR
12 XXFTO1FOO1 DD UNIT=SYSDA,DCB=(RECFM=VBS,BLKSIZE=&B),
XX SPACE=(CYL,(&C,&C))
13 XXFTO2FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
14 FTO3FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))
15 FTO4FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(&C,&C))

```


| | | | | | | | | | | |
|-----------|-------|-----|-------|---------|------|-------|-------|-------|--|-----|
| REDUCER | 800 | 804 | | 2.333 | | 3.0 | | | | 60 |
| ELBOW | - 804 | 805 | | | | | | | | 61 |
| RUN | 805 | 806 | | | | -4.0 | | | | 62 |
| ELBOW | - 806 | 807 | | | | | | | | 63 |
| RESTRAINT | | 807 | | 1.0 | | | | | | 64 |
| RUN | 807 | 808 | 9.75 | | | | | | | 65 |
| ELBOW | - 808 | 809 | | | | | | | | 66 |
| RUN | 809 | 810 | | | | -8.0 | | | | 67 |
| ELBOW | - 810 | 811 | | | | | | | | 68 |
| RUN | 811 | 812 | 6.0 | | | | | | | 69 |
| RESTRAINT | | 812 | | 1.0 | | | | | | 70 |
| ELBOW | - 812 | 813 | | | | | | | | 71 |
| RUN | 813 | 814 | | | | 7.5 | | | | 72 |
| ELBOW | - 814 | 815 | | | | | | | | 73 |
| RUN | 815 | 816 | 9.25 | | | | | | | 74 |
| ELBOW | - 816 | 818 | | | | | | | | 75 |
| RUN | 818 | 820 | | 7.5 | | | | | | 76 |
| ANCHOR | | 820 | | | | | | | | 77 |
| STDISPL | 1 | 820 | -0.75 | -1.0 | | | | | | 78 |
| RUN | 15 | 105 | | | | -3.0 | 2.0 | 1.0 | | 79 |
| RESTRAINT | | 105 | | 1.0 | | | | | | 80 |
| RUN | 105 | 109 | | | | -14.0 | | | | 81 |
| RESTRAINT | | 109 | | 1.0 | | | | | | 82 |
| ELBOW | - 109 | 110 | | | | | | | | 83 |
| RUN | 110 | 114 | | | | -12.0 | | | | 84 |
| ELBOW | - 114 | 115 | | | | | | | | 85 |
| RUN | 115 | 117 | | | | 7.0 | | | | 86 |
| RESTRAINT | | 117 | | 1.0 | | | | | | 87 |
| RUN | 117 | 119 | | | | 6.75 | | | | 88 |
| ELBOW | - 119 | 120 | | | | | | | | 89 |
| RUN | 120 | 124 | -3.5 | | | | | | | 90 |
| ELBOW | - 124 | 125 | | | | | | | | 91 |
| RUN | 125 | 130 | | | | 12.0 | | | | 92 |
| ELBOW | - 130 | 135 | | | | | | | | 93 |
| RUN | 135 | 140 | 3.5 | | | | | | | 94 |
| ELBOW | - 140 | 145 | | | | | | | | 95 |
| RUN | 145 | 165 | | -2.0 | | | | | | 96 |
| RESTRAINT | | 165 | 1.E8 | 29000.0 | 1.E8 | 1.2E7 | 1.E10 | 9.1E5 | | 97 |
| STDISPL | 1 | 165 | | 5.1 | | | | | | 98 |
| RUN | 25 | 205 | | | | -3.0 | 2.0 | 1.0 | | 99 |
| RESTRAINT | | 205 | | 1.0 | | | | | | 100 |
| RUN | 205 | 209 | | | | -14.0 | | | | 101 |
| RESTRAINT | | 209 | | 1.0 | | | | | | 102 |
| ELBOW | - 209 | 210 | | | | | | | | 103 |
| RUN | 210 | 214 | | | | -12.0 | | | | 104 |
| ELBOW | - 214 | 215 | | | | | | | | 105 |
| RUN | 215 | 217 | | | | 7.0 | | | | 106 |
| RESTRAINT | | 217 | | 1.0 | | | | | | 107 |
| RUN | 217 | 219 | | | | 6.75 | | | | 108 |
| ELBOW | - 219 | 220 | | | | | | | | 109 |
| RUN | 220 | 224 | -3.5 | | | | | | | 110 |
| ELBOW | - 224 | 225 | | | | | | | | 111 |
| RUN | 225 | 230 | | | | 12.0 | | | | 112 |
| ELBOW | - 230 | 235 | | | | | | | | 113 |
| RUN | 235 | 240 | 3.5 | | | | | | | 114 |
| ELBOW | - 240 | 245 | | | | | | | | 115 |
| RUN | 245 | 265 | | -2.0 | | | | | | 116 |
| RESTRAINT | | 265 | 1.E8 | 29000.0 | 1.E8 | 1.2E7 | 1.E10 | 9.1E5 | | 117 |
| STDISPL | 1 | 265 | | 5.1 | | | | | | 118 |
| RUN | 35 | 305 | | | | -3.0 | 2.0 | 1.0 | | 119 |
| RESTI | | 305 | | 1.0 | | | | | | 120 |
| RUN | 305 | 309 | | | | -14.0 | | | | 121 |

| | | | | | | | | | | |
|-----------|---|------|------|-------|---------|--------|-------|-------|-------|-----|
| RESTRAINT | | 309 | | 1.0 | | | | | | 122 |
| ELBOW | - | 309 | 310 | | | | | | | 123 |
| RUN | | 310 | 314 | -12.0 | | | | | | 124 |
| ELBOW | - | 314 | 315 | | | | | | | 125 |
| RUN | | 315 | 317 | | | 7.0 | | | | 126 |
| RESTRAINT | | | 317 | 1.0 | | | | | | 127 |
| RUN | | 317 | 319 | | | 6.75 | | | | 128 |
| ELBOW | - | 319 | 320 | | | | | | | 129 |
| RUN | | 320 | 324 | -3.5 | | | | | | 130 |
| ELBOW | - | 324 | 325 | | | | | | | 131 |
| RUN | | 325 | 330 | | | 12.0 | | | | 132 |
| ELBOW | - | 330 | 335 | | | | | | | 133 |
| RUN | | 335 | 340 | 3.5 | | | | | | 134 |
| ELBOW | - | 340 | 345 | | | | | | | 135 |
| RUN | | 345 | 365 | | -2.0 | | | | | 136 |
| RESTRAINT | | 365 | | 1.E8 | 29000.0 | 1.E8 | 1.2E7 | 1.E10 | 9.1E5 | 137 |
| STDISPL | 1 | 365 | | | 5.1 | | | | | 138 |
| RUN | | 45 | 405 | | | -3.0 | 2.0 | 1.0 | | 139 |
| ELBOW | - | 405 | 406 | | | | | | | 140 |
| RUN | | 406 | 407 | -3.75 | | | | | | 141 |
| ELBOW | - | 407 | 408 | | | | | | | 142 |
| RUN | | 408 | 409 | | | -4.667 | | | | 143 |
| ELBOW | - | 409 | 410 | | | | | | | 144 |
| RUN | | 410 | 411 | 4.0 | | | | | | 145 |
| ELBOW | - | 411 | 412 | | | | | | | 146 |
| RUN | | 412 | 413 | | | -7.0 | | | | 147 |
| ELBOW | - | 413 | 414 | | | | | | | 148 |
| RUN | | 414 | 415 | | | -12.0 | | | | 149 |
| ELBOW | - | 415 | 416 | | | | | | | 150 |
| RUN | | 416 | 417 | | | 4.5 | | | | 151 |
| RESTRAINT | | 417 | 417 | 1.0 | | | | | | 152 |
| RUN | | 417 | 419 | | | 4.5 | | | | 153 |
| ELBOW | - | 419 | 420 | | | | | | | 154 |
| RUN | | 420 | 424 | -5.75 | | | | | | 155 |
| ELBOW | - | 424 | 425 | | | | | | | 156 |
| RUN | | 425 | 430 | | | 11.5 | | | | 157 |
| ELBOW | - | 430 | 432 | | | | | | | 158 |
| RUN | | 432 | 434 | 2.0 | | | | | | 159 |
| ELBOW | - | 434 | 435 | | | | | | | 160 |
| RUN | | 435 | 440 | | | 3.0 | | | | 161 |
| ELBOW | - | 440 | 445 | | | | | | | 162 |
| RUN | | 445 | 465 | | -2.0 | | | | | 163 |
| RESTRAINT | | 465 | | 1.E8 | 29000.0 | 1.E8 | 1.2E7 | 1.E10 | 9.1E5 | 164 |
| STDISPL | 1 | 465 | | | 5.1 | | | | | 165 |
| RUN | | 92 | 2000 | | | .708 | 6.0 | | | 166 |
| RUN | | 2000 | 2005 | | | 6.542 | | | | 167 |
| ELBOW | - | 2005 | 2010 | | | | | 2.0 | | 168 |
| RUN | | 2010 | 2035 | -6.0 | | | | | | 169 |
| ELBOW | - | 2035 | 2040 | | | | | | | 170 |
| RUN | | 2040 | 2045 | | | 4.0 | | | | 171 |
| ELBOW | - | 2045 | 2050 | | | | | | | 172 |
| RUN | | 2050 | 2055 | -7.0 | | | | | | 173 |
| ELBOW | - | 2055 | 2060 | | | | | | | 174 |
| RUN | | 2060 | 2065 | | | -6.5 | | | | 175 |
| ELBOW | - | 2065 | 2068 | | | | | | | 176 |
| RUN | | 2068 | 2070 | | | -3.292 | | | | 177 |
| REDUCER | | 2070 | 2072 | | | -.458 | | | | 178 |
| REDUCER | | 2072 | 2075 | | | -2.25 | | 2.0 | | 179 |
| ELBOW | - | 2075 | 2080 | | | | | 1.0 | | 180 |
| RUN | | 2080 | 2090 | 3.0 | | | | | | 181 |
| TEE | | 2090 | 1410 | 2.806 | | | | | | 182 |
| RUN | | 2090 | 2095 | 3.25 | | | | | | 183 |

| | | | | | | | | | |
|-----------|-------|------|-------|--------|--|--------|--|-----|-----|
| RUN | 2095 | 2100 | 3.25 | | | | | | 184 |
| TEE | 2100 | 1310 | 2.806 | | | | | | 185 |
| RUN | 2100 | 2150 | 3.25 | | | | | | 186 |
| RESTRAINT | | 2150 | | 50000. | | 50000. | | | 187 |
| RUN | 2150 | 2200 | 3.25 | | | | | | 188 |
| TEE | 2200 | 1210 | 2.806 | | | | | | 189 |
| RUN | 2200 | 2250 | 3.25 | | | | | | 190 |
| RUN | 2250 | 2300 | 3.25 | | | | | | 191 |
| TEE | 2300 | 1110 | 2.806 | | | | | | 192 |
| RUN | 2300 | 2305 | 1.0 | | | | | | 193 |
| ANCHOR | | 2305 | | | | | | | 194 |
| RUN | 2300 | 1110 | | 2.0 | | 5.0 | | 2.0 | 195 |
| ELBOW | -1110 | 1111 | | | | | | | 196 |
| RUN | 1111 | 1130 | -4.95 | | | 4.95 | | | 197 |
| ELBOW | -1130 | 1131 | | | | | | | 198 |
| RUN | 1131 | 1150 | 4.95 | | | 4.95 | | | 199 |
| ELBOW | -1150 | 1151 | | | | | | | 200 |
| RUN | 1151 | 1160 | -2.3 | | | 2.3 | | | 201 |
| ELBOW | -1160 | 1161 | | | | | | | 202 |
| RUN | 1161 | 1165 | | 2.0 | | | | | 203 |
| ANCHOR | | 1165 | | | | | | | 204 |
| RUN | 2200 | 1210 | | 2.0 | | 5.0 | | 2.0 | 205 |
| ELBOW | -1210 | 1211 | | | | | | | 206 |
| RUN | 1211 | 1230 | -4.95 | | | 4.95 | | | 207 |
| ELBOW | -1230 | 1231 | | | | | | | 208 |
| RUN | 1231 | 1250 | 4.95 | | | 4.95 | | | 209 |
| ELBOW | -1250 | 1251 | | | | | | | 210 |
| RUN | 1251 | 1260 | -2.3 | | | 2.3 | | | 211 |
| ELBOW | -1260 | 1261 | | | | | | | 212 |
| RUN | 1261 | 1265 | | 2.0 | | | | | 213 |
| ANCHOR | | 1265 | | | | | | | 214 |
| RUN | 2100 | 1310 | | 2.0 | | 5.0 | | 2.0 | 215 |
| ELBOW | -1310 | 1311 | | | | | | | 216 |
| RUN | 1311 | 1330 | -4.95 | | | 4.95 | | | 217 |
| ELBOW | -1330 | 1331 | | | | | | | 218 |
| RUN | 1331 | 1350 | 4.95 | | | 4.95 | | | 219 |
| ELBOW | -1350 | 1351 | | | | | | | 220 |
| RUN | 1351 | 1360 | -2.3 | | | 2.3 | | | 221 |
| ELBOW | -1360 | 1361 | | | | | | | 222 |
| RUN | 1361 | 1365 | | 2.0 | | | | | 223 |
| ANCHOR | | 1365 | | | | | | | 224 |
| RUN | 2090 | 1410 | | 2.0 | | 5.0 | | 2.0 | 225 |
| ELBOW | -1410 | 1411 | | | | | | | 226 |
| RUN | 1411 | 1430 | -4.95 | | | 4.95 | | | 227 |
| ELBOW | -1430 | 1431 | | | | | | | 228 |
| RUN | 1431 | 1450 | 4.95 | | | 4.95 | | | 229 |
| ELBOW | -1450 | 1451 | | | | | | | 230 |
| RUN | 1451 | 1460 | -2.3 | | | 2.3 | | | 231 |
| ELBOW | -1460 | 1461 | | | | | | | 232 |
| RUN | 1461 | 1465 | | 2.0 | | | | | 233 |
| ANCHOR | | 1465 | | | | | | | 234 |
| STDISPL | 1 | 1165 | | - .12 | | | | | 235 |
| STDISPL | 1 | 1265 | | - .12 | | | | | 236 |
| STDISPL | 1 | 1365 | | - .12 | | | | | 237 |
| STDISPL | 1 | 1465 | | - .12 | | | | | 238 |
| STRESS7 | | | | | | | | | 239 |
| 10CASES | 1 | | | | | | | | 240 |
| ALLDONE | | | | | | | | | 241 |

ASME SECTION III CLASS 2 DR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 5 | 1.000 | 607. | 607. | 4220. | 4827. |
| | 15 | 2.317 | 607. | 607. | 9023. | 9629. |
| RUN | 15 | 2.317 | 607. | 607. | 4987. | 5594. |
| | 20 | 1.000 | 607. | 607. | 2174. | 2780. |
| RUN | 20 | 1.000 | 607. | 607. | 2174. | 2780. |
| | 25 | 2.317 | 607. | 607. | 5560. | 6167. |
| RUN | 25 | 2.317 | 607. | 607. | 3536. | 4143. |
| | 30 | 1.000 | 607. | 607. | 1671. | 2278. |
| RUN | 30 | 1.000 | 607. | 607. | 1671. | 2278. |
| | 35 | 2.317 | 607. | 607. | 5338. | 5945. |
| RUN | 35 | 2.317 | 607. | 607. | 6473. | 7080. |
| | 40 | 1.000 | 607. | 607. | 2956. | 3563. |
| RUN | 40 | 1.000 | 607. | 607. | 2956. | 3563. |
| | 45 | 2.317 | 607. | 607. | 7553. | 8159. |
| RUN | 45 | 2.317 | 607. | 607. | 9428. | 10035. |
| | 51 | 2.317 | 607. | 607. | 9714. | 10321. |
| RUN | 51 | 2.317 | 607. | 607. | 11046. | 11653. |
| | 52 | 1.000 | 607. | 607. | 4735. | 5341. |
| REDUCE | 52 | 2.000 | 553. | 553. | 11479. | 12031. |
| | 53 | 2.000 | 553. | 553. | 11389. | 11942. |
| RUN | 53 | 1.000 | 553. | 553. | 5695. | 6247. |
| | 54 | 1.000 | 553. | 553. | 5541. | 6094. |
| RUN | 54 | 1.000 | 553. | 553. | 5541. | 6094. |
| | 61 | 1.000 | 553. | 553. | 5251. | 5803. |
| ELBOW | 61 | 2.864 | 553. | 553. | 15038. | 15590. |
| | 62 | 2.864 | 553. | 553. | 12271. | 12823. |
| RUN | 62 | 1.000 | 553. | 553. | 4284. | 4837. |
| | 65 | 1.000 | 553. | 553. | 5607. | 6160. |

ASME SECTION III CLASS 2 DR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ.8 PSI | OCCASIONAL STRESS EQ.9 PSI | EXPANSION STRESS EQ.10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ.11 PSI |
|--------|------|------------------------------|------------------------------------|-------------------------------------|-------------------------------------|--|
| ELBOW | 65 | 2.864 | 553. | 553. | 16060. | 16612. |
| | 66 | 2.864 | 553. | 553. | 18742. | 19294. |
| RUN | 66 | 1.000 | 553. | 553. | 6544. | 7096. |
| | 69 | 1.000 | 553. | 553. | 6698. | 7251. |
| ELBOW | 69 | 2.864 | 553. | 553. | 19185. | 19737. |
| | 70 | 2.864 | 553. | 553. | 16601. | 17154. |
| RUN | 70 | 1.000 | 553. | 553. | 5796. | 6349. |
| | 74 | 1.000 | 553. | 553. | 5138. | 5690. |
| ELBOW | 74 | 2.864 | 553. | 553. | 14715. | 15267. |
| | 75 | 2.864 | 553. | 553. | 17418. | 17970. |
| RUN | 75 | 1.000 | 553. | 553. | 6081. | 6634. |
| | 79 | 1.000 | 553. | 553. | 6232. | 6784. |
| ELBOW | 79 | 2.864 | 553. | 553. | 17848. | 18400. |
| | 80 | 2.864 | 553. | 553. | 15430. | 15982. |
| RUN | 80 | 1.000 | 553. | 553. | 5387. | 5940. |
| | 82 | 1.000 | 553. | 553. | 4260. | 4812. |
| ELBOW | 82 | 2.864 | 553. | 553. | 12201. | 12753. |
| | 83 | 2.864 | 553. | 553. | 8561. | 9113. |
| RUN | 83 | 1.000 | 553. | 553. | 2989. | 3542. |
| | 85 | 1.000 | 553. | 553. | 3021. | 3573. |
| ELBOW | 85 | 2.864 | 553. | 553. | 8652. | 9204. |
| | 86 | 2.864 | 553. | 553. | 8177. | 8729. |
| RUN | 86 | 1.000 | 553. | 553. | 2855. | 3407. |
| | 87 | 1.000 | 553. | 553. | 2292. | 2844. |
| ELBOW | 87 | 2.864 | 553. | 553. | 6564. | 7117. |
| | 88 | 2.864 | 553. | 553. | 3918. | 4471. |
| RUN | 88 | 1.000 | 553. | 553. | 1368. | 1921. |
| | 89 | 1.000 | 553. | 553. | 1286. | 1838. |

079T1000008
 200

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| ELBOW | 89 | 2.864 | 553. | 553. | 3683. | 4236. |
| | 90 | 2.864 | 553. | 553. | 7292. | 7844. |
| RUN | 90 | 1.000 | 553. | 553. | 2546. | 3099. |
| | 76 | 1.000 | 553. | 553. | 3395. | 3948. |
| ELBOW | 76 | 2.864 | 553. | 553. | 9724. | 10276. |
| | 77 | 2.864 | 553. | 553. | 10821. | 11374. |
| RUN | 77 | 1.000 | 553. | 553. | 3778. | 4331. |
| | 67 | 1.000 | 553. | 553. | 4066. | 4618. |
| ELBOW | 67 | 2.864 | 553. | 553. | 11645. | 12197. |
| | 68 | 2.864 | 553. | 553. | 12912. | 13465. |
| RUN | 68 | 1.000 | 553. | 553. | 4508. | 5061. |
| | 91 | 1.000 | 553. | 553. | 4068. | 4621. |
| RUN | 91 | 1.000 | 553. | 553. | 4068. | 4621. |
| | 92 | 2.173 | 553. | 553. | 8784. | 9337. |
| RUN | 92 | 2.173 | 553. | 553. | 9045. | 9597. |
| | 93 | 1.000 | 553. | 553. | 4156. | 4708. |
| RUN | 93 | 1.000 | 553. | 553. | 4156. | 4708. |
| | 95 | 1.000 | 553. | 553. | 4195. | 4748. |
| RUN | 51 | 2.317 | 607. | 607. | 6733. | 7340. |
| | 800 | 1.000 | 607. | 607. | 3267. | 3874. |
| REDUCE | 800 | 2.000 | 553. | 553. | 7921. | 8474. |
| | 804 | 2.000 | 553. | 553. | 8834. | 9386. |
| ELBOW | 804 | 2.864 | 553. | 553. | 12650. | 13202. |
| | 805 | 2.864 | 553. | 553. | 13463. | 14016. |
| RUN | 805 | 1.000 | 553. | 553. | 4701. | 5253. |
| | 806 | 1.000 | 553. | 553. | 4422. | 4975. |
| ELBOW | 806 | 2.864 | 553. | 553. | 12666. | 13218. |
| | 807 | 2.864 | 553. | 553. | 10782. | 11335. |

201 079T1000008

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 807 | 1.000 | 553. | 553. | 3765. | 4317. |
| | 808 | 1.000 | 553. | 553. | 1887. | 2439. |
| ELBOW | 808 | 2.864 | 553. | 553. | 5404. | 5956. |
| | 809 | 2.864 | 553. | 553. | 3139. | 3691. |
| RUN | 809 | 1.000 | 553. | 553. | 1096. | 1648. |
| | 810 | 1.000 | 553. | 553. | 4144. | 4696. |
| ELBOW | 810 | 2.864 | 553. | 553. | 11867. | 12420. |
| | 811 | 2.864 | 553. | 553. | 14504. | 15057. |
| RUN | 811 | 1.000 | 553. | 553. | 5064. | 5617. |
| | 812 | 1.000 | 553. | 553. | 4678. | 5230. |
| ELBOW | 812 | 2.864 | 553. | 553. | 13398. | 13950. |
| | 813 | 2.864 | 553. | 553. | 9811. | 10364. |
| RUN | 813 | 1.000 | 553. | 553. | 3426. | 3978. |
| | 814 | 1.000 | 553. | 553. | 1466. | 2019. |
| ELBOW | 814 | 2.864 | 553. | 553. | 4200. | 4752. |
| | 815 | 2.864 | 553. | 553. | 7716. | 8269. |
| RUN | 815 | 1.000 | 553. | 553. | 2694. | 3247. |
| | 816 | 1.000 | 553. | 553. | 4853. | 5405. |
| ELBOW | 816 | 2.864 | 553. | 553. | 13898. | 14451. |
| | 818 | 2.864 | 553. | 553. | 13132. | 13685. |
| RUN | 818 | 1.000 | 553. | 553. | 4585. | 5138. |
| | 820 | 1.000 | 553. | 553. | 3852. | 4404. |
| RUN | 15 | 2.317 | 384. | 384. | 19380. | 19765. |
| | 105 | 1.000 | 384. | 384. | 9039. | 9424. |
| RUN | 105 | 1.000 | 384. | 384. | 9039. | 9424. |
| | 109 | 1.000 | 384. | 384. | 995. | 1379. |
| ELBOW | 109 | 2.267 | 384. | 384. | 2255. | 2640. |
| | 110 | 2.267 | 384. | 384. | 4260. | 4645. |

079T1000008
202

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 110 | 1.000 | 384. | 384. | 1880. | 2264. |
| | 114 | 1.000 | 384. | 384. | 10389. | 10773. |
| ELBOW | 114 | 2.267 | 384. | 384. | 23548. | 23932. |
| | 115 | 2.267 | 384. | 384. | 23733. | 24117. |
| RUN | 115 | 1.000 | 384. | 384. | 10471. | 10855. |
| | 117 | 1.000 | 384. | 384. | 6008. | 6392. |
| RUN | 117 | 1.000 | 384. | 384. | 6008. | 6392. |
| | 119 | 1.000 | 384. | 384. | 2047. | 2431. |
| ELBOW | 119 | 2.267 | 384. | 384. | 4639. | 5024. |
| | 120 | 2.267 | 384. | 384. | 2846. | 3231. |
| RUN | 120 | 1.000 | 384. | 384. | 1256. | 1640. |
| | 124 | 1.000 | 384. | 384. | 2165. | 2550. |
| ELBOW | 124 | 2.267 | 384. | 384. | 4908. | 5293. |
| | 125 | 2.267 | 384. | 384. | 6068. | 6452. |
| RUN | 125 | 1.000 | 384. | 384. | 2677. | 3062. |
| | 130 | 1.000 | 384. | 384. | 7314. | 7698. |
| ELBOW | 130 | 2.267 | 384. | 384. | 16577. | 16961. |
| | 135 | 2.267 | 384. | 384. | 17438. | 17823. |
| RUN | 135 | 1.000 | 384. | 384. | 7693. | 8078. |
| | 140 | 1.000 | 384. | 384. | 7762. | 8146. |
| ELBOW | 140 | 2.267 | 384. | 384. | 17593. | 17977. |
| | 145 | 2.267 | 384. | 384. | 16694. | 17078. |
| RUN | 145 | 1.000 | 384. | 384. | 7365. | 7750. |
| | 165 | 1.000 | 384. | 384. | 6418. | 6803. |
| RUN | 25 | 2.317 | 384. | 384. | 18981. | 19366. |
| | 205 | 1.000 | 384. | 384. | 8830. | 9214. |
| RUN | 205 | 1.000 | 384. | 384. | 8830. | 9214. |
| | 209 | 1.000 | 384. | 384. | 1609. | 1993. |

079T1000008
203

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ.8 PSI | OCCASIONAL STRESS EQ.9 PSI | EXPANSION STRESS EQ.10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ.11 PSI |
|--------|------|------------------------------|------------------------------------|-------------------------------------|-------------------------------------|--|
| ELBOW | 209 | 2.267 | 384. | 384. | 3647. | 4031. |
| | 210 | 2.267 | 384. | 384. | 5248. | 5632. |
| RUN | 210 | 1.000 | 384. | 384. | 2315. | 2700. |
| | 214 | 1.000 | 384. | 384. | 10317. | 10701. |
| ELBOW | 214 | 2.267 | 384. | 384. | 23384. | 23768. |
| | 215 | 2.267 | 384. | 384. | 23539. | 23924. |
| RUN | 215 | 1.000 | 384. | 384. | 10385. | 10770. |
| | 217 | 1.000 | 384. | 384. | 5954. | 6338. |
| RUN | 217 | 1.000 | 384. | 384. | 5954. | 6338. |
| | 219 | 1.000 | 384. | 384. | 2104. | 2489. |
| ELBOW | 219 | 2.267 | 384. | 384. | 4769. | 5154. |
| | 220 | 2.267 | 384. | 384. | 2999. | 3384. |
| RUN | 220 | 1.000 | 384. | 384. | 1323. | 1708. |
| | 224 | 1.000 | 384. | 384. | 2040. | 2424. |
| ELBOW | 224 | 2.267 | 384. | 384. | 4624. | 5008. |
| | 225 | 2.267 | 384. | 384. | 5640. | 6024. |
| RUN | 225 | 1.000 | 384. | 384. | 2488. | 2873. |
| | 230 | 1.000 | 384. | 384. | 7145. | 7529. |
| ELBOW | 230 | 2.267 | 384. | 384. | 16194. | 16579. |
| | 235 | 2.267 | 384. | 384. | 17203. | 17588. |
| RUN | 235 | 1.000 | 384. | 384. | 7590. | 7974. |
| | 240 | 1.000 | 384. | 384. | 7810. | 8195. |
| ELBOW | 240 | 2.267 | 384. | 384. | 17703. | 18088. |
| | 245 | 2.267 | 384. | 384. | 16996. | 17380. |
| RUN | 245 | 1.000 | 384. | 384. | 7498. | 7883. |
| | 265 | 1.000 | 384. | 384. | 6622. | 7006. |
| RUN | 35 | 2.317 | 384. | 384. | 19578. | 19963. |
| | 305 | 1.000 | 384. | 384. | 9143. | 9527. |

079T1000008
204

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 305 | 1.000 | 384. | 384. | 9143. | 9527. |
| | 309 | 1.000 | 384. | 384. | 2184. | 2569. |
| ELBOW | 309 | 2.267 | 384. | 384. | 4951. | 5335. |
| | 310 | 2.267 | 384. | 384. | 6130. | 6515. |
| RUN | 310 | 1.000 | 384. | 384. | 2705. | 3089. |
| | 314 | 1.000 | 384. | 384. | 10500. | 10885. |
| ELBOW | 314 | 2.267 | 384. | 384. | 23800. | 24185. |
| | 315 | 2.267 | 384. | 384. | 23966. | 24350. |
| RUN | 315 | 1.000 | 384. | 384. | 10573. | 10958. |
| | 317 | 1.000 | 384. | 384. | 6060. | 6444. |
| RUN | 317 | 1.000 | 384. | 384. | 6060. | 6444. |
| | 319 | 1.000 | 384. | 384. | 2256. | 2640. |
| ELBOW | 319 | 2.267 | 384. | 384. | 5112. | 5497. |
| | 320 | 2.267 | 384. | 384. | 3311. | 3695. |
| RUN | 320 | 1.000 | 384. | 384. | 1461. | 1845. |
| | 324 | 1.000 | 384. | 384. | 1973. | 2358. |
| ELBOW | 324 | 2.267 | 384. | 384. | 4473. | 4857. |
| | 325 | 2.267 | 384. | 384. | 5380. | 5765. |
| RUN | 325 | 1.000 | 384. | 384. | 2374. | 2758. |
| | 330 | 1.000 | 384. | 384. | 7192. | 7576. |
| ELBOW | 330 | 2.267 | 384. | 384. | 16301. | 16685. |
| | 335 | 2.267 | 384. | 384. | 17488. | 17872. |
| RUN | 335 | 1.000 | 384. | 384. | 7715. | 8100. |
| | 340 | 1.000 | 384. | 384. | 8103. | 8488. |
| ELBOW | 340 | 2.267 | 384. | 384. | 18367. | 18752. |
| | 345 | 2.267 | 384. | 384. | 17823. | 18207. |
| RUN | 345 | 1.000 | 384. | 384. | 7863. | 8248. |
| | 365 | 1.000 | 384. | 384. | 7020. | 7405. |

079T1000008
 205

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 45 | 2.317 | 384. | 384. | 14166. | 14551. |
| | 405 | 1.000 | 384. | 384. | 6411. | 6796. |
| ELBOW | 405 | 2.267 | 384. | 384. | 14531. | 14916. |
| | 406 | 2.267 | 384. | 384. | 13240. | 13625. |
| RUN | 406 | 1.000 | 384. | 384. | 5841. | 6226. |
| | 407 | 1.000 | 384. | 384. | 6390. | 6774. |
| ELBOW | 407 | 2.267 | 384. | 384. | 14483. | 14868. |
| | 408 | 2.267 | 384. | 384. | 14256. | 14641. |
| RUN | 408 | 1.000 | 384. | 384. | 6290. | 6674. |
| | 409 | 1.000 | 384. | 384. | 4919. | 5303. |
| ELBOW | 409 | 2.267 | 384. | 384. | 11149. | 11534. |
| | 410 | 2.267 | 384. | 384. | 9344. | 9728. |
| RUN | 410 | 1.000 | 384. | 384. | 4122. | 4507. |
| | 411 | 1.000 | 384. | 384. | 2472. | 2857. |
| ELBOW | 411 | 2.267 | 384. | 384. | 5604. | 5988. |
| | 412 | 2.267 | 384. | 384. | 3903. | 4288. |
| RUN | 412 | 1.000 | 384. | 384. | 1722. | 2107. |
| | 413 | 1.000 | 384. | 384. | 3141. | 3525. |
| ELBOW | 413 | 2.267 | 384. | 384. | 7119. | 7503. |
| | 414 | 2.267 | 384. | 384. | 9201. | 9586. |
| RUN | 414 | 1.000 | 384. | 384. | 4060. | 4444. |
| | 415 | 1.000 | 384. | 384. | 10208. | 10593. |
| ELBOW | 415 | 2.267 | 384. | 384. | 23139. | 23523. |
| | 416 | 2.267 | 384. | 384. | 22927. | 23311. |
| RUN | 416 | 1.000 | 384. | 384. | 10115. | 10499. |
| | 417 | 1.000 | 384. | 384. | 7371. | 7755. |
| RUN | 417 | 1.000 | 384. | 384. | 7371. | 7755. |
| | 419 | 1.000 | 384. | 384. | 4928. | 5312. |

079T1000008
 206

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| ELBOW | 419 | 2.267 | 384. | 384. | 11170. | 11554. |
| | 420 | 2.267 | 384. | 384. | 9368. | 9753. |
| RUN | 420 | 1.000 | 384. | 384. | 4133. | 4518. |
| | 424 | 1.000 | 384. | 384. | 4135. | 4520. |
| ELBOW | 424 | 2.267 | 384. | 384. | 9373. | 9757. |
| | 425 | 2.267 | 384. | 384. | 9034. | 9419. |
| RUN | 425 | 1.000 | 384. | 384. | 3986. | 4370. |
| | 430 | 1.000 | 384. | 384. | 4903. | 5287. |
| ELBOW | 430 | 2.267 | 384. | 384. | 11112. | 11497. |
| | 432 | 2.267 | 384. | 384. | 12294. | 12678. |
| RUN | 432 | 1.000 | 384. | 384. | 5424. | 5808. |
| | 434 | 1.000 | 384. | 384. | 5450. | 5834. |
| ELBOW | 434 | 2.267 | 384. | 384. | 12352. | 12737. |
| | 435 | 2.267 | 384. | 384. | 13973. | 14358. |
| RUN | 435 | 1.000 | 384. | 384. | 6165. | 6549. |
| | 440 | 1.000 | 384. | 384. | 7367. | 7751. |
| ELBOW | 440 | 2.267 | 384. | 384. | 16697. | 17082. |
| | 445 | 2.267 | 384. | 384. | 17149. | 17534. |
| RUN | 445 | 1.000 | 384. | 384. | 7566. | 7951. |
| | 465 | 1.000 | 384. | 384. | 6922. | 7306. |
| RUN | 92 | 2.173 | 309. | 309. | 8081. | 8390. |
| | 2000 | 1.000 | 309. | 309. | 5541. | 5850. |
| RUN | 2000 | 1.000 | 309. | 309. | 5541. | 5850. |
| | 2005 | 1.000 | 309. | 309. | 2661. | 2969. |
| ELBOW | 2005 | 1.953 | 309. | 309. | 4471. | 4780. |
| | 2010 | 1.953 | 309. | 309. | 3828. | 4136. |
| RUN | 2010 | 1.000 | 309. | 309. | 1960. | 2268. |
| | 2035 | 1.000 | 309. | 309. | 709. | 1017. |

079T1000008
207

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ.8 PSI | OCCASIONAL STRESS EQ.9 PSI | EXPANSION STRESS EQ.10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ.11 PSI |
|--------|------|------------------------------|------------------------------------|-------------------------------------|-------------------------------------|--|
| ELBOW | 2035 | 1.953 | 309. | 309. | 1384. | 1693. |
| | 2040 | 1.953 | 309. | 309. | 871. | 1179. |
| RUN | 2040 | 1.000 | 309. | 309. | 446. | 754. |
| | 2045 | 1.000 | 309. | 309. | 1025. | 1333. |
| ELBOW | 2045 | 1.953 | 309. | 309. | 2001. | 2310. |
| | 2050 | 1.953 | 309. | 309. | 2627. | 2936. |
| RUN | 2050 | 1.000 | 309. | 309. | 1345. | 1654. |
| | 2055 | 1.000 | 309. | 309. | 2884. | 3193. |
| ELBOW | 2055 | 1.953 | 309. | 309. | 5633. | 5942. |
| | 2060 | 1.953 | 309. | 309. | 5501. | 5809. |
| RUN | 2060 | 1.000 | 309. | 309. | 2816. | 3125. |
| | 2065 | 1.000 | 309. | 309. | 988. | 1297. |
| ELBOW | 2065 | 1.953 | 309. | 309. | 1930. | 2239. |
| | 2068 | 1.953 | 309. | 309. | 1423. | 1732. |
| RUN | 2068 | 1.000 | 309. | 309. | 729. | 1037. |
| | 2070 | 1.000 | 309. | 309. | 841. | 1149. |
| REDUCE | 2070 | 2.000 | 309. | 309. | 1682. | 1990. |
| | 2072 | 2.000 | 309. | 309. | 2075. | 2384. |
| REDUCE | 2072 | 2.000 | 384. | 384. | 793. | 1177. |
| | 2075 | 2.000 | 384. | 384. | 963. | 1348. |
| ELBOW | 2075 | 2.938 | 607. | 607. | 229. | 836. |
| | 2080 | 2.938 | 607. | 607. | 403. | 1009. |
| RUN | 2080 | 1.000 | 607. | 607. | 137. | 744. |
| | 2090 | 2.806 | 607. | 607. | 412. | 1018. |
| RUN | 2090 | 2.806 | 607. | 607. | 2881. | 3488. |
| | 2095 | 1.000 | 607. | 607. | 345. | 952. |
| RUN | 2095 | 1.000 | 607. | 607. | 345. | 952. |
| | 2100 | 2.806 | 607. | 607. | 2862. | 3468. |

079T1000008
208

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|--------------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 2100 2150 | 2.806 1.000 | 607. 607. | 607. 607. | 3047. 3329. | 3654. 3935. |
| RUN | 2150 2200 | 1.000 2.806 | 607. 607. | 607. 607. | 3329. 4395. | 3935. 5001. |
| RUN | 2200 2250 | 2.806 1.000 | 607. 607. | 607. 607. | 6732. 2506. | 7339. 3112. |
| RUN | 2250 2300 | 1.000 2.806 | 607. 607. | 607. 607. | 2506. 7391. | 3112. 7998. |
| RUN | 2300 2305 | 2.806 1.000 | 607. 607. | 607. 607. | 11534. 4766. | 12141. 5372. |
| RUN | 2300 1110 | 2.806 1.000 | 384. 384. | 384. 384. | 19178. 7838. | 19562. 8222. |
| ELBOW | 1110 1111 | 2.267 2.267 | 384. 384. | 384. 384. | 17765. 14882. | 18149. 15267. |
| RUN | 1111 1130 | 1.000 1.000 | 384. 384. | 384. 384. | 6566. 10593. | 6950. 10978. |
| ELBOW | 1130 1131 | 2.267 2.267 | 384. 384. | 384. 384. | 24011. 23648. | 24395. 24033. |
| RUN | 1131 1150 | 1.000 1.000 | 384. 384. | 384. 384. | 10433. 6650. | 10818. 7034. |
| ELBOW | 1150 1151 | 2.267 2.267 | 384. 384. | 384. 384. | 15072. 15608. | 15456. 15992. |
| RUN | 1151 1160 | 1.000 1.000 | 384. 384. | 384. 384. | 6886. 2968. | 7271. 3353. |
| ELBOW | 1160 1161 | 2.267 2.267 | 384. 384. | 384. 384. | 6728. 1988. | 7113. 2373. |
| RUN | 1161 1165 | 1.000 1.000 | 384. 384. | 384. 384. | 877. 5654. | 1262. 6038. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY


| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|--------------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 2200 1210 | 2.806 1.000 | 384. 384. | 384. 384. | 11432. 3845. | 11816. 4229. |
| ELBOW | 1210 1211 | 2.267 2.267 | 384. 384. | 384. 384. | 8715. 8735. | 9099. 9120. |
| RUN | 1211 1230 | 1.000 1.000 | 384. 384. | 384. 384. | 3854. 10394. | 4238. 10778. |
| ELBOW | 1230 1231 | 2.267 2.267 | 384. 384. | 384. 384. | 23558. 22173. | 23943. 22558. |
| RUN | 1231 1250 | 1.000 1.000 | 384. 384. | 384. 384. | 9782. 6930. | 10167. 7314. |
| ELBOW | 1250 1251 | 2.267 2.267 | 384. 384. | 384. 384. | 15707. 17195. | 16091. 17580. |
| RUN | 1251 1260 | 1.000 1.000 | 384. 384. | 384. 384. | 7586. 4158. | 7971. 4542. |
| ELBOW | 1260 1261 | 2.267 2.267 | 384. 384. | 384. 384. | 9424. 4107. | 9808. 4491. |
| RUN | 1261 1265 | 1.000 1.000 | 384. 384. | 384. 384. | 1812. 5209. | 2196. 5594. |
| RUN | 2100 1310 | 2.806 1.000 | 384. 384. | 384. 384. | 6678. 1308. | 7063. 1692. |
| ELBOW | 1310 1311 | 2.267 2.267 | 384. 384. | 384. 384. | 2964. 7714. | 3348. 8098. |
| RUN | 1311 1330 | 1.000 1.000 | 384. 384. | 384. 384. | 3403. 9360. | 3788. 9744. |
| ELBOW | 1330 1331 | 2.267 2.267 | 384. 384. | 384. 384. | 21215. 18802. | 21599. 19187. |
| RUN | 1331 1350 | 1.000 1.000 | 384. 384. | 384. 384. | 8295. 6715. | 8680. 7099. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| ELBOW | 1350 | 2.267 | 384. | 384. | 15220. | 15604. |
| | 1351 | 2.267 | 384. | 384. | 17691. | 18075. |
| RUN | 1351 | 1.000 | 384. | 384. | 7805. | 8189. |
| | 1360 | 1.000 | 384. | 384. | 5695. | 6080. |
| ELBOW | 1360 | 2.267 | 384. | 384. | 12909. | 13293. |
| | 1361 | 2.267 | 384. | 384. | 9982. | 10366. |
| RUN | 1361 | 1.000 | 384. | 384. | 4404. | 4788. |
| | 1365 | 1.000 | 384. | 384. | 5873. | 6257. |
| RUN | 2090 | 2.806 | 384. | 384. | 12484. | 12868. |
| | 1410 | 1.000 | 384. | 384. | 5467. | 5851. |
| ELBOW | 1410 | 2.267 | 384. | 384. | 12391. | 12776. |
| | 1411 | 2.267 | 384. | 384. | 13774. | 14158. |
| RUN | 1411 | 1.000 | 384. | 384. | 6077. | 6461. |
| | 1430 | 1.000 | 384. | 384. | 7880. | 8265. |
| ELBOW | 1430 | 2.267 | 384. | 384. | 17862. | 18246. |
| | 1431 | 2.267 | 384. | 384. | 14562. | 14947. |
| RUN | 1431 | 1.000 | 384. | 384. | 6425. | 6809. |
| | 1450 | 1.000 | 384. | 384. | 6393. | 6777. |
| ELBOW | 1450 | 2.267 | 384. | 384. | 14490. | 14875. |
| | 1451 | 2.267 | 384. | 384. | 17822. | 18207. |
| RUN | 1451 | 1.000 | 384. | 384. | 7863. | 8247. |
| | 1460 | 1.000 | 384. | 384. | 7258. | 7643. |
| ELBOW | 1460 | 2.267 | 384. | 384. | 16452. | 16836. |
| | 1461 | 2.267 | 384. | 384. | 15562. | 15947. |
| RUN | 1461 | 1.000 | 384. | 384. | 6866. | 7250. |
| | 1465 | 1.000 | 384. | 384. | 7567. | 7952. |



APPENDIX 6.5
INPUT AND OUTPUT DATA FOR NA PIPING TO RECEIVER
(LOWER MANIFOLD)



| REVISIONS | | | |
|-----------|--------------|------|----------|
| LTR | DESCRIPTION | DATE | APPROVED |
| | 0050-2-HCDA | | |
| | 0004-6-HCDA | | |
| | 0005-6-HCDA | | |
| | 0003-10-HCDA | | |

LOWER

| | | | | |
|-------------------------|-----|---------|---|----------------|
| DR BY | KCG | 3/22/68 | Rockwell International Corporation Atomic International Division | |
| CHK BY | | | | |
| CARRIZO PLAINS - UNIT 1 | | | SIZE | CODE IDENT NO. |
| M & P | | | B | 09974 |
| STRESS | | | SCALE | DRAWING NO. |
| | | | | SHEET 1 OF 1 |

079T1000008


| | | |
|-------------------------|--|----------------------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 214 |
| CHECKED BY: | | PAGE NO. OF 079TI000008 |
| DATE: <u>2/18/83</u> | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | No Lines to Receiver | REFERENCE | | |
|-------------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0004 - G - HCDA THRU 0011 - G - HCDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 6.625" / sch. 40 | | | |
| Pipe Thickness x | 0.280" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | — | | | |
| Weight of Pipe LBS/FT | 18.97 | | | |
| Weight of contents LBS/ft | .9 x 12.51 = 11.26 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} (18.625^2 - 6.625^2) \frac{14}{144}$ = 23.14 | | | |
| Total Weight ^x LBS/ft | 53.4 lbs/ft | | | |
| E _e ^x | 28.3 x 10 ⁶ psi | | | |
| Seismic Category | II | | | |


| | | |
|-------------------------|--|-------------------------------|
| PREPARED BY: <u>KLG</u> |  | 215 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <u>2/18/83</u> | | REPORT NO. <u>079TI000008</u> |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | LINE TO ACCUMULATOR TANK T-3 | REFERENCE | | |
|-------------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0013-12-HBDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 12.75" std. | | | |
| Pipe Thickness x | .375" | | | |
| Pipe Material | Carbon Steel | | | |
| Insulation Type | | | | |
| Weight of Pipe Lbs/Ft | 49.56 | | | |
| Weight of contents Lbs/ft | 19 x 49 = 44.1 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (24.75^2 - 12.75^2) \frac{14}{144}$ = 34.36 | | | |
| Total Weight ^x Lbs/ft | 128.0 | | | |
| E _c ^x | 27.9 x 10 ⁶ psi | | | |
| Seismic Category | III | | | |


| | | |
|-------------------------|---|-------------|
| PREPARED BY: <u>RCG</u> |  Rockwell International Energy Systems Group | 216 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: <u>2/18/83</u> | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | INLET HEADER FOR RECEIVER | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0003-14-HCDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 14.0" / sch 20 | | | |
| Pipe Thickness x | .375" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe LBS/ft | 55.0 | | | |
| Weight of contents LBS/ft | .9 x 59.7 = 53.7 | | | |
| Weight of Insulation LBS/ft | $\frac{\pi}{4} (38^2 - 14^2) \frac{14}{144} = 95.3$ | | | |
| Total Weight LBS/ft | 204.0 | | | |
| E_e^x | 28.3×10^6 psi | | | |
| Seismic Category | III | | | |


| | | |
|-------------------------|---|-------------------------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 217 |
| CHECKED BY: | | PAGE NO. _____ OF _____ |
| DATE: <u>3/18/83</u> | | REPORT NO. <u>079TI000008</u> |
| | | MODEL NO. _____ |

TABLE B-1
INPUT DATA

| SYSTEM | | REFERENCE | | |
|--------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0096-10-HCDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 10.75 / sch 40 | | | |
| Pipe Thickness x | .365" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe Lbs/ft | 40.48 | | | |
| Weight of contents Lbs/ft | 1.9 x 34.1 = 30.69 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (22.75^2 - 10.75^2) \times 14/144 = 30.69$ | | | |
| Total Weight Lbs/ft | 101.9 | | | |
| E _c ^x | 28.3 x 10 ⁶ | | | |
| Seismic Category | II | | | |



| | | |
|-------------------------|--|---------------------------|
| PREPARED BY: <u>KCG</u> |  Rockwell International Energy Systems Group | 218 PAGE NO. OF |
| CHECKED BY: | | 079TI000008 REPORT NO. |
| DATE: <u>8/18/83.</u> | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | By pass | REFERENCE | | |
|-------------------------------------|---|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0051-2-14 CDA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 2.375" / sch 40 | | | |
| Pipe Thickness x | .154" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe Lbs/Ft | 3.653 | | | |
| Weight of contents Lbs/ft | .9 x 1.455 = 1.310 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (14.375^2 - 2.375^2) \frac{14}{144}$ = 15.3 | | | |
| Total Weight ^x Lbs/ft | 20.3 | | | |
| E _c ^x | 28.3 x 10 ⁶ | | | |
| Seismic Category | III | | | |

| | | |
|------------------|---|-------------|
| PREPARED BY: KCL |  Rockwell International Energy Systems Group | 219 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 2/18/83 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

Allowable stress for SA-312, TP304 stainless steel.
For piping in and out of Receiver

$$S_A = f (1.25 S_c + 0.25 S_h)$$

f is a function equivalent full temperature cycles.

$$N = N_E + \rho_1^5 N_1 + \rho_2^5 N_2$$

$$N_E = \text{cycles corresponding to } 1100^\circ\text{F to } 70^\circ\text{F} \\ = 30 \text{ (assumed)}$$

$$N_1 = 22,000 \text{ Cycles}$$

$$N_2 = 28,000 \text{ Cycles}$$

$$\Delta T_E = 1100^\circ - 70 = 1030^\circ\text{F}$$

$$\Delta T_1 = 1100^\circ - 400^\circ = 700^\circ\text{F}$$

$$\Delta T_2 = 1100^\circ - 610^\circ = 490^\circ\text{F}$$


$$N = 30 + \left(\frac{\Delta T_1}{\Delta T_E}\right)^5 22000 + \left(\frac{\Delta T_2}{\Delta T_E}\right)^5 28000$$

$$= 30 + \left(\frac{700}{1030}\right)^5 \cdot 22000 + \left(\frac{490}{1030}\right)^5 \cdot 28000$$

$$= 30 + 3190 + 683$$

$$= 3903 < 7000 \text{ Cycles}$$

Therefore $f = 1.0$.

| | | |
|------------------|---|-------------|
| PREPARED BY: KCG |  Rockwell International Energy Systems Group | 220 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 2/18/83 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

$$S_c = 18.7 \text{ ksi}$$

$$S_h @ 1100^\circ F = 8.8 \text{ ksi}$$

$$S_A = 1.0 (1.25 \times 18.7 + 0.25 \times 8.8)$$

$$= 25.575 \text{ ksi}$$

$$S_h + S_A = 34.375 \text{ ksi}$$

$$S_h @ 610^\circ F = 11.36 \text{ ksi}$$

$$S_A = 1.0 (1.25 \times 18.7 + 0.25 \times 11.36)$$

$$= 26.215 \text{ ksi}$$

```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000
13:17:01 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
13:17:01 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
13:17:01 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
13:17:01 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
13:17:01 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=$WW232.CARRIZO.LOWER.MANIFOLD.DATA
13:17:01 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
13:17:01 IAT4401 LOCATE FOR STEP=G DD=FT69FOO1 DSN=$WWO49.ROCKPIPE.USERS
13:17:01 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
13:17:01 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
13:17:01 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
13:17:02 USES: CVTSOK D $WWO49.NUPIPE.LOAD
13:17:02 USES AVTSOA D $WW232.CARRIZO.LOWER.MANIFOLD.DATA
13:17:02 IAT5200 JOB 3911 ($WW232U2) IN SETUP ON MAIN=C P=03 LOCAL
13:17:02 IAT5210 J=3911 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
13:17:02 IAT5210 J=3911 FT15FOO1 USING D AVTSOA ON 520 $WW232.CARRIZO.LOWER.MANIFOLD.DATA
13:17:07 IAT2000 JOB 3911 $WW232U2 SELECTED I GRP=BIG
13:17:10 I R= $WW232U2 NEF995I $WW232U2 STARTED, 4/14/83,13.14.54 ASID=00053
13:17:10 I R= $WW232U2 IEF403I $WW232U2 - STARTED - TIME=13.14.54
13:17:35 I R= $WW232U2 +IH0002I STOP 1
13:17:36 I R= $WW232U2 IEF404I $WW232U2 - ENDED - TIME=13.15.20
13:17:36 I R= $WW232U2 NEF996I $WW232U2 ENDED, 4/14/83,B.U.= 1.0078 *0716935 ,3081-13,JOB CC= 001
13:17:37 IAT5400 JOB 3911 ($WW232U2) IN BREAKDOWN
/$WW232U2 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RMO05 00000300
/ EXEC ROCKPIPE,PROG=SMALL
/G.SYSIN DD DSN=$WW232.CARRIZO.LOWER.MANIFOLD.DATA,DISP=SHR
1 // $WW232U2 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
// REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
2 // EXEC ROCKPIPE,PROG=SMALL
3 XXROCKPIPE PROC DSN='$WWO49.NUPIPE.LOAD',PROG=SMALL,C=10,
XX PROGA=SEVEN,B=19069,PROGE=OPT2,DSNE='$WWO49.ELTEMP.LOAD',
XX USERS='$WWO49.ROCKPIPE.USERS'
*** AL HROMJAK ROCKWELL INTERNATIONAL, ESG. COMNET 393-3318
*** FT50FOO1 FOR 7-SPECTRA NODE ACCELERATIONS.
*** IN BOTH STEPS, FT66 CONTAINS DIAGNOSTIC OUTPUT.
*** FT66FOO1 IN G STEP CONTAINS TIME SPENT IN MAJOR PROGRAM PHASES.
*** FT16FOO1 DUMMIED WHEN P STEP DELETED.
*** FT17FOO1, FT18FOO1, FT19FOO1, FT20FOO1 ADDED FOR SNUBBER ITERATIONS
4 XXA EXEC PGM=&PROGA
*** THIS STEP READS THE 7 SPECTRA AND TRANSLATES THEM TO A NEW POINT
*** NEW SPECTRA WRITTEN ON FTO1FOO1
5 XXSTEPLIB DD DSN=&DSN,DISP=SHR
6 XXFTO1FOO1 DD UNIT=SYSDA,DSN=&&SPEC,SPACE=(TRK,(10),RLSE),DISP=(,PASS),
XX DCB=(RECFM=F,LRECL=80,BLKSIZE=80)
7 XXFTO5FOO1 DD DDNAME=SYSIN
8 XXFTO6FOO1 DD SYSOUT=*
9 XXFT66FOO1 DD DUMMY,DCB=(RECFM=VBA,BLKSIZE=2020)
10 XXG EXEC PGM=&PROG
*** THIS STEP EXECUTES ROCKPIPE. LOAD CASES, 7-SPECTRA (IF ANY), AND
*** GEOMETRY ARE READ FROM UNIT FT15'S 3 CONCATANATED DATA SETS. LOAD
*** CASES TO BE DELETED FROM PRINTING ARE DETECTED AND THE CASE NO.'S
*** MADE PLUS. ALL 3 FILES FROM FT15 ARE WRITTEN ON FTO5 AS ONE FILE TO
*** BE READ BY NUPIPE.
11 XXSTEPLIB DD DSN=&DSN,DISP=SHR
12 XXFTO1FOO1 DD UNIT=SYSDA,DCB=(RECFM=VBS,BLKSIZE=8B),
XX SPACE=(CYL,(8C,8C))
13 XXFTO2FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(8C,8C))
14 XXFTO3FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(8C,8C))
15 XXFTO4FOO1 DD UNIT=SYSDA,DCB=*.FTO1FOO1,SPACE=(CYL,(8C,8C))

```


ORIGINAL INPUT BY GURSAHANI ON 04/14/83 AT 13:15:03 WITH PRIORITY 3
 CARRIZO LOWER MANIFOLD AND 14" HEADER UPTO THE TANK

| | | | | | | | | |
|-------------------------------|-------|-------|--------|---------|--------|-----|--|----|
| CONTROL | | 2.0 | 1.0 | | | | | 1 |
| FLEXAN | 1 | 1 | 2.0 | | | | | 2 |
| THERMAL AT DESIGN TEMPERATURE | | | | | | | | 3 |
| XSECTN | 1 | 14.00 | 0.375 | 204.0 | 28.3 | 65. | | 4 |
| XSECTN | 2 | 12.75 | 0.375 | 128.5 | 28.3 | 65. | | 5 |
| XSECTN | 3 | 10.75 | 0.365 | 101.9 | 28.3 | 65. | | 6 |
| XSECTN | 4 | 6.625 | 0.280 | 53.4 | 28.3 | 65. | | 7 |
| XSECTN | 5 | 2.375 | 0.154 | 20.3 | 28.3 | 65. | | 8 |
| XSECTN | 6 | 12.75 | 0.375 | 128.5 | 27.9 | 65. | | 9 |
| OPVAL 610 | 1 | 1 | 25.34 | .06366 | | 65. | | 10 |
| OPVAL 610 | 1 | 2 | 25.61 | .04702 | | 65. | | 11 |
| ANCHOR | | 5310 | | | | | | 12 |
| RUN | 5310 | 5305 | 1.0 | | 1.0 | 1.0 | | 13 |
| TEE | 5305 | 6110 | 2.806 | | | | | 14 |
| RUN | 5305 | 5300 | 3.0 | | | | | 15 |
| TEE | 5300 | 5525 | 2.806 | | | | | 16 |
| RUN | 5300 | 5200 | 3.5 | | | | | 17 |
| TEE | 5200 | 6210 | 2.806 | | | | | 18 |
| RUN | 5200 | 5150 | 3.25 | | | | | 19 |
| RESTRAINT | | 5150 | | 50000. | 50000. | | | 20 |
| RUN | 5150 | 5100 | 3.25 | | | | | 21 |
| TEE | 5100 | 6310 | 2.806 | | | | | 22 |
| RUN | 5100 | 5095 | 3.25 | | | | | 23 |
| RUN | 5095 | 5090 | 3.25 | | | | | 24 |
| TEE | 5090 | 6410 | 2.806 | | | | | 25 |
| RUN | 5090 | 5085 | 1.5 | | | | | 26 |
| RUN | 5085 | 5080 | 1.5 | | | | | 27 |
| ELBOW | -5080 | 5075 | | | | | | 28 |
| RUN | 5075 | 5070 | | 6.0 | | | | 29 |
| TEE | 5070 | 5062 | 2.806 | | | | | 30 |
| RUN | 5070 | 5065 | 0.92 | | | | | 31 |
| RUN | 5070 | 5062 | -.459 | | .794 | | | 32 |
| RUN | 5062 | 5060 | -2.572 | | 4.456 | | | 33 |
| ELBOW | -5060 | 5055 | | | | | | 34 |
| RUN | 5055 | 5050 | | -6.0 | | | | 35 |
| ELBOW | -5050 | 5045 | | | | | | 36 |
| RUN | 5045 | 5040 | -1.5 | | | | | 37 |
| VALVE | 5040 | 5035 | -0.5 | | | | | 38 |
| VALVE | 5035 | 5030 | -0.5 | | | | | 39 |
| RUN | 5030 | 5025 | -1.5 | | | | | 40 |
| REDUCER | 5025 | 5024 | -1.083 | | 3.0 | | | 41 |
| RUN | 5024 | 5022 | -3.0 | | | | | 42 |
| RESTRAINT | | 5022 | | 50000. | 50000. | | | 43 |
| RUN | 5022 | 5020 | -5.75 | | | | | 44 |
| VALVE | 5020 | 5015 | -1.5 | | | | | 45 |
| VALVE | 5015 | 5013 | -1.5 | | | | | 46 |
| RUN | 5013 | 5010 | -2.0 | | | | | 47 |
| RUN | 5010 | 5005 | -2.333 | | | | | 48 |
| REDUCER | 5005 | 5004 | -0.667 | | | | | 49 |
| RUN | 5004 | 5000 | -.833 | | 2.0 | | | 50 |
| TEE | 5000 | 5004 | | | | | | 51 |
| RUN | 5000 | 5475 | | -.0.833 | 6.0 | 2.0 | | 52 |
| RUN | 5475 | 5480 | | -0.417 | | | | 53 |
| RUN | 5480 | 5482 | | -0.75 | | | | 54 |
| ANCHOR | | 5482 | | | | | | 55 |
| RUN | 5000 | 5405 | | 0.833 | | | | 56 |
| RUN | 5405 | 5410 | | 11.167 | | | | 57 |
| ELBOW | -5410 | 5420 | | | | | | 58 |
| | | | | | | | | 59 |

| | | | | | | | | | | |
|---------|-------|------|-------|--|-------|--|--|-------|-----|-----|
| DUMMY | 5410 | 5420 | | | | | | 1.0 | | 60 |
| DUMMY | 5420 | 5425 | | | | | | 1.0 | | 61 |
| ELBOW | -5420 | 5425 | | | | | | | | 62 |
| RUN | 5425 | 5430 | | | 6.0 | | | | | 63 |
| ELBOW | -5430 | 5435 | | | | | | | | 64 |
| RUN | 5435 | 5440 | -10.0 | | | | | | | 65 |
| ELBOW | -5440 | 5445 | | | | | | | | 66 |
| RUN | 5445 | 5450 | | | 13.0 | | | | | 67 |
| ELBOW | -5450 | 5455 | | | | | | | | 68 |
| RUN | 5455 | 5460 | 14.5 | | | | | | | 69 |
| ELBOW | -5460 | 5465 | | | | | | | | 70 |
| RUN | 5465 | 5470 | | | 6.5 | | | | | 71 |
| ANCHOR | | 5470 | | | | | | | | 72 |
| STDISPL | 1 | 5470 | -.41 | | -0.55 | | | | | 73 |
| BRANCH | 5480 | 5485 | | | | | | -1.75 | 5.0 | 74 |
| ELBOW | -5485 | 5490 | | | | | | | 1.0 | 75 |
| GRUN | 5490 | 5495 | -3.0 | | | | | | | 76 |
| ELBOW | -5495 | 5496 | | | | | | | | 77 |
| GRUN | 5496 | 5500 | | | | | | -1.75 | | 78 |
| ELBOW | -5500 | 5503 | | | | | | | | 79 |
| GRUN | 5503 | 5504 | 2.5 | | | | | | | 80 |
| VALVE | 5504 | 5505 | 0.5 | | | | | | | 81 |
| VALVE | 5505 | 5506 | 0.5 | | | | | | | 82 |
| GRUN | 5506 | 5510 | 6.5 | | | | | | | 83 |
| ELBOW | -5510 | 5515 | | | | | | | | 84 |
| GRUN | 5515 | 5520 | | | | | | -1.75 | | 85 |
| ELBOW | -5520 | 5525 | | | | | | | | 86 |
| GRUN | 5525 | 5300 | | | 1.25 | | | | | 87 |
| RUN | 5305 | 6110 | | | 2.0 | | | 4.0 | | 88 |
| ELBOW | -6110 | 6111 | | | | | | | | 89 |
| RUN | 6111 | 6130 | 4.95 | | | | | -4.95 | | 90 |
| ELBOW | -6130 | 6131 | | | | | | | | 91 |
| RUN | 6131 | 6150 | -4.95 | | | | | -4.95 | | 92 |
| ELBOW | -6150 | 6151 | | | | | | | | 93 |
| RUN | 6151 | 6160 | 2.3 | | | | | -2.3 | | 94 |
| ELBOW | -6160 | 6161 | | | | | | | | 95 |
| RUN | 6161 | 6165 | | | 2.0 | | | | | 96 |
| ANCHOR | | 6165 | | | | | | | | 97 |
| RUN | 5200 | 6210 | | | 2.0 | | | | | 98 |
| ELBOW | -6210 | 6211 | | | | | | | | 99 |
| RUN | 6211 | 6230 | 4.95 | | | | | -4.95 | | 100 |
| ELBOW | -6230 | 6231 | | | | | | | | 101 |
| RUN | 6231 | 6250 | -4.95 | | | | | -4.95 | | 102 |
| ELBOW | -6250 | 6251 | | | | | | | | 103 |
| RUN | 6251 | 6260 | 2.3 | | | | | -2.3 | | 104 |
| ELBOW | -6260 | 6261 | | | | | | | | 105 |
| RUN | 6261 | 6265 | | | 2.0 | | | | | 106 |
| ANCHOR | | 6265 | | | | | | | | 107 |
| RUN | 5100 | 6310 | | | 2.0 | | | | | 108 |
| ELBOW | -6310 | 6311 | | | | | | | | 109 |
| RUN | 6311 | 6330 | 4.95 | | | | | -4.95 | | 110 |
| ELBOW | -6330 | 6331 | | | | | | | | 111 |
| RUN | 6331 | 6350 | -4.95 | | | | | -4.95 | | 112 |
| ELBOW | -6350 | 6351 | | | | | | | | 113 |
| RUN | 6351 | 6360 | 2.3 | | | | | -2.3 | | 114 |
| ELBOW | -6360 | 6361 | | | | | | | | 115 |
| RUN | 6361 | 6365 | | | 2.0 | | | | | 116 |
| ANCHOR | | 6365 | | | | | | | | 117 |
| RUN | 5090 | 6410 | | | 2.0 | | | | | 118 |
| ELBOW | -6410 | 6411 | | | | | | | | 119 |
| RUN | 6411 | 6430 | 4.95 | | | | | -4.95 | | 120 |
| ELBOW | -6430 | 6431 | | | | | | | | 121 |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 5310 | 1.000 | 607. | 607. | 4590. | 5196. |
| | 5305 | 2.806 | 607. | 607. | 10439. | 11046. |
| RUN | 5305 | 2.806 | 607. | 607. | 6345. | 6952. |
| | 5300 | 2.806 | 607. | 607. | 4452. | 5059. |
| RUN | 5300 | 2.806 | 607. | 607. | 4506. | 5113. |
| | 5200 | 2.806 | 607. | 607. | 2525. | 3131. |
| RUN | 5200 | 2.806 | 607. | 607. | 663. | 1270. |
| | 5150 | 1.000 | 607. | 607. | 1169. | 1775. |
| RUN | 5150 | 1.000 | 607. | 607. | 1169. | 1775. |
| | 5100 | 2.806 | 607. | 607. | 2480. | 3087. |
| RUN | 5100 | 2.806 | 607. | 607. | 3528. | 4135. |
| | 5095 | 1.000 | 607. | 607. | 1400. | 2006. |
| RUN | 5095 | 1.000 | 607. | 607. | 1400. | 2006. |
| | 5090 | 2.806 | 607. | 607. | 4339. | 4946. |
| RUN | 5090 | 2.806 | 607. | 607. | 5229. | 5835. |
| | 5085 | 1.000 | 607. | 607. | 1674. | 2281. |
| RUN | 5085 | 1.000 | 607. | 607. | 1674. | 2281. |
| | 5080 | 1.000 | 607. | 607. | 1687. | 2294. |
| ELBOW | 5080 | 2.938 | 607. | 607. | 4956. | 5563. |
| | 5075 | 2.938 | 607. | 607. | 2033. | 2640. |
| RUN | 5075 | 1.000 | 607. | 607. | 692. | 1299. |
| | 5070 | 2.806 | 607. | 607. | 6530. | 7137. |
| RUN | 5070 | 2.806 | 607. | 607. | 0. | 607. |
| | 5065 | 1.000 | 607. | 607. | 0. | 607. |
| RUN | 5070 | 2.806 | 607. | 607. | 6530. | 7137. |
| | 5062 | 1.000 | 607. | 607. | 2423. | 3030. |
| RUN | 5062 | 1.000 | 607. | 607. | 2423. | 3030. |
| | 5060 | 1.000 | 607. | 607. | 2853. | 3460. |

079T1000008
225

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| ELBOW | 5060 | 2.938 | 607. | 607. | 8383. | 8990. |
| | 5055 | 2.938 | 607. | 607. | 6375. | 6982. |
| RUN | 5055 | 1.000 | 607. | 607. | 2170. | 2776. |
| | 5050 | 1.000 | 607. | 607. | 1533. | 2139. |
| ELBOW | 5050 | 2.938 | 607. | 607. | 4504. | 5110. |
| | 5045 | 2.938 | 607. | 607. | 4127. | 4734. |
| RUN | 5045 | 1.000 | 607. | 607. | 1405. | 2011. |
| | 5040 | 1.000 | 607. | 607. | 1477. | 2084. |
| RUN | 5030 | 1.000 | 607. | 607. | 1229. | 1836. |
| | 5025 | 1.000 | 607. | 607. | 1152. | 1758. |
| REDUCE | 5025 | 2.000 | 479. | 479. | 4073. | 4552. |
| | 5024 | 2.000 | 479. | 479. | 4751. | 5230. |
| RUN | 5024 | 1.000 | 479. | 479. | 2376. | 2854. |
| | 5022 | 1.000 | 479. | 479. | 4262. | 4741. |
| RUN | 5022 | 1.000 | 479. | 479. | 4262. | 4741. |
| | 5020 | 1.000 | 479. | 479. | 2710. | 3188. |
| RUN | 5013 | 1.000 | 479. | 479. | 2335. | 2814. |
| | 5010 | 1.000 | 479. | 479. | 2371. | 2850. |
| RUN | 5010 | 1.000 | 479. | 479. | 2371. | 2850. |
| | 5005 | 1.000 | 479. | 479. | 2695. | 3174. |
| REDUCE | 5005 | 2.000 | 479. | 479. | 5391. | 5869. |
| | 5004 | 2.000 | 479. | 479. | 5665. | 6143. |
| RUN | 5004 | 1.000 | 553. | 553. | 1941. | 2494. |
| | 5000 | 2.173 | 553. | 553. | 4505. | 5058. |
| RUN | 5000 | 2.173 | 553. | 553. | 3848. | 4400. |
| | 5475 | 1.000 | 553. | 553. | 1930. | 2482. |
| RUN | 5475 | 1.000 | 553. | 553. | 1930. | 2482. |
| | 5480 | 1.000 | 553. | 553. | 2060. | 2612. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 5480 | 1.000 | 553. | 553. | 2076. | 2628. |
| | 5482 | 1.000 | 553. | 553. | 2393. | 2945. |
| RUN | 5000 | 2.173 | 553. | 553. | 5669. | 6222. |
| | 5405 | 1.000 | 553. | 553. | 2591. | 3143. |
| RUN | 5405 | 1.000 | 553. | 553. | 2591. | 3143. |
| | 5410 | 1.000 | 553. | 553. | 2456. | 3009. |
| ELBOW | 5410 | 2.864 | 553. | 553. | 7034. | 7587. |
| | 5420 | 2.864 | 553. | 553. | 6365. | 6917. |
| ELBOW | 5420 | 2.864 | 553. | 553. | 6365. | 6917. |
| | 5425 | 2.864 | 553. | 553. | 6650. | 7202. |
| RUN | 5425 | 1.000 | 553. | 553. | 2322. | 2874. |
| | 5430 | 1.000 | 553. | 553. | 2182. | 2735. |
| ELBOW | 5430 | 2.864 | 553. | 553. | 6249. | 6802. |
| | 5435 | 2.864 | 553. | 553. | 3519. | 4071. |
| RUN | 5435 | 1.000 | 553. | 553. | 1229. | 1781. |
| | 5440 | 1.000 | 553. | 553. | 3503. | 4056. |
| ELBOW | 5440 | 2.864 | 553. | 553. | 10034. | 10586. |
| | 5445 | 2.864 | 553. | 553. | 12861. | 13413. |
| RUN | 5445 | 1.000 | 553. | 553. | 4490. | 5043. |
| | 5450 | 1.000 | 553. | 553. | 4767. | 5319. |
| ELBOW | 5450 | 2.864 | 553. | 553. | 13652. | 14204. |
| | 5455 | 2.864 | 553. | 553. | 11032. | 11585. |
| RUN | 5455 | 1.000 | 553. | 553. | 3852. | 4405. |
| | 5460 | 1.000 | 553. | 553. | 3570. | 4123. |
| ELBOW | 5460 | 2.864 | 553. | 553. | 10225. | 10778. |
| | 5465 | 2.864 | 553. | 553. | 12860. | 13413. |
| RUN | 5465 | 1.000 | 553. | 553. | 4490. | 5043. |
| | 5470 | 1.000 | 553. | 553. | 4365. | 4917. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| BRANCH | 5480 | 1.000 | 251. | 251. | 5929. | 6179. |
| | 5485 | 1.000 | 251. | 251. | 2509. | 2759. |
| ELBOW | 5485 | 1.732 | 251. | 251. | 4346. | 4597. |
| | 5490 | 1.732 | 251. | 251. | 3078. | 3328. |
| GRUN | 5490 | 1.800 | 251. | 251. | 3198. | 3449. |
| | 5495 | 1.800 | 251. | 251. | 832. | 1082. |
| ELBOW | 5495 | 1.732 | 251. | 251. | 800. | 1051. |
| | 5496 | 1.732 | 251. | 251. | 1346. | 1597. |
| GRUN | 5496 | 1.800 | 251. | 251. | 1399. | 1649. |
| | 5500 | 1.800 | 251. | 251. | 6295. | 6545. |
| ELBOW | 5500 | 1.732 | 251. | 251. | 6058. | 6309. |
| | 5503 | 1.732 | 251. | 251. | 6748. | 6999. |
| GRUN | 5503 | 1.800 | 251. | 251. | 7011. | 7262. |
| | 5504 | 1.800 | 251. | 251. | 4303. | 4554. |
| GRUN | 5506 | 1.800 | 251. | 251. | 3106. | 3357. |
| | 5510 | 1.800 | 251. | 251. | 4517. | 4767. |
| ELBOW | 5510 | 1.732 | 251. | 251. | 4347. | 4598. |
| | 5515 | 1.732 | 251. | 251. | 3700. | 3951. |
| GRUN | 5515 | 1.800 | 251. | 251. | 3845. | 4095. |
| | 5520 | 1.800 | 251. | 251. | 2067. | 2318. |
| ELBOW | 5520 | 1.732 | 251. | 251. | 1989. | 2240. |
| | 5525 | 1.732 | 251. | 251. | 2475. | 2726. |
| GRUN | 5525 | 1.800 | 251. | 251. | 2572. | 2822. |
| | 5300 | 2.806 | 251. | 251. | 3447. | 3698. |
| RUN | 5305 | 2.806 | 384. | 384. | 19225. | 19610. |
| | 6110 | 1.000 | 384. | 384. | 7846. | 8231. |
| ELBOW | 6110 | 2.267 | 384. | 384. | 17785. | 18169. |
| | 6111 | 2.267 | 384. | 384. | 14877. | 15261. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|--------------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 6111 6130 | 1.000 1.000 | 384. 384. | 384. 384. | 6563. 10600. | 6948. 10984. |
| ELBOW | 6130 6131 | 2.267 2.267 | 384. 384. | 384. 384. | 24026. 23666. | 24410. 24050. |
| RUN | 6131 6150 | 1.000 1.000 | 384. 384. | 384. 384. | 10441. 6655. | 10826. 7040. |
| ELBOW | 6150 6151 | 2.267 2.267 | 384. 384. | 384. 384. | 15085. 15619. | 15469. 16004. |
| RUN | 6151 6160 | 1.000 1.000 | 384. 384. | 384. 384. | 6891. 2966. | 7275. 3351. |
| ELBOW | 6160 6161 | 2.267 2.267 | 384. 384. | 384. 384. | 6724. 1994. | 7108. 2378. |
| RUN | 6161 6165 | 1.000 1.000 | 384. 384. | 384. 384. | 880. 5665. | 1264. 6049. |
| RUN | 5200 6210 | 2.806 1.000 | 384. 384. | 384. 384. | 12605. 4272. | 12989. 4656. |
| ELBOW | 6210 6211 | 2.267 2.267 | 384. 384. | 384. 384. | 9683. 9084. | 10067. 9468. |
| RUN | 6211 6230 | 1.000 1.000 | 384. 384. | 384. 384. | 4008. 10576. | 4392. 10961. |
| ELBOW | 6230 6231 | 2.267 2.267 | 384. 384. | 384. 384. | 23973. 22651. | 24357. 23035. |
| RUN | 6231 6250 | 1.000 1.000 | 384. 384. | 384. 384. | 9993. 7108. | 10378. 7493. |
| ELBOW | 6250 6251 | 2.267 2.267 | 384. 384. | 384. 384. | 16112. 17542. | 16496. 17926. |
| RUN | 6251 6260 | 1.000 1.000 | 384. 384. | 384. 384. | 7739. 4139. | 8124. 4524. |

079T1000008
229

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| ELBOW | 6260 | 2.267 | 384. | 384. | 9382. | 9767. |
| | 6261 | 2.267 | 384. | 384. | 3898. | 4282. |
| RUN | 6261 | 1.000 | 384. | 384. | 1720. | 2104. |
| | 6265 | 1.000 | 384. | 384. | 5396. | 5780. |
| RUN | 5100 | 2.806 | 384. | 384. | 8715. | 9100. |
| | 6310 | 1.000 | 384. | 384. | 914. | 1298. |
| ELBOW | 6310 | 2.267 | 384. | 384. | 2072. | 2456. |
| | 6311 | 2.267 | 384. | 384. | 6227. | 6611. |
| RUN | 6311 | 1.000 | 384. | 384. | 2747. | 3132. |
| | 6330 | 1.000 | 384. | 384. | 10326. | 10711. |
| ELBOW | 6330 | 2.267 | 384. | 384. | 23406. | 23790. |
| | 6331 | 2.267 | 384. | 384. | 21188. | 21573. |
| RUN | 6331 | 1.000 | 384. | 384. | 9348. | 9732. |
| | 6350 | 1.000 | 384. | 384. | 7518. | 7902. |
| ELBOW | 6350 | 2.267 | 384. | 384. | 17040. | 17424. |
| | 6351 | 2.267 | 384. | 384. | 19325. | 19709. |
| RUN | 6351 | 1.000 | 384. | 384. | 8526. | 8910. |
| | 6360 | 1.000 | 384. | 384. | 5663. | 6048. |
| ELBOW | 6360 | 2.267 | 384. | 384. | 12836. | 13221. |
| | 6361 | 2.267 | 384. | 384. | 9094. | 9478. |
| RUN | 6361 | 1.000 | 384. | 384. | 4012. | 4396. |
| | 6365 | 1.000 | 384. | 384. | 6239. | 6624. |
| RUN | 5090 | 2.806 | 384. | 384. | 10232. | 10616. |
| | 6410 | 1.000 | 384. | 384. | 1942. | 2327. |
| ELBOW | 6410 | 2.267 | 384. | 384. | 4402. | 4787. |
| | 6411 | 2.267 | 384. | 384. | 8086. | 8471. |
| RUN | 6411 | 1.000 | 384. | 384. | 3568. | 3952. |
| | 6430 | 1.000 | 384. | 384. | 10329. | 10714. |


079T1000008
230

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| ELBOW | 6430 | 2.267 | 384. | 384. | 23412. | 23797. |
| | 6431 | 2.267 | 384. | 384. | 20390. | 20774. |
| RUN | 6431 | 1.000 | 384. | 384. | 8996. | 9380. |
| | 6450 | 1.000 | 384. | 384. | 8201. | 8585. |
| ELBOW | 6450 | 2.267 | 384. | 384. | 18588. | 18972. |
| | 6451 | 2.267 | 384. | 384. | 21655. | 22039. |
| RUN | 6451 | 1.000 | 384. | 384. | 9554. | 9938. |
| | 6460 | 1.000 | 384. | 384. | 7308. | 7693. |
| ELBOW | 6460 | 2.267 | 384. | 384. | 16565. | 16950. |
| | 6461 | 2.267 | 384. | 384. | 13990. | 14375. |
| RUN | 6461 | 1.000 | 384. | 384. | 6172. | 6557. |
| | 6465 | 1.000 | 384. | 384. | 7885. | 8269. |



APPENDIX 6.6
INPUT AND OUTPUT DATA FOR SODIUM PIPING IN TOWER




| | | |
|------------------|--|-------------|
| PREPARED BY: KCG |  Rockwell International Energy Systems Group | 234 |
| CHECKED BY: | | PAGE NO. OF |
| DATE: 4-18-83 | | 079TI000008 |
| | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | Tower Piping | REFERENCE | | |
|--------------------------------|--|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0013-12-HB DA | | | |
| Design Temperature | 610° F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 610° F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 12.75"/sch 40 | | | |
| Pipe Thickness x | .375" | | | |
| Pipe Material | CS | | | |
| Insulation Type | - | | | |
| Weight of Pipe LBS/FT | 49.56 | | | |
| Weight of contents Lbs/ft | 9 x 49 = 44.1 | | | |
| Weight of Insulation Lbs/ft | $\frac{\pi}{4} (24.75^2 - 12.75^2) \frac{14}{144}$ = 34.4 | | | |
| Total Weight LBS/ft | 128.5 | | | |
| E_e^x | 27.9×10^6 psi | | | |
| Seismic Category | I | | | |


| | | |
|-------------------------|---|--------------------------------|
| PREPARED BY: <u>KCQ</u> |  Rockwell International Energy Systems Group | 235 |
| CHECKED BY: | | PAGE NO. <u>079TI000008</u> OF |
| DATE: <u>4-18-83</u> | | REPORT NO. |
| | | MODEL NO. |

TABLE B-1
INPUT DATA

| SYSTEM | Tower Pipings | REFERENCE | | |
|---------------------------------------|------------------|-----------|------|------|
| | | NO. | REV. | PAGE |
| Line Number | 0024-8-GCDA | | | |
| Design Temperature | 1100°F | | | |
| Design Pressure | 65 psi | | | |
| Normal operating Temperature | 1055°F | | | |
| Normal operating Pressure | 65 psi | | | |
| Pipe O.D./schedule | 8.625" / sch. 40 | | | |
| Pipe Thickness x | .322" | | | |
| Pipe Material | SS 304 | | | |
| Insulation Type | - | | | |
| Weight of Pipe Lbs / Ft | 28.55 | | | |
| Weight of contents Lbs / ft | 9 x 21.69 = 19.5 | | | |
| Weight of Insulation Lbs / ft | - | | | |
| Total Weight ^x Lbs / ft | 48.1 | | | |
| E _e ^x | 28.3 | | | |
| Seismic Category | I | | | |

```

IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP. DEVICE=INTRDR , OOO
09:49:15 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
09:49:15 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:49:15 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=$WWO49.NUPIPE.LOAD
09:49:15 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:49:15 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=$WW232.CARRIZO.RISER.CS610.DATA
09:49:15 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA
09:49:15 IAT4401 LOCATE FOR STEP=G DD=FT69FOO1 DSN=$WWO49.ROCKPIPE.USERS
09:49:15 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:49:15 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=$WWO49.ELTEMP.LOAD
09:49:15 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK
09:49:16 USES CVTSOK 01 043546 D $WWO49.NUPIPE.LOAD
09:49:16 USES AVTSOA 01 043546 D $WW232.CARRIZO.RISER.CS610.DATA
09:49:38 IAT5200 JOB 0890 ($WW232A2) IN SETUP ON MAIN=I P=03 LOCAL
09:49:38 IAT5210 J=0890 STEPLIB USING D CVTSOK ON 528 $WWO49.NUPIPE.LOAD
09:49:38 IAT5210 J=0890 FT15FOO1 USING D AVTSOA ON 520 $WW232.CARRIZO.RISER.CS610.DATA
09:51:07 IAT2000 JOB 0890 $WW232A2 SELECTED I GRP=BIG
09:51:09 I R= $WW232A2 NEF995I $WW232A2 STARTED, 4/18/83,09.51.29 ASID=00017
09:51:09 I R= $WW232A2 IEF403I $WW232A2 - STARTED - TIME=09.51.29
09:51:39 I R= $WW232A2 +IH0002I STOP 1
09:51:40 I R= $WW232A2 IEF404I $WW232A2 - ENDED - TIME=09.52.00
09:51:40 I R= $WW232A2 NEF996I $WW232A2 ENDED, 4/18/83,B.U.= .7241 *0716935 ,3081-13,JOB CC= 001
09:51:41 IAT5400 JOB 0890 ($WW232A2) IN BREAKDOWN
/$WW232A2 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', *
/ REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=$WW232
/*MAIN ORG=RMO05,SYSTEM=/C 00000300
/ EXEC ROCKPIPE,PROG=SMALL
/G.SYSIN DD DSN=$WW232.CARRIZO.RISER.CS610.DATA,DISP=SHR

```

079T1000008
236

ORIGINAL INPUT BY GURSAHANI ON 04/18/83 AT 09:51:37 WITH PRIORITY 3
 CARRIZO 12" CS DOWNCOMER

| | | | | | | | | | |
|-------------------------------|---|-----|-------|---------|--------|---------|-----|--|----|
| CONTROL | | | 2.0 | | | | | | 1 |
| FLEXAN | 1 | 1 | 2.0 | | | | | | 2 |
| THERMAL AT DESIGN TEMPERATURE | | | | | | | | | |
| XSECTN | | 1 | 12.75 | 0.375 | 128.5 | 27.9 | 65. | | 3 |
| OPVAL 610 | 1 | 1 | 25.61 | .04702 | | | 65. | | 4 |
| ANCHOR | | | | | | | | | 5 |
| RUN | | 5 | 10 | -3.5 | | 1.0 | 1.0 | | 6 |
| ELBOW | - | 10 | 15 | | | | | | 7 |
| RUN | | 15 | 20 | 8.0 | | | | | 8 |
| RUN | | 20 | 25 | 8.167 | | | | | 9 |
| ELBOW | - | 25 | 30 | | | | | | 10 |
| RUN | | 30 | 35 | | | | | | 11 |
| ELBOW | - | 35 | 40 | | | | | | 12 |
| RUN | | 40 | 45 | -20.5 | | | | | 13 |
| RUN | | 45 | 50 | -20.5 | | | | | 14 |
| ELBOW | - | 50 | 55 | | | | | | 15 |
| RUN | | 55 | 60 | -14.5 | | | | | 16 |
| RUN | | 60 | 65 | -14.5 | | | | | 17 |
| ELBOW | - | 65 | 70 | | | | | | 18 |
| RUN | | 70 | 75 | -11.5 | | | | | 19 |
| RUN | | 75 | 80 | -11.5 | | | | | 20 |
| ANCHOR | | | 80 | -12.833 | -67.5 | -17.833 | | | 21 |
| RUN | | 80 | 105 | -11.5 | | | | | 22 |
| RUN | | 105 | 110 | -11.5 | | | | | 23 |
| ELBOW | - | 110 | 115 | | | | | | 24 |
| RUN | | 115 | 120 | 14.75 | | | | | 25 |
| RUN | | 120 | 125 | 14.75 | | | | | 26 |
| ELBOW | - | 125 | 130 | | | | | | 27 |
| RUN | | 130 | 135 | -20.5 | | | | | 28 |
| RUN | | 135 | 140 | -20.5 | | | | | 29 |
| ELBOW | - | 140 | 145 | | | | | | 30 |
| RUN | | 145 | 150 | -16.5 | | | | | 31 |
| RUN | | 150 | 155 | -16.5 | | | | | 32 |
| ELBOW | - | 155 | 160 | | | | | | 33 |
| RUN | | 160 | 165 | -11.5 | | | | | 34 |
| RUN | | 165 | 170 | -11.5 | | | | | 35 |
| ANCHOR | | | 170 | -16.333 | -154.5 | -17.833 | | | 36 |
| RUN | | 170 | 205 | -11.5 | | | | | 37 |
| RUN | | 205 | 210 | -11.5 | | | | | 38 |
| ELBOW | - | 210 | 215 | | | | | | 39 |
| RUN | | 215 | 220 | 19.0 | | | | | 40 |
| RUN | | 220 | 225 | 19.0 | | | | | 41 |
| ELBOW | - | 225 | 230 | | | | | | 42 |
| RUN | | 230 | 235 | -20.5 | | | | | 43 |
| RUN | | 235 | 240 | -20.5 | | | | | 44 |
| ELBOW | - | 240 | 245 | | | | | | 45 |
| RUN | | 245 | 250 | -20.75 | | | | | 46 |
| RUN | | 250 | 255 | -20.75 | | | | | 47 |
| ELBOW | - | 255 | 260 | | | | | | 48 |
| RUN | | 260 | 265 | -11.5 | | | | | 49 |
| RUN | | 265 | 270 | -11.5 | | | | | 50 |
| ANCHOR | | | 270 | -19.833 | -241.5 | -17.833 | | | 51 |
| RUN | | 270 | 305 | -11.5 | | | | | 52 |
| RUN | | 305 | 310 | -11.5 | | | | | 53 |
| ELBOW | - | 310 | 315 | | | | | | 54 |
| RUN | | 315 | 320 | 22.25 | | | | | 55 |
| RUN | | 320 | 325 | 22.25 | | | | | 56 |
| ELBOW | - | 325 | 330 | | | | | | 57 |
| | | | | | | | | | 58 |
| | | | | | | | | | 59 |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 5 | 1.000 | 553. | 553. | 2554. | 3107. |
| | 10 | 1.000 | 553. | 553. | 2511. | 3063. |
| ELBOW | 10 | 2.864 | 553. | 553. | 7191. | 7744. |
| | 15 | 2.864 | 553. | 553. | 6557. | 7109. |
| RUN | 15 | 1.000 | 553. | 553. | 2289. | 2842. |
| | 20 | 1.000 | 553. | 553. | 1582. | 2134. |
| RUN | 20 | 1.000 | 553. | 553. | 1582. | 2134. |
| | 25 | 1.000 | 553. | 553. | 1335. | 1888. |
| ELBOW | 25 | 2.864 | 553. | 553. | 3825. | 4377. |
| | 30 | 2.864 | 553. | 553. | 3338. | 3890. |
| RUN | 30 | 1.000 | 553. | 553. | 1165. | 1718. |
| | 35 | 1.000 | 553. | 553. | 1363. | 1916. |
| ELBOW | 35 | 2.864 | 553. | 553. | 3905. | 4457. |
| | 40 | 2.864 | 553. | 553. | 4474. | 5026. |
| RUN | 40 | 1.000 | 553. | 553. | 1562. | 2115. |
| | 45 | 1.000 | 553. | 553. | 1676. | 2228. |
| RUN | 45 | 1.000 | 553. | 553. | 1676. | 2228. |
| | 50 | 1.000 | 553. | 553. | 2374. | 2926. |
| ELBOW | 50 | 2.864 | 553. | 553. | 6799. | 7351. |
| | 55 | 2.864 | 553. | 553. | 6331. | 6884. |
| RUN | 55 | 1.000 | 553. | 553. | 2211. | 2763. |
| | 60 | 1.000 | 553. | 553. | 212. | 764. |
| RUN | 60 | 1.000 | 553. | 553. | 212. | 764. |
| | 65 | 1.000 | 553. | 553. | 1803. | 2355. |
| ELBOW | 65 | 2.864 | 553. | 553. | 5163. | 5716. |
| | 70 | 2.864 | 553. | 553. | 5637. | 6189. |
| RUN | 70 | 1.000 | 553. | 553. | 1968. | 2521. |
| | 75 | 1.000 | 553. | 553. | 1582. | 2135. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 75 | 1.000 | 553. | 553. | 1582. | 2135. |
| | 80 | 1.000 | 553. | 553. | 1330. | 1882. |
| RUN | 80 | 1.000 | 553. | 553. | 1816. | 2368. |
| | 105 | 1.000 | 553. | 553. | 1738. | 2290. |
| RUN | 105 | 1.000 | 553. | 553. | 1738. | 2290. |
| | 110 | 1.000 | 553. | 553. | 1670. | 2223. |
| ELBOW | 110 | 2.864 | 553. | 553. | 4783. | 5336. |
| | 115 | 2.864 | 553. | 553. | 4271. | 4824. |
| RUN | 115 | 1.000 | 553. | 553. | 1491. | 2044. |
| | 120 | 1.000 | 553. | 553. | 2. | 555. |
| RUN | 120 | 1.000 | 553. | 553. | 2. | 555. |
| | 125 | 1.000 | 553. | 553. | 1487. | 2039. |
| ELBOW | 125 | 2.864 | 553. | 553. | 4258. | 4810. |
| | 130 | 2.864 | 553. | 553. | 4769. | 5322. |
| RUN | 130 | 1.000 | 553. | 553. | 1665. | 2218. |
| | 135 | 1.000 | 553. | 553. | 1794. | 2347. |
| RUN | 135 | 1.000 | 553. | 553. | 1794. | 2347. |
| | 140 | 1.000 | 553. | 553. | 1923. | 2475. |
| ELBOW | 140 | 2.864 | 553. | 553. | 5507. | 6060. |
| | 145 | 2.864 | 553. | 553. | 5054. | 5606. |
| RUN | 145 | 1.000 | 553. | 553. | 1765. | 2317. |
| | 150 | 1.000 | 553. | 553. | 79. | 631. |
| RUN | 150 | 1.000 | 553. | 553. | 79. | 631. |
| | 155 | 1.000 | 553. | 553. | 1607. | 2159. |
| ELBOW | 155 | 2.864 | 553. | 553. | 4602. | 5154. |
| | 160 | 2.864 | 553. | 553. | 5055. | 5608. |
| RUN | 160 | 1.000 | 553. | 553. | 1765. | 2318. |
| | 165 | 1.000 | 553. | 553. | 1697. | 2250. |

079T1000008
240

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 165 | 1.000 | 553. | 553. | 1697. | 2250. |
| | 170 | 1.000 | 553. | 553. | 1619. | 2172. |
| RUN | 170 | 1.000 | 553. | 553. | 1389. | 1941. |
| | 205 | 1.000 | 553. | 553. | 1336. | 1888. |
| RUN | 205 | 1.000 | 553. | 553. | 1336. | 1888. |
| | 210 | 1.000 | 553. | 553. | 1289. | 1842. |
| ELBOW | 210 | 2.864 | 553. | 553. | 3692. | 4245. |
| | 215 | 2.864 | 553. | 553. | 3385. | 3937. |
| RUN | 215 | 1.000 | 553. | 553. | 1182. | 1734. |
| | 220 | 1.000 | 553. | 553. | 9. | 562. |
| RUN | 220 | 1.000 | 553. | 553. | 9. | 562. |
| | 225 | 1.000 | 553. | 553. | 1163. | 1715. |
| ELBOW | 225 | 2.864 | 553. | 553. | 3331. | 3883. |
| | 230 | 2.864 | 553. | 553. | 3638. | 4191. |
| RUN | 230 | 1.000 | 553. | 553. | 1270. | 1823. |
| | 235 | 1.000 | 553. | 553. | 1358. | 1911. |
| RUN | 235 | 1.000 | 553. | 553. | 1358. | 1911. |
| | 240 | 1.000 | 553. | 553. | 1446. | 1999. |
| ELBOW | 240 | 2.864 | 553. | 553. | 4142. | 4695. |
| | 245 | 2.864 | 553. | 553. | 3874. | 4427. |
| RUN | 245 | 1.000 | 553. | 553. | 1353. | 1905. |
| | 250 | 1.000 | 553. | 553. | 63. | 616. |
| RUN | 250 | 1.000 | 553. | 553. | 63. | 616. |
| | 255 | 1.000 | 553. | 553. | 1226. | 1779. |
| ELBOW | 255 | 2.864 | 553. | 553. | 3512. | 4065. |
| | 260 | 2.864 | 553. | 553. | 3780. | 4333. |
| RUN | 260 | 1.000 | 553. | 553. | 1320. | 1872. |
| | 265 | 1.000 | 553. | 553. | 1274. | 1826. |

079T1000008
241

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 265 | 1.000 | 553. | 553. | 1274. | 1826. |
| | 270 | 1.000 | 553. | 553. | 1220. | 1773. |
| RUN | 270 | 1.000 | 553. | 553. | 1180. | 1732. |
| | 305 | 1.000 | 553. | 553. | 1126. | 1678. |
| RUN | 305 | 1.000 | 553. | 553. | 1126. | 1678. |
| | 310 | 1.000 | 553. | 553. | 1078. | 1631. |
| ELBOW | 310 | 2.864 | 553. | 553. | 3089. | 3641. |
| | 315 | 2.864 | 553. | 553. | 2866. | 3418. |
| RUN | 315 | 1.000 | 553. | 553. | 1001. | 1553. |
| | 320 | 1.000 | 553. | 553. | 23. | 575. |
| RUN | 320 | 1.000 | 553. | 553. | 23. | 575. |
| | 325 | 1.000 | 553. | 553. | 955. | 1508. |
| ELBOW | 325 | 2.864 | 553. | 553. | 2735. | 3288. |
| | 330 | 2.864 | 553. | 553. | 2958. | 3510. |
| RUN | 330 | 1.000 | 553. | 553. | 1033. | 1585. |
| | 335 | 1.000 | 553. | 553. | 1122. | 1675. |
| RUN | 335 | 1.000 | 553. | 553. | 1122. | 1675. |
| | 340 | 1.000 | 553. | 553. | 1212. | 1764. |
| ELBOW | 340 | 2.864 | 553. | 553. | 3470. | 4023. |
| | 345 | 2.864 | 553. | 553. | 3288. | 3841. |
| RUN | 345 | 1.000 | 553. | 553. | 1148. | 1701. |
| | 350 | 1.000 | 553. | 553. | 64. | 617. |
| RUN | 350 | 1.000 | 553. | 553. | 64. | 617. |
| | 355 | 1.000 | 553. | 553. | 1020. | 1572. |
| ELBOW | 355 | 2.864 | 553. | 553. | 2920. | 3473. |
| | 360 | 2.864 | 553. | 553. | 3103. | 3655. |
| RUN | 360 | 1.000 | 553. | 553. | 1083. | 1636. |
| | 365 | 1.000 | 553. | 553. | 1036. | 1589. |

This page left intentionally blank

This page left intentionally blank

This page left intentionally blank

| SUMMARY OF ERRORS FOR THIS JOB | ERROR NUMBER | NUMBER OF ERRORS |
|---|--------------|------------------|
| | 208 | 22 |
| IAT6140 JOB ORIGIN FROM GROUP=RM206 , DSP=IJP, DEVICE=INTRDR , 000 | | |
| 10:50:07 IAT4401 LOCATE FOR STEP=A DD=STEPLIB DSN=\$WWO49.NUPIPE.LOAD | | |
| 10:50:07 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | |
| 10:50:07 IAT4401 LOCATE FOR STEP=G DD=STEPLIB DSN=\$WWO49.NUPIPE.LOAD | | |
| 10:50:07 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | |
| 10:50:07 IAT4401 LOCATE FOR STEP=G DD=FT15FOO1 DSN=\$WW232.CARRIZO.RISER.SS1100.DATA | | |
| 10:50:07 IAT4402 UNIT=3350 ,VOL(S)=AVTSOA | | |
| 10:50:07 IAT4401 LOCATE FOR STEP=G DD=FT69FOO1 DSN=\$WWO49.ROCKPIPE.USERS | | |
| 10:50:07 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | |
| 10:50:07 IAT4401 LOCATE FOR STEP=ELTEMP DD=STEPLIB DSN=\$WWO49.ELTEMP.LOAD | | |
| 10:50:07 IAT4402 UNIT=3350 ,VOL(S)=CVTSOK | | |
| 10:50:07 USES CVTSOK D \$WWO49.NUPIPE.LOAD | | |
| 10:50:07 USES AVTSOA D \$WW232.CARRIZO.RISER.SS1100.DATA | | |
| 10:50:07 IAT5200 JOB 2315 (\$WW232C1) IN SETUP ON MAIN=I P=03 LOCAL | | |
| 10:50:07 IAT5210 J=2315 STEPLIB USING D CVTSOK ON 528 \$WWO49.NUPIPE.LOAD | | |
| 10:50:07 IAT5210 J=2315 FT15FOO1 USING D AVTSOA ON 520 \$WW232.CARRIZO.RISER.SS1100.DATA | | |
| 10:50:10 IAT2000 JOB 2315 \$WW232C1 SELECTED I GRP=BIG | | |
| 10:50:11 I R= \$WW232C1 NEF995I \$WW232C1 STARTED, 4/18/83,10.50.31 ASID=00007 | | |
| 10:50:11 I R= \$WW232C1 IEF403I \$WW232C1 - STARTED - TIME=10.50.31 | | |
| 10:50:49 I R= \$WW232C1 +IH0002I STOP 1 | | |
| 10:50:50 I R= \$WW232C1 IEF404I \$WW232C1 - ENDED - TIME=10.51.10 | | |
| 10:50:50 I R= \$WW232C1 NEF996I \$WW232C1 ENDED, 4/18/83,B.U.= .7319 *07,16935 ,3081-I3,JOB CC= 001 | | |
| 10:50:50 IAT5400 JOB 2315 (\$WW232C1) IN BREAKDOWN | | |
| / \$WW232C1 JOB 'GURSAHANI LB30130340*0716935 005 5001003037', * | | |
| / REGION=4500K,TIME=4,MSGCLASS=T,MSGLEVEL=1,NOTIFY=\$WW232 | | |
| /*MAIN ORG=RMO05,SYSTEM=/C 00000300 | | |
| / EXEC ROCKPIPE,PROG=SMALL | | |
| /G.SYSIN DD DSN=\$WW232.CARRIZO.RISER.SS1100.DATA,DISP=SHR | | |

0791100008
247

ORIGINAL INPUT BY GURSAHANI ON 04/18/83 AT 10:50:48 WITH PRIORITY 3
 CARRIZO 8" SS DOWNCOMER

| | | | | | | | | | |
|-------------------------------|-------|------|--------|-------|------|------|-----|--|----|
| CONTROL | | | 2.0 | | | | | | 1 |
| FLEXAN | 1 | 1 | 2.0 | | | | | | 2 |
| THERMAL AT DESIGN TEMPERATURE | | | | | | | | | |
| XSECTN | 1 | | 8.625 | 0.322 | 48.1 | 28.3 | 65. | | 3 |
| OPVAL1100 | 1 | 1 | 21.8 | .1284 | | | 65. | | 4 |
| ANCHOR | | 1005 | | | | | | | 5 |
| RUN | 1005 | 1010 | | -3.5 | | 1.0 | 1.0 | | 6 |
| ELBOW | -1010 | 1015 | | | | | | | 7 |
| RUN | 1015 | 1020 | | | 2.0 | | | | 8 |
| RUN | 1020 | 1025 | | | 2.25 | | | | 9 |
| ELBOW | -1025 | 1030 | | | | | | | 10 |
| RUN | 1030 | 1035 | 15.5 | | | | | | 11 |
| ELBOW | -1035 | 1040 | | | | | | | 12 |
| RUN | 1040 | 1045 | | -20.5 | | | | | 13 |
| RUN | 1045 | 1050 | | -20.5 | | | | | 14 |
| ELBOW | -1050 | 1055 | | | | | | | 15 |
| RUN | 1055 | 1060 | -14.5 | | | | | | 16 |
| RUN | 1060 | 1065 | -14.5 | | | | | | 17 |
| ELBOW | -1065 | 1070 | | | | | | | 18 |
| RUN | 1070 | 1075 | | -11.5 | | | | | 19 |
| RUN | 1075 | 1080 | | -11.5 | | | | | 20 |
| ANCHOR | | 1080 | | | | | | | 21 |
| RUN | 1080 | 1105 | | -11.5 | | | | | 22 |
| RUN | 1105 | 1110 | | -11.5 | | | | | 23 |
| ELBOW | -1110 | 1115 | | | | | | | 24 |
| RUN | 1115 | 1120 | 14.75 | | | | | | 25 |
| RUN | 1120 | 1125 | 14.75 | | | | | | 26 |
| ELBOW | -1125 | 1130 | | | | | | | 27 |
| RUN | 1130 | 1135 | | -20.5 | | | | | 28 |
| RUN | 1135 | 1140 | | -20.5 | | | | | 29 |
| ELBOW | -1140 | 1145 | | | | | | | 30 |
| RUN | 1145 | 1150 | -16.5 | | | | | | 31 |
| RUN | 1150 | 1155 | -16.5 | | | | | | 32 |
| ELBOW | -1155 | 1160 | | | | | | | 33 |
| RUN | 1160 | 1165 | | -11.5 | | | | | 34 |
| RUN | 1165 | 1170 | | -11.5 | | | | | 35 |
| ANCHOR | | 1170 | | | | | | | 36 |
| RUN | 1170 | 1205 | | -11.5 | | | | | 37 |
| RUN | 1205 | 1210 | | -11.5 | | | | | 38 |
| ELBOW | -1210 | 1215 | | | | | | | 39 |
| RUN | 1215 | 1220 | 19.0 | | | | | | 40 |
| RUN | 1220 | 1225 | 19.0 | | | | | | 41 |
| ELBOW | -1225 | 1230 | | | | | | | 42 |
| RUN | 1230 | 1235 | | -20.5 | | | | | 43 |
| RUN | 1235 | 1240 | | -20.5 | | | | | 44 |
| ELBOW | -1240 | 1245 | | | | | | | 45 |
| RUN | 1245 | 1250 | -20.75 | | | | | | 46 |
| RUN | 1250 | 1255 | -20.75 | | | | | | 47 |
| ELBOW | -1255 | 1260 | | | | | | | 48 |
| RUN | 1260 | 1265 | | -11.5 | | | | | 49 |
| RUN | 1265 | 1270 | | -11.5 | | | | | 50 |
| ANCHOR | | 1270 | | | | | | | 51 |
| RUN | 1270 | 1305 | | -11.5 | | | | | 52 |
| RUN | 1305 | 1310 | | -11.5 | | | | | 53 |
| ELBOW | -1310 | 1315 | | | | | | | 54 |
| RUN | 1315 | 1320 | 22.25 | | | | | | 55 |
| RUN | 1320 | 1325 | 22.25 | | | | | | 56 |
| ELBOW | -1325 | 1330 | | | | | | | 57 |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|--------------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 1005 1010 | 1.000 1.000 | 435. 435. | 435. 435. | 6509. 6148. | 6945. 6583. |
| ELBOW | 1010 1015 | 2.440 2.440 | 435. 435. | 435. 435. | 15000. 14429. | 15436. 14865. |
| RUN | 1015 1020 | 1.000 1.000 | 435. 435. | 435. 435. | 5914. 5864. | 6349. 6299. |
| RUN | 1020 1025 | 1.000 1.000 | 435. 435. | 435. 435. | 5864. 5859. | 6299. 6294. |
| ELBOW | 1025 1030 | 2.440 2.440 | 435. 435. | 435. 435. | 14296. 13267. | 14731. 13702. |
| RUN | 1030 1035 | 1.000 1.000 | 435. 435. | 435. 435. | 5438. 1273. | 5873. 1708. |
| ELBOW | 1035 1040 | 2.440 2.440 | 435. 435. | 435. 435. | 3106. 4345. | 3541. 4780. |
| RUN | 1040 1045 | 1.000 1.000 | 435. 435. | 435. 435. | 1781. 4553. | 2216. 4988. |
| RUN | 1045 1050 | 1.000 1.000 | 435. 435. | 435. 435. | 4553. 7479. | 4988. 7914. |
| ELBOW | 1050 1055 | 2.440 2.440 | 435. 435. | 435. 435. | 18249. 17472. | 18684. 17907. |
| RUN | 1055 1060 | 1.000 1.000 | 435. 435. | 435. 435. | 7161. 826. | 7596. 1261. |
| RUN | 1060 1065 | 1.000 1.000 | 435. 435. | 435. 435. | 826. 5517. | 1261. 5952. |
| ELBOW | 1065 1070 | 2.440 2.440 | 435. 435. | 435. 435. | 13461. 14238. | 13896. 14673. |
| RUN | 1070 1075 | 1.000 1.000 | 435. 435. | 435. 435. | 5835. 4253. | 6271. 4688. |

079T1000008
250

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 1075 | 1.000 | 435. | 435. | 4253. | 4688. |
| | 1080 | 1.000 | 435. | 435. | 2544. | 2979. |
| RUN | 1080 | 1.000 | 435. | 435. | 4159. | 4594. |
| | 1105 | 1.000 | 435. | 435. | 3981. | 4417. |
| RUN | 1105 | 1.000 | 435. | 435. | 3981. | 4417. |
| | 1110 | 1.000 | 435. | 435. | 3820. | 4255. |
| ELBOW | 1110 | 2.440 | 435. | 435. | 9319. | 9755. |
| | 1115 | 2.440 | 435. | 435. | 8650. | 9085. |
| RUN | 1115 | 1.000 | 435. | 435. | 3545. | 3980. |
| | 1120 | 1.000 | 435. | 435. | 17. | 452. |
| RUN | 1120 | 1.000 | 435. | 435. | 17. | 452. |
| | 1125 | 1.000 | 435. | 435. | 3579. | 4014. |
| ELBOW | 1125 | 2.440 | 435. | 435. | 8733. | 9168. |
| | 1130 | 2.440 | 435. | 435. | 9402. | 9837. |
| RUN | 1130 | 1.000 | 435. | 435. | 3854. | 4289. |
| | 1135 | 1.000 | 435. | 435. | 4154. | 4589. |
| RUN | 1135 | 1.000 | 435. | 435. | 4154. | 4589. |
| | 1140 | 1.000 | 435. | 435. | 4454. | 4890. |
| ELBOW | 1140 | 2.440 | 435. | 435. | 10868. | 11304. |
| | 1145 | 2.440 | 435. | 435. | 10274. | 10709. |
| RUN | 1145 | 1.000 | 435. | 435. | 4211. | 4646. |
| | 1150 | 1.000 | 435. | 435. | 195. | 631. |
| RUN | 1150 | 1.000 | 435. | 435. | 195. | 631. |
| | 1155 | 1.000 | 435. | 435. | 3820. | 4255. |
| ELBOW | 1155 | 2.440 | 435. | 435. | 9321. | 9756. |
| | 1160 | 2.440 | 435. | 435. | 9915. | 10350. |
| RUN | 1160 | 1.000 | 435. | 435. | 4064. | 4499. |
| | 1165 | 1.000 | 435. | 435. | 3902. | 4337. |

079T1000008
251

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------|----------------------------|-----------------------------|-----------------------------|--|
| RUN | 1165 | 1.000 | 435. | 435. | 3902. | 4337. |
| | 1170 | 1.000 | 435. | 435. | 3725. | 4160. |
| RUN | 1170 | 1.000 | 435. | 435. | 3167. | 3602. |
| | 1205 | 1.000 | 435. | 435. | 3047. | 3482. |
| RUN | 1205 | 1.000 | 435. | 435. | 3047. | 3482. |
| | 1210 | 1.000 | 435. | 435. | 2938. | 3373. |
| ELBOW | 1210 | 2.440 | 435. | 435. | 7168. | 7603. |
| | 1215 | 2.440 | 435. | 435. | 6768. | 7203. |
| RUN | 1215 | 1.000 | 435. | 435. | 2774. | 3209. |
| | 1220 | 1.000 | 435. | 435. | 5. | 440. |
| RUN | 1220 | 1.000 | 435. | 435. | 5. | 440. |
| | 1225 | 1.000 | 435. | 435. | 2763. | 3199. |
| ELBOW | 1225 | 2.440 | 435. | 435. | 6742. | 7178. |
| | 1230 | 2.440 | 435. | 435. | 7143. | 7578. |
| RUN | 1230 | 1.000 | 435. | 435. | 2928. | 3363. |
| | 1235 | 1.000 | 435. | 435. | 3130. | 3566. |
| RUN | 1235 | 1.000 | 435. | 435. | 3130. | 3566. |
| | 1240 | 1.000 | 435. | 435. | 3333. | 3768. |
| ELBOW | 1240 | 2.440 | 435. | 435. | 8132. | 8567. |
| | 1245 | 2.440 | 435. | 435. | 7782. | 8217. |
| RUN | 1245 | 1.000 | 435. | 435. | 3189. | 3625. |
| | 1250 | 1.000 | 435. | 435. | 152. | 587. |
| RUN | 1250 | 1.000 | 435. | 435. | 152. | 587. |
| | 1255 | 1.000 | 435. | 435. | 2886. | 3321. |
| ELBOW | 1255 | 2.440 | 435. | 435. | 7041. | 7477. |
| | 1260 | 2.440 | 435. | 435. | 7391. | 7827. |
| RUN | 1260 | 1.000 | 435. | 435. | 3029. | 3465. |
| | 1265 | 1.000 | 435. | 435. | 2920. | 3355. |

ASME SECTION III CLASS 2 OR ANSI B31.1.B STRESS SUMMARY

| MEMBER | NODE | STRESS INTENSIF FACTOR | SUSTAINED STRESS EQ. 8 PSI | OCCASIONAL STRESS EQ. 9 PSI | EXPANSION STRESS EQ. 10 PSI | SUSTAINED PLUS EXPANSION STRESS EQ. 11 PSI |
|--------|------|------------------------------|-------------------------------------|--------------------------------------|--------------------------------------|---|
| RUN | 1265 | 1.000 | 435. | 435. | 2920. | 3355. |
| | 1270 | 1.000 | 435. | 435. | 2801. | 3236. |
| RUN | 1270 | 1.000 | 435. | 435. | 2676. | 3111. |
| | 1305 | 1.000 | 435. | 435. | 2556. | 2991. |
| RUN | 1305 | 1.000 | 435. | 435. | 2556. | 2991. |
| | 1310 | 1.000 | 435. | 435. | 2446. | 2881. |
| ELBOW | 1310 | 2.440 | 435. | 435. | 5968. | 6403. |
| | 1315 | 2.440 | 435. | 435. | 5679. | 6114. |
| RUN | 1315 | 1.000 | 485. | 435. | 2328. | 2763. |
| | 1320 | 1.000 | 435. | 435. | 37. | 473. |
| RUN | 1320 | 1.000 | 435. | 435. | 37. | 473. |
| | 1325 | 1.000 | 435. | 435. | 2253. | 2688. |
| ELBOW | 1325 | 2.440 | 435. | 435. | 5496. | 5932. |
| | 1330 | 2.440 | 435. | 435. | 5785. | 6220. |
| RUN | 1330 | 1.000 | 435. | 435. | 2371. | 2806. |
| | 1335 | 1.000 | 435. | 435. | 2575. | 3010. |
| RUN | 1335 | 1.000 | 435. | 435. | 2575. | 3010. |
| | 1340 | 1.000 | 435. | 435. | 2779. | 3214. |
| ELBOW | 1340 | 2.440 | 435. | 435. | 6780. | 7215. |
| | 1345 | 2.440 | 435. | 435. | 6542. | 6978. |
| RUN | 1345 | 1.000 | 435. | 435. | 2681. | 3117. |
| | 1350 | 1.000 | 435. | 435. | 149. | 584. |
| RUN | 1350 | 1.000 | 435. | 435. | 149. | 584. |
| | 1355 | 1.000 | 435. | 435. | 2384. | 2819. |
| ELBOW | 1355 | 2.440 | 435. | 435. | 5816. | 6252. |
| | 1360 | 2.440 | 435. | 435. | 6054. | 6489. |
| RUN | 1360 | 1.000 | 435. | 435. | 2481. | 2916. |
| | 1365 | 1.000 | 435. | 435. | 2371. | 2807. |

T A B L E O F C O N T E N T S

| LOAD CASE NUMBER | TITLE | PAGE |
|------------------|-------------------------------|------|
| 1 | THERMAL AT DESIGN TEMPERATURE | 15 |
| | CODE STRESS ANALYSIS | 20 |

BY: GURSAHANI CPU SECONDS USED: 1.713 PRIORITY: 3

ON MAIN: 04/18/83 AT 10:50:48 OFF MAIN: 04/18/83 AT 10:51:01