

RECEIVED BY TIC MAR 1 1980

Heat Rejection From Geothermal Power Plants

EPRI

Keywords:

Geothermal
Power Plant
Cooling
Water Consumption
Dry Cooling
Wet Peaking
Heat Rejection

EPRI ER-1216
Project 927-1
Final Report
November 1979

MASTER

Prepared by
R. W. Beck and Associates
Denver, Colorado

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ELECTRIC POWER RESEARCH INSTITUTE

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Heat Rejection From Geothermal Power Plants

ER-1216
Research Project 927-1

Final Report, November 1979

Prepared by

R. W. BECK AND ASSOCIATES
400 Prudential Plaza
Denver, Colorado 80265

Principal Investigator
Randy D. Horsak

Prepared for

California Energy Commission
1111 Howe Avenue
Sacramento, California 95825

Project Manager
Kenneth Henwood

and

Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, California 94304

EPRI Project Manager
Phillip N. La Mori
Fossil Fuel and Advanced Systems Division

ORDERING INFORMATION

Requests for copies of this report should be directed to Research Reports Center (RRC), Box 10090, Palo Alto, CA 94303, (415) 961-9043. There is no charge for reports requested by EPRI member utilities and affiliates, contributing nonmembers, U.S. utility associations, U.S. government agencies (federal, state, and local), media, and foreign organizations with which EPRI has an information exchange agreement. On request, RRC will send a catalog of EPRI reports.

~~Copyright © 1979 Electric Power Research Institute, Inc.~~

EPRI authorizes the reproduction and distribution of all or any portion of this report and the preparation of any derivative work based on this report, in each case on the condition that any such reproduction, distribution, and preparation shall acknowledge this report and EPRI as the source.

NOTICE

This report was prepared by the organization(s) named below as an account of work sponsored by the Electric Power Research Institute, Inc. (EPRI). Neither EPRI, members of EPRI, the organization(s) named below, nor any person acting on their behalf: (a) makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or (b) assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this report.

Prepared by
R. W. Beck and Associates
Denver, Colorado

ABSTRACT

Comprehensive computer programs are developed for purposes of determining cooling makeup water requirements and electricity production costs for evaporative (wet) and dry/wet-peaking cooling towers, which are the principal cooling technologies for rejecting the heat from hydrothermal power plants. Such information can be used to determine the incremental cost of reducing the water consumption of the cooling system, or, conversely, what cost would be incurred at a site if only a certain quantity of water were available, thus requiring the supplemental use of dry cooling systems.

Parametric economic analyses were performed for both flash steam and binary conversion processes for various combinations of resource temperatures, climatological types, hydrothermal "fuel" costs, and cooling system makeup water costs. Results of these analyses are presented in a number of curves showing relative busbar cost of electricity as a function of relative amount of cooling makeup water required. These curves show that use of wet/dry cooling systems can cut makeup water requirements by factors of about 2 to 4 at the cost of an additional 10% to 25% in the busbar price of electricity.

Turbine-generator performance curves are constructed for a range of condensing conditions for both the flash steam and hydrocarbon binary-cycle turbines. Estimates of hydrothermal resources in the western United States are also given.

EPRI PERSPECTIVE

PROJECT DESCRIPTION

Because a major portion of the U. S. hydrothermal resources are located in the arid and semiarid western states, the availability of water for geothermal power plant cooling could become a critical constraint on the growth of geothermal energy utilization. The contract for Research Project (RP) 927-1 was issued to provide a detailed study of the problem of waste heat rejection under conditions relevant to commercial use of geothermal resources in water deficient areas. Although this study focused on geothermal power generation, the problem of cooling water supply in arid regions is germane to other types of power plants, and the data derived in this Final Report should be of use in other EPRI projects and in utility planning.

PROJECT OBJECTIVES

EPRI awarded the contract in order to obtain a comparative analysis of alternate heat rejection systems, taking into account the variability of geothermal resources, regional climatic differences, geologic conditions, water availability, and power conversion options. The many possible combinations of these factors required development of computational models for use in parametric analyses. From these analyses, specific correlations can be derived for plants such as the binary cycle power plant proposed for Heber in the Imperial Valley and for binary and direct flash power plants at other resources having development potential in the next 10-year period.

PROJECT RESULTS

High penalties in both capital cost and decreased power output make totally dry cooling systems an unacceptably expensive option for geothermal heat rejection. Use of a dry/wet-peaking cooling system can greatly reduce cooling water consumption at some penalty in the busbar electricity cost. The penalty is in the 10 to 20% range when consumptive use of cooling water is cut by half. Greater reductions in cooling water use, e.g. cutting back to only one fifth of the water used by a purely evaporative (wet) system, can be achieved at a busbar cost penalty ranging from 15 to 35%. Busbar costs of electricity depend much more on resource temperature and production costs (e.g., wells) than on costs of cooling water and cooling systems. When compared on the same 182°C (360°F) resource, binary power plants require about 17% more cooling water than flash plants because the binary plants can use more of the low temperature heat available from the resource.

Vasel Roberts, Program Manager
Fossil Fuel and Advanced Systems Division

CONTENTS

<u>Section</u>	<u>Page</u>
1 INTRODUCTION	1-1
2 DEVELOPMENT OF CRITERIA FOR PARAMETRIC EVALUATIONS OF COOLING SYSTEMS FOR HYDROTHERMAL POWER PLANTS	2-1
Introduction	2-1
Hydrothermal Resources in the Western United States	2-2
Hydrothermal Plant Conversion Processes	2-4
Climatology and Cooling System Performance	2-5
Cooling System Types	2-7
Water Resource Considerations	2-11
Availability of Water	2-11
Institutional and Legal Considerations	2-12
Cost of Water	2-13
Hydrothermal Resource Costs	2-13
Economic Parameters	2-14
3 COMBINED PERFORMANCE OF HYDROTHERMAL CONVERSION PROCESSES AND COOLING TOWER SYSTEMS	3-1
General	3-1
Hydrothermal Conversion System	3-2
Binary Conversion Process	3-2
Flash Steam Conversion Process	3-4
Turbine-Generator System	3-6
Hydrocarbon Turbine	3-6
Flash Steam Turbine	3-7

<u>Section</u>	<u>Page</u>
3	
Gross Heat Rate	3-7
Cost Heat Rate	3-8
Combined Performance of Hydrothermal Conversion Systems With Cooling Towers	3-9
4	
OPTIMIZATION AND EVALUATION OF ALTERNATIVE HEAT REJECTION SYSTEMS FOR HYDROTHERMAL POWER PLANTS	4-1
General Methodology	4-1
Costs Affected by Type or Design of Heat Rejection System	4-2
Heat Rejection System Capital Cost	4-2
Hydrothermal Energy Conversion System Capital Cost	4-3
Annual Hydrothermal Resource Cost	4-3
Annual Cooling Water Makeup Cost	4-4
Costs Associated with Loss of Generating Capability	4-4
Factors Which Influence the Optimization and Comparative Evaluations of Alternative Heat Rejection Systems	4-6
Capital Cost of Heat Rejection System	4-6
Capital Cost of Hydrothermal Energy Conversion System	4-6
Annual Operation and Maintenance Costs	4-7
Turbine-Generator Performance Characteristics	4-7
Ambient Air Temperatures	4-8
Cost of Replacement Capacity	4-9
Cost of Replacement Energy	4-9
Annual Fixed-Charge Rate	4-9
Unit Hydrothermal Resource Costs	4-10
Unit Water Costs	4-10
Description of Computer Programs	4-10

<u>Section</u>	<u>Page</u>
5 PARAMETRIC EVALUATIONS OF COOLING SYSTEMS FOR HYDROTHERMAL POWER PLANTS	5-1
Range of Parameters Considered in Analyses	5-1
Preliminary Analyses Performed	5-2
Loss of Generating Capability	5-2
Direct Versus Indirect Dry Towers	5-3
Effect of Turbine Design Back Pressure	5-3
Results of Parametric Analyses	5-4
Information Obtainable from Computer Programs	5-4
Results of Analyses of Evaporative Cooling Systems	5-5
Results of Analyses of Dry/Wet Peaking Cooling Systems	5-10
Conclusions	5-14
Recommendations for Subsequent Studies	5-16
Accuracy of Results	5-16
APPENDIX A DESCRIPTION OF HYDROTHERMAL RESOURCES IN THE WESTERN UNITED STATES	A-1
APPENDIX B DISTRIBUTION OF AMBIENT DRY-BULB TEMPERATURES AT FOUR SITES - PERCENT OCCURRENCE	B-1
APPENDIX C SUMMARY OF COST ESTIMATES FOR BINARY AND FLASH STEAM CONVERSION PLANTS	C-1
APPENDIX D SAMPLE COMPUTER PRINTOUT FOR EVAPORATIVE COOLING TOWER SYSTEMS	D-1
APPENDIX E SAMPLE COMPUTER PRINTOUT FOR DIRECT DRY/WET PEAKING COOLING TOWER SYSTEMS	E-1
APPENDIX F SUMMARY OF ANALYSES OF EVAPORATIVE COOLING SYSTEMS	F-1
APPENDIX G BUSBAR ENERGY PRODUCTION COST MULTIPLIERS FOR BINARY AND FLASH STEAM SYSTEMS WITH DRY/WET PEAKING COOLING TOWERS	G-1

TABLES

<u>Table</u>	<u>Page</u>
2-1 Estimates of Nominal 30-Year Electrical Production Capacity for the Major Hydrothermal Regions as a Function of Heat Flow	2-4
2-2 Approximate Extreme Meteorological Parameters for Selected Hydrothermal Sites	2-8
2-3 Climatological Parameters for Sites Selected for Parametric Analysis	2-9
3-1 Flash Pressures Assumed for Hydrothermal Flash Steam Conversion Processes	3-5
3-2 Steam Turbine Inlet Conditions for Hydrothermal Flash Steam Conversion Processes	3-7
5-1 Definition of Cost Multipliers for Evaporative Cooling Towers	5-8
5-2 Base Cases for Busbar Energy Production Cost and Water Consumption for Evaporative and Dry/Wet Peaking Cooling Towers	5-8
5-3 Busbar Energy Production Cost Multipliers for 182° C (360° F) Binary Systems Using Evaporative Cooling Towers	5-9
5-4 Table of Useful Conversion Factors for Parametric Analysis	5-9
5-5 Definition of Cost Multipliers and Water Percentages for Dry/Wet Peaking Cooling Towers	5-12

ILLUSTRATIONS

<u>Figure</u>	<u>Page</u>
2-1 Major Hydrothermal Regions and Sites in the Western United States	2-15
3-1 Temperature Profiles of Hydrothermal Heat Exchangers	3-11
3-2 Turbine-Generator Performance - Binary	3-12
3-3 Turbine-Generator Performance - Flashed Steam	3-12
3-4 Gross Plant Heat Rate - Binary	3-13
3-5 Gross Plant Heat Rate - Flashed Steam	3-13
3-6 Cost Heat Rate - Binary	3-14
3-7 Cost Heat Rate - Flashed Steam	3-14
3-8 Turbine Heat Rejection - Binary	3-15
3-9 Turbine Heat Rejection - Flashed Steam	3-15
3-10 Performance of an 11° C (20° F) ITD Mechanical-Draft Direct Dry Cooling Tower	3-16
3-11 Performance of a 33° C (60° F) ITD Mechanical-Draft Direct Dry Cooling Tower	3-16
3-12 Performance of a 56° C (100° F) ITD Mechanical-Draft Direct Dry Cooling Tower	3-17
3-13 Performance of a 21° C (70° F) Design Wet Bulb Mechanical-Draft Wet Cooling Tower	3-17
3-14 Combined Performance of Elliott Turbine With a Mechanical-Draft Direct Dry Cooling Tower	3-18
3-15 Combined Performance of Elliott Turbine With a Mechanical-Draft Wet Cooling Tower	3-18
3-16 Typical Combined Performance of Elliott Turbine With a Mechanical-Draft Direct Wet/Dry Cooling System	3-19

<u>Figure</u>	<u>Page</u>
5-1 Illustration of Busbar Energy Production Cost Versus Makeup Water Requirement for Dry/Wet Peaking Cooling Tower System for Different Design Maximum Operating Back Pressures	5-18
5-2 Busbar Energy Production Cost Multipliers for Evaporative Cooling Towers as a Function of Resource Temperature (All Sites) for Flash Steam Systems	5-19
5-3 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 182 ^o C (360 ^o F) Binary at Basin and Range Site	5-20
5-4 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 182 ^o C (360 ^o F) Binary at Pacific Northwest Site	5-21
5-5 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 182 ^o C (360 ^o F) Binary at High Mountain Site	5-22
5-6 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 182 ^o C (360 ^o F) Binary at Hot Desert Site	5-23
5-7 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 150 ^o C (300 ^o F), 182 ^o C (360 ^o F) and 246 ^o C (475 ^o F) Flash at Basin and Range Site	5-24
5-8 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 150 ^o F (300 ^o F), 182 ^o C (360 ^o F) and 246 ^o C (475 ^o F) Flash at Pacific Northwest Site	5-25
5-9 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 150 ^o C (300 ^o F), 182 ^o C (360 ^o F) and 246 ^o C (475 ^o F) Flash at High Mountain Site	5-26
5-10 Busbar Energy Production Cost Multipliers for Dry/Wet Peaking Cooling Towers for 150 ^o C (300 ^o F), 182 ^o C (360 ^o F) and 246 ^o C (475 ^o F) Flash at Hot Desert Site	5-27

SUMMARY

PURPOSE OF STUDY

The objectives of this study were (1) to identify the makeup water sources and demand for geothermal power production and (2) to develop analytical techniques and perform a comparative analysis of the waste heat rejection options for geothermal power plants, thereby determining how water consumption may be reduced. The results of this study will be used to identify options that are best suited for geothermal waste heat rejection by region, resource type, and conversion technology.

In this study, consideration is given to hydrothermal reservoirs with temperatures between 150°C and 246°C, because these offer potential for the development of commercial power generation facilities. Most of the known hydrothermal resources are located in the western United States, where water resources are scarce, highly allocated, or influenced by regional institutional and legal considerations.

Wet, wet/dry, and dry cooling towers appear to be the principal cooling technologies for rejecting the waste heat from hydrothermal power plants. Comprehensive computer programs have been developed for this project for purposes of determining cooling water makeup requirements and energy production costs for the aforementioned cooling technologies. Parametric economic analyses have been performed for both flash steam and binary conversion processes for various

combinations of resource temperatures, climatological types, hydrothermal "fuel costs", and cooling system makeup water costs.

PARAMETRIC ANALYSES PERFORMED

Specifically, the parametric analyses performed for this study assumed the following range of values:

- Hydrothermal resource temperature: 150 C (300 F), 182 C (360 F), and 246 C (475 F)
- Hydrothermal power plant conversion process: flash steam and binary
- Climatological type: High Mountain, Pacific Northwest, Basin and Range, and Hot Desert
- Cooling system type: mechanical-draft wet towers and mechanical-draft direct dry/wet peaking towers
- Annual fixed-charge rate: 15 percent
- Hydrothermal "fuel cost": $\$0.50/10^6$ Btu and $\$1.00/10^6$ Btu
- Makeup water cost: $\$0.10/\text{Kgal}$, $\$1.00/\text{Kgal}$, and $\$2.50/\text{Kgal}$ (includes acquisition, transportation, treatment, and disposal costs)

By selectively analyzing various combinations of values for these parameters, it is possible to compare the busbar energy production costs and makeup water requirements for hydrothermal power plants equipped with alternative cooling tower systems under different site, design, and economic conditions.

The results of the analyses are presented in the form of curves representing relative busbar energy production costs as a function of percentage water use for a range of fuel and makeup water costs at the four sites. Zero percent water consumption represents a plant with dry cooling towers only, whereas 100 percent water consumption represents a plant with evaporative (wet) cooling

towers only. The points between zero and 100 percent represent plants having different size combinations of dry and wet cooling towers, with a higher value of water consumption indicating a combination of a smaller dry tower with a larger wet tower. From such curves, the decision-maker can determine the incremental cost of reducing the water consumption of the cooling system, or, conversely, what cost would be incurred at a site if only a certain quantity of water were available, thereby requiring the supplemental use of dry cooling systems.

INFORMATION OBTAINABLE FROM COMPUTER PROGRAMS

The computer programs which were developed to economically optimize and evaluate mechanical-draft evaporative and direct dry/wet peaking cooling tower systems provide the following information for each combination of resource temperature, conversion process, climatic condition, fuel cost, fixed-charge rate, and makeup water cost considered:

- Gross annual base generation and auxiliary energy requirements
- Annual makeup water requirements
- Annual plant capital and operating costs
- Annual hydrothermal "fuel" and operating costs
- Annual makeup water and operating costs
- Total annual capital and operating costs
- Busbar energy production costs
- Busbar component cost breakdown
- Summary of pertinent cooling tower and condenser design data
- Cost breakdown for cooling tower, condenser, circulating water facilities, controls, engineering and contingencies, interest during construction, and conversion plant
- Annual turbine operation profile

- Annual plant generation profile
- Distribution of heat load between wet and dry towers for the dry/wet peaking tower

RESULTS OF STUDY

Conclusions

Several key results were obtained from analysis of the range of values calculated in the parametric studies performed under this contract. The main observations are:

- Busbar energy production costs are very sensitive to hydrothermal resource temperature and hydrothermal "fuel cost" and less sensitive to climatological type and makeup water cost. All other parameters remaining constant, busbar energy production costs for 150°C (300°F) resources are generally on the order of 80 percent higher than for 246°C (475°F) resources. Likewise, an increase in "fuel cost" from \$0.50 to \$1.00/10⁶ Btu will result in an increase in busbar costs on the order of 50 percent. However, an increase in water cost from \$0.10 to \$2.50/Kgal will result in an increase in busbar costs of only about 15 percent. The differences in busbar costs for the four sites are typically on the order of 5 percent.
- Turbine-generator design significantly determines the overall plant performance and economics of both the binary and flash steam conversion systems. Direct comparisons between binary and flash steam systems for 150°C (300°F) and 246°C (475°F) resources were not possible in this study since optimum binary fluid choices and turbine designs are not yet available.
- Analyses indicate that binary systems yield slightly lower busbar energy production costs than flash steam systems for the 182°C (360°F) resource temperature, although makeup water requirements are higher than for flash steam systems. Higher heat rejection for the binary system relative to the flash system accounts for the higher makeup water requirements.
- No computer analyses were performed for the radial hydrocarbon turbine design for the binary conversion process (turbine performance data were not available in time for this study). An examination of the radial turbine performance characteristics which were furnished by a manufacturer indicates that the busbar energy production cost and cooling system makeup water requirements should not differ significantly from those of the axial hydrocarbon turbine unless there are significant differences in capital or operating costs between the two types of turbines.

- On the basis of the turbine performance data available for this study, cooling system makeup water requirements for evaporative cooling towers serving flash steam systems are approximately 24-27 percent higher for 150°C (300°F) resources than for 182°C (360°F) resources, and approximately 29-30 percent lower for 246°C (475°F) resources than for 182°C (360°F) resources. Makeup water requirements for evaporative cooling systems serving binary systems are approximately 17-21 percent higher than for flash steam systems for 182°C (360°F) resource temperatures.
- For the range of fuel and makeup water costs considered, an all-dry cooling tower system does not appear to be economically competitive with an evaporative cooling tower system. However, the addition of a relatively small evaporative peaking tower to the dry tower (such as 95 percent dry/5 percent wet) will substantially reduce the busbar cost penalty incurred by an all-dry system. As the cost of makeup water increases, the relative difference in busbar cost between an all-dry or a dry/wet peaking tower and an evaporative tower decreases significantly.
- For low water costs (\$0.10/Kgal), the penalty in busbar cost for saving approximately 60 percent water by use of a dry/wet peaking cooling tower is on the order of 7-15 percent for non-desert sites and 9-25 percent for desert sites. However, for higher water costs (\$2.50/Kgal), the penalty decreases to approximately 1-4 percent for non-desert sites and 2-10 percent for desert sites. The economic penalty for saving more water increases as additional dry cooling is used. Therefore, the use of dry/wet peaking towers may be feasible for hydrothermal power plants under certain site, plant design, and economic conditions, as well as social and environmental constraints.
- Busbar energy production costs and cooling system makeup water requirements as estimated in this study for given plant design and economic constraints do not vary significantly for non-desert sites. However, busbar costs are approximately 2-6 percent higher and makeup water requirements are approximately 6-17 percent higher for desert sites.
- Several methods for accounting for costs associated with loss of generating capacity were considered in this study. Busbar energy production costs are slightly lower for the method which does not penalize for loss of capacity during operation at high ambient temperature conditions than for the other methods. However, typical differences in cost for these alternative methods are on the order of a few percent.
- Direct dry towers resulted in lower busbar energy production costs than indirect dry towers for the generating units with the sizes evaluated in this report. Differences in cost are typically on the order of a few percent of the total busbar cost, so that this conclusion could change if relative capital costs of the two systems are different from those assumed.

- For study purposes, the design back pressure value does not significantly affect the relative estimated busbar energy production cost or cooling system makeup water requirements. In the actual design of a hydrothermal power plant, however, the design back pressure is an important consideration.

Accuracy of Results

The accuracy with which cost estimates can be made for new energy conversion technologies is directly related to the history and experience of the industries developing the technologies. In the case of hydrothermal power plants, capital cost estimates are subject to inaccuracies resulting from a lack of cost trends, which can be established only after several power plants have been designed and constructed. Moreover, site-specific costs due to local labor and materials cost differences or physical site conditions will also markedly affect plant costs for any actual installation.

The accuracy with which the computer programs developed for this study simulate actual power plant performance is limited primarily by the accuracy or applicability of the turbine performance data, climatological data, and capital cost data. Estimates of makeup water requirements are based upon rigorous procedures adopted by the Cooling Tower Institute and therefore are limited primarily by the accuracy or applicability of the turbine performance and climatological data. Therefore, as data are refined, the accuracy of estimating energy production costs and makeup water requirements can also be refined.

Limitations of Study

The results of the parametric analyses presented in this report represent a wide range of variables and assumptions which affect the performance and economics of hydrothermal power plants. However, since geothermal energy is still in the development stage, necessary data are not yet available for many aspects of the power plant design, e.g. the performance of binary turbine-generators for many resource conditions.

The binary turbine data used in the analyses performed are based upon the Elliott turbine design for a 182°C (360°F) resource and therefore do not represent optimum hydrocarbon working fluid choices or turbine designs for either 150°C (300°F) or 246°C (475°F) resources. By comparison, the flash steam turbine data used in the analyses are based upon well-established turbine performance estimating methods and therefore are considered to be valid for all three temperatures investigated.

Recommendations for Subsequent Studies

In addition to the need for binary turbine-generation performance data for a range of hydrothermal resource temperatures, our analyses indicate that the following studies are warranted:

- Analyses of alternative hydrocarbon turbine designs should be performed before any major decision is made regarding either the selection of a hydrocarbon turbine or the selection of one conversion process over another.
- The actual operation of hydrothermal power plants in conjunction with other conventional power plants on the utility grid should be evaluated. Forced outage rate, planned outage for scheduled maintenance, and summer and winter capacity of the hydrothermal plant should be investigated with respect to operating economics.

- Because of the high fuel costs and cooling system auxiliary energy requirements associated with hydrothermal plants, natural-draft cooling systems may be more economical than mechanical-draft systems at many locations and should therefore be evaluated in subsequent studies. The choice between mechanical-draft and natural-draft cooling towers is usually based on economics, although in some instances environmental considerations could favor the use of natural-draft towers.

Section 1

INTRODUCTION

The relatively low temperatures of geothermal resources result in thermal efficiencies of 10-15 percent in power conversion cycles. If conventional evaporative cooling methods are to be used, large quantities of cooling water will be required. However, most of the known resources are located in the western United States where water resources are scarce, highly allocated, or influenced by regional institutional and legal considerations.

The primary objectives of this study, therefore, were (1) to identify the makeup water requirements for geothermal power production and (2) to develop analytical techniques and perform a comparative analysis of the waste heat rejection options for geothermal power plants to determine how water consumption may be reduced. The results of this study will be used to identify options that are best suited for geothermal waste heat rejection by region, resource type, and conversion technology.

Section 2

DEVELOPMENT OF CRITERIA FOR PARAMETRIC EVALUATIONS OF COOLING SYSTEMS FOR HYDROTHERMAL POWER PLANTS*

INTRODUCTION

In order to make meaningful economic evaluations of alternative cooling systems for hydrothermal power plants, several parameters are involved in the determination of energy production costs and makeup water requirements. The parameters analyzed in this study include the following:

- Temperature of hydrothermal resource
- Hydrothermal power plant conversion process
- Climatological characteristics which affect cooling system performance
- Cooling system type, performance, and cost
- Availability and cost of makeup water
- Hydrothermal fluid production cost
- Financial parameters

By selectively analyzing various combinations of values for these parameters, it is possible to compare the electrical energy production costs and makeup water requirements for hydrothermal power plants equipped with alternative heat rejection systems under different site, design, and economic conditions.

*Some technical data contained in Section 2 were prepared for this project by Dr. G. V. Keller and Dr. L. T. Grose, faculty members at the Colorado School of Mines.

HYDROTHERMAL RESOURCES IN THE WESTERN UNITED STATES*

Of the three basic types of geothermal resources in the world -- hydrothermal (wet and dry steam), hot dry rock, and geopressurized zones -- hydrothermal resources appear to offer the greatest potential for immediate development. Hydrothermal reservoirs, which consist of high-temperature water under pressure, are fairly common in the western United States. Hot dry rock systems, although more abundant, have not yet been evaluated beyond the preliminary research stage. Geopressurized zones are also being examined through research and exploratory efforts, but preliminary indications are that considerable technological effort will be required before the resources can be developed on a commercial basis.

The eleven western states are characterized by many phenomena which suggest anomalously high heat concentrations at shallow depths in the earth's crust. Subsurface heat flow in the western states is significantly higher than in the rest of the contiguous United States, and more than a thousand thermal springs have been found. Tensional tectonic activity is widespread and of young geological age, much of it manifest in historic seismic activity; and recent volcanism is widespread. Many basins are filled with large volumes of water-soaked layers, some of which are thermally insulated. The presence of all these phenomena in the western states suggests that the region has considerable potential for high-temperature hydrothermal energy development.

Hydrothermal resources are generally classified according to a number of different characteristics such as volcanism, resource occurrence, nature of

*The information provided in this subsection is based upon work performed in conjunction with this study by Dr. G. V. Keller and Dr. L. T. Grose of the Colorado School of Mines.

hydrothermal fluids, and mechanism of heat entrapment. In order to delineate those regions having potential for electrical energy production, nine geothermal regions have been defined in Figure 2-1 according to a combination of geological features and upper mantle and crustal processes. For the purpose of this report, however, only hydrothermal systems that have sufficiently high temperature (>150 C (302 F)) for electrical energy production are considered. The classification used herein is based on estimated reservoir base temperatures as follows:

- Low temperature: 150-200 C (302-392 F)
- Intermediate temperature: 201-250 C (393-482 F)
- High temperature: >250 C (>482 F)

The approach used in this report to estimate hydrothermal reserves (as described in Appendix A) is based upon the statistical data available from heat flow determinations which have been made throughout the continental United States. Assuming that the heat flow determinations are randomly distributed, these data can be used to estimate the hydrothermal resource base in each of the nine regions. The recoverable energy from hydrothermal sources in each region can then be estimated as a function of heat flow by using conventional methods of estimating hydrothermal fluid production, electrical energy production from hydrothermal fluid, and the area assumed to be available for hydrothermal development. By estimating the electrical energy which might be produced by a region, the electrical production capacity for the region can be estimated for a nominal 30-year facility lifetime, as shown in Table 2-1. It is recognized that the schedule for actual development will depend upon the economic balance between hydrothermal power and other competing sources of power generation.

In order to analyze plant performance for various resource conditions, resource temperatures of 150 C (302 F), 182 C (360 F), and 246 C (475 F) have been selected

for the parametric analyses. These values not only provide a range of temperatures but also are representative of several hydrothermal resources which have been discovered to date (Raft River, Heber, and Valles Caldera).

TABLE 2-1
ESTIMATES OF NOMINAL 30-YEAR ELECTRICAL PRODUCTION CAPACITY
FOR THE MAJOR HYDROTHERMAL REGIONS AS A FUNCTION OF HEAT FLOW

Hydrothermal Region	MWe			Total
	(3-4 hfu)	(4-5 hfu)	(> 5 hfu)	
Central California Coast Range	1,450	1,740	850	4,040
Cascade Range	200	120	30	350
Snake River Plain	2,050	3,420	3,000	8,470
Northwestern Basin and Range	5,600	7,560	3,780	16,940
Central Basin and Range	150	70	20	240
Eastern Basin and Range	880	620	160	1,660
Salton-Imperial Valley	480	800	700	1,980
Southern Basin and Range	960	420	90	1,470
Rio Grande Rift System	<u>1,840</u>	<u>2,050</u>	<u>1,100</u>	<u>4,990</u>
TOTAL	13,610	16,800	9,730	40,140

(Note: Discussion of hfu is given in Appendix A.)

HYDROTHERMAL PLANT CONVERSION PROCESSES

A number of processes have been devised for converting the thermal energy of water-dominated geothermal resources into electrical energy. The principal conversion processes are the flash steam process, the binary process, and the hybrid process, which is a combination of the flash and binary processes. As

further described in Section 3, these processes operate on the principle of producing a vapor either directly from the hydrothermal resource (flash steam process) or by transfer of energy from the hydrothermal resource to a suitable working fluid (binary process). The vapor is then expanded through a turbine or expander to produce mechanical work which, in turn, is used to drive an electrical generator. In this report, both the flash steam and the binary processes are analyzed.

CLIMATOLOGY AND COOLING SYSTEM PERFORMANCE

Climatological parameters not only determine the availability of water within a region but also affect power plant cooling system performance. For instance, in a dry cooling tower, higher ambient dry-bulb temperatures increase the turbine back pressure, which results in poorer fuel economy and loss of generating capability. The full range of annual ambient air temperatures at the site affect the fuel economy, but it is the maximum temperatures which have the more significant economic effect. The maximum temperature, in combination with the cooling system design parameters and the turbine characteristics, sets the maximum loss of generating capability which would be experienced during the year and is a major factor in determining the economically optimum design of a dry cooling tower system. Section 4 further describes the effect of climate upon cooling system design and performance.

The wet-bulb temperature likewise is an important parameter in the design and performance of evaporative-type cooling tower systems, since the wet-bulb temperature of the air is the lowest temperature to which the water circulating through the tower can be theoretically cooled. The design wet-bulb temperature of the air for a specific site is generally selected as that wet-bulb temperature which is exceeded no more than a small percentage of the time.

Makeup water requirements are also directly related to site wet-bulb temperature profiles, since the difference between the temperature of the hot circulating water and the ambient wet-bulb temperature is the driving force for evaporation in a wet cooling system. Because this temperature difference is greater in the summer, evaporation rates are higher during summer weather. Convective heat transfer, by comparison, is a function of the difference between the temperature of the hot circulating water and the ambient dry-bulb temperature. Greater temperature differences usually occur in the winter, with consequent increases in convective heat transfer.

Saturation deficit is defined as the quantity of water vapor required to saturate the ambient air. If the ambient wet-bulb temperature is high and the relative humidity is low, the evaporation rate in a wet cooling system is high and the convective heat transfer rate is low (high saturation deficit). On the other hand, if the ambient wet-bulb temperature is low and the relative humidity is high, the evaporation rate will be reduced and the convective heat transfer rate will be increased (low saturation deficit).

Additionally, as site elevation increases, the capital cost of the cooling system and the required fan horsepower tend to increase, since the reduced air density makes it necessary to move a volume of air greater than that required at a lower elevation through the cooling system in order to achieve the same mass flow rate. In other words, a tower designed to meet a certain duty at a lower elevation may not be capable of meeting that same duty at a higher elevation. This effect is somewhat offset, however, by the fact that air temperatures are generally lower at high elevations. Evaporation rates also increase with elevation due to the lower atmospheric pressures at higher elevations.



APPENDIX A

DESCRIPTION OF HYDROTHERMAL RESOURCES
IN THE WESTERN UNITED STATES

Note: Technical data contained in this section were prepared for this project by G. V. Keller and L. T. Grose of the Colorado School of Mines.

FIGURE 5-10

BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
 FOR DRY/WET PEAKING COOLING TOWERS
 FOR 150°C (300°F), 182°C (360°F) AND 246°C (475°F) FLASH AT HOT DESERT SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

Approximate extreme meteorological parameters for the selected major hydrothermal sites in the western United States (shown in Figure 2-1) are presented in Table 2-2. For purposes of parametric analyses, however, the following four types of sites represent an adequate range of dry-bulb and wet-bulb temperature variations, elevation, and geographical location insofar as the analysis of cooling systems for hydrothermal plants is concerned:

- Hot Desert (Data source: Heber, California)
- Basin and Range (Data source: Reno, Nevada)
- Pacific Northwest (Data source: Medford, Oregon)
- High Mountain (Data source: Valles Caldera, New Mexico)

Maximum, 2½ percent summer, and average dry-bulb and wet-bulb temperatures for the four sites are given in Table 2-3. Hourly climatological data in the form of dry-bulb temperature distributions for distinct categories of relative humidity were obtained from published sources for each type of site and are shown in Appendix B. This type of data is useful in analyzing the performance of alternative cooling systems under all conditions experienced during a typical year.

COOLING SYSTEM TYPES

Because of the relatively low temperatures of hydrothermal resources, the thermal efficiencies of hydrothermal conversion cycles are quite low, on the order of 10 percent. Thus, the waste heat rejection from the turbine exhaust flow of a hydrothermal power plant typically will be 20,000 to 30,000 Btu/kWh of electrical generation at design conditions, compared to approximately 5000 Btu/kWh for a modern fossil-fueled plant. If conventional evaporative cooling methods are to be used for geothermal power plants, large quantities of cooling water will be required.

Table 2-2

APPROXIMATE EXTREME METEOROLOGICAL PARAMETERS FOR SELECTED HYDROTHERMAL SITES

Hydrothermal Site	Hydrothermal Region	Barometric Pressure		1% Summer Dry-Bulb Temperature		1% Summer Wet-Bulb Temperature		99% Winter Dry-Bulb Temperature	
		mm Hg	(in. Hg)	C	(F)	C	(F)	C	(F)
1. Geysers-Clear Lake, CA	I	705	(27.8)	34	(94)	22	(72)	-3	(26)
2. Surprise Valley, CA	IV	640	(25.2)	32	(89)	17	(63)	-17	(1)
3. Gerlach and Fly Ranch, NV	IV	655	(25.8)	34	(93)	17	(63)	-14	(7)
4. Brady's Hot Springs, NV	IV	640	(25.2)	34	(93)	17	(63)	-14	(7)
5. Steamboat Springs, NV	IV	630	(24.8)	34	(93)	17	(63)	-14	(7)
6. Long Valley, CA	IV	585	(23.0)	38	(100)	18	(64)	-9	(16)
7. Coso Hot Springs, CA	IV	640	(25.2)	40	(104)	20	(68)	-8	(18)
8. Beowawe, NV	IV	630	(24.8)	34	(94)	18	(64)	-25	(-13)
9. Raft River, ID	IV	615	(24.2)	34	(94)	18	(65)	-22	(-8)
10. Roosevelt Hot Springs, UT	VI	610	(24.0)	34	(94)	18	(65)	18	(-1)
11. Imperial Valley, CA	VII	760	(29.9)	46	(114)	27	(81)	-2	(29)
12. Valles Caldera, NM	IX	545	(21.5)	33	(92)	18	(64)	-20	(-4)

Table 2-3

CLIMATOLOGICAL PARAMETERS FOR SITES SELECTED FOR PARAMETRIC ANALYSIS

<u>Type of Site</u>	<u>Maximum Temperature</u>		<u>2½% Summer Temperature</u>		<u>Average Temperature</u>		<u>Elevation</u>	
	<u>Dry-Bulb</u>	<u>Wet-Bulb</u>	<u>Dry-Bulb</u>	<u>Wet-Bulb</u>	<u>Dry-Bulb</u>	<u>Wet-Bulb</u>	<u>M</u>	<u>(Ft)</u>
	<u>C (F)</u>	<u>C (F)</u>	<u>C (F)</u>	<u>C (F)</u>	<u>C (F)</u>	<u>C (F)</u>		
Hot Desert	49 (120)	33 (92)	43 (110)	27 (80)	23 (73)	14 (57)	0	(0)
Basin and Range	39 (102)	21 (69)	33 (92)	17 (62)	10 (50)	4 (40)	1300	(1400)
Pacific Northwest	42 (107)	25 (76)	34 (94)	20 (68)	12 (53)	10 (46)	400	(1300)
High Mountain	36 (97)	21 (70)	31 (87)	16 (61)	8 (47)	3 (37)	2700	(8800)

As further described in Sections 3 and 4, wet, wet-dry, and dry cooling towers were the principal cooling systems considered in this study for rejecting the waste heat from a hydrothermal power plant. Once-through cooling, cooling ponds, and spray ponds are other cooling system alternatives, although they do not have as universal application as cooling towers for hydrothermal power plants.

If sufficient surface water or groundwater is available, or if the hydrothermal fluid can be used for cooling tower makeup, the conventional wet cooling tower can be used. Dry cooling towers, which transfer the waste heat from a power plant directly to the atmosphere by means of air-cooled, finned-tube heat exchangers without consumptive use of water, afford greater flexibility in power plant siting than other methods of waste heat rejection. This can be an especially important factor in considering the development of hydrothermal power plants. However, the low available energy of hydrothermal resources, which results in a rapid deterioration of turbine-generator performance as the condensing temperature increases above the design value, will have a significant effect on the relative economics of all-dry cooling tower systems for such applications.

By combining wet and dry cooling methods in a single system, the makeup water requirements associated with all-wet systems may be reduced significantly, usually with a considerably smaller increase in electrical energy production costs than would result from the use of an all-dry system. With this type of cooling combination the wet tower provides the additional cooling capacity required to maintain a relatively low back pressure, thus reducing the amount of generating capacity lost during high ambient air temperature operation.

WATER RESOURCE CONSIDERATIONS

The location and quantity of water for cooling system makeup is of fundamental importance to both the siting and design of power generation facilities. While conventional power plants are generally located in the proximity of surface water or groundwater resources, hydrothermal plants must be located at the production reservoirs, which may or may not be located in the vicinity of sufficient cooling water resources. Furthermore, since the majority of hydrothermal resources occur in arid climates, it is reasonable to assume that the availability of water for cooling system makeup may be of concern in many of the areas of hydrothermal interest. In many western areas, water resources are scarce, highly allocated, or influenced by regional institutional and legal considerations. Consequently, large quantities of water may have to be imported to the hydrothermal site, or special design provisions must be made which will reduce or eliminate the need for cooling system makeup water.

Availability of Water

The availability of water for various uses in the western United States is closely related to the climatic conditions which exist in the various regions. Moreover, the climatic types which would require the greatest amount of cooling system makeup water as a result of evaporation typically have the smallest amount of potentially available water.

The patterns of precipitation in the western states are extremely complex and variable as a result of predominant physiographic features, such as mountain ranges, which tend to inhibit and redirect the flow of moist air. Heaviest precipitation usually occurs in the vicinity of mountain ranges, especially on the windward slope. Moreover, maximum precipitation usually occurs in the winter, so that water storage reservoirs are required for irrigation and other purposes.

The average annual precipitation in the western United States ranges from approximately 12 to more than 200 cm (5 to more than 80 inches) per year, with corresponding surface runoff ranging from approximately 1 to 200 cm (1 to 80 inches) per year. Hence, the availability of surface water for various uses from precipitation and resultant runoff may be quite high in the humid regions, although it is generally very low in the more arid regions.

In many regions of the western states, groundwater resources are hydrologically related to surface water resources and therefore are also dependent upon patterns of precipitation. The use of groundwater resources in some areas may not be feasible since increased use may further deplete already dwindling reservoirs. The use of geothermal fluids may be feasible at some sites, depending upon their chemical composition and the necessity to reinject fluids to prevent subsidence or maintain reservoir integrity.

Institutional and Legal Considerations

Since water is a scarce resource in most of the western United States, a large number of institutions and regulatory bodies have been established to provide for equitable distribution. The availability of water for use by hydrothermal plants may therefore be limited or influenced by constraints associated with water rights and state and federal allocation policies.

Included in allocation policies are international agreements, interstate compacts, and federal and Indian claims to water rights. In addition, individual states have enacted legislation to exercise control over the acquisition and use of water within the state, and many states exercise control over the use of groundwater as well. The appropriation system of water allocation is predominant in the western states. The major feature of this system is the concept of "first in time, first in right"; that is, the right of the earliest appropriator

supersedes all other claims. Appropriation by other appropriators is possible only if water is available in excess of that claimed by the earlier appropriators. During periods of water shortages, some appropriators may not be entitled to any water.

The appropriation system has been replaced by a permit system in most of the western states. This system, based primarily on the appropriation law, is essentially an administrative change which gives the state engineer or board of water rights the authority to grant or deny applications for water rights.

Cost of Water

The cost of water for power plant makeup is highly dependent upon the general availability and quality of the source of water. For instance, the unit cost of water (i.e. cost per gallon, acre-foot, etc.) may be relatively high for those sites where the water is either in short supply or highly allocated. Similarly, the transportation of water from a remote source, or the treatment of poor quality water, may result in a relatively high makeup water cost. The determination of exact costs of makeup water for the various regions of the western states would be a labyrinthian exercise. However, by performing analyses for a range of water costs, parametric economic evaluations of cooling systems can be made without extensive hydrological studies on a site-specific basis. The cost of water in this study is assumed to include acquisition, transportation, treatment, and disposal.

HYDROTHERMAL RESOURCE COSTS

In the optimization and evaluation of alternative heat rejection systems for hydrothermal power plant applications, it was assumed that the hydrothermal resource will be purchased by the utility from a producer who will provide the

resource at the plant site. Therefore, the costs of developing, producing, and supplying the hydrothermal resource were considered to be included in the fuel cost rather than being treated separately in the economic analysis. Hydrothermal fuel cost is further described in Sections 3 and 4.

ECONOMIC PARAMETERS

In analyzing waste heat rejection systems for hydrothermal power plants, the following factors should be considered:

- Size of cooling system
- Capital cost
- Annual fixed-charge rate
- Ambient air temperature and durations
- Resource cost
- Turbine-generator performance
- Auxiliary energy requirements
- Replacement capacity and energy costs
- Makeup water costs
- Operation and maintenance costs

Computer models which consider the above factors were used to perform optimization and economic analyses of waste heat rejection systems for the various resources (high, intermediate, and low temperature) for both the flash steam and binary conversion processes. These models are described in detail in Section 4.




FIGURE 2-1
SELECTED MAJOR HYDROTHERMAL REGIONS AND SITES
IN THE WESTERN UNITED STATES

Section 3

COMBINED PERFORMANCE OF HYDROTHERMAL CONVERSION PROCESSES AND COOLING TOWER SYSTEMS

GENERAL

In evaluating alternative cooling tower systems for power plants, an understanding of the combined performance of the turbine-generator and cooling tower is essential. The complex relationships which exist between the tower and the turbine must first be determined in order to predict the performance of a combination of turbine-generator and cooling tower system.

The three major factors given consideration in this part of the study were:

- Hydrothermal Conversion System
- Turbine-Generator System
- Cooling Tower System

The conversion system includes the hydrothermal heat exchanger for the binary system and the flash tanks and moisture separators for the flash steam system. The turbine-generator system assumed for this study includes the hydrocarbon turbine and generator for the binary system and the steam turbine and generator for the flash steam system. The cooling tower system includes the cooling tower or towers, condenser, and circulating water facilities.

HYDROTHERMAL CONVERSION SYSTEM

Binary Conversion Process

A binary conversion system utilizes a heat exchanger which transfers heat from the hot hydrothermal fluid to a secondary working fluid such as a hydrocarbon. The unique fluid properties of commercial isobutane, for example, permit much higher working pressures than possible with steam at the same temperature, thereby increasing overall turbine efficiency. Also, due to the low specific volume of commercial isobutane as compared to steam, the hydrocarbon turbine is physically smaller than the steam turbine and has a lower capital cost.

For the sites and resource temperatures considered in this study, the following assumptions were made regarding the binary conversion process:

- In order to prevent fouling of reinjection facilities, the geothermal supplier has established a minimum reinjection temperature of 71 C (160 F). Therefore, maximum energy is extracted from the hydrothermal fluid when the temperature of the hydrothermal fluid leaving the heat exchanger is 71 C (160 F).
- "Fuel cost" is based upon the amount of energy extracted, that is, cost per pound per hour of hydrothermal fluid pumped. Minimum fuel cost will occur when the spent hydrothermal fluid is reinjected at 71 C (160 F).

In evaluating the heat exchanger performance of the binary conversion system, two basic equations were used:

$$(1) Q = UA \bar{\Delta T}$$

where Q = Heat transferred by heat exchanger (Btu/hr)

U = Heat transfer coefficient of heat exchanger (Btu/hr-ft²-°F)

A = Surface area of heat exchanger (ft²)

$\overline{\Delta T}$ = Average incremental temperature difference across heat exchanger ($^{\circ}\text{F}$)

$$\text{and (2) } Q = \dot{m}_h C_p (T_{in} - T_{out}) \quad \text{or} \quad Q = \dot{m}_i (h_{out} - h_{in})$$

where Q = Heat transferred by heat exchanger (Btu/hr)

\dot{m}_h = Mass flow rate of hydrothermal fluid (lbs/hr)

C_p = Specific heat of hydrothermal fluid (Btu/lb- $^{\circ}\text{F}$)

T_{in} = Hydrothermal resource temperature ($^{\circ}\text{F}$)

T_{out} = Hydrothermal fluid return temperature ($^{\circ}\text{F}$)

\dot{m}_i = Mass flow rate of isobutane (lbs/hr)

h_{in} = Enthalpy of isobutane entering heat exchanger (Btu/lb)

h_{out} = Enthalpy of isobutane leaving heat exchanger (Btu/lb)

It was assumed that the heat transfer coefficient U would remain constant for the expected temperature conditions. Because heat exchanger surface area A is geometrically fixed, the ratio $Q/\overline{\Delta T}$ would be constant also, thereby enabling calculations to be made over the expected range of condensing temperatures of the hydrocarbon turbine. Using equations (1) and (2) (assuming $C_p = 1.0$ Btu/lb- $^{\circ}\text{F}$), T_{out} can be calculated for the range of condensing temperatures. This method of evaluating heat exchanger performance falls well within the accuracy limits of this study and, in addition, simplifies calculations considerably.

Figure 3-1 illustrates the heat exchanger temperature profiles for the 150 C (300 F), 182 C (360 F), and 246 C (475 F) resources. Since the hydrocarbon turbine cycle was assumed to be the same for all three resource temperatures, a single temperature profile curve for commercial isobutane is given.

The binary cycle using commercial isobutane was designed specifically for a 182 C (360 F) hydrothermal resource. Thus, when used with a 246 C (475 F) resource, the binary cycle using commercial isobutane does not take full advantage of the high resource temperature. In the case of the 150 C (300 F) resource, the heat exchanger experiences pinch point problems, as shown in Figure 3-1, which prevent a low hydrothermal fluid return temperature. This significantly increases fuel requirements and fuel cost and makes the 150 C (300 F) supercritical isobutane cycle a poor design choice as well.

An earlier study performed by the Ben Holt Company of Pasadena, California (EPRI ER-301) showed that subcritical isobutane cycles or supercritical cycles using 50 percent propane and 50 percent isobutane would be better suited for the 150 C (300 F) resource temperature. The 50 percent propane/50 percent isobutane supercritical cycle would also be well suited to the 150 C (300 F) resource temperature, but performance data for a turbine operating with this mixture were not available at the time this study was performed.

Flash Steam Conversion Process

A flash steam conversion process utilizes the thermodynamic flashing principle to convert a portion of the hot hydrothermal fluid into usable steam to drive a steam turbine. The percent of hot hydrothermal fluid that flashes to steam ranges from about 10 percent for the 150 C (300 F) resource to about 25 percent for the 246 C (475 F) resource. Each resource temperature operates at different flash pressures, as shown in Table 3-1.

TABLE 3-1

FLASH PRESSURES ASSUMED FOR HYDROTHERMAL
FLASH STEAM CONVERSION PROCESSES

Resource Temperature °C (°F)	First Stage Flash Pressure kP (psia)	Second Stage Flash Pressure kP (psia)
150 C (300 F)	290 (42)	110 (16)
182 C (360 F)	379 (55)	138 (20)
246 C (475 F)	1055 (153)	232 (33.7)

The pressures shown are those used by the Ben Holt Company in EPRI Research Project 580, Topical Report 2, November 1976. The Ben Holt Company indicated that these pressures are the optimum combination for each resource temperature for minimizing the hydrothermal fluid flow from the resource.

A significant fuel cost penalty for the flash steam conversion system is incurred since the hydrothermal fluid is flashed at above atmospheric pressure in order to prevent leakage of air into the system. Therefore, the spent hydrothermal fluid, even when mixed with cool condensate, will always be at a temperature above 93 C (200 F) and could reach temperatures as high as 116 C (240 F), depending on resource temperature and ambient air temperatures. The high return temperature of the spent hydrothermal fluid represents a consistent penalty of 40 to 80 Btu/lb of fluid with respect to the 71 C (160 F) minimum return temperature limitation. This results in an increase in required hydrothermal fluid of 25 percent for the 246 C (475 F) resource and 50 percent for the 150 C (300 F) resource to generate the same amount of energy. Apart from flashing at lower-than-atmospheric pressures, which is not recommended, little can be done to reduce this penalty.

TURBINE-GENERATOR SYSTEM

Hydrocarbon Turbine

The turbine used for the binary analysis was an Elliott tandem-compound two-flow hydrocarbon turbine rated at 65.0 MWe at 586 kP (85 psia) exhaust pressure with commercial isobutane as the working fluid. Constant turbine inlet conditions of 379 kP (550 psia) and 143 C (290 F) upstream of the throttle valve were assumed. In order to maintain constant turbine inlet conditions with varying condensing temperature (a requirement due to limited turbine performance data), it was necessary to vary the flow of hydrothermal fluid through the heat exchanger to compensate for the effect due to the changing temperature of the isobutane entering the heat exchanger from the condenser. This operation would probably require a more sophisticated control system to function properly. The Elliott Company has also established a limit on turbine-generator output of 69.55 MWe, a 7 percent over-limit of the generator. Although considered in the computer analyses, the generator output limit was not shown in representing the turbine-generator performance in the curves of this section.

Figure 3-2 compares the performance of the Elliott axial-flow turbine with the performance of the Rotoflow radial-flow turbine. Both curves are for 3792 kP (550 psia), 143 C (290 F) throttle conditions and approximately 3,900,000 kg/hr (8,700,000 lb/hr) of commercial isobutane. Although computer analyses of the radial turbine were not performed in this study, it was assumed that the axial turbine evaluation is representative of what the radial turbine would have produced, had the required data been available. This is due to the fact that the performance of both turbines is comparable near the turbine design point. Therefore, except for differences in capital or operating costs, the evaluated busbar costs should be comparable for both the axial and radial turbine designs.

Flash Steam Turbine

The turbine used for the flash steam analyses was a General Electric tandem-compound four-flow steam turbine rated at 55.0 MWe at 14 kP (4 inches Hg) exhaust pressure. Turbine inlet conditions, as shown in Table 3-2, were assumed to be constant for a specific resource temperature.

TABLE 3-2

STEAM TURBINE INLET CONDITIONS FOR HYDROTHERMAL FLASH STEAM CONVERSION PROCESSES

<u>Resource Temperature</u> °C (°F)	<u>First Stage Turbine Inlet</u> Pressure kP (psia)	<u>Second Stage Turbine Inlet</u> Pressure kP (psia)
150 (300)	269 (39.1)	103 (14.9)
182 (360)	353 (51.2)	128 (18.6)
246 (475)	981 (142.3)	216 (31.3)

Different turbine inlet pressures require different turbine designs, so that the 150 C (300 F) resource temperature, having the lowest flash pressures, requires the largest steam turbine due to the higher specific volume of the low pressure steam. Performance of the steam turbine for all three resource temperatures is illustrated in Figure 3-3. The curves shown were calculated using established General Electric steam turbine performance estimating methods.

Gross Heat Rate

Gross heat rate, illustrated in Figures 3-4 and 3-5, is defined in this study as the heat input into the cycle by the hydrothermal fluid divided by the gross energy output, and is expressed in Btu/kWh. The single curve for the binary case is representative of all three resource temperatures studied. Conversely, the flash steam cycle gross heat rate is unique for each resource temperature. Gross heat rate for the binary system was calculated from the Elliott hydrocarbon

turbine performance data, and gross heat rate for the flash steam system was calculated from the General Electric steam turbine performance data.

Cost Heat Rate

The cost heat rates shown in Figures 3-6 and 3-7 form the basis for fuel cost evaluation in this study. Cost heat rate is defined as the hydrothermal heat energy charged to the plant divided by the gross energy output, and is expressed in Btu/kWh. The 246 C (475 F) resource, when referenced to the established minimum hydrothermal fluid return temperature of 71 C (160 F), provides 315 Btu/lb of available heat. Likewise, the 182 C (360 F) resource provides 200 Btu/lb, and the 150 C (300 F) resource provides 140 Btu/lb, assuming the hydrothermal fluid has a specific heat of 1.0 Btu/lb-°F. Therefore, if the cost of hydrothermal fluid is \$0.50/10⁶ Btu, the cost of 1000 pounds of hydrothermal fluid is \$0.16 for the 246 C (475 F) resource, \$0.10 for the 182 C (360 F) resource, and \$0.07 for the 150 C (300 F) resource. However, because the plant hydrothermal fluid requirement increases with decreasing resource temperature, the net result is that overall fuel cost in mills/kWh is higher with a lower temperature resource. If the evaluation were made on the basis of equal cost per 1000 pounds for all three resources, relative busbar costs among the three resources would increase, but would not affect the conclusions of this study.

Figure 3-6 illustrates cost heat rate for the binary case. It should be emphasized that the curves shown for the 150 C (300 F) and 246 C (475 F) resources reflect high fuel costs due to the use of a non-optimum hydrocarbon working fluid (commercial isobutane) as previously explained. With optimized binary designs, one would expect to see a more even spread between the curves as in Figure 3-7, which reflects optimum designs for the flash steam cases.

COMBINED PERFORMANCE OF HYDROTHERMAL CONVERSION SYSTEMS WITH COOLING TOWERS

Figures 3-8 and 3-9 show turbine heat rejection for the binary cases and the flash steam cases, respectively. These curves are important in the design of the cooling tower system. For a given cooling tower, increased heat rejection results in a higher exhaust pressure, poorer plant performance, and, in the case of a wet tower, higher evaporative losses.

Figures 3-10 through 3-16 demonstrate combined performance of a binary turbine and a cooling tower. To avoid confusion and an excessive number of curves, similar illustrations were not included in the report for the flash steam cases, since the figures included for the binary cases are representative of the flash steam cases as well.

Figure 3-10 shows performance curves for an 11 C (20 F) ITD mechanical-draft direct dry cooling tower with the heat rejection curve for the binary turbine superimposed, and demonstrates combined performance of the binary turbine with a dry cooling tower. At a given ambient air temperature, using an 11 C (20 F) ITD tower, the binary turbine will have a unique heat rejection and condensing temperature. The condensing temperature is the sum of the ambient air temperature plus the tower ITD at the point of design tower heat rejection. This holds true for direct dry towers with any ITD. Figures 3-11 and 3-12 show progressively smaller direct dry towers with a 33 C (60 F) ITD and 56 C (100 F) ITD, assuming the same design heat rejection as the 11 C (20 F) ITD tower. Tower performance is shown only over a range of ambient air temperatures sufficient to include the Elliott turbine heat rejection curve.

Figure 3-13 illustrates the combined performance a wet cooling tower with a design wet-bulb temperature of 21 C (70 F) serving a binary turbine. From this

graph, it can be shown that a 6 C (10 F) change in wet-bulb temperature, for example, has only about half the effect on condensing temperature with a wet tower that the same change in ambient air temperature has on condensing temperature with a direct dry tower. Under ambient temperature conditions where a dry tower would lose significant capability, a wet tower would perform with very little loss in capability. Figures 3-14 and 3-15 illustrate this point by demonstrating performance of the binary turbine with a dry and wet tower, respectively. For example, assume that the site has an average ambient air temperature of 12 C (53 F) and an average wet-bulb temperature of 8 C (46 F), and that the maximum ambient air temperature is 42 C (107 F) and maximum wet-bulb temperature is 23 C (73 F). Using Figure 3-15, at an 8 C (46 F) wet-bulb temperature, the gross generator output of the binary turbine would be 68.5 MW. At the maximum wet-bulb temperature of 23 C (73 F), the gross generator output would be 59 MW, a loss in capability of 9.5 MW. Using Figure 3-14, assuming a 33 C (60 F) ITD dry tower and an ambient air temperature of 12 C (53 F), the gross generator output would be 63.0 MW. At the maximum ambient air temperature of 42 C (107 F), the gross generator output would be 31.5 MW, a loss of 31.5 MW.

It is extremely cumbersome to exactly represent the performance of a wet/dry system in the form of a graphic illustration, since performance would have to be represented as a function of both wet-bulb temperature and dry-bulb temperature simultaneously. Figure 3-16, which represents only an approximation of a typical case, shows the gross generator output curve and the net generator output curve (gross output less auxiliary power) for the binary turbine. Operation of the dry/wet peaking cooling tower is described in Section 4.




FIGURE 3-1 TEMPERATURE PROFILES OF HYDROTHERMAL HEAT EXCHANGERS




FIGURE 3-2 TURBINE-GENERATOR PERFORMANCE - BINARY








FIGURE 3-3 TURBINE-GENERATOR PERFORMANCE-FLASHED STEAM








FIGURE 3-8 TURBINE HEAT REJECTION - BINARY










FIGURE 3-9 TURBINE HEAT REJECTION - FLASHED STEAM










FIGURE 3-16 TYPICAL COMBINED PERFORMANCE OF ELLIOTT TURBINE WITH A MECHANICAL-DRAFT DIRECT WET-DRY COOLING SYSTEM

Section 4

OPTIMIZATION AND EVALUATION OF ALTERNATIVE HEAT REJECTION SYSTEMS FOR HYDROTHERMAL POWER PLANTS

GENERAL METHODOLOGY

In order to make economic evaluations of alternative heat rejection systems for hydrothermal power plant applications, the design of each candidate heat rejection system should be optimized for each set of site, plant, and operating conditions to be considered. The optimum design for the heat rejection system will be that which results in the lowest net electrical energy production costs. The optimum system, associated costs, and water requirements can then be determined by comparing the results of the optimization analyses for the various types of heat rejection systems.

The pertinent design variables to be optimized relate primarily to the physical size of the heat exchange components of the system. These variables include (1) the cooling range and approach in an evaporative cooling tower and (2) the initial temperature difference (ITD) between the temperature of the warm circulating water entering an indirect dry tower, or the condensing temperature of the turbine cycle working fluid in a direct dry tower, and the temperature of the ambient air entering the tower. In general, the capital cost of a heat rejection system increases, and system performance, turbine-generator performance, and operating economy improve as the sizes of the heat exchange components increase.

The required sizes and installed capital costs of the various system components are determined for the given site and plant design conditions. The cumulative annual combined performance of the heat rejection system design and turbine-generator are then determined based upon an assumed operating mode and duration of ambient temperatures. Evaluated annual capital and operating costs, penalties, and credits can then be determined. Net electrical energy production costs on a kilowatt-hour basis are determined by dividing total annual net evaluated costs by annual net electrical generation.

Turbine-generators rated at different turbine exhaust conditions and/or having different performance characteristics should also be investigated, since the generating capability will vary for different heat rejection system designs. Therefore, in order to make comparisons among heat rejection systems, the performance obtained in each case should be measured against an assumed reference system as described hereinafter.

The above procedure is then repeated for other combinations of values for the system design variables. The optimum design of the heat rejection system is then determined from a comparison of the net electrical energy production costs calculated for the various designs considered. By performing similar analyses for various types of heat rejection systems, the economically optimum type and design of heat rejection system can be determined.

COSTS AFFECTED BY TYPE OR DESIGN OF HEAT REJECTION SYSTEM

Heat Rejection System Capital Cost

The heat rejection system capital cost includes equipment, materials, and installation or erection costs for all components and facilities from the turbine exhaust flange outward. This would include condensers, towers, circulating

water facilities, storage facilities, controls, and any other components required by a particular type of heat rejection system.

Appropriate allowances for engineering and contingencies, escalation, and interest during construction are also included in the estimated capital cost. Annual operation and maintenance costs are also typically calculated as a percentage of total heat rejection system capital cost.

Hydrothermal Energy Conversion System Capital Cost

The hydrothermal energy conversion system includes the heat exchangers, fluid circulating facilities, piping, turbine-generator, controls, and any other equipment directly involved in the conversion of the thermal energy of the hydrothermal resource into electrical energy. The optimum turbine-generator design and design condensing temperature may be affected by the type of heat rejection system and may also affect the overall design and total capital cost of the conversion system. In addition, conversion system and heat rejection system auxiliary power requirements will also affect the required size and capital cost of the conversion system. Appropriate allowances for indirect costs are also included in the estimated capital cost of the conversion system.

Annual Hydrothermal Resource Cost

Lower conversion cycle efficiencies of turbines designed for high condensing temperature operation, as compared with those designed for lower condensing temperatures, will result in greater annual hydrothermal resource requirements and costs for the same electrical energy production. Conversion cycle efficiency and annual hydrothermal resource requirements and costs will therefore depend upon the type of conversion process being considered.

Annual Cooling Water Makeup Cost

Conventional evaporative heat rejection methods require considerable quantities of cooling water makeup to replace losses due to evaporation, blowdown, and drift. Makeup requirements and costs are dependent upon cooling system design and can be significantly reduced by use of wet/dry cooling tower systems and essentially eliminated with dry cooling towers.

Costs Associated With Loss of Generating Capability

The generating capability of a hydrothermal turbine-generator decreases significantly with increasing turbine exhaust pressure, or condensing temperature, which increases with ambient temperature. Traditional approaches to analyzing heat rejection systems have assumed that either the conversion system and/or the heat rejection system must be sized to meet the electrical load demand under high ambient temperature conditions or provisions must be made for replacing losses associated with the reduced capability of the generating unit under high ambient temperature conditions. Alternatively, the conversion system and heat rejection system can be designed without provisions for sizing to meet a demand or for replacing losses.

Sizing the Conversion System. Sizing the conversion system, including the turbine-generator, to meet the desired electrical load demand at the highest condensing temperature expected will result in a high capital cost plant with excess generating capacity under the more favorable operating conditions which will exist during the remainder of the year. No provision is made for installing replacement capacity, and therefore no penalties are assessed. The reasonableness of this approach will depend upon the following considerations:

- Whether or not a market or need exists for the excess generation

- Whether or not the hydrothermal resource flow rate can be varied, thereby conserving the resource under favorable operating conditions
- The economic trade-off between the high capital cost of the conversion system and the potential income or savings associated with the available excess generating capability.

Sizing the Heat Rejection System. An alternative method of analysis is to size the heat rejection system so that high condensing temperatures will be avoided during high ambient temperature operation. This would result in greater cooling capacity than required under lower ambient temperature conditions. This might be a reasonable approach for evaporative-type heat rejection systems, since the variation in turbine-generator performance due to ambient conditions generally is limited to a relatively narrow range. This approach is not likely to be feasible for dry cooling systems, however, since the performance of a dry tower is nearly a linear function of ambient dry-bulb temperature, which typically varies over a wide range throughout the year at most sites. Thus, a dry tower system designed on the basis of the maximum ambient dry-bulb temperature occurring at a given site would be very large and costly and would have a much greater cooling capacity at low ambient temperatures than could be effectively utilized by a hydrothermal generating unit. The required size of the dry tower can be reduced significantly, however, by combining it with a wet peaking tower.

Replacement of Losses. Alternatively, the hydrothermal energy conversion and heat rejection systems can be designed on the basis of ambient conditions which will prevail over a greater part of the year, with capacity losses resulting from the reduced generating capability at higher temperatures being replaced from other sources. The required peaking capacity and replacement generation could be provided by gas turbines or other peaking units, or could be purchased from other utility systems which have excess generating capacity available.

No Sizing or Replacement of Losses. Since geothermal energy is normally considered to be a base load energy alternative, a "take-what-you-get" type of operating mode may also be reasonable. In this type of mode, the conversion system and heat rejection system are not sized to meet a demand, and replacement capacity and energy are not provided. Rather, it is assumed that the plant is utilized strictly for energy production and not for satisfying capacity requirements, although at least some measure of generating capacity can be considered as available for the system.

FACTORS WHICH INFLUENCE THE OPTIMIZATION AND COMPARATIVE EVALUATIONS OF ALTERNATIVE HEAT REJECTION SYSTEMS

Optimization of a heat rejection system essentially represents a trade-off between annual costs associated with constructing, owning, operating, and maintaining the system and annual costs related to the performance of the system. The optimum selection of a heat rejection system also includes consideration of the effects of each type of heat rejection system on the evaluated capital costs and operating economy of the hydrothermal energy conversion system.

Capital Cost of Heat Rejection System

The capital cost of a heat rejection system increases with the size of the system and is a major factor in determining the optimum design. The capital costs of optimum-sized dry and wet/dry cooling tower systems typically are higher than for evaporative-type systems for a given application.

Capital Cost of Hydrothermal Energy Conversion System

The size and capital cost of the hydrothermal energy conversion system are functions of the turbine-generator design, turbine cycle conversion efficiency, and the auxiliary power requirements of the conversion and heat rejection systems.

Efficient turbine-generator designs are likely to be relatively expensive but will reduce the operating cost by providing better turbine-cycle conversion efficiencies. Cycle efficiency improves with decreasing turbine exhaust pressure, or condensing temperature, and thus favors a larger size of heat rejection system. In a binary system, plant output and performance deteriorate as the hydrocarbon turbine operates off the design point. However, auxiliary power requirements increase with the size of the heat rejection system, thereby increasing the required size, auxiliary power requirements, and capital cost of the hydrothermal energy conversion system.

Annual Operation and Maintenance Costs

Annual operation and maintenance costs typically are calculated as percentages of the installed capital costs and increase with the size of the energy conversion and heat rejection systems. Estimates of capital costs will therefore affect estimates of operation and maintenance costs in the analyses.

Turbine-Generator Performance Characteristics

In addition to affecting the size and capital cost of the hydrothermal energy conversion system, the turbine-generator performance characteristics will also determine the design heat load on the heat rejection system. Turbine-generator performance will also determine both the annual net electrical generation produced by the hydrothermal unit, assuming a constant geothermal fluid flow, and the peaking capacity and replacement generation requirements.

The optimization of the heat rejection system, particularly in the case of dry towers, may also be affected by the performance characteristics of the turbine-generator at low exhaust pressures or condensing temperatures. At the back pressure at which the exhaust flow from a steam turbine has reached sonic velocity, further decreases in turbine exhaust pressure fail to produce any

additional improvement in turbine-generator performance. For a hydrocarbon turbine, efficiency falls off sharply and performance deteriorates below a specific blade path pressure ratio. Therefore, the turbine-generator may be unable to effectively utilize the cooling capacity of a large heat rejection system under low ambient temperature conditions.

Ambient Air Temperatures

As mentioned in Section 2, the performance of dry cooling tower systems is nearly a linear function of ambient dry-bulb temperature, whereas the performance of evaporative-type heat rejection systems is affected primarily by the ambient wet-bulb temperature and, to a lesser extent, the ambient dry-bulb temperature. Wet-bulb temperatures generally do not vary over as great a range as dry-bulb temperatures. Since the approach to the wet-bulb temperature decreases as wet-bulb temperature increases, the performance of an evaporative-type heat rejection system generally is not as adversely affected by increases in ambient temperature as that of a dry system. At low ambient temperatures the performance of a dry cooling system may exceed that of an evaporative system. Thus, the most favorable applications for dry cooling systems are where average and maximum ambient temperatures are relatively low. High ambient temperatures will greatly increase the optimum size of a dry cooling system and will favor the use of evaporative-type heat rejection systems. The penalties associated with the use of dry cooling systems for high ambient temperature applications can be reduced significantly, however, by combining a dry tower with a wet peaking tower.

The entire range of ambient air temperatures occurring at a site affect the annual electrical generation and the replacement energy requirements of the plant. However, for a utility with a summer peak electrical demand, the maximum ambient temperature generally determines the peaking capacity requirements or,

alternatively, the size of the generating plant if peaking capacity is not to be provided.

Cost of Replacement Capacity

Although the cost of capacity required to replace the loss of generating capability suffered at high ambient temperatures is a capital cost item, it results from a consideration of the performance of the heat rejection system. Therefore, an increase in the cost of peaking capacity will tend to increase the optimum size of the heat rejection system.

Cost of Replacement Energy

An increase in the cost of replacement energy required to meet the electrical load demand when the hydrothermal generating unit cannot do so will favor a larger heat rejection system and a turbine-generator design whose performance is less affected by increases in exhaust pressure or condensing temperature.

Annual Fixed-Charge Rate

The annual fixed-charge rate is the percentage rate applied to the capital costs of the hydrothermal energy conversion system, the heat rejection system, and the installed peaking capacity to determine the annual costs of the following items:

- Interest, or cost of money
- Depreciation, or amortization
- Interim replacements
- Insurance, or payments in lieu of insurance
- Taxes, or payments in lieu of taxes

By increasing the annual fixed-charge rate, the significance of capital costs in the economic analyses also increases.

Unit Hydrothermal Resource Costs

For this study, it has been assumed that the hydrothermal resource will be purchased by the utility from a producer who will provide the resource at the plant site. Therefore, the costs of developing, producing, and supplying the hydrothermal resource will be considered to be included in the fuel cost rather than being determined separately in the economic analyses. An increase in the unit cost of the hydrothermal resource will favor conversion system (including the turbine-generator) and heat rejection system designs which maximize the overall conversion efficiency, i.e., larger, higher capital cost heat rejection systems.

It has also been assumed that the utility will purchase geothermal heat on a cost per million Btu basis calculated as a function of the difference between the initial resource temperature and a set minimum return temperature designed to prevent scaling in the reinjection wells. Therefore, depending upon the initial temperature of the resource, the utility would pay for a set number of Btu per pound of resource, regardless of return temperature.

Unit Water Costs

The cost of cooling water makeup is assumed to include the base cost of the water plus the cost of supplying and treating it. Higher unit water costs will improve the comparative economics of wet/dry and dry cooling tower systems.

DESCRIPTION OF COMPUTER PROGRAMS

The foregoing pages describe the general approach incorporated in the computer programs which have been developed for optimizing and evaluating cooling tower systems for hydrothermal plants. Input data are read into the programs at the time of execution from three separate data files. These files contain the following types of data:

- Site-specific data, such as ambient temperature duration data
- Characteristic performance data for the turbine-generator design being considered
- Input data applicable to a particular analysis, such as the ranges of unit input energy and makeup water costs to be considered; the source and costs of peaking capacity and replacement generation, if provided; the assumed annual operating profile; and the scheduled startup date for the plant

Basic design, characteristic performance, and unit capital cost data applicable to the various components of the cooling tower systems are incorporated in the programs in DATA statements.

The performance of a cooling tower system design is determined by use of applicable characteristic tower performance equations. For example, dry cooling towers are sized on the basis of performance data supplied by manufacturers of such equipment. Performance equations adopted by the Cooling Tower Institute are used to determine the performance and size of an evaporative cooling tower for given design conditions. Steam surface condensers are designed according to Heat Exchange Institute (HEI) standards, whereas hydrocarbon condensers are designed on the basis of manufacturer-supplied information. Other components of the heat rejection system, such as pumps and piping, are sized in accordance with established power plant design practice. The wet/dry program assumes that the turbine exhaust flow is directed to two separate condensers, one served by a wet tower and the other served by a dry tower.

The capital costs of major equipment items (towers, condensers, pumps, etc.) are determined from manufacturers' quotations and pricing guides. Construction costs are estimated on the basis of published information, manufacturers' installation and erection cost estimates, and construction cost data compiled by R. W. Beck and Associates from previous design and construction engineering

jobs. Capital cost data incorporated in the computer programs are based on national average material costs and labor rates and a given base year. Adjustments can be made for annual escalation rates, construction cost indices applicable to the given site, the projected length of the construction period, and the scheduled startup date for the plant.

The wet/dry cooling tower program assumes that the wet tower will be used only as a peaking tower to prevent the condensing temperature from exceeding a specified maximum value when the dry tower alone could not maintain the specified condensing pressure or temperature. This operating mode results in the minimum water consumption for the wet/dry system. For instance, if the dry cooling tower is able to carry the full heat load without exceeding the specified maximum operating back pressure at a given ambient air temperature, only the dry tower is used. When the minimum back pressure operating condition is reached, dry tower fan power is reduced by switching fans to half-speed or by taking fans out of service in order to reduce auxiliary energy requirements. When ambient temperatures increase to the point where the dry tower alone is not able to maintain the specified maximum operating back pressure, wet tower capacity is activated as required to maintain that back pressure. If additional wet cooling were added at this point, the back pressure would decrease, with resulting improvement in turbine-generator performance. However, this mode of operating the wet/dry cooling system to achieve optimum fuel economy is not considered, since the purpose of the wet/dry cooling tower program is to determine the amount of water which can be saved.

The annual combined performance of the turbine-generator and heat rejection system is evaluated on essentially an hour-by-hour basis over the annual range of ambient temperature conditions normally expected to occur at the given site.

The computer programs are structured to use weather data as published in the Decennial Census of United States Climate - Summary of Hourly Observations.

A list of the information which can be obtained from the computer programs is presented in Section 5.

Section 5

PARAMETRIC EVALUATIONS OF COOLING SYSTEMS FOR HYDROTHERMAL POWER PLANTS

RANGE OF PARAMETERS CONSIDERED IN ANALYSES

In order to make meaningful economic evaluations of alternative cooling systems for hydrothermal power plants, numerous parameters should be analyzed to determine busbar energy production costs and makeup water requirements. A detailed discussion of these parameters is provided in Section 2, and the computer programs which have been developed to perform the evaluations are described in Section 4.

Specifically, the parametric analyses performed for this study assumed the following range of values:

- Hydrothermal resource temperature: 150 C (300 F), 182 C (360 F), and 246 C (475 F)
- Hydrothermal power plant conversion process: Flash steam and binary
- Climatological type: High Mountain, Pacific Northwest, Basin and Range, and Hot Desert
- Cooling system type: Mechanical-draft wet towers and mechanical-draft direct dry/wet peaking towers
- Annual fixed-charge rate: 15 percent
- Hydrothermal "fuel cost": $\$0.50/10^6$ Btu and $\$1.00/10^6$ Btu
- Makeup water cost: $\$0.10/\text{Kgal}$, $\$1.00/\text{Kgal}$, and $\$2.50/\text{Kgal}$ (includes acquisition, transportation, treatment, and disposal costs)

By selectively analyzing various combinations of values for these parameters, it is possible to compare the busbar energy production costs and makeup water requirements for hydrothermal power plants equipped with alternative cooling tower systems under different site, design, and economic conditions.

The following assumptions were made for all cases considered:

- Nominal electrical output of flash steam plant: 55 MWe gross and 50 MWe net
- Nominal electrical output of binary plant: 65 MWe gross and 50 MWe net
- Scheduled commercial startup date: 1980
- Annual hours of operation: 6500
- Capital costs described in Appendix C
- 4.5 cycles of concentration of circulating water in the evaporative cooling tower

PRELIMINARY ANALYSES PERFORMED

Loss of Generating Capability

As described in Section 4, several methods may be used for accounting for costs associated with the loss of generating capability during periods of high ambient temperature. Preliminary analyses were performed in order to determine the magnitude of the differences in busbar energy production cost for the following three methods of accounting for loss:

- Sizing the conversion system
- Replacement of losses
- No sizing or replacement of losses

In all of the preliminary cases considered, busbar costs were slightly lower when no penalty was assessed for capacity and energy losses, i.e., designing the plant for certain ambient temperature conditions and then "taking what you get". Typical differences in cost were on the order of a few mills/kWh, equivalent to a few percent of the total busbar cost. The parametric analyses presented in this report were therefore performed assuming that no penalty was assessed for loss of capability.

Direct Versus Indirect Dry Towers

Preliminary computer analyses were performed for dry/wet peaking cooling tower systems for both direct and indirect dry towers. In all of the preliminary cases considered, the use of direct dry towers resulted in lower busbar energy production costs than indirect dry towers. The primary reason for the improvement in economics with a direct dry cooling system is the fact that the direct dry towers do not have the thermodynamic loss associated with the surface condenser used with the indirect dry cooling system. Because of the long duration of high ambient dry-bulb temperatures at the sites considered in this study, the elimination of the surface condenser TTD has a marked effect on the tower size and performance. Typical differences in cost were on the order of a few mills/kWh, or a few percent of the total busbar cost. The parametric analyses presented in this report were therefore performed assuming direct dry towers.

Effect of Turbine Design Back Pressure

Preliminary computer analyses were performed for a range of design back pressures for the wet tower and design maximum operating back pressures for the dry/wet peaking tower in order to determine optimum back pressure design values for each case considered. For most cases, the range was 80-95 psia for the binary systems and 3-4.5 in. Hg for the flash steam systems.

Binary and flash steam systems served by evaporative cooling towers generally optimized at different design back pressures for each resource temperature considered at each site. The results presented in this report for the binary systems are based upon the corresponding optimum back pressure values. However, since makeup water requirements for the flash systems change slightly with different design back pressures, design back pressures which optimized for the majority of the cases at a particular site were selected as representative of that site for all resource temperatures.

If busbar energy production cost is plotted as a function of makeup water requirement for a dry/wet peaking cooling tower for several different design maximum operating back pressures, a family of curves is produced as illustrated in Figure 5-1. In actual practice, a "least-cost curve" can be constructed from the family of curves so that the design back pressure which results in the lowest busbar cost for a given quantity of makeup water would be selected. However, in order to facilitate the reduction of data for the dry/wet peaking cases, the family of curves was simply "averaged" for both the binary and flash steam cases. As subsequently described, the results of this study are presented in terms of a base case and a set of cost multipliers to be used for related cases. Therefore, averaging does not significantly affect the accuracy of the results.

RESULTS OF PARAMETRIC ANALYSES

Information Obtainable from Computer Programs

The computer programs which were developed to economically optimize and evaluate mechanical-draft evaporative and direct dry/wet peaking cooling tower systems provide the following information for each combination of resource temperature,

conversion process, climatic condition, fuel cost, fixed charge rate, and makeup water cost considered:

- Gross annual base generation and auxiliary energy requirements
- Annual makeup water requirements
- Annual plant capital and operating costs
- Annual geothermal energy and operating costs
- Annual makeup water and operating costs
- Total annual capital and operating costs
- Busbar energy production costs, exclusive of site-specific costs due to site inaccessibility, local labor and materials variability, pollution control measures, transmission line facilities, and taxes
- Busbar component cost breakdown
- Summary of pertinent cooling tower and condenser design data
- Cost breakdown for cooling tower, condenser, circulating water facilities, controls, engineering and contingencies, interest during construction, and conversion plant
- Annual turbine operation profile
- Annual plant generation profile
- Distribution of heat load between wet and dry towers for the dry/wet peaking tower

Sample computer output for the mechanical-draft evaporative cooling tower program is given in Appendix D, while sample output for the mechanical-draft direct dry/wet peaking cooling tower program is given in Appendix E. (Computer printouts for all the cases analyzed are available for inspection at the EPRI offices.)

Results of Analyses of Evaporative Cooling Systems

Analyses of mechanical-draft evaporative cooling towers for both binary and flash steam systems were performed for 150 C (300 F), 182 C (360 F), and 246 C

(475 F) resources for the sites, fuel costs, and makeup water costs previously described. Because of the large number of cases studied, the results of the analyses have been condensed for the text of this report.

As discussed in Section 3, the binary turbine data used in the analyses are based upon the Elliott turbine design optimized for a 182 C (360 F) resource and therefore do not represent optimum hydrocarbon fluid choices or turbine designs for either 150 C (300 F) or 246 C (475 F) resources. For this reason, the results of the binary analyses for 150 C (300 F) and 246 C (475 F) are presented in Appendix F rather than in the text of this report. By comparison, the flash steam turbine data used in the analyses are based upon well-established turbine designs and therefore are considered to be valid for all three temperatures investigated.

The approach used in this report to portray results of the computer analyses is to define a base case and establish a set of cost multipliers. This approach was possible since varying such parameters as fuel cost and water cost did not noticeably affect makeup water requirements. Therefore, for a given resource temperature and climatological type, the busbar energy production costs could be expressed as multiples of each other, which simplified the presentation of the results considerably.

For binary systems, the base case was selected as the busbar energy production cost of a 182 C (360 F) binary system with an evaporative cooling tower using a fuel cost of $\$0.50/10^6$ Btu and a makeup water cost of $\$0.10/\text{Kgal}$. For flash systems, the base case was selected as the busbar energy production cost of a 182 C (360 F) flash steam system with an evaporative cooling tower using a fuel cost of $\$0.50/10^6$ Btu and a makeup water cost of $\$0.10/\text{Kgal}$. Busbar costs for other resource temperatures, fuel costs, and makeup water costs may be determined

by multiplying the base cost by an appropriate multiplier. Definitions of cost cost multipliers for evaporative cooling towers are shown in Table 5-1, while the base cases for binary and flash steam systems for evaporative cooling towers are shown in Table 5-2. Cost multipliers for the 182 C (360 F) binary cases are listed in Table 5-3, and cost multipliers for the flash steam cases are plotted according to resource temperature in Figure 5-2 for the different sites. Table 5-4 provides a list of conversion factors used in the parametric analyses.

The cost multipliers presented in Table 5-3 (binary) and Figure 5-2 (flash steam system) apply to all four sites considered. This is primarily due to the fact that the various cases analyzed for a particular site were referenced to the 182 C (360 F) case for $\$0.50/10^6$ Btu fuel cost and $\$0.10/\text{Kgal}$ water cost at that same site. Another fact worth noting is that there is little difference in the base case busbar energy production costs and cooling tower makeup water requirements shown in Table 5-2 for the three non-desert sites considered. Cooling tower makeup water requirements and busbar costs were slightly higher for the Hot Desert site than the other sites due to higher ambient temperatures.

In order to illustrate the use of the cost multiplier concept, the following sample calculations are presented for both binary and flash steam systems using evaporative cooling towers.

Sample Calculation. Find the makeup water requirement and busbar energy production cost (exclusive of site-specific factors) for a 182 C (360 F) binary system served by a mechanical-draft evaporative cooling tower at a High Mountain site assuming that fuel costs $\$1.00/10^6$ Btu and water costs $\$1.00/\text{Kgal}$. From Table 5-3, the appropriate cost multiplier is 1.57. From Table 5-2, the water consumption and base cost (for a 360 F resource at $\$0.50/10^6$ Btu and $\$0.10/\text{Kgal}$) are 3003 acre-feet per year and 31.08 mills/kWh. The busbar energy production cost for this example is therefore 1.57×31.08 , or 48.80 mills/kWh.

Table 5-1

DEFINITION OF COST MULTIPLIERS FOR
EVAPORATIVE COOLING TOWERS

Binary

$$\text{cost multiplier} = \frac{\text{Mills/kWh at site for } 360^{\circ}, \text{ FC, WC}}{\text{Mills/kWh at site for } 360^{\circ} \text{ Binary, } \$0.50/10^6 \text{ Btu, } \$0.10/\text{Kgal}}$$

Flash

$$\text{cost multiplier} = \frac{\text{Mills/kWh at site for T, FC, WC}}{\text{Mills/kWh at site for } 360^{\circ} \text{ Flash, } \$0.50/10^6 \text{ Btu, } \$0.10/\text{Kgal}}$$

where T = temperature of the resource
 FC = Fuel cost in $\$/10^6$ Btu
 WC = Water cost in $\$/\text{Kgal}$ ($K = 10^3$)

Table 5-2

BASE CASES FOR BUSBAR ENERGY PRODUCTION COST
AND WATER CONSUMPTION FOR EVAPORATIVE AND
DRY/WET PEAKING COOLING TOWERS

Binary

360 F binary case using $\$0.50/10^6$ Btu fuel cost and $\$0.10/\text{Kgal}$ water cost:

<u>Site</u>	<u>Mills/kWh</u>	<u>Acre-Feet</u>
		<u>360 F</u>
Pacific Northwest	31.65	2871
Basin and Range	31.22	2931
High Mountain	31.08	3003
Hot Desert	33.02	3355

Flash

360 F flash case using $\$0.50/10^6$ Btu fuel cost and $\$0.10/\text{Kgal}$ water cost:

<u>Site</u>	<u>Mills/kWh</u>	<u>Acre-Feet</u>		
		<u>300 F</u>	<u>360 F</u>	<u>475 F</u>
Pacific Northwest	33.68	3083	2454	1909
Basin and Range	33.47	3154	2496	1942
High Mountain	33.42	3244	2564	1995
Hot Desert	34.31	3447	2774	2135

(Note: Based upon 50 MWe net plant sizes operating 6500 hours per year.)

Table 5-3

BUSBAR ENERGY PRODUCTION COST MULTIPLIERS FOR 182 C (360 F)
 BINARY SYSTEMS USING EVAPORATIVE COOLING TOWERS

<u>Site</u>	<u>Fuel Cost, \$/10⁶ Btu</u>	<u>Water Cost, \$/Kgal</u>	<u>Cost Multiplier</u>
(All Sites)	0.50	0.10	1.00
		1.00	1.08
		2.50	1.21
	1.00	0.10	1.48
		1.00	1.57
		2.50	1.70

Table 5-4

TABLE OF USEFUL CONVERSION FACTORS
 FOR PARAMETRIC ANALYSIS

$$300 \text{ F} = 150 \text{ C}$$

$$360 \text{ F} = 182 \text{ C}$$

$$475 \text{ F} = 246 \text{ C}$$

$$1 \text{ acre-foot} = 325,851 \text{ gallons}$$

$$1 \text{ acre-foot} = 1233 \text{ cubic meters}$$

$$\$0.10/\text{Kgal} = \$ 32/\text{acre-foot}$$

$$\$1.00/\text{Kgal} = \$325/\text{acre-foot}$$

$$\$2.50/\text{Kgal} = \$814/\text{acre-foot}$$

$$K = 10^3$$

Sample Calculation. Find the makeup water requirement and busbar energy production cost (exclusive of site-specific factors) for a 246 C (475 F) flash steam system served by a mechanical-draft evaporative cooling tower at a Basin and Range site assuming that fuel costs $\$0.50/10^6$ Btu and water costs $\$2.50/\text{Kgal}$. From Figure 5-2, the appropriate cost multiplier is 0.91. From Table 5-2, the water consumption and base cost (for a 360 F resource at $\$0.50/10^6$ Btu and $\$0.10/\text{Kgal}$) are 1942 acre-feet per year and 33.47 mills/kWh. The busbar energy production cost for this example is therefore 0.91×33.47 , or 30.46 mills/kWh.

Results of Analyses of Dry/Wet Peaking Cooling Systems

Analyses of mechanical-draft direct dry/wet peaking cooling towers for both binary and flash steam systems were also performed for 150 C (300 F), 182 C (360 F), and 246 C (475 F) resources for the sites, fuel costs, and makeup water costs previously described. Because of the large number of cases studied, the results of the analyses have similarly been condensed for the text of this report. The results of the binary systems for 150 C (300 F) and 246 C (475 F) resources are not included in the text of this report for the reasons previously cited.

The same approach is used to portray results of the computer analyses for dry/wet peaking cooling towers -- that is, to define a base case and establish a set of cost multipliers to be used for related cases. For binary systems, the base case was selected as the busbar energy production cost of a 182 C (360 F) binary system with an evaporative cooling tower using a fuel cost of $\$0.50/10^6$ Btu and a water cost of $\$0.10/\text{Kgal}$. For flash steam systems, the base case was selected as the busbar energy production cost of a 182 C (360 F) flash steam system with an evaporative cooling tower using a fuel cost of $\$0.50/10^6$ Btu and a water cost of $\$0.10/\text{Kgal}$. Busbar costs for different resource temperatures, fuel costs, and makeup water costs may be determined by multiplying the base cost by an

appropriate multiplier. Definitions of cost multipliers for dry/wet peaking cooling towers are shown in Table 5-5, while the base cases for binary and flash steam systems for dry/wet peaking cooling towers are shown in Table 5-2.

Cost multipliers for the 182 C (360 F) binary cases are plotted as a function of percent water requirement in Figures 5-3 through 5-6 for the sites considered, and cost multipliers for the flash steam cases for all resource temperatures considered are similarly plotted in Figures 5-7 through 5-10. Appendix G contains tabulations of the multipliers used for plotting both the binary and flash steam curves.

Zero percent water consumption represents a plant with dry cooling towers only, whereas 100 percent water consumption represents a plant with evaporative (wet) cooling towers only. The points between zero and 100 percent represent plants having different size combinations of dry and wet cooling towers, with a higher value of water consumption indicating a combination of a smaller dry tower with a larger wet tower. From such a graph, the decision-maker can determine the incremental cost of reducing the water consumption of the cooling system, or, conversely, what cost would be incurred at a site if only a certain quantity of water were available, thereby requiring the supplemental use of dry cooling systems.

Sample Calculation. Find the makeup water requirement and busbar energy production cost (exclusive of site-specific factors) for a 246 C (475 F) flash steam system served by a mechanical-draft dry/wet peaking cooling tower designed to use only 10 percent of the water required by an evaporative cooling tower at a Basin and Range site assuming that fuel costs $\$0.50/10^6$ Btu and water costs $\$2.50/\text{Kgal}$. From Figure 5-7, the appropriate cost multiplier is 0.95. From Table 5-2, the water consumption and base cost (for a 360 F resource served by

Table 5-5

DEFINITION OF COST MULTIPLIERS AND WATER
PERCENTAGES FOR DRY/WET PEAKING COOLING TOWERS

Binary

$$\% \text{ water consumption} = \frac{\text{Acre-feet required at site for wet/dry}}{\text{Acre-feet required at site for wet}}$$

$$\text{cost multiplier} = \frac{\text{Mills/kWh at site for wet/dry for } 360^{\circ}, \text{ FC, WC}}{\text{Mills/kWh at site for wet for } 360^{\circ} \text{ Binary, } \$0.50/10^6 \text{ Btu, } \$0.10/\text{Kgal}}$$

Flash

$$\% \text{ water consumption} = \frac{\text{Acre-feet required at site for wet/dry}}{\text{Acre-feet required at site for T for wet}}$$

$$\text{cost multiplier} = \frac{\text{Mills/kWh at site for wet/dry for T, FC, WC}}{\text{Mills/kWh at site for wet for } 360^{\circ} \text{ Flash, } \$0.50/10^6 \text{ Btu, } \$0.10/\text{Kgal}}$$

where T = Temperature of the resource

FC = Fuel cost in $\$/10^6$ Btu

WC = Water cost in $\$/\text{Kgal}$

an evaporative cooling tower at $\$0.50/10^6$ Btu and $\$0.10/\text{Kgal}$) are 1942 acre-feet per year and 33.47 mills/kWh. The busbar energy production cost for this example is therefore 0.95×33.47 , or 31.80 mills/kWh. The water requirement is 0.1×1942 , or 194 acre-feet per year. Similarly, using 3 percent and 47 percent of the water required for an evaporative cooling tower results in busbar costs of 37.6 mills/kWh and 30.8 mills/kWh, respectively. As previously shown in a sample calculation, the evaporative cooling tower results in a busbar cost of 30.46 mills/kWh and requires 1942 acre-feet per year.

The penalty in busbar cost for using only 10 percent of the water can also be computed directly from Figure 5-7 by determining a ratio of the busbar cost of 10 percent water use (10 percent evaporative tower and 90 percent dry tower) to 100 percent water use (100 percent evaporative tower), or $0.95/0.91 = 1.04$. Therefore, saving 90 percent of the water required by an evaporative tower will increase busbar cost by approximately 4 percent and result in a cost of $(0.95/0.91) \times 30.46$, or 31.80 mills/kWh.

Sample Calculation. Find the makeup water requirement and busbar energy production cost (exclusive of site-specific factors) for a 182 C (360 F) binary system served by a mechanical-draft dry/wet peaking cooling tower designed to use only 10 percent of the water required by an evaporative cooling tower at a High Mountain site assuming that fuel costs $\$1.00/10^6$ Btu and water costs $\$1.00/\text{Kgal}$. From Figure 5-5, the appropriate cost multiplier is 1.69. From Table 5-2, the water consumption and base cost (for a 360 F resource served by an evaporative cooling tower at $\$0.50/10^6$ Btu and $\$0.10/\text{Kgal}$) are 3003 acre-feet per year and 31.08 mills/kWh. The busbar energy production cost for this example is therefore 1.69×31.08 , or 52.53 mills/kWh. The water requirement is 0.1×3003 , or 300 acre-feet per year. Similarly, using 3 percent and 47 percent of the water required for an evaporative cooling tower results in busbar costs of 60.6 mills/

kWh and 51.3 mills/kWh, respectively. As previously shown in a sample calculation, the evaporative cooling tower results in a busbar cost of 48.80 mills/kWh and requires 3003 acre-feet per year.

The penalty in busbar cost for using only 10 percent of the water can also be computed directly from Figure 5-5 by determining a ratio of the busbar cost of 10 percent water use (10 percent evaporative tower and 90 percent dry tower) to 100 percent water use (100 percent evaporative tower), or $1.69/1.57 = 1.08$. Therefore, saving 90 percent of the water required by an evaporative tower will increase busbar cost by approximately 8 percent and result in a cost of $(1.69/1.57) \times 48.8$, or 52.53 mills/kWh.

Conclusions

Several conclusions may be drawn based upon the range of values analyzed in the parametric analyses performed in this study:

- Busbar energy production costs are very sensitive to hydrothermal resource temperature and hydrothermal "fuel cost" and less sensitive to climatological type and makeup water cost. All other parameters remaining constant, busbar energy production costs for 150 C (300 F) resources are generally on the order of 80 percent higher than for 246 C (475 F) resources. Likewise, an increase in "fuel cost" from \$0.50 to \$1.00/10⁶ Btu will result in an increase in busbar costs on the order of 50 percent. However, an increase in water cost from \$0.10 to \$2.50/Kgal will result in an increase in busbar costs of only about 15 percent. The differences in busbar costs for the four sites are typically on the order of 5 percent.
- Turbine-generator design significantly determines the overall plant performance and economics of both the binary and flash steam conversion systems. Direct comparisons between binary and flash steam systems for 150 C (300 F) and 246 C (475 F) resources were not possible in this study since optimum binary fluid choices and turbine designs are not yet available.
- Analyses indicate that binary systems yield slightly lower busbar energy production costs than flash steam systems for the 182 C (360 F) resource temperature, although makeup water requirements are higher than for flash steam systems. Higher heat rejection

for the binary system relative to the flash system accounts for the higher makeup water requirements.

- No computer analyses were performed for the radial hydrocarbon turbine design for the binary conversion process (turbine performance data were not available in time for this study). An examination of the radial turbine performance characteristics which were furnished by a manufacturer indicates that the busbar energy production cost and cooling system makeup water requirements should not differ significantly from those of the axial hydrocarbon turbine unless there are significant differences in capital or operating costs between the two types of turbines.
- On the basis of the turbine performance data available for this study, cooling system makeup water requirements for evaporative cooling towers serving flash steam systems are approximately 24-27 percent higher for 150 C (300 F) resources than for 182 C (360 F) resources, and approximately 29-30 percent lower for 246 C (475 F) resources than for 182 C (360 F) resources. Makeup water requirements for evaporative cooling systems serving binary systems are approximately 17-21 percent higher than for flash steam systems for 182 C (360 F) resource temperatures.
- For the range of fuel and makeup water costs considered, an all-dry cooling tower system does not appear to be economically competitive with an evaporative cooling tower system. However, the addition of a relatively small evaporative peaking tower to the dry tower (such as 95 percent dry/5 percent wet) will substantially reduce the busbar cost penalty incurred by an all-dry system. As the cost of makeup water increases, the relative difference in busbar cost between an all-dry or dry/wet peaking tower and an evaporative tower decreases significantly.
- For low water costs (\$0.10/Kgal), the penalty in busbar cost for saving approximately 60 percent water by use of a dry/wet peaking cooling tower is on the order of 7-15 percent for non-desert sites and 9-25 percent for desert sites. However, for higher water costs (\$2.50/Kgal), the penalty decreases to approximately 1-4 percent for non-desert sites and 2-10 percent for desert sites. The economic penalty for saving more water increases as additional dry cooling is used. Therefore, the use of dry/wet peaking towers may be feasible for hydrothermal power plants under certain site, plant design, and economic conditions as well as social and environmental constraints.
- Busbar energy production costs and cooling system makeup water requirements as estimated in this study for given plant design and economic constraints do not vary significantly for non-desert sites. However, busbar costs are approximately 2-6 percent higher and makeup water requirements are approximately 6-17 percent higher for desert sites.
- Several methods for accounting for costs associated with loss of generating capacity were considered in this study. Busbar energy production costs are slightly lower for the method which does not penalize for loss of capacity during operation at high ambient

temperature conditions than for the other methods. However, typical differences in cost for these alternative methods are on the order of a few percent.

- Direct dry towers resulted in lower busbar energy production costs than indirect dry towers for the generating units with the sizes evaluated in this report. Differences in cost are typically on the order of a few percent of the total busbar cost, so that this conclusion could change if relative capital costs of the two systems are different from those assumed.
- For study purposes, the design back pressure value does not significantly affect the relative estimated busbar energy production cost or cooling system makeup water requirements. In the actual design of a hydrothermal power plant, however, the design back pressure is an important consideration.

Recommendations for Subsequent Studies

In addition to the need for binary turbine-generation performance data for a range of hydrothermal resource temperatures, our analyses indicate that the following studies are warranted:

- Analyses of alternative hydrocarbon turbine designs should be performed before any major decision is made regarding either the selection of a hydrocarbon turbine or the selection of one conversion process over another.
- The actual operation of hydrothermal power plants in conjunction with other conventional power plants on the utility grid should be evaluated. Forced outage rate, planned outage for scheduled maintenance, and summer and winter capacity of the hydrothermal plant should be investigated with respect to operating economics.
- Because of the high fuel costs and cooling system auxiliary energy requirements associated with hydrothermal plants, natural-draft cooling systems may be more economical than mechanical-draft systems at many locations and should therefore be evaluated in subsequent studies. The choice between mechanical-draft and natural-draft cooling towers is usually based on economics, although in some instances environmental considerations could favor the use of natural-draft towers.

Accuracy of Results

The accuracy with which cost estimates can be made for new energy conversion technologies is directly related to the history and experience of the industries

developing the technologies. In the case of hydrothermal power plants, capital cost estimates are subject to inaccuracies resulting from a lack of cost trends, which can be established only after several power plants have been designed and constructed. Moreover, site-specific costs due to local labor and materials cost differences or physical site conditions will also markedly affect plant costs for any actual installation.

The accuracy with which the computer programs developed for this study simulate actual power plant performance is limited primarily by the accuracy or applicability of the turbine performance data, climatological data, and capital cost data. Estimates of makeup water requirements are based upon rigorous procedures adopted by the Cooling Tower Institute and therefore are limited primarily by the accuracy or applicability of the turbine performance and climatological data. Therefore, as data are refined, the accuracy of estimating energy production costs and makeup water requirements can also be refined.

FIGURE 5-1

ILLUSTRATION OF BUSBAR ENERGY PRODUCTION COST VERSUS MAKE-UP WATER REQUIREMENT FOR DRY/WET PEAKING COOLING TOWER SYSTEM FOR DIFFERENT DESIGN MAXIMUM OPERATING BACK PRESSURES (DMOBP)




FIGURE 5-2

BUSBAR ENERGY PRODUCTION COST MULTIPLIERS FOR
EVAPORATIVE COOLING TOWERS AS A FUNCTION OF
RESOURCE TEMPERATURE (ALL SITES)
FOR FLASH STEAM SYSTEMS





FIGURE 5-3



BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
 FOR DRY/WET PEAKING COOLING TOWERS
 FOR 182°C (360°F) BINARY AT BASIN AND RANGE SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

FIGURE 5-4


BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
 FOR DRY/WET PEAKING COOLING TOWERS
 FOR 182°C (360°F) BINARY AT PACIFIC NORTHWEST SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

FIGURE 5-5



BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
FOR DRY/WET PEAKING COOLING TOWERS
FOR 182°C (360°F) BINARY AT HIGH MOUNTAIN SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

FIGURE 5-6



BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
 FOR DRY/WET PEAKING COOLING TOWERS
 FOR 182°C (360°F) BINARY AT HOT DESERT SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

FIGURE 5-7



BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
 FOR DRY/WET PEAKING COOLING TOWERS
 FOR 150°C (300°F), 182°C (360°F) AND 246°C (475°F) FLASH AT BASIN AND RANGE SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

FIGURE 5-8



BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
 FOR DRY/WET PEAKING COOLING TOWERS
 FOR 150°C (300°F), 182°C (360°F) AND 246°C (475°F) FLASH AT PACIFIC NORTHWEST SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

FIGURE 5-9

BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
 FOR DRY/WET PEAKING COOLING TOWERS
 FOR 150°C (300°F), 182°C (360°F) AND 246°C (475°F) FLASH AT HIGH MOUNTAIN SITE



NOTE: PERCENT WATER IS BASED UPON MAKEUP WATER REQUIREMENT FOR EVAPORATIVE TOWER

Appendix A

DESCRIPTION OF HYDROTHERMAL RESOURCES IN THE WESTERN UNITED STATES

REGIONAL SUMMARY OF KNOWN HYDROTHERMAL RESOURCES

The following is a summary of known hydrothermal resource areas with potential for electrical energy production. The systems described include both the hot water and vapor-dominated convection systems which have been most commonly detected thus far by associated hot springs and/or fumaroles.

Type and Extent of Hydrothermal Resources

Geological and geophysical evidence for hydrothermal energy sources abounds in the eleven western states. Nine geothermal regions are defined in Figure 2-1, based on a combination of features and upper mantle and crustal processes. Major factors used in the identification of different hydrothermal regions include geology, heat flow, tectonic activity, seismicity, volcanism, hydrology, and temperature gradients. Delineation of these nine regions is interpretative, since the quantity and quality of data is extremely limited. Salient elements of each region are summarized below. The regions are listed in order of geographical numbering in Figure 2-1, not in order of estimated potential.

Region I: Central California Coast Ranges. The central California coast range is dominated by the active San Andreas fault system. Heat flow is variable but regionally above normal and is sustained by local frictional heating and volcanism. Young volcanic and hot spring activity are extensive in the Geysers-Clear Lake

area (Site 1), which appears to represent the only obvious significant hydrothermal area in the region.

Region II: Cascade Range. Although the Cascade Range is entirely volcanic, the eastern side of the Range is youngest and most volcanically and tectonically active, and of greatest geothermal interest. Hot springs, fumarolic activity, altered groundwater flows, and young lava flows attest to shallow heat concentrations associated with modern volcanoes in the Range, such as Mts. Lassen, Shasta, Belknap, Hood, St. Helens, Rainier, and Baker. Heat flow data are sparse, but the eastern Cascades are believed to exhibit higher-than-normal values associated with extrusion centers. Tensional faulting is concentrated along the eastern margin of the Range. Relatively few thermal data are available for this province, and hydrothermal exploration and drilling have not been extensive to date.

Region III: Snake River Plain. The Snake River Plain is a prominent volcano-tectonic and physiographic hydrothermal province. Numerous thermal springs occur along the fault-bounded north and south margins of the Plain. Cold groundwater migration to the Snake River through highly permeable lavas obscures expression of the high temperature water that is believed to lie within the Snake River Plain graben. A few heat-flow determinations along the margin of the Plain indicate regionally high heat flux. The thick water-saturated sediments and flows that fill the graben should act as excellent thermal insulators, and thereby trap large amounts of heat beneath the shallow zone of cold water sweep.

A few deep oil and gas wildcat wells have been drilled in the western part of the Snake River Plain. All drillings encountered hot water, which indicates significantly higher-than-normal thermal gradient and subsurface temperatures.

Region IV: Northwestern Basin and Range. This province is extremely large and contains abundant evidence that many hydrothermal systems exist. The western part consists of the especially active tectonic and volcanic zone that borders the Sierra Nevada and the Cascades. There are numerous normal faults, many of which are associated with high-temperature springs. Other springs are more clearly related to young volcanic activity. Heat flow in this province is regionally twice normal and joins with the high heat flow regime of the Snake River Plain to make the highest heat flow region known on the North American continent. The northwestern part of the region is underlain by moderately but intricately faulted lava flows and sedimentary interbeds. The southeastern and southern parts of the province are marked by strong Basin and Range topography and comprise a complex of plutonic, volcanic, and sedimentary rocks. Heat may be concentrated beneath thermally insulating layers of the larger basins and lava plateaus.

Several specific high-temperature hydrothermal areas (Sites 2-8) occur in the western Basin and Range. All are believed to hold potential for electrical energy generation.

Region V: Central Basin and Range. This portion of the Basin and Range province contains fewer thermal features than the marginal zones to the west and east. Young volcanism is rare, and the seismic activity which occurs (mainly in the southern part) is markedly less than in adjacent areas. Heat flow is close to normal and even subnormal in this portion of the Basin and Range. Interbasin hydrologic flow is extensive and may drain away much heat from the upper few thousand meters of porous carbonate sequences that occur in the region. High-temperature springs are rare, and moderate- to low-temperature springs are few in number. Clearly, this region has relatively low geothermal potential.

Region VI: Eastern Basin and Range. This region is characterized by many features that indicate relatively high hydrothermal potential similar to the western margin at the Basin and Range province. Heat flow is moderately high and young normal faults are abundant. Volcanism is locally significant and high-temperature springs occur infrequently. Large areas of thick sedimentation fill, such as the Great Salt Lake Basin, Sevien Desert, etc., may act as thermal blankets. One potentially major geothermal field has been discovered in the area of young silicic volcanism and young normal faulting (Site 10), and exploration boreholes have been drilled in another system (Site 9) which has relatively low temperatures.

Region VII: Salton-Imperial Valley. The Imperial Valley is the site of intense lateral faulting, with the Pacific side moving northward with respect to the Continental side. This transform faulting, accompanied by transform faulting at intervals along the main fault trend, has led to incipient rifting and thinning of the crust, bringing the mantle to depths as shallow as ten or fifteen kilometers. The Imperial Valley itself is filled with young alluvium estimated to be as deep as 10,000 meters (33,000 feet). There is evidence of volcanism in the center of the Imperial Valley, although only very minor outcrops of volcanic rock occur at Obsidian Buttes on the southern end of the Salton Sea and the Cerro Prieto in Northern Mexico. Several fields have been drilled in the Imperial Valley, including the Salton Sea field, the Heber field, the North Brawley field, the Dunes field, and the East Mesa field (Site 11).

This outstanding hydrothermal province possesses all the geological and geophysical features that characterize hydrothermal provinces in many areas of the world. Several major anomalies are currently being evaluated.

Region VIII: Southern Basin and Range. In general, this portion of the Basin and Range province has moderate hydrothermal potential. Heat flow is above normal, but young tectonic and volcanic activity is not widespread and thermal springs occur sparingly. Alluvial fill basins, however, are extensive, and there is a good possibility that hydrothermal systems occur in these basins beneath insulating cover. While no hydrothermal reservoirs have been defined in this region to date, the Coso Hot Springs area in Southern California appears to have considerable potential.

Region IX: Rio Grande Rift System. This long and narrow tectonic depression displays all of the features of Basin and Range thermal regimes and is regarded as an extension of the Basin and Range province into the stable and cold Rocky Mountain foreland region. The San Juan volcanic field of southwestern Colorado is included within the Rio Grande province on the basis of high heat flow and thermal springs. Large areas within the Rift have almost twice the normal heat flow. Tectonism and volcanism are moderately active, and hot springs are moderately abundant. Intra-rift basins are large, deep, and filled with water-bearing sediments and volcanics which may have insulating properties.

Apparently, one successful development of a hydrothermal reservoir is taking place at Valles Caldera (Site 12), which is an abnormally large silicic eruptive center.

ESTIMATES OF HYDROTHERMAL RESOURCES BY REGION

The approach used in this report to estimate hydrothermal reserves is based on statistical data available from heat flow determinations which have been made at over 600 locations throughout the continental United States. Assuming that the heat flow determinations are randomly distributed throughout the United States

and that the origin of high heat flow and normal heat flow are the same, these data can be used to estimate the hydrothermal resource base.

As a minimum requirement for utilization, a hydrothermal system must have certain minimum temperatures which can be reached by drilling. Temperature will depend both on heat flow and on the thermal conductivity of the section. Conductivity may range from 3 to 5 x 10⁻³ thermal conductivity units* in alluvial sediments up to 7 to 9 x 10⁻³ units in crystalline rocks. If an average conductivity of 6 x 10⁻³ units is selected, then heat flows of varying magnitudes would result in the approximate temperatures shown in Table A-1. These gradients assume that no convection takes place over the indicated range of depths. If rocks with lower conductivities are present in the surficial portion of the section, temperatures will be higher. The values in Table A-1 indicate that a heat flow of 3 hfu (the median heat flow for the United States is 1.52 hfu) is required before temperatures suitable for hydrothermal development are likely to be present at drillable depths.

The distribution of heat flow determinations over the Basin and Range Province is based upon 86 values which have been measured in an area of 680,000 km² (262,000 mi²). This province comprises 14 percent of the data for the United States, although it represents only five percent of the area. Other areas of the west which have high heat flow are correspondingly oversampled in comparison to the eastern United States, where the heat flow is relatively low. The median heat flow in the Basin and Range Province is 2.01 hfu, resulting in the estimated percentages of values in excess of 3, 4, and 5 hfu shown in Table A-3.

*Thermal conductivity is measured as calories per second per square centimeter for a thermal gradient of one degree per centimeter.

Table A-1

ESTIMATED RESOURCE TEMPERATURE AS A FUNCTION OF HEAT FLOW AND DEPTH

Heat Flow,* hfu	Temperature Gradient At Average Conductivity,		Temperature, C (F)					
	C/km	(F/mile)	1 km (0.62 mile)		2 km (1.24 miles)		3 km (1.86 miles)	
3	50	(145)	70	(158)	120	(248)	170	(338)
4	67	(194)	87	(189)	153	(307)	220	(428)
5	83	(240)	103	(217)	186	(367)	269	(516)

Based on the probability distribution for heat flow determinations throughout the United States, the estimated fractions of heat flow determinations and associated areas above 3, 4, and 5 hfu are shown in Table A-2.

Table A-2

ESTIMATED PERCENTAGE OF NATIONAL HEAT FLOW DETERMINATIONS IN EXCESS OF SPECIFIC HEAT FLOW VALUES

Heat Flow, hfu	Percentage of Values in Excess	Area Represented, km ² (miles ²)
3	4.5	540,000 (208,500)
4	1.2	144,000 (55,600)
5	0.2	24,000 (9,270)

These areas are based on the assumption that heat flow tests have been made uniformly and randomly throughout the United States. However, it is likely that the far western states have been oversampled, and that these area estimates are therefore too high.

* Heat flow is measured as microcalories per square centimeter per second.

Table A-3

ESTIMATED PERCENTAGE OF BASIN AND RANGE HEAT FLOW DETERMINATIONS
IN EXCESS OF SPECIFIC HEAT FLOW VALUES

Heat Flow, hfu	Percentage of Values in Excess	Area Represented, km ² (miles ²)
3	9.0	61,200 (23,600)
4	2.0	13,600 (5,250)
5	0.3	2,040 (790)

It is not possible to compile exact distributions of heat flow for the nine hydrothermal regions previously described because of the relatively small number of determinations in each area. Approximate distributions based on the average probabilistic heat flow for each province may be used to estimate the areas with heat flows above 3, 4, and 5 hfu in each province as indicated in Table A-4.

Aside from the uncertain knowledge of the distribution, other uncertainties are involved in determining the extent of the area which will have heat flow above a certain value. Some areas will be unavailable because they lie in national parks, wilderness areas, or inaccessible locations. Other areas may have high temperature but will not easily produce fluids (these are called hot dry rocks) or will not be discovered because of ineffective exploration methods. It is therefore assumed that the remaining developable areas will only be one-fourth the size of the original exploration areas.

As a basis for estimating reserves, it is also assumed that a well can drain a vertical section one kilometer thick, so that one cubic kilometer of storage underlies each square kilometer of surface. On the average, 5 to 10 percent of this volume is water which can be extracted to deliver energy to the surface. The amount of water recoverable from each cubic kilometer of rock is therefore 5 to 10 x 10⁷ metric tons (5.5 to 11 x 10⁷ tons).

Table A-4

ESTIMATED DISTRIBUTION OF HEAT FLOW AREAS IN
SPECIFIC HYDROTHERMAL REGIONS

Hydrothermal Region	Total Area,		Areas of Heat Flow, km ² (miles ²)					
	km ²	(miles ²)	3-4 hfu		4-5 hfu		>5 hfu	
Central Calif. Coast Range	80,000	(31,000)	5,440	(2,100)	1,736	(670)	424	(164)
Cascade Range	80,000	(31,000)	744	(287)	120	(46)	16	(6)
Snake River Plain	60,000	(23,000)	7,680	(2,960)	3,420	(1,320)	1,500	(580)
Northwestern Basin and Range	270,000	(104,000)	21,060	(8,130)	7,560	(2,920)	1,890	(730)
Central Basin and Range	190,000	(73,000)	554	(214)	66	(25)	10	(4)
Eastern Basin and Range	200,000	(77,000)	3,300	(1,270)	620	(240)	80	(30)
Salton-Imperial Valley	14,000	(5,400)	1,792	(690)	798	(310)	350	(135)
Southern Basin and Range	270,000	(104,000)	3,591	(1,390)	413	(160)	46	(18)
Rio Grande Rift System	<u>100,000</u>	<u>(38,600)</u>	<u>6,900</u>	<u>(2,660)</u>	<u>2,050</u>	<u>(790)</u>	<u>550</u>	<u>(210)</u>
TOTAL	1,264,000	(487,000)	51,061	(19,700)	16,783	(6,480)	4,866	(1,880)

Electrical energy production estimates are based on current practice at The Geysers dry steam field. The reservoir temperature at The Geysers is 235 C (455 F), from which the steam expands and cools to a temperature of 150 to 170 C (302 to 338 F). At this temperature, approximately 10 kg (22 lb) of steam are required to generate one kilowatt-hour. Furthermore, only a fraction of the water produced from the reservoir can be flashed to steam for use in a steam turbine. The percentages of useful steam produced at 150 C (302 F) for various resource temperatures are shown in Table A-5.

Table A-5

ESTIMATED PERCENTAGE OF RESOURCE WATER CONVERTIBLE TO STEAM AT
VARIOUS RESERVOIR TEMPERATURES

Resource Temperature		Percent Water Convertible to Steam at 150 C (302 F)
C	(F)	
170	(338)	4.1
220	(428)	14.7
270	(518)	26.2

The total recoverable energy from hydrothermal sources in the western United States can therefore be estimated as a function of heat flow by using the developed information on fluid production, electrical energy production, and the area assumed to be available for hydrothermal development. The estimated recoverable energy over a production life of 30 years is shown in Table A-6.

Table A-6

ESTIMATES OF RECOVERABLE ENERGY FROM HYDROTHERMAL RESOURCES IN THE
WESTERN UNITED STATES AS A FUNCTION OF HEAT FLOW

Heat Flow, hfu (C/F)	Recoverable Energy Over 30 Years kWh x 10 ¹²
3-4 (170/338)	2.62-5.23
4-5 (220/428)	3.08-6.17
> 5 (270/518)	<u>1.59-3.19</u>
TOTAL	7.29-14.59

Similarly, electrical production capacity for the western United States is estimated in Table A-7 for the nominal 30-year production rates shown. Estimated production capacities for the individual hydrothermal areas are shown in Table A-8.

Table A-7

ESTIMATES OF NOMINAL ELECTRICAL PRODUCTION CAPACITY FROM
HYDROTHERMAL RESOURCES IN THE WESTERN UNITED STATES AS
A FUNCTION OF HEAT FLOW

Heat Flow, hfu (C/F)	Nominal 30-Year Production Rate, MWe/km ²	Nominal 30-Year Production Capacity, MWe
3-4 (170/338)	0.8	13,610
4-5 (220/428)	3.0	16,800
> 5 (270/518)	6.0	<u>9,730</u>
TOTAL		40,140

Table A-8

ESTIMATES OF NOMINAL 30-YEAR ELECTRICAL PRODUCTION CAPACITY
FOR THE MAJOR HYDROTHERMAL REGIONS AS A FUNCTION OF HEAT FLOW

Hydrothermal Region	MWe			Total
	(3-4 hfu)	(4-5 hfu)	(>5 hfu)	
Central California Coast Range	1,450	1,740	850	4,040
Cascade Range	200	120	30	350
Snake River Plain	2,050	3,420	3,000	8,470
Northwestern Basin and Range	5,600	7,560	3,780	16,940
Central Basin and Range	150	70	20	240
Eastern Basin and Range	880	620	160	1,660
Salton-Imperial Valley	480	800	700	1,980
Southern Basin and Range	960	420	90	1,470
Rio Grande Rift System	<u>1,840</u>	<u>2,050</u>	<u>1,100</u>	<u>4,990</u>
TOTAL	13,610	16,800	9,730	40,140

Better utilization of the heat energy can be accomplished with the lower reservoir temperature if successive flashing is used, or if heat is transferred to a working fluid with a low boiling point such as in a binary system. At the lower temperature, approximately twice as much energy can be recovered, or conversely, the amount of mass that must be used per unit of electricity generated is one-half.

The reliability of these estimates is closely related to the reliability of the statistical distributions assumed for the various provinces. As additional wells are drilled, these statistics can be improved. Nevertheless, the total estimated capacity is roughly equivalent to other conservative estimates made in recent years which foresee the ultimate development of several tens of thousands of megawatts of geothermal generating capacity in the western United States.

Some comment should be made on the relatively low potential for production estimated in the Imperial Valley. Extensive exploration has continued for almost three decades in this area and five potentially productive geothermal reservoirs have already been discovered -- Salton Sea, North Brawley, Heber, the Dunes, and East Mesa. Nevertheless, the Imperial Valley represents a mature exploration area where a significant portion of reserves has already been found. The large number of discoveries to date therefore does not reflect an even larger potential for undiscovered systems.

The relatively large potential for discovery of geothermal resources in the northwestern Basin and Range area also requires some discussion. Although numerous prospects have been drilled, no development appears to have taken place. There is also some concern that the distribution of heat flow values reported for this area includes a disproportionate number of recent determinations of heat flow made in areas selected for their geothermal potential.

APPENDIX B

DISTRIBUTION OF AMBIENT DRY-BULB TEMPERATURES
AT FOUR SITES - PERCENT OCCURRENCE

DISTRIBUTION OF AMBIENT DRY-BULB TEMPERATURES
AT SAMPLE BASIN AND RANGE SITE - PERCENT OCCURRENCE

Temperature Range	Relative Humidity						Total
	0-29%	30-49%	50-69%	70-79%	80-89%	90-100%	
104-100	.03	-	-	-	-	-	.03
99-95	.40	-	-	-	-	-	.40
94-90	1.37	-	-	-	-	-	1.37
89-85	2.70	.07	-	-	-	-	2.77
84-80	3.40	.40	-	-	-	-	3.80
79-75	3.38	.79	.03	-	-	-	4.20
74-70	2.96	1.60	.21	.01	-	-	4.78
69-65	2.36	2.41	.48	.13	.05	-	5.43
64-60	1.87	3.11	1.26	.13	.11	.03	6.51
59-55	1.36	3.40	2.40	.49	.15	.09	7.89
54-50	1.13	3.33	3.70	1.06	.33	.09	9.64
49-45	.66	2.99	4.27	1.71	.57	.17	10.37
44-40	.30	2.34	3.85	2.35	1.01	.27	10.12
39-35	.06	1.11	3.46	2.27	1.95	.62	9.47
34-30	.01	.51	2.56	2.03	2.25	1.03	8.39
29-25	-	.15	1.48	1.65	2.16	.59	6.03
24-20	-	.06	.84	1.19	1.85	.49	4.43
19-15	-	-	.27	.74	1.29	.28	2.58
14-10	-	-	.07	.40	.63	.05	1.15
9-5	-	-	.01	.10	.30	-	.41
4-0	-	-	.01	.08	.08	-	.17
(-1)-(-5)	-	-	-	.03	.01	.01	.05
(-6)-(-10)	-	-	-	.01	-	-	.01
TOTAL	21.99	22.27	24.90	14.38	12.74	3.72	100.00

DISTRIBUTION OF AMBIENT DRY-BULB TEMPERATURES
AT SAMPLE HIGH MOUNTAIN SITE - PERCENT OCCURRENCE

Temperature Range	Relative Humidity						Total
	0-29%	30-49%	50-69%	70-79%	80-89%	90-100%	
99-95	.02	-	-	-	-	-	.02
94-90	.32	-	-	-	-	-	.32
89-85	.57	-	-	-	-	-	.57
84-80	1.14	.03	.02	-	-	-	1.19
79-75	2.00	.87	.14	-	-	-	3.01
74-70	2.64	1.74	.93	-	-	-	5.31
69-65	3.16	2.90	2.10	.03	-	-	8.19
64-60	3.35	3.21	2.45	.22	-	-	9.23
59-55	3.51	2.85	1.68	.83	.61	.02	9.50
54-50	2.99	3.77	1.32	.83	.71	.07	9.69
49-45	2.13	3.50	1.24	.43	.37	.01	7.68
44-40	1.77	4.25	1.48	.63	.63	.06	8.82
39-35	.86	4.26	2.80	.83	.66	.18	9.59
34-30	.45	3.03	3.21	.64	.87	.64	8.84
29-25	.29	2.08	2.48	1.56	.95	.67	8.03
24-20	.06	.94	1.72	1.11	.81	.42	5.06
19-15	.01	.58	.88	.67	.49	.26	2.89
14-10	-	.06	.26	.39	.30	.18	1.19
9-5	-	.01	.15	.11	.10	.31	.68
4-0	-	-	.06	.02	-	.07	.15
(-1)-(-5)	-	-	.02	.01	-	-	.03
(-6)-(-10)	-	-	-	.01	-	-	.01
TOTAL	25.27	34.08	22.94	8.32	6.50	2.89	100.00

DISTRIBUTION OF AMBIENT DRY-BULB TEMPERATURES
AT SAMPLE HOT DESERT SITE - PERCENT OCCURRENCE

Temperature Range	Relative Humidity						Total
	0-29%	30-49%	50-69%	70-79%	80-89%	90-100%	
124-120 °F	-	-	-	-	-	-	-
119-115	.10	.02	-	-	-	-	.12
114-110	.36	.11	-	-	-	-	.47
109-105	1.20	.39	-	-	-	-	1.59
104-100	2.04	.66	-	-	-	-	2.70
99-95	4.02	1.68	.16	-	-	-	5.86
94-90	4.62	1.97	.70	-	-	-	7.29
89-85	5.23	2.16	1.45	.25	.01	-	9.10
84-80	5.07	2.67	1.28	.73	.24	.01	10.00
79-75	4.25	3.77	.74	.27	.15	.08	9.26
74-70	3.37	4.73	1.08	.14	.06	.06	9.44
69-65	2.51	5.24	2.07	.19	.06	.02	10.09
64-60	1.64	4.69	3.03	.38	.09	.08	9.91
59-55	.99	3.87	2.95	.53	.29	.14	8.77
54-50	.58	2.65	2.74	.46	.35	.19	6.97
49-45	.31	1.59	1.90	.50	.31	.15	4.76
44-40	.16	.77	.88	.38	.24	.15	2.58
39-35	.03	.27	.30	.11	.05	.10	.86
34-30	-	.09	.07	.02	.01	-	.19
29-25	-	.01	.02	-	-	-	.03
24-20	-	-	.01	-	-	-	.01
TOTAL	36.48	37.34	19.38	3.96	1.86	.98	100.00

DISTRIBUTION OF AMBIENT DRY-BULB TEMPERATURES
AT SAMPLE PACIFIC NORTHWEST SITE - PERCENT OCCURRENCE

Temperature Range	Relative Humidity						Total
	0-29%	30-49%	50-69%	70-79%	80-89%	90-100%	
124-120 °F	-	-	-	-	-	-	-
119-115	-	-	-	-	-	-	-
114-110	-	-	-	-	-	-	-
109-105	.01	-	-	-	-	-	.01
104-100	.14	-	-	-	-	-	.14
99-95	.58	.05	-	-	-	-	.63
94-90	1.16	.34	-	-	-	-	1.50
89-85	1.54	.85	.01	-	-	-	2.40
84-80	1.35	1.79	.05	-	-	-	3.19
79-75	.93	2.63	.32	-	-	-	3.88
74-70	.53	3.06	1.25	.09	.01	.01	4.95
69-65	.38	2.88	2.73	.33	.09	.03	6.44
64-60	.18	2.09	4.19	1.19	.39	.11	8.15
59-55	.10	1.56	4.35	2.33	1.22	.67	10.23
54-50	.07	1.01	3.91	2.64	2.49	1.42	11.54
49-45	.03	.56	2.64	2.70	3.17	3.24	12.34
44-40	.01	.23	1.49	1.95	3.56	5.53	12.77
39-35	-	.05	.59	1.05	2.60	6.05	10.34
34-30	-	.02	.16	.47	1.62	5.32	7.59
29-25	-	.02	.07	.18	.88	1.93	3.08
24-20	-	.01	.01	.07	.33	.28	.70
19-15	-	-	.01	.02	.05	.02	.10
14-10	-	-	-	.01	.01	-	.02
TOTAL	7.01	17.15	21.78	13.03	16.42	24.61	100.00

APPENDIX C

SUMMARY OF COST ESTIMATES FOR BINARY AND
FLASH STEAM CONVERSION PLANTS

SUMMARY OF COST ESTIMATES FOR 65 MWe (GROSS) BINARY CONVERSION PLANTS

	<u>150 C (300 F) Resource</u>	<u>182 C (360 F) Resource</u>	<u>246 C (475 F) Resource</u>
<u>Total Major Equipment</u>			
Pressure Vessels			
Heat Exchangers			
Pumps			
Compressors			
Freight and Storage			
Turbine-Generator			
Total	\$ 8,847,000	\$ 7,763,000	\$ 7,107,000
<u>Total Construction Items</u>			
Concrete			
Pipes, Valves, Fittings			
Structural Steel			
Instruments			
Painting			
Electrical			
Insulation			
Paving, Roads, Fences			
Buildings			
Total	8,503,000	7,819,000	6,662,000
<u>Indirect Field Costs</u>	4,461,000	3,947,000	3,098,000
<u>Office Cost and Fee</u>	<u>2,624,500</u>	<u>2,402,000</u>	<u>2,074,500</u>
<u>Total Plant Cost</u>	\$24,435,500	\$21,931,000	\$18,941,500

NOTES:

1. "Total Construction Items" includes subcontractors and construction labor.
2. "Total Plant Cost" does not include cooling tower, condenser, or circulating water facilities; special site-specific costs due to site inaccessibility, local labor and materials variability, pollution control measures, or transmission line facilities; or taxes.
3. All costs given are in January, 1980 dollars.
4. Plant cost estimates are based upon information provided by the Ben Holt Company of Pasadena, California.

SUMMARY OF COST ESTIMATES FOR 55 MWe (GROSS) FLASH-STEAM CONVERSION PLANTS

	<u>150 C (300 F) Resource</u>	<u>182 C (360 F) Resource</u>	<u>246 C (475 F) Resource</u>
<u>Total Major Equipment</u>			
Pressure Vessels			
Heat Exchangers			
Pumps			
Compressors			
Freight and Storage			
Turbine-Generator			
Total	\$13,102,000	\$11,974,000	\$11,046,000
<u>Total Construction Items</u>			
Concrete			
Pipes, Valves, Fittings			
Structural Steel			
Instruments			
Painting			
Electrical			
Insulation			
Paving, Roads, Fences			
Buildings			
Total	8,442,000	7,411,000	6,851,000
<u>Indirect Field Costs</u>	4,592,000	4,587,000	3,457,000
<u>Office Cost and Fee</u>	<u>3,214,500</u>	<u>2,948,500</u>	<u>2,627,000</u>
<u>Total Plant Cost</u>	\$29,350,500	\$26,920,500	\$23,981,000

NOTES:

1. "Total Construction Items" includes subcontractors and construction labor.
2. "Total Plant Cost" does not include cooling tower, condenser, or circulating water facilities; special site-specific costs due to site inaccessibility, local labor and materials variability, pollution control measures, or transmission line facilities; or taxes.
3. All costs given are in January, 1980 dollars.
4. Plant cost estimates are based upon information provided by the Ben Holt Company of Pasadena, California.

APPENDIX D

SAMPLE COMPUTER PRINTOUT FOR
EVAPORATIVE COOLING TOWER SYSTEMS

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

PLANT LOCATION	BASIN AND RANGE
NOMINAL SIZE AND TYPE OF PLANT	50.0 MWE (NET) GEOTHERMAL
TYPE OF CONVERSION PROCESS	FLASHED STEAM
GEOTHERMAL RESOURCE TEMPERATURE	360 F
TURBINE-GENERATOR DESIGN	TC4F DOUBLE-ENTRY AXIAL FLOW
PERIOD OF PEAK ELECTRICAL DEMAND	SUMMER
NOMINAL TEMPERATURE AT AND ABOVE WHICH PEAKING CONDITIONS ARE ASSUMED TO EXIST	82 F
SOURCE OF REPLACEMENT GENERATION - CAPACITY REQUIREMENT BASED ON ZERO REPLACEMENT GENERATION	
PEAKING	NONE PROVIDED
OFF-PEAK	NONE PROVIDED
SITE ELEVATION (REFERENCED TO SEA LEVEL)	4404 FT
DESIGN WET-BULB TEMPERATURE	62 F
SITE CONSTRUCTION COST INDICES	
MATERIALS	1.000
LABOR	1.000
LENGTH OF CONSTRUCTION PERIOD	18 MONTHS
SCHEDULED COMMERCIAL STARTUP DATE	1980
ANNUAL HOURS OF BASE-LOAD OPERATION	6500

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST • O+M: \$.50 / MILLION BTU MAKEUP WATER COST • O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

TOWER DESIGN CONDITIONS	TURBINE GENERATOR OUTPUT	RATED TURBINE GENERATOR OUTPUT	GROSS ANNUAL GENERATION	AUXILIARY ENERGY REQUIREMENT	ANNUAL EXCESS GENERATION	REPLACEMENT CAPACITY REQUIREMENT	ANNUAL REPLACE-MENT ENERGY REQD	ANNUAL MAKEUP WATER REQUIRE-MENT	TOTAL ANNUAL PLANT AND O+M COST	ANNUAL REPLACE-MENT AND O+M COST	ANNUAL GEO-THERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACE-MENT ENERGY COST	ANNUAL MAKEUP WATER AND O+M COST	TOTAL ANNUAL CAPITAL + OPER-ATING COSTS	BUSBAR ENERGY PRODUCTION COSTS	
F	F	MWE	MWH	MWH	MWH	KW	82F	82F	AC-FT	\$	\$	\$	\$	\$	\$	/KWH	
21.1	25	55.00	385593	39896	0	0	0	0	2520	5851933	0	5708194	0	0	82108	11642235	33.68
22.1	24	55.00	385889	39422	0	0	0	0	2517	5848778	0	5708426	0	0	82009	11639213	33.61
23.1	23	55.00	385800	39018	0	0	0	0	2514	5847899	0	5708658	0	0	81906	11638463	33.56
24.1	22	55.00	385902	38668	0	0	0	0	2511	5848502	0	5708891	0	0	81806	11639199	33.52
25.1	21	55.00	386024	38392	0	0	0	0	2506	5852656	0	5709188	0	0	81662	11643507	33.49
OPTIMUM																	
26.1	20	55.00	386141	38153	0	0	0	0	2502	5857549	0	5709452	0	0	81544	11648544	33.47
27.1	19	55.00	386254	37992	0	0	0	0	2499	5866807	0	5709673	0	0	81430	11657910	33.47
28.1	18	55.00	386385	37856	0	0	0	0	2495	5876441	0	5709981	0	0	81296	11667719	33.48
29.1	17	55.00	386507	37804	0	0	0	0	2491	5891349	0	5710237	0	0	81164	11682750	33.50
30.1	16	55.00	386643	37769	0	0	0	0	2489	5906247	0	5710578	0	0	81090	11697915	33.53

* AT 4.0 IN. HGA

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST • O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

COOLING RANGE (F)	APPROACH TO WET BULB (F)	ANNUAL CAPITAL AND O+M COST		ANNUAL GEOTHERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COST	BUSBAR ENERGY PRODUCTION COSTS
		CONVERSION PLANT	COOLING SYSTEM			CAPACITY PEAK-ING	COST NON-PEAKING	ENERGY COST ABOVE 82F	BELOW 82F		
21.1	25	14.0172	2.9108	16.5121	0.	0.	0.	0.	0.	.2375	33.6776
22.1	24	13.9941	2.8969	16.4256	0.	0.	0.	0.	0.	.2368	33.6135
23.1	23	13.9733	2.8900	16.4618	0.	0.	0.	0.	0.	.2362	33.5613
24.1	22	13.9551	2.8880	16.4410	0.	0.	0.	0.	0.	.2356	33.5197
25.1	21	13.9391	2.8966	16.4231	0.	0.	0.	0.	0.	.2349	33.4938
OPTIMUM											
26.1	20	13.9249	2.9077	16.4071	0.	0.	0.	0.	0.	.2343	33.4740
27.1	19	13.9139	2.9320	16.3948	0.	0.	0.	0.	0.	.2338	33.4745
28.1	18	13.9033	2.9574	16.3831	0.	0.	0.	0.	0.	.2333	33.4771
29.1	17	13.8963	2.9987	16.3756	0.	0.	0.	0.	0.	.2328	33.5034
30.1	16	13.8895	3.0399	16.3686	0.	0.	0.	0.	0.	.2324	33.5305

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

TOWER DESIGN CONDITIONS	RATED TURBINE OUTPUT	GROSS ANNUAL GENERATION	ANNUAL AUXILIARY ENERGY REQUIREMENT	ANNUAL EXCESS GENERATION	REPLACEMENT CAPACITY REQUIREMENT	ANNUAL MAKEUP WATER REQUIREMENT	ANNUAL TOTAL CAPITAL AND O+M COST	ANNUAL REPLACEMENT CAPACITY AND O+M COST	ANNUAL GEO-THERMAL ENERGY COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT ENERGY COST	ANNUAL MAKEUP WATER COST	TOTAL ANNUAL CAPITAL + OPERATING COSTS	BUSBAR ENERGY PRODUCTION COSTS			
COND- TIONS	APPR F	(%) F	MWH	MWH	MWH	MWH	\$	\$	\$	\$	\$	\$	\$	/KWH			
23.1	23	55.00	385800	39018	0	0	0	0	2514	5847899	0	5708658	0	0	819056	12375613	35.69
24.1	22	55.00	385902	38604	0	0	0	0	2511	5848502	0	5708891	0	0	818059	12375452	35.64
25.1	21	55.00	386024	38392	0	0	0	0	2506	5852656	0	5709188	0	0	816623	12378468	35.61
26.1	20	55.00	386141	38153	0	0	0	0	2502	5857549	0	5709452	0	0	815439	12382439	35.58
27.1	19	55.00	386254	37992	0	0	0	0	2499	5866807	0	5709673	0	0	814298	12390778	35.58
OPTIMUM																	
28.1	18	55.00	386385	37856	0	0	0	0	2495	5876441	0	5709981	0	0	812964	12399386	35.58
29.1	17	55.00	386507	37804	0	0	0	0	2491	5891349	0	5710237	0	0	811641	12413227	35.60
30.1	16	55.00	386643	37769	0	0	0	0	2489	5906247	0	5710578	0	0	810698	12427724	35.62

* AT 4.0 IN. HGA

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST • O+M: \$.50 / MILLION BTU MAKEUP WATER COST • O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

D-5

COOLING RANGE (F)	APPROACH TO WET BULB (F)	ANNUAL CAPITAL AND O+M COST		ANNUAL GEOTHERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COST	BUSBAR ENERGY PRODUCTION COSTS
		CONVERSION PLANT	COOLING SYSTEM			CAPACITY PEAK-ING	COST NON-PEAKING	ENERGY COST ABOVE 82F	BELOW 82F		
23.1	23	13.9733	2.8900	16.4618	0.	0.	0.	0.	0.	2.3619	35.6870
24.1	22	13.9551	2.8880	16.4410	0.	0.	0.	0.	0.	2.3559	35.6401
25.1	21	13.9391	2.8966	16.4231	0.	0.	0.	0.	0.	2.3491	35.6080
26.1	20	13.9249	2.9077	16.4071	0.	0.	0.	0.	0.	2.3433	35.5830
27.1	19	13.9139	2.9320	16.3948	0.	0.	0.	0.	0.	2.3382	35.5789
OPTIMUM											
28.1	18	13.9033	2.9574	16.3831	0.	0.	0.	0.	0.	2.3326	35.5764
29.1	17	13.8963	2.9987	16.3756	0.	0.	0.	0.	0.	2.3276	35.5983
30.1	16	13.8895	3.0399	16.3686	0.	0.	0.	0.	0.	2.3243	35.6224

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL C+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

D-6

TOWER DESIGN CONDI- TIONS RNG APPR	RATED TURBINE GENER- ATOR UNIT OUTPUT (%) MWE	GROSS ANNUAL BASE UNIT GENER- ATION MWH	ANNUAL AUXIL- IARY ENERGY REQUIRE- MENT MWH	REPLACEMENT CAPACITY ANNUAL EXCESS GENER- ATION MWH	REPLACEMENT ANNUAL REQUIRE- MENT ABV BLO 82F KW	REPLACEMENT ANNUAL REQUIRE- MENT BLO 82F KW	ANNUAL REPLACE- MENT EN- ERGY REQD ABV BLO 82F MWH	ANNUAL REPLACE- MENT EN- ERGY REQD BLO 82F MWH	WATER RE- QUIRE- MENT AC-FT	TOTAL ANNUAL PLANT AND O+M CAPITAL COST \$	ANNUAL REPLACE- MENT AND O+M CAPACITY COST \$	ANNUAL GEO- THERMAL ENERGY AND O+M COST \$	ANNUAL EXCESS GENER- ATION CREDIT \$	ANNUAL REPLACE- MENT ENERGY COST \$	ANNUAL MAKEUP WATER AND O+M COST \$	TOTAL ANNUAL CAPITAL + OPER- ATING COSTS \$	BUSBAR ENERGY PRODUC- TION COSTS MILLS /KWH
23.1 23	55.00	385800	39018	0	0	0	0	0	2514	5847899	0	5708658	0	0	2047639	13604196	39.23
24.1 22	55.00	385902	38568	0	0	0	0	0	2511	5848502	0	5708891	0	0	2045148	13602541	39.17
25.1 21	55.00	386024	38392	0	0	0	0	0	2506	5852656	0	5709188	0	0	2041558	13603402	39.13
26.1 20	55.00	386141	38153	0	0	0	0	0	2502	5857549	0	5709452	0	0	2038597	13605597	39.10
27.1 19	55.00	386254	37922	0	0	0	0	0	2499	5866807	0	5709673	0	0	2035744	13612225	39.09
OPTIMUM																	
28.1 18	55.00	386385	37856	0	0	0	0	0	2495	5876441	0	5709981	0	0	2032410	13618832	39.08
29.1 17	55.00	386507	37804	0	0	0	0	0	2491	5891349	0	5710237	0	0	2029104	13630689	39.09
30.1 16	55.00	386643	37769	0	0	0	0	0	2489	5906247	0	5710578	0	0	2027246	13644071	39.11

* AT 4.0 IN. HGA

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

D-7

COOLING RANGE (F)	APPROACH TO WET BULB (F)	ANNUAL CAPITAL AND O+M COST		ANNUAL GEOTHERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COST	BUSBAR ENERGY PRODUCTION COSTS
		CONVERSION PLANT	COOLING SYSTEM			CAPACITY COST	NON-PEAKING	ENERGY COST ABOVE 82F	BELOW 82F		
23.1	23	13.9733	2.8900	16.4618	0.	0.	0.	0.	0.	5.9047	39.2298
24.1	22	13.9551	2.8880	16.4410	0.	0.	0.	0.	0.	5.8898	39.1739
25.1	21	13.9371	2.8966	16.4231	0.	0.	0.	0.	0.	5.8728	39.1316
26.1	20	13.9249	2.9077	16.4071	0.	0.	0.	0.	0.	5.8582	39.0979
27.1	19	13.9139	2.9320	16.3948	0.	0.	0.	0.	0.	5.8454	39.0862
OPTIMUM											
28.1	18	13.9033	2.9574	16.3831	0.	0.	0.	0.	0.	5.8314	39.0752
29.1	17	13.8963	2.9987	16.3756	0.	0.	0.	0.	0.	5.8190	39.0896
30.1	16	13.8895	3.0349	16.3686	0.	0.	0.	0.	0.	5.8108	39.1088

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST * O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

TOWER DESIGN CONDI- TIONS	RATED TURBINE GENER- ATOR OUTPUT (%)	GROSS ANNUAL BASE UNIT GENER- ATION MWH	ANNUAL AUXIL- IARY ENERGY REQUIRE- MENT MWH	REPLACEMENT CAPACITY REQUIRE- MENT MWH	ANNUAL EXCESS GENER- ATION		ANNUAL REQUIRE- MENT ENERGY		ANNUAL MAKEUP WATER RE- QUIRE- MENT AC-FT	TOTAL ANNUAL PLANT CAPITAL AND O+M COST \$	ANNUAL REPLACE- MENT CAPACITY AND O+M COST \$	ANNUAL GEO- THERMAL ENERGY AND O+M COST \$	ANNUAL EXCESS GENER- ATION CREDIT \$	ANNUAL REPLACE- MENT ENERGY COST \$	ANNUAL MAKEUP WATER AND O+M COST \$	TOTAL ANNUAL CAPITAL + OPER- ATING COSTS \$	BUSBAR ENERGY PRODUC- TION COSTS /KWH
					82F MWH	82F KW	82F MWH	82F MWH									
23.1	23	55.00	385000	39018	0	0	0	0	2514	5847699	0	11417316	0	0	81906	17347121	50.02
24.1	22	55.00	355702	38608	0	0	0	0	2511	5846502	0	11417781	0	0	81806	17348089	49.96
25.1	21	55.00	389024	38392	0	0	0	0	2506	5852656	0	11418376	0	0	81662	17352695	49.92
26.1	20	55.00	386141	38153	0	0	0	0	2502	5857549	0	11418904	0	0	81544	17357996	49.88
27.1	19	55.00	386254	37992	0	0	0	0	2499	5866807	0	11419347	0	0	81430	17367584	49.87
OPTIMUM																	
28.1	18	55.00	386385	37856	0	0	0	0	2495	5876441	0	11419963	0	0	81296	17377700	49.86
29.1	17	55.00	386507	37804	0	0	0	0	2491	5891349	0	11420474	0	0	81164	17392987	49.88
30.1	16	55.00	386643	37769	0	0	0	0	2489	5906247	0	11421157	0	0	81090	17408493	49.90

* AT 4.0 IN. HGA

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

COOLING RANGE (F)	APPROACH TO WET BULB (F)	ANNUAL CAPITAL AND O+M COST		ANNUAL GEOTHERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COST	BUSBAR ENERGY PRODUCTION COSTS
		CONVERSION PLANT	COOLING SYSTEM			CAPACITY PEAK-ING	COST NON-PEAKING	ENERGY COST ABOVE 82F	BELOW 82F		
23.1	23	13.9733	2.8900	32.9236	0.	0.	0.	0.	0.	.2362	50.0231
24.1	22	13.9551	2.8880	32.8821	0.	0.	0.	0.	0.	.2356	49.9607
25.1	21	13.9391	2.8966	32.8462	0.	0.	0.	0.	0.	.2344	49.9168
26.1	20	13.9249	2.9077	32.8141	0.	0.	0.	0.	0.	.2343	49.8811
27.1	19	13.9139	2.9320	32.7895	0.	0.	0.	0.	0.	.2338	49.8693
OPTIMUM											
28.1	18	13.9033	2.9574	32.7662	0.	0.	0.	0.	0.	.2333	49.8602
29.1	17	13.8963	2.9987	32.7513	0.	0.	0.	0.	0.	.2328	49.8790
30.1	16	13.8895	3.0399	32.7372	0.	0.	0.	0.	0.	.2324	49.8990

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

TOWER DESIGN CONDITIONS	RATED TURBINE GENERATOR OUTPUT	GROSS ANNUAL BASE UNIT GENERATION	ANNUAL AUXILIARY ENERGY REQUIREMENT	ANNUAL EXCESS GENERATION	REPLACEMENT CAPACITY REQUIREMENT	ANNUAL REPLACEMENT ENERGY	ANNUAL MAKEUP WATER	TOTAL ANNUAL PLANT AND O+M COST	ANNUAL REPLACEMENT CAPACITY AND O+M COST	ANNUAL GEO-THERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT ENERGY COST	ANNUAL MAKEUP WATER AND O+M COST	TOTAL ANNUAL CAPITAL + OPERATING COSTS	BUSBAR ENERGY PRODUCTION COSTS
RNG APPR F F	(%) MWE	MWH	MWH	MWH	ABV 82F KW BLO KW	ABV 82F MWH BLO MWH	AC-FT	\$	\$	\$	\$	\$	\$	\$	MILLS /KWH
23.1 23	55.00	385800	39014	0	0 0	0 0	2514	5847899	0	11417316	0	0	819056	18084271	52.15
24.1 22	55.00	385902	38668	0	0 0	0 0	2511	5848502	0	11417781	0	0	818059	18084343	52.08
25.1 21	55.00	386024	38392	0	0 0	0 0	2506	5852656	0	11418376	0	0	816623	18087656	52.03
26.1 20	55.00	386141	38153	0	0 0	0 0	2502	5857549	0	11418904	0	0	815439	18091891	51.99
27.1 19	55.00	386254	37992	0	0 0	0 0	2499	5866807	0	11419347	0	0	814298	18100452	51.97
OPTIMUM															
28.1 18	55.00	386385	37856	0	0 0	0 0	2495	5876441	0	11419963	0	0	812964	18109368	51.96
29.1 17	55.00	386507	37804	0	0 0	0 0	2491	5891349	0	11420474	0	0	811641	18123464	51.97
30.1 16	55.00	386643	37769	0	0 0	0 0	2489	5906247	0	11421157	0	0	810898	18138302	51.99

* AT 4.0 IN. HGA

D-10

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST • O+M: \$1.00 / MILLION BTU MAKEUP WATER COST • O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

D-11

COOLING RANGE (F)	APPROACH TO WET BULB (F)	ANNUAL CAPITAL AND O+M COST		ANNUAL GEOTHERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COST	BUSBAR ENERGY PRODUCTION COSTS
		CONVERSION PLANT	COOLING SYSTEM			CAPACITY COST PEAK-ING	NON-PEAKING	ENERGY COST ABOVE 82F	BELOW 82F		
23.1	23	13.9733	2.8900	32.9236	0.	0.	0.	0.	0.	2.3619	52.1488
24.1	22	13.9551	2.8800	32.8821	0.	0.	0.	0.	0.	2.3559	52.0811
25.1	21	13.9391	2.8966	32.8462	0.	0.	0.	0.	0.	2.3491	52.0310
26.1	20	13.9249	2.9077	32.8141	0.	0.	0.	0.	0.	2.3433	51.9901
27.1	19	13.9139	2.9320	32.7895	0.	0.	0.	0.	0.	2.3382	51.9736
OPTIMUM											
28.1	18	13.9033	2.9574	32.7662	0.	0.	0.	0.	0.	2.3326	51.9595
29.1	17	13.8963	2.9987	32.7513	0.	0.	0.	0.	0.	2.3276	51.9739
30.1	16	13.8895	3.0399	32.7372	0.	0.	0.	0.	0.	2.3243	51.9909

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST * O+M: \$1.00 / MILLION BTU MAKEUP WATER COST * O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

TOWER DESIGN CONDITIONS	RATED TURBINE GENERATOR OUTPUT	GROSS ANNUAL BASE UNIT GENERATION	ANNUAL AUXILIARY ENERGY REQUIREMENT	ANNUAL EXCESS GENERATION	REPLACEMENT CAPACITY REQUIREMENT		ANNUAL ENERGY REQUIREMENT		ANNUAL MAKEUP WATER REQUIREMENT	TOTAL ANNUAL PLANT AND O+M COST	ANNUAL REPLACEMENT CAPACITY AND O+M COST	ANNUAL GEO-THERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT ENERGY COST	ANNUAL MAKEUP WATER AND O+M COST	TOTAL ANNUAL CAPITAL + OPERATING COSTS	BUSBAR ENERGY PRODUCTION COSTS /KWH	
					ABV 82F	BLV 82F	ABV 82F	BLV 82F										AC-FT
23.1	23	55.00	385800	39018	0	0	0	0	0	2514	5847899	0	11417316	0	0	2047639	19312855	55.69
24.1	22	55.00	385902	38668	0	0	0	0	0	2511	5848502	0	11417781	0	0	2045148	19311432	55.61
25.1	21	55.00	386024	38392	0	0	0	0	0	2506	5852656	0	11418376	0	0	2041558	19312590	55.55
26.1	20	55.00	386141	38153	0	0	0	0	0	2502	5857549	0	11418904	0	0	2038597	19315049	55.51
27.1	19	55.00	386254	37992	0	0	0	0	0	2499	5866807	0	11419347	0	0	2035744	19321898	55.48
OPTIMUM																		
28.1	18	55.00	386385	37856	0	0	0	0	0	2495	5876441	0	11419963	0	0	2032410	19328813	55.46
29.1	17	55.00	386507	37804	0	0	0	0	0	2491	5891349	0	11420474	0	0	2029104	19340926	55.47
30.1	16	55.00	386643	37769	0	0	0	0	0	2489	5906247	0	11421157	0	0	2027246	19354650	55.48

* AT 4.0 IN. HGA

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION

BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

D-13

COOLING RANGE (F)	APPROACH TO WET BULB (F)	ANNUAL CAPITAL AND O+M COST		ANNUAL GEOTHERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COST	BUSBAR ENERGY PRODUCTION COSTS
		CONVERSION PLANT	COOLING SYSTEM			CAPACITY COST	NON-PEAKING	ENERGY COST ABOVE 82F	ENERGY COST BELOW 82F		
23.1	23	13.9733	2.8900	32.9236	0.	0.	0.	0.	0.	5.9047	55.6916
24.1	22	13.9551	2.8880	32.8821	0.	0.	0.	0.	0.	5.8898	55.6150
25.1	21	13.9391	2.8966	32.8462	0.	0.	0.	0.	0.	5.8728	55.5547
26.1	20	13.9249	2.9077	32.8141	0.	0.	0.	0.	0.	5.8582	55.5050
27.1	19	13.9139	2.9320	32.7895	0.	0.	0.	0.	0.	5.8454	55.4809
OPTIMUM											
28.1	18	13.9033	2.9574	32.7662	0.	0.	0.	0.	0.	5.8314	55.4583
29.1	17	13.8963	2.9987	32.7513	0.	0.	0.	0.	0.	5.8190	55.4653
30.1	16	13.8895	3.0399	32.7372	0.	0.	0.	0.	0.	5.8108	55.4774

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM
SUMMARY OF DESIGN DATA

COOLING TOWER

DESIGN HEAT LOAD	1142 MILLION BTU/HR
DESIGN WET-BULB TEMPERATURE	62 F
DESIGN RANGE	26.06 F
DESIGN APPROACH	20.00 F
CIRCULATING WATER FLOW	87615 GPM
DESIGN L/G RATIO	1.560
DESIGN KAV/L	1.212
TOTAL FAN BRAKE HORSEPOWER	1014 BHP
TOTAL PUMP BRAKE HORSEPOWER (BASED ON ASSUMED HEAD OF 75 FT H ₂ O)	2074 BHP

CONDENSER

CONDENSER DUTY	1127 MILLION BTU/HR
DESIGN BACK PRESSURE	3.00 IN. HGA
DESIGN TTD	7.00 F
DESIGN AVERAGE CIRCULATING WATER TEMPERATURE	95.03 F
VELOCITY THROUGH TUBES	7.00 FPS
HEAT TRANSFER SURFACE	100513 SQ FT
TUBE TYPE	STANDARD
TUBE MATERIAL	ADMIRALTY
TUBE DIAMETER	.875 IN.-OD
TUBE GAGE	18 BWG

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM
CAPITAL COST BREAKDOWN

	\$
I. COOLING TOWER	-----
A. TOWER	1315975
B. BASIN AND FOUNDATIONS	537900
TOTAL	----- 1853875
II. CIRCULATING WATER FACILITIES	
A. PUMPS AND MOTORS	684833
B. PIPING AND STRUCTURE	1270240
TOTAL	----- 1955073
III. ELECTRICAL	403408
IV. CONDENSER	816720
ESTIMATED COOLING SYSTEM CAPITAL COST	=====
	5029076
ENGINEERING AND CONTINGENCIES (15.0 PERCENT)	754361
INTEREST DURING CONSTRUCTION (8.00 PERCENT/ANNUM)	540679
TOTAL ESTIMATED COOLING SYSTEM CAPITAL COST	----- 6324116
TOTAL ESTIMATED CONVERSION PLANT CAPITAL COST	26920500
INSTALLED PEAKING CAPACITY	0
TOTAL ESTIMATED CAPITAL INVESTMENT	=====
	33244616

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM
SUMMARY OF DESIGN DATA

COOLING TOWER

DESIGN HEAT LOAD	1142 MILLION RTU/HR
DESIGN WET-BULB TEMPERATURE	62 F
DESIGN RANGE	28.06 F
DESIGN APPROACH	18.00 F
CIRCULATING WATER FLOW	81370 GPM
DESIGN L/G RATIO	1.384
DESIGN KAV/L	1.372
TOTAL FAN BRAKE HORSEPOWER	1107 BHP
TOTAL PUMP BRAKE HORSEPOWER (BASED ON ASSUMED HEAD OF 75 FT H2O)	1926 BHP

CONDENSER

CONDENSER DUTY	1127 MILLION RTU/HR
DESIGN BACK PRESSURE	3.00 IN. HGA
DESIGN TTD	7.00 F
DESIGN AVERAGE CIRCULATING WATER TEMPERATURE	94.03 F
VELOCITY THROUGH TUBES	7.00 FPS
HEAT TRANSFER SURFACE	97136 SQ FT
TUBE TYPE	STANDARD
TUBE MATERIAL	ADMIRALTY
TUBE DIAMETER	.875 IN.-OD
TUBE GAGE	18 BWG

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM
CAPITAL COST BREAKDOWN

	\$
I. COOLING TOWER	-----
A. TOWER	1436283
B. BASIN AND FOUNDATIONS	587076
TOTAL	----- 2023359
II. CIRCULATING WATER FACILITIES	
A. PUMPS AND MOTORS	655114
B. PIPING AND STRUCTURE	1215117
TOTAL	----- 1870230
III. ELECTRICAL	440288
IV. CONDENSER	789278
ESTIMATED COOLING SYSTEM CAPITAL COST	===== 5123155
ENGINEERING AND CONTINGENCIES (15.0 PERCENT)	768473
INTEREST DURING CONSTRUCTION (8.00 PERCENT/ANNUUM)	550564
TOTAL ESTIMATED COOLING SYSTEM CAPITAL COST	----- 6442192
TOTAL ESTIMATED CONVERSION PLANT CAPITAL COST	26920500
INSTALLED PEAKING CAPACITY	0
TOTAL ESTIMATED CAPITAL INVESTMENT	===== 33362692

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION
ANNUAL TURRINE OPERATING PROFILE

OPERATING BACK PRESSURE (OBP) - IN. HGA
Vs.
HOURS PRESSURE IS EQUALLED OR EXCEEDED

WET TOWER RANGE F	WET TOWER APPH F	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS		
26.06	20.0	3.3	2	3.2	6	3.2	8	3.2	9	3.1	35	3.1	61	3.1	64	3.0	153		
		3.0	167	3.0	175	3.0	177	2.9	229	2.9	404	2.9	411	2.9	443	2.8	451		
		2.8	555	2.8	782	2.7	792	2.7	874	2.7	1093	2.7	1282	2.7	1288	2.6	1480		
		2.6	1501	2.6	1657	2.6	1860	2.6	1929	2.5	2092	2.5	2554	2.5	2592	2.5	2713		
		2.5	2824	2.4	2842	2.4	3058	2.4	3336	2.4	3424	2.4	3490	2.4	3643	2.3	3837		
		2.3	3951	2.3	4201	2.3	4328	2.3	4475	2.3	4518	2.2	4670	2.2	4895	2.2	4962		
		2.2	5108	2.2	5128	2.2	5332	2.2	5498	2.1	5541	2.1	5681	2.1	5714	2.1	5821		
		2.1	5918	2.1	5918	2.1	5960	2.0	6080	2.0	6157	2.0	6212	2.0	6216	2.0	6234		
		2.0	6318	2.0	6366	2.0	6384	1.9	6387	1.9	6428	1.9	6454	1.9	6458	1.9	6484		
		1.8	6485	1.8	6495	1.8	6496	1.7	6499	1.7	6500								
		28.06	18.0	3.3	2	3.2	6	3.2	8	3.2	9	3.1	35	3.1	61	3.1	64	3.0	153
				3.0	167	3.0	175	3.0	177	2.9	229	2.9	404	2.9	411	2.9	443	2.8	451
				2.8	555	2.8	782	2.7	792	2.7	874	2.7	1093	2.7	1250	2.7	1282	2.6	1288
				2.6	1480	2.6	1501	2.6	1657	2.6	1860	2.5	1929	2.5	2082	2.5	2093	2.5	2592
2.4	2824			2.4	2842	2.4	3058	2.4	3336	2.4	3424	2.4	3490	2.3	3643	2.3	3837		
2.3	3910			2.3	3951	2.3	4201	2.3	4328	2.2	4475	2.2	4518	2.2	4670	2.2	4895		
2.2	4962			2.2	5108	2.2	5128	2.2	5260	2.1	5332	2.1	5498	2.1	5537	2.1	5541		
2.1	5681			2.1	5714	2.1	5821	2.1	5918	2.0	5918	2.0	5960	2.0	6080	2.0	6157		
2.0	6212			2.0	6234	1.9	6318	1.9	6366	1.9	6384	1.9	6387	1.9	6428	1.9	6454		
1.9	6458			1.8	6478	1.8	6484	1.8	6485	1.8	6490	1.8	6495	1.7	6496	1.7	6497		
1.7	6499			1.6	6500														

MECHANICAL DRAFT EVAPORATIVE COOLING TOWER SYSTEM OPTIMIZATION AND EVALUATION
ANNUAL PLANT GENERATING PROFILE

ELECTRICAL OUTPUT AT GIVEN AMBIENT WET-BULB TEMPERATURE
VS. OPERATING HOURLY TEMPERATURE IS EQUALLED OR EXCEEDED

WET TOWER RNG APPR F F	AMB WBT F	GROSS T-G MWE	NET PLANT MWE	HRS	AMB WBT F	GROSS T-G MWE	NET PLANT MWE	HRS	AMB WBT F	GROSS T-G MWE	NET PLANT MWE	HRS	AMB WBT F	GROSS T-G MWE	NET PLANT MWE	HRS	AMB WBT F	GROSS T-G MWE	NET PLANT MWE	HRS	
26.1 20	66.8	57.36	51.49	2	57.9	57.46	51.59	6	66.5	57.62	51.75	8	66.1	57.67	51.80	9	65.6	57.70	51.83	35	
	64.1	57.67	52.00	61	63.7	57.89	52.02	64	62.5	58.00	52.13	153	62.1	58.06	52.19	167	61.5	58.12	52.25	175	
	61.0	58.15	52.26	177	60.2	58.25	52.38	229	59.3	58.34	52.47	404	58.9	58.37	52.50	411	57.8	58.46	52.59	443	
	56.8	58.58	52.71	451	56.4	58.61	52.74	555	56.1	58.64	52.77	776	56.0	58.64	52.77	782	54.2	58.78	52.91	792	
	53.5	58.83	52.96	874	53.0	58.85	52.98	1093	52.5	58.89	53.02	1250	52.2	58.89	53.02	1282	51.1	58.96	53.09	1288	
	49.8	59.04	53.17	1480	49.4	59.05	53.19	1501	49.2	59.08	53.21	1657	48.6	59.12	53.25	1860	47.6	59.19	53.32	1929	
	46.5	59.26	53.39	2082	46.2	59.26	53.39	2093	44.8	59.34	53.47	2554	44.6	59.36	53.49	2592	43.3	59.42	53.55	2713	
	43.0	59.44	53.57	2824	41.3	59.51	53.65	2842	40.9	59.53	53.66	3058	40.5	59.55	53.68	3336	40.0	59.56	53.69	3424	
	39.8	59.58	53.71	3490	38.4	59.61	53.74	3643	37.0	59.66	53.74	3837	36.6	59.67	53.80	3910	36.3	59.67	53.80	3951	
	36.1	59.68	53.81	4201	35.1	59.70	53.83	4328	33.8	59.73	53.86	4475	33.2	59.74	53.87	4518	33.0	59.75	53.88	4670	
	31.8	59.77	53.90	4895	31.4	59.78	53.91	4962	30.4	59.79	53.92	5108	29.8	59.81	53.94	5128	29.3	59.82	53.95	5260	
	29.2	59.82	53.95	5332	27.6	59.85	53.98	5498	26.5	59.88	54.01	5537	26.4	59.88	54.01	5541	25.6	59.89	54.02	5681	
	25.3	59.90	54.03	5714	24.6	59.91	54.04	5821	23.2	59.93	54.06	5918	22.9	59.94	54.07	5918	21.6	59.97	54.10	5950	
	21.2	59.97	54.10	5960	20.8	59.98	54.11	6080	20.0	59.99	54.12	6157	18.7	60.01	54.14	6212	17.1	60.04	54.17	6216	
	16.6	60.05	54.18	6234	15.9	60.06	54.19	6318	15.3	60.07	54.20	6366	14.2	60.09	54.22	6384	11.7	60.13	54.26	6387	
	11.1	60.14	54.27	6428	10.9	60.15	54.28	6454	9.7	60.16	54.30	6458	6.3	60.21	54.34	6478	5.8	60.21	54.34	6484	
	5.1	60.22	54.35	6485	1.4	60.25	54.38	6490	1.0	60.25	54.38	6495	.4	60.26	54.39	6496	-3.2	60.27	54.40	6497	
	-3.5	60.27	54.40	6497	-3.8	60.27	54.40	6499	-8.6	60.27	54.40	6500									
	28.1 18	66.8	57.30	51.47	2	67.9	57.43	51.61	6	66.5	57.59	51.77	8	66.1	57.65	51.82	9	65.6	57.70	51.88	35
		64.1	57.64	52.02	61	63.7	57.89	52.07	64	62.5	58.00	52.18	153	62.1	58.06	52.23	167	61.5	58.12	52.30	175
61.0		58.15	52.33	177	60.2	58.25	52.42	229	59.3	58.34	52.52	404	58.9	58.40	52.58	411	57.8	58.49	52.67	443	
56.8		58.58	52.76	451	56.4	58.64	52.81	555	56.1	58.66	52.84	776	56.0	58.66	52.84	782	54.2	58.81	52.98	792	
53.5		58.83	53.03	874	53.0	58.89	53.07	1093	52.5	58.92	53.09	1250	52.2	58.94	53.11	1282	51.1	59.00	53.18	1288	
49.8		59.08	53.26	1480	49.4	59.10	53.28	1501	49.2	59.12	53.30	1657	48.6	59.17	53.34	1860	47.6	59.23	53.41	1929	
46.5		59.30	53.48	2082	46.2	59.32	53.50	2093	44.8	59.40	53.58	2554	44.6	59.40	53.58	2592	43.3	59.48	53.65	2713	
43.0		59.46	53.65	2824	41.3	59.56	53.74	2842	40.9	59.58	53.75	3058	40.5	59.59	53.77	3336	40.0	59.60	53.78	3424	
39.8		59.61	53.79	3490	38.4	59.66	53.84	3643	37.0	59.69	53.87	3837	36.6	59.70	53.88	3910	36.3	59.71	53.88	3951	
36.1		59.71	53.89	4201	35.1	59.74	53.91	4328	33.8	59.76	53.94	4475	33.2	59.78	53.95	4518	33.0	59.78	53.96	4670	
31.8		59.81	53.98	4895	31.4	59.82	53.99	4962	30.4	59.84	54.01	5108	29.8	59.85	54.03	5128	29.3	59.86	54.03	5260	
29.2		59.86	54.04	5332	27.6	59.89	54.07	5498	26.5	59.91	54.09	5537	26.4	59.92	54.10	5541	25.6	59.93	54.11	5681	
25.3		59.94	54.12	5714	24.6	59.95	54.12	5821	23.2	59.97	54.15	5918	22.9	59.98	54.16	5918	21.6	60.01	54.19	5950	
21.2		60.01	54.19	5960	20.8	60.02	54.19	6080	20.0	60.04	54.21	6157	18.7	60.05	54.23	6212	17.1	60.09	54.27	6216	
16.6		60.09	54.27	6234	15.9	60.11	54.29	6318	15.3	60.12	54.30	6366	14.2	60.14	54.31	6384	11.7	60.18	54.35	6387	
11.1		60.18	54.36	6428	10.9	60.19	54.37	6454	9.7	60.21	54.38	6458	6.3	60.24	54.42	6478	5.8	60.25	54.42	6484	
5.1		60.25	54.43	6485	1.4	60.27	54.44	6490	1.0	60.27	54.44	6495	.4	60.27	54.44	6496	-3.2	60.27	54.45	6497	
-3.5		60.27	54.45	6497	-3.8	60.27	54.45	6499	-8.6	60.27	54.44	6500									

APPENDIX E

SAMPLE COMPUTER PRINTOUT FOR
DIRECT DRY/WET PEAKING COOLING TOWER SYSTEMS

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION

PLANT LOCATION	BASIN AND RANGE
NOMINAL SIZE AND TYPE OF PLANT	50.0 MWE (NET) GEOTHERMAL
TYPE OF CONVERSION PROCESS	ORGANIC FLUID
GEOTHERMAL RESOURCE TEMPERATURE	360 F
TURBINE-GENERATOR DESIGN	TC2F AXIAL FLOW
WORKING FLUID	COMMERCIAL ISOBUTANE
NOMINAL DESIGN MAXIMUM OPERATING EXHAUST PRESSURE	80.0 PSIA
TYPE OF DRY TOWER	DIRECT
PERIOD OF PEAK ELECTRICAL DEMAND	SUMMER
NOMINAL TEMPERATURE AT AND ABOVE WHICH PEAKING CONDITIONS ARE ASSUMED TO EXIST	82 F
SOURCE OF REPLACEMENT GENERATION - CAPACITY REQUIREMENT BASED ON ZERO REPLACEMENT GENERATION	
PEAKING	NONE PROVIDED
OFF-PEAK	NONE PROVIDED
SITE ELEVATION (REFERENCED TO SEA LEVEL)	4400 FT
SITE CONSTRUCTION COST INDICES	
MATERIALS	1.000
LABOR	1.000
ESTIMATED LENGTH OF CONSTRUCTION PERIOD	18 MONTHS
SCHEDULED COMMERCIAL STARTUP DATE	1980
ANNUAL HOURS OF BASE LOAD OPERATION	6500

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST • O+M: \$.50 / MILLION BTU MAKEUP WATER COST • O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

1-2

TOWER DESIGN CONDITIONS	WET	PEAKING TOWER	DRY TOWER	GROSS ANNUAL BASE UNIT GENER- ATION MWH	ANNUAL AUXIL- IARY ENERGY REQUIRE- MENT MWH	REPLACEMENT CAPACITY REQUIRE- MENT ANNUAL EXCESS GENER- ATION MWH	ABV 82F MW	BLO 82F MW	REPLACE- MENT EN- ERGY MWH	ANNUAL REPLACE- MENT EN- ERGY MWH	MAKEUP WATER RE- QUIRE- MENT AC-FT	TOTAL ANNUAL REPLACE- MENT AND O+M CAPITAL COST \$	ANNUAL REPLACE- MENT AND O+M CAPACITY COST \$	ANNUAL GEO- THERMAL ENERGY AND O+M COST \$	ANNUAL EXCESS GENER- ATION CREDIT \$	ANNUAL REPLACE- MENT ENERGY AND O+M COST \$	ANNUAL MAKEUP WATER AND O+M COST \$	TOTAL ANNUAL CAPITAL + OPER- ATING COSTS \$	BUSBAR ENERGY PRODUC- TION COSTS /KWH
20	22.0	21	451409	83377	0	0.	0.	0	0	92	11504731	0	5300909	0	0	3010	16808651	45.67	
30	22.0	21	450125	86986	0	0.	0.	0	0	162	9461484	0	5300550	0	0	5266	14767300	40.65	
40	23.0	20	448533	90469	0	0.	0.	0	0	268	8441041	0	5300102	0	0	8728	13749870	38.40	
50	23.0	20	446369	93741	0	0.	0.	0	0	402	7935753	0	5299472	0	0	13100	13248325	37.57	
60	23.0	20	443031	96400	0	0.	0.	0	0	582	7487973	0	5298522	0	0	18974	12805469	36.94	
70	23.0	20	440040	98102	0	0.	0.	0	0	793	7186093	0	5297665	0	0	25850	12509608	36.58	
80	24.0	19	437886	98527	0	0.	0.	0	0	1017	6966856	0	5297059	0	0	33153	12297068	36.24	
90	25.0	18	436868	99152	0	0.	0.	0	0	1230	6798956	0	5296783	0	0	40084	12135823	35.93	
100	25.0	18	436569	99107	0	0.	0.	0	0	1413	6658079	0	5296734	0	0	46043	12000856	35.56	

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
 BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-3

TOWER DESIGN CONDITIONS	ANNUAL CAPITAL AND O+M COSTS			ANNUAL GEOTHERMAL ENERGY AND O+M COSTS	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENRGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COSTS	BUSBAR ENERGY PRODUCTION COSTS		
	DRY ITD F	WET RNG F	APPR F			CONVERSION PLANT	COOLING DRY	SYSTEM WET	CAPACITY COST PEAK- ING			NON- PEAKING	ENERGY COST ABOVE 82F
20	22.0	21	10.7202	17.5060	3.0280	14.4034	0.	0.	0.	0.	0.	.0082	45.6717
30	22.0	21	10.8677	11.8621	3.3177	14.5925	0.	0.	0.	0.	0.	.0145	40.6546
40	23.0	20	11.0248	9.0536	3.4957	14.8021	0.	0.	0.	0.	0.	.0244	38.4006
50	23.0	20	11.1948	7.3777	3.9322	15.0285	0.	0.	0.	0.	0.	.0371	37.5703
60	23.0	20	11.3884	6.2140	3.9997	15.2854	0.	0.	0.	0.	0.	.0547	36.9427
70	23.0	20	11.5447	5.4164	4.0546	15.4931	0.	0.	0.	0.	0.	.0756	36.5844
80	24.0	19	11.6325	4.7904	4.1066	15.6090	0.	0.	0.	0.	0.	.0977	36.2361
90	25.0	18	11.6890	4.2923	4.1508	15.6841	0.	0.	0.	0.	0.	.1187	35.9350
100	25.0	18	11.6978	3.8781	4.1539	15.6958	0.	0.	0.	0.	0.	.1364	35.5621

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-4

TOWER DESIGN CONDITIONS	WET	PEAKING TOWER	DRY TOWER	GROSS ANNUAL UNIT GENERATION	ANNUAL AUXILIARY ENERGY REQUIREMENT	ANNUAL EXCESS GENERATION	REPLACEMENT CAPACITY	ANNUAL REQUIREMENT	ANNUAL ENERGY REQUIREMENT	ANNUAL MAKEUP WATER REQUIREMENT	TOTAL ANNUAL CAPITAL AND O+M COST	ANNUAL REPLACEMENT CAPACITY AND O+M COST	ANNUAL GEO-THERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT ENERGY COST	ANNUAL MAKEUP WATER AND O+M COST	TOTAL ANNUAL CAPITAL + OPERATING COSTS	BUSBAR ENERGY PRODUCTION COSTS
ITD	RNG	APPR	F	MWH	MWH	MWH	ABV 82F	BLO 82F	ABV 82F	BLO 82F	\$	\$	\$	\$	\$	\$	\$	MILLS /KWH
20	22.0	21	451409	83377	0	0.	0.	0	0	92	11504731	0	5300909	0	0	30104	16835744	45.75
30	22.0	21	450125	86885	0	0.	0.	0	0	162	9461484	0	5300550	0	0	52664	14814697	40.79
40	23.0	20	448533	90469	0	0.	0.	0	0	268	8441041	0	5300102	0	0	87283	13828425	38.62
50	23.0	20	446369	93741	0	0.	0.	0	0	402	7935753	0	5299472	0	0	130998	13366224	37.90
60	23.0	20	443031	96400	0	0.	0.	0	0	582	7487973	0	5298522	0	0	189740	12976235	37.44
70	23.0	20	440040	98102	0	0.	0.	0	0	793	7186093	0	5297665	0	0	258500	12742258	37.26
80	24.0	19	437886	98527	0	0.	0.	0	0	1017	6966856	0	5297059	0	0	331534	12595448	37.12
90	25.0	18	436468	99152	0	0.	0.	0	0	1230	6798956	0	5296783	0	0	400838	12496577	37.00
100	25.0	18	436569	99107	0	0.	0.	0	0	1413	6658079	0	5296734	0	0	460432	12415244	36.79

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
 BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-5

ITD	TOWER DESIGN CONDITIONS		ANNUAL CAPITAL AND O+M COSTS			ANNUAL GEOTHERMAL ENERGY AND O+M COSTS	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COSTS	BUSBAR ENERGY PRODUCTION COSTS
	DRY	WET	CONVERSION PLANT	COOLING DRY	SYSTEM WET			PEAK-ING	NON-PEAKING	ABOVE 82F	BELOW 82F		
20	22.0	21	10.7262	17.5060	3.0280	14.4034	0.	0.	0.	0.	0.	.0818	45.7453
30	22.0	21	10.8677	11.8621	3.3177	14.5925	0.	0.	0.	0.	0.	.1450	40.7851
40	23.0	20	11.0248	9.0536	3.4957	14.8021	0.	0.	0.	0.	0.	.2438	38.6200
50	23.0	20	11.1948	7.3777	3.9322	15.0285	0.	0.	0.	0.	0.	.3715	37.9046
60	23.0	20	11.3884	6.2140	3.9997	15.2858	0.	0.	0.	0.	0.	.5474	37.4353
70	23.0	20	11.5447	5.4164	4.0546	15.4931	0.	0.	0.	0.	0.	.7560	37.2648
80	24.0	19	11.6325	4.7904	4.1066	15.6090	0.	0.	0.	0.	0.	.9769	37.1154
90	25.0	18	11.6890	4.2923	4.1508	15.6841	0.	0.	0.	0.	0.	1.1869	37.0032
100	25.0	18	11.6978	3.8781	4.1539	15.6958	0.	0.	0.	0.	0.	1.3644	36.7900

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-6

TOWER DESIGN CONDITIONS	WET	PEAKING TOWER	DRY TOWER	GROSS ANNUAL UNIT GENERATION	ANNUAL AUXILIARY ENERGY REQUIREMENT	ANNUAL EXCESS GENERATION	REPLACEMENT CAPACITY	ABV 82F	BLO 82F	ANNUAL REPLACE- MENT EN- ERGY REQD	MAKEUP WATER RE- QUIRE- MENT	ANNUAL TOTAL PLANT AND O+M COST	ANNUAL REPLACE- MENT CAPACITY	ANNUAL GEO- THERMAL ENERGY AND O+M COST	ANNUAL EXCESS GENER- ATION CREDIT	ANNUAL REPLACE- MENT ENERGY COST	ANNUAL MAKEUP WATER AND O+M COST	TOTAL ANNUAL CAPITAL + OPER- ATING COSTS	BUSBAR ENERGY PRODU- TION COSTS /KWH	
ITD F	RNG F	APPH F	GENER- ATION MWH	REQUIRE- MENT MWH	GENER- ATION MWH	ABV 82F MW	BLO 82F MW	ABV 82F MWH	BLO 82F MWH	AC-FT	\$	\$	\$	\$	\$	\$	\$	\$	\$	MILLS /KWH
20	22.0	21	451409	83377	0	0.	0.	0	0	92	11504731	0	5300909	0	0	75260	16880900	45.87		
30	22.0	21	450125	86886	0	0.	0.	0	0	162	9461484	0	5300550	0	0	131659	14893692	41.00		
40	23.0	20	448533	90469	0	0.	0.	0	0	268	8441041	0	5300102	0	0	218207	13959349	38.99		
50	23.0	20	446369	93741	0	0.	0.	0	0	402	7935753	0	5299472	0	0	327495	13562721	38.46		
60	23.0	20	443031	96400	0	0.	0.	0	0	582	7487973	0	5298522	0	0	474349	13260844	38.26		
70	23.0	20	440040	98102	0	0.	0.	0	0	793	7186093	0	5297665	0	0	646249	13130008	38.40		
80	24.0	19	437886	98527	0	0.	0.	0	0	1017	6966856	0	5297059	0	0	828834	13092749	38.58		
90	25.0	18	436868	99152	0	0.	0.	0	0	1230	6798956	0	5296783	0	0	1002094	13097833	38.78		
100	25.0	18	436569	99107	0	0.	0.	0	0	1413	6658079	0	5296734	0	0	1151079	13105891	38.84		

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
 BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$.50 / MILLION BTU MAKEUP WATER COST + O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-7

TOWER DESIGN CONDITIONS			ANNUAL CAPITAL AND O+M COSTS			ANNUAL GEOTHERMAL ENERGY AND O+M COSTS	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COSTS	BUSBAR ENERGY PRODUCTION COSTS
DRY	WET		CONVERSION	COOLING	SYSTEM			PEAK-	NON-	ABOVE	BELOW		
ITD	RNG	APPR	PLANT	DRY	WET	AND O+M COSTS		ING	PEAKING	82F	82F	AND O+M COSTS	
F	F	F											
20	22.0	21	10.7262	17.5060	3.0280	14.4034	0.	0.	0.	0.	0.	.2045	45.8680
30	22.0	21	10.8677	11.8621	3.3177	14.5925	0.	0.	0.	0.	0.	.3625	41.0025
40	23.0	20	11.0248	9.0536	3.4957	14.8021	0.	0.	0.	0.	0.	.6094	38.9856
50	23.0	20	11.1948	7.3777	3.9322	15.0285	0.	0.	0.	0.	0.	.9287	38.4619
60	23.0	20	11.3884	6.2140	3.9997	15.2858	0.	0.	0.	0.	0.	1.3685	38.2564
70	23.0	20	11.5447	5.4164	4.0546	15.4931	0.	0.	0.	0.	0.	1.8900	38.3988
80	24.0	19	11.6325	4.7904	4.1066	15.6090	0.	0.	0.	0.	0.	2.4424	38.5808
90	25.0	18	11.6890	4.2923	4.1508	15.6841	0.	0.	0.	0.	0.	2.9673	38.7835
100	25.0	18	11.6978	3.8781	4.1539	15.6958	0.	0.	0.	0.	0.	3.4110	38.8366

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-8

TOWER DESIGN CONDITIONS	GROSS ANNUAL WET PEAKING TOWER	WET APPH	UNIT GENERATION MWH	ANNUAL AUXILIARY ENERGY REQUIREMENT MWH	ANNUAL EXCESS GENERATION MWH	REPLACEMENT CAPACITY REQUIREMENT		ANNUAL REPLACEMENT ENERGY REQUIREMENT		ANNUAL MAKEUP WATER AC-FT	TOTAL ANNUAL PLANT AND O+M COST \$	ANNUAL REPLACEMENT CAPACITY AND O+M COST \$	ANNUAL GEO-THERMAL ENERGY AND O+M COST \$	ANNUAL EXCESS GENERATION CREDIT \$	ANNUAL REPLACEMENT ENERGY AND O+M COST \$	ANNUAL MAKEUP WATER AND O+M COST \$	TOTAL ANNUAL CAPITAL + OPERATING COSTS \$	BUSBAR ENERGY PRODUCTION COSTS MILLS /KWH
						ABV 82F MW	BLO 82F MW	ABV 82F MWH	BLO 82F MWH									
20	22.0	21	451409	83377	0	0.	0.	0	0	92	11504731	0	10601818	0	0	3010	22109559	60.08
30	22.0	21	450125	86886	0	0.	0.	0	0	162	9461484	0	10601099	0	0	5266	20067849	55.25
40	23.0	20	448533	90469	0	0.	0.	0	0	268	8441041	0	10600203	0	0	8728	19049972	53.20
50	23.0	20	446369	93741	0	0.	0.	0	0	402	7935753	0	10598944	0	0	13100	18547797	52.60
60	24.0	19	443032	96186	0	0.	0.	0	0	582	7495146	0	10597044	0	0	18967	18111157	52.22
70	25.0	18	440041	97525	0	0.	0.	0	0	794	7201463	0	10595330	0	0	25883	17822676	52.03
80	25.0	18	437891	98170	0	0.	0.	0	0	1018	6975053	0	10594117	0	0	33163	17602333	51.81
90	25.0	18	436868	99152	0	0.	0.	0	0	1230	6798956	0	10593567	0	0	40084	17432606	51.62
100	27.0	16	436574	98251	0	0.	0.	0	0	1414	6687825	0	10593465	0	0	46073	17327362	51.22

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
 BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST • O+M: \$1.00 / MILLION BTU MAKEUP WATER COST • O+M: \$.10 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-9

TOWER DESIGN CONDITIONS	ANNUAL CAPITAL AND O+M COSTS		ANNUAL GEOTHERMAL ENERGY AND O+M COSTS	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS		ANNUAL MAKEUP WATER AND O+M COSTS	BUSBAR ENERGY PRODUCTION COSTS					
	DRY	WET			CONVERSION PLANT	COOLING DRY			SYSTEM WET	PEAK- ING	NON- PEAKING	ABOVE 82F	BELOW 82F
ITD F	RNG F	APPR F											
20	22.0	21	10.7262	17.5060	3.0280	28.8068	0.	0.	0.	0.	0.	.0082	60.0751
30	22.0	21	10.8677	11.8621	3.3177	29.1850	0.	0.	0.	0.	0.	.0145	55.2471
40	23.0	20	11.0248	9.0536	3.4957	29.6042	0.	0.	0.	0.	0.	.0244	53.2027
50	23.0	20	11.1948	7.3777	3.9322	30.0570	0.	0.	0.	0.	0.	.0371	52.5988
60	24.0	19	11.3814	6.2101	4.0179	30.5526	0.	0.	0.	0.	0.	.0547	52.2167
70	25.0	18	11.5252	5.4073	4.0927	30.9338	0.	0.	0.	0.	0.	.0756	52.0346
80	25.0	18	11.6201	4.7853	4.1263	31.1848	0.	0.	0.	0.	0.	.0976	51.8141
90	25.0	18	11.6890	4.2923	4.1508	31.3682	0.	0.	0.	0.	0.	.1187	51.6191
100	27.0	16	11.6681	3.8682	4.2313	31.3117	0.	0.	0.	0.	0.	.1362	51.2154

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

TOWER ITD	DESIGN CONDITIONS			GROSS ANNUAL BASE UNIT GENER- ATION MWH	ANNUAL AUXIL- IARY ENERGY REQUIRE- MENT MWH	REPLACEMENT CAPACITY REQUIRE- MENT			ANNUAL REPLACE- MENT EN- ERGY REQD		ANNUAL MAKEUP WATER RE- QUIRE- MENT AC-FT	TOTAL ANNUAL PLANT AND O+M CAPITAL COST \$	ANNUAL REPLACE- MENT CAPACITY AND O+M COST \$	ANNUAL GEO- THERMAL ENERGY AND O+M COST \$	ANNUAL EXCESS GENER- ATION CREDIT \$'	ANNUAL REPLACE- MENT ENERGY COST \$	ANNUAL MAKEUP WATER AND O+M COST \$	TOTAL ANNUAL CAPITAL • OPER- ATING COSTS \$	BUSBAR ENERGY PRODUC- TION COSTS MILLS /KWH
	DRY	PEAKING	WET			ANNUAL EXCESS GENER- ATION MWH	ABV 82F	BLO 82F	ABV 82F	BLO 82F									
20	22.0	21	451409	83377	0	0.	0.	0	0	92	11504731	0	10601818	0	0	30104	22136653	60.15	
30	22.0	21	450125	86886	0	0.	0.	0	0	162	9461484	0	10601099	0	0	52664	20115246	55.38	
40	23.0	20	448533	90469	0	0.	0.	0	0	268	8441041	0	10600203	0	0	87283	19128526	53.42	
50	23.0	20	446369	93741	0	0.	0.	0	0	402	7935753	0	10598944	0	0	130998	18665696	52.93	
60	24.0	19	443032	96186	0	0.	0.	0	0	582	7495146	0	10597044	0	0	189669	18281859	52.71	
70	25.0	18	440041	97525	0	0.	0.	0	0	794	7201463	0	10595330	0	0	258828	18055621	52.71	
80	25.0	18	437891	98170	0	0.	0.	0	0	1018	6975053	0	10594117	0	0	331632	17900801	52.69	
90	25.0	18	436868	99152	0	0.	0.	0	0	1230	6798956	0	10593567	0	0	400838	17793360	52.69	
100	27.0	16	436574	98251	0	0.	0.	0	0	1414	6687825	0	10593465	0	0	460727	17742017	52.44	

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
 BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$1.00 / K-GAL
 PEAKING CAPACITY COST: 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-11

TOWER DESIGN CONDITIONS			ANNUAL CAPITAL AND O+M COSTS			ANNUAL GEOTHERMAL ENERGY AND O+M COSTS	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COSTS	BUSBAR ENERGY PRODUCTION COSTS
DRY	WET		CONVERSION PLANT	COOLING DRY	SYSTEM WET			PEAK-ING	NON-PEAKING	ABOVE 82F	BELOW 82F		
ITD F	RNG F	APPR F											
20	22.0	21	10.7262	17.5060	3.0280	28.8068	0.	0.	0.	0.	0.	.0818	60.1487
30	22.0	21	10.8677	11.8621	3.3177	29.1850	0.	0.	0.	0.	0.	.1450	55.3776
40	23.0	20	11.0248	9.0536	3.4957	29.6042	0.	0.	0.	0.	0.	.2438	53.4221
50	23.0	20	11.1948	7.3777	3.9322	30.0570	0.	0.	0.	0.	0.	.3715	52.9332
60	24.0	19	11.3814	6.2101	4.0179	30.5526	0.	0.	0.	0.	0.	.5468	52.7088
70	25.0	18	11.5252	5.4073	4.0927	30.9338	0.	0.	0.	0.	0.	.7557	52.7147
80	25.0	18	11.6201	4.7853	4.1263	31.1848	0.	0.	0.	0.	0.	.9762	52.6927
90	25.0	18	11.6890	4.2923	4.1508	31.3682	0.	0.	0.	0.	0.	1.1869	52.6873
100	27.0	16	11.6681	3.8682	4.2313	31.3117	0.	0.	0.	0.	0.	1.3618	52.4410

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST • O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

TOWER DESIGN CONDITIONS	WET TOWER	PEAKING TOWER	DRY TOWER	GROSS ANNUAL BASE GENERATION MWH	ANNUAL AUXILIARY ENERGY REQUIREMENT MWH	ANNUAL EXCESS GENERATION MWH	REPLACEMENT CAPACITY REQUIREMENT	ABV 82F	BLO 82F	ANNUAL REPLACEMENT ENERGY REQD 82F	ANNUAL MAKEUP WATER REQUIREMENT AC-FT	TOTAL ANNUAL PLANT AND O+M COST \$	ANNUAL REPLACEMENT CAPACITY AND O+M COST \$	ANNUAL GEO-THERMAL ENERGY AND O+M COST \$	ANNUAL EXCESS GENERATION CREDIT \$	ANNUAL REPLACEMENT ENERGY COST \$	ANNUAL MAKEUP WATER AND O+M COST \$	TOTAL ANNUAL CAPITAL + OPERATING COSTS \$	BUSBAR ENERGY PRODUCTION COSTS MILLS /KWH
20	22.0	21	451409	83377	0	0.	0.	0	0	92	11504731	0	10601818	0	0	75260	22181809	60.27	
30	22.0	21	450125	86886	0	0.	0.	0	0	162	9461484	0	10601099	0	0	131659	20194242	55.60	
40	23.0	20	448533	90469	0	0.	0.	0	0	268	8441041	0	10600203	0	0	218207	19259450	53.79	
50	23.0	20	446369	93741	0	0.	0.	0	0	402	7935753	0	10598944	0	0	327495	18862193	53.49	
60	24.0	19	443032	96186	0	0.	0.	0	0	582	7495146	0	10597044	0	0	474172	18566362	53.53	
70	25.0	18	440041	97525	0	0.	0.	0	0	794	7201463	0	10595330	0	0	647070	18443862	53.85	
80	25.0	18	437891	98170	0	0.	0.	0	0	1018	6975053	0	10594117	0	0	829080	18398249	54.16	
90	25.0	18	436868	99152	0	0.	0.	0	0	1230	6798956	0	10593567	0	0	1002094	18394616	54.47	
100	27.0	16	436574	98251	0	0.	0.	0	0	1414	6687825	0	10593465	0	0	1151818	18433108	54.48	

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
 BUSBAR COMPONENT COST BREAKDOWN - MILLS PER KWH

ANNUAL FIXED-CHARGE RATE: 15.0 PCT GEOTHERMAL ENERGY COST + O+M: \$1.00 / MILLION BTU MAKEUP WATER COST + O+M: \$2.50 / K-GAL
 PEAKING CAPACITY COST: \$ 0 PER KW NON-PEAKING REPLACEMENT CAPACITY COST: \$ 0 PER KW
 REPLACEMENT ENERGY COST AT AND ABOVE 82 F: 0. MILLS PER KWH BELOW 82 F: 0. MILLS PER KWH
 FIXED ANNUAL O+M COSTS (PCT OF CAPITAL COST): CONVERSION PLANT: 3.0 COOLING SYSTEM: 1.0 PEAKING PLANT: 0.

E-13

ITD	TOWER DESIGN CONDITIONS		ANNUAL CAPITAL AND O+M COSTS			ANNUAL GEOTHERMAL ENERGY AND O+M COSTS	ANNUAL EXCESS GENERATION CREDIT	ANNUAL REPLACEMENT CAPACITY AND ENERGY AND O+M COSTS				ANNUAL MAKEUP WATER AND O+M COSTS	BUSBAR ENERGY PRODUCTION COSTS
	DRY F	WET F	APPR F	CONVERSION PLANT	COOLING DRY			SYSTEM WET	PEAK-ING	NON-PEAKING	ENERGY COST ABOVE 82F		
20	22.0	21	10.7262	17.5060	3.0280	28.8068	0.	0.	0.	0.	0.	.2045	60.2714
30	22.0	21	10.8677	11.8621	3.3177	29.1850	0.	0.	0.	0.	0.	.3625	55.5950
40	23.0	20	11.0248	9.0536	3.4957	29.6042	0.	0.	0.	0.	0.	.6094	53.7878
50	23.0	20	11.1948	7.3777	3.9322	30.0570	0.	0.	0.	0.	0.	.9287	53.4904
60	24.0	19	11.3814	6.2101	4.0179	30.5526	0.	0.	0.	0.	0.	1.3671	53.5291
70	25.0	18	11.5252	5.4073	4.0927	30.9338	0.	0.	0.	0.	0.	1.8892	53.8482
80	25.0	18	11.6201	4.7853	4.1263	31.1848	0.	0.	0.	0.	0.	2.4405	54.1570
90	25.0	18	11.6890	4.2923	4.1508	31.3682	0.	0.	0.	0.	0.	2.9673	54.4677
100	27.0	16	11.6681	3.8682	4.2313	31.3117	0.	0.	0.	0.	0.	3.4045	54.4837

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
SUMMARY OF DESIGN DATA

DRY TOWER SYSTEM

TOWER ITD - F	20.00	30.00	40.00	50.00	60.00	70.00	80.00	90.00	100.00
DEGREES SUBCOOLING - F	0.	0.	0.	0.	0.	0.	0.	0.	0.
AMBIENT DRY-BULB TEMP - F	82.20	72.20	62.20	52.20	46.49	36.49	26.49	16.49	6.49
TURBINE BACK PRESS - PSIA	75.24	75.24	75.24	75.24	80.00	80.00	80.00	80.00	80.00
TOWER HEAT LOAD - MBTU/HR	1332	1332	1332	1332	1319	1319	1319	1319	1319
AIR FACE VELOCITY - FPM	500	500	500	500	500	500	500	500	500
TOWER SURFACE - SQ FT	1086425	724283	543212	434570	358607	307378	268955	239071	215164
FAN BRAKE HORSEPOWER - HP	10252	6835	5126	4101	3384	2901	2538	2256	2030
TOWER PLAN AREA - ACRES	5.12	3.41	2.56	2.05	1.69	1.45	1.27	1.13	1.01

WET PEAKING TOWER SYSTEM

COOLING RANGE - F	21.96	21.96	22.96	22.96	22.96	22.96	23.96	24.96	24.96
APPROACH TO WET-BULB - F	21.00	21.00	20.00	20.00	20.00	20.00	19.00	18.00	18.00
CONDENSER TTD - F	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00
AMBIENT WET-BULB TEMP - F	62.00	62.00	62.00	62.00	62.00	62.00	62.00	62.00	62.00
TURBINE BACK PRESS - PSIA	90.00	90.00	90.00	90.00	90.00	90.00	90.00	90.00	90.00
TOWER HEAT LOAD - MBTU/HR	1020	1120	1170	1319	1319	1319	1319	1319	1319
CIRCULATING WATER FLOW - GPM	92897	101974	101873	114895	114895	114895	110100	105689	105689
CONDENSER SURFACE - SQ FT	795331	873042	896043	1010583	1010583	1010583	993493	977141	977141
TOWER L/G RATIO	1.765	1.765	1.649	1.649	1.649	1.649	1.544	1.447	1.447
TOWER CHARACTERISTIC (KAV/L)	1.080	1.080	1.152	1.152	1.152	1.152	1.229	1.311	1.311
CIRC WATER PUMP BHP - HP	2199	2414	2412	2720	2720	2720	2607	2502	2502
FAN BRAKE HORSEPOWER - HP	914	1004	1090	1229	1229	1229	1285	1340	1340

SUPPLEMENTAL AUXILIARY

WET COOLING TOWER SYSTEM

AUXILIARY HEAT LOAD - MBTU/HR	17.3	17.3	17.3	17.3	17.1	17.1	17.1	17.1	17.1
CIRCULATING WATER FLOW - GPM	2309	2309	2309	2309	2286	2286	2286	2286	2286
CIRC WATER PUMP BHP - HP	55	55	55	55	54	54	54	54	54
FAN BRAKE HORSEPOWER - HP	23	23	23	23	23	23	23	23	23

GENERATING PLANT

RATED TURBINE-GENERATOR

OUTPUT AT 85.0 PSIA - MW	65.0	65.0	65.0	65.0	65.0	65.0	65.0	65.0	65.0
PLANT AUXILIARY POWER - MW	11.6	11.6	11.6	11.6	11.6	11.6	11.6	11.6	11.6
INSTALLED PEAKING CAPACITY - MW	0.	0.	0.	0.	0.	0.	0.	0.	0.

- NOTES: 1. MBTU/HR = MILLION BTU/HR
2. CONDENSER SURFACE = TOTAL HEAT TRANSFER SURFACE
3. TOWER SURFACE = BARE-TUBE SURFACE OF FINNED-TUBE HEAT EXCHANGER

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
CAPITAL COST BREAKDOWN

DRY TOWER ITD - F	20.00	30.00	40.00	50.00	60.00	70.00	80.00	90.00	100.00
WET PEAKING TOWER RANGE - F	21.96	21.96	22.96	22.96	22.96	22.96	23.96	24.96	24.96
WET PEAKING TOWER APPROACH - F	21.00	21.00	20.00	20.00	20.00	20.00	19.00	18.00	18.00

DRY TOWER SYSTEM	\$	\$	\$	\$	\$	\$	\$	\$	\$
DRY TOWER (INCL FOUNDATION)	29480235	19653490	14740117	11792094	9730838	8340719	7298129	6487226	5838503
TURBINE EXHAUST TRUNK	204892	204892	204892	204892	204892	204892	204892	204892	204892
TOTAL	29685127	19858382	14945009	11996986	9935730	8545611	7503021	6692118	6043395
NITROGEN BLANKETING SYSTEM	14019	9346	7010	5608	4628	3966	3471	3085	2777
ELECTRICAL	2156148	1437432	1074074	862459	711701	610030	533776	474468	427021
TOTAL DRY TOWER SYSTEM	31855294	21305160	16030093	12865053	10652059	9159607	8040268	7169670	6473192

WET-PEAKING TOWER SYSTEM
(INCLUDING SUPPLEMENTAL
AUXILIARY COOLING WET CELL)

WET TOWER	1217023	1332986	1445020	1625873	1625578	1625578	1697509	1769471	1769471
BASIN AND FOUNDATION	497454	544853	590647	664570	664450	664450	693851	723265	723265
TOTAL TOWER	1714477	1877839	2035667	2290443	2290028	2290028	2391360	2492736	2492736
CONDENSER	1390671	1526551	1564770	1767047	1767047	1767047	1737165	1708572	1708572
CIRCULATING WATER FACILITIES									
PUMPS AND MOTORS	719841	760266	759826	815463	815369	815369	795182	776306	776306
PIPING	1335173	1410154	1404338	1512535	1512361	1512361	1474918	1439906	1439906
TOTAL	2055013	2170420	2169164	2327999	2327730	2327730	2270100	2216213	2216213
ELECTRICAL	373074	408622	429966	498406	498315	498315	520365	542425	542425
TOTAL WET TOWER SYSTEM	5533236	5983433	6214566	6883894	6883120	6883120	6918990	6959946	6959946

INDIRECT COOLING SYSTEM COSTS

ENGINEERING AND CONTINGENCIES	5608279	4093289	3336699	2962342	2630277	2406409	2243889	2119442	2014971
INTEREST DURING CONSTRUCTION	4235385	3080017	2592770	2214794	1962001	1791571	1667330	1572042	1492508
TOTAL COOLING SYSTEM CAPITAL INVESTMENT AT STARTUP	47232195	3461899	28084128	24926083	22127457	20240707	18870476	17821100	16940617

GENERATING PLANT

GEOTHERMAL CONVERSION PLANT (INCLUDING TURBINE-GENERATOR)	21931000	21931000	21931000	21931000	21931000	21931000	21931000	21931000	21931000
INSTALLED PEAKING CAPACITY	0	0	0	0	0	0	0	0	0
TOTAL GEOTHERMAL PLANT INVESTMENT AT STARTUP	69163195	56392899	50015128	46857083	44058457	42171707	40801476	39752100	38871617

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
CAPITAL COST BREAKDOWN

THE FOLLOWING RESULTS ARE THE SAME AS ON PREVIOUS PRINTOUTS EXCEPT FOR THE FOLLOWING ITD(S): 60 70 80 100

	20.00	30.00	40.00	50.00	60.00	70.00	80.00	90.00	100.00
DRY TOWER ITD - F	20.00	30.00	40.00	50.00	60.00	70.00	80.00	90.00	100.00
WET PEAKING TOWER RANGE - F	21.96	21.96	22.96	22.96	23.96	24.96	24.96	24.96	26.96
WET PEAKING TOWER APPROACH - F	21.00	21.00	20.00	20.00	19.00	18.00	18.00	18.00	16.00

DRY TOWER SYSTEM	\$	\$	\$	\$	\$	\$	\$	\$	\$
DRY TOWER (INCL FOUNDATION)	29480235	19653490	14740117	11792094	9730838	8340719	7298129	6487226	5838503
TURBINE EXHAUST TRUNK	204892	204892	204892	204892	204892	204892	204892	204892	204892
TOTAL	29685127	19858382	14945009	11996986	9935730	8545611	7503021	6692118	6043395
NITROGEN BLANKETING SYSTEM	14019	9346	7010	5608	4628	3966	3471	3085	2777
ELECTRICAL	2156148	1437432	1074074	862459	711701	610030	533776	474468	427021
TOTAL DRY TOWER SYSTEM	31855294	21305160	16030093	12865053	10652059	9159607	8040268	7169670	6473192

WET-PEAKING TOWER SYSTEM
(INCLUDING SUPPLEMENTAL
AUXILIARY COOLING WET CELL)

WET TOWER	1217023	1332986	1445020	1625873	1697509	1769471	1769471	1769471	1944359
BASIN AND FOUNDATION	497454	544853	590647	664570	693851	723265	723265	723265	794750
TOTAL TOWER	1714477	1877839	2035667	2290443	2391360	2492736	2492736	2492736	2739109
CONDENSER	1390671	1526551	1566770	1767047	1737165	1708572	1708572	1708572	1654913
CIRCULATING WATER FACILITIES									
PUMPS AND MOTORS	719841	760266	759826	815463	795182	776306	776306	776306	741976
PIPING	1335173	1410154	1409338	1512535	1474918	1439906	1439906	1439906	1376229
TOTAL	2055013	2170420	2169164	2327999	2270100	2216213	2216213	2216213	2118205
ELECTRICAL	373074	408622	442966	498406	520365	542425	542425	542425	596037
TOTAL WET TOWER SYSTEM	5533236	5983433	6214566	6883894	6918990	6959946	6959946	6959946	7108264

INDIRECT COOLING SYSTEM COSTS

ENGINEERING AND CONTINGENCIES	5608279	4093289	3336699	2962342	2635657	2417933	2250032	2119442	2037218
INTEREST DURING CONSTRUCTION	4235385	3080017	2502770	2214794	1965582	1799281	1671459	1572042	1507854
TOTAL COOLING SYSTEM CAPITAL INVESTMENT AT STARTUP	47232195	34461899	28084128	24926083	22172288	20336767	18921704	17821100	17126529

GENERATING PLANT

GEOTHERMAL CONVERSION PLANT (INCLUDING TURBINE-GENERATOR)	21931000	21931000	21931000	21931000	21931000	21931000	21931000	21931000	21931000
INSTALLED PEAKING CAPACITY	0	0	0	0	0	0	0	0	0
TOTAL GEOTHERMAL PLANT INVESTMENT AT STARTUP	69163195	56392899	50015128	46857083	44103288	42267767	40852704	39752100	39057529

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
DISTRIBUTION OF HEAT LOAD BETWEEN DRY AND WET-PEAKING TOWERS

DRY TOWER DESIGN ITD - F

DRY- BULB TEMP F	20			30			40			50			60			70			80			90			100					
	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET	HEAT LOAD	PCT DRY	PCT WET			
102	1319	23	77	1319	15	85	1319	11	89	1319	0	100	1319	0	100	1319	0	100	1319	0	100	1319	0	100	1319	0	100			
97	1319	48	52	1319	32	68	1319	24	76	1319	19	81	1319	16	84	1319	14	86	1319	12	88	1319	11	89	1319	0	100			
92	1319	73	27	1319	49	51	1319	37	63	1319	29	71	1319	24	76	1319	21	79	1319	18	82	1319	16	84	1319	14	86			
87	1319	98	2	1319	66	34	1319	49	51	1319	39	61	1319	32	68	1319	28	72	1319	24	76	1319	22	78	1319	19	81			
82	1332	100	0	1319	82	18	1319	62	38	1319	49	51	1319	41	59	1319	35	65	1319	31	69	1319	27	73	1319	24	76			
77	1332	100	0	1318	100	0	1319	74	26	1319	60	40	1319	49	51	1319	42	58	1319	37	63	1319	33	67	1319	29	71			
72	1332	100	0	1332	100	0	1319	87	13	1319	70	30	1319	57	43	1319	49	51	1319	43	57	1319	38	62	1319	34	66			
67	1332	100	0	1332	100	0	1318	100	0	1319	80	20	1319	66	34	1319	56	44	1319	49	51	1319	44	56	1319	39	61			
62	1332	100	0	1332	100	0	1332	100	0	1319	90	10	1319	74	26	1319	64	36	1319	56	44	1319	49	51	1319	44	56			
57	1332	100	0	1332	100	0	1332	100	0	1319	100	0	1319	82	18	1319	71	29	1319	62	38	1319	55	45	1319	49	51			
52	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1319	91	9	1319	78	22	1319	68	32	1319	61	39	1319	54	46			
47	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1318	100	0	1319	85	15	1319	74	26	1319	66	34	1319	59	41			
42	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1331	100	0	1319	92	8	1319	81	19	1319	72	28	1319	64	36			
37	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1318	100	0	1319	87	13	1319	77	23	1319	69	31			
32	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1331	100	0	1319	93	7	1319	83	17	1319	74	26			
27	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1318	100	0	1319	88	12	1319	79	21			
22	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1331	100	0	1319	94	6	1319	84	16			
17	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1318	100	0	1319	89	11			
12	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1330	100	0	1319	94	6			
7	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1318	100	0			
2	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1330	100	0			
-3	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0			
-8	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0	1332	100	0			
ANNUAL HRS OF TOWER OPERA- TION	-----			-----			-----			-----			-----			-----			-----			-----			-----			-----		
DRY	6500			6500			6500			6498			6498			6498			6498			6498			6472			6459		
WET	297			544			1128			1904			3043			4376			5537			6217			6459			6459		

NOTES: 1. HEAT LOAD IS TURBINE HEAT REJECTION IN MILLION BTU/HR AT OPERATING BACK PRESSURE OCCURRING AT GIVEN AMBIENT CONDITION
2. AT HIGH AMBIENT TEMPERATURES WHERE OPERATING BACK PRESSURE IS ALLOWED TO EXCEED THE SPECIFIED MAXIMUM, IF NECESSARY WITH A GIVEN COOLING SYSTEM DESIGN, THE HEAT LOAD AND PERCENT DISTRIBUTION MAY DIFFER SLIGHTLY FROM THE RESULTS SHOWN ABOVE

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
SUMMARY OF DESIGN DATA

THE FOLLOWING RESULTS ARE THE SAME AS ON PREVIOUS PRINTOUTS EXCEPT FOR THE FOLLOWING ITD(S): 60 70 80 100

DRY TOWER SYSTEM

TOWER ITD - F	20.00	30.00	40.00	50.00	60.00	70.00	80.00	90.00	100.00
DEGREES SUBCOOLING - F	0.	0.	0.	0.	0.	0.	0.	0.	0.
AMBIENT DRY-BULB TEMP - F	82.20	72.20	62.20	52.20	46.49	36.49	26.49	16.49	6.49
TURBINE BACK PRESS - PSIA	75.24	75.24	75.24	75.24	80.00	80.00	80.00	80.00	80.00
TOWER HEAT LOAD - MBTU/HR	1332	1332	1332	1332	1319	1319	1319	1319	1319
AIR FACE VELOCITY - FPM	500	500	500	500	500	500	500	500	500
TOWER SURFACE - SQ FT	1086425	724283	543212	434570	358607	307378	268955	239071	215164
FAN BRAKE HORSEPOWER - HP	10252	6835	5126	4101	3384	2901	2538	2256	2030
TOWER PLAN AREA - ACRES	5.12	3.41	2.56	2.05	1.69	1.45	1.27	1.13	1.01

WET PEAKING TOWER SYSTEM

COOLING RANGE - F	21.96	21.96	22.96	22.96	23.96	24.96	24.96	24.96	26.96
APPROACH TO WET-BULB - F	21.00	21.00	20.00	20.00	19.00	18.00	18.00	18.00	16.00
CONDENSER ITD - F	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00
AMBIENT WET-BULB TEMP - F	62.00	62.00	62.00	62.00	62.00	62.00	62.00	62.00	62.00
TURBINE BACK PRESS - PSIA	90.00	90.00	90.00	90.00	90.00	90.00	90.00	90.00	90.00
TOWER HEAT LOAD - MBTU/HR	1020	1120	1170	1319	1319	1319	1319	1319	1319
CIRCULATING WATER FLOW - GPM	92897	101974	101873	114895	110100	105689	105689	105689	97849
CONDENSER SURFACE - SQ FT	795331	873042	896043	1010583	993493	977141	977141	977141	946453
TOWER L/G RATIO	1.765	1.765	1.649	1.649	1.544	1.447	1.447	1.447	1.277
TOWER CHARACTERISTIC (KAV/L)	1.080	1.080	1.152	1.152	1.229	1.311	1.311	1.311	1.494
CIRC WATER PUMP BHP - HP	2199	2414	2412	2720	2607	2502	2502	2502	2316
FAN BRAKE HORSEPOWER - HP	914	1004	1090	1229	1245	1340	1340	1340	1475

SUPPLEMENTAL AUXILIARY
WET COOLING TOWER SYSTEM

AUXILIARY HEAT LOAD - MBTU/HR	17.3	17.3	17.3	17.3	17.1	17.1	17.1	17.1	17.1
CIRCULATING WATER FLOW - GPM	2309	2309	2309	2309	2286	2286	2286	2286	2286
CIRC WATER PUMP BHP - HP	55	55	55	55	54	54	54	54	54
FAN BRAKE HORSEPOWER - HP	23	23	23	23	23	23	23	23	23

GENERATING PLANT

RATED TURBINE-GENERATOR									
OUTPUT AT 85.0 PSIA - MW	65.0	65.0	65.0	65.0	65.0	65.0	65.0	65.0	65.0
PLANT AUXILIARY POWER - MW	11.6	11.6	11.6	11.6	11.6	11.6	11.6	11.6	11.6
INSTALLED PEAKING CAPACITY - MW	0.	0.	0.	0.	0.	0.	0.	0.	0.

- NOTES: 1. MBTU/HR = MILLION BTU/HR
2. CONDENSER SURFACE = TOTAL HEAT TRANSFER SURFACE
3. TOWER SURFACE = BAKE-TUBE SURFACE OF FINNED-TUBE HEAT EXCHANGER

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
ANNUAL TURBINE OPERATING PROFILE

DRY TOWER ID F	WET-PEAKING TOWER		OPERATING BACK PRESSURE (OBP) - PSIA VS. HOURS PRESSURE IS EQUALLED OR EXCEEDED																
	RANGE F.	APPR F.	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	OBP	HRS	
	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
20	21.96	21.0	92.1	2	80.0	297	75.2	6501											
30	21.96	21.0	92.2	2	81.7	28	80.3	301	80.0	817	75.2	6501							
40	22.96	20.0	92.4	2	84.2	28	80.2	381	80.0	1481	75.2	6501							
50	22.96	20.0	92.5	2	82.0	28	80.1	541	80.0	2417	75.2	6501							
60	22.96	20.0	92.5	2	83.6	28	80.5	702	80.0	3717	75.6	4376	75.2	6501					
60	23.96	19.0	92.5	2	83.5	28	80.5	702	80.0	3717	75.6	4376	75.2	6501					
70	22.96	20.0	92.5	2	84.5	28	80.4	643	80.0	4991	75.7	5537	75.2	6501					
70	24.96	18.0	92.7	2	84.5	28	80.4	643	80.0	4991	75.7	5537	75.2	6501					
80	23.96	19.0	92.5	2	85.3	28	80.9	32	80.9	122	80.4	513	80.0	5929	75.8	6217	75.2	6501	
80	24.96	18.0	92.7	2	85.2	28	80.9	32	80.8	122	80.4	513	80.0	5929	75.8	6217	75.2	6501	
90	24.96	18.0	92.7	2	86.0	28	82.1	32	81.7	122	80.4	289	80.0	6384	76.0	6459	75.2	6501	
100	24.96	18.0	92.7	2	90.8	28	83.1	32	82.4	122	80.5	148	80.0	6486	76.0	6497	75.2	6501	
100	26.96	16.0	92.8	2	91.0	28	83.0	32	82.3	122	80.5	148	80.0	6486	76.0	6497	75.2	6501	

E-19

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
ANNUAL PLANT GENERATING PROFILE

		20.0		30.0		40.0		50.0		60.0		70.0		80.0		90.0		100.0	
DRY TWR ITD-F		20.0		30.0		40.0		50.0		60.0		70.0		80.0		90.0		100.0	
WET TWR RNG-F		22.0		22.0		23.0		23.0		23.0		23.0		24.0		25.0		25.0	
WET TWR APP-F		21.0		21.0		20.0		20.0		20.0		20.0		19.0		18.0		18.0	
AMB HRS TEMP		GROSS NET		GROSS NET		GROSS NET		GROSS NET		GROSS NET		GROSS NET		GROSS NET		GROSS NET		GROSS NET	
DRY- EQUALLED		T-G PLANT		T-G PLANT		T-G PLANT		T-G PLANT		T-G PLANT		T-G PLANT		T-G PLANT		T-G PLANT		T-G PLANT	
BULB OR		OUT- OUT-		OUT- OUT-		OUT- OUT-		OUT- OUT-		OUT- OUT-		OUT- OUT-		OUT- OUT-		OUT- OUT-		OUT- OUT-	
TEMP EXCEEDED		PUT PUT		PUT PUT		PUT PUT		PUT PUT		PUT PUT		PUT PUT		PUT PUT		PUT PUT		PUT PUT	
F HRS		MWE MWE		MWE MWE		MWE MWE		MWE MWE		MWE MWE		MWE MWE		MWE MWE		MWE MWF		MWE MWE	
102	2	60.41	37.67	60.37	40.21	60.29	41.47	60.21	45.27	60.21	45.27	60.21	45.27	60.21	45.32	60.12	45.27	60.12	45.27
97	28	67.20	44.87	66.26	46.10	64.87	46.05	66.10	47.77	65.20	47.46	64.66	47.32	64.24	47.24	63.85	47.13	61.12	46.27
92	117	67.20	45.20	67.20	47.71	67.20	48.84	67.20	49.41	67.20	49.75	67.20	49.90	66.74	49.75	66.26	49.55	65.86	49.33
87	297	67.20	46.90	67.20	47.85	67.20	49.18	67.20	49.72	67.20	50.18	67.20	50.45	67.19	50.69	67.17	50.84	67.16	50.89
82	544	69.55	49.76	67.20	48.86	67.20	49.26	67.20	49.82	67.20	50.35	67.20	50.67	67.20	50.98	67.20	51.21	67.20	51.30
77	817	69.55	54.64	67.06	49.73	67.20	49.28	67.20	49.86	67.20	50.42	67.20	50.78	67.20	51.12	67.20	51.38	67.20	51.51
72	1128	69.55	56.26	69.55	52.39	67.20	50.28	67.20	49.88	67.20	50.45	67.20	50.83	67.20	51.19	67.20	51.47	67.20	51.61
67	1481	69.55	56.95	69.55	55.01	67.10	51.19	67.20	51.00	67.20	50.47	67.20	50.85	67.20	51.23	67.20	51.52	67.20	51.68
62	1904	69.55	57.30	69.55	56.18	69.55	53.73	67.20	51.30	67.20	50.79	67.20	50.87	67.20	51.25	67.20	51.55	67.20	51.72
57	2417	69.55	57.49	69.55	56.79	69.55	55.37	67.14	52.08	67.20	51.60	67.20	50.87	67.20	51.26	67.20	51.47	67.20	51.74
52	3043	69.55	57.61	69.55	57.14	69.55	56.24	69.55	54.55	67.20	52.06	67.20	51.99	67.20	51.27	67.20	51.58	67.20	51.76
47	3717	69.55	57.66	69.55	57.35	69.55	56.75	69.55	55.66	66.95	52.48	67.20	52.00	67.20	52.34	67.20	51.49	67.20	51.77
42	4376	69.55	57.73	69.55	57.49	69.55	57.06	69.55	56.33	69.37	54.90	67.20	52.60	67.20	52.35	67.20	51.59	67.20	51.77
37	4991	69.55	57.77	69.55	57.58	69.55	57.27	69.55	56.75	69.55	55.84	66.96	52.89	67.20	52.55	67.20	52.62	67.20	51.78
32	5537	69.55	57.79	69.55	57.65	69.55	57.41	69.55	57.03	69.55	56.39	69.33	55.26	67.20	52.98	67.20	52.63	67.20	52.80
27	5929	69.55	57.81	69.55	57.70	69.55	57.52	69.55	57.23	69.55	56.75	69.55	56.05	66.97	53.21	67.20	52.90	67.20	52.81
22	6217	69.55	57.82	69.55	57.73	69.55	57.59	69.55	57.36	69.55	57.00	69.55	56.48	69.28	55.51	67.20	53.32	67.20	52.81
17	6384	69.55	57.83	69.55	57.76	69.55	57.64	69.55	57.47	69.55	57.19	69.55	56.79	69.55	56.22	66.99	53.46	67.20	53.24
12	6459	69.55	57.84	69.55	57.78	69.55	57.69	69.55	57.54	69.55	57.32	69.55	57.01	69.55	56.57	69.23	55.69	67.20	53.54
7	6486	69.55	57.85	69.55	57.80	69.55	57.72	69.55	57.60	69.55	57.42	69.55	57.18	69.55	56.84	69.55	56.36	66.94	53.60
2	6497	69.55	57.85	69.55	57.81	69.55	57.74	69.55	57.65	69.55	57.50	69.55	57.30	69.55	57.03	69.55	56.66	69.19	55.84
-3	6500	69.55	57.86	69.55	57.82	69.55	57.77	69.55	57.68	69.55	57.56	69.55	57.40	69.55	57.18	69.55	56.88	69.55	56.48
-8	6501	69.55	57.86	69.55	57.83	69.55	57.78	69.55	57.71	69.55	57.61	69.55	57.48	69.55	57.30	69.55	57.05	69.55	56.73

MECHANICAL DRAFT DRY/WET-PEAKING COOLING TOWER SYSTEM ECONOMIC OPTIMIZATION AND EVALUATION
ANNUAL PLANT GENERATING PROFILE

THE FOLLOWING RESULTS ARE THE SAME AS ON PREVIOUS PRINTOUTS EXCEPT FOR THE FOLLOWING ITD(S): 60 70 80 100

		20.0	30.0	40.0	50.0	60.0	70.0	80.0	90.0	100.0							
DRY TWR ITD-F		20.0	30.0	40.0	50.0	60.0	70.0	80.0	90.0	100.0							
WET TWR RNG-F		22.0	22.0	23.0	23.0	24.0	25.0	25.0	25.0	27.0							
WET TWR APP-F		21.0	21.0	20.0	20.0	19.0	18.0	18.0	18.0	16.0							
AMB DRY- BULB TEMP F	HRS EQUALLED OR EXCEEDED HRS	GROSS		GROSS		GROSS		GROSS		GROSS		GROSS		GROSS		GROSS	
		T-G	NET	T-G	NET	T-G	NET	T-G	NET	T-G	NET	T-G	NET	T-G	NET	T-G	NET
		PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT	PLANT
		OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-	OUT-
		PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT	PUT
		MWE	MWE	MWE	MWE	MWE	MWE	MWE	MWE	MWE	MWE	MWE	MWE	MWF	MWE	MWE	MWE
102	2	60.41	37.67	60.37	40.21	60.29	41.47	60.21	45.27	60.21	45.32	60.12	45.27	60.12	45.27	60.04	45.23
97	28	67.20	44.87	66.26	46.10	64.87	46.05	66.10	47.77	65.25	47.55	64.70	47.45	64.28	47.33	63.85	47.13
92	117	67.20	45.20	67.20	47.71	67.20	48.84	67.20	49.41	67.20	49.84	67.20	50.02	66.78	49.82	66.26	49.55
87	297	67.20	46.90	67.20	47.85	67.20	49.18	67.20	49.72	67.20	50.28	67.20	50.63	67.19	50.78	67.17	50.84
82	544	69.55	49.76	67.20	48.86	67.20	49.26	67.20	49.82	67.20	50.44	67.20	50.86	67.20	51.07	67.20	51.21
77	817	69.55	54.64	67.06	49.73	67.20	49.28	67.20	49.86	67.20	50.52	67.20	50.96	67.20	51.21	67.20	51.38
72	1128	69.55	56.26	69.55	52.39	67.20	50.28	67.20	49.88	67.20	50.55	67.20	51.01	67.20	51.28	67.20	51.47
67	1481	69.55	56.95	69.55	55.01	67.10	51.19	67.20	51.00	67.20	50.56	67.20	51.03	67.20	51.31	67.20	51.52
62	1904	69.55	57.30	69.55	56.18	69.55	53.73	67.20	51.30	67.20	50.87	67.20	51.05	67.20	51.33	67.20	51.55
57	2417	69.55	57.49	69.55	56.79	69.55	55.37	67.14	52.08	67.20	51.65	67.20	51.05	67.20	51.35	67.20	51.57
52	3043	69.55	57.61	69.55	57.14	69.55	56.24	69.55	54.55	67.20	52.09	67.20	52.08	67.20	51.35	67.20	51.58
47	3717	69.55	57.68	69.55	57.35	69.55	56.75	69.55	55.66	66.95	52.48	67.20	52.09	67.20	52.38	67.20	51.59
42	4376	69.55	57.73	69.55	57.49	69.55	57.06	69.55	56.33	69.37	54.90	67.20	52.64	67.20	52.39	67.20	51.59
37	4991	69.55	57.77	69.55	57.58	69.55	57.27	69.55	56.75	69.55	55.84	66.96	52.89	67.20	52.59	67.20	52.62
32	5537	69.55	57.79	69.55	57.65	69.55	57.41	69.55	57.03	69.55	56.39	69.33	55.26	67.20	53.02	67.20	52.63
27	5929	69.55	57.81	69.55	57.70	69.55	57.52	69.55	57.23	69.55	56.75	69.55	56.05	66.97	53.21	67.20	52.90
22	6217	69.55	57.82	69.55	57.73	69.55	57.59	69.55	57.36	69.55	57.00	69.55	56.48	69.28	55.51	67.20	53.32
17	6384	69.55	57.83	69.55	57.76	69.55	57.64	69.55	57.47	69.55	57.19	69.55	56.79	69.55	56.22	66.99	53.46
12	6459	69.55	57.84	69.55	57.78	69.55	57.69	69.55	57.54	69.55	57.32	69.55	57.01	69.55	56.57	69.23	55.69
7	6486	69.55	57.85	69.55	57.80	69.55	57.72	69.55	57.60	69.55	57.42	69.55	57.18	69.55	56.84	69.55	56.36
2	6497	69.55	57.85	69.55	57.81	69.55	57.74	69.55	57.65	69.55	57.50	69.55	57.30	69.55	57.03	69.55	56.66
-3	6500	69.55	57.86	69.55	57.82	69.55	57.77	69.55	57.68	69.55	57.56	69.55	57.40	69.55	57.18	69.55	56.88
-8	6501	69.55	57.86	69.55	57.83	69.55	57.78	69.55	57.71	69.55	57.61	69.55	57.48	69.55	57.30	69.55	57.05

APPENDIX F

SUMMARY OF ANALYSIS OF EVAPORATIVE
COOLING SYSTEMS

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
 FOR BASIN & RANGE CLIMATE - 150 C (300 F) RESOURCE
 15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/106 Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	31.6/20	16.4	3.5	24.6	0.3	44.8	3154
		100	31.6/20	16.4	3.5	24.6	3.2	47.7	3154
		250	31.6/20	16.4	3.5	24.6	8.0	52.5	3154
	100	10	31.6/20	16.4	3.5	49.2	0.3	69.4	3154
		100	31.6/20	16.4	3.5	49.2	3.2	72.3	3154
		250	31.6/20	16.4	3.5	49.2	8.0	77.1	3154
Binary	50	10	21.5/13	13.4	5.4	34.9	0.3	54.0	2976
		100	21.5/13	13.4	5.4	34.9	2.9	56.6	2976
		250	21.5/13	13.4	5.4	34.9	7.4	61.1	2976
	100	10	22.5/12	13.4	5.5	69.6	0.3	88.8	2978
		100	22.5/12	13.4	5.5	69.6	3.0	91.5	2978
		250	22.5/12	13.4	5.5	69.6	7.4	95.9	2978

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR BASIN & RANGE CLIMATE - 182 C (360 F) RESOURCE
15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/10⁶ Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	26.1/20	13.9	2.9	16.4	0.3	33.5	2502
		100	28.1/18	13.9	3.0	16.4	2.3	35.6	2495
		250	28.1/18	13.9	3.0	16.4	5.8	39.1	2495
	100	10	28.1/18	13.9	3.0	32.8	0.2	49.9	2495
		100	28.1/18	13.9	3.0	32.8	2.3	52.0	2495
		250	28.1/18	13.9	3.0	32.8	5.8	55.5	2495
Binary	50	10	22.8/16	11.3	4.4	15.2	0.3	31.2	2931
		100	22.8/16	11.3	4.4	15.2	2.8	33.7	2931
		250	23.8/15	11.3	4.4	15.2	6.9	37.8	2930
	100	10	24.8/14	11.3	4.5	30.3	0.3	46.4	2931
		100	24.8/14	11.3	4.5	30.4	2.7	48.9	2931
		250	24.8/14	11.3	4.5	30.4	6.8	53.0	2931

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR BASIN & RANGE CLIMATE - 246 C (475 F) RESOURCE
15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost ¢/10⁶Btu</u>	<u>Makeup Water Cost ¢/Kgal</u>	<u>Optimum Cooling Tower Range/ Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	26.1/20	12.2	2.3	11.5	0.2	26.2	1948
		100	28.1/18	12.2	2.3	11.5	1.8	27.8	1941
		250	28.1/18	12.2	2.3	11.5	4.5	30.5	1941
	100	10	28.1/18	12.1	2.3	23.1	0.2	37.7	1941
		100	28.1/18	12.1	2.3	23.1	1.8	39.3	1941
		250	28.1/18	12.1	2.3	23.1	4.5	42.0	1941
Binary	50	10	22.8/16	9.6	4.3	14.8	0.3	29.0	2931
		100	22.8/16	9.6	4.3	14.8	2.7	31.4	2931
		250	22.8/16	9.6	4.3	14.8	6.8	35.5	2931
	100	10	23.8/15	9.6	4.4	29.4	0.3	43.7	2930
		100	23.8/15	9.6	4.4	29.4	2.7	46.1	2930
		250	24.8/14	9.6	4.5	29.4	6.7	50.2	2931

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR HIGH MOUNTAIN CLIMATE - 150 C (300 F) RESOURCE
15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/10⁶ Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	31.6/21	16.5	3.4	24.6	0.3	44.8	3244
		100	31.6/21	16.5	3.4	24.5	3.3	47.7	3244
		250	31.6/21	16.5	3.4	24.6	8.2	52.7	3244
	100	10	31.6/21	16.5	3.4	49.1	.3	69.3	3244
		100	31.6/21	16.5	3.4	49.1	3.3	72.3	3244
		250	31.6/21	16.5	3.4	49.1	8.2	77.2	3244
Binary	50	10	21.5/14	13.4	5.2	34.8	0.3	53.7	3037
		100	22.5/13	13.4	5.3	34.7	3.0	56.4	3037
		250	22.5/13	13.4	5.3	34.7	7.5	60.9	3037
	100	10	* 23.5/12	13.3	5.4	69.4	0.3	88.4	3038
		100	23.5/12	13.3	5.4	69.4	3.0	91.1	3038
		250	23.5/12	13.3	5.4	69.4	7.5	95.6	3038

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR HIGH MOUNTAIN CLIMATE - 182 C (360 F) RESOURCE
15% PCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost ¢/10⁶ Btu</u>	<u>Makeup Water Cost ¢/Kgal</u>	<u>Optimum Cooling Tower Range/ Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	27.1/20	13.9	2.9	16.4	0.2	33.4	2569
		100	27.1/20	13.9	2.9	16.4	2.4	35.6	2569
		250	29.1/18	13.9	2.9	16.4	6.0	39.2	2561
	100	10	29.1/18	13.9	3.0	32.7	0.2	49.8	2561
		100	29.1/18	13.9	2.9	32.7	2.4	51.9	2561
		250	29.1/18	13.9	2.9	32.7	6.0	55.5	2561
Binary	50	10	23.8/16	11.3	4.3	15.2	0.3	31.1	3003
		100	23.8/16	11.3	4.3	15.2	2.8	33.6	3003
		250	23.8/16	11.3	4.3	15.2	7.0	37.8	3003
	100	10	24.8/15	11.3	4.3	30.3	0.3	46.2	3003
		100	24.8/15	11.3	4.3	30.3	2.8	48.8	3003
		250	25.8/14	11.2	4.5	30.2	7.0	52.9	3004

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR HIGH MOUNTAIN CLIMATE - 246 C (475 F) RESOURCE
15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/106 Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/ Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>	
Flash	50	10	27.1/20	12.2	2.3	11.5	0.2	26.2	1999	
		100	27.1/20	12.2	2.3	11.5	1.8	27.8	1999	
		250	29.1/18	12.2	2.3	11.5	4.6	30.6	1993	
	100	10	29.1/18	12.2	2.3	23.0	0.2	37.7	1993	
		100	29.1/18	12.2	2.3	23.0	1.8	39.3	1993	
		250	29.1/18	12.2	2.3	23.0	4.6	42.1	1993	
	Binary	50	10	23.8/16	9.6	4.3	14.7	0.3	28.9	3003
			100	23.8/16	9.6	4.3	14.7	2.7	31.3	3003
			250	23.8/16	9.6	4.3	14.7	6.9	35.5	3003
100		10	23.8/16	9.6	4.3	29.4	0.3	43.6	3003	
		100	23.8/16	9.6	4.3	29.4	2.7	46.0	3003	
		250	24.8/15	9.6	4.3	29.4	6.9	50.2	3003	

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
 FOR HOT DESERT CLIMATE - 150 C (300 F) RESOURCE
 15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost ¢/10⁶Btu</u>	<u>Makeup Water Cost ¢/Kgal</u>	<u>Optimum Cooling Tower Range/ Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	26.4/12	16.7	3.8	24.9	0.4	45.8	3447
		100	26.4/12	16.7	3.8	24.9	3.6	49.0	3447
		250	26.4/12	16.7	3.9	24.9	8.9	54.4	3447
	100	10	26.4/12	16.7	3.8	49.9	0.4	70.8	3447
		100	26.4/12	16.7	3.8	49.9	3.6	74.0	3447
		250	26.4/12	16.7	3.8	49.9	8.9	79.3	3447
Binary	50	10	12.8/8	14.0	6.7	36.5	0.3	57.5	3397
		100	12.8/8	14.0	6.7	36.4	3.5	60.6	3397
		250	12.8/8	14.0	6.7	36.4	8.8	65.9	3397
	100	10	12.8/8	14.0	6.7	72.9	0.3	93.9	3397
		100	12.8/8	14.0	6.7	72.9	3.5	97.1	3397
		250	12.8/8	13.9	6.7	72.9	8.8	102.3	3397

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
 FOR HOT DESERT CLIMATE - 182 C (360 F) RESOURCE
 15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/10⁶ Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	21.6/12	14.1	3.3	16.6	0.3	34.3	2773
		100	21.6/12	14.1	3.3	16.7	2.6	36.7	2773
		250	21.6/12	14.1	3.3	16.6	6.6	40.6	2773
	100	10	21.6/12	14.1	3.3	33.3	0.3	51.0	2773
		100	22.6/11	14.1	3.3	33.3	2.6	53.3	2775
		250	22.6/11	14.1	3.3	33.3	6.6	57.3	2775
Binary	50	10	17.0/8	11.6	5.5	15.6	0.3	33.0	3355
		100	17.0/8	11.6	5.5	15.6	3.2	35.9	3355
		250	17.0/8	11.6	5.5	15.6	8.0	40.7	3355
	100	10	17.0/8	11.6	5.5	31.2	0.3	48.6	3355
		100	17.0/8	11.6	5.5	31.2	3.2	51.5	3355
		250	17.0/8	11.6	5.5	31.2	8.1	56.4	3355

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
 FOR HOT DESERT CLIMATE - 246 C (475 F) RESOURCE
 15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/10⁶ Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/ Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>	
Flash	50	10	26.4/12	12.4	2.3	11.8	0.2	26.7	2135	
		100	26.4/12	12.4	2.3	11.8	2.0	28.5	2135	
		250	26.4/12	12.4	2.3	11.8	5.0	31.5	2135	
	100	10	26.4/12	12.4	2.3	23.6	0.2	38.5	2135	
		100	26.4/12	12.4	2.3	23.6	2.0	40.3	2135	
		250	26.4/12	12.4	2.3	23.6	5.0	43.3	2135	
	Binary	50	10	17.0/8	9.9	5.4	15.1	0.3	30.7	3355
			100	17.0/8	9.9	5.3	15.1	3.2	33.5	3355
			250	17.0/8	9.9	5.4	15.1	7.9	38.3	3355
100		10	17.0/8	9.9	5.3	30.2	0.3	45.7	3355	
		100	17.0/8	9.9	5.3	30.2	3.2	48.6	3355	
		250	17.0/8	9.9	5.3	30.2	7.9	53.3	3355	

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR PACIFIC NORTHWEST CLIMATE - 150 C (300 F) RESOURCE
15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/10⁶ Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	27.6/18	16.6	3.6	24.7	0.3	45.2	3094
		100	27.6/18	16.5	3.6	24.7	3.2	48.0	3094
		250	29.6/16	16.5	3.7	24.6	7.9	52.7	3083
	100	10	28.6/17	16.5	3.7	49.3	0.3	69.8	3088
		100	29.6/16	16.5	3.7	49.3	3.1	72.6	3083
		250	29.6/16	16.5	3.7	49.3	7.9	77.4	3083
Binary	50	10	16.5/12	13.6	5.8	35.2	0.3	54.9	2911
		100	16.5/12	13.6	5.8	35.3	2.9	57.6	2911
		250	16.5/12	13.6	5.8	35.3	7.3	62.0	2911
	100	10	16.5/12	13.6	5.8	70.5	0.3	90.2	2911
		100	16.5/12	13.6	5.8	70.5	2.9	92.8	2911
		250	16.5/12	13.6	5.8	70.5	7.3	97.2	2911

F-10

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR PACIFIC NORTHWEST CLIMATE - 182 C (360 F) RESOURCE
15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost c/10⁶Btu</u>	<u>Makeup Water Cost c/Kgal</u>	<u>Optimum Cooling Tower Range/Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>	
Flash	50	10	29.6/16	14.1	2.9	16.5	0.2	33.7	2455	
		100	29.6/16	14.1	2.9	16.5	2.3	35.8	2455	
		250	29.6/16	14.1	2.9	16.5	5.8	39.3	2455	
	100	10	29.6/16	14.1	2.8	33.1	0.2	50.2	2455	
		100	29.6/16	14.1	2.8	33.1	2.3	52.3	2455	
		250	31.6/14	14.1	2.9	33.0	5.8	55.8	2447	
	Binary	50	10	20.8/12	11.3	4.8	15.2	0.3	31.6	2871
			100	20.8/12	11.3	4.9	15.2	2.7	34.1	2871
			250	20.8/12	11.3	4.9	15.2	6.7	38.1	2871
100		10	20.8/12	11.3	4.9	30.4	0.3	46.9	2871	
		100	20.8/12	11.3	4.9	30.4	2.7	49.3	2871	
		250	20.8/12	11.3	4.9	30.4	6.7	53.3	2871	

SUMMARY OF ANALYSIS OF EVAPORATIVE COOLING SYSTEMS
FOR PACIFIC NORTHWEST CLIMATE - 246 C (475 F) RESOURCE
15% FCR

<u>Geothermal Conversion Process</u>	<u>Geothermal "Fuel" Cost ¢/10⁶ Btu</u>	<u>Makeup Water Cost ¢/Kgal</u>	<u>Optimum Cooling Tower Range/ Approach, °F</u>	<u>Conversion Plant Capital + OM mills/kWh</u>	<u>Cooling System Capital + OM mills/kWh</u>	<u>Geothermal "Fuel" + OM mills/kWh</u>	<u>Makeup Water + OM mills/kWh</u>	<u>Total Busbar Energy Cost mills/kWh</u>	<u>Annual Makeup acre-feet</u>
Flash	50	10	27.6/18	12.3	2.2	11.6	0.2	26.3	1915
		100	29.6/16	12.3	2.2	11.6	1.8	27.9	1909
		250	29.6/16	12.3	2.3	11.6	4.4	30.6	1909
	100	10	29.6/16	12.3	2.2	23.3	0.2	38.0	1909
		100	29.6/16	12.3	2.2	23.3	1.8	39.6	1909
		250	30.6/15	12.2	2.3	23.3	4.4	42.2	1905
Binary	50	10	19.8/13	9.6	4.7	14.8	0.3	29.4	2873
		100	19.8/13	9.6	4.7	14.8	2.7	31.8	2873
		250	20.8/12	9.6	4.8	14.8	6.6	35.8	2871
	100	10	20.8/12	9.6	4.8	29.5	0.3	44.2	2871
		100	20.8/12	9.6	4.8	29.5	2.7	46.6	2871
		250	20.8/12	9.6	4.8	29.5	6.6	50.5	2871

APPENDIX G

BUSBAR ENERGY PRODUCTION COST MULTIPLIERS
FOR BINARY AND FLASH STEAM SYSTEMS WITH
DRY/WET PEAKING COOLING TOWERS

Busbar Energy Production Cost Multipliers for Binary Systems with
Dry/Wet Peaking Cooling Towers for Basin and Range Site

\$.50/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
3.75	2.20	2.20	2.21	1.48	1.48	1.49	1.40	1.41	1.41
6.65	2.04	2.05	2.06	1.32	1.32	1.33	1.24	1.25	1.26
10.68	1.97	1.98	1.98	1.24	1.25	1.26	1.17	1.18	1.19
15.69	1.95	1.96	1.98	1.20	1.22	1.24	1.13	1.14	1.16
22.21	1.93	1.95	1.99	1.18	1.20	1.23	1.11	1.12	1.15
29.65	1.93	1.96	1.10	1.17	1.19	1.23	1.09	1.11	1.15
37.36	1.92	1.96	2.01	1.15	1.18	1.23	1.08	1.11	1.15
44.46	1.91	1.95	2.02	1.14	1.18	1.23	1.06	1.10	1.16
50.46	1.90	1.95	2.02	1.13	1.17	1.24	1.05	1.09	1.16

\$1.00/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
3.75	3.27	3.27	3.27	1.94	1.94	1.94	1.85	1.85	1.86
6.65	3.13	3.13	3.14	1.78	1.79	1.80	1.70	1.70	1.71
10.68	3.07	3.08	3.07	1.71	1.72	1.73	1.63	1.64	1.65
15.69	3.07	3.08	3.10	1.68	1.70	1.71	1.60	1.61	1.63
22.21	3.07	3.09	3.12	1.66	1.68	1.71	1.58	1.59	1.62
29.65	3.08	3.11	3.15	1.65	1.68	1.72	1.56	1.59	1.63
37.36	3.07	3.12	3.17	1.64	1.67	1.72	1.55	1.58	1.63
44.46	3.08	3.12	3.18	1.63	1.67	1.73	1.54	1.58	1.63
50.46	3.07	3.11	3.19	1.62	1.66	1.73	1.53	1.57	1.63

Busbar Energy Production Cost Multipliers for Flash Steam Systems
With Dry/Wet Peaking Cooling Towers for Basin and Range Site

\$.50/10⁶ Btu

300° F				360° F				475° F			
% Water	\$.10	\$1.00	\$2.50	% Water	\$.10	\$1.00	\$2.50	% Water	\$.10	\$1.00	\$2.50
2.25	1.93	1.94	1.94	2.84	1.43	1.44	1.44	3.66	1.12	1.12	1.13
3.74	1.74	1.74	1.75	4.73	1.29	1.29	1.30	6.08	1.01	1.01	1.02
6.28	1.65	1.66	1.67	7.93	1.22	1.23	1.23	10.20	0.96	0.96	0.97
9.73	1.60	1.61	1.62	12.30	1.78	1.19	1.20	15.81	0.92	0.93	0.93
14.24	1.56	1.57	1.60	17.99	1.15	1.16	1.18	23.12	0.90	0.91	0.92
19.66	1.54	1.57	1.60	24.84	1.14	1.16	1.18	31.93	0.90	0.90	0.92
25.65	1.53	1.55	1.60	32.41	1.13	1.15	1.18	41.66	0.88	0.90	0.92
31.45	1.51	1.54	1.60	39.74	1.12	1.14	1.18	51.08	0.87	0.89	0.92
36.56	1.49	1.53	1.60	46.19	1.11	1.13	1.18	59.37	0.86	0.89	0.92

\$1.00/10⁶ Btu

300° F				360° F				475° F			
% Water	\$.10	\$1.00	\$2.50	% Water	\$.10	\$1.00	\$2.50	% Water	\$.10	\$1.00	\$2.50
2.25	2.65	2.65	2.65	2.84	1.91	1.91	1.92	3.66	1.46	1.46	1.46
3.74	2.46	2.46	2.47	4.73	1.77	1.77	1.78	6.08	1.35	1.35	1.36
6.28	2.37	2.38	2.39	7.93	1.70	1.71	1.72	10.20	1.30	1.30	1.31
9.73	2.33	2.34	2.35	12.30	1.66	1.67	1.68	15.81	1.26	1.27	1.28
14.24	2.29	2.31	2.33	17.99	1.64	1.65	1.67	23.12	1.24	1.25	1.27
19.66	2.28	2.30	2.33	24.84	1.63	1.65	1.67	31.93	1.24	1.25	1.27
25.65	2.26	2.29	2.34	32.41	1.62	1.64	1.67	41.66	1.23	1.24	1.27
31.45	2.25	2.28	2.34	39.74	1.61	1.63	1.67	51.08	1.22	1.24	1.27
36.56	2.23	2.27	2.34	46.17	1.60	1.63	1.68	59.37	1.21	1.23	1.27

Busbar Energy Production Cost Multipliers for Binary Systems
with Dry/Wet Peaking Cooling Towers for High Mountain Site

\$.50/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
2.56	2.20	2.21	2.21	1.48	1.48	1.49	1.39	1.40	1.40
3.46	2.03	2.04	2.04	1.32	1.32	1.32	1.23	1.24	1.24
6.23	1.97	1.98	1.98	1.24	1.25	1.25	1.16	1.17	1.17
11.49	1.94	1.95	1.97	1.20	1.21	1.23	1.13	1.14	1.15
18.41	1.93	1.95	1.97	1.18	1.20	1.22	1.11	1.12	1.14
25.74	1.93	1.95	1.98	1.16	1.18	1.22	1.10	1.12	1.15
33.47	1.92	1.95	2.00	1.15	1.18	1.22	1.09	1.11	1.16
40.79	1.91	1.95	2.00	1.14	1.17	1.23	1.08	1.11	1.16
47.09	1.91	1.95	2.02	1.13	1.17	1.24	1.07	1.11	1.17

\$1.00/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
2.56	3.27	3.27	3.27	1.94	1.94	1.95	1.84	1.84	1.85
3.46	3.11	3.12	3.12	1.78	1.78	1.79	1.69	1.69	1.69
6.23	3.07	3.07	3.08	1.71	1.72	1.72	1.62	1.63	1.63
11.49	3.06	3.07	3.08	1.68	1.69	1.70	1.59	1.60	1.61
18.41	3.07	3.08	3.11	1.66	1.69	1.70	1.58	1.60	1.62
25.74	3.07	3.10	3.13	1.65	1.67	1.71	1.58	1.59	1.62
33.47	3.08	3.11	3.16	1.64	1.67	1.71	1.57	1.60	1.64
40.79	3.07	3.11	3.17	1.63	1.66	1.72	1.56	1.60	1.65
47.09	3.07	3.11	3.18	1.63	1.66	1.73	1.55	1.59	1.65

Busbar Energy Production Cost Multipliers for Flash Steam Systems
With Dry/Wet Peaking Cooling Towers For High Mountain Site

\$.50/10⁶ Btu

300° F				360° F				475° F			
<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
1.88	1.95	1.95	1.95	2.38	1.45	1.45	1.45	3.06	1.13	1.14	1.14
2.22	1.75	1.75	1.76	2.81	1.30	1.30	1.30	3.61	1.02	1.02	1.02
3.45	1.65	1.66	1.66	4.37	1.22	1.22	1.23	5.61	0.96	0.96	0.96
6.57	1.60	1.60	1.61	8.31	1.78	1.18	1.19	10.68	0.92	0.93	0.93
11.44	1.56	1.57	1.59	14.47	1.15	1.16	1.17	18.60	0.90	0.91	0.92
16.89	1.53	1.55	1.58	21.37	1.13	1.14	1.17	27.47	0.89	0.90	0.91
22.75	1.51	1.53	1.58	28.78	1.12	1.14	1.17	36.99	0.87	0.89	0.91
28.64	1.49	1.53	1.58	36.23	1.11	1.13	1.17	46.57	0.87	0.88	0.91
33.91	1.48	1.52	1.58	42.90	1.10	1.12	1.17	55.14	0.86	0.88	0.91

\$1.00/10⁶ Btu

300° F				360° F				475° F			
<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
1.88	2.65	2.65	2.65	2.38	1.92	1.92	1.92	3.06	1.47	1.47	1.47
2.22	2.46	2.46	2.47	2.81	1.77	1.77	1.78	3.61	1.35	1.35	1.36
3.45	2.37	2.37	2.38	4.37	1.70	1.70	1.71	5.61	1.30	1.30	1.30
6.57	2.32	2.32	2.34	8.31	1.66	1.66	1.67	10.68	1.26	1.27	1.27
11.44	2.28	2.29	2.32	14.47	1.63	1.64	1.66	18.60	1.24	1.25	1.26
16.89	2.26	2.28	2.31	21.37	1.62	1.63	1.65	27.47	1.23	1.24	1.26
22.75	2.24	2.26	2.30	28.78	1.60	1.62	1.65	36.99	1.22	1.23	1.25
28.64	2.22	2.26	2.31	36.23	1.59	1.61	1.66	46.57	1.21	1.23	1.26
33.91	2.21	2.25	2.31	42.90	1.58	1.61	1.66	55.14	1.20	1.22	1.26

Busbar Energy Production Cost Multipliers for Binary Systems
With Dry/Wet Peaking Cooling Towers For Hot Desert Site

\$.50/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
12.70	2.29	2.30	2.23	1.52	1.53	1.55	1.44	1.45	1.46
20.75	2.14	2.17	2.21	1.37	1.39	1.42	1.29	1.31	1.33
29.93	2.08	2.11	2.17	1.30	1.33	1.40	1.22	1.24	1.28
39.17	2.04	2.08	2.15	1.26	1.29	1.35	1.18	1.21	1.27
47.51	2.01	2.06	2.14	1.23	1.27	1.35	1.16	1.20	1.26
54.66	1.98	2.04	2.14	1.21	1.26	1.34	1.13	1.18	1.26
60.45	1.96	2.02	2.13	1.18	1.24	1.33	1.11	1.16	1.25
64.59	1.94	2.01	2.12	1.17	1.23	1.33	1.09	1.15	1.25
68.76	1.93	2.00	2.11	1.16	1.22	1.32	1.08	1.14	1.24

\$1.00/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
12.70	3.38	3.40	3.42	1.99	1.99	2.02	1.89	1.90	1.92
20.75	3.26	3.29	3.33	1.85	1.87	1.90	1.75	1.77	1.79
29.93	3.22	3.25	3.31	1.79	1.81	1.86	1.69	1.71	1.75
39.17	3.19	3.23	3.30	1.75	1.79	1.81	1.66	1.69	1.74
47.51	3.17	3.22	3.30	1.72	1.76	1.84	1.64	1.67	1.74
54.66	3.14	3.20	3.30	1.70	1.75	1.83	1.62	1.65	1.73
60.45	3.12	3.18	3.29	1.67	1.73	1.82	1.59	1.64	1.73
64.59	3.10	3.17	3.28	1.66	1.72	1.82	1.57	1.63	1.72
68.76	3.09	3.15	3.27	1.64	1.71	1.81	1.56	1.62	1.71

Busbar Energy Production Cost Multipliers for Flash Steam Systems
With Wet/Dry Peaking Cooling Towers For Hot Desert Site

\$.50/10⁶ Btu

300° F				360° F				475° F			
<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
4.29	2.00	2.01	2.02	5.34	1.48	1.48	1.49	6.93	1.14	1.15	1.15
8.47	1.79	1.80	1.82	10.53	1.32	1.33	1.34	13.68	1.05	1.03	1.04
14.47	1.68	1.70	1.73	17.99	1.24	1.26	1.28	23.37	0.96	0.97	0.99
21.09	1.62	1.64	1.68	26.21	1.20	1.22	1.25	34.05	0.93	0.94	0.97
28.02	1.58	1.61	1.67	34.82	1.17	1.20	1.24	45.25	0.91	0.93	0.96
34.67	1.55	1.59	1.66	43.08	1.15	1.18	1.97	55.97	0.90	0.92	0.96
40.35	1.52	1.57	1.65	50.14	1.13	1.17	1.23	65.15	0.88	0.91	0.96
45.05	1.51	1.56	1.65	55.98	1.13	1.17	1.23	72.74	0.87	0.90	0.95
48.68	1.49	1.55	1.64	60.49	1.11	1.16	1.23	75.78	0.87	0.90	0.95

\$1.00/10⁶ Btu

300° F				360° F				475° F			
<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
4.29	2.74	2.75	2.76	5.34	1.97	1.97	1.98	6.93	1.49	1.49	1.50
8.47	2.53	2.54	2.56	10.53	1.81	1.82	1.83	13.68	1.37	1.37	1.38
14.47	2.42	2.44	2.47	17.99	1.74	1.75	1.77	23.37	1.31	1.32	1.33
21.09	2.36	2.38	2.42	26.21	1.69	1.71	1.74	34.05	1.28	1.29	1.31
28.02	2.31	2.35	2.40	34.82	1.67	1.69	1.73	45.25	1.26	1.28	1.31
34.67	2.28	2.32	2.39	43.08	1.65	1.68	1.73	55.97	1.24	1.27	1.30
40.35	2.26	2.31	2.39	50.14	1.63	1.67	1.73	65.15	1.23	1.26	1.30
45.05	2.24	2.29	2.38	55.98	1.62	1.66	1.72	72.74	1.22	1.25	1.30
48.68	2.22	2.28	2.37	60.49	1.61	1.57	1.72	75.78	1.21	1.24	1.30

Busbar Energy Production Cost Multipliers for Binary Systems with
Dry/Wet Peaking Cooling Towers for Pacific Northwest Site

\$.50/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
4.18	2.18	2.23	2.19	1.46	1.46	1.47	1.38	1.39	1.40
6.86	2.02	2.03	2.04	1.30	1.31	1.32	1.23	1.24	1.25
10.69	1.96	1.97	1.98	1.23	1.24	1.25	1.16	1.17	1.18
16.20	1.94	1.96	1.98	1.20	1.21	1.23	1.13	1.14	1.16
23.65	1.94	1.96	1.99	1.18	1.20	1.23	1.11	1.13	1.16
32.32	1.94	1.97	2.01	1.17	1.19	1.24	1.09	1.12	1.16
40.86	1.93	1.96	2.02	1.15	1.19	1.24	1.08	1.11	1.16
47.96	1.92	1.96	2.02	1.14	1.18	1.24	1.07	1.10	1.16
53.71	1.90	1.95	2.02	1.13	1.17	1.17	1.05	1.10	1.16

\$1.00/10⁶ Btu

% Water	300° F			360° F			475° F		
	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
4.18	3.23	3.24	3.24	1.91	1.92	1.92	1.83	1.84	1.84
6.86	3.09	3.10	3.11	1.76	1.77	1.78	1.68	1.69	1.70
10.69	3.06	3.06	3.08	1.70	1.71	1.72	1.62	1.63	1.64
16.20	3.06	3.07	3.10	1.68	1.69	1.71	1.59	1.60	1.62
23.65	3.08	3.10	3.13	1.67	1.68	1.71	1.58	1.59	1.63
32.32	3.10	3.12	3.17	1.65	1.68	1.73	1.57	1.59	1.63
40.86	3.09	3.13	3.18	1.65	1.68	1.73	1.55	1.58	1.64
47.96	3.08	3.12	3.19	1.63	1.67	1.73	1.54	1.58	1.64
53.71	3.07	3.11	3.19	1.62	1.66	1.73	1.53	1.57	1.64

Busbar Energy Production Cost Multipliers for Flash Steam Systems
With Dry/Wet Peaking Cooling Towers for Pacific Northwest Site

\$.50/10⁶ Btu

300° F				360° F				475° F			
<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
2.04	1.88	1.88	1.89	2.57	1.40	1.40	1.40	3.30	1.10	1.10	1.10
2.66	1.71	1.71	1.71	3.34	1.27	1.27	1.27	4.30	0.99	0.99	1.00
4.18	1.63	1.63	1.64	5.26	1.20	1.21	1.21	6.76	0.94	0.94	0.95
6.71	1.58	1.58	1.60	8.44	1.17	1.17	1.18	10.84	0.91	0.92	0.92
10.54	1.54	1.55	1.57	13.24	1.15	1.15	1.17	17.02	0.89	0.90	0.91
15.76	1.52	1.53	1.56	19.80	1.13	1.15	1.17	25.46	0.88	0.89	0.91
22.15	1.52	1.53	1.57	27.83	1.13	1.14	1.17	35.78	0.88	0.89	0.91
28.71	1.50	1.53	1.58	36.06	1.12	1.15	1.19	46.36	0.88	0.89	0.92
34.32	1.49	1.52	1.58	43.11	1.12	1.14	1.19	55.42	0.87	0.89	0.92

\$1.00/10⁶ Btu

300° F				360° F				475° F			
<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>	<u>% Water</u>	<u>\$.10</u>	<u>\$1.00</u>	<u>\$2.50</u>
2.04	2.59	2.59	2.60	2.57	1.87	1.88	1.88	3.30	1.43	1.43	1.44
2.66	2.42	2.43	2.43	3.34	1.75	1.75	1.75	4.30	1.33	1.33	1.34
4.18	2.35	2.35	2.36	5.26	1.69	1.69	1.70	6.76	1.28	1.29	1.29
6.71	2.31	2.32	2.33	8.44	1.66	1.66	1.67	10.84	1.26	1.26	1.27
10.54	2.28	2.29	2.31	13.24	1.64	1.65	1.66	17.02	1.24	1.26	1.26
15.76	2.25	2.27	2.30	19.80	1.63	1.64	1.66	25.46	1.23	1.24	1.26
22.15	2.24	2.27	2.30	27.83	1.62	1.64	1.67	35.78	1.23	1.24	1.26
28.71	2.24	2.27	2.32	36.06	1.62	1.65	1.69	46.36	1.23	1.24	1.27
34.32	2.23	2.26	2.33	43.11	1.61	1.64	1.69	55.42	1.22	1.24	1.28