

SUMMARY COVER SHEET

CONTRIBUTED PAPER

INVITED PAPER

ORIGINAL AND THREE COPIES REQUIRED

TITLE: Nuclear Fuel Rod Response During LOFT Tests L2-2 and L2-3

AUTHOR(S): (List authors in the proper order and exactly as they are to be published. PLACE AN ASTERISK AFTER EACH AUTHOR WHO IS AN ANS MEMBER; AN "S" AFTER STUDENT AUTHOR.)

1. D. A. Niebruegge
2. E. L. Tolman
- 3.

AFFILIATION(S): (List corresponding author's affiliation and complete mailing address)

1. EG&G Idaho, Inc. P.O.Box 1625, Idaho Falls, ID 83401
2. Same as above
- 3.

MASTER

Indicate number of author to whom correspondence should be addressed 1 and complete page 4.

To whom should the page charge be billed? EG&G Idaho, Inc. P.O.Box 1625, Idaho Falls, ID 83401

Preferred: Attach purchase order with appropriate purchase order number to original copy of the summary.

FOR CONTRIBUTED SUMMARY:

Identify ANS Division or Technical Group having cognizance of your subject Nuclear Reactor Safety

In which subject category (from page 3) do you feel this summary belongs? 10.4.2

Alternative Category: 10.4.1

Has the substance of this summary been presented or published previously (including U.S. DOE or equivalent reports)?

YES (NO) Give details _____

Has the paper been submitted for publication in a technical journal?

YES (NO) Give details _____

Have you presented related papers?

(YES) NO Give details L2-2 Fuel Response presented at ANS Summer Meeting,

Has this summary been approved for publication by your institution or company?

(YES) NO Give details Patent Clearance obtained

Atlanta

FOR INVITED SUMMARY:

Which ANS Division or Technical Group invited you? _____

Person who invited you _____ Session No. _____

FOR CONTRIBUTED OR INVITED SUMMARY:

Number of: Pages 2 Tables 0 Figures 1

Word Count: Text 700 + (No. of figures plus tables) × 150 1 + (No. of lines of equations × 10) 0

Total 850

Original line drawings or glossy black-and-white print of each figure must be attached to original.

A COMPLETED SUMMARY COVER SHEET, TOGETHER WITH THE INFORMATION REQUESTED ON PAGE 4, MUST BE ATTACHED TO EACH OF THE FOUR SETS OF THE SUMMARY. Please have copies made to complete your four sets.

FILING AND MAILING INFORMATION

Name and full mailing address of author
to whom correspondence should be sent.
(Type or print legibly - form used for mailing.)

LOG # _____

D. A. Niebruegge
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, Idaho 83401

Telephone:
Commercial: (208) 526-9562
FTS: 583-9562

Title of Summary Nuclear Fuel Rod Response During LOFT Tests L2-2 and L2-3

This is to acknowledge receipt of your summary. Please use the log number above in future correspondence.

This summary will be considered for inclusion in the program of the American Nuclear Society's 1979 Winter Meeting, San Francisco, California, Nov. 11 - 16, 1979. Another copy of this form will be sent to you about July 23, 1979.

Your paper has been reviewed and:

- | | |
|---|---|
| <input type="checkbox"/> 1. Accepted for presentation at the 1979 Winter Meeting. (See Attached Instructions) | <input type="checkbox"/> 3. It is suggested that your summary be combined with the summary referenced as Log # _____ (See Attachment) |
| <input type="checkbox"/> 2. It is suggested that your summary be revised. (See Attachment) | <input type="checkbox"/> 4. Rejected. (See Attached Comments) |

Your paper is being returned without review because:

- | | |
|--|---|
| <input type="checkbox"/> 1. It was received after the deadline date. | <input type="checkbox"/> 2. It significantly exceeds the word limit of 900 words. |
|--|---|

In all correspondence regarding your summary, please refer to the Log Number shown above.

Thank you for submitting this summary.

Sincerely,

Neil Norman
ANS Technical Program Chairman
1979 Winter Meeting

NUCLEAR FUEL ROD RESPONSE DURING
LOFT TESTS L2-2 and L2-3

by

D. A. Niebruegge and E. L. Tolman

EG&G Idaho, Inc.

P.O. Box 1625

Idaho Falls, Idaho 83401

NOTICE
This report was prepared as a result of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of its agencies, makes any warranty, express or implied, or assumes any liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.

MASTER

Comparisons of the measured fuel rod peak cladding temperatures for the first two nuclear loss-of-coolant experiments (LOCE), LOCEs L2-2 and L2-3, are presented. These LOCEs were performed in the Loss-of-Fluid Test (LOFT) facility at the Idaho National Engineering Laboratory. The LOCEs provided a basis for evaluating the effect of initial power on the maximum cladding temperatures during a large break (200% guillotine) LOCE and identified important core thermal-hydraulic responses that influence the peak cladding temperatures.

The LOFT facility is providing data on the integral response of nuclear reactor systems to postulated loss-of-coolant accidents. The LOFT reactor has been scaled to model large pressurized water reactors (PWR). The LOFT core contains 1300 fuel rods pressurized to 0.10 MPa helium which are 1.676 m in length and have nominal commercial PWR fuel radial dimensions. LOCEs L2-2 and L2-3 were 200% cold leg break LOCEs and were conducted with a maximum linear heat generation rate of 26.2 and 39 kW/m, respectively. Nearly 200 thermocouples monitored fuel response.

Figure 1 presents typical fuel rod cladding thermocouple data at peak power locations from LOCEs L2-2 and L2-3. The differences in cladding temperature response can be attributed to the difference in steady state power and associated fuel rod stored energy and slight differences in the initial thermal-hydraulic conditions. The increased stored energy was the main factor resulting in the difference in

peak cladding temperature, 780 K versus 920 K. The difference in cladding temperature response following the 5-to-8-s cladding quench was due to a larger initial fuel stored energy in LOCE L2-3 which was sufficient to sustain the temperature rise until the emergency core coolant reflooded the core. The energy remaining in the fuel in LOCE L2-2 following the early quench was not sufficient to sustain a cladding temperature rise.

Comparison of the measured thermal-hydraulic data from the LOCEs show the cladding temperatures to be influenced by two major hydraulic phenomena which were nearly identical for each experiment. The first is related to the reestablishment of core flow after initial core flow stagnation. For both LOCEs, within milliseconds after the break, core flow stagnation occurred which eventually resulted in a boiling crisis and increased cladding temperatures from 1.0 to 1.5 s. At approximately 2.5 s, positive core flow was reestablished in both experiments which limited further cladding temperature increase. The limited cladding temperature increase at 2.5 s can be seen in Figure 1 for both experiments. The second important hydraulic effect is due to increased, lower quality flow through the reactor vessel between 6 to 8 s that resulted in cladding temperature quench. This is a result of flow redistribution through the reactor vessel when the inlet broken leg experienced saturated choking. This increased core flow resulted in a bottom-to-top quench of the cladding temperatures. The peak cladding temperatures during LOCE L2-3 generally took longer to quench, indicating that the cladding rewet characteristics are a function of temperature.

No fuel rod failure occurred in either LOCE. Comparison of measured cladding temperature and pressure loadings indicate the cladding to be within elastic limits. Based on zircaloy material property data, pressurized fuel rods would not have experienced ballooning in either experiment.

Analysis of results from LOCEs L2-2 and L2-3 led to the following conclusions:

- (1) Cladding thermal response is strongly coupled to core thermal hydraulics. The core thermal hydraulics were very similar during LOCEs L2-2 and L2-3, resulting in similar fuel rod response. The differences in cladding temperatures are due to differences in fuel rod power.
- (2) Resumption of a small positive core flow is sufficient to further limit post-departure from nucleate boiling cladding temperature rise.
- (3) Elevated cladding temperatures can be cooled and quenched during the blowdown phase of a LOCE.
- (4) The cladding temperatures and pressure loadings are not sufficiently severe to result in plastic deformation (collapse). For pressurized PWR fuel experiencing the LOCE L2-3 experimental conditions, cladding ballooning would not be expected.




Fig. 1 Typical fuel rod peak cladding temperatures from LOCEs L2-2 and L2-3.