

SUMMARY COVER SHEET

CONTRIBUTED PAPER

INVITED PAPER

ORIGINAL AND THREE COPIES REQUIRED

TITLE: Blowdown Hydraulic Influence on Core Thermal Response in LOFT Nuclear Experiment L2-3

AUTHOR(S): (List authors in the proper order and exactly as they are to be published. PLACE AN ASTERISK AFTER EACH AUTHOR WHO IS AN ANS MEMBER; AN "S" AFTER STUDENT AUTHOR.)

1. D. L. Reeder*

2.

3.

MASTER

AFFILIATION(S): (List corresponding author's affiliation and complete mailing address.)

1. EG&G Idaho, Inc., P. O. Box 1625, Idaho Falls, ID 83401

2.

3.

Indicate number of author to whom correspondence should be addressed 1, and complete page 4.

To whom should the page charge be billed? EG&G Idaho, Inc.

Preferred: Attach purchase order with appropriate purchase order number to original copy of the summary.

FOR CONTRIBUTED SUMMARY:

Identify ANS Division or Technical Group having cognizance of your subject Nuclear Reactor Safety

In which subject category (from page 3) do you feel this summary belongs? 10.4.2

Alternative Category: 10.4.1

Has the substance of this summary been presented or published previously (including U.S. DOE or equivalent reports)?

YES NO Give details _____

Has the paper been submitted for publication in a technical journal?

YES NO Give details _____

Have you presented related papers?

YES NO Give details _____

Has this summary been approved for publication by your institution or company?

YES NO Give details Patent Clearance applied for.

FOR INVITED SUMMARY:

Which ANS Division or Technical Group invited you? _____

Person who invited you _____ Session No. _____

FOR CONTRIBUTED OR INVITED SUMMARY:

Number of: Pages _____ Tables _____ Figures _____

Word Count: Text 723 (No. of figures plus tables) × 150 300 + (No. of lines of equations × 10) 0

Total 1023

Original line drawings or glossy black-and-white prints of each figure must be attached to original.

A COMPLETED SUMMARY COVER SHEET, TOGETHER WITH THE INFORMATION REQUESTED ON PAGE 4, MUST BE ATTACHED TO EACH OF THE FOUR SETS OF THE SUMMARY. Please have copies made to complete your four sets.



CALL FOR PAPERS

AMERICAN NUCLEAR SOCIETY

1979 WINTER MEETING

November 11 - 16, 1979
San Francisco, California

Members of the SOCIETY
are invited to submit
papers for presentation
at the 1979
Winter Meeting of the
American Nuclear Society
San Francisco, California
Nov. 11 - 16, 1979
and to sponsor papers
by nonmembers

General Information: Summaries of all contributed papers must be submitted to the Technical Program Chairman for review by the National Program Committee. Accepted papers are to be presented orally and the summaries will be published in the *Transactions of the American Nuclear Society*. Publication in *Transactions* does not preclude publication of the complete paper elsewhere. All accepted summaries become the property of the American Nuclear Society and, on acceptance, transfer of proprietary rights will be covered by an instrument to be executed by the authors. Accepted summaries may be edited to ensure uniformity of presentation. Please note that contributions are not limited to the subject categories on page 3. However, sessions with insufficient response may be merged. Outstanding summaries will be identified to the editors of ANS technical journals as possible subjects for full papers.

Content: Each contributed summary must present facts that are new and significant. A simple listing of material to be presented is not acceptable. Abstracts are not acceptable. The summary must contain not only the work that has been performed but also the results achieved. Proper reference should be made to all closely related information that has been published. **SUMMARIES SHOULD INCLUDE AN INTRODUCTORY STATEMENT INDICATING THE PURPOSE OF THE WORK AND A CLOSING STATEMENT SUMMARIZING THE SIGNIFICANT NEW RESULTS.**

Word Count: The summary must not exceed 900 words with figures or tables counting as 150 words each. There must be at least 450 words of narrative; therefore, no more than 3 figures and/or tables are allowed. References are not included in the word count, but must be limited to absolute minimum necessary (a bibliographical listing is not acceptable). Each line of an equation counts as 10 words. Limit the title to 10 words and reduce the number of authors listed to the minimum possible. A summary that does not meet these criteria may be returned without review.

Tables, Figures, Mathematics: Figures and tables are normally printed one column wide (7.50 cm). Lettering on figures must be at least 1 mm high after reduction, and the design of tables should suit the width limitation. Each table or figure must be on a separate page. The figures (for one copy of the summary) must be high-quality gloss photographs or reproducible black-on-white drawings. It is now ANS policy to use SI units (with allowance for eV and barns) in all summaries. A good reference is ANSI/ASTM E 380-76, Standard for Metric Practice (available from Headquarters for \$4 prepaid). A copy of "Metric Guide for ANS Publications" is available on request.

References: References are listed at the end of the summary and indicated numerically in the text by superscript numbers. Reference information should be listed according to whichever of the following forms is appropriate:

- Journal reference: G. E. Doe, *J. Appl. Phys.*, 24, 194 (1950).
- Book reference: G. E. Doe, *The Gammatron*, 2nd ed., Vol. 1, Chap. 2, p. 69, McGraw-Hill Book Co., New York (1952).
- Report reference: G. E. Doe, "How to Reference a Report," ANS, American Nuclear Society (1977).

Restricted Information: It is the responsibility of the authors to protect classified or proprietary information.

Page Charge: A charge of \$95.00 per final printed page (prorated) is assessed for each summary published in *Transactions*. It is customary for the institution supporting the author's research to bear this expense. Preferred: attach purchase order, with appropriate purchase order number, to the original copy of the summary.

DEADLINE FOR CONTRIBUTED SUMMARIES: Four sets (original plus three copies) of each summary, with completed "Summary Cover Sheet" (page 2) and page 4 of this Call for Papers, must reach the Technical Program Chairman **POSTMARKED NO LATER THAN Friday, June 22, 1979**. Summaries received after deadline will not be considered.

DEADLINE FOR INVITED SUMMARIES: The deadline is the same as for contributed summaries. It is the responsibility of the ANS Program Committee Division Representative to ensure that this deadline is met. (Four sets of each summary, with completed cover sheets, must be received.)

Review Procedures: Each summary will be reviewed by the National Program Committee together with representatives of Divisions and Technical Groups. The principal author will be notified on or about July 23, 1979.

Mailing Address: Please send your four sets of the summaries, prepared in accordance with these instructions, to:

Neil Norman, ANS Technical Program Chairman
Attn: Ruth Farnakes
American Nuclear Society
555 North Kensington Ave.
LaGrange Park, IL 60525

Oral Presentations: Normally 20 minutes are allowed for oral presentation and questions. Invited presentations may be assigned longer time limits (authors will be notified). 35-mm slides are preferred for oral presentation. Arrangements for audiovisual equipment (other than 35-mm slide projector or overhead projector) will be made only if requested prior to the meeting. (Form is supplied to authors of accepted papers.)

Poster Presentations: Poster sessions normally last about 2½ hours. A display board and presentation title will be provided. Authors are expected to be available for discussion during the entire session.

FILING AND MAILING INFORMATION

Name and full mailing address of author to whom correspondence should be sent. (Type or print legibly - form used for mailing.)

LOG # _____

Mr. D. L. Reeder
TSA
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, ID 83401

Telephone:	(208) 526-9091
Commercial:	
FTS:	583-9091

Title of Summary Blowdown Hydraulic Influence on Core Thermal Response in LOFT Nuclear Experiment L2-3

This is to acknowledge receipt of your summary. Please use the log number above in future correspondence.

This summary will be considered for inclusion in the program of the American Nuclear Society's 1979 Winter Meeting, San Francisco, California, Nov. 11 - 16, 1979. Another copy of this form will be sent to you about July 23, 1979.

Your paper has been reviewed and:

- 1. Accepted for presentation at the 1979 Winter Meeting. (See Attached Instructions)
- 2. It is suggested that your summary be revised. (See Attachment)
- 3. It is suggested that your summary be combined with the summary referenced as Log # _____. (See Attachment)
- 4. Rejected. (See Attached Comments)

Your paper is being returned without review because:

- 1. It was received after the deadline date.
- 2. It significantly exceeds the word limit of 900 words.

In all correspondence regarding your summary, please refer to the Log Number shown above.

Thank you for submitting this summary.

Sincerely,

Neil Norman
ANS Technical Program Chairman
1979 Winter Meeting


BLOWDOWN HYDRAULIC INFLUENCE ON CORE
THERMAL RESPONSE IN LOFT NUCLEAR EXPERIMENT L2-3

by

D. L. Reeder

EG&G Idaho, Inc.
P.O. Box 1625

Idaho Falls, Idaho 83401



Experimental research into pressurized water reactor (PWR) loss-of-coolant phenomena conducted in the Loss-of-Fluid Test (LOFT) facility¹ has given results indicating that for very large pipe breaks the core thermal response is tightly coupled to the fluid hydraulic phenomena during the blowdown phase of the loss-of-coolant transient. This summary presents and discusses data supporting this conclusion.

LOFT Loss-of-Coolant Experiment (LOCE) L2-3 simulated a complete double-ended offset shear break of a primary coolant reactor vessel inlet pipe in a commercial PWR. The LOFT system conditions at experiment initiation were: fuel rod maximum linear heat generation rate (MLHGR) of 39.4 ± 3 kW/m, hot leg temperature of 593 ± 3 K, core ΔT of 32.2 ± 4 K, system pressure of 15.06 ± 0.03 MPa, and flow rate/system volume of 25.6 ± 0.8 kg/m³. These conditions are typical of those in commercial PWR systems at normal operating conditions.

The thermal transient of the fuel cladding in the LOFT 1.68-m core was found to be limited in magnitude by the system hydraulics within the first 10 s of the blowdown. The peak fuel cladding temperature in this experiment was 914 K which occurred 4.95 s into the transient. This temperature is below fuel cladding damage thresholds.

~~55/1~~
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

The system depressurized to the saturation pressure of the fluid in the hot channels of the core in about 50 ms, followed by a core flow reversal at 0.3 s. The hotter fuel rods in the core began to experience departure from nucleate boiling at 0.94 s, followed by a rapid increase (~ 250 K/s) in fuel cladding temperature which began to moderate between 1.3 and 2 s with the reestablishment of low magnitude positive core flow. During this time, the hotter core fluid delivered to the lower plenum during the initial core flow reversal was migrating up the downcomer to the broken loop cold leg (BLCL), raising the temperature to saturation, and causing saturated choking to occur. The accompanying flow reduction reduced the magnitude of BLCL flow to below that of the intact loop cold leg (ILCL), allowing a portion of the ILCL flow to be diverted to the downcomer, lower plenum, and core regions, and causing a core-wide return to nucleate boiling (RNB) between 5 and 8.5 s. Following this RNB, the hotter fuel rods began to dry out at 9s and remained in a dryout condition until quenched by emergency core coolant (ECC).

ECC filled the lower plenum by 35 s, at which time core reflood started and proceeded at a rate of 100 mm/s, completely reflooding the core by 55 s. The accompanying quench occurred from the bottom up and the top down, quenching the hotter center region of the core last. Figure 1 shows a three dimensional axial temperature profile in the center fuel module.

The temperature-pressure history of the fuel rod experiencing the peak cladding temperature is shown in Figure 2 along with the thresholds for cladding deformation. These threshold conditions would have to have been maintained for 15 s for deformation to occur². The data did not reach these conditions, and the period of time near the thresholds was about 3 s, indicating no cladding deformation occurred during LOCE L2-3.

The early RNB was directly related to the hydraulic effects of the saturated choking in the BLCL and subsequent diversion of some ILCL fluid into the core. These hydraulic effects were seen in LOCE

L2-2³ and can be expected in other double-ended cold leg break loss-of-coolant transients in which a core ΔT is present and the pumps are operating. As the phenomena require the ILCL flow to be maintained after BLCL saturated choking occurs, the hydraulic influence may be diminished if power is lost to the primary coolant pumps coincident with pipe rupture.

The analysis of LOCE L2-3, initiated from nominal operating conditions, has revealed information pertinent to understanding the behavior of a reactor operating at normal power conditions that is subjected to a large break loss-of-coolant transient. Specifically:

- (1) The hydraulic events early in the transient strongly influence and limit the severity of the core thermal response.
- (2) These hydraulic events can be expected to occur in double-ended cold leg break loss-of-coolant transients at higher power densities.
- (3) The fuel rod cladding was not damaged in the experiment.
- (4) The LOFT ECC system was very effective in reflooding the core and quenching the fuel rods.

REFERENCES

1. D. L. Reeder, LOFT System and Test Description (5.5-ft Nuclear Core 1 LOCEs), NUREG/CR-0247, TREE-1208 (July 1978).
2. C. S. Olsen, Zircaloy Cladding Collapse Under Off-Normal Temperature and Pressure Conditions, TREE-NUREG-1239 (April 1978).
3. M. McCormick-Barger, Experiment Data Report for LOFT Power Ascension Test L2-2, NUREG/CR-0492, TREE-1322 (February 1979).




Fig. 1 Three-dimensional axial profile of cladding temperature in center fuel module.




Fig. 2 Temperature and pressure history of fuel rod experiencing peak cladding temperature during LOCE L2-3 compared with modes of cladding deformation.