

EVALUATION OF THE INFLUENCE OF  
SEISMIC RESTRAINT CHARACTERISTICS  
ON LMFBR PIPING

R. H. MALLETT

MASTER

SUMMARY

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Structural evaluation of nuclear power plant piping systems involves consideration of response due to various types of dynamic loadings. Stresses induced in the piping by dynamic loadings depend upon the piping restraints because the response of the piping is inextricably tied to the response of the restraints. For the case of breeder reactor heat transport system piping (large diameter and thin-walled), the piping restraints are comprised of a series of complex components. The representation of these piping restraints in the piping system dynamic analysis involves modeling the structural and dynamic characteristics of these components. Small changes in these component characteristics can result in marked changes in the piping response obtained from the piping system dynamic analysis.

For the Clinch River Breeder Reactor Plant (CRBRP) heat transport system piping within the reactor containment building, dynamic analyses of the piping loops have been performed to study the effect of restraint stiffness on the dynamic behavior of the piping, i.e., changes in frequencies, mode shapes, loads, stresses, and displacements. In addition, analysis and testing of typical CRBRP restraint system components have been performed for the purpose of quantifying and verifying the basic characteristics of the restraints used in the piping system dynamic analysis.

This paper presents the results of the analysis and testing described above. In particular, it is shown that piping restraint effects on breeder reactor piping response are important considerations in the design/analysis process.

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

PAGES 1706 to 1706-22

WERE INTENTIONALLY  
LEFT BLANK

# **EVALUATION OF THE INFLUENCE OF SEISMIC RESTRAINT CHARACTERISTICS ON LMFBR PIPING**

**U.S. DEPARTMENT OF ENERGY (DOE)  
AND  
JAPAN POWER REACTOR AND  
NUCLEAR FUEL DEVELOPMENT CORPORATION (PNC)**

**SPECIALIST MEETING  
ON  
HIGH TEMPERATURE PIPING  
DESIGN AND ANALYSIS**



**WESTINGHOUSE ADVANCED REACTORS DIVISION  
MADISON, PENNSYLVANIA  
MARCH 26-30, 1979**

**Robert H. Mallett, Manager  
CRBRP Mechanical Equipment  
and Piping Design**

# **OUTLINE OF PRESENTATION**

- Background to CRBRP Consideration of Piping Restraint Effects
- Dependence of Pipe Stress on Restraint Stiffness
- Time History Analyses With Free Play Effects
- Determination of Restraint Stiffness
- Advanced Studies of Piping Restraint Effects

# TEST SETUP



# **BASIC PIPING SYSTEM TESTS**

## **Preliminary Observations on PSA-10 Results**

- **Test Frame Stiffness**—Input Displacement Ranged From 3 to 12 Times Output Displacement at Test Frame
- **Transverse Accelerations**—Snubber Transverse Accelerations Approach Value of Axial Acceleration
- **Shifting of Pipe Clamp**—Accumulated Circumferential Shift of 55 Mils and Radial Settlement of 30 Mils
- **Drift From Neutral Position**—Maximum Value of 335 Mils
- **Failure of Snubber**—Structural Failure at Faulted Condition Load Rating


## **Preliminary Conclusions of PSA-10 Tests**

- **Pipe Clamp Functioned as Intended**—Clamp and Pipe Responded Integrally Rather Than Independently, no Structural Failure
- **Seismic Snubber Requires Additional Evaluation**—Characterization of Drift and Review of Load Rating


# **POTENTIALLY SIGNIFICANT PARAMETERS OF PIPING RESTRAINTS**

- Stiffness
- Damping
- Impacting
- Free Play
- Lockup Threshold
- Frequency
- Force Level
- Drift
- Different Tension/Compression Behavior


# SEISMIC MODEL FOR CRBRP PRIMARY HEAT TRANSPORT SYSTEM CROSS-OVER PIPING LEG



# SEISMIC STRESS RESULTS AS A FUNCTION OF RESTRAINT STIFFNESS FOR CRBRP PHTS CROSS-OVER PIPING




# SEISMIC MODEL FOR CRBRP PRIMARY HEAT TRANSPORT SYSTEM COLD LEG PIPING



1. ELBOW NUMBERS ARE IDENTIFIED BY

2. ALL ELBOWS 36" R  
 SNUBBER LOCATION

# SEISMIC STRESS RESULTS AS A FUNCTION OF RESTRAINT STIFFNESS FOR CRBRP HTS COLD LEG PIPING



# CONSIDERATION OF ACCELERATION LOCK-UP THRESHOLD

### • DESCRIPTION


- ASSUME SNUBBER LOCKUP IS GOVERNED BY 0.02G ACCELERATION THRESHOLD; INDEPENDENT OF AMPLITUDE
- AT FREQUENCIES LESS THAN 2 CPS, LARGE DISPLACEMENT AMPLITUDES CAN DEVELOP WITHOUT ACTIVATING SNUBBERS
- NATURAL FREQUENCIES LESS THAN 2 CPS ARE PLAUSIBLE IF ANCHOR-TO-ANCHOR PIPE LENGTHS ARE CONSIDERED

### • ILLUSTRATIVE EXAMPLE


- A 24" PIPE 95' ANCHOR-TO-ANCHOR HAS A NATURAL FREQUENCY OF 1 CPS AND MAY VIBRATE WITH 0.2" AMPLITUDE WITHOUT ACTIVATING 0.02G SNUBBERS

## • CONCLUSION

- INVESTIGATION OF PIPE RESTRAINT EFFECTS SHOULD INCLUDE CONSIDERATION OF RESPONSE BELOW LOCK-UP THRESHOLDS




# REPRESENTATIVE LMFBR PRIMARY PIPING FOR STUDY OF SNUBBER FREE PLAY




## SNUBBER MODELS FOR STUDY OF FREEPLAY EFFECTS

Simplified Representation of Snubber/Pipe Area



Detailed Representation of Snubber/Pipe Area



# RESULTS OF SNUBBER FREE PLAY STUDY


CASE	MODEL	SUPPORT K (N/m)	CLAMP K (N/m)	RESTITUTION COEFFICIENT	MASS ASSOCIATED WITH SNUBBERS (kg)	SNUBBER K (N/m)	SNUBBER TOTAL GAP (mm)	MAX. BEND. STRESS ELBOWS 5, 6 & 7 (MPa)
1	Resp. Spect. Phase II	$1.75 \times 10^7$		NA	0	NA	0	28.5
2	Resp. Spect. Phase II	$1.75 \times 10^8$		NA	0	NA	0	14.6
3	Time His. Simplified	--	--	.5	2977	$1.75 \times 10^7$	1.5	28.6 for .67 sec
4	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.5	87 & 87	$1.75 \times 10^{10}$	1.5	55.1 for .60 sec
5	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.5	<u>175 &amp; 175</u>	$1.75 \times 10^{10}$	1.5	59.3 for .60 sec
6	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.8	87 & 87	$1.75 \times 10^{10}$	1.5	57.9 for .60 sec
7	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.5	87 & 87	$1.75 \times 10^9$	1.5	53.8 for .60 sec
8	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.3	87 & 87	$1.75 \times 10^{10}$	1.5	55.8 for .60 sec
9	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.5	87 & 87	$1.75 \times 10^{10}$	.75	31.7 for .65 sec
10	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.5	87 & 87	NA	.000	20.0 for .60 sec
11	Time His. Detailed	$3.5 \times 10^8$	$3.5 \times 10^8$	.5	175 & 175	$3.5 \times 10^8$	1.5	36.5 for .65 sec
12	Resp. Spect. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	NA	175 & 175	NA	0	65.2
13	Resp. Spect. Detailed	$3.5 \times 10^8$	$3.5 \times 10^8$	NA	175 & 175	NA	0	14.5
14	Time His. Detailed	$5.2 \times 10^7$	$2.6 \times 10^7$	.5	87 & 87	$1.75 \times 10^7$	1.5	25.5 for .62 sec
15	Time His. Simplified	--	--	.5	2977	$1.75 \times 10^7$	.75	14.5 for .67 sec

- Ring Stiffness


$$K = 1.12 Eb (t/r)^3$$

or

$$K = 19400 bt^3$$



Where  $E = 30 \times 10^6$  psi,  $r = 12$  in



- Simplified Model of Clamp/Pipe Stiffness

$$K = 19400 \left[ b_{ctc}^3 + b_{ptp}^3 \right]$$

- Introduction of Estimated Effective Pipe Length


$$K = 19400 \left[ b_{ctc}^3 + 50 t_p^{2.6} \right] \quad \text{Where } b_p = 1.68 r (r/t)^{0.366}$$

- Example:  $t_c = t_p = 0.5$  in.,  $b_c = 8.0$  in.

$$K = 19400 \left[ 1.0 + 8.2 \right]$$

- Conclude: Clamp/Pipe Stiffness is Due Primarily to Pipe


# POINT LOAD ESTIMATE OF STIFFNESS



(b) COMPARISON OF END CONDITION



## (c) STIFFNESS DETERMINATION

- DISPLACEMENT UNDER APPLIED LOAD = .213 cm  
 $K_{\text{pipe}} = 44,500/.213 = 2.1 \times 10^7 \text{ N/m}$  ( $1.2 \times 10^5 \text{ lb/in}$ )
- DISPLACEMENT AT  $90^\circ$  TO LOAD = .137 cm  
 $K_{\text{pipe}} = 44,500/.137 = 3.2 \times 10^7 \text{ N/m}$  ( $1.8 \times 10^5 \text{ lb/in}$ )



# CLAMP/PIPE STIFFNESS BY DETAILED ANALYSIS

- DESCRIPTION OF FINITE ELEMENT MODEL




32" SIMPLY SUPPORTED BEAM  
24" DIAMETER  
1/2" THICKNESS  
14740# SIDE LOAD (PUSH)  
9760# PRELOAD

- SUMMARY OF RESULTS

- 0.013 INCH BEAM CENTERLINE DISPLACEMENT
- 0.021 INCH LUG DISPLACEMENT RELATIVE TO CENTERLINE
- $7.0 \times 10^5$  LB/INCH CLAMP/PIPE STIFFNESS,  $K_{CLAMP/PIPE}$

# TEST OF CLAMP/PIPE STIFFNESS



## **SUMMARY OF PHTS 24 INCH HOT LEG CLAMP/PIPE STIFFNESS DETERMINATION**

No.	Basis of Clamp/Pipe Stiffness Approximations	Clamp/Pipe Compression $10^{-5} (K_C \text{ Lb/In})$	Stiffness Tension $10^{-5}(K_C \text{ Lb/In})$
1	Ring-Plus Clamp Pinched by Point Loads, Ring Width of 48 Inches	1.1	—
2	Preliminary Clamp/Pipe Stiffness Test, Preload O.O. Compression	1.6	—
3	Preliminary Clamp/Pipe Stiffness Test, Preload 5000	1.8	0.9
4	Preliminary Clamp/Pipe Stiffness Test, Preload 10000	1.8	1.1
5	Cylinder Pinched by Point Loads Using Displacement Under Load	1.2	—
6	Cylinder Pinched by Point Loads Using Displacement 90° to Load	1.8	—
7	Detailed Finite Element Model of Clamp/Pipe	7.0	3.3
Best Estimate for Preliminary Support Flexibility Effects Study		2.0	2.0

# ADVANCED STUDIES OF PIPING RESTRAINT EFFECTS

## PIPING RESTRAINT EFFECTS ON PIPING INTEGRITY

Session Chairman: R. H. MALLETT  
Westinghouse, Advanced Reactors Division

Session Vice Chairman: R. J. BOSNAK  
U. S. Nuclear Regulatory Commission

### Technical Papers and Presentations:

1. "AN OVERVIEW OF EFFORTS TO RESOLVE SAFETY ISSUES ASSOCIATED WITH SNUBBERS UTILIZED IN NUCLEAR POWER GENERATING FACILITIES"  
J. Kovacs, U. S. Nuclear Regulatory Commission
2. "MECHANICAL SNUBBER CHARACTERISTICS"  
B. T. Lothers, Pacific Scientific Company
3. "THE EFFECT OF SUPPORT STIFFNESS UPON THE SEISMIC RESPONSE OF PIPING SYSTEMS"  
J. D. Stevenson and L. A. Bergman, Woodward Clyde Consultants
4. "A SNUBBER RESPONSE SENSITIVITY STUDY"  
A. T. Onesto, Energy Technology Engineering Center
5. "EVALUATION OF THE INFLUENCE OF SEISMIC RESTRAINT CHARACTERISTICS ON BREEDER REACTOR PIPING SYSTEMS"  
R. M. Mello and L. P. Pollono, Westinghouse Advanced Reactors Division
6. "COMPARISON OF NON-LINEAR ANALYSIS, LINEAR ANALYSIS, AND TEST RESULTS FOR CANTILEVER BEAM WITH SNUBBER SUBJECT TO SINUSOIDAL LOAD"  
E. O. Swain, H. L. Hwang, C. T. Nieh, J. L. Thompson, General Electric Company
7. "EFFECTS OF RESTRAINT STIFFNESS AND GAP ON THE DYNAMIC RESPONSE OF PIPING SYSTEMS"  
K. C. Chang, E. R. Johnson, and P. J. Kotwicki, Westinghouse Electric Corporation
8. "NON-LINEAR SEISMIC ANALYSIS OF LMFBR PIPING"  
W. G. Brussalis, Westinghouse Electric Corporation
9. "NON-LINEAR RESPONSE OF PIPING"  
N. Varadarajan, S. Levy, M. Triplett, J. Thompson, G. Esswein, General Electric Company
10. "EFFECTS OF ENERGY ABSORBING RESTRAINERS ON SEISMIC STRESSES IN PIPING"  
G. H. Powell and D. G. Row, University of California
11. "STATUS REPORT-A DYNAMIC TESTING AND ANALYSES RESEARCH PROGRAM ON THE NON-LINEAR RESPONSE OF PIPING SYSTEMS AND COMPONENTS"  
G. E. Howard and P. Ibanez, ANCO Engineers, Inc.  
C. Chan, Electric Power Research Institute
12. "STATUS REPORT-US NRC STUDY TO DETERMINE EFFECTS OF POSTULATED EVENT DEVICES ON NORMAL OPERATIONS OF LWR PIPING SYSTEMS"  
K. D. Desai, Nuclear Regulatory Commission  
R. Hookeway, Teledyne Engineering Services

### ASME TECHNICAL SESSION AND SPECIAL PUBLICATION

ASME National Congress on Pressure vessels and Piping San Francisco,  
California  
June 25-29, 1979

## **CRBRP DEVELOPMENT ACTIVITY DESCRIPTION**

- Objective of Development Program
  - To Develop and Verify Models of Piping Restraints for use in Design of HTS Piping
- Reason for Development Program
  - Preliminary Analyses and Tests Indicate That Piping Restraint Effects on Piping Integrity are More Important and More Complex Than Presently Reflected in Conventional Piping Design Practice
- Technical Approach
  - By Correlation of Predicted and Measured Responses of Representative Piping Systems
- Expected Results
  - Guidance for Locating and Designing Pipe Clamps
  - Models of Piping Restraints for use in Plant Piping Design Analyses
  - Design Requirements to Place on Piping Restraint Devices and Structures