

 Atomic International North American Rockwell		SUPPORTING DOCUMENT																																								
PROGRAM TITLE FAST REACTOR (CENTRAL STATION)		NUMBER TI-097-241-010 REV LTR/CHG NO. SEE SUMMARY OF CHG																																								
DOCUMENT TITLE IN-VESSEL TRANSFER MACHINE SEAL THERMAL ANALYSIS		DOCUMENT TYPE TECHNICAL INFORMATION																																								
PREPARED BY/DATE T. Shimazaki 3/1/74		DEPT 716	MAIL ADDR T006																																							
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____		ORIGINAL ISSUE DATE 12-15-73																																								
APPROVALS O. P. Steele III K. Foster		GO NO. 41231 PAGE 1 OF 26 REL. DATE 3-5-74																																								
SECURITY CLASSIFICATION (CHECK ONE BOX ONLY)		(CHECK ONE BOX ONLY) AEC <input checked="" type="checkbox"/> DOD <input type="checkbox"/> UNCL <input checked="" type="checkbox"/> CONF. <input type="checkbox"/> SECRET <input type="checkbox"/> DEFENSE <input type="checkbox"/> INFO.																																								
AUTHORIZED CLASSIFIER		DATE																																								
DISTRIBUTION		ABSTRACT																																								
<table border="1"> <thead> <tr> <th>*</th> <th>NAME</th> <th>MAIL ADDR</th> </tr> </thead> <tbody> <tr> <td>Berg, G.</td> <td>LB31</td> <td>An analysis of the grapple drive stem temperature during operation of the IVTM (In-Vessel Transfer Machine) indicates that the maximum stem wall temperature at the seals will be 270°F when the system is at dynamic thermal equilibrium. If the transfer operation is initiated with the grapple drive stem initially at thermal equilibrium in the lowered position, a pre-cooling step will be required if the maximum temperature of the grapple drive stem wall at the seals is to be limited to 300°F.</td> </tr> <tr> <td>Bilibin, K.</td> <td>LB26</td> <td></td> </tr> <tr> <td>Foster, K. (5)</td> <td>LB10</td> <td></td> </tr> <tr> <td>Kurzeka, W.</td> <td>T006</td> <td></td> </tr> <tr> <td>Shimazaki, T.</td> <td>T006</td> <td></td> </tr> <tr> <td>Steele, O. P. III</td> <td>T006</td> <td></td> </tr> <tr> <td>Stewart, A.</td> <td>T036</td> <td></td> </tr> <tr> <td>* Matlin, E.</td> <td>LB34</td> <td></td> </tr> <tr> <td>* Meyers, G. W.</td> <td>LB17</td> <td></td> </tr> <tr> <td>* Poucher, F.</td> <td>T478</td> <td></td> </tr> <tr> <td>Clausen, H.</td> <td>T006</td> <td>This report supersedes and cancels TI-097-241-007, Rev. A, and TI-097-241-009.</td> </tr> <tr> <td>Kellogg, L.</td> <td>LA49</td> <td></td> </tr> </tbody> </table>		*	NAME	MAIL ADDR	Berg, G.	LB31	An analysis of the grapple drive stem temperature during operation of the IVTM (In-Vessel Transfer Machine) indicates that the maximum stem wall temperature at the seals will be 270°F when the system is at dynamic thermal equilibrium. If the transfer operation is initiated with the grapple drive stem initially at thermal equilibrium in the lowered position, a pre-cooling step will be required if the maximum temperature of the grapple drive stem wall at the seals is to be limited to 300°F.	Bilibin, K.	LB26		Foster, K. (5)	LB10		Kurzeka, W.	T006		Shimazaki, T.	T006		Steele, O. P. III	T006		Stewart, A.	T036		* Matlin, E.	LB34		* Meyers, G. W.	LB17		* Poucher, F.	T478		Clausen, H.	T006	This report supersedes and cancels TI-097-241-007, Rev. A, and TI-097-241-009.	Kellogg, L.	LA49			
*	NAME	MAIL ADDR																																								
Berg, G.	LB31	An analysis of the grapple drive stem temperature during operation of the IVTM (In-Vessel Transfer Machine) indicates that the maximum stem wall temperature at the seals will be 270°F when the system is at dynamic thermal equilibrium. If the transfer operation is initiated with the grapple drive stem initially at thermal equilibrium in the lowered position, a pre-cooling step will be required if the maximum temperature of the grapple drive stem wall at the seals is to be limited to 300°F.																																								
Bilibin, K.	LB26																																									
Foster, K. (5)	LB10																																									
Kurzeka, W.	T006																																									
Shimazaki, T.	T006																																									
Steele, O. P. III	T006																																									
Stewart, A.	T036																																									
* Matlin, E.	LB34																																									
* Meyers, G. W.	LB17																																									
* Poucher, F.	T478																																									
Clausen, H.	T006	This report supersedes and cancels TI-097-241-007, Rev. A, and TI-097-241-009.																																								
Kellogg, L.	LA49																																									
DISCLAIMER <small>This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.</small>																																										
RESERVED FOR NR PROPRIETARY/LEGAL NOTICES THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PERTINENT BRANCH, AEC.																																										
* TITLE PAGE ONLY		<small>This report was prepared by the United States Atomic Energy Commission and their contractors, sub contractors, or consultants. The Commission does not warrant the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.</small>																																								

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
I	INTRODUCTION	4
II	SYSTEM DESCRIPTION AND ASSUMPTIONS	4
III	METHOD OF CALCULATION	7
IV	RESULTS	7
V	DISCUSSION	13
	A. SEAL LUBRICANT TEMPERATURE	13
	B. EFFECT OF GRAPPLE SPEED	13
	C. EFFECT OF CHANGE OF COVER GAS TO HELIUM	13
VI	CONCLUSIONS	13
	REFERENCES	15
APPENDIX A		16
APPENDIX B		19

TABLES

A-1	DESCRIPTION OF CONNECTORS SHOWN IN FIGURE A-1	16
-----	--	----

FIGURES

1	In-Vessel Section Assembly of IVTM	5
2	Assumed Fuel Transfer Port Wall and Ring Adapter Temperature During Fuel Transfer Operation	6
3	IVTM Transfer Cycle	8
4	Grapple Drive Stem Wall Temperature at Beginning of Raised Position Dwells in 1st and 3rd Transfer Cycles and in Transfer Cycles when System is Nearly at Dynamic Thermal Equilibrium	9
5	Temperatures of Structures Surrounding	11
6	Cooling of Stem Wall by Dwell 3-1/2 Feet Below Raised Position During Initial Lifting in First Transfer Cycle	12

TABLE OF CONTENTS (continued)

<u>Figure</u>		<u>Page</u>
A-1	Heat Transfer Network	17
A-2	Connectors Between Boundary Nodes and Stem Wall Nodes	18
B-1	IVTM Seal and Bushing Test Configuration	20
B-2	Stem Wall Temperature at Beginning of Raised Position Dwell	21
B-3	Stem Wall and Slug Temperatures at End of Raised Position Dwell in 4th and 8th Cycles	22
B-4	Seal Housing Temperature vs Number of Cycles	24
B-5	Stem Wall Temperature of Seal Housing Elevation When at Raised Position vs Number of Cycles	25

I. INTRODUCTION

The results of an analysis of the maximum grapple drive stem temperature at the grapple drive stem reciprocating seals during fuel transfer operation of the In-Vessel Transfer Machine (IVTM) are presented.

This report supercedes and cancels TI-097-241-007, Rev. A, and TI-097-241-009. The results given in the latter documents have been found to be invalid.

II. SYSTEM DESCRIPTION AND ASSUMPTIONS

Figure 1 shows the in-vessel section assembly of the IVTM. The vertical travel of the grapple drive stem, which is shown in the lowered position, is such that the part of the grapple drive stem that is immersed in the hot sodium pool when in the lowered position, reaches to within a foot of the grapple drive stem reciprocating seals located in the seal housing at the upper end of the support body and shielding structure. Of concern, due to the temperature limitation of the seals, is the maximum grapple drive stem temperature seen by the reciprocating seals during fuel transfer operation.

The dimensions of the IVTM given in Ref. 1, were used in the analysis.

The following assumptions were made in the analysis:

1. Ambient temperature = 80°F
2. Sodium pool temperature = 500°F
3. Cover gas = Argon
4. Emissivity of stainless steel = 0.3
5. Vertical travel of grapple drive stem = 18 Ft
6. Grapple drive stem speed = See Fig. 3
7. The Fuel Transfer Port wall and the Ring Adapter temperature remains constant during the fuel transfer operation and is assumed to be as shown by the solid curve in Fig. 2. It can be seen by comparing this assumed temperature distribution for the top shield during operation and shutdown, respectively, shown by the dashed curves in Fig. 2, that the assumed temperature distribution for the Fuel Transfer Port wall and Ring Adapter is that which should approximately prevail very shortly after shutdown.
8. The fuel transfer operation is that in which there is no waiting between each fuel transfer cycle for execution of a fuel handling cycle. This approach yields a conservative result of the grapple stem temperature reciprocating through the seals.

THE CHINESE PEOPLE IN THE MARKET




Fig. 1 Vessel Section Assembly of IUTM

NOTES & GRAPHS: DETAIL SEE SHEET 2
& LAYOUT IS INCOMPLETE

1	CONTRACT	145-73
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		
37		
38		
39		
40		
41		
42		
43		
44		
45		
46		
47		
48		
49		
50		
51		
52		
53		
54		
55		
56		
57		
58		
59		
60		
61		
62		
63		
64		
65		
66		
67		
68		
69		
70		
71		
72		
73		
74		
75		
76		
77		
78		
79		
80		
81		
82		
83		
84		
85		
86		
87		
88		
89		
90		
91		
92		
93		
94		
95		
96		
97		
98		
99		
100		
101		
102		
103		
104		
105		
106		
107		
108		
109		
110		
111		
112		
113		
114		
115		
116		
117		
118		
119		
120		
121		
122		
123		
124		
125		
126		
127		
128		
129		
130		
131		
132		
133		
134		
135		
136		
137		
138		
139		
140		
141		
142		
143		
144		
145		
146		
147		
148		
149		
150		
151		
152		
153		
154		
155		
156		
157		
158		
159		
160		
161		
162		
163		
164		
165		
166		
167		
168		
169		
170		
171		
172		
173		
174		
175		
176		
177		
178		
179		
180		
181		
182		
183		
184		
185		
186		
187		
188		
189		
190		
191		
192		
193		
194		
195		
196		
197		
198		
199		
200		
201		
202		
203		
204		
205		
206		
207		
208		
209		
210		
211		
212		
213		
214		
215		
216		
217		
218		
219		
220		
221		
222		
223		
224		
225		
226		
227		
228		
229		
230		
231		
232		
233		
234		
235		
236		
237		
238		
239		
240		
241		
242		
243		
244		
245		
246		
247		
248		
249		
250		
251		
252		
253		
254		
255		
256		
257		
258		
259		
260		
261		
262		
263		
264		
265		
266		
267		
268		
269		
270		
271		
272		
273		
274		
275		
276		
277		
278		
279		
280		
281		
282		
283		
284		
285		
286		
287		
288		
289		
290		
291		
292		
293		
294		
295		
296		
297		
298		
299		
300		
301		
302		
303		
304		
305		
306		
307		
308		
309		
310		
311		
312		
313		
314		
315		
316		
317		
318		
319		
320		
321		
322		
323		
324		
325		
326		
327		
328		
329		
330		
331		
332		
333		
334		
335		
336		
337		
338		
339		
340		
341		
342		
343		
344		
345		
346		
347		
348		
349		
350		
351		
352		
353		
354		
355		
356		
357		
358		
359		
360		
361		
362		
363		
364		
365		
366		
367		
368		
369		
370		
371		
372		
373		
374		
375		
376		
377		
378		
379		
380		
381		
382		
383		
384		
385		
386		
387		
388		
389		
390		
391		
392		
393		
394		
395		
396		
397		
398		
399		
400		
401		
402		
403		
404		
405		
406		
407		
408		
409		
410		
411		
412		
413		
414		
415		
416		
417		
418		
419		
420		
421		
422		
423		
424		
425		
426		
427		
428		
429		
430		
431		
432		
433		
434		
435		
436		
437		
438		
439		
440		
441		
442		
443		
444		
445		
446		
447		
448		
449		
450		
451		
452		
453		
454		
455		
456		
457		
458		
459		
460		
461		
462		
463		
464		
465		
466		
467		
468		
469		
470		
471		
472		
473		
474		
475		
476		
477		
478		
479		
480		
481		
482		
483		
484		
485		
486		
487		
488		
489		
490		
491		
492		
493		
494		
495		
496		
497		
498		
499		
500		
501		
502		
503		
504		
505		
506		
507		
508		
509		
510		
511		
512		
513		
514		
515		
516		
517		
518		
519		
520		
521		
522		
523		
524		
525		
526		
527		
528		
529		
530		
531		
532		
533		
534		
535		
536		
537		
538		
539		
540		
541		
542		
543		
544		
545		
546		
547		
548		
549		
550		
551		
552		
553		
554		
555		
556		
557		
558		
559		
560		
561		
562		
563		
564		
565		
566		
567		
568		
569		
570		
571		
572		
573		
574		
575		
576		
577		
578		
579		
580		
581		
582		
583		
584		
585		
586		
587		
588		
589		
590		
591		
592		
593		




Figure 3 shows the fuel transfer cycle and the assumed time (in seconds) required to complete each step (Ref's. 3 and 4).

III. METHOD OF CALCULATION

Computer Program DEAP (Ref. 5) was used. To simulate the grapple drive stem motion, the moving boundary concept was employed in the formulation of the heat transfer network (Appendix A). The validity of this method of calculation was checked by applying it to the configuration and cycle of the I VTM Seal and Bushing Test. Comparison of computed temperatures with measured temperatures indicates that valid results are obtained by this method of calculation (Appendix B). (The method of calculation employed in superseded reports TI-097-241-007, Rev. A, and TI-097-241-009, differed in that the grapple drive stem motion was simulated by making the nodes in the grapple drive stem flow nodes. In this method, the boundary condition at the upper end of the stem cannot be simulated exactly in this problem. The approximation used for the boundary condition at the upper end of the stem was apparently inadequate or inappropriate, inasmuch as invalid results were obtained.)

IV. RESULTS

The starting point in the grapple drive stem temperature vs time computation was taken to be the beginning of Step "b" (see Fig. 3), after the grapple drive stem had initially reached equilibrium temperature in the lowered position. Computer runs were made for the first three transfer cycles and for transfer cycles when the system is close to dynamic thermal equilibrium.

Fig. 4 shows the grapple drive stem wall temperature at the beginning of the raised position dwells during the first and third transfer cycles and during the transfer cycles when the system has nearly attained dynamic thermal equilibrium. Also shown in Fig. 4 is the grapple drive stem wall temperature at the start of Step "b" in the first transfer cycle. It is observed that the seals will see stem wall temperatures as high as about 600°F during the first transfer cycle. The stem wall temperature at the seal decreases with succeeding transfer cycles. After a sufficient number of transfer cycles, when dynamic thermal equilibrium is approached, the maximum wall temperature seen by the seals is 325°F for the 18 foot stroke case. For shorter strokes, the stem wall temperature seen by the seals can be determined approximately by shifting the curves in Fig. 4 downward an appropriate distance or, conversely, by shifting the effective elevation of the seals upward. For example, if the stroke is 17.2 feet (the design stroke) instead of 18 feet, the effective elevation of the lower end of the seals would be 110.8 feet instead of 110.0 feet. For this case, it can be seen from Fig. 4 that when the system is approximately at dynamic thermal equilibrium, the maximum stem wall temperature seen by the seals would be 270°F.

Fig. 3
IVTM Transfer Cycle




Fig. 4
Grapple Drive Stem Wall Temperatures at
Beginning of Raised Position Dwells in 1st & 3rd
Transfer Cycles and in Transfer Cycles when
System is Nearly at Dynamic Thermal Equilibrium




Fig. 5 shows the temperatures of the structures surrounding the grapple drive stem during the first and third transfer cycles and during subsequent transfer cycles when the system is close to a dynamic thermal equilibrium.

If the maximum permissible stem wall temperature at the seals is 300°F, it can be seen from Fig. 4 that this temperature limitation is not met during the first few transfer cycles, if, initially, the grapple drive stem is at thermal equilibrium in the lowered position. Ways to avoid exceeding the 300°F stem wall temperature limitation at the seals include the following:

1. During the initial lifting of the grapple drive stem in the first transfer cycle, stop the lifting when the stem temperature at the seals approaches 300°F. From the results shown in Fig. 4, this would occur when the stem is about 3-1/2 feet below the raised position, for the 17.2 feet design stroke. If the stem is held in this position for a period of about 40 minutes (see solid curves in Fig. 6), it would cool sufficiently, i.e., to $\leq 300^{\circ}\text{F}$, so that the lifting can be resumed and completed without the stem wall temperature exceeding 300°F at the seals. Normal transfer operation is followed thereafter.
2. Start transfer operation with the grapple drive stem initially at thermal equilibrium in the raised position.
3. If, during the course of the transfer operation, the grapple drive stem is held in the lowered, or nearly lowered position for an extended period, the temperature of the grapple drive stem would increase and tend to reach the lowered, or nearly lowered, position equilibrium temperature. In this event, it may be necessary to go thru Step 1 again. However, the required dwell time may now be longer inasmuch as the support body will now be hotter. Figure 6 shows that if the temperature of the support body opposite the peak temperature point in the stem is 183°F at the start of the partially raised position dwell, the dwell time required for the peak temperature in the stem wall to drop from 600°F to 300°F will be 60 minutes.

At the upper end of the grapple drive stem, where the grapple finger actuating rod seals are located, the grapple finger actuating rod temperature will always be approximately the same as the temperature of the adjacent grapple drive stem wall. The maximum temperature that this region could reach will be less than the maximum temperature of the seal housing which, from Figure 5, is seen to be about 160°F.





Fig. 6
Cooling of Stem Wall by Dwell 32°F
Below Raised Position During Initial
Lifting in 1st Transfer Cycle



V. DISCUSSION

A. SEAL LUBRICANT TEMPERATURE

While it is possible to program the operation of the IVTM so that the grapple drive stem wall temperature at the seals never exceeds 300°F, this does not necessarily mean that the seal lubricant will not be exposed to temperatures higher than 300°F. Any lubricant that is left on the stem surface after the surface slides down past the wiper and scraper would be subject to temperatures up to greater than 600°F if the grapple drive stem is permitted to stay in the lowered position for an extended period.

B. EFFECT OF GRAPPLE SPEED

Each time the grapple drive stem is lowered into the sodium pool and then raised, heat is, in effect, pumped from the sodium pool to the support body and shielding structure through the grapple finger actuating rod and the grapple drive stem, and the temperatures of these components are increased. Hence, increasing the number of strokes per unit time, by increasing the grapple drive stem speed and/or by decreasing the time between strokes, without changing the fraction of total time the grapple drive stem is in the raised or lowered position, will increase the heat pumping rate, and therefore, the maximum grapple drive stem wall temperature at the seals.

C. EFFECT OF CHANGE OF COVER GAS TO HELIUM

If the cover gas is changed from argon to helium, the maximum temperature of the grapple drive stem wall at the seals would be lower inasmuch as the rate of heat transfer from the grapple drive stem to the support body and shielding structure, which is, on the average, colder than the drive stem, would be increased due to the higher thermal conductivity of helium.

VI. CONCLUSIONS

1. The maximum grapple drive stem wall temperature at the grapple drive stem seals will be about 270°F for the assumed transfer cycle when the system is at dynamic thermal equilibrium.
2. If the transfer operation is started with the grapple drive stem initially at thermal equilibrium in the lowered position, it will be necessary to pre-cool the stem if the maximum permissible temperature of the stem wall at the seals is 300°F. The pre-cooling can be accomplished by stopping the initial lifting of the stem when the stem is about 3-1/2 feet below the full raised position and holding it in this

position for 40 minutes before resuming the transfer operation. No pre-cooling is required if the transfer operation is started with the grapple drive stem initially in the raised position.

3. While it is possible to program the operation of the IVTM so that the grapple drive stem wall temperature at the seals never exceeds 300°F, this does not necessarily mean that the seal lubricant will not be exposed to temperatures higher than 300°F.
4. The maximum temperature that the grapple finger actuating rod seals could be subjected to will be less than 160°F.
5. Increasing the speed of the grapple drive stem will increase the stem wall temperature at the seals.
6. Changing the cover gas from argon to helium will decrease the stem wall temperature at the seals.

REFERENCES

1. Drawing R-N097241007, as of 3-30-73
2. TI-097-220-003, "Reactor Vessel and Vessel Cover Thermal Studies", M. J. Gabler, 12-19-72.
3. RFT-097-241-002, "Fuel Transfer Machine Seal and Guide Bushing Test Requirements", K. Bilibin, 12-13-72.
4. K. Bilibin, Feb. 1973.
5. LAP 69-552(RC), "Manual for the Differential Equation Analyzer Program. (DEAP), Volume I", B. L. McFarland, 10-1-69.

APPENDIX A
HEAT TRANSFER NETWORK

The heat transfer network used is shown in Figures A-1 and A-2.

The vertical distance between nodes was taken as 2 feet. For this vertical distance between nodes, there are 18 nodes in the stem and 18 nodes in the finger-actuating rod. Programming is simplified if the number of nodes in the stem and in the finger-actuating rod is a multiple of 10. Therefore, dummy nodes 41 and 60 were added to the stem and dummy nodes 61 and 80 were added to the finger-actuating rod. These four nodes function only as dummies by virtue of an artificially high thermal resistance inserted between each of these nodes and the respective, adjacent end nodes.

The connectors shown in Fig. A-1 are described in Table A-I. The connectors shown in Fig. A-2 are described in Fig. A-2. Appropriate functions are used in the *030 section of the DEAP input to cancel all connectors other than the appropriate ones for any particular stroke position of the grapple drive stem.

TABLE A-I
DESCRIPTION OF CONNECTORS
SHOWN IN FIGURE A-1

<u>Connectors</u>	<u>Description</u>
Y002-Y007	Conduction thru argon
Y008-Y010	Air Convection
Y011-Y020	
Y023-Y030	Conduction thru S. S.
Y033-Y039	
Y461-Y480	Conduction thru argon
Y481-Y500	Radiation
Y501-Y519	Conduction thru S. S.
Y541-Y559	Conduction thru S. S.
Y561-Y570	Conduction thru sodium
Y591-Y600	Radiation

Fig. A-1 Heat Transfer Network





Fig. A.2
Connectors Between Boundary Nodes
and Stem Wall Nodes

Boundary Nodes	Connectors		
	Conduction	Convection	Radiation
(-) 8 (Air)		$Y_{061} - Y_{080}$ $Y_{041} - Y_{060}$ $Y_{521} - Y_{540}$	$Y_{081} - Y_{100}$
(-) 21 (Sodium)			
22	$Y_{101} - Y_{120}$		$Y_{281} - Y_{300}$
33	$Y_{121} - Y_{140}$		$Y_{301} - Y_{320}$
34	$Y_{141} - Y_{160}$		$Y_{321} - Y_{340}$
35	$Y_{161} - Y_{180}$		$Y_{341} - Y_{360}$
36	$Y_{181} - Y_{200}$		$Y_{361} - Y_{380}$
37	$Y_{201} - Y_{220}$		$Y_{381} - Y_{400}$
38	$Y_{221} - Y_{240}$		$Y_{401} - Y_{420}$
39	$Y_{241} - Y_{260}$		$Y_{421} - Y_{440}$
40	$Y_{261} - Y_{280}$		$Y_{441} - Y_{460}$

APPENDIX B

CALCULATION OF GRAPPLE DRIVE STEM TEMPERATURE IN IVTM SEAL & BUSHING TEST

I. INTRODUCTION

In order to check the validity of the method of calculation used to calculate the temperature of the IVTM grapple drive stem, this method of calculation was applied to the IVTM Seal & Bushing Test configuration and cycle. The calculated results are compared with experimental data.

II. SYSTEM DESCRIPTION & ASSUMPTIONS

Fig. B-1 shows a schematic representation of the IVTM Seal and Bushing Test configuration. The grapple drive stem travels 60 inches at a speed of 15 feet/min. The dwell time is 105 seconds in the raised position and 120 seconds in the lowered position.

The thickness of the stem wall is not known with certainty. It is not less than 1/4" and may be greater. In the calculations, the stem wall thickness was assumed to be 1/4". The diameter of the 12" long stainless steel slugs stocked in the stem is presumably 3-1/4". For this set of dimensions, the annular gap between the stem wall and the slugs is 1/8"

III. RESULTS

Calculations were made for the case in which the seal housing was neither heated nor insulated. Computer runs were made for the first eight cycles, with the grapple drive stem initially at thermal equilibrium in the lowered position.

Fig. B-2 shows the stem wall temperature at the beginning of the raised position dwell in the first, second, fourth and eighth cycles. It is seen that at least up thru the fourth cycle, the stem wall is cooled more rapidly in the vicinity of about 64 inches below the upper end of the stem than elsewhere. This is the wall region that is at the same elevation as the seal housing when the stem is in the raised position. The reason why the stem wall is cooled more rapidly in this region, is that the seal housing is quite cool initially, the thermal impedance between the seal housing and the stem wall is relatively small due to the small clearance (0.013") between the seal housing and the stem wall, and the stem is in the raised position a significant fraction (40%) of the total cycle time.

Fig. B-3 shows the stem wall and slug temperatures at the end of the raised position dwell in the fourth and eighth cycles. It is seen that the slug temperature at the seal housing elevation is virtually unperturbed as compared with the stem wall temperature. This is due to the

Fig. B-1
IV TM 5 and 6 Bushing Test Configuration




Fig. B-2
Stem Wall Temperature at Beginning
of Raised Position Dwell





Fig. 4-3

Steam Wall and Slug Temperatures at
End of Raised Position Dwell in 446 and
846 Cycles



relatively high thermal impedance (1/8" air gap) between the stem wall and the slugs.

Fig. B-4 shows the increase in seal housing temperature with number of cycles. The measured seal housing temperature after many cycles is in the range of 115°F to 120°F.

Fig. B-5 shows a plot of the temperatures of the stem wall at the seal housing elevation when at the raised position (i.e., at the T/C location) vs number of cycles. It is seen that the stem wall temperatures decrease with number of cycles up to the eighth cycle. At the eighth cycle, the stem wall temperature curves have just about flattened out. Inasmuch as the seal housing temperature is still rising at the eighth cycle (see Fig. B-4) at least the raised dwell curves in Fig. B-5 should start rising after the eighth cycle. If the equilibrium seal housing temperature is taken to be 120°F (which is 13°F higher than the seal housing temperature at the eighth cycle), the raised dwell curves would ultimately rise to about 13°F above what they are at the eighth cycle. Accordingly, the temperature of the stem wall at the seal housing elevation when at the raised position, will be $167 + 13 = 180$ °F at the start of the raised dwell and $150 + 13 = 163$ °F at the end of the raised dwell. The measured stem wall temperature at this elevation was 205°F regardless of whether it was at the start or end of the raised dwell.

IV. DISCUSSION

Possible reasons for these differences between measured and predicted stem wall temperatures include the following:

1. The stem wall thickness may be greater than 1/4"*. If so, the stem wall temperature at the T/C location would be depressed less, due to (a) greater heat transfer from the slugs, by virtue of the decreased air gap between the wall and the slugs, and (b) greater heat flow in the longitudinal direction in the stem wall. A greater wall thickness would also decrease the change in wall temperature during the raised dwell, inasmuch as the heat capacity will be greater.
2. The T/C in the stem was probably seeing a temperature intermediate between the stem wall temperature and the higher slug temperature. This is likely inasmuch as the T/C sheath in the vicinity of the junction was located in a slot in the slug and was probably in contact with the slug.

*Subsequent to the performance of these calculation, it was found that the stem wall thickness is 3/8" and that the slugs fitted quite snugly inside the stem tube.

Fig G-4

Seal Housing Temperature vs No. of Cycles





Fig. E-5

Stem Wall Temperature of Seal Housing Elevation
when at Raised Position vs. start of Cycles



V. CONCLUSIONS

The calculated results for the stem wall temperatures in the IVTM Seal and Bushing Test indicate that probably reasonably good agreement between the calculated and measured temperatures would have been obtained if the correct stem wall thickness had been used in the calculation. It is, therefore, concluded that the method of calculation used will produce valid results.