

86-75 (1)

I-25/31 RECEIVED BY OCTI MAR 04 1986

DF-1586-5

SERI/TR-253-2604
DE86004419

January 1986



Reliability Testing of Active SDHW Components

Part II: Results of Collector Scaling Tests and the Effect on Thermal Performance from Scale Build-Up

Carl E. Bingham
Robert B. Farrington



SERI

Solar Energy Research Institute

A Division of Midwest Research Institute

1617 Cole Boulevard
Golden, Colorado 80401-3393

Operated for the
U.S. Department of Energy
under Contract No. DE-AC02-83CH10093

**DO NOT MICROFILM
COVER**

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

SERI/TR-253-2604
UC Category: 59a
DE86004419

SERI/TR--253-2604
DE86 004419

Reliability Testing of Active SDHW Components

Part II: Results of Collector Scaling Tests and the Effect on Thermal Performance from Scale Build-Up

Carl E. Bingham
Robert B. Farrington

MASTER

January 1986

Prepared under Task No. 3001.10
FTP No. 465

Solar Energy Research Institute

A Division of Midwest Research Institute

1617 Cole Boulevard
Golden, Colorado 80401

Prepared for the
U.S. Department of Energy
Contract No. DE-AC02-83CH10093

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED *26*

Blank Page


PREFACE


Building space conditioning and water heating account for more than one-third of the nation's total energy consumption. Because solar energy can be efficiently captured at the low to moderate temperatures required for space conditioning and water heating, there is a good match among the resource, technology, and energy demand. In support of the Federal Government's goal to encourage the provision, both today and over the long term, of adequate, reliable, and reasonably priced energy supplies, DOE's Active Heating and Cooling (AHAC) Program supports research to develop the technology base that will allow the private sector to produce competitive active solar products and services.

The AHAC program consists of research on systems, components, and materials for solar cooling, heating, and domestic water applications. The technologies that are being pursued include heating, closed- and open-cycle absorption cooling, and liquid and solid desiccant cooling. The systems research associated with the AHAC program consists of analysis, experimental testing, and reliability testing and evaluation. The reliability research subelement is composed of identifying the causes and frequency of AHAC systems reliability problems and recommending appropriate research to improve the overall reliability of AHAC systems. Specific activities include laboratory testing of component reliability, outdoor exposure testing of materials and components, development of test standards for critical components, development of analysis techniques to estimate the effects of reliability on system performance and delivered energy cost, and evaluation of the performance of state-of-the-art AHAC systems. This report supports the AHAC reliability program by determining experimentally the degree of scale accumulation and analytically the effect of scaling on direct systems.

This report is one of three completed under the Component Reliability Program under the leadership of Charles Kutscher. The other reports are: Part 1: Test Results of Sensors Used in Control Systems, SERI/TR-253-2602, and Part 3: Development of a Fault Detection System, SERI/TR-253-2605. The U.S. Department of Energy, Office of Solar Heat Technology, provided the funding for this effort. This report was reviewed by Mary Linskens and Charles


Kutscher (SERI), Stanley W. Moore (Los Alamos National Laboratory), and Edward R. Durlak (the Naval Civil Engineering Laboratory).



Robert B. Farrington


Carl E. Bingham

Approved for

SOLAR ENERGY RESEARCH INSTITUTE


John P. Thornton, Manager
Thermal Systems and Engineering Branch


L. J. Shannon, Director
Solar Heat Research Division

SUMMARY

The objective of this work was to determine how much scale, caused by repeated filling and draining, accumulates in a flat-plate collector.

Laboratory testing of solar domestic hot water system components in FY 1983 showed that a significant amount of scale accumulated on draindown (drainout) valves, air vents, vacuum breakers, check valves subject to periodic draining on one side (such as when used as an isolation valve), and tempering valves. In FY 1984, we tested a flat-plate collector to measure the degree of scale accumulation caused by evaporation of water.

Testing over a period of one year and 9733 cycles caused a 7% decrease in collector volume because of scale, which is equivalent to uniform scaling of 0.25 mm. A 1-mm scaling thickness would decrease the heat removal factor by 6% and increase the absorber plate temperature and overall heat loss factor U_L by 5°C and 2%, respectively. This would result in a 13% reduction in the amount of energy collected. Homeowners in geographical areas where the water has a high potential for scaling should not use direct solar energy systems that use conventional flat-plate collectors unless they treat the water before it enters the system.

TABLE OF CONTENTS

	<u>Page</u>
1.0 Introduction.....	1
2.0 Testing.....	2
2.1 Procedure.....	2
2.2 Results.....	3
3.0 Analytical Model.....	7
4.0 Analytical Results.....	10
5.0 Conclusions and Recommendations.....	13
6.0 References.....	14
Appendix.....	15

LIST OF FIGURES

	<u>Page</u>
2-1 Laboratory Test Setup.....	2
2-2 Change in Collector Volume Caused by Scale.....	4
4-1 Scale Thickness versus Plate Temperature.....	11
4-2 Scale Thickness versus Efficiency and Removal Factors.....	12

LIST OF TABLES

	<u>Page</u>
2-1 Significant Scaling Loop Events.....	3
2-2 Collector Volume Measurements.....	5
2-3 Water Quality Test Results.....	6
4-1 Reference Collector Specifications.....	10

SECTION 1.0

INTRODUCTION

Farrington's (1984) tests on components for active solar energy systems using water as the transport medium reveal that a significant amount of scale (such as calcium carbonate) accumulated in air vents, vacuum breakers, check valves, draindown (drainout) valves, and tempering valves. Scale forms in pipes for one of two reasons. First, because the solubility of carbonates in water decreases with increasing temperature, carbonates will precipitate out of water in high temperatures, such as found in solar collectors. This could cause scale in tempering valves where the hot port serves as a heat source for the cold port. Argonne National Laboratory (1981) and Vitro Laboratories (1981) briefly reviewed scaling by precipitation, and Argonne (1979) discussed the prediction of calcium carbonate scaling in solar energy systems.

The second reason that scale forms is that minerals are deposited on the surface when water evaporates. As the water evaporates, the concentration of the minerals in the remaining water increases, eventually exceeding the saturation point in water, and the minerals precipitate out of the solution and onto nearby surfaces. This is the probable reason for scale accumulation in the other components mentioned.

Scale accumulation is a potential problem in direct solar energy systems that use flat-plate collectors primarily because of reduced heat transfer rates resulting in a reduction in system performance.

This report discusses the construction of a scaling loop and the results of repeatedly filling and draining the loop. An analytical model of scaling in solar collectors is then discussed along with the potential effect of scaling on their thermal performance. Finally, conclusions and recommendations from the experimental and analytical results are presented.

SECTION 2.0

TESTING

The best method to determine how scale affects collector performance is to have a certified collector testing facility measure performance before and after scale buildup. However, shipping the collector after the scaling test would probably dislodge much of the scale. Also, the collector would have to accumulate a large amount of scale before much confidence could be put into the results. The change in efficiency caused by the scale would have to be larger than the uncertainty of the measurement process. Therefore, we measured the degree of scaling by the change in volume of the collector (rather than change in collector performance) and later by dismantling the absorber plate.

2.1 PROCEDURE

We designed a test to determine the amount of scale accumulation in a flat-plate collector resulting from repeated filling and draining, such as in a draindown (drainout) system. The laboratory setup is shown in Figure 2-1. The tests were run with Golden, Colorado, tap water. We measured the water quality periodically and recorded the temperature, flow, and cycles regularly. Using a titration process with a measurement uncertainty of $\pm 5\%$, we determined the calcium hardness and total alkalinity.




Figure 2-1. Laboratory Test Setup

We also measured the conductivity ($\pm 5\%$) and the pH ($\pm 2\%$) of the water. These measurements were necessary to determine the Langelier Saturation Index (see the appendix).

The collector used for this test was a single-glazed 3 m^2 (32 ft^2) unit with a copper fin and tube absorber. A list of significant events is given in Table 2-1. The test loop initially circulated water at 71°C (160°F) through the collectors at 3.8 L/m (1 gpm) for 15 min and then drained for 15 min. We detected very little scale accumulation after 874 cycles, so we changed the circulation time to 5 min and draining to 25 min to increase the scaling rate. After 3716 cycles and still very little scale deposits, we increased the storage tank temperature to 93°C (200°F) to further speed up the rate of scaling.

2.2 RESULTS

The change in volume of a flat-plate collector caused by uniform scaling is shown in Figure 2-2. Uniform scaling along the pipe walls of only 10% of the pipe radius will reduce the collector volume by 19% or 519 mL of a 2.73-L collector. However, if the scale thickness is 20% of the pipe radius, the collector volume will decrease 36% (which is simply because the volume is proportional to the square of the radius).

Table 2-2 is a record of the measurements of the collector volume. Notice the very small standard deviation of the measurements. The standard deviations are 0.27% of the mean for the first set of measurements, 0.40% of the mean for the second set of measurements, 0.73% of the mean for the third set of measurements, and 1.3% of the mean for the fourth set of measurements. The random error of the measurements is therefore very small. Since we were concerned with the change in volume and not the absolute volume of the collector, the systematic error of the measurement from inaccuracies in the

Table 2-1. Significant Scaling Loop Events

Date	Event	Cycles Temperature ($^\circ\text{C}$)	Mean Tank Volume (mL)	Collector
4/26/84	Test began	0	71	2729.4
7/2/84	Moved experiment	864	--	--
8/16/84	Reduced circulation time to 5 min	874	71	2695.6
11/21/84	Increased tank temperature to 93°C	3716	93	2650.6
4/12/85	Test completed	9733	93	2535.2

graduated cylinder were not important as long as we used the same measurement procedure and equipment. Periodic inspection of the removable pipe section did not show any significant accumulation. Overall, the collector volume decreased by about 7.1%, which is equivalent to uniform scaling of 0.25 mm. After completion of the test, the absorber was dismantled and inspected. Visual inspection showed a trace of scaling in the absorber tubes, although the sections inspected appeared to have less than 0.25 mm scale.

The results of the water quality tests are shown in Table 2-3. In general, the water quality was fairly consistent. The Langelier Saturation Index (see the appendix), a qualitative measure of calcium carbonate saturation (when >0) or corrosion (when <0), was positive, which indicated a tendency to form scale from the precipitation of calcium carbonates. The Langelier Index does not predict the potential for scaling caused by evaporation, and it is very dependent on temperature; increasing the temperature from 10°C to 80°C increases the Langelier Saturation Index by about 1.2.

The Palin Index was calculated at 12.5 using the average measurements and 76°C , the highest temperature given for the Palin Index Factors in the Argonne report (1979). This value is at the high end of the scale-forming category, which is consistent with the results from the Langelier Saturation Index.




Figure 2-2. Change in Collector Volume Caused by Scale

Table 2-2. Collector Volume Measurements

Date	Number of Cycles	Measurement	Volume (mL)	Change in Volume (mL) (%)	
4/26/84	0	1	2726		
		2	2721		
		3	2726		
4/27/84	0	4	2739		
		5	2735		
		Mean	2729.4	0	0
		Std. dev.	7.4		
8/16/84	874	1	2694		
		2	2710		
		3	2694		
		4	2680		
		5	2700		
		Mean	2695.6	33.8	1.2
	Std. dev.	10.9			
11/21/84	3716	1	2679		
		2	2662		
		3	2635		
		4	2635		
		5	2642		
		Mean	2650.6	78.8	2.9
	Std. dev.	19.4			
4/12/85	9733	1	2497		
		2	2531		
		3	2527		
		4	2568		
		5	2594		
		6	2517		
		7	2523		
		8	2567		
		9	2493		
		Mean	2535.2	194.2	7.1
			Std. dev.	34.2	

Table 2-3. Water Quality Test Results

Date	Calcium Hardness (g/gal CaCO ₃)	Total Hardness (g/gal CaCO ₃)	Methyl Orange Alkalinity (g/gal CaCO ₃)	Conductivity (µmhos/cm)	pH _s	pH	Temperature (°F)	Langelier Index
04/27/84	11	--	10	580	6.6	8.0	165	1.4
05/07/84	10	--	10	540	6.7	7.7	165	1.0
05/08/84	11	--	11	470	6.6	8.1	165	1.5
05/10/84	11	--	10	440	6.6	8.0	165	1.4
05/11/84	11	--	10	480	6.7	8.0	165	1.3
05/14/84	11	--	11	540	6.6	8.0	165	1.4
05/23/84	10	--	10	500	6.8	7.9	165	1.1
05/29/84	10	--	11	360	6.7	8.0	165	1.3
06/05/84	10	--	11	490	6.6	7.8	165	1.2
06/11/84	10	--	10	490	6.7	7.9	165	1.2
06/18/84	8	--	9	450	6.8	7.9	165	1.1
11/20/84	12	18	14	600	6.4	7.8	165	1.4
11/21/84	12	17	13	700	6.4	8.2	165	1.8
11/27/84	13	18	14	680	6.4	7.8	165	1.4
11/28/84	12	18	13	720	6.4	7.6	165	1.2
11/29/84	12	17	13	630	6.4	7.8	165	1.4
12/20/84	12	16	13	510	6.3	7.9	195	1.6
12/27/84	12	17	13	550	6.3	7.9	195	1.6
01/04/85	11	15	12	500	6.3	7.8	195	1.5
01/08/85	12	16	13	630	6.3	7.9	195	1.6
01/15/85	11	15	13	530	6.3	7.9	195	1.6
02/26/85	10	13	10	580	6.5	7.9	195	1.4
03/06/85	10	14	10	580	6.5	8.2	195	1.7
03/14/85	9	13	11	560	6.5	7.9	195	1.4
03/21/85	10	12	10	610	6.5	7.5	195	1.0
03/28/85	10	14	10	620	6.5	7.9	195	1.4
04/05/85	9	13	10	600	6.6	7.8	195	1.2
04/11/85	9	12	9	540	6.6	7.9	195	1.3
\bar{x}	10.68	15.18	11.21	553	65.2	7.89		1.37
Std. dev.	1.19	±2.13	±1.55	±82	±0.15	±0.15		±0.20
Std. dev. (% of mean)	11	±14	±14	±15	±2	±2		±15

Multiply g/gal by 17.12 to obtain mg/L.

SECTION 3.0

ANALYTICAL MODEL

Scaling affects the performance of flat-plate collectors in several ways. One is the insulating effect of scale, which causes a higher plate temperature and greater heat losses to the cooler ambient air. We can determine this insulating effect by incorporating a fouling factor in the heat removal factor and heat loss coefficient. Severe scaling reduces the cross-sectional area of the collector passageways, leading to higher pressure drops in the system that cause lower flow rates, higher operating temperatures, and greater heat losses.

Baumeister (1967) gives information on fouling factors for heat exchangers. However, since fouling or scaling is generally not uniform, either dimensionally or with time, only average factors are given. This is a problem for our analysis since we want to understand how the varying thicknesses of scale affect collector performance.

The easiest way to approach this analytically is to determine the effect of scale accumulation on the heat removal factor F_R . Duffie and Beckman (1974) discuss in detail the important performance parameters of flat-plate collectors, including the development of all the major quantities used here.

The heat removal factor is defined as

$$F_R = P_1 [1 - \exp(-F'/P_1)] \quad , \quad (3-1)$$

where

$$P_1 = \frac{\text{collector mass flow rate } (\dot{m}) \times \text{collector fluid specific heat } (C_p)}{\text{collector area } (A_c) \times \text{collector overall heat loss factor } (U_L)}$$

F' = collector efficiency factor.

The collector efficiency factor is defined as

$$F' = \frac{1/U_L}{W \left\{ \frac{1}{U_L [D + (W - D)F]} + \frac{1}{C_b} + \frac{1}{\pi D_i h_i} \right\}} \quad , \quad (3-2)$$

where

U_L = collector overall heat loss factor

C_b = bond conductance between the tube and the fin

h_i = convective heat transfer coefficient between the collector fluid and the tube inside wall

D_i = tube inside diameter

D = tube outside diameter

W = distance between centerlines of tubes

F = fin efficiency.

The fin efficiency for straight fins with a rectangular cross section is given by

$$F = \frac{\tanh[m(W - D)/2]}{m(W - D)/2}, \quad (3-3)$$

where

$$m = (U_L/k\delta)^{1/2}$$

k = conductivity of the fin material

δ = fin thickness.

The denominator in Eq. 3-2 is the heat transfer resistance between the collector fluid and the ambient air. It is this factor that is modified to include the resistance from scaling. Each term of the denominator represents a separate thermal resistance. The denominator can be expressed as

$$1/U_o = W(1/C_a + 1/C_b + 1/C_f), \quad (3-4)$$

where

$1/U_o$ = heat transfer resistance between the fluid and the ambient air

$1/C_a$ = resistance between ambient air and the plate above the tube
($1/U_L[D + (W - D)F]$)

$1/C_b$ = resistance caused by the tube/plate bond $1/C_b$

$1/C_f$ = resistance caused by the convective heat transfer from the tube to the fluid ($1/\pi D_i h_i$).

In our analysis we changed C_f to represent the conductive heat transfer between the fluid and the scale by reducing the interior diameter of the tube by the thickness of the scale. We also added an additional term to account for the thermal resistance caused by the scale itself. Our underlying assumption is that the scale is smooth and of uniform thickness. This additional term is

$$1/C_s = \frac{\ln[D_i/(D_i - 2t)]}{2\pi k_s}, \quad (3-5)$$

where

$1/C_s$ = thermal resistance caused by the conductivity of scale

k_s = thermal conductivity of scale

t = thickness of scale.



The collector efficiency factor, including the scaling factor, is then

$$F' = \frac{1/U_L}{W(1/U_L[D + (W-D)F] + 1/C_b + \{\ln[D_i/(D_i-2t)]/2\pi k_s\} + 1/\pi(D_i-2t)h_i)} \quad (3-6)$$

If the conductivity of the scale was known, then we could calculate the effect of scale accumulation on F_R . However, this assumes that all of the parameters except t are independent of the scale accumulation, which is not completely accurate. The collector overall heat loss coefficient is a function of the absorber plate temperature, which increases with scale buildup.

If we use the heat conduction equation for a multilayer cylinder (Chapman 1974),

$$q = \frac{2\pi L(T_1 - T_3)}{[\ln(r_2/r_1)]/k_s + [\ln(r_3/r_2)]/k_t}, \quad (3-7)$$

where

- q = heat flow through cylinder (W)
- L = length of cylinder (m)
- T_1 = outer surface temperature, pipe ($^{\circ}\text{C}$)
- T_3 = inner surface temperature, scale ($^{\circ}\text{C}$)
- r_1 = outer radius of pipe (m)
- r_2 = inner radius of pipe (m)
- r_3 = inner radius of scale (m)
- k_s = scale thermal conductivity (W/m $^{\circ}\text{C}$)
- k_t = tube thermal conductivity (W/m $^{\circ}\text{C}$),

we can arrange the terms to determine the difference in temperature between the inner scale surface and the outer tube surface as a function of scale thickness ($r_2 - r_3$) as follows:

$$T_1 - T_3 = q \left\{ \frac{[\ln(r_2/r_1)]/k_s + [\ln(r_3/r_2)]/k_t}{2\pi L} \right\}. \quad (3-8)$$

This analysis enables us to estimate the rise in plate temperature caused by the conductivity of the scale. From this rise in plate temperature we estimate the subsequent rise in U_L for a given case using the relationship between the absorber plate temperature and the top loss coefficient given in Duffie and Beckman (1974). The elevated U_L is used to calculate the new fin efficiency F , collector efficiency factor F' , and the collector heat removal factor F_R .

SECTION 4.0

ANALYTICAL RESULTS

To put the analytical results in perspective we must first assess our assumptions. One assumption is that the scale is smooth and of uniform thickness. In reality, scale tends to build up locally and in varying thicknesses. Since it is difficult to predict the locations and local thicknesses of scaling we assume a smooth, uniform scaling for this analysis.

Another major assumption is that the increased pressure drop caused by scaling will not significantly lower the flow rate to a point where the elevated plate temperature (caused by the reduced flow rate) would affect the overall collector performance. The pressure drop across the collector is inversely proportional to the fifth power of the tube inner diameter (Crane Co. 1980). Reducing the inner diameter of the tubes by 2 mm to 5 mm increases the pressure drop fivefold. Note that if we reduce the flow rate in the collector significantly, the elevated plate temperature would reduce the collector heat removal factor F_R . However, our analysis did not include this effect.

Our analysis is based on a collector with the specifications listed in Table 4-1. The results presented here are primarily because of the increased resistance caused by the scaling, resulting in an increased plate temperature and higher heat loss.

If we take a case where we have a 1-m length of 9-mm (outside diameter) copper tube with a wall thickness of 1 mm, receiving 500 W/m^2 , we can determine that the ΔT across the tube wall with no scale is less than 0.1°C . Assuming the scale consists of calcium carbonate (CaCO_3) with a thermal conductivity of

Table 4-1. Reference Collector Specifications

Flow rate \dot{m}	0.06 kg/s (1.0 gpm)
Aperture A	3.0 m^2 (32.3 ft^2)
Back and edge heat loss coefficient U_{be}	$1.5 \text{ W m}^{-2} \text{ }^\circ\text{C}$ ($0.263 \text{ Btu/h ft}^2 \text{ }^\circ\text{F}$)
Tube spacing W	10.7 cm (4.2 in.)
Tube inside diameter	7 mm (0.28 in.)
Tube thickness	1 mm (0.04 in.)
Bond conductance C_b	$1000 \text{ W/m }^\circ\text{C}$ ($580 \text{ Btu/h ft }^\circ\text{F}$)
Fluid heat transfer coefficient h_i	$300 \text{ W/m}^2 \text{ }^\circ\text{C}$ ($52.8 \text{ Btu/h ft}^2 \text{ }^\circ\text{F}$)
Fin thickness	0.5 mm (0.02 in.)
Plate emittance	0.10
Number of covers	1
Wind heat loss coefficient	$5 \text{ W/m}^2 \text{ }^\circ\text{C}$ ($0.88 \text{ Btu/h ft}^2 \text{ }^\circ\text{F}$)

0.6 W/m°C (Thermophysical Research Center 1970), we can determine the temperature drop across the tube wall and scale as a function of scale thickness. The results as portrayed in Figure 4-1 show that with severe scaling (a thickness of 2 mm) the ΔT across the tube and scale is about 12°C. This increases the overall collector loss coefficient U_L .

If we assume an initial plate temperature of 60°C and an ambient temperature of 10°C, we can use the graphs in Duffie and Beckman (1974) to estimate the collector top loss coefficient U_t . Using the relationship

$$U_L = U_t + U_{be} \tag{4-1}$$

where U_{be} is the collector back and edge loss coefficient, we may determine a new U_L to calculate the fin efficiency F using Eq. 3-3, the collector efficiency factor F' using Eq. 3-5, and the collector heat removal factor F_R using Eq. 3-1.

The results of this analysis are shown in Figure 4-2. The 0.25-mm and 1-mm scale in our reference collector should result in a 1% and 6% reduction in the collector efficiency factor F' , respectively. Similar results for the collector heat removal factor F_R are shown in Figure 4-2.




Figure 4-1. Scale Thickness versus Plate Temperature




Figure 4-2. Scale Thickness versus Efficiency and Removal Factors

SECTION 5.0

CONCLUSIONS AND RECOMMENDATIONS

Our test results show some scale accumulation from repeated wetting and drying of the collector. However, scale buildup from evaporation does not appear to be a significant problem. We are now operating a collector loop to determine the accumulation of scale from precipitation when the collector is a heat source.

Our analytical results show that even scale accumulation as thin as 1 mm can significantly reduce system performance (by 13%). Clearly, users in geographical areas that have water with a high potential for scaling or a history of a scale buildup should consider using treated water in their solar systems or consider using indirect systems with heat exchangers easily accessible for clearing or replacement.

SECTION 6.0

REFERENCES

- Argonne National Laboratory, 1979 (Aug.), Prediction of Calcium Carbonate Scaling from Water in Solar-Energy Systems, ANL/SDP-TM-79-7, SOLAR/0905-79/70, Argonne, IL: ANL.
- Argonne National Laboratory, 1981 (Sept.), Final Reliability and Materials Guidelines for Solar Domestic Hot-Water Systems, ANL/SDP-11, SOLAR/0909-81/70, Argonne, IL: ANL.
- Baumeister, Theodore, ed., 1967, Standard Handbook for Mechanical Engineers, New York: McGraw-Hill.
- Chapman, Alan J., 1974, Heat Transfer, 3rd ed., New York: MacMillan.
- Crane Co., 1980, "Flow of Fluids," Tech Paper 410, New York: Crane Co.
- Duffie, J., and W. Beckman, 1974, Solar Energy Thermal Processes, New York: John Wiley and Sons.
- Farrington, R., 1984 (July), Failure Testing of Active Solar Energy Components, SERI/TR-253-2187, Golden, CO: Solar Energy Research Institute.
- Thermophysical Research Center, Purdue University, 1970, Thermophysical Properties of Matter, Vol. 2: Thermal Conductivity of Non-Metallic Solids, Lafayette, IN: Purdue University.
- Vitro Laboratories, 1981 (Dec.), Corrosion and Scaling in Solar Heating Systems, SOLAR/0909-81/70, Silver Spring, MD: Vitro.

APPENDIX

LANGELIER SATURATION INDEX*

The Langelier Saturation Index (LI), a measure of a solution's ability to dissolve or deposit calcium carbonate, often is used as an indicator of the corrosiveness of water. The index is not related directly to corrosion but is related to the deposition of a calcium carbonate film or scale that can insulate pipes, boilers, and other components of a system from contact with water. When no protective scale is formed, water is considered to be aggressive and corrosion can occur. Highly corrosive water can cause system failures or result in health problems from dissolved lead and other heavy metals. On the other hand, an excess of scale can damage water systems, necessitating repair or replacement.

The Langelier Index is defined as the difference between actual pH (measured) and calculated pH_s (the pH at which water is saturated with calcium carbonate). The magnitude and sign of the LI value show a water's tendency to form or dissolve scale and thus inhibit or encourage corrosion.

Although information obtained from the LI is not quantitative, it can be useful in estimating water treatment requirements for low pressure boilers, cooling towers, and water treatment plants and in serving as a general indicator of the corrosiveness of water.

The index is a gauge of whether water will precipitate or dissolve calcium carbonate. If the pH_s is equal to the actual pH, the water is considered "balanced." This means that calcium carbonate will not be dissolved or precipitated. If the pH_s is less than the actual pH (the LI is a positive number), the water tends to deposit calcium carbonate and is scale-forming (nonaggressive). If the pH_s is greater than the actual pH (the LI is a negative number), the water is not saturated and will dissolve calcium carbonate (aggressive).

Remember, the LI value is not a quantitative measure of calcium carbonate saturation or corrosion.

*Taken from Hach Analytical Procedure Publication 8073 "Langelier and Aggressive Indices."

SELECTED DISTRIBUTION LIST

Aeolian Kinetics
P.O. Box 100
Providence, RI 02901
Attn: Mr. Ralph Beckman

Alabama Solar Energy Center
University of Alabama
Huntsville, AL 35899
Attn: Dr. Gerry Guinn

ALTEN
2581 Leghorn Street
Mountain View, CA 94043
Attn: Mr. Barry P. Scott

American Mechanical Supply
3080 South Zuni
Englewood, CO 80110
Attn: Mr. Jay Stein

American Society of
Mechanical Engineering
United Engineering Center
345 East 47th Street
New York, NY 10017
Attn: Ms. Diane Kaylor, News Editor

American Solar Energy Society
1230 Grandview Avenue
Boulder, CO 80302

American Solar King Corporation
P.O. Box 2512
Waco, TX 76702-2512
Attn: Mr. James Coellner

Archer Industries
142 South Hale Avenue
Escondido, CA 92025
Attn: Mr. Mike Landry

Mr. Peter Armstrong
715 Peterson Street
Fort Collins, CO 80524

Astron
5604 Departure Drive
Raleigh, NC 27604
Attn: Mr. John J. Buzenberg

Argonne National Laboratory
Building 362
9700 South Cass Avenue
Argonne, IL 60439
Attn: Mr. William Shertz

Mr. Steven Baker
Solar and Architectural Consultant
360 East 15th Avenue
Eugene, OR 97401

Bear Solar Company
P.O. Box 3684
Evergreen, CO 80439
Attn: Mr. Gary A. Williams

Mr. Jurg Bieri
4910 Seaport Avenue
Richmond, CA 94804

Bio-Energy Systems Company
Besicorp Group, Inc.
P.O. Box 191
Ellenville, NY 12428
Attn: Mr. George J. Peteya, Jr.

Brookhaven National Laboratory
Building 475
Upton, NY 11973
Attn: Mr. William Wilhelm

Business Publishers, Inc.
951 Pershing Drive
Silver Spring, MD 20910
Attn: Mr. Allan L. Frank

California Polytechnic
State University
Agr. Engineering Department
San Luis Obispo, CA 93407
Attn: Professor Ed Carnegie

California State University
6000 "J" Street
Sacramento, CA 95819
Attn: Dr. Jim Berguam

Centre of Energy Studies
Indian Institute of Technology
New Delhi-16
INDIA
Attn: Dr. Tara Chandra Kandpal

Colorado State University
Department of Mechanical Engineering
Fort Collins, CO 80523
Attn: Dr. S. Karaki

Colorado State University
Department of Mechanical Engineering
Fort Collins, CO 80523
Attn: Dr. Byron Winn

Contemporary Systems, Inc.
Route 12
Walpole, NH 03608
Attn: Mr. John Christopher

Mr. Charles Dahl, P.E.
3613 Willowick Drive
Ventura, CA 93003

Danish Solar Energy Testing Lab
Technological Institute
P.O. Box 141
Taastrup, DENMARK
Attn: Mr. Torkild Vest Hansen,
Manager

Davis Energy Group
2655 Portage Bay Avenue, Suite #1
Davis, CA 95616
Attn: Mr. Jack Androvich

DMNES
P.O. Box 1830
Limassol, Cyprus
Attn: Mr. Mike Merino

DSET Laboratories
Box 1850 Black Canyon Stage I
Phoenix, AZ 85029
Attn: Mr. Matthew Rupp

Energy Contractors Group
13161 Newhope Street
Garden Grove, CA 92643
Attn: Mr. Guy Rohlfs Voss

Energy Systems Centre
Ontario Research Foundation
Mississauga, Ontario
CANADA L5K 1R3
Attn: Mr. Bruce E. Sibbitt

Environment One Corporation
2773 Balltown Road
Schenectady, NY 12309
Attn: Mr. George A. Vorsheim, Jr.

ETEC
Rockwell International Corporation
P.O. Box 1449
Canoga Park, CA 91304
Attn: Mr. J. Balkwill, T036

ETEC
Rockwell International Corporation
P.O. Box 1449
Canoga Park, CA 91304
Attn: Mr. Paul Pekrul

Florida Power and Light
P.O. Box 529100
Miami, FL 33152
Attn: Mr. Tom Headley

Florida Solar Energy Center
300 State Road 401
Cape Canaveral, FL 32920-4099
Attn: Mr. Charles J. Cromer, P.E.

Florida Solar Energy Center
300 State Road 401
Cape Canaveral, FL 32920-4099
Attn: Mr. Jim Huggins

Florida Solar Energy Center
300 State Road 401
Cape Canaveral, FL 32920-4099
Attn: Ms. Iraida B. Rickling,
University Librarian

Florida Solar Energy Center
300 State Road 401
Cape Canaveral, FL 32920-4099
Attn: Dr. James D. Roland



Florida Solar Energy Center
300 State Road 401
Cape Canaveral, FL 32920-4099
Attn: Mr. Marvin Yarosh

Dr. Jeff M. Gordon
University of Colorado
Civil Engineering Department
Campus Box 428
Boulder, CO 80309

Heliotope General
3733 Kenora Drive
Spring Valley, CA 92077
Attn: Mr. Sam Dawson

Honeywell, Inc.
Technology Strategy Center
1700 West Highway 36
Roseville, NM 55113
Attn: Mr. Bob Aasen

Independent Energy, Inc.
P.O. Box 1305
42 Ladd Street
East Greenwich, RI 02818
Attn: Mr. Fred Bootz,
Director of Marketing

King Saud University
P.O. Box 800
Riyadh
SAUDI ARABIA 11421
Attn: Dr. Ing. H. Sifrata

KLR Engineering
438 Washington Street
Keane, NH 03431
Attn: Mr. Joe Kohler

Korea Institute of Energy
and Resources
P.O. Box 339
Taejeon
Chungnam, SOUTH KOREA
Attn: Dr. Paul Auh

Korea Institute of Energy
and Resources
P.O. Box 339
Taejeon
Chungnam, SOUTH KOREA
Attn: Dr. Lee Jong Ho

Dr. Jan F. Kreider, P.E.
Consulting Engineer
1455 Oak Circle
Boulder, CO 80302

Lawrence Berkeley Laboratory
University of California
Building 90-2024
Berkeley, CA 94720
Attn: Dr. Mashuri Warren

Los Alamos National Laboratory
Mail Stop J 576
P.O. Box 1663
Los Alamos, NM 87544
Attn: Mr. John Avery

Dr. Peter Lunde
4 Daniel Lane
W. Simsbury, CT 06092

NASA-Kennedy Space Center
SI-PEI-1
Kennedy Space Center, FL 32899
Attn: Mr. Jim Orr

Dr. Ali M. El Nashar
Water and Electricity Department
P.O. Box 219
Abu Dhabi
United Arab Emirates

National Bureau of Standards
Thermal Solar Group
Building 226, Room B-322
Gaithersburg, MD 20899
Attn: Dr. Hunter Fanney

National Bureau of Standards
Building 226, Room B-320
Gaithersburg, MD 20899
Attn: Mr. Robert Dickers

National Technical University
of Athens
School of Chemical Engineering
Thermodynamics and Transport
Phenomena Laboratory
Athens 147, GREECE GR-106 82
Attn: Dr. John Palyvos

Naval Civil Engineering Lab
Port Hueneme, CA 93043
Attn: Mr. Ed Durlak (Code L73)

New Mexico Energy Research and
Development Institute
Room 358, Pinon Building
1220 South St. Francis Drive
Santa Fe, NM 87501
Attn: Mr. Steve Parker,
Project Scientist

New Mexico Solar Energy Institute
Box 3SOL
Las Cruces, NM 88003
Attn: Dr. Roger Farrer

North Carolina A&T State University
Mechanical Engineering Department
Greensboro, NC 27420
Attn: Dr. Tony Min

North Carolina A&T State University
Mechanical Engineering Department
Greensboro, NC 27411
Attn: Dr. David Klett

Novan Energy, Inc.
1630 North 63rd Street
Boulder, CO 80301
Attn: Mr. Peter Jacobs

Oregon Department of Energy
Labor and Industries Building
Room 102
Salem, OR 97310-0831
Attn: Mr. David Robison

Pacific Gas and Electric Company
77 Beale Street
Room A-1256
San Francisco, CA 94106
Attn: Mr. Jonathan Costa

Penn State University
P.O. Box 519
Uniontown, PA 15401
Attn: Prof. David B. Meredith

Public Works Canada
Solar Programs Office
Sir Charles Tupper Building
Ottawa, Ontario
CANADA K1A 0M2
Attn: Mr. Peter Sauer

Pyramid Controls
421-16 North Buchanan Circle
Pacheco, CA 94553

Ramada Energy Systems
1421 South McClintock
Tempe, AZ 85281
Attn: Mr. John Gamero-Abarca

Raypack, Inc.
3111 Agoura Road
Westlake Village, CA 91361
Attn: Mr. Allan Boniface

Red Rocks Community College
12600 West 6th Avenue
Golden, CO 80401
Attn: Mr. Jon Klima

Reynolds Metals Company
P.O. Box 27003
Richmond, VA 23261
Attn: R. Spears

Rho Sigma/Watsco, Inc.
1800 West Fourth Avenue
Hialeah, FL 33010
Attn: Dr. Joseph Mibelli

Robert Shaw Controls Company
Uni-Line Division
P.O. Box 2000
Corona, CA 91718-2000
Attn: Mr. Warren Hubert

Royal Scientific Society
P.O. Box 5211
Amman, JORDAN
Attn: Mr. Malek Kabariti



Sacramento Municipal
Utility District
P.O. Box 15830
Sacramento, CA 95852-1830
Attn: Mr. Donald Kazama

Mr. Bob Schuman
1090 Youngfield Street
Golden, CO 80401

Science Applications
International Corp.
5113 Leesburg Pike
Suite 710
Falls Church, VA 22041
Attn: Mr. William Scholten

Select Sun Energy Systems
715-2 Whitney Avenue
Lantana, FL 33482
Attn: M. Burm

Solar Development, Inc.
3630 Reese Avenue
Garden Industrial Park
Riviera Beach, FL 33404
Attn: Mr. Donald J. Kazimir

Solar Industries, Inc.
2300 Highway 34
Manasquam, NJ 08736
Attn: Mr. Dave Sizelove

Solaron Corporation
1885 West Dartmouth Avenue
Englewood, CO 80110
Attn: Mr. M. Faybik

Solaron Corporation
1885 West Dartmouth Avenue
Englewood, CO 80110
Attn: Dr. George Lof

Solartrope
3060 East La Palma
Anaheim, CA 92806
Attn: Mr. Frank Sagara

Solcan Ltd.
RR3 London
Ontario, CANADA
N6A 4B7
Attn: Mr. Peter Swartman

State of Wisconsin
Division of State Facilities Mgmt.
Bureau of Energy
101 South Webster Street, 8th Floor
Madison, WI 53702
Attn: Mr. George J. Alfano

Sunbelt Energy Corporation
2686 South Tejon
Englewood, CO 80110
Attn: Mr. Mike Davis

Sunland
1115 Chestnut
Burbank, CA 91506
Attn: Mr. Dick Talbert

Sunlok Energy Systems of Central
Oregon
P.O. Box 6957
Bend, OR 97708
Attn: Mr. Ron Kiepert

Sunmaster Corporation
35 West William Street
P.O. Box 1077
Corning, NY 14830
Attn: Mr. Michael Platt, P.E.

Swedish Council for
Building Research
Sankt Goransgatan 66
S-11233
Stockholm, SWEDEN
Attn: Mr. Hans E. B. Andersson

C. J. Swet
7040 Woodville Road
Mt. Airy, MD 21771

Tata Energy Research Institute
7 Jorbagh
New Delhi - 110003
INDIA
Attn: Dr. Veena Joshi



Tennessee Valley Authority
MR 3S-43E
1101 Market Street
Chattanooga, TN 37402-2801
Attn: Mr. Dale Depew

Tennessee Valley Authority
3S-44D Signal Place
1101 Market Street
Chattanooga, TN 37402-2801
Attn: Mr. Stephen Ira

Tennessee Valley Authority
MR 3S-40E
1101 Market Street
Chattanooga, TN 37402-2801
Attn: Mr. Gasper DeGaetano

Tennessee Valley Authority
SP 1S-71A-C
1101 Market Street
Chattanooga, TN 37402-2801
Attn: Mr. Dale Smotherman

Texas Tech University
Department of Mechanical Engineering
Lubbock, TX 79409-4289
Attn: Dr. Jerry Dunn

Mr. William Thompson
1570 Swadley Street
Lakewood, CO 80215

Trident Energy Systems
1355 Willow Way
Concord, CA 94520
Attn: David Horne

U.S. Solar Corporation
P.O. Drawer K
Hampton, FL 32044
Attn: Dr. W. Farber,
Vice President

U.S. Department of Energy
Forrestal Building
1000 Independence Avenue, S.W.
Washington, D.C. 20585
Attn: Mr. Robert Hassett
CE-311, 5H-065

U.S. Department of Energy
Forrestal Building
1000 Independence Avenue, S.W.
Washington, D.C. 20585
Attn: Dr. Fred Morse
CE-31, 5H-095

U.S. Department of Energy
Forrestal Building
1000 Independence Avenue, S.W.
Washington, D.C. 20585
Attn: Mr. Dave Pellish
CE-312, 5H-047

Universidad Politecnica
Department: Termodinamica
P.O. Box 22012
Valencia, SPAIN
Attn: Prof. J. Canada Ribera

University of California
Department of Mechanical Engineering
Irvine, CA 92717
Attn: Dr. M. Young

University of Houston
Department of Mechanical Engineering
University Park
Houston, TX 77004
Attn: Dr. Rick Bannerot

University of Nebraska
4911 Davenport
Omaha, NE 68132
Attn: Dr. Bing Chen

University of Wisconsin
1343 Engineering Research Building
Madison, WI 53706
Attn: Dr. W. Beckman

Vitro Laboratories
14000 Georgia Avenue
Silver Spring, MD 20910
Attn: Mr. Ed Pollock

Wyle Labs
Solar Lab
7800 Governors Drive West
Huntsville, AL 35807
Attn: Mr. Joseph Matzkiw



Professor John Yellott
901 West El Caminito Drive
Phoenix, AZ 85021

SERI Staff:

Gordon Gross
Chuck Kutscher
Al Lewandowski
Mary Linskens
Daryl Myers
Paul Notari
Ken Olsen
Doug Powell
Jim Pruett
Steve Rubin
Walter Short
Chet Wells