

NUREG/CR-0401

SAND78-1452

Unlimited Release

R-2

MASTER

**Qualification Testing Evaluation Program  
Light Water Reactor Safety Research  
Quarterly Report**

**April - June 1978**

Lloyd L. Bonzon, Kenneth T. Gillen, Lowell H. Jones, Edward A. Salazar

Printed November 1978

This report documents a part of the Qualification Testing Evaluation (QTE) Program being conducted by Sandia Laboratories.



**Sandia Laboratories**

SF 2900 Q(7-73)

**Prepared for  
U. S. NUCLEAR REGULATORY COMMISSION**

**DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED**

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

---

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

## NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, or any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

The views expressed in this report are not necessarily those of the U. S. Nuclear Regulatory Commission.

Available from  
National Technical Information Service  
Springfield, VA 22161

NUREG/CR-0401  
SAND78-1452  
Unlimited Release  
R-2

QUALIFICATION TESTING EVALUATION PROGRAM:  
LIGHT WATER REACTOR SAFETY RESEARCH.  
QUARTERLY REPORT

APRIL - JUNE 1978

Lloyd L. Bonzon  
Kenneth T. Gillen  
Lowell H. Jones  
Edward A. Salazar

Program contact: L. L. Bonzon, 4432

Manuscript Submitted: August 1978 ✓  
Date Published: November 1978

APPROVED:

*S. J. McLean*  
Manager, Nuclear Fuel Cycle Safety Research Department

*W. W. Rogers*  
Director, Nuclear Fuel Cycle Programs Directorate

Sandia Laboratories  
Albuquerque, NM 87185  
operated by  
Sandia Corporation  
for the  
U.S. Department of Energy

NOTICE  
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Prepared for  
Research Support Branch  
Office of Water Reactor Safety Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555  
Under Interagency Agreement DOE 40-550-75  
NRC FIN No. A-1051-8

#### AUTHOR CREDITS

Author credits for the abstracted topical sections are shown in the report. Section 1 and the general subsections of Sections 2 and 3 were written and edited by L. Bonzon. The general subsection of Section 4 was written by K. Gillen, E. Salazar, and R. Clough, and arranged and edited by L. Bonzon.

## CONTENTS

	<u>Page</u>
<u>Chapters</u>	
1. Programmatic Overview	11
1.1 Task 1 - Qualification Testing Methodologies Assessment	13
1.2 Task 2 - Radiation Qualification Source Evaluation	14
1.3 Task 3 - Accelerated Aging Study	15
1.4 Quarterly Programmatic and Common-Task Activities	17
1.5 Publications/Presentations	23
1.6 References	31
2. Qualification Testing Methodologies Assessment	33
2.1 Task 1 - Technical Activities Summary	33
2.2 Class 1E Equipment Identification	37
2.2.1 Study Scope	37
2.2.2 Systems Descriptions and Environmental Design Criteria	39
2.2.3 Class 1E Equipment Lists	42
2.2.4 Generic Equipment Data Packages	45
2.2.5 Summary and Discussion	47
2.3 References	49
3. Radiation Qualification Source Evaluation	50
3.1 Task 2 - Technical Activities Summary	50
3.2 Calculations to Support Radiation Simulators Adequacy Assessments	52
3.2.1 Cable Model and Methods of Calculation	53
3.2.2 Calculations and Results	55
3.2.3 Discussion	58
3.3 References	62
4. Accelerated Aging Study	63
4.1 Task 3 - Technical Activities Summary	63
4.2 Aging Facilities	66
4.2.1 Low-Intensity Radiation Aging Facility	67
4.2.2 Thermal Aging Facility	77
4.3 References	79

## ILLUSTRATIONS

	<u>Page</u>
<b>Figure</b>	
2.1a Containment accident design envelope, pressure-time	43
2.1b Containment accident design envelope, temperature-time	43
3.1 Model of the power cable	54
3.2 Comparison of depth-dose for Co-60 and Cs-137 with airborne gamma rays (Source 1). The isotopic source results have been normalized at the outer zone (surface) of Hypalon	59
3.3 Comparison of depth-dose for Co-60 with airborne betas (Source 1); Co-60 result normalized to the average dose at the surface	59
3.4 Comparison of depth-dose for Co-60 and Cs-137 with plate- out gamma rays (Source 1). Both the Co-60 and Cs-137 results have been normalized to the average surface dose	60
3.5 Comparison of depth-dose for Co-60 (normalized at average dose in surface zone) with plate-out betas (Source 1)	60
3.6 Comparison of depth-dose for Co-60 (normalized to average dose in surface zone) with waterborne gamma rays (Source 1)	61
3.7 Comparison of depth-dose for Co-60 (normalized to average dose in surface zone) with waterborne betas (Source 1)	61
4.1 Low-intensity cobalt array (LICA) test facility	68
4.2 Linear array radiation source and test chamber arrangement	69
4.3 Typical heater test cell	71
4.4 Current LICA arrangement with approximate centerline dose rates noted for each test cell holder	72
4.5 Dose rate parallel to linear cobalt array in closest test chambers, level I	74
4.6 Vertical dose rate profile along center of level I (outside) can	75
4.7 A. Dosimeter chip location for radial mapping; B. Radial dose rate results; C. Sample basket configuration	76
4.8 Section view of temperature aging chamber	78

## TABLES

	<u>Page</u>
<b>Table</b>	
1.1 Session: Environmental Equipment Qualification	22
1.2 Industry Liaison	24
2.1 In-Containment Systems Description	40
2.2 Containment Environmental Parameters for the Generic PWR	41
2.3 Accident Integrated Air Dose	44
2.4 NG System Class 1E Equipment	46
3.1 Guide Sources Specifications	53
3.2 Charge Deposition in the Cable	57

QUALIFICATION TESTING EVALUATION PROGRAM  
LIGHT WATER REACTOR SAFETY RESEARCH  
QUARTERLY REPORT

APRIL - JUNE 1978

1. Programmatic Overview

Programs were initiated in late 1974 to evaluate the significance of synergistic effects in post-loss-of-coolant accident (LOCA) testing of Class 1E equipment. As a result of these activities, two complementary tasks were identified and initiated in late 1975; these were (1) to evaluate and improve accelerated aging methodologies, and (2) to determine the nuclear source term as specified in Regulatory Guide 1.89.1.1. In late 1976 these three tasks were integrated into a broader program, Qualification Testing Evaluation (QTE), the goal of which was to evaluate the overall adequacy of the qualification testing of safety-related equipment and to resolve specific anomalies and uncertainties with qualification testing as outlined in IEEE-323-1974.<sup>1,2</sup>

The objectives of the QTE program are to obtain data needed for confirmation of the suitability of current standards and regulatory guides for Class 1E safety-related equipment and to obtain data that will provide an improved technical basis for modifications of these standards and guides where appropriate. Specific major objectives of the research are as follows:

1. To provide assessments of post-LOCA qualification testing methodologies, including a qualitative assessment of the synergistic effects resulting from the combined environmental testing of representative Class 1E equipment;

2. To determine the radiation environment from the nuclear source term for a design basis LOCA and evaluate the adequacy of radiation simulators; and
3. To provide methods that can be used to simulate the natural aging process of representative Class 1E materials by accelerated aging methods.

This program addresses three distinct tasks of concern in the type-testing of Class 1E equipment which reflect the objectives stated above. Under Task 1, LOCA testing methodologies and anomalies will be studied to define testing details and to identify potential weaknesses in safety-system components and materials. For example, the possible existence of synergistic effects will be determined for a range of typical components. These synergisms would result from the simultaneous applications of the LOCA environments as compared with the sequential application of radiation, followed by the other LOCA environments, on identical components.

The Task 2 effort involves an assessment of the prescribed LOCA-radiation sources magnitudes, an evaluation of existing radiation simulators, an evaluation of component response to the LOCA-radiation signature, and the development of guidelines and rationale for use of radiation simulators in typetesting of Class 1E components.

Typetesting requires a component which is "aged" to simulate normal degradation during its design life under exposure to the ambient environments existing in nuclear power plants. In Task 3, a proposed accelerated aging method will be experimentally verified for single and combined stress (i.e., potentially synergistic) environments and, where available, "benchmark" data will be obtained from naturally-aged materials existing in nuclear power plants.

### 1.1 Task 1 - Qualification Testing Methodologies Assessment

The FY78 effort under this task is concentrated in seven broad areas and numerous related subtasks.

1. LOCA typetests have been conducted, sequentially and simultaneously, on several Class 1E systems: electrical cables, connector assemblies, and splice assemblies. One additional test in this series is scheduled; tests interpretations, evaluations and documentation will be completed.

2. A major effort will be the completion and approval of a comprehensive test plan to be used as the long-range coordinating plan for the LOCA-testing methodologies study. This subtask is supported by the test facility upgrade and vulnerability evaluation subtasks.

3. A test facility upgrade proposal is being prepared and the test facility upgraded to: (a) accommodate larger and more diverse Class 1E test items; and (b) allow selectable radiation dose rates and minimize radiation spatial gradients. The facility upgrade will include new radiation sources, source positioning equipment, facility shielding and cell modifications, test chambers, and diagnostic/test equipment.

4. A basis for the test plan is an evaluation of the apparent "LOCA-sensitivity" of safety-related equipment. A specific data base for this vulnerability evaluation is being obtained by subcontract to an architect-engineer, and will include Class 1E equipment lists, manufacturers, normal and accident environments definition, and comprehensive data packages for each equipment item.

5. Offsite data to complement the Sandia test data will be acquired, as availability allows, through subcontracts to manufacturers, testing laboratories, etc. Offsite expertise will be used to review the test plan and facility upgrade proposal as appropriate. As the testing schedule

requires, offsite testing may be conducted to serve as benchmarks or supplements to the Sandia test effort, especially during the period of test plan and facility development.

6. Initial planning and definition will be conducted under a subtask to provide an assessment of the design adequacy (DAA) of Class 1E systems subject to LOCA-caused nonrandom multiple failures, with the objective of evaluating qualification test methods as to their validity in predicting performance under LOCA-environment conditions. As currently envisioned, the subtask outlined includes: (a) identification of "most important" and "most sensitive" safety-related equipment; (b) survey of manufacturers to identify representative designs/manufacturers used in current plant designs; (c) selection of generic designs by performing a preliminary DAA to identify potential failure modes; (d) conducting detailed DAA on these generic designs to identify failure modes; (e) conducting quality control audits during manufacture, installation, and use; (f) conducting tests and/or typetests to assess design adequacy.

7. At the specific request of the Commission, additional tests of connectors in a simulated LOCA environment will be defined and conducted using connectors qualified according to the IEEE-323 standards.<sup>1.2,1.3</sup>

## 1.2 Task 2 - Radiation Qualification Source Evaluation

The FY78 effort under this task is concentrated in five broad areas and related subtasks.

1. Additional source specification calculations based on the latest Regulatory Guide 1.89 guidelines,<sup>1.4</sup> and complementing previous calculations,<sup>1.5</sup> will be completed. These calculations will investigate, parametrically, various implicit, explicit, and unspecified assumptions in the Guide.

2. Based on these calculated radiation signatures (energy release rate, energy/number spectra, and particle type), a preliminary evaluation of the adequacy of currently used radiation simulators to duplicate the

environments will be made. The evaluation will be based on "equivalence" of dose rate, depth-dose, and charged-particle distribution profiles in typical Class 1E equipment.

3. The assessment of radiation damage to Class 1E equipment from the dose-rate and depth-dose profiles will be completed. The objective of this subtask is to specify how closely the matching of dose rate, depth-dose, etc., must be accomplished to assure equivalence of damage by radiation simulators.

4. A "best-estimate" LOCA radiation signature will be defined and will be based on the accident-time-release sequencing as specified in WASH-14001.6 and other references.1.7,1.8,1.9 The signature will eliminate several unrealistic, but conservative, assumptions specified in Regulatory Guide 1.89 and may be the basis of a revised Guide.

5. Depending on the results of these subtasks, effort may be directed toward (a) tailoring/designing of simulators to achieve better duplication of the actual component damage profiles, (b) devising benchmark calculations of LOCA radiation environments and component damage to assist in the evaluation of the computational capabilities of Class 1E equipment qualifiers, and (c) developing guidelines and rationale for the use of simulators in typetesting.

### 1.3 Task 3 - Accelerated Aging Study

The FY78 effort under this task is concentrated in eight broad areas and numerous related subtasks.

1. Single environment aging tests are being conducted on electrical cable materials; elongation is used as the measure of damage in these tests. Single environment acceleration functions of damage versus time will be obtained.

2. Aging tests in combined radiation and temperature environments will be conducted in order to determine the importance of synergisms and to test the method postulated for combined environment accelerated aging.

3. Tests to evaluate environmental rate effects will be conducted. Of particular concern are the rate effects associated with oxygen diffusion and radiation.

4. Alternate indicators of damage will continue to be investigated under this task. Examples of such indicators are voltage-withstand, mandrel-bend tests and dissipation factor; these tests closely parallel current industry failure criteria which require "functionability" of electrical cable.

5. The acquisition and analyses of ambient-aged cable (when available) to serve as benchmarks to the accelerated aging tests will continue. Prior experience indicates that the nuclear plant ambient environments are poorly defined; unless reliable environmental information can be obtained, ambiently aged cable samples are of limited value to the task.

6. As an alternate to accelerated aging methods, other methods of estimating age or equipment life will be evaluated. Such a method could employ "sacrificial samples"; resistance to aging degradation for "short" periods of time would be experimentally verified and requalification tests utilized to extrapolate the remaining acceptable "life" of the equipment.

7. Preliminary extensions of all these efforts will be made, perhaps including extensions to other ambient environments (e.g., mechanical stress, other gaseous environs, humidity), other Class 1E equipment or materials, and to older style cables currently installed in nuclear power plants.

8. The effect of aging on the retention or degradation of fire-retardant additives in electrical cable will be investigated. Test specimens will be made of the common polymer materials and known fire-retardant additives; these will be subjected to accelerated aging and undergo quantitative testing to determine change in flammability with age.

#### 1.4 Quarterly Programmatic and Common-Task Activities

The several programmatic activities necessary for continuity and development are highlighted in this section. Technical activities specific to each task are in Sections 2.1, 3.1, and 4.1 which follow.

Program Reviews with NRC Staff: On April 21, W. Rutherford requested information on qualification testing facilities capability and costing. This was followed, on May 2, with a telecon request by W. Rutherford, R. Feit, and G. Bennett to transmit the Class 1E equipment lists (developed by UEC under contract to Sandia) to assist Inspection and Enforcement (IE) staff in their response to the Commission directive to develop a "Plan for an Analysis of Alternatives for Conducting Independent Verification Testing of Environmentally Qualified Equipment." The requested information was transmitted by letter dated May 5, 1978.

A "Plan to Investigate the Adequacy of Quality Assurance Practices for NRC-Sponsored Confirmatory Research Programs" was discussed by NRC/DOE/Contractor staff in Silver Spring on May 11, led by G. Bennett. R. Luna and L. Bonzon attended this meeting as the Sandia representatives to provide the requested information on Sandia's formal QA practices with regard to these research programs.

On May 11, discussions centering on a proposed work statement to Sandia (to estimate the costing of a large-scale qualification test facility) and the Commission-requested connector tests were held with R. Feit and W. Rutherford in Silver Spring. W. Rutherford provided certain elaboration and clarification of the work scope and timetables. R. Feit discussed the connector-tests status and the necessary information required from the utilities and vendors before particular connectors could be selected and tested.

A review of the radiation qualification and simulator evaluation effort was made for P. Tam, H. Krug, A. Hintze, L. Soffer, F. Akstulewicz, and R. Feit in Bethesda on May 12. The discussion included a brief review

of the formal reports generated and work in progress to date with emphasis on the LOCA beta signature and simulator adequacy. The proposed study by NRR and Standards to estimate generic in-containment LOCA radiation dose and dose rates to Class 1E equipment was detailed by P. Tam. It is expected that a funded study will be requested by NRR/Standards to be programmed by RSR in the very near future.

On May 12, discussions were held with A. Hintze, at Nicholson Lane, on the status of and schedule for Regulatory Guide 1.89; it is currently being reviewed internally by NRR staff.

A review of staff responses to equipment (radiation) qualification was discussed with J. Slider in Bethesda on May 12. A discussion of the applicable Sandia work in progress was presented. (Mr. Slider requested several formal reports; these were transmitted to him on May 15.) Regulatory Guide 1.97 was also discussed, specifically the correctness of the  $10^8$  R/hr rate requirement for post-accident monitoring (PAM) equipment qualification. Several recent program reports, 1.5, 1.10, 1.11 are pertinent to scoping the rate requirement for PAM equipment.

On June 15, W. Rutherford visted Sandia to discuss the Commission-requested connector tests and the IE Alternatives Study. Significant effort was devoted to contacting the potential connector assesmbly suppliers to determine if their files were sufficient to allow the reconstruction of certain previously purchased assemblies. A review of utility-supplied connector purchase/test information was made to determine insufficiencies and to develop specific IE and Sandia action items to promote the testing efficacy. A detailed discussion of the IE Alternatives Study led to a list of action items for the IE and Sandia staffs; Sandia's principal effort will be to proceed to arrange for the necessary staff support, while the funding authorization proceeds through NRC and DOE.

On June 22, R. Scholl requested information on the availability of Class 1E electrical cable from prior test programs, and the scheduling of

LOCA-simulation equipment. NRR will ask Sandia to perform moisture migration tests in single conductor electrical cable.

Program Formalization: Two Buff-Book submittals were prepared and submitted on April 26 and June 29. These generally represented routine input, except that several potential programmatic difficulties were identified which could affect the milestone schedules for select subtasks; specifically, certain unexpected review/reporting requirements and significant additional tasks will require a revised priority schedule for all tasks.

A draft Schedule 189 for FY78 was prepared in early April. Internal review and sign-off was completed in early May and submitted to DOE/ALO on May 15. Official transmittal to RSR was completed by letter dated June 2 from DOE/ALO. This preliminary Schedule 189 outlines the major task efforts and cost estimates for the QTE program; the suggested funding level is somewhat reduced from the FY78 authorized funding.

The routine reporting of program activities is done through formal quarterly reports issued 4 to 6 months after the close of the reported quarter. The first quarterly 1.12 (October-December, 1977) completed sign-off on April 21 and was issued on May 15. A draft of the second quarterly 1.13 (January-March, 1978) was completed on June 28 and is undergoing internal Sandia-required review and sign-off.

Standards Committee and Meetings Participation: On March 22, S. Khalifa of TVA, as a member of IEEE Subcommittee 2, Working Group 2.11, requested that K. Gillen assist in developing a guide for typetests of Class 1E connectors, connections, and field splices. Mr. Khalifa is very interested in the proposed Sandia method for accelerated aging in combined stress environments, 1.12, 1.14 since no other general approach currently exists. He intends to propose the Sandia method as an available technique to achieve simultaneous thermal and radiation aging and to estimate the qualified life. On April 3, Mr. Khalifa formalized his request (by letter) to provide assistance and information to the Working Group. After

discussions with R. Feit, K. Gillen formally (letter dated May 22) agreed to work with the committee in the development of the guide.

K. Gillen (as a member) and E. Salazar hosted and attended the third meeting of IEEE/ICC Working Group 12-37, April 28, in Albuquerque. The group is charged with the study of environmental aging of electrical cable insulation and jacketing systems. The end objective is to determine methods that will allow cable to be "aged" to a condition representative of selected years of use under specified operating conditions. The meeting discussion included: a review of a proposed outline for "Electrical Insulation Selection Criteria for Nuclear Power Plant Service"; the proposed Delphi-survey to obtain the industry experience; and, a review of the Sandia program and results to date. After the meeting, committee members toured the Sandia aging facilities.

L. Bonzon attended the 24th Annual IES Meeting, in Ft. Worth on April 20, specifically the session on "Qualification of Components for Nuclear Power Plants." The session included papers on IEEE standards activities, radiation qualification, seismic qualification, and BWR-blowdown scale tests.

Diablo Canyon Plant Tour: Sandia staff visited the Diablo Canyon Nuclear Power Station on April 7. Located near San Luis Obispo, CA, the station consists of twin 1060 MW(E) Westinghouse PWRs. The purpose of the visit was to examine in-place Class 1E equipment with particular emphasis on interfaces, mounting, and location of the equipment. Pacific Gas and Electric served as its own architect-engineer and constructor for the project; since it is virtually complete, it is an ideal facility to inspect and is representative of the current state-of-the-art.

International Exchange: During the previous quarter, it was proposed to the Technical Program Chairman that a dedicated session on Qualification Testing Methodology be incorporated into the program of the International Meeting on Nuclear Power Reactor Safety, to be held October 16-19, 1978 in Brussels, Belgium. Concurrently, twelve abstracts were

submitted in mid-March, covering all aspects of the NRC, IEEE, and Sandia (and subcontractors) programs. Ten abstracts were Sandia-sponsored; the remaining two were related, but independently submitted. (Sandia-sponsored abstracts, with author list and Sandia designation, are described in Section 1.5.)

On May 24, notice was received that the Technical Program Committee had created a new session, "Environmental Equipment Qualification," and that the papers were accepted but were to be combined to reduce the number. The committee's comments were incorporated, resulting in the session as outlined in Table 1.1, which was forwarded by letter dated May 30. Full papers will be included in the Proceedings of the meeting.

Foreign Interest: Dr. Y. Nakase, Japan Atomic Energy Research Institute, requested specific information (by letter, received April 4) on the test methods described in Reference 1.15, particularly the dose rate chosen in the testing. His inquiries were answered by letter dated April 10; certain additional formal reports were transmitted as enclosures. Dr. Nakase also requested information (June 9) on the October 1978 International Meeting on Nuclear Power Reactor Safety, which was forwarded to him.

On May 17, at their request, a brief program review was presented to A. Onodera (Hitachi), Y. Fujise (Mitsubishi), K. Ikeda (Kobe Steel), and Y. Maki (Central Research Institute); all are Japanese nationals.

By letter dated June 1, Dr. K. Yahagi (EE Dept., Waseda University, Tokyo, Japan) requested approval to visit Sandia Laboratories on November 10, 1978. Dr. Yahagi is Chairman of the 30-member Committee on the Ionizing Radiation Resistance of Electrical Insulating Materials. The Committee, sponsored by the Institute of Electrical Engineers of Japan, is chartered to prepare a comprehensive Japanese standard, paralleling IEEE-323 and IEEE-383, on the qualification of Class 1E equipment for use in Japanese nuclear power stations. His request was approved on June 28 and forwarded to him.

TABLE 1.1  
Session: Environmental Equipment Qualification

Author	Submitted For	Presentation Time	Title
R. Feit	Publication/ Presentation	15 minutes	The Nuclear Regulatory Commission Research Program to Improve the Operational Safety of Nuclear Power Plants
H. Thornburg <sup>*</sup>	Publication/ Presentation	25 minutes	Quality Assurance and Its Effect on Safety
J. Fragola	Publication/ Presentation	20 minutes	Standards Activities Related to Class 1E Equipment Qualification
R. Luna L. Bonzon	Publication/ Presentation	15 minutes	Methodology Assessment: An Overview of the Qualification Testing Evaluation (QTE) Program
K. Gillen	Publication/ Presentation	20 minutes	A Proposed Method for Combined Environment Accelerated Aging
K. Gillen E. Salazar	Publication	--	Aging of Nuclear Power Plant Safety Cables
L. Bonzon	Publication/ Presentation	20 minutes	An Experimental Investigation of Synergisms in Class 1E Components
S. Kasturi G. Dowd L. Bonzon	Publication/ Presentation	20 minutes	Qualification of Class 1E Equipment: The Role of the Utility and Architect-Engineer
N. Lurie J. Naber L. Bonzon	Publication	--	The Hypothesized LOCA Radiation Signature and the Problem of Simulator Adequacy
L. Bonzon N. Lurie	Publication/ Presentation	20 minutes	The Best-Estimate LOCA Radiation Signature: What It Means to Equipment Qualification
R. Leadon <sup>**</sup>	Publication/ Presentation	25 minutes	Damage Mechanisms to Cables in Reactor Environments
L. Bonzon R. Luna S. Carfagno	Publication/ Presentation	20 minutes	Qualification Problems: The Rest of the Iceberg

<sup>\*</sup>USNRC, independently submitted.

<sup>\*\*</sup>IRT Corporation, independently submitted.

Industry Liaison: The general interest in the overall QTE program remains exceptionally high. A number of industry requests were received and processed during this quarter. These requests are briefly reviewed in Table 1.2.

Related Study for IE: In early May, IE requested Sandia assistance in support of a Commission-requested study of alternatives "...for conducting independent verification testing of environmentally qualified equipment which is required to operate in safety systems."<sup>1.16</sup> On May 5, Class 1E equipment lists were forwarded to W. Rutherford. On May 11, Sandia was asked to quote on a portion of the study to estimate the costs involved in constructing, equipping, and operating a test facility that could be used for conducting environmental tests in accordance with IEEE-323-1974 requirements on environmentally sensitive equipment. The Sandia quote was forwarded by letter, through R. Feit, on May 16.

On June 2, Sandia was asked to conduct the entire study as an expanded scope of work under an existing contract. Sandia responded affirmatively by letter dated June 5. Discussions were held with IE staff on June 15 and 29 to clarify and elaborate on the study. Subcontractors have expressed interest in assisting Sandia in this study. Funding for the study had not been received as of June 30.

#### 1.5 Publications/Presentations

The following is an inclusive list of formal publications and presentations which detail aspects of the QTE Program. Those marked by an asterisk (\*) became available during the reported quarter.

-- L. J. Klamerus, "Tests I and II, Sequential Mode; Cables and Paints," Sandia Laboratories, Albuquerque, NM, January 1976.<sup>†</sup>

---

<sup>†</sup>These Quick-Look reports are available in the USNRC Public Document Room; test results are being incorporated into a topical report for wide distribution.

TABLE 1.2  
Industry Liaison

<u>Date</u>	<u>Company</u>	Requested		
		<u>Prior Reports</u>	<u>Mailing List</u>	<u>Other</u>
April 12	Bendix-Sidney			Information on connector tests
May 4	Bendix-Sidney			Information on connector tests
May 9	Battelle-Columbus			To provide testing service to Sandia
May 18	ITT-Phoenix	SAND78-0718		
May 19	SAI-LaJolla	SAND78-0718 SAND78-0341	X	
May 23	Bechtel-Ann Arbor	SAND78-0341		Chemical spray effects during LOCA simulation
May 24	B&W-Lynchburg	SAND77-1713C SAND77-1654C		
May 26	Hitachi-New York	SAND78-0718 SAND78-0341 SAND78-0091	X	
May 26	AECL-Ontario	SAND78-0718 SAND78-0341 SAND78-0091	X	
May 30	Sigmaform-Santa Clara	Test VIII		
May 31	CE-Windsor	SLA-73-5349A		Aging to MIL 217B experience
June 1	ITT-Phoenix			Typical ambient aging temperature and allowable acceleration
June 2	LASL-Los Alamos	SAND78-0091		
June 5	AEP-New York	SAND78-0718 SAND78-0341 SAND78-0091	X	Radiation damage to PAM equipment per RG 1.97
June 12	GE-Gaithersburg			General
June 12	GE-Bridgeport	SAND78-0718 SAND78-0341 SAND78-0091	X	
June 13	SAI-LaJolla			Information on future work
June 14	B&W-Lynchburg	SAND78-0341	X	Generic containment dose and rate values
June 16	B&W-Lynchburg	SAND77-1075A		
June 19	YAE-C-Westboro			Extrapolation of test data to Connecticut Yankee
June 20	SAI-LaJolla			Information on future work
June 21	S&L-Chicago			LOCA-radiation source term
June 21	S&W-Boston			Information on future work
June 26	FIRL-Philadelphia			Dose conversion factors and available radiation test facilities

-- L. J. Klamerus, "Test III, Simultaneous Mode; Cables and Paints," Sandia Laboratories, Albuquerque, NM, April 1976.<sup>†</sup>

-- L. L. Bonzon, "In-Containment Radiation Environments Following the Hypothetical LOCA (LWR)," SAND76-5152A, Transactions of the American Nuclear Society, Vol 23, 1976.

-- L. J. Klamerus, "Test IV, Simultaneous Mode; Cables and Paints," Sandia Laboratories, Albuquerque, NM, July 1976.<sup>†</sup>

-- L. L. Bonzon, "Test V, Simultaneous Mode; Cables and Paints," Sandia Laboratories, Albuquerque, NM, August 1976.<sup>†</sup>

-- L. L. Bonzon, "Test VI, Simultaneous Mode; Cables, Connectors, and Lubricants," Sandia Laboratories, Albuquerque, NM, January 1977.<sup>†</sup>

-- L. L. Bonzon, "Test VII, Sequential Mode; Cables, Connectors, and Lubricants," Sandia Laboratories, Albuquerque, NM, February 1977.<sup>†</sup>

-- K. T. Gillen, E. A. Salazar and C. W. Frank, "Proposed Research on Class 1 Components to Test a General Approach to Accelerated Aging Under Combined Stress Environments," SAND76-0715, NUREG-0100, Sandia Laboratories, Albuquerque, NM, April 1977.

-- L. L. Bonzon, "Design Basis Event (DBE) Testing," SAND77-0150C, 1977 Proceedings of the Institute of Environmental Sciences, April 1977.

---

\* These Quick-Look reports are available in the USNRC Public Document Room; test results are being incorporated into a topical report for wide distribution.

- D. V. Paulson and S. P. Carfagno, "A Review of Class 1E Cable Qualification Data," FIRL Final Report F-C4598-1, prepared for Sandia Laboratories, June 1977. (Being incorporated into a Sandia topical report.)
- N. A. Lurie, "Definition of Loss-of-Coolant Accident Source for Radiation Component Qualification: Phase 1 Final Report," IRT 8167-001, prepared for Sandia Laboratories, June 1977. (This report intended for internal Sandia use only.)
- L. L. Bonzon, "Test VIII, Sequential Mode; Cables, Splices, and Connectors," Sandia Laboratories, Albuquerque, NM, July 1977.†
- L. L. Bonzon, "Radiation Signature Following the Hypothesized LOCA," SAND76-0740, NUREG76-6521, Sandia Laboratories, Albuquerque, NM, September 1977.
- K. T. Gillen, "Accelerated Aging in Combined Stress Environments," SAND77-0511A, Proceedings of the International Conference on Environmental Degradation of Engineering Materials, Virginia Polytechnic Institute Press, October 10-12, 1977.
- L. L. Bonzon, "Radiation Signature Following the Hypothesized LOCA," SAND76-0740, NUREG76-6521, Sandia Laboratories, Albuquerque, NM, Revised October 1977.
- D. V. Paulson and S. P. Carfagno, "Apparatus and Procedures for Qualification of Class 1E Electrical Cable," FIRL Final Report F-C4598-2, prepared for Sandia Laboratories, October 1977. (This report intended for internal Sandia use only.)

---

† These Quick-Look reports are available in the USNRC Public Document Room; test results are being incorporated into a topical report for wide distribution.

-- L. L. Bonzon, "Synergistic Effects and Source Term Considerations Associated with Class 1E LOCA Qualification Testing," SAND77-1713C, USNRC Fifth Water Reactor Safety Research Information Meeting, November 7-11, 1977.

-- K. T. Gillen and E. A. Salazar, "Accelerated Aging Studies of Electric Cable Material," SAND77-1654C, USNRC Fifth Water Reactor Safety Research Information Meeting, November 7-11, 1977.

-- L. L. Bonzon, K. T. Gillen, and E. A. Salazar, "A Consolidated Program to Evaluate Class 1E Equipment Qualification Techniques," SAND77-1075A, Transactions of the American Nuclear Society, Vol 27, 1977.

-- N. A. Lurie, D. H. Houston, and J. A. Naber, "Definition of Loss-of-Coolant Accident Radiation Source: Final Report-- Phases 2, 3, and 4," IRT 8167-002, prepared for Sandia Laboratories, December 1977. (This report intended for internal Sandia use only.)

-- L. L. Bonzon, N. A. Lurie, and J. A. Naber, "Adequacy of Radiation Sources for Qualification of Class 1E Reactor Components," IRT 8167-003/SAND78-0161A, January 1978. Accepted for publication/presentation at the American Nuclear Society, 1978 Annual Meeting, San Diego, CA, June 1978.

-- K. T. Gillen, "Combined Environmental Accelerated Aging Model Applied to Electric Cable Material," SAND78-0178A, presented at the Materials Science and Materials Chemistry Special Seminar, Westinghouse R&D Center, Pittsburgh, PA, January 30, 1978.

-- L. L. Bonzon, N. A. Lurie, D. H. Houston, and J. A. Naber, "Definition of Loss-of-Coolant Accident Radiation Source," SAND78-0090, Sandia Laboratories, Albuquerque, NM, February 1978.

- N. A. Lurie, D. H. Houston, and J. A. Naber, "Definition of Loss-of-Coolant Accident Radiation Source, Summary and Conclusions: Final Report--Phases 2, 3, and 4," IRT 8167-004, prepared for Sandia Laboratories, February 1978. (This report intended for internal Sandia use only.)
- K. T. Gillen and E. A. Salazar, "Single and Combined Environmental Accelerated Aging of Electrical Cable Insulation and Jacketing Materials," SAND78-0559A, March 1978. Accepted for publication/presentation at the 1978 Conference on Electrical Insulation and Dielectric Phenomena, Pocono Manor, PA, October 29-November 2, 1978.
- L. L. Bonzon, "Design Basis Event (DBE) Testing," SAND77-0150C, Technology Monograph, A Compilation of Qualification Considerations for Nuclear Power Generating Stations, Institute of Environmental Sciences, 1977.
- The following ten (10) abstracts were submitted in March to the International Meeting on Nuclear Power Reactor Safety, Brussels, Belgium, to be held October 1978:
  - R. E. Luna and L. L. Bonzon, "Methodology Assessment: The Role of the Independent Laboratory," SAND78-0342A.
  - L. L. Bonzon and R. E. Luna, "The Qualification Testing Evaluation (QTE) Program: An Overview," SAND78-0343A.
  - K. T. Gillen and E. A. Salazar, "Aging of Nuclear Power Plant Safety Cables," SAND78-0344A.
  - K. T. Gillen, "A Proposed Method for Combined Environment Accelerated Aging," SAND78-0501A.

- L. L. Bonzon, D. V. Paulson, and S. P. Carfagno, "An Evaluation of Synergistic Effects in Electrical Cables During LOCA Typetests, Using Historical Data," SAND78-0345A.
- L. L. Bonzon, "An Experimental Investigation of Synergisms in Class 1E Components," SAND78-0346A.
- L. L. Bonzon, S. G. Kasturi, and G. T. Dowd, "Qualification of Class 1E Equipment: The Role of the Utility and Architect-Engineer," SAND78-0347A.
- L. L. Bonzon, N. A. Lurie, and J. A. Naber, "The Hypothesized LOCA Radiation Signature and the Problem of Simulator Adequacy," SAND78-0348A/IRT 8167-005.
- L. L. Bonzon and N. A. Lurie, "The Best-Estimate LOCA Radiation Signature: What It Means to Equipment Qualification," SAND78-0349A/IRT 8167-006.
- L. L. Bonzon, R. E. Luna, and S. P. Carfagno, "Qualification Problems: The Rest of the Iceberg," SAND78-0350A.

\*-- F. V. Thome, "Preliminary Data Report, Testing to Evaluate Synergistic Effects from LOCA Environments. Test IX. Simultaneous Mode; Cables, Splice Assemblies, and Electrical Insulation Samples," SAND78-0718, Sandia Laboratories, Albuquerque, NM, April 1978.

\*-- "Qualification Testing Evaluation Program, Light Water Reactor Safety Research, Quarterly Report, October - December 1977," SAND78-0341, Sandia Laboratories, Albuquerque, NM, April 1978.

\*-- L. L. Bonzon, N. A. Lurie, D. H. Houston, and J. A. Naber, "Definition of Loss-of-Coolant Accident Radiation Source:

Summary and Conclusions," SAND78-0091, Sandia Laboratories, Albuquerque, NM, May 1978.

\*-- R. L. Clough, "Computer Modeling of Polymer Radiation Chemistry," SAND78-0876A, May 1978. Presented at, and published in the Proceedings of, the Fifth International Symposium on the Chemistry of the Organic Solid State, Brandeis University, Waltham, MA, June 13-16, 1978.

\*-- K. T. Gillen and E. A. Salazar, "A Model for Combined Environment Accelerated Aging Applied to a Neoprene Cable Jacketing Material," SAND78-0559, June 1978. Accepted for publication/presentation at the 1978 Conference on Electrical Insulation and Dielectric Phenomena, Pocono Manor, PA, October 29 - November 2, 1978.

\*-- N. A. Lurie, J. A. Naber, and L. L. Bonzon, "Adequacy of Radiation Sources for Qualification of Class 1E Reactor Components," IRT 8167-003/SAND78-0161A, Transactions of the American Nuclear Society, Vol 28, 1978.

## 1.6 References

- 1.1 "Qualification of Class 1E Equipment for Nuclear Power Plants," Regulatory Guide 1.89, September 23, 1974.
- 1.2 "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations," IEEE Std 323-1974, The Institute of Electrical and Electronics Engineers, Inc., 1974.
- 1.3 "IEEE Trial-Use Standard: General Guide for Qualifying Class 1E Electric Equipment for Nuclear Power Generating Stations," IEEE Std 323-1971, The Institute of Electrical and Electronics Engineers, Inc., 1971.
- 1.4 "Qualification of Safety-Related Electric Equipment for Nuclear Power Plants," Regulatory Guide 1.89, Rev. 1, Draft, November 1, 1976.
- 1.5 L. L. Bonzon, "Radiation Signature Following the Hypothesized LOCA," SAND76-0740, NUREG76-6521, Sandia Laboratories, Albuquerque, NM, Revised October 1977.
- 1.6 "Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants; Appendix VII: Release of Radioactivity in a Reactor Accident," WASH-1400, NUREG75/014, U.S. Nuclear Regulatory Commission, October 1975.
- 1.7 D. Y. Hsia and R. O. Chester, "A Study of the Fission Product Release from a Badly Damaged Water-Cooled Reactor," ORNL-TM-4702, Oak Ridge National Laboratory, June 1974.
- 1.8 "Core-Meltdown Experimental Review," SAND74-0382 (Revision), NUREG-0205, Sandia Laboratories, Albuquerque, NM, March 1977.
- 1.9 M. J. Kolar, J. R. McCarty, and N. C. Olson, "Post-Loss-of-Coolant Accident Doses to Pressurized Water Reactor Equipment," Nuclear Technology 36: 74-78, November 1977.
- 1.10 L. L. Bonzon and D. W. Dugan, "Preliminary Test Facility Upgrade Proposal," Sandia Laboratories Internal Memorandum, prepared for review by Burns & Roe, Inc., November 1977.
- 1.11 L. L. Bonzon, N. A. Lurie, D. H. Houston, and J. A. Naber, "Definition of Loss-of-Coolant Accident Radiation Source: Summary and Conclusions," SAND78-0091, Sandia Laboratories, Albuquerque, NM, May 1978.
- 1.12 "Qualification Testing Evaluation Program, Quarterly Report, October - December, 1977," SAND78-0341, Sandia Laboratories, Albuquerque, NM, April 1978.
- 1.13 L. L. Bonzon, K. T. Gillen and F. V. Thome, "Qualification Testing Evaluation Program, Quarterly Report, January - March,

1978," SAND78-0799, NUREG/CR-0276, Sandia Laboratories, Albuquerque, NM, August 1978.

1.14 K. T. Gillen, E. A. Salazar, and C. W. Frank, "Proposed Research on Class 1 Components to Test a General Approach to Accelerated Aging Under Combined Stress Environments," SAND76-0715, NUREG-0100, Sandia Laboratories, Albuquerque, NM, April 1977.

1.15 L. L. Bonzon, "Synergistic Effects and Source Term Considerations Associated with Class 1E LOCA Qualification Testing," SAND77-1713C, USNR Fifth Water Reactor Safety Research Information Meeting, November 7-11, 1977.

1.16 "Memorandum and Order, In the Matter of Petition for Emergency and Remedial Action," Commissioners, U.S. Nuclear Regulatory Commission, April 13, 1978.

## 2. Qualification Testing Methodologies Assessment

The activities under Task 1 are numerous and diverse. The programmatic activities were discussed in Section 1.4; Section 2.1 highlights the various technical activities. Section 2.2 details a specific program aspect that engendered particular effort and achieved a significant milestone during the reported quarter.

### 2.1 Task 1 - Technical Activities Summary

Publications: Final distribution of SAND78-0718, "Preliminary Data Report, Text IX. Simultaneous Mode; Cables, Splice Assemblies, and Electrical Insulation Samples,"<sup>2.1</sup> was made in early May. This report (see also Reference 2.2) describes the test and results and compares the test with Test VIII, its sequential complement. There were no functional failures in either test, with cables and cables with splices maintaining rated current and voltage loads through both tests. The preliminary results indicate that no significant functional or material synergism exists. All splicing materials endured the conditions of LOCA better than the insulation materials in the attached cable. Type A cable showed less degradation of its electrical properties than did types B or C. The insulation tensile-specimens did not exhibit any strong synergistic effects, but the data indicate the potential importance of accurate and adequate aging.

Connector Tests: A significant new task, identified during the previous quarter, requires additional testing of cable connector assemblies. Based on the UCS petition of November 4, 1977, the USNRC Commissioners requested that "additional tests of connectors in a simulated LOCA environment be conducted by Sandia Laboratories using connectors qualified according to the IEEE-323 standard when a suitable test facility is available."

The significant effort this quarter involved the interpretation of, and response to, the Commissioners' memorandum by NRC (RSR, NRR, IE) staff

and internal review of proposed test plans and specific connectors/plants to be retested. By letter dated May 22, DOR staff recommended the following connectors:<sup>2.3</sup>

- BWR      (1) Peach Bottom - Pyle National Connectors; or
- (2) Browns Ferry - Bendix Connectors
- PWR      (1) Palisades - Viking Spec Connectors; or
- (2) Oconee - Viking Spec Connectors.

The staff recommended considering other connectors, if necessary, "...due to availability of the connectors to be tested, extensive procurement time or other constraints."

Based on these recommendations, connector procurement/test packages were obtained from these utilities and initial contacts made with suppliers. Since Viking no longer manufactures connectors, other (PWR) plants/connectors are also being considered by IE staff.

UEC Subcontract: United Engineers and Constructors (UEC) is completing a four-concurrent-phase subcontract to assemble comprehensive data packages for all in-containment Class 1E equipment for a contemporary PWR nuclear power plant. Through March, twenty data packages had been completed. During this quarter one additional data package (on motors) was transmitted, as well as extensive revisions to the Class 1E equipment list. Four data packages remain to be completed under the current contract scope. (See also Section 2.2).

FIRL Subcontract: The principal efforts under this contract during the quarter were the continuing review of the UEC subcontract submittals (see above) and the test facility upgrade proposal reviews required by NRC/RSR staff. For the latter, the general conceptual plan was forwarded to FIRL by letter dated May 30. FIRL responded in a letter dated June 27,

which contained 15 points, comments, or considerations. In general they concurred with the conceptual philosophy of the design:<sup>2.4</sup>

"The essential purpose of the upgrading is to achieve a more versatile testing facility suitable for experimental type testing rather than routine testing . . . . The proposal appears to do this well.

"Overall, it appears that the upgraded facility will be able to handle larger items at greater dose rate and with a larger selection of dose rates; it will also provide a more uniform dose rate than the present facility. These factors should lead to more useful results than are available at present."

Two other packages are being drafted to be forwarded to FIRL for review in early July: autoclave and ancillary equipment, and High Intensity Adjustable Cobalt Array (HIACA).

Synergism Topical Report: A topical report, "An Experimental Investigation of Synergisms in Class 1 Components Subjected to LOCA Typetests,"<sup>2.5</sup> was drafted and received preliminary review in late 1977. It incorporated the results of the synergistic typetests (through Test VIII) and included the full report of the offsite synergism study performed by FIRL.<sup>2.6</sup>

Following the completion of Test IX,<sup>2.1</sup> the test results and the data analyses were incorporated into the draft in April and internal Sandia reviews were initiated in May. Final reviews are expected to be completed in August with final printing and distribution scheduled for September.

QA Program for NRC-Sponsored Research: In a Memorandum and Order<sup>2.7</sup> issued by the NRC Commissioners on April 13, 1978, the NRC staff was directed to:

"Develop a plan to investigate the adequacy of quality assurance practices for NRC-sponsored confirmatory research programs and provide recommendations to the Commission."

On May 11, R. Luna and L. Bonzon met with other NRC, DOE, and DOE-laboratory staff to discuss a May 9 draft plan developed by RSR personnel. Based on the meeting discussion, a second draft was forwarded to Sandia on May 15 with a request for comment by May 25.

Facility Upgrade: The existing test facility will be upgraded to accommodate larger and more diverse Class 1E test items and to allow selectable radiation dose rates and stationary radiation spatial gradients. The upgrade includes (1) new radiation sources and source-positioning apparatus, (2) an electro-hydraulic control system to select irradiation rates and to interlock for safety, (3) facility shielding modifications, (4) irradiation cell modifications, (5) test chambers, and (6) diagnostic/test equipment.

The major efforts this quarter were concentrated in three areas: a redesign of the original concept of radiation source positioning; installation of additional facility shielding and cell modifications; and continued design definition of the test chamber and support equipment.

A new design of the HIACA was initiated to replace the excessively long (12 ft) and rigid test fixture design that was initially proposed. The new design allows precise visual assurance of cobalt source position; it consists of a hydraulically telescoping series of nested tubes that raise the 50-in. (double-length) cobalt pencils to the same 12-ft height, but is only 5-1/2 ft high when completely nested. Fabrication costs are reduced from the previous design and all radiation source transfers can be accomplished underwater in the open pool.

Additional shielding was attached to the common irradiation cell walls; this consisted of two inches of depleted uranium plate on each side of the wall.<sup>2.8</sup> In addition, two through-ports were core drilled into the cell ceiling to provide ingress/egress capability for experiment/loading/diagnostic equipment.

As described in a previous subsection (FIRL Subcontract), documentation of design objectives and designs was formalized to allow FIRL review. Three packages are to be prepared: general plan; autoclave and ancillary equipment; and HIACA. The first of these was forwarded to FIRL on May 30 and was formally reviewed by letter dated June 27; 2.4 in general, FIRL concurred with the conceptual philosophy of the design. The two other packages are being drafted to be forwarded in early June.

The bulk of the quarterly effort centered on the continuing design definition of the major equipment items and facility modifications. In some cases, long-lead-time items were identified and orders placed (e.g., autoclave dome heads, pumps, hydraulic hose). Major effort remains for the autoclave handling/support apparatus, HIACA, source-handling tools, elevator modification, and additional facility shielding.

## 2.2 Class 1E Equipment Identification<sup>2.9</sup>

### 2.2.1 Study Scope

In order to provide a basis for equipment selected for use in LOCA-simulation methodology typetests, a comprehensive study was required. This included assembling and/or determining the following pertinent information:

- (a) complete listing of typical Class 1 equipment
- (b) realistic ambient and accident environments
- (c) physical construction of equipment and materials list
- (d) performance specification, service-life history, and maintenance schedule
- (e) general equipment vulnerability and "weak-links" where known by prior use experience
- (f) electrical/mechanical/environmental interfaces.

Three other objectives can be realized using the data obtained. First, the materials list and construction details should allow

---

<sup>\*</sup>This section prepared by L. Bonzon, Division 5432.

comparisons to be made with performance data available in the literature or with prior typetest results; this may preclude the necessity for typetesting all components or manufacturer's types with comparable materials. Second, the amount of equipment potentially requiring typetesting can be estimated based on the available data. Third, realistic ambient and accident environment specifications should allow optimum typetest environmental envelopes and procedures to be developed. This may lead to typetests based on realistic, not (conservative) envelope, considerations.

In late July 1977, UEC was authorized to conduct this study in a four-concurrent-phase subcontract for a contemporary PWR nuclear power plant for which UEC was committed to provide comprehensive equipment qualification certifications during the licensing process. The scope of the effort was limited to in-containment Class 1E equipment and that Class 1E equipment located just adjacent to containment in the penetration area. Through the course of the study UEC completed four distinct subtasks: description of systems; Class 1E equipment lists; environmental design criteria; and equipment data packages.

The description of systems delineates the major safety systems and their importance and function in mitigating accident consequences.

The Class 1E equipment list enumerates all equipment potentially exposed to harsh accident environments and provides information such as service description, plant location, accidents scenarios during which it functions, time at which it is required to start after an accident and the duration of function, environmental conditions, and number of cycles through which it will be operated throughout plant life.

The environmental design criteria describe the conditions of aging and accident environments in terms of (a) best estimate of the normal operating environment, (b) maximum service environmental conditions, and (c) qualification parameters, including margin. (A service environment chart and equipment location plans were also developed.)

An equipment description data package was compiled for each category of equipment. Non-proprietary information was obtained from 46 vendors, out of which 22 data packages were prepared. The data packages contain a description of the equipment, operating principle, installation and interface details, operating and environmental conditions, performance specification, materials of construction, maintenance procedures, periodic testing and calibration procedures, vulnerability details, and manufacturer's bulletins and test reports.

#### 2.2.2 Systems Descriptions and Environmental Design Criteria

In this generic PWR design, some 20 systems within containment have Class 1E equipment as integral part(s) of the system. These systems, their function, and their Class 1E function, are briefly described in Table 2.1. While some of the systems provide an active Class 1E function (spec., CAH, CBS, CS, EDE, FW, MM, RH, SI), the majority containing Class 1E equipment provide containment-isolation or reactor-trip functions only. In terms of the complexity of the system, relative to numbers of Class 1E equipment, the reactor coolant (RC) system is the most complex; it contains 12 flow transmitters, 8 flow relays, 3 level transmitters, 6 pressure transmitters, 25 temperature elements, 12 pneumatic or motor-operator valve actuators, 12 position switches, and associated cabling, connectors, enclosures, etc. Out of all these items, only nine are located just outside containment (in the equipment tunnel up to the first isolation valve outside containment).

The electrical/mechanical equipment located within the containment and the area outside but adjacent to the containment penetration must be designed to withstand the normal environmental conditions of pressure, temperature, humidity, and radiation, and then operate during a design-basis accident, without failure. The design also considers environmental conditions prevalent during certain tests, e.g., periodic containment leak-rate testing. Specific maximum/normal/minimum environments were detailed for all plant areas; Table 2.2 summarizes the in-containment information.

TABLE 2.1  
In-Containment Systems Description

System	Function	Class 1E Function
CAH - Containment Air Handling	Air cooling/circulation for hydrogen mixing.	Recirculation portion is an engineered safety feature (ESF).
CAP - Containment Air Purge	Purge air prior to personnel entry at cold shutdown.	CAP isolation components are active safety.
CBS - Containment Building Spray	Sprays atmosphere with sodium hydroxide, borated water solution to remove iodine and reduce containment pressure after an accident.	CBS system is an ESF.
CC - Primary Component Cooling Water	Cooling system for all safety-related or (potentially) contaminated systems or components.	CC components providing containment isolation are active safety.
COP - Containment On-line Purge	Limit containment radioactivity concentrations during normal operation.	COP isolation components are active safety.
CS - Chemical and Volume Control	Maintain inventory and chemistry of the reactor coolant. Charging pumps provide high pressure injection for ECCS.	High pressure injection is a safety function.
EDE - Electrical Distribution-Emergency	Provides electrical power for all safety-related equipment.	Provides electrical power for all safety-related equipment.
FW - Feedwater	Provide water for the first level heat sink to the primary systems via the steam generators. Emergency feedwater is an ESF providing decay heat removal.	Emergency feedwater is an ESF providing decay heat removal. FW components provide input to Reactor Protection System.
MM - Miscellaneous Equipment	Includes connectors, terminal blocks, NEMA enclosures.	Includes connectors, terminal blocks, NEMA enclosures.
MS - Main Steam	Transports energy from the RC system to the turbine generator.	MS instrumentation provides inputs to the Reactor Protection System. MS isolation components are active safety.
NG - Nitrogen Gas	Nitrogen gas is supplied to accumulators, pressurizer relief tank, and the main steam lines for blanketing and pressurization.	NG isolation components are active safety.
NI - Nuclear Instrumentation	Provides input to the reactor control system during normal operation.	NI provides input to the Reactor Protection System.
RC - Reactor Coolant	Cooling of reactor core and heat transfer to the steam system.	RC components provide containment isolation and inputs to the Reactor Protection System.
RII - Residual Heat Removal	Provides decay heat removal to bring plant to cold shutdown.	RII is an ESF; provides low pressure injection for ECCS.
RM - Radiation Monitoring	Provides radiation monitoring function throughout the plant.	RM provides inputs to the Reactor Protection System.
RMW - Reactor Make-up Water	Provides reactor quality water for chemical and volume control in primary systems.	RMW isolation components are active safety.
SB - Steam Generator Blowdown	Provides bleed-off of water on secondary side for control of water chemistry.	SB isolation components are active safety.
SI - Safety Injection	Provides medium pressure core injection for ECCS.	SI is an ESF.
VG - Equipment Vent	Provides a collecting system for gases from radioactive or hydrogenated components and for evacuation of piping systems during filling.	VG isolation components are active safety.
WLD - Equipment and Floor Drains	Collects all liquids from systems for processing.	WLD isolation components are active safety.

TABLE 2.2

## Containment Environmental Parameters for the Generic PWR

	<u>Normal</u>	<u>Accident</u>	<u>Post-Accident</u>
Pressure (PSIG)	60 (test)		
Maximum	1.5	52	6
Normal	0.5	N/A	N/A
Temperature (F)	100 (test)		
Maximum	120	278*	160
Minimum	50	50	
Humidity (%)			
Maximum	90	Steam/Air Mixture	Steam/Air Mixture
Minimum	5		
Containment Spray			
	None	Boric Acid 1.2% Wt PH 7.5 - 10.5 NAOH Used to control PH	None

\*Temperature transient of 296°F is reached for first minute.

To analyze the normal radiation environment expected, the containment is divided into three radiation areas: inside the primary shield, inside the secondary shield, and outside the secondary shield to the containment wall. Inside the primary and secondary shield the radiation dose rate during normal plant operation is estimated at 50 rad/hr; integrated over 40 years, this gives  $2 \times 10^7$  rads. For reactor coolant piping instrumentation in this area, the radiation dose rate during normal plant operation is estimated at 820 rad/hr; integrated over 40 years this gives  $3 \times 10^8$  rads. Outside the secondary shield to the containment wall the radiation dose rate during normal plant operation is estimated at

150 mrad/hr; integrated over 40 years this gives  $5.3 \times 10^4$  rads. However, for equipment in close proximity to radioactive pipes or sumps the radiation could be much higher and is conservatively estimated to be 50 rad/hr. Complete equipment location drawings have been provided to allow estimates of ambient radiation environments for each specific item; these radiation values are also reflected in the Class 1E equipment lists (Section 2.2.3).

The qualification parameters were established using the margins as follows:

Pressure = Maximum pressure + 10%

Temperature = Maximum temperature + 15%

Humidity = Maximum humidity

Gamma Dose = Maximum + 10%

Beta Dose = Maximum + 10%

Figure 2.1 shows the accidents and envelope curves for containment pressure and temperature. The integrated accident dose is listed in Table 2.3.

### 2.2.3 Class 1E Equipment Lists

The Class 1E equipment list delineates all Class 1E equipment located inside and outside containment in the penetration area. For each piece of equipment this list provides information such as service description, plant location, accidents during which it functions, time at which it is required to start after an accident and the duration for which it functions, environmental conditions, number of cycles through which it will be operated throughout plant life, its safety function, and the supplier/model of the equipment item.




Figure 2.1a. Containment accident design envelope, pressure-time




Figure 2.1b. Containment accident design envelope, temperature-time

TABLE 2.3  
Accident Integrated Air Dose

<u>Time After LOCA</u>	<u>Beta (rad)</u>	<u>Gamma (rad)</u>	<u>Total (rad)</u>
1 hour	5.2(+6)*	1.1(+6)	6.3(+6)
12 hours	1.8(+7)	3.2(+6)	2.1(+7)
1 day	2.5(+7)	4.1(+6)	2.9(+7)
10 days	8.0(+7)	1.1(+7)	9.1(+7)
1 month	1.0(+8)	1.3(+7)	1.1(+8)
6 months	1.2(+8)	1.3(+7)	1.3(+8)
1 year	1.4(+8)	1.3(+7)	1.5(+8)

\*Read as  $5.2 \times 10^6$

These lists are computer generated, and sorts are provided as an aid to the user by (1) system, (2) location, and (3) device type. A typical example of such a list is shown in Table 2.4 (nitrogen gas system). The Class 1E equipment is composed of flow relays (FY), pneumatic valve actuators (V), and position switches (ZS); the function of this equipment is isolation (ISOL) and post-accident monitoring (PAM). Other information useful in interpreting the table is:

1. Accident code 60; LOCA without containment spray, including:
  - small primary system pipe rupture
  - steam generator tube rupture
  - rupture of a control rod drive mechanism housing;

2. For the pressure/temperature/humidity/dose columns:

- line 1 is the best estimate of the normal (i.e., typical) operating, or service, environments
- line 2 is the maximum realistic service environmental conditions including the accident
- line 3 is the qualification parameters which include margin over the realistic estimates in line 2.

A very interesting feature of the list is the "realism" in the table entries; the impact of realism on qualification (capability) is great.

Besides the maximum service environmental conditions, which are certainly important in qualification, the start and duration of operation are also crucial aspects. As an example, the flow relay (NG-FY-4609) must start to function 70 seconds after initiation of accident code 60 (see Table 2.4) and complete its function 1 second later. However, the architect-engineer requires qualification of this equipment for 1300 seconds; this qualification duration accounts for margin, certain unspecified accident occurrence and sensing scenarios, and general reluctance to assume the realistic, but short, duration. A purpose of this study is, in fact, to contrast the realistic and qualification parameters.

#### 2.2.4 Generic Equipment Data Packages

A descriptive data package was compiled for each generic category of equipment. To date, a total of 46 vendors have been contacted for non-proprietary information from which 22 data packages have been prepared. The data packages contain a description of the equipment, operating principle, installation and interface details, operating and environmental conditions, performance specification, materials of construction, maintenance procedures, periodic testing and calibration procedures, vulnerability details, and manufacturer's bulletins and test reports.

TABLE 2.4

CLASS 1E EQUIPMENT LIST

NG System Class 1E Equipment

REV. 05

SORT NO. 01 SHEET 25

DATE 06/30/78

## SYSTEM: NG - NITROGEN GAS

REV NO.	EQUIPMENT ID	SERVICE LEGEND	MFGR MODEL	LOC CODE	START DUR:	NO OF	BEST EST-NORM OPER ENVIR			DESN LIFE	IS AGING	METH OF REQD	REMARKS
							EST	MAX SERV	ENVIR COND				
					TRN	SFTY	QUAL	EST	PRESS TEMP HUM INTEGRATED DOSE	QUAL			
						FUCT	UNITS	QUAL	PSIG F % B-RADS G-RADS	LIFE			
05	NG - FY - 13	NG-V-13 SOV	W ASCO TUN- FT8316 NEL	60	70	500	0.0	104	95	N/A	5.3E04		
					71		.006	148	95	N/A	1.1E06		
					ISOL	1300	1000	.006	163	100	N/A	1.2E06	
					B	SEC							
05	NG - FY - 36	NG-V-36 SOV	W ASCO TUN- LB8316 NEL	60	70	500	0.0	104	95	N/A	5.3E04		
					71		.006	148	95	N/A	1.1E06		
					ISOL	1300	1000	.006	163	100	N/A	1.2E06	
					A	SEC							
05	NG - FY - 4609	N2 SUPPLY ISOL W IRC NG-V37 SOV	CNTN 60 -26	60	70	500	0.5	120	90	N/A	5.3E04		
					71		60	278	100	5.2E06	1.1E06		
					ISOL	1300	1000	66	293	100	5.7E06	1.2E06	
					B	SEC							
04	NG - V - 13	N2 SUPPLY ISO W ORC NG-V13	W C-V 100	TUN- NEL	60	70	500	0.0	104	95	N/A	2E07	
					75		.006	148	95	N/A	2.1E07		
					ISOL	1300	1000	.006	163	100	N/A	2.3E07	
					B	SEC							
05	NG - V - 36	N2 SUPPLY ISO W ORC NG-V36	TUN- NEL	60	70	500	0.0	104	95	N/A	2E07		
					75		.006	148	95	N/A	2.1E07		
					ISOL	1300	1000	.006	163	100	N/A	2.3E07	
					A	SEC							
05	NG - V - 37	N2 SUPPLY ISO W IRC NG-V37	CNTN 60 -26	60	70	500	0.5	120	90	N/A	2E07		
					73		60	278	100	5.2E06	2.1E07		
					ISOL	1300	1000	66	293	100	5.7E06	2.3E07	
					B	SEC							
04	NG - ZS - 13	NG-V-13 POS	W NAMC TUN- EA170 NEL	60	CONT 1	CONT 1	0.0 .006	104 148	95 95	N/A N/A	2E07 3.3E07		
					PAM	1	.006	163	100	N/A	3.6E07		
					B	YEAR							
04	NG - ZS - 36	NG-V-36 POS	W NAMC TUN- EA170 NEL	60	CONT 1	CONT 1	0.0 .006	104 148	95 95	N/A N/A	2E07 3.3E07		
					PAM	1	.006	163	100	N/A	3.6E07		
					A	YEAR							
05	NG - ZS - 37	NG-V-37 POS	W	CNTN 60 -26	CONT 1	CONT 1	0.5 60	120 278	90 100	N/A 1.4E08	2E07 3.3E07		
					PAM	1	.006	163	100	1.5E08	3.6E07		
					B	YEAR							

In some cases, because of proprietary information restrictions, UEC staff developed a generic data package based on known industry capability. Data packages have been completed for:

Limit Switches	600 Volt Control Cable
Solenoid Valves	600 Volt Power Cable
Containment Electrical Penetrations	300 Volt Instrumentation Cable
Terminal Blocks	300 Volt Thermocouple Extension Cable
Pneumatic Actuators	Motor Operated Actuators
Resistance Temperature Detectors	Level Switches
Thermocouples	Differential Pressure Switches
Terminal Blocks	Transmitters
Terminal Lugs (Manufacturer 1)	Electrical Enclosures
Wiring Ducts (Deleted)	Motors
Terminal Lugs (Manufacturer 2)	Radiation Monitors

Of these items, four are generic: penetrations, DP switches, transmitters, and motors. In addition, four more packages remain to be completed: flow relay, neutron flux element, pressure relay, and connectors.

#### 2.2.5 Summary and Discussion

This Class 1E equipment compilation and data package development represent the first consolidated effort to completely describe the equipment item and its normal and accident environments and functions. The study provides a substantive data base for various aspects of the QTE program; in particular, it will:

- provide a basis for equipment for the LOCA simulation methodology tests;
- allow analyses of equipment functionability when exposed to the specified environments through knowledge of construction, interface, and material data;
- allow establishment of test regimen from the function, construction, size, and interface data;
- provide contrast between "realistic" and qualification parameters;
- allow the detailing of optimum typetest envelopes and procedures based on realistic parameters.

### 2.3 References

- 2.1 F. V. Thome, "Preliminary Data Report, Test IX. Simultaneous Mode; Cables, Splice Assemblies, and Electrical Insulation Samples," SAND78-0718, Sandia Laboratories, Albuquerque, NM, April 1978.
- 2.2 L. L. Bonzon, K. T. Gillen, and F. V. Thome, "Qualification Testing Evaluation, Quarterly Report, January-March, 1978," SAND78-0799, Sandia Laboratories, Albuquerque, NM, August 1978.
- 2.3 Letter dated May 22, 1978, D. G. McDonald (DOR/NRC) to R. Feit (RSR/NRC), "Connectors Recommended to be Subjected to Verification Testing in Accordance with the Commission Directive."
- 2.4 Letter dated June 27, 1978, R. J. Gibson (FIRL) to L. L. Bonzon (SLA), " FIRL Comments and Review of Test Facility Upgrade Proposal."
- 2.5 L. L. Bonzon, "An Experimental Investigation of Synergisms in Class 1 Components Subjected to LOCA Typetests," SAND78-0067, Sandia Laboratories, Albuquerque, NM, August 1978.
- 2.6 D. V. Paulson and S. P. Carfagno, "A Review of Class 1E Qualification Data," FIRL Final Report F-C4598-1, prepared for Sandia Laboratories, June 1977. (Incorporated into SAND78-0067.)
- 2.7 USNRC Commissioners, " Memorandum and Order, In the Matter of Petition for Emergency and Remedial Action," April 13, 1978.
- 2.8 L. L. Bonzon and D. W. Dugan, "Preliminary Test Facility Upgrade Proposal," Sandia Laboratories Internal Memorandum, prepared for review by Burns & Roe, Inc., November 1977.
- 2.9 UEC, Inc., J.O. 6602-002. Submittals to Sandia Laboratories under Contract 07-3426.

### 3. Radiation Qualification Source Evaluation

The various technical activities under Task 2 are generally discussed in Section 3.1; the program activities were discussed in Section 1.4. Section 3.2 details a specific program aspect that engendered particular effort and achieved a significant milestone during the reported quarter.

#### 3.1 Task 2 - Technical Activities Summary

Publications and Presentations: Final distribution of SAND78-0091, "Definition of Loss-of-Coolant Accident Radiation Source: Summary and Conclusions,"<sup>3.1</sup> was made in May. This report, prepared by IRT Corporation under contract to Sandia Laboratories, details the radiation energy release rates and spectra corresponding to the sources specified in Regulatory Guide 1.89,<sup>3.2</sup> for the radiation qualification of Class 1E equipment. The effects of several parameters not completely specified in the Guide, such as reactor fuel composition, operating duration and power level, and treatment of the progeny, were evaluated. The results are presented as time-dependent beta and gamma ray energy release rates and spectra, and are fundamental quantities that are generally applicable to any nuclear power station. The full report, SAND78-0090,<sup>3.3</sup> is principally useful as a source of additional data.

A paper was presented by N. Lurie at the 1978 Annual Meeting of the American Nuclear Society, San Diego, on June 21.<sup>3.4</sup> It describes calculations of the time-dependent LOCA radiation signature (as specified in Regulatory Guide 1.89), and calculations of depth-dose damage profiles in Class 1E components which can be used to evaluate simulator adequacy.

IRT Subcontract--1: A subcontract with IRT Corporation to perform parametric calculations of the LOCA radiation signatures and depth-dose calculations in selected Class 1E components from the LOCA and simulators signatures was effectively completed this quarter. Phases 1-4 results were

documented as References 3.1 and 3.3. A draft report on Phases 5-6 was completed in April for Sandia review and comment.<sup>3.5</sup> These latter phases involve the calculation of depth-dose and charged-particle distribution profiles in modeled equipment exposed to radiation from the LOCA source and simulator sources. The calculations will be used to evaluate simulator adequacy as discussed in Reference 3.4. Comments on the Phases 5-6 draft were forwarded to IRT by letter dated May 26. These are currently being addressed by IRT staff, with a final report to be issued in July. Receipt of the draft concludes the subcontract, except for incorporation of the comments and corrections which will be accomplished under Subcontract--2.

IRT Subcontract--2: Based on previous subcontract experience and the developed calculational techniques, a contract was awarded to IRT Corporation in late March to develop a "best-estimate" LOCA radiation signature. The signature will be generally based on the accident-time-release sequencing as specified in WASH-1400<sup>3.6</sup> and other recent literature. (See also Reference 3.7.)

The subcontract is in two parts. Part I, in four phases, is a preparation of a "best-estimate" LOCA radiation signature, dose and rate calculations for a generic containment structure, and calculations of selected Class 1E equipment response to the signature. Part II effectively extends the contract through September, and requests IRT to provide additional assistance to supplement, expand, update, and reevaluate prior submittals as deemed necessary.

A preliminary draft of the Phase 1 report was discussed with IRT staff on June 20 at San Diego. Based on these discussions, a comment copy will be forwarded to Sandia in early July.

By letter dated June 26, IRT was requested to perform a LOCA-radiation damage assessment of electric cables and an assessment of radiation simulator adequacy to be based on the previous work of References 3.1, 3.5, and 3.8. This additional work is limited in scope and is

to be completed by mid-August. Sandia personnel are performing a concurrent complementary assessment effort.

Generic Containment LOCA-Radiation Profiles: NRC staff (specifically NRR and Standards) are developing a user's requirement letter for a proposed study to estimate generic in-containment LOCA radiation doses and dose rates to Class 1E equipment. At a May 12 meeting with NRC staff, L. Bonzon outlined the applicable work under NRC sponsorship completed, or in progress. It is expected that a funded study to be programmed by RSR will be requested by NRR/Standards in the near future.

Expressions of (unsolicited) subcontractor interest in performing this work have been received from IRT, SAI, and Stone & Webster. Meetings with these companies were held on June 20 and 21 in San Diego to discuss the implementation of this new effort. The work may be directed towards defining some generic plant areas for which dose and rate calculations could be made; these would include open plant areas, shielded (labyrinth) rooms, drywell, congested piping area, nearby structure (walls) area, etc. Computational methodology, as well as typical calculations, could then be defined for each area.

### 3.2 Calculations to Support Radiation Simulators Adequacy Assessments<sup>\*3.4, 3.5</sup>

The LOCA radiation sources appropriate for Class 1E equipment qualification testing have been specified in Regulatory Guide 1.89.<sup>3.2</sup> These sources are divided into two source strengths (one for containment heat-removal systems, etc., and one for other safety-related electric systems) and three spatial distribution categories: (1) airborne

---

\*This section prepared by L. Bonzon, Division 5432.

(uniformly dispersed in the containment atmosphere); (2) plate-out (plated-out on surfaces exposed to the containment atmosphere); and (3) waterborne (intimately mixed with coolant water). (See Table 3.1.)

TABLE 3.1  
Guide Sources Specifications<sup>3.2</sup>

Source 1 (Containment heat-removal systems, etc.)	Airborne	100% Noble gases, 25% Iodines
	Plate-Out	25% Iodines, 1% Solids
	Waterborne	50% Halogens, 1% Solids
Source 2 (Safety-related electrical systems)	Airborne	10% Noble gases (except Kr-85), 30% Kr-85, 5% Iodines
	Plate-Out	5% Iodines
	Waterborne	10% Halogens

These sources have been redefined in terms of energy release rate and particle/energy spectra as functions of time and have been reported in References 3.1, 3.3, and 3.4.

With the LOCA sources signatures established, energy and charge deposition profiles can be calculated for the sources and for common radiation simulators. These calculations can then be used to support the assessments of simulators adequacy. Initial calculations have been completed for a generic electric cable and for Co-60 and Cs-137 simulators by IRT Corporation; the results of these calculations are summarized in the succeeding subsections.

### 3.2.1 Cable Model and Methods of Calculation

Many types and brands of electric cable are used in nuclear power plants but a typical Class 1E type is a 600-V power cable consisting of a

copper core with elastomer insulator and jacket (Figure 3.1). Typically, the dimensions and materials vary widely; thus, the model selected may be considered as typical, but not exactly like any one manufacturer's brand in particular. In general any organic,  $\text{CH}_2$ -dominated materials would yield similar calculational results if material thickness and density are appropriately considered.




Figure 3.1. Model of the power cable

For the LOCA-sources calculations, the cable was assumed to be centered in the sources volume (for the waterborne and airborne sources) and the plate-out source was assumed to be uniformly deposited on the cable jacket surface. Furthermore, the airborne source was taken to consist of a uniform distribution of point sources in 70-psig saturated steam. The spatially extended source distributions are not tractable to direct brute-force Monte Carlo transport methods. The reason for this is that the cable subtends a very small solid angle; in other words, the probability that a source particle sampled from the air will hit the cable is too small to get statistically meaningful results in a reasonable time. Consequently, an approximation technique was used to map the distributed airborne and waterborne sources into a practical configuration.

The simulator sources were assumed to be isotropic emitters on the surface of a cylinder radius of 12 in. (30.48 cm), coaxial with the cable. Air at standard temperature and pressure (STP) with a density of 0.001293 g/cm<sup>3</sup> filled the space between source and cable. A test chamber is typically used to contain the test piece and its environment. The effect of a 1/4-in. (0.64-cm) steel test chamber with an inside radius of 10 in. (25.4 cm), also coaxial with the cable, was examined; the test chamber has little effect. For Co-60, the average photon energy penetrating the test chamber is 1.156 MeV compared to 1.253 MeV without the chamber.

The calculations of energy and charged-particle deposition were carried out using SANDYL, a general and widely recognized coupled photon-electron transport code. It uses the physical approach which consists of random sampling and simulation of individual histories which are used to construct the solution to the physical problem.

### 3.2.2 Calculations and Results

Selections from the source spectra reported in References 3.1 and 3.3 were made for the depth-dose studies in the model cable. The results for

an equilibrium irradiation for Sources 1 and 2, which included all daughters but did not include capture and depletion effects, were used. Cooling times producing the hardest (i.e., highest average energy) and softest spectra were selected in order to study the bounding conditions. The hardest spectrum occurs at the shortest cooling time. As a matter of practicality, the very short cooling times are not expected to be accurate since a significant number of nuclides which contribute to the energy release at short times do not have spectral data in the library. Therefore, the one-minute cooling time data were selected for the hard spectrum. The softest spectrum (i.e., lowest average energy) occurs between 1 and 10 days depending on the type of source; the 4-day results were selected. For each source and each distribution category, depth-dose calculations were carried out at two times for betas and gammas.

The charged particle distribution is shown in Table 3.1. Net charge deposition in each layer is shown for Co-60 and for each of the sources investigated in this work. Charge deposition is interpreted as the instantaneous charge deposited for the various identified fission product sources. No mechanisms for leakage or other forms of dispersal of the charges have been included. The gamma-ray sources (including Co-60) consistently produce a positive charge on the outer layer of the jacket (Hypalon), but no regular pattern is apparent on the interior of the cable. On the other hand, the beta sources produce a much larger negative charge on the outermost region of the cable; this falls off with decreasing radius in a much more regular pattern. For the case of the cable surrounded by water, the charge buildup is about two orders of magnitude smaller. Of course, in a combined beta-gamma radiation field, there will be some compensation of the opposite signed charge depositions. Interpretation of these results and their importance insofar as failure of the cable is concerned must await analysis of the mechanisms of damage in the cable.

TABLE 3.2  
Charge Deposition in the Cable

Net Electrons Deposited per  $10^3$  Source Gamma Rays

Material	Zone Outer Radius (mm)	$^{60}\text{Co}$	Airborne				Plate-Out				Waterborne			
			Source 1 1 min	Source 1 4 days	Source 2 1 min	Source 2 4 days	Source 1 1 min	Source 1 4 days	Source 2 1 min	Source 2 4 days	Source 1 1 min	Source 1 4 days	Source 2 1 min	Source 2 4 days
Hypalon	11.304	-5.10	-1.30	-0.30	-1.70	-0.45	-9.15	-8.15	-8.15	-5.00	-0.95	-0.85	-1.60	-0.75
"	10.847	-2.35	-0.45	0.10	-0.80	0.15	-0.55	0.25	-1.95	-0.80	-0.40	-0.15	0.35	0.05
"	10.390	0.45	0.40	-0.05	0.20	-0.05	1.25	0.50	0.15	-0.35	0.60	0.20	-0.15	0.15
"	9.932	0.70	-0.65	0.30	0.35	0.15	0.25	0.80	-0.90	1.55	-0.30	0.10	0.15	-0.20
EPR	9.474	0.10	0.25	-0.05	-0.10	0.15	-0.65	-1.20	0.75	-1.25	-0.10	0.10	0.25	0.35
"	8.928	-0.35	0	-0.25	0.15	-0.15	-1.05	0.75	-0.35	0.90	0.50	-0.10	-0.05	-0.25
"	8.382	-0.30	-0.15	0.25	-0.15	-0.20	-1.05	0.25	0.05	-0.70	-0.20	0.05	-0.25	-0.10
"	7.836	0	-0.50	-0.10	-0.40	0	0.95	-0.60	0.35	-0.35	-0.25	-0.25	-0.20	0.10
Copper	7.290	-0.60	0	0.10	0.25	0.20	0.20	0	-0.25	0.45	-0.15	-0.15	0.25	0.05
"	5.832	-0.25	0.25	-0.10	-0.10	-0.20	0.55	0.60	0.60	0.30	0.35	0.10	0.10	0.05
"	4.374	1.50	0.15	0.05	-0.05	0.05	-0.30	-0.30	0.10	-0.10	-0.25	-0.05	0	-0.05
"	2.916	-0.30	-0.15	-0.05	0.20	-0.05	0	0.15	-0.40	0	0.05	0.05	0.05	0
"	1.458	-0.15	0.10	0	-0.05	0.05	0	-0.05	0.25	0	-0.05	0	0	0

Net Electrons Deposited per  $10^3$  Source Betas

Material	Zone Outer Radius (mm)	$^{60}\text{Co}$	Airborne				Plate-Out				Waterborne			
			Source 1 1 min	Source 1 4 days	Source 2 1 min	Source 2 4 days	Source 1 1 min	Source 1 4 days	Source 2 1 min	Source 2 4 days	Source 1 1 min	Source 1 4 days	Source 2 1 min	Source 2 4 days
Hypalon	11.304	-5.10	60.90	175.80	75.60	169.80	350.20	363.30	357.30	535.80	2.94	2.01	2.76	8.09
"	10.847	-2.35	29.00	10.70	29.30	11.90	114.50	116.70	119.60	65.50	1.34	0.40	0.88	1.08
"	10.390	0.45	22.60	0.60	22.70	2.00	60.50	61.33	56.50	11.50	0.84	0.15	0.40	0.27
"	9.932	0.70	17.30	0	17.10	0.20	34.90	39.00	34.00	3.40	0.46	0.05	0.24	0.02
EPR	9.474	0.10	14.20	0	14.90	0.10	19.80	17.33	17.90	0.60	0.33	0.06	0.11	0.01
"	8.928	-0.35	12.30	0	9.80	0	9.70	12.00	9.30	0.20	0.19	-0.01	0.03	0.01
"	8.382	-0.30	9.10	0	7.20	0	7.10	4.33	7.70	-0.10	0.11	0.02	0.03	0
"	7.836	0	8.20	0	5.20	0	4.80	3.33	3.20	0.10	0.13	0.02	0.02	0
Copper	7.290	-0.60	26.40	0	16.10	0	9.10	10.33	8.20	0	0.26	0	0.01	0
"	5.832	-0.25	0.50	0	0	0	0.10	0	0.10	0	0	0	0	0
"	4.374	1.50	0	0	0	0	0.10	0	0	0	0	0	0	0
"	2.916	-0.30	0	0	0	0	-0.10	0	0	0	0	0	0	0
"	1.458	-0.15	0	0	0	0	0	0	0	0	0	0	0	0

Results of the depth-dose calculations for the Source 1 and simulator spectra are shown in Figures 3.2 through 3.7. Since the shapes of the depth-dose profiles are of primary interest here, the simulator results were normalized to the LOCA calculations to give the same dose in the outer layer of the jacket. Clearly, the gamma (LOCA) sources are reasonably uniform across the insulation and jacket. Just as clearly, the limited penetration power of the betas results in steep depth-dose gradients.

### 3.2.3 Discussion

If equivalence of these profiles is to be used as the only basis for judging simulator adequacy, then it must be concluded that these isotopic sources are inadequate; the most serious discrepancy is with the beta sources, as expected. The penetrability and energy loss characteristics of beta particles are very different from those of gamma rays, and thus it is not surprising that mono-energetic gamma sources provide a poor simulation of betas.

However, before judgments on simulator adequacy can be made, it is necessary to understand and evaluate the damage and failure mechanisms due to radiation for each piece of Class 1E equipment. This is the subject of a continuing effort and one on which simulator adequacy will be ultimately judged; the calculations represented in this section are only part of the basis for adequacy assessment.




Figure 3.2

Comparison of depth-dose for Co-60 and Cs-137 with airborne gamma rays (Source 1). The isotopic source results have been normalized at the outer zone (surface) of Hypalon




Figure 3.3

Comparison of depth-dose for Co-60 with airborne betas (Source 1); Co-60 result normalized to the average dose at the surface




Figure 3.4

Comparison of depth-dose for Co-60 and Cs-137 with plate-out gamma rays (Source 1). Both the Co-60 and Cs-137 results have been normalized to the average surface dose




Figure 3.5

Comparison of depth-dose for Co-60 (normalized at average dose in surface zone) with plate-out betas (Source 1)




Figure 3.6

Comparison of depth-dose for Co-60 (normalized to average dose in surface zone) with waterborne gamma rays (Source 1)




Figure 3.7

Comparison of depth-dose for Co-60 (normalized to average dose in surface zone) with waterborne betas (Source 1)

### 3.3 References

- 3.1 L. L. Bonzon, N. A. Lurie, D. H. Houston, and J. A. Naber, "Definition of Loss-of-Coolant Accident Radiation Source: Summary and Conclusions," SAND78-0091/IRT 8167-004, Sandia Laboratories, Albuquerque, NM, May 1978.
- 3.2 "Qualification of Safety-Related Electric Equipment for Nuclear Power Plants," USNRC Regulatory Guide 1.89 Rev. 1 (Draft), November 1, 1976.
- 3.3 L. L. Bonzon, N. A. Lurie, D. H. Houston, and J. A. Naber, "Definition of Loss-of-Coolant Accident Radiation Source," SAND78-0090/IRT 8167-002, Sandia Laboratories, Albuquerque, NM, February 1978.
- 3.4 N. A. Lurie, J. A. Naber, and L. L. Bonzon, "Adequacy of Radiation Sources for Qualification of Class 1E Reactor Components," IRT 8167-003/SAND78-016A, Transactions of the American Nuclear Society, Vol 28, 1978.
- 3.5 N. A. Lurie, "Calculations to Support Radiation Simulator Adequacy Assessments for Class 1 Equipment," Draft IRT 8167-010, April 1978. (Draft report for Sandia review and comment.)
- 3.6 "Reactor Safety Study: An Assessment of Accident Risks in U. S. Commercial Nuclear Power Plants; Appendix VII, Release of Radioactivity in Reactor Accidents," WASH-1400/NUREG 75/014, U. S. Nuclear Regulatory Commission, October 1975.
- 3.7 L. L. Bonzon, K. T. Gillen, and F. V. Thome, "Qualification Testing Evaluation, Quarterly Report, January-March, 1978," SAND78-0799, Sandia Laboratories, Albuquerque, NM, August 1978.
- 3.8 L. L. Bonzon, "Radiation Signature Following the Hypothesized LOCA," SAND76-0740/NUREG 76-6521, Sandia Laboratories, Albuquerque, NM, October 1977 (Revised).

#### 4. Accelerated Aging Study

The activities under Task 3 were numerous and diverse. The programmatic activities were discussed in Section 1.4; Section 4.1 highlights the various technical activities. Section 4.2 details a specific program aspect that engendered particular effort and achieved a significant milestone during the reported quarter.

##### 4.1 Task 3 - Technical Activities Summary

Publications and Presentations: A paper entitled "Computer Modeling of Polymer Radiation Chemistry,"<sup>4.1</sup> was presented by R. Clough at the Fifth International Symposium on the Chemistry of the Organic Solid State, Brandeis University in June; it will also be published in the proceedings of the symposium. The computer program duplicates the structural changes that occur during irradiation of polyethylene with input variable in terms of temperature, irradiation rate, and details of the initial material composition.

A full paper entitled, "A Model for Combined Environment Accelerated Aging Applied to a Neoprene Cable Jacketing Material,"<sup>4.2</sup> was submitted in June to the 1978 Conference on Electrical Insulation and Dielectric Phenomena, to be held October 29-November 2, 1978, in Pocono Manor. In the paper, a model potentially applicable to combined environment aging and methods for carrying out accelerated aging in combined environment situations is discussed; data on single and combined environment aging of neoprene are presented and analyzed using the proposed model.

Alternate Damage Indicators: Two methods to evaluate electric cable "age" using active on-line electric measurements were initially evaluated during this quarter.

Based on LOCA-simulation testing,<sup>4.3</sup> it was found that the dissipation factor changes as cable is aged. (The dissipation factor is

the ratio of loss current to charging current in the dielectric and indicates the quality of the "capacitor.") Following this test, arrangements were made with an equipment supplier to supply test equipment for evaluation. Preliminary testing of cables in ambient- and elevated-temperature environments indicated that the method has potential but requires further refinement and automation of the test equipment.

A separate technique to measure dielectric conductivity (the product of angular frequency and loss factor) was also evaluated.<sup>4.4</sup> Using digital processing techniques and fast Fourier transform analysis, the technique was evaluated using test equipment supplied by an equipment supplier. Loss could be determined in the cable, but not dispersion of the loss, because of equipment and computer program limitations. Further refinement of the test apparatus is underway by the supplier and the technique will be reevaluated.

Fire-Retardant Aging Program: The study to investigate the effects of aging on fire retardants in electric cable is progressing. Two polymers, ethylene propylene terpolymer and chlorosulfonated polyethylene, commonly used in cables for nuclear power generating stations, have been master-batch compounded into representative rubber formulations. Four fire retardants are being evaluated. Materials with and without fire retardants are being aged in thermal, radiation, and combined thermal-radiation environments. A contract has been let to the Smithers Laboratory to perform combustion tests using the Ohio State Rate Release Calorimeter. Combustion tests are scheduled to begin in late August. Simultaneous analytical/chemical tests will be made on the samples to measure fire-retardant retention.

Embrittled Polyethylene Cable Evaluation: Accelerated aging experiments on cables obtained from the Savannah River Plant reactor building have been essentially completed. The experiments were designed to determine if deterioration observed in the polyethylene insulation of cables was primarily due to thermal environments or if extremely large

synergistic effects of combined radiation and temperature environments might have been a major factor in their deterioration. Polyvinyl chloride-jacketed, polyethylene-insulated cable, which had not been exposed to the reactor environment, was exposed to single, sequential, and combined thermal and/or radiation environments. Although the results are still being evaluated, preliminary analysis indicates that strong synergistic effects exist both for the polyethylene insulation and for the polyvinyl chloride jacket.

NRL Subcontract: Since April 1977, the Naval Research Laboratories (NRL) has been subcontracted to provide radiation services related to the accelerated aging study. A number of modern cable insulation and jacketing materials have been aged in various combinations of radiation, temperature, and humidity. The subcontract was extended through this fiscal year to provide a test facility complementary to the Sandia (LICA) irradiation facility. An additional series of dose rate, humidity, thermal, and combined aging experiments were completed this quarter and are currently being evaluated.

Computer Calculations on Polyethylene Radiation Degradation: Work has continued on a computer program to model the structural changes that occur in polyethylene exposed to high energy radiation under a variety of radiation and temperature conditions. The program is based on kinetic parameters for free radical mediated chemical reactions which have been taken from the literature. Computed results on yields of hydrogen evolution and crosslinking, including the effects of temperature, have been obtained. Some dose-rate effects data have also been generated. Further calculations on these and other related phenomena are planned. Parameters for inclusion of molecular oxygen in the reactions and for allowance of a wider range of initial structural features in the unirradiated polymer are being examined for inclusion in the computations. A presentation describing the methodology of the program and the results obtained to date was given at the Fifth International Symposium on the Chemistry of the Organic Solid State at Brandeis University, June 12-16.4.1

Low Intensity Cobalt Array (LICA) Facility: During the past quarter, a number of aging cells have been constructed and tested in the new radiation aging facility (a more complete description of this facility is in Section 4.2). Room temperature radiation aging exposures have been applied to (1) a PVC jacketed, polyethylene insulated cable (from Savannah River) at two different dose rates; (2) various commercial cable material (EPR, Hypalon, Tefzel®); and (3) sheets of specially formulated EPR and Hypalon materials which will be used to investigate fire-retardant aging. Combined environment aging exposures have been applied to the Savannah River cables at 80°C and 4 krad/hr in both air and inert (nitrogen or argon) environments. In addition, a neoprene material has been aged in eight different combined environments in an attempt to generate sufficient data to make an early determination of the utility of the proposed combined environment accelerated aging method.

Thermal Aging Facility: Since the completion of this new facility (see Section 4.2), a number of materials have been or are being aged at various temperatures ranging from 363°K to 423°K. The materials include a chloroprene jacket, three chlorosulfonated polyethylene materials, a CLPO insulation, and an EPR insulation. In addition, unused Savannah River cable has been aged at 80°C in an air-circulating oven.

#### 4.2 Aging Facilities\*

In order to carry out certain aspects of the extensive experimental work proposed for the aging program, two versatile aging facilities have been constructed. The first is a low-intensity radiation-aging facility (LICA) which allows combined environment accelerated aging to be carried out under selected conditions of radiation dose rate, temperature and gaseous atmosphere. The second facility is useful for carrying out

---

® Registered trademark of E. I. du Pont de Nemours and Company, Inc.

\*This section prepared by K. Gillen, L. Jones, and E. Salazar, Division 5813.

thermal aging under various gaseous environments and gas flow conditions. Detailed descriptions of these facilities and their capabilities will be given in this section.

#### 4.2.1 Low Intensity Radiation Aging Facility

Figure 4.1 shows an artist's rendition of the radiation facility. Approximately 9000 curies of Co-60 is positioned at the bottom of a water-filled concrete tank whose dimensions are 4 ft wide by 8 ft long by 15 ft deep. Radiation aging is carried out in water-tight test cells by lowering the cells to the bottom of the tank. Thirteen feet of water, separating the Co-60 from experimenters at the top of the tank, provides radiation shielding. A water level control system and various radiation level monitors connected to an alarm system provide backup safety.

Details of the radiation aging portion of the facility are shown in Figure 4.2. Two parallel channels support the Co-60 holder, air tanks, and the test cell holders. The Co-60 holder, configured similar to a linear test tube rack, has 58 equally spaced holes each capable of containing a single 0.45 in. diameter pencil of Co-60. Currently, twenty five 12-in. long Co-60 pencils (approximately 9000 total curies) are fairly evenly distributed along the holder. The extra 33 holes allow flexibility in minimizing dose rate gradients parallel to the cobalt holder and could be used as high-dose-rate locations for small samples. Test cell holders, each containing 4 cylindrical holes, are oriented parallel to the linear cobalt holder and are located on both sides of the source at various distances from it. Test cells placed in any of the holes of a given holder receive comparable radiation dose rates. The particular dose rate is governed by the distance from the cobalt array and by the shielding between the test cell and the array. Gradients in dose rates occur in the individual test cells; for example, there is a dropoff in dose rates between the parts of the cell closest to, and furthest from, the cobalt. Minimizing these radial gradients requires moving the cell as far from the cobalt as possible. At the same time, it is desirable to minimize the

amount of Co-60 required for a given dose rate at a given distance; this necessitates a minimum of shielding between the test cells and the cobalt. These two requirements were satisfied by using air tanks for filling any space between the Co-60 holder and the test cell holders and by designing air-filled (water-tight) test cell holders. This arrangement not only minimizes gradients across the test cells for a given dose rate, but also minimizes the steps in dose rate occurring among adjacent test cell holders.




Figure 4.1. Low-intensity cobalt array (LICA) test facility




Figure 4.2. Linear array radiation source and test chamber arrangement

Another feature of the design is the flexibility to reposition the test cell holders along the track to select appropriate dose rates for a given experiment. This also implies that new test cell holders capable of holding bigger size test cells could be easily incorporated into the apparatus.

A detailed sketch of a test cell is shown in Figure 4.3. The cylindrical sample aging region (4-in. diameter and 7 in. long) is located inside a brass can, which is in turn suspended from the lid of a double-walled stainless-steel can. (The double-walled design provides some thermal insulation.) When the stainless-steel lid is lifted free of the stainless-steel can, a brass lid at the bottom of the brass can is easily removed, allowing access to the sample aging region. The sample region is

heated using an insulated nichrome wire wrapped around the brass can and around a pancake heater which lies between the brass can and the stainless-steel lid. The auxiliary pancake heater was found to be useful for reducing rather substantial temperature gradients at the top of the sample aging region caused by the heat-sink effect of the massive top of the stainless-steel can. To accurately control and monitor the temperature in the sample region, two resistance temperature devices (RTDs) were incorporated in the design. A control RTD is directly clamped to the inside wall of the brass can and a monitor RTD is positioned close to the center of the sample aging region. A 1-1/8 in. OD plastic tube runs from the top of the stainless-steel can up through the water tank. Lead wires for the heater and the two RTDs feed through this tube. In addition, a small tube inside the outer plastic tube is used to circulate air or other gaseous environments past the sample region at controlled flow rates. The temperature capabilities of the test cells are room temperature to 423°K; with slight modification it should be possible to reach 523°K. At 423°K, long term stability and accuracy of the temperature was found to be better than  $\pm 0.3^{\circ}\text{K}$ . Measured temperature gradients across the sample aging region were less than  $\pm 1.0^{\circ}\text{K}$ .

Figure 4.4 shows the current arrangement of the test cell holders as viewed from the top of the tank. Three adjacent test cell holders are located as close as possible to one side of the cobalt source. On the other side, a 9-in. wide air tank separates three adjacent test cell holders from the cobalt. The radiation doses for the various test cell locations in this arrangement were measured using TLD-400 dosimeter chips. During the mapping, test cells filled all 24 aging locations, a situation similar to that anticipated during actual aging exposures. Analysis after exposure of a single TLD chip leads to an uncertainty in the estimated dose rate of  $\pm 10\%$ . However, by using numerous chips distributed throughout a given test cell, dose rates can be determined with greater precision. A large number of readings in a given cell allow estimates to be made of dose rate gradients in the sample aging region.




Figure 4.3. Typical heater test cell




Figure 4.4. Current LICA arrangement with approximate centerline dose rates noted for each test cell holder

Some of the mapping results are summarized in Figures 4.4 through 4.7. Figure 4.4 shows the approximate dose rates found for the 6 test cell locations. The dose rates range from 95 krad/hr to 4 krad/hr in roughly five equal steps. The test cell holders are labeled with Roman numerals I through VI in order of their decreasing dose rates. Figure 4.5 shows dose rate results for dosimeters located on a line parallel to the cobalt source and through the centers of the sample regions in the four test cells of radiation level I. The results imply that dose rate gradients across a given cell are not severe. Figure 4.6 gives the vertical dose

profile along the center of an outside cell in level I. These results show that vertical gradients are also small for a 6-in.-long sample. On the other hand, radial gradients (gradients along the direction perpendicular to the plane of the cobalt) are significant for all test cell locations. The largest radial gradients occur in the cells of level I; representative data are shown in Figure 4.7 for a line through the center of the sample aging region of an outside level I cell. The dose rate drops from approximately 120 krad/hr at the wall nearest the cobalt to 75 krad/hr at the farthest wall. If a large component is being aged, periodic rotations of the test cell during aging can be used to achieve approximately homogeneous total radiation doses throughout the component. Rotations may not be necessary for smaller components. (The radiation facility is currently being used to age electric cables and cable materials.) The samples are 5 in. long with relatively small cross sections. Since vertical radiation dose gradients are small, the samples can be aged standing up in sample baskets which are compartmentalized (Figure 4.7C). By noting the particular compartment used for aging a given sample, the experimental dose rate can be estimated to  $\pm 5\%$ .

In summary, the recently completed radiation aging facility will be useful for carrying out long term aging experiments at controlled temperatures (maximum of 423°K), radiation dose rates (maximum of 100 krad/hr) and atmospheric conditions (dry and humid air, inert gas, etc.). The flexibility of the design will allow larger aging chambers to be easily constructed if necessary. It will also be possible to modify the chambers so that electrical power can be supplied to a component during aging.




Figure 4.5. Dose rate parallel to linear cobalt array in closest test chambers, level I




Figure 4.6. Vertical dose rate profile along center of level I (outside) can






Figure 4.7. A. Dosimeter chip location for radial mapping;  
 B. Radial dose rate results;  
 C. Sample basket configuration

#### 4.2.2 Thermal Aging Facility

Thermal aging is normally carried out in air-circulating ovens. There are numerous disadvantages and potential problems associated with this arrangement. Large temperature gradients occur in many ovens, and rapid movement of air past samples will often hasten the removal of volatile components (plasticizers, anti-oxidants), leading to unrealistically accelerated degradations. If two or more materials are aged in the same oven there is the danger that outgassing or volatile degradation products from one material will affect the deterioration of another material. If, for this reason, only one material is aged in a given oven, the number of ovens required for a long-term aging program can be prohibitive.

With the above problems in mind, a unique and versatile thermal aging facility was constructed. The facility uses air-circulating ovens, each modified to accomodate a number of self-contained aging cells. A detailed sketch of one of these aging cells is shown in Figure 4.8. It consists of a bell jar glass chamber which rests on a silicone gasket which in turn rests on an aluminum stand. A gas inlet line enters the sample aging region from the bottom through holes in the aluminum base and the silicone gasket. A small hole at the top of the glass chamber serves as a gas exit and as a means of introducing a permanently positioned thermocouple into the center of the sample region. Lead and aluminum collars help to insure an air-tight seal around the base of the glass chamber. These seals also improve the thermal stability and lessen temperature gradients in the sample aging region. A perforated stainless steel sample basket sits inside of the glass chamber. To gain access to the samples, the glass chamber is lifted and tipped sideways to allow the sample basket to slip free.

The aging cells were constructed in two sizes; smaller cells hold 2 in. ID by 5 in.-long sample baskets, while larger cells accomodate 3 in. ID by 5 in.-long baskets. Three of the smaller aging cells have been incorporated in 1 ft<sup>3</sup> air-circulating oven; as many as six of the large cells have been placed in bigger ovens.




Figure 4.8. Section view of temperature aging chamber

The advantages of this aging facility over a typical air-circulating oven are numerous. One oven equipped with from three to six aging cells can be used to age simultaneously a number of different materials without interactions among materials. In addition, the gas inlet system allows aging to be carried out under various atmospheres (air, inert gas) and controlled gas-flow conditions. Thermocouples permanently positioned in each aging cell offer a convenient means of monitoring the temperature

near the center of the samples. The thermal mass of the metal collars offers other advantages; extensive temperature mapping inside the cells indicates that variations in temperature throughout the sample region are less than 1°K at 423°K, and there is much less short-term cyclic temperature fluctuation inside a cell than in the surrounding oven.

This facility is currently being used to carry out thermal oxidative aging on various Class 1E qualified electric cables and cable materials in order to obtain acceleration functions appropriate to single environment thermal aging.

#### 4.3 References

- 4.1 R. L. Clough, "Computer Modeling of Polymer Radiation Chemistry," SAND78-0876A, May 1978. Presented at, and published in the proceedings of, the Fifth International Symposium on the Chemistry of the Organic Solid State, Brandeis University, Waltham, MA, June 13-16, 1978.
- 4.2 K. T. Gillen and E. A. Salazar, "A Model for Combined Environment Accelerated Aging Applied to a Neoprene Cable Jacketing Material," SAND78-0559C, June 1978. Accepted for publication/presentation at the 1978 Conference on Electrical Insulation and Dielectric Phenomena, Pocono Manor, PA, October 29 - November 2, 1978.
- 4.3 F. V. Thome, "Preliminary Data Report, Test IX. Simultaneous Mode; Cables, Splice Assemblies, and Electrical Insulation Samples," SAND78-0718, Sandia Laboratories, Albuquerque, NM, April 1978.
- 4.4 Internal Memorandum, O. Milton to R. T. Johnson, "Dielectric Spectroscopy Applied to the Aging of Cable Dielectrics," May 17, 1978.

DISTRIBUTION:

U.S. Nuclear Regulatory Comm. R2 (335)  
Division of Document Control  
Distribution Services Branch  
7920 Norfolk Avenue  
Bethesda, MD 20014

3 M Company  
2501 Hudson Road  
St. Paul, MN 55119  
Attn: W. P. Smith

Aerojet Nuclear Company  
Idaho National Eng. Lab  
550 Second Street  
Idaho Falls, ID 83401  
Attn: N. C. Kaufman

Alison Control Inc.  
35 Daniel Road  
Fairfield, NJ 07006  
Attn: C. A. Doak

Allis Chalmers (2)  
4620 Forest Avenue  
Norwood, OH 45212  
Attn: R. F. Gilton  
V. R. Scardina

American Electric Power Service (3)  
2 Broadway  
New York, NY 10004  
Attn: G. D. Weatherford  
P. K. Eapen  
K. E. Loader

American Insulated Wire Corp.  
Central Ave. and Freeman St  
Pawtucket, RI 02862  
Attn: A. M. Aubrey

AMN Impianti Termici E. Nucleari  
Via Pacinotti, 20  
16151 Genova Sampierdarena  
Italy  
Attn: G. Bottinelli

Anaconda Wire and Cable Company  
East 8th Street  
Marion, IN 46953  
Attn: T. H. Ling

Anaconda Co.  
Wire and Cable Division  
421 King Street  
Alexandria, VA 22314  
Attn: M. J. Bork, Jr.

Argonne National Laboratory  
Box 2528  
Idaho Falls, ID  
Attn: R. Curran

ASEA-ATOM  
Engineering  
S-721 04  
Vasteras  
Sweden  
Attn: G. Kvist

ASEA KABEL AB  
P.O. Box 42108  
S-126 12  
Stockholm  
Sweden  
Attn: C. T. Jacobsen

Atomic Energy of Canada, Limited  
Chalk River  
Ontario  
Canada  
Attn: G. F. Lynch

Atomic Energy of Canada, Limited (2)  
Power Projects  
Sheridan Park Research Community  
Mississauga  
Ontario L5K1B2  
Attn: N. Cheesman  
B. Marshall

Babcock & Wilcox  
7735 Old Georgetown Road  
Bethesda, MD 20014  
Attn: R. B. Borsum

Babcock & Wilcox (5)  
P.O. Box 1260  
Lynchburg, VA 24505  
Attn: J. Cuvelier  
T. Gochowsky  
A. Schwartz  
C. Whitmarsh  
N. Burstein

DISTRIBUTION: (cont)

Bailey Meter Company (2)  
29801 Euclid Avenue  
Wickliffe, OH 44092  
Attn: R. K. Jahn  
J. W. Malcolm

Battelle Columbus Laboratory (2)  
505 King Avenue  
Columbus, OH 43201  
Attn: W. H. Abbott  
G. Derringer

Battelle Institute V  
Am Romerhof 35  
D6000 Frankfurt/M  
Federal Republic of Germany  
Attn: B. Holzer

Bechtel Power Corporation  
12400 E. Imperial Highway  
Norwalk, CA 90650  
Attn: P. Kine

Bechtel Power Corporation  
P.O. Box 3965  
San Francisco, CA 94119  
Attn: J. Murrow

Bechtel Power Corp. (2)  
1233 West Loop South  
Houston, TX 77027  
Attn: F. B. Marsh  
R. Velarde

Bechtel Corporation (7)  
50 Beale Street  
San Francisco, CA 94105  
Attn: T. G. Cullen  
C. M. Graft  
R. Nossardi  
J. Wickert  
K. Bailey  
R. Stade  
A. Valachovic

Belgonucleaire  
rue de Champ-de-Mars, 25  
B-1050 Brussels  
Belgium  
Attn: J. P. van Dievoet

Bechtel Power Corp. (10)  
15740 Shady Grove Road  
Gaithersburg, MD 20760  
Attn: F. Roddy  
T. S. Killen  
R. L. Ashley  
D. Gaston  
W. Hopkins  
R. Vatsan  
C. E. Corley  
D. C. Gasdo  
B. Kanga  
N. Willoughby

Bendix Corp.  
Sidney, NY 13838  
Attn: J. B. Becker

Boston Edison Co.  
800 Boylston St.  
Boston, MA 02199  
Attn: R. Venkataraman

Boston Edison Co.  
1165 Mass. Ave.  
Boston, MA 02125  
Attn: A. V. Morisi

Boston Ins. Wire & Cable Co.  
65 Bay Street  
Boston, MA 02125  
Attn: A. Garshick

Brand-Rex Company  
Willimantic, CT 06226  
Attn: E. M. Walton

Brookhaven National Laboratory (2)  
Department of Applied Science  
Associated Universities, Inc.  
Upton, L.I., NY 11973  
Attn: G. W. Bennett  
D. L. Metz

Bundesanstalt fur Material Prufung  
Unter den Eichen 87  
1 Berlin 45  
Germany  
Attn: K. Wundrich

Burndy Corp.  
Norwalk, CT 06856  
Attn: R. Lai

DISTRIBUTION: (cont)

Burns & Roe, Inc. (2)  
633 Industrial Avenue  
Paramas, NJ 07652  
Attn: E. Gahan  
T. Jhun

Calspan Corp.  
P.O. Box 235  
Buffalo, NY 14221  
Attn: F. A. Bierl

Carboline Company (2)  
350 Hanley Industrial Court  
St. Louis, MO 63144  
Attn: J. R. Lopata  
J. F. Montle

Carolina Power & Light Company  
P.O. Box 1551  
Raleigh, NC 27602  
Attn: E. G. Hollowell

CERN  
Laboraotorie 1  
CH-1211 Geneva 23  
Switzerland  
Attn: H. Schonbacher

Centre d'Etudes Nucleaires de Saclay (3)  
Boite Postale No. 21  
91190 GIF-SUR-YVETTE  
France 37.08  
Attn: J. Laizier  
E. Bouteiller  
P. Tanguy

Cerro-Rockbestos  
P.O. Box 1102  
New Haven, CT 06504  
Attn: G. Buettner

Charles T. Main, Inc.  
Southeast Tower, Prudential Center  
Boston, MA 02199  
Attn: J. F. Bates

Cleveland Electric Illuminating (2)  
P.O. Box 5000  
Cleveland, OH 44101  
Attn: A. Kaplan  
D. Green

Collyer Insultated Wire  
100 Higginson Ave.  
Lincoln, RI 02865  
Attn: J. R. Kushner

Colt Industries  
701 Lawton Avenue  
Beloit, WI 53511  
Attn: W. Brill

Combustion Engineering (9)  
1000 Prospect Hill Road  
Windsor, CT 06095  
Attn: D. Sentell  
R. P. Daigle  
G. Caruthers  
L. M. Johnson  
J. Carter  
J. Corsi  
R. Bradshaw  
W. Albert  
S. Stephansen

Commonwealth Associates, Inc. (5)  
209 E. Washington  
Jackson, MI 49201  
Attn: G. K. Henry  
N. C. Olson  
M. J. Kolar  
J. R. McCarty  
D. M. Berger

Commonwealth Edison Co.  
P.O. Box 767  
Chicago, IL 60137  
Attn: H. K. Stolt

Conductores Monterrey, S.A.  
APDO Postal 2039  
Monterrey, N.L.  
Mexico  
Attn: Ing. Patricio G. Murga G.

Consolidated Edison Co. of N.Y., Inc  
4 Irving Place  
New York, NY 10003  
Attn: L. J. Savio

Cutler Hammer  
4201 N. 27th St.  
Milwaukee, WI 53216  
Attn: J. Kroll

DISTRIBUTION: (cont)

    Cyprus/Rome Cable  
    P.O. Box 71  
    Rome, NY 13440  
    Attn: I. J. Marwick

    Department of Energy  
    Albuquerque Operations Office  
    Special Projects Division  
    Albuquerque, NM 87115  
    Attn: D. K. Nowlin

    Department of Energy  
    Sandia Area Office  
    Albuquerque, NM 87115  
    Attn: G. E. Cordova

    Detroit Edison  
    2000 Second Ave.  
    Detroit, MI 48226  
    Attn: V. J. Herter

    D. L. Dye  
    Consulting Physicist  
    12825 SE 45th Place  
    Bellevue, WA 98006

    Dow Corning (2)  
    Midland, MI 48640  
    Attn: F. C. Dall  
          T. Orbeck

    Duke Power Company (4)  
    P.O. Box 2178  
    Charlotte, NC 28242  
    Attn: J. L. Creshaw  
          W. J. Foley  
          R. A. Pace  
          B. M. Rice

    EG&G Idaho Inc.  
    P.O. Box 1625  
    Idaho Falls, ID 83401  
    Attn: INEL Technical Library

    E. I. du Pont de Nemours  
    Plastic Products & Resins  
    Parkersburg, WV 26101  
    Attn: J. O. Punderson

    E. I. du Pont de Nemours  
    Elastomer Chemicals  
    Trenton, NJ 08600  
    Attn: J. C. Hedberg

    E. I. du Pont de Nemours (3)  
    Savannah River Laboratories  
    Aiken, SC 29801  
    Attn: N. E. Bibler  
          L. W. Patrick  
          J. Leeth

    E. I. du Pont de Nemours (2)  
    Wilmington, DE 19898  
    Attn: E. W. Fasig, Jr.  
          C. Palmer

    Electra de Viesgo, S.A.  
    Departamento Nuclear  
    Medio, 12 - SANTANDER  
    Spain  
    Attn: J. L. del Val

    Electricite de France (2)  
    Service Etudes Et Projects  
    Thermiques et Nucleaires  
    Tour E.D.F.-G.D.F. Cedex No. 8  
    92080 PARIS LA DEFENSE  
    France  
    Attn: J. Roubault  
          M. Barbet

    Electric Power Research Institute (4)  
    P.O. Box 10412  
    Palo Alto, CA 94303  
    Attn: R. Swanson  
          D. G. Cain  
          R. Pack  
          B. Bernstein

    Electric Penetration Research Assoc.  
    P.O. Box 1783  
    Huntington Beach, CA 92647  
    Attn: D. D. Yuey

    Essex International  
    P.O. Box 1000  
    Lafayette, IN 47902  
    Attn: J. L. Steiner

DISTRIBUTION: (cont)

EURATOM

C.E.C. J.R.C.  
Ispra (Varese), Italy  
Attn: G. Mancini

EURATOM

Joint Research Centre  
Petten Establishment  
European Communities  
Petten, the Netherlands  
Attn: M. Van de Voorde

Factory Mutual Research (2)  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
Attn: M. J. Miller  
S. N. Bajpai

Fisher Controls Co.  
P.O. Box 190  
Marshalltown, IA 50158  
Attn: H. Rich

Florida Power Corp.  
P.O. Box 14042  
St. Petersburg, FL 33733  
Attn: A. L. Gomez

Florida Power & Light  
P.O. Box 013100  
Miami, FL 33101  
Attn: W. Thue

Foxboro Company (3)  
Foxboro, MA 02035  
Attn: J. Childs  
J. T. Keiper  
J. Rooney

Framatome (2)  
77/81, Rue Du Mans  
92403 Courbevoie  
France  
Attn: J. Meyer  
G. Chauvin

Franklin Institute Research  
Laboratories (3)  
20th and Parkway  
Philadelphia, PA 19103  
Attn: S. P. Carfagno  
D. Paulson  
Z. Zudans

Furukawa Electric Co., Ltd.  
Hiratsuka Wire Works  
1-9 Higashi Yawata 5 Chome  
Hiratsuka, Kanagawa Pref.  
Japan 254  
Attn: E. Oda

General Atomic Company  
P.O. Box 426  
Platteville, CO 80651  
Attn: J. T. Bauer

General Atomic Company  
P.O. Box 81608  
San Diego, CA 92138  
Attn: T. R. Colandrea

General Cable  
800 Rahway Ave.  
Union, NJ 07083  
Attn: J. G. Quin

General Electric Company (2)  
Research and Development Center  
Schenectady, NY 12305  
Attn: K. N. Mathes  
D. R. Johnston

General Electric Company  
1 River Road  
Schenectady, NY 12345  
Attn: D. J. Meraner

General Electric Company  
3001 East Lake Rd.  
Bldg. 9-1  
Erie, PA 16531  
Attn: W. B. Penn

General Electric Company (3)  
Wire & Cable Products Dept.  
1285 Boston Ave.  
Bridgeport, CT 06602  
Attn: J. E. Conley  
E. Kingsbury  
C. Hosticka

General Electric Company  
4720 Montgomery Lane  
Suite 1107  
Bethesda, MD 20014  
Attn: N. C. Shirley

DISTRIBUTION: (cont)

General Electric Company  
6901 Elmwood Ave.  
Philadelphia, PA 19142  
Attn: P. W. Juneau, Jr.

General Electric Company  
Silicones  
Waterford, NY 12188  
Attn: T. Loman

General Electric Company (3)  
175 Curtner Avenue  
San Jose, CA 95114  
Attn: L. D. Test  
D. R. Rogers  
W. R. Shelton

Georgia Power and Light  
P.O. Box 4545  
Atlanta, GA 30302  
Attn: J. A. Maxwell

Gilbert Associates (2)  
525 Lancaster Avenue  
Reading, PA 19603  
Attn: V. Willems  
T. L. Kamphouse

Gould, Inc. (2)  
P.O. Box 486  
Ft. Washington, PA 19034  
Attn: C. Kunkel  
E. Rhoads

Gulf States Utilities Co.  
P.O. Box 2951  
Beaumont, TX 77704  
Attn: J. C. Wright

Gulton, S.C.D.  
1644 Whittier Avenue  
Costa Mesa, CA 92627  
Attn: H. Potter

Hanford Engineering  
Development Laboratory  
P.O. Box 1970  
Richland, WA 99352  
Attn: R. Schenter

Henry Pratt Co.  
401 South Highland Ave.  
Aurora, IL 60507  
Attn: R. P. Saar

Hitachi Cable Ltd. (2)  
777 Third Avenue  
New York, NY 10017  
Attn: H. J. Amino  
M. Sasson

IIT Research Institute  
10 West 35th Street  
Chicago, IL 60616  
Attn: I. Pincus

Institute of Electrical and  
Electronics Engineers, Inc.  
345 East 47 Street  
New York, NY 10017  
Attn: J. Fragola

IRT Corporation (3)  
P.O. Box 80817  
San Diego, CA 92138  
Attn: N. Lurie  
J. Wilkenfeld  
D. H. Houston

Isomedix, Incorporated  
P.O. Box 177  
Parisippny, NJ 07054  
Attn: G. R. Dietz

ITT Cannon (3)  
2801 Air Lane  
Phoenix, AZ 85034  
Attn: G. J. Panek  
R. Van Meter  
D. Yue

ITT General Controls  
801 Allen Avenue  
Glendale, CA 92101  
Attn: G. R. Brown

ITT Surprenant  
172 Sterling Street  
Clinton, MA 01501  
Attn: E. W. Bennett

DISTRIBUTION: (cont)

Japan Atomic Energy Research Institute (2)  
Takasaki Radiation Chemistry  
Research Establishment  
Watanuki-Machi  
Takasaki, Gunma-Ken  
Japan  
Attn: Y. Nakase  
S. Machi

M. A. Lamont  
P.O. Box 4305  
East Providence, RI 02914

Masoneilan International Inc.  
63 Nahatan Street  
Norwood, MA 02062  
Attn: J. Waal

Japan Atomic Energy Research Institute  
Tokai-Mura  
Naka-Gun  
Ibaraki-Ken  
Japan  
Attn: A. Kchsaka

Meideusha Electric Mfg. Co. Ltd.  
1-17, 2-Chome Osaki  
Shinagawa-Ku  
Tokyo, Japan  
Attn: M. Kanazashi

John Hopkins University (3)  
Applied Physics Lab.  
John Hopkins Road  
Laurel, MD 20810  
Attn: W. Berl  
R. Fristrom  
L. Hunter

Mission Research Corp.  
735 State Street  
P.O. Box 719  
Santa Barbara, CA 93102  
Attn: A. M. Chodorow

Kaman Sciences Corp.  
1500 Garden of the Gods Road  
Colorado Springs, CO 80907  
Attn: J. White

MPR Associates, Inc.  
1140 Connecticut Ave. NW  
Washington, DC 20036  
Attn: B. C. Klein

Kansai Electric Power Co.  
1203 Allendale Road  
McLean, VA 22101  
Attn: J. Yamaguchi

Naval Research Laboratory  
Washington, DC 20375  
Attn: F. J. Campbell  
E. L. Brancato

Kerite Company  
Seymour, CT 06483  
Attn: J. B. Gardner

Naval Ship Research and  
Development Center  
Electronics Division Code 2772  
Annapolis, MD 21402  
Attn: M. A. DeLucia

Limitorque Corp.  
King of Prussia, PA 19406  
Attn: W. J. Denkowsky

Neely Nuclear Center  
Georgia Institute of Technology  
225 No. Ave. NW  
Atlanta, GA 30332  
Attn: M. V. Davis

Long Island Lighting Co.  
175 East Old Country Road  
Hicksville, NY 11801  
Attn: A. T. Baker

NELPIA (3)  
The Exchange - Suite  
Farmington Avenue  
Farmington, CT 06032  
Attn: P. S. Snyder  
L. P. Mariani  
J. Carney

Los Alamos Scientific Lab  
Los Alamos, NM 87545  
Attn: T. R. England

DISTRIBUTION: (cont)

Neutron Products, Inc.  
Dickerson, MD 20753  
Attn: D. G. Woodward

Niagara Mohawk  
30 Erie Boulevard West  
Syracuse, NY 13202  
Attn: D. E. Sandwick

Niagara Mohawk Power Corp.  
P.O. Box 32  
Lycoming, NY 13093  
Attn: R. L. Raymond

Northeast Utilities Service Co.  
P.O. Box 270  
Hartford, CT 08101  
Attn: R. Luther

Northern Indiana Public Service Co.  
Nuclear Staff  
RR#3, Box 501  
Chesterton, IN 46304  
Attn: R. R. Ray

Nuclear Controls & Electronics Corp.  
175 W. 2950 South  
Salt Lake City, UT 84115  
Attn: R. J. Hall

Nuclear Safety Research Association  
Room No. 1037, National Press Bldg.  
529-14th Street NW  
Washington, DC 20045  
Attn: I. Yabe

NUS Corporation (2)  
4 Research Place  
Rockville, MD 20850  
Attn: D. E. Bassett  
E. R. Wiot

NUS Corporation  
2536 Countryside Blvd.  
Clearwater, FL 33515  
Attn: J. C. Plunkett

Oak Ridge National Labs (4)  
P.O. Box X  
Oak Ridge, TN 37830  
Attn: G. Goldberg  
W. B. Cottrell  
E. W. Hagen  
L. T. Corbin

Offshore Power Systems  
P.O. Box 8000  
Jacksonville, FL 32211  
Attn: J. W. Wanless

Okonite Company (3)  
P.O. Box 340  
Ramsey, NJ 07446  
Attn: E. E. McIllween  
R. A. Guba  
J. S. Lasky

Oy Stromberg Ab,  
Helsinki Works  
Box 118  
SF-00101  
Helsinki 10  
Finland  
Attn: P. Paloniemi

Pacific Gas and Electric  
Diablo Canyon  
P.O. Box 56  
Avila Beach, CA 93424  
Attn: K. Doss

Pacific Gas and Electric (3)  
77 Beale Street  
San Francisco, CA 94106  
Attn: R. Young  
G. C. Lenfestery  
S. Traisman

Pacific Gas & Electric (2)  
245 Market Street  
San Francisco, CA 94106  
Attn: J. H. Lawson  
F. J. Dan

DISTRIBUTION: (cont)

Pennsylvania State Univ.  
Applied Research Lab.  
P.O. Box 30  
State College, PA 16801  
Attn: R. E. Bland

Phelps Dodge Magnet Wire Co.  
P.O. Box 600  
Ft. Wayne, IN 46801  
Attn: P. E. Alexander

Phelps Dodge Magnet Wire Co.  
Foot-of-Point Street  
P.O. Box 391  
Yonkers, NY 10702  
Attn: M. B. Singer

Philadelphia Electric Co. (5)  
2301 Market Street - N3-1  
Philadelphia, PA 19101  
Attn: A. J. Simmons  
J. Cannon  
L. Hamilton  
J. Garland  
F. Light

Plastoid Corporation  
Hamburg, NJ 07419  
Attn: H. Jehan

PORTEC, Inc.  
Electric Products Div.  
1725 Clarkstone Rd.  
Cleveland, OH 44112  
Attn: P. M. Silverberg

Power Conversion Products  
42 East Street  
Crystal Lake, IL 60014  
Attn: C. F. Seyer

Public Service Electric & Gas Co. (2)  
80 Park Place  
Newark, NJ 07102  
Attn: T. J. Martin  
J. Pirrong

Public Service Electric & Gas  
P.O. Box 8000  
Jacksonville, FL 32211  
Attn: P. W. Metcalfe

Puget Power  
Puget Power Building  
Bellvue, WA 98009  
Attn: R. Isernhagen

Pyle National Company  
Bay Bridge Office Plaza  
Suite 335  
5801 Christie St  
Emeryville, CA 94608  
Attn: R. Hansen

Pyle National Company  
1334 North Kostner Avenue  
Chicago, IL 60651  
Attn: J. F. Shearer

Pyle National Company  
18199 Canyon Ct.  
Fountain Valley, CA 92708  
Attn: P. A. Pickens

Raychem Corporation (5)  
300 Constitution Dr.  
Menlo Park, CA 94025  
Attn: F. LaFetra  
W. T. Starr  
C. Shalvoy  
S. E. Schumer  
F. Ballew

Reliance Electric Company (2)  
24701 Euclid Ave.  
Cleveland, OH 44117  
Attn: T. L. Gruber  
W. G. Stiffler

Reynolds Metals Co.  
P.O. Box 27003  
Richmond, VA 23261  
Attn: R. R. Howard

Rhein-Westf TUV  
Steuben Str 53  
D-43 Essen  
Federal Republic of Germany  
Attn: R. Sarturi

Rockwell International  
400 N. Lexington Avenue  
Pittsburgh, PA 15208  
Attn: B. Millerville

DISTRIBUTION: (cont)

Rosemount Incorporated  
P.O. Box 35129  
Minneapolis, MN 55435  
Attn: I. Ismail

R. Salomon  
1621 Kenmare Drive  
Dresher, PA 19025

Samuel Moore and Co.  
P.O. Box 7  
Aurora, OH 44202  
Attn: R. Krobot

Sargent and Lundy (6)  
55 East Monroe Street  
Chicago, IL 60603  
Attn: C. L. Tsai  
C. M. Chiappetta  
C. Halstat  
E. Normand  
A. M. Levy  
R. E. Cotta

Science Applications Inc. (5)  
P.O. Box 2351  
La Jolla, CA 92037  
Attn: V. J. Orphan  
J. A. Naber  
G. L. Simmons  
W. A. Woolson  
M. G. Stamatelatos

Sigmaform Corporation  
2401 Walsh Avenue  
Santa Clara, CA 95050  
Attn: M. J. Stanek

Southern California Edison Co.  
P.O. Box 800  
Rosehead, CA 91770  
Attn: J. L. Cohen

Southern Science Applications, Inc.  
P.O. Box 10  
Dunedin, FL 33528  
Attn: R. P. Hancock

Southern Services Co. (2)  
P.O. Box 2625  
Birmingham, AL 35202  
Attn: W. M. Pate  
H. T. Hubbard

Square D Company  
252 N. Tippecanoe Street  
Peru, IN 46970  
Attn: R. Giska

Stanford Research Inst. (2)  
Menlo Park, CA 94025  
Attn: S. Brauman  
R. Woolfolk

Stone & Webster Eng. Corp.  
P.O. Box 5200  
Cherry Hill, NJ 08034  
Attn: T. Bates

Stone & Webster Eng. Corp.  
P.O. Box 2325  
Boston, MA 02107  
Attn: T. J. McGrath  
A. P. Stakutes  
E. A. Warman  
R. Lo  
G. B. Enticknap  
E. T. Boulette  
A. Fitzpatrick  
R. B. Taylor  
K. Pitty

Studsvik Energiteknik AB  
S-61182  
Nyköping, Sweden  
Attn: E. Hellstrand

Systems Development Corp.  
2500 Colorado Avenue  
Santa Monica, CA 90406  
Attn: J. Mecozzi

Teknekron Energy Resource  
Analysts Corp.  
2118 Milvia Street  
Berkeley, CA 94704  
Attn: J. N. Conway

DISTRIBUTION: (cont)

Tennessee Valley Authority (2)  
300 Union Building  
Knoxville, TN 37902  
Attn: F. W. Chandler  
S. Khalifa

Texas Municipal Power Agency  
600 Arlington Downs Tower  
Arlington, TX 76011  
Attn: J. C. Wright

Texas Utilities Company  
2001 Bryan Street  
Dallas, TX 75201  
Attn: W. Garrison

Thomas and Betts Company  
36 Butler Street  
Elizabeth, NJ 07207  
Attn: M. Bromberg

Tokyo Electric Power Co. Inc.  
No. 1-3 1-Chome Uchisaiwai-Cho  
Chiyoda-Ku, Tokyo, Japan  
Zip Code 100  
Attn: H. Hamada

Toledo Edison  
Edison Plaza  
300 Madison Ave.  
Toledo, OH 43652  
Attn: M. D. Calcamuggio

Traction & Electricite  
Rue de La Science 31  
1040 Brussels, Belgium  
Attn: P. A. Dozinel

Uniroyal  
Emic Bldg., Spencer St.  
Naugatuck, CT 06770  
Attn: J. D. Hunt

United Engineers & Constructors (4)  
30 South 17th Street  
Philadelphia, PA 19101  
Attn: S. G. Kasturi  
M. Pai  
R. E. Allen  
J. M. Fox

U.S. Nuclear Regulatory Commission (32)  
Washington, DC 20555

Attn: M. A. Taylor  
R. E. Heineman  
P. Mathews  
R. Schull  
V. Stello  
R. Ferguson  
L. Rubenstein  
G. A. Arlotto  
E. Imbro  
V. Thomas  
S. Hanauer  
L. Soffer  
J. Slider  
B. Grimes  
C. F. Miller  
A. S. Hintze  
D. S. Sullivan  
I. Villalya  
W. R. Rutherford  
R. Tedesco  
T. Ippolito  
M. Kehnemuyi  
V. Panciera  
V. Benaroya  
W. Butler  
E. G. Case  
K. R. Wichman  
J. Murphy  
K. Seyfrit  
A. Szukiewicz  
P. Tam  
J. Glynn

U.S. Nuclear Regulatory Commission  
Public Document Room  
Washington, DC 20555

U.S. Nuclear Regulatory Commission  
Advisory Committee on Reactor Safeguards  
Washington, DC 20555  
Attn: R. F. Fraley

U.S. Nuclear Regulatory Commission (10)  
Washington, DC 20555  
Attn: R. A. Feit

DISTRIBUTION: (cont)

University of Connecticut  
Department of Chemistry  
Stoors, CT 06268  
Attn: J. A. Tanaka

Virginia Electric & Power  
P.O. Box 26666  
Richmond, VA 23261  
Attn: J. M. Davis

Waseda University  
Dept. of Electrical Engineering  
170-4, Shinjuku, Tokyo  
Japan  
Attn: K. Yahagi

Washington Public Power  
Supply System (3)  
P.O. Box 968  
Richland, WA 99352  
Attn: N. S. Porter  
W. L. Nees  
W. D. Bainard

Westinghouse Electric Corp. (6)  
P.O. Box 355  
Pittsburgh, PA 15230  
Attn: R. B. Miller  
I. Garber  
J. Sejvar  
W. D. Loftus  
J. Marshall  
C. V. Fields

Westinghouse Electric Corp.  
Westinghouse Circle  
Horseheads, NY 14845  
Attn: R. L. Korner

Westinghouse R&D Center (3)  
Beulah Road  
Pittsburgh, PA 15235  
Attn: F. Trunzon  
J. Bartko  
L. Edelman

Westinghouse Electric Corp.  
Electro-Mechanical Division  
Cheswick, PA 15024  
Attn: R. F. Edwards

Westinghouse Electric Corp.  
469 Sharpsville Ave.  
Sharon, PA 16146  
Attn: H. R. Sheppard

Westinghouse Electric Corp.  
East Pittsburgh, PA 15112  
Attn: C. R. Ruffing

Westinghouse Nuclear Europe (3)  
Rue de Stalle 73  
1180 Brussel, Belgium  
Attn: R. Minguet  
R. Doesema  
J. Cremader

William Powell Company  
P.O. Box 14006  
Cincinnati, OH 45214  
Attn: R. Koester

Wisconsin Electric Power Co.  
231 West Michigan Street  
Milwaukee, WI 53201  
Attn: L. Storz

Wyle Laboratories  
128 Maryland Street  
El Segundo, CA 90245  
Attn: P. M. Turkheimer

Wyle Laboratories  
7800 Governors Drive West  
Hunstville, AL 35807  
Attn: R. M. Scates

Yankee Atomic Electric (2)  
20 Turnpike Road  
Westborough, MA 01581  
Attn: G. T. Dowd, Jr.  
T. Mooney

DISTRIBUTION: (cont)

2533 J. K. S. Walter  
2533 R. C. Gauerke  
2533 A. A. Sena  
3312 R. B. Stump  
3313 A. L. Stanley  
5000 A. Narath  
5100 J. K. Galt  
5152 R. C. Hughes  
5200 E. H. Beckner  
5300 O. E. Jones  
5312 C. L. Christensen  
5400 A. W. Snyder  
5410 D. J. McCloskey  
5412 S. V. Asselin  
5420 J. V. Walker  
5430 R. M. Jefferson  
5431 W. A. Von Riesemann  
5432 R. E. Luna  
5432 D. L. Berry  
5432 L. L. Bonzon (15)  
5432 D. W. Dugan  
5432 L. J. Klamerus  
5432 F. R. Krause  
5432 L. D. Lambert  
5432 W. B. Leisher  
5432 J. A. Lewin  
5432 F. V. Thome  
5433 R. B. Pope  
5450 J. A. Reuscher  
5451 T. R. Schmidt  
5453 W. J. Whitfield  
5700 J. H. Scott  
5800 R. S. Claassen  
5810 R. G. Kepler  
5811 L. A. Harrah  
5811 R. L. Clough  
5812 C. J. Northrup  
5813 J. G. Curro  
5813 K. T. Gillen (2)  
5813 L. H. Jones (2)  
5813 E. A. Salazar (2)  
5815 R. T. Johnson  
8266 E. A. Aas  
3141 T. L. Werner (5)  
3151 W. L. Garner (3)  
for DOE/TIC (Unlimited Release)  
DOE/TIC (25)  
(R. P. Campbell, 3172-3)