

# Fault Tree Analysis for Reliability Prediction of Gas Turbine Type Power Plants

## Keywords:

Fault Tree Analysis  
Prediction  
Reliability  
Gas Turbine

MASTER

EPRI

EPRI AF-811  
Volume 2  
Appendices  
TPS 77-707  
Final Report  
June 1978

Prepared by  
Science Applications, Inc.  
Palo Alto, California

REPRODUCTION OF THIS DOCUMENT IS UNLIMITED

ELECTRIC POWER RESEARCH INSTITUTE

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

---

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

# Fault Tree Analysis for Reliability Prediction of Gas Turbine Type Power Plants

AF-811, Volume 2  
Technical Planning Study 77-707

## Final Report, June 1978 Appendices

Prepared by

SCIENCE APPLICATIONS, INC.  
2680 Hanover Street  
Palo Alto, California 94304

Principal Investigators  
J. E. Kelly  
R. C. Erdmann  
K. Gilbert

Prepared for

Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, California 94304

EPRI Project Manager  
Jerome Weiss  
Fossil Fuel and Advanced Systems Division

LEGAL NOTICE

This report was prepared by Science Applications, Inc. (SAI) as an account of work sponsored by the Electric Power Research Institute, Inc. (EPRI). Neither EPRI, members of EPRI, Science Applications, Inc., nor any person acting on behalf of either: (a) makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or (b) assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this report.

## Appendix A

### GLOSSARY

Fault Tree - A logic diagram, drawn from an effect to cause (usually backward in time), which ties together the sequences that can lead to an undesired event from basic component failures.

Top Event - The (usually) undesired event that sits on top of the fault tree.

Cut Set - A set of components whose simultaneous failure will lead to the top event. The term, as used here, refers to the irreducible minimum number of components within each cut set.

Reliability - The probability that the system operates as desired for the amount of time specified.

## Appendix B

### FAULT TREE MODEL AND METHODOLOGY DESCRIPTION

Fault tree analysis is a procedure used to examine systems to determine component failure modes and other events (e.g., operator errors) which can, individually or in combination, cause a system failure resulting in downtime.


A system fault tree is a logic diagram which depicts the component failure modes and other fault events capable of producing, through AND and OR combinatorial logic, system failure. It is a binary model of the fault modes of a system and, as such, can be readily converted to a probabilistic model of the system. Individual component fault probabilities can be assigned to the model and combined to obtain system failure probabilities.

The symbolism used in the fault tree analysis in this study are shown and defined in Table B-1. Figure B-1 depicts the gas turbine at the Naval Station plant studied. All the subsequent figures show the tree top and its 35 branches that were constructed in this study.


Table B-1

FAULT TREE SYMBOLOLOGY


EVENT REPRESENTATIONS




The rectangle identifies an event that results from the combination of fault events through the input logic gate.




The triangles are used as transfer symbols. A line from the apex of the triangle indicates a transfer in and a line from the side denotes a transfer out.




or



The circle describes a basic fault event that requires no further development. Frequency and mode of failure of items so identified are derived from empirical data.




The diamond describes a fault event that is considered basic in a given fault tree. The possible causes of the event are not developed because the event is of insufficient consequence or the necessary information is unavailable.




The house is used as a switch to include or eliminate parts of the fault tree as those parts may or may not apply to certain situations.

Table B-1  
FAULT TREE SYMBOLOLOGY (Continued)


LOGIC OPERATIONS



AND gate describes the logical operation whereby the coexistence of all input events is required to produce the output event.




OR gate defines the situation whereby the output event will exist if one or more of the input events exists.



A small circle above the circle, diamond or rectangle indicates the negative of what is contained in that symbol.

Blank Page




FT4C-3F CROSS-SECTIONAL VIEW

L-58234

Figure B-1

B-5

Blank Page



Figure

-TOP-  
STEAM NOT AVAILABLE  
AT PLANT DISCHARGE

Blank Page




Figure B-3

J1 GAS TURBINE  
FAILS TO START

Blank Page




FIGURE B-4

T8 STARTING FUEL  
NOT AVAILABLE

Blank Page




FIGURE B-5

J2 GAS TURBINE  
DISCONTINUES RUNNING

Blank Page




FIGURE B-7

FT1 BEARING LUBE  
SYSTEM FAILS OR IS  
INDICATED AS FAILED

Blank Page




FIGURE B-8

FT2 FAILURE OCCURS  
IN SCAVENGER  
SUBSYSTEM

Blank Page




FIGURE B-9  
FAILURE OCCURS  
IN PRESSURE

Blank Page




FIGURE B-10

J6 PROPER FUEL  
MIXTURE NOT AVAILABLE

Blank Page




FIGURE B-11

T6 FUEL NOT AVAILABLE  
TO ENGINE

Blank Page




FIGURE B-12

T10 FAILURE OCCURS  
IN FIRE PROTECTION  
VALVE

Blank Page




FIGURE B-13

T11 FAILURE OCCURS  
IN V7 ISOLATION  
VALVES

Blank Page




FIGURE B-14

T19 FAILURE OCCURS  
IN OTHER TANK  
OUTLETS OR TANK

Blank Page




FIGURE B-15

T14 FAILURE OCCURS  
IN TANK FILL  
SUBSYSTEM

Blank Page




FIGURE B-16

FAILURE OCCURS IN  
OTHER TANK OUTLETS  
OR TANK T20

Blank Page




FIGURE B-17

T22 SINGLE  
EVENT BETWEEN  
V7 VALVES AND  
STORAGE TANKS

Blank Page




FIGURE B-18

S1 IMPROPER  
STEAM INJECTED  
IN ENGINE

Blank Page




FIGURE B-19

GAS GENERATOR  
TRIPS E3

Blank Page




FIGURE P-20

J4 LUBE OIL NOT  
AVAILABLE FROM  
MAIN OIL PUMP

Blank Page




FIGURE B-21

TR3 INADVERTENT  
LUBE OIL TEMPERATURE  
HIGH TRIP

Blank Page




FIGURE B-22

J5 BEARING NUMBER 5  
NOT PROPERLY  
LUBRICATED

Blank Page




FIGURE B-23

J3 FAILURE  
OCCURS IN BEARINGS  
1, 2, 2.5, OR 3

Blank Page




FIGURE B-24

## PT1 POWER TURBINE TRIP

Blank Page




FIGURE B-25

W5 WATER NOT  
AVAILABLE FROM  
BOILER FEED PUMPS

Blank Page




FIGURE B-26

W6 WATER  
NOT AVAILABLE  
FROM DEAERATOR

Blank Page




FIGURE B-27

W7 FAILURE  
OCCURS IN  
CHECK VALVE

Blank Page




FIGURE B-28

W8 WATER  
NOT AVAILABLE  
FROM MAKE-UP  
PUMPS

Blank Page




FIGURE B-29

WATER NOT AVAILABLE  
FROM MAKE-UP TANK

Blank Page




FIGURE B-30

W11 FAILURE  
OCCURS IN SOFTENER  
VALVE SYSTEM

Blank Page




FIGURE B-31

WATER OR BRINE  
NOT AVAILABLE TO  
SOFTENERS

Blank Page




FIGURE B-32

T15A FAILURE OCCURS  
IN V8 VALVE

Blank Page




FIGURE B-33

W19 FAILURE OCCURS  
IN CHECK VALVE

Blank Page




FIGURE B-

## IMPROPER PRESSURE CAUSES SHUTDOWN E

Blank Page




FIGURE B-35

T3 FAILURE  
OCCURS IN PACK  
BOILER OR FUEL

Blank Page




FIGURE B-36

T18 FUEL NOT  
AVAILABLE TO PUMPS

Blank Page




FIGURE B-37  
AC PUMPS FAIL