

27  
8-22-78

# MASTER

BDX-613-1805 (Rev.)

## PLATING THICKNESS STANDARDS


### Milestone Report

✓  
R. J. Russell, Project Leader

Project Team:  
G. J. Hale  
G. A. McWhirt  
D. M. Sherman

Published August 1978

Prepared for the United States Department of Energy  
Under Contract Number EY-76-C-04-0613.



Kansas City  
Division

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Printed in the United States of America

Available From the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161.

Price:      Microfiche    \$3.00  
                Paper Copy    \$4.00 ~~50~~

BDX-613-1805 (Rev.)  
Distribution Category UC-38

## PLATING THICKNESS STANDARDS

Published August 1978

Project Leader:  
R. J. Russell

Project Team:  
G. J. Hale  
G. A. McWhirt  
D. M. Sherman

## Milestone Report

### NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Communications Services



Kansas City  
Division

*fly*

## PLATING THICKNESS STANDARDS

BDX-613-1805 (Rev.), UNCLASSIFIED Milestone Report, Published August 1978

Prepared by R. J. Russell

Standards which are unavailable commercially or from the National Bureau of Standards have been developed to support the nondestructive measurement of plating thickness. Reference and working standards of copper on Kapton and aluminum on Kapton have been put into service. Their fabrication, measurement, certification, and calibration recall are discussed.

WPC-myw

MASTER

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

The Bendix Corporation  
Kansas City Division  
P. O. Box 1159  
Kansas City, Missouri 64141

A prime contractor with the United States Department of Energy under Contract Number EY-76-C-04-0613

## CONTENTS

Section	Page
SUMMARY . . . . .	6
DISCUSSION . . . . .	7
SCOPE AND PURPOSE . . . . .	7
ACTIVITY . . . . .	7
<u>Background</u> . . . . .	7
<u>Fabrication of Standards</u> . . . . .	7
<u>Thickness of Reference Standards</u> . . . . .	10
<u>Thickness of Working Standards</u> . . . . .	12
<u>Deposit Characteristics</u> . . . . .	14
ACCOMPLISHMENTS . . . . .	20
FUTURE WORK . . . . .	23
REFERENCES . . . . .	24
DISTRIBUTION . . . . .	25

## ILLUSTRATIONS

Figure		Page
1	Working Plating-Thickness Standards and Reference Standards of Aluminum on Kapton (P-97894) . . . . .	8
2	Placement of Kapton Laminated Buttons and Optical Flats in the Vapor-Deposition Fixture. . . . .	9
3	Optical Flats Before Deposition and After Deposition (P-93854) . . . . .	13
4	Deformation-Correction Graph for the Link Gage Block Interferometer. . . . .	14
5	Aluminum-On-Kapton Data Reduction. . . . .	16
6	Copper-On-Kapton Data Reduction. . . . .	17
7	Beta-Backscatter Least-Squares Calibration Curve for Physical-Vapor-Deposited Aluminum on Kapton . . . . .	18
8	Four-Point Resistance Least-Squares Calibration Curve for Physical-Vapor-Deposited Copper on Kapton . . . . .	19
9	Probe-Location Coordinates on Kapton Strips Used for Plating-Thickness-Uniformity Determination: . . . . .	20

## TABLES

Number		Page
1	Aluminum-Thickness Reference Standards . . . . .	11
2	Copper-Thickness Reference Standards . . . . .	12
3	Data for Least-Squares Regression. . . . .	15
4	Thickness Uniformity of Aluminum-On-Kapton Deposits .	21
5	Thickness Uniformity of Copper-On-Kapton Deposits .	22
6	Density of Physical-Vapor-Deposited Copper and Aluminum .	23

## SUMMARY

Because aluminum-on-Kapton and copper-on-Kapton plating-thickness standards are not available from the National Bureau of Standards or any known commercial source, standards have been developed and fabricated at Bendix Kansas City. Interferometry and weight-gain methods were used to determine the metal thickness on each of the reference standards. The reference standards were used to certify the thickness of several sets of working standards by comparison using beta-backscatter methods for aluminum on Kapton and four-point resistance measurements for copper on Kapton.

All working standards have been placed on a calibration schedule for periodic inspection for damage and comparison with a set of reference standards. By this technique, each working standard either will be recertified and returned to service or replaced with a certified standard.

The precision of the reference standards was evaluated by a series of statistical tests that were performed on each set of calibration data. These tests provided an effective means for determining the quality of the data and estimating the measurement uncertainty. The measurement uncertainty of the thickness values assigned to the working standards should not exceed  $\pm 0.26 \mu\text{m}$  for aluminum on Kapton and  $\pm 0.43 \mu\text{m}$  for copper on Kapton.

## DISCUSSION

### SCOPE AND PURPOSE

This project was initiated to develop plating-thickness measurement standards for use with nondestructive thickness-measuring equipment. These standards, unavailable from the National Bureau of Standards or any commercial sources, are required to support the inspection of products at Bendix Kansas City and the Los Alamos Scientific Laboratories (LASL). When available, working standards will be purchased from a commercial source.

The development and fabrication of thickness standards and the resulting plating-thickness standards will benefit both Bendix Kansas City and LASL by making possible the nondestructive measurement of plating thickness on products with a high degree of precision.

This report describes the methods used to verify the thickness of the plating that was deposited on the reference standards together with those used for the fabrication, calibration, and calibration-recall scheduling of the working standards.

### ACTIVITY

#### Background

A variety of plating-thickness standards have been fabricated at Bendix Kansas City.<sup>1</sup> As a result of the experience gained, Bendix was requested by LASL to fabricate plating-thickness standards of aluminum on Kapton and copper on Kapton. Two sets of working standards of each material were fabricated to support LASL's immediate needs and, in addition, two sets of working standards were furnished to the Bendix Kansas City Nondestructive Testing Laboratory. All working standards will be scheduled for calibration by Bendix Metrology Laboratory personnel (Figure 1).

#### Fabrication of Standards

The fabrication of plating-thickness standards begins with the preparation of the substrate. Each different type of standard fabricated requires its own special substrate preparation. For example, the optical flats which provide a stable reference surface for the deposit must be measured for thickness and mass. They are cleaned with solvent and placed in a holding fixture similar to the one in Figure 2.




Figure 1. Working Plating-Thickness Standards (Left) and Reference Standards (Eight) of Aluminum on Kapton




Figure 2. Placement of Kapton Laminated Buttons and Optical Flats in the Vapor-Deposition Fixture

The substrates for working standards were fabricated from two flat pieces of Kapton laminated together and cut to size (55 by 280 mm). These substrates were used for the fabrication of the aluminum working standards and for the first five runs of copper working standards. However, because of the high deposition temperature of copper, the laminated material had a tendency to delaminate. The subsequent six runs therefore were changed to a single layer of 0.127-mm Kapton. The described strips of Kapton were mounted in curved fixtures which allowed the metal to be uniformly deposited. Two fixtures were used for each run.

The substrates for the reference standards were fabricated by punching 19-mm discs from a Kapton sheet which was identical in composition to those used for the working standards. After these

discs had been laminated to aluminum housings, the assemblies, called *buttons*, were cleaned and mounted in the holding fixtures along with an equal number of optical flats (Figure 2).

The fixtures were loaded into a motor-powered planetary system inside the vacuum chamber, and they were rotated as the metal was being deposited. The deposition rate was controlled through the use of a quartz microbalance inside the chamber. When the metal had attained the desired nominal thickness, the system was shut down and allowed to cool before the optical flats, buttons, and the material for the working standards were removed.

The thickness of the metal on the optical flats was measured with a Link Gage Block Interferometer, and the determined average thickness value was assigned to the three buttons that had been fabricated during the deposition. Comparative measurements indicated that the difference between the thickness of the metal deposited on the optical flats and the thickness of the metal deposited on the buttons was insignificant.<sup>2</sup> The buttons from this deposition were placed in a set which was designated *reference standards*. Tables 1 and 2 identify the reference standards that were fabricated.

The working standards necessary to support production measurements were fabricated by bonding small die-punched sections of the metal-coated Kapton sheets to aluminum housings. Beta-backscatter techniques were used to compare the thickness of the aluminum working standards with that of the reference standards. A four-point resistance measurement was used to compare the thickness of the copper working standards.

A schedule for periodic calibration-recall assures the continued integrity of the working standards. If the standards become worn or damaged, they will be replaced with new sections. When the available supply of working-standard material has been exhausted, the described fabrication process must be duplicated to obtain additional working standards.

#### Thickness of Reference Standards

The thickness of the metal deposited on the optical flats was determined with a Link Gage Block Interferometer by measuring the thickness before and after deposition (Figure 3).<sup>1</sup> The interferometer has a resolution of 3 nm and an estimated measurement uncertainty of 50 nm.

Because the interferometer has the disadvantage of being a contact-type instrument, corrections for stylus deformation are required. Figure 4 shows the correction curves that were developed. These curves were generated by varying the stylus force of

Table 1. Aluminum-  
Thickness  
Reference  
Standards

Reference- Standard Designation	Certified Thickness ( $\mu$ m)
AL-FL-1	10.67
AL-FL-2	10.67
AL-FL-3	10.67
AL-FL-4	10.11
AL-FL-5	10.11
AL-FL-6	10.11
AL-FL-7	9.53
AL-FL-8	9.53
AL-FL-9	9.53
AL-FL-10	11.38
AL-FL-11	11.38
AL-FL-12	11.38
AL-FL-16	11.76
AL-FL-17	11.76
AL-FL-18	11.76
AL-FL-19	9.12
AL-FL-20	9.12
AL-FL-21	9.12
AL-FL-22	10.57
AL-FL-23	10.57
AL-FL-24	10.57

the instrument and measuring the resulting film thickness. The changes in the film thickness versus the stylus force were plotted, and the curves were forced through zero deformation at zero force to produce the correction graph.

Table 2. Copper-Thickness Reference Standards

Reference- Standard Designation	Certified Thickness ( $\mu$ m)
CU-FL-4	7.21
CU-FL-5	7.21
CU-FL-10	11.81
CU-FL-11	11.81
CU-FL-12	11.81
CU-FL-16	10.41
CU-FL-18	10.41
CU-FL-25	9.78
CU-FL-26	9.78
CU-FL-27	9.78
CU-FL-28	8.76
CU-FL-29	8.76
CU-FL-30	8.76
CU-FL-31	11.05
CU-FL-32	11.05
CU-FL-33	11.05

The thickness values that were determined from the plated optical flats were corrected through the use of the appropriate curve. The resulting value is the thickness measured to the peak of the deposited material at zero load. The thickness values determined from the three optical flats were averaged and the averaged value was assigned to each of the buttons, as shown in Tables 1 and 2. The buttons then were placed in a set containing the reference standards that are now in service.

#### Thickness of Working Standards

The previously described reference standards were used to calibrate three sets of working standards. The thickness comparisons were performed through the use of beta-backscatter measuring equipment for aluminum on Kapton, and a four-point resistance measurement for copper on Kapton (Table 3).<sup>3</sup>




Figure 3. Optical Flats Before Deposition (Above) and After Deposition (Below)

The reference standards were measured, the instrument output was plotted with respect to thickness, and a least-squares linear regression was used to determine the equation of the line. Several statistical tests also were performed on the data simultaneously with the execution of the regression; these results are shown in Figures 5 and 6.

The thickness of the working standards is calculated by substituting the instrument output into the equation developed from the reference standards. An estimate of the measurement precision can be obtained from the calculated statistical tolerance limit shown in Figures 5 and 6. Graphic representations of the calibration curves are shown in Figures 7 and 8.

The working standards have been assigned thickness values and scheduled for routine, periodic calibration recall. At the end of the specified time interval, the standards will be inspected and recalibrated. If acceptable, they will be put back into service. An unacceptable standard will be replaced before the set is returned to the user.




Figure 4. Deformation-Correction Graph for the Link Gage Block Interferometer

#### Deposit Characteristics

The following described tests were performed to assure satisfactory characteristics of the deposited metal.

##### Thickness Uniformity

Because the small area of metal that is deposited on each reference standard does not permit an investigation of the plating-thickness uniformity, flat strips of Kapton (Figure 9) were fabricated for this purpose. Prior to the deposition of the metal, the strips were placed in a curved fixture to provide a uniform distribution of the deposit. Upon completion of the deposition, the strips were removed from the fixture and allowed to return to their original flat configuration before the plating-uniformity measurements were made.

Table 3. Data for Least-Squares Regression

Aluminum/Kapton		Copper/Kapton	
(Counts/s)	Thickness ( $\mu\text{m}$ )	Conductance (S)	Thickness ( $\mu\text{m}$ )
2798.3	10.57	1536	7.214
2671.7	9.12	1520	7.214
2713.6	9.53	1984	8.763
2805.7	10.57	1972	8.763
2863.4	11.38	1976	8.763
2675.0	9.12	2165	9.779
2806.9	10.57	2198	9.779
2673.7	9.12	2203	9.779
2895.1	11.76	2356	10.414
2893.2	11.76	2331	10.414
2765.7	10.11	2564	11.049
2715.9	9.53	2532	11.049
2865.7	11.38	2577	11.049
2762.7	10.11	2681	11.811
2713.4	9.53	2762	11.811
2759.5	10.11	2732	11.811
2864.1	11.38		
2898.9	11.76		

The thickness of the metal was measured across the surface of the strips at 25.0-mm intervals, the locations of which are shown in Figure 9. Variations in the measured thickness are shown in Tables 4 and 5.

The deposits were found to be thickest at the center of the strips, and progressively thinner as the edges were approached. The largest variation was observed in the measurements made adjacent to the upper and lower edges. By eliminating these measurements from the data accumulated from the aluminum deposits, a thickness gradient of approximately  $0.008 \mu\text{m}/\text{mm}$  was obtained. The standard deviation of the thickness of the aluminum deposited in this area was found to be  $0.13 \mu\text{m}$ .

RUN. LINEAR

ENTER X Y PAIRS

2798.3 10.57

2671.7 9.12

2713.6 9.53

2805.7 10.57

2863.4 11.38

2675.0 9.12

2806.9 10.57

2673.7 9.12

2895.1 11.76

2893.2 11.76

2765.7 10.11

2715.9 9.53

2865.7 11.38

2762.7 10.11

2713.4 9.53

2759.5 10.11

2864.1 11.38

2898.9 11.76

MEAN SQUARE ERROR= 0.24861500E-02

STANDARD ERROR= 0.49861308E-01

COEFFICIENT OF VARIATION= 0.0048

CORRELATION= 0.998752

FOR A 90 PERCENT CONFIDENCE INTERVAL

SLOPE= 0.01199274 +/- 0.00026171

NORMALIZED INTERCEPT TOLERANCE= 0.0700

INTERCEPT= -22.996437 +/- 0.729052

RUN TEST RESULTS:N=18 NR=10

XB= 2785.6948 YB= 10.4117 T= 1.7459 F= 1.7188

90% OF THE DATA POINTS FALL WITHIN THE LISTED TOLERANCE 90% OF THE TIME

X= 2694.4199 Y= 9.3170 +/- 0.1140

X= 2717.1399 Y= 9.5895 +/- 0.1124

X= 2739.8599 Y= 9.8620 +/- 0.1112

X= 2762.5798 Y= 10.1345 +/- 0.1104

X= 2785.3000 Y= 10.4069 +/- 0.1101

X= 2808.0200 Y= 10.6794 +/- 0.1104

X= 2830.7400 Y= 10.9519 +/- 0.1111

X= 2853.4600 Y= 11.2244 +/- 0.1124

X= 2876.1799 Y= 11.4968 +/- 0.1140

X= 2898.8999 Y= 11.7693 +/- 0.1159

\$

Figure 5. Aluminum-On-Kapton Data Reduction

In the case of the copper deposit, a thickness gradient of approximately  $0.005 \mu\text{m}/\text{mm}$  was obtained, and the standard deviation of the thickness of the copper deposited in this area was found to be  $0.08 \mu\text{m}$ .

RUN LINEAR

ENTER X Y PAIRS

1536.0 7.214

1520.0 7.214

1984.0 8.763

1972.0 8.763

1976.0 8.763

2165.0 9.779

2198.0 9.779

2203.0 9.779

2356.0 10.414

2331.0 10.414

2564.0 11.049

2532.0 11.049

2577.0 11.049

2681.0 11.811

2762.0 11.811

2732.0 11.811

MEAN SQUARE ERROR= 0.14659235E-01

STANDARD ERROR= 0.12107533E .00

COEFFICIENT OF VARIATION= 0.0121

CORRELATION= 0.996952

FOR A 90 PERCENT CONFIDENCE INTERVAL

SLOPE= 0.00385079 +/- 0.00014184

NORMALIZED INTERCEPT TOLERANCE= 0.0321

INTERCEPT= 1.280682 +/- 0.319921

RUN TEST RESULTS:N=16 NR= 9

XB= 2255.5625 YB= 9.9664 T= 1.7613 F= 1.7980

90% OF THE DATA POINTS FALL WITHIN THE LISTED TOLERANCE 90% OF THE TIME

X= 1644.2000 Y= 7.6121 +/- 0.2930

X= 1768.4000 Y= 8.0904 +/- 0.2866

X= 1892.6000 Y= 8.5687 +/- 0.2811

X= 2016.8000 Y= 9.0470 +/- 0.2769

X= 2141.0000 Y= 9.5252 +/- 0.2744

X= 2265.2000 Y= 10.0035 +/- 0.2736

X= 2389.3999 Y= 10.4818 +/- 0.2746

X= 2513.6001 Y= 10.9600 +/- 0.2775

X= 2637.8000 Y= 11.4383 +/- 0.2819

X= 2762.0000 Y= 11.9166 +/- 0.2876

\$

Figure 6. Copper-On-Kapton Data Reduction

From the test results, the uniformity of the metal deposit should be adequate to fabricate working standards capable of supporting present production activity.




Figure 7. Beta-Backscatter Least-Squares Calibration Curve for Physical-Vapor-Deposited Aluminum on Kapton

#### Density

The density of each material deposited was determined by measuring the mass and volume of the plating. The measured volume required corrections for nonuniformity of diameter, taper at the edge of the plating (caused by fixture-shadowing), and surface roughness.

Table 6 shows an average value of  $9.07 \text{ g/cm}^3$  for the density of physical-vapor-deposited copper; the estimated uncertainty in the determination was  $\pm 3$  percent. The density value shown for aluminum ( $2.6 \text{ g/cm}^3$ ) has not been corrected for surface roughness.

#### Composition of Copper Deposit

The appearance of the deposited copper was observed to vary from bright and metallic to a reddish matte. The reddish color is caused by surface roughness which is produced by the high deposition temperature.




Figure 8. Four-Point Resistance Least-Squares Calibration Curve for Physical-Vapor-Deposited Copper on Kapton

An Auger-Electron-Spectrometer examination of the rough surface indicated the presence of oxygen, carbon, and chlorine (all common surface elements). The surface then was sputtered with argon to remove approximately 20 nm of material, and the analysis was repeated. The second analysis revealed the presence of only copper, thus indicating a very pure deposit.




Figure 9. Probe-Location  
Coordinates on Kapton  
Strips Used for Plating-  
Thickness-Uniformity  
Determination

#### ACCOMPLISHMENTS

Reference thickness standards of copper on Kapton and aluminum on Kapton have been fabricated and put into service. These reference standards were used to calibrate working standards which, in

Table 4. Thickness Uniformity of Aluminum-On-Kapton Deposits

Part	Vertical Coordinate*	Thickness for Horizontal Coordinate Indicated*		
		1 ( $\mu$ m)	2 ( $\mu$ m)	3 ( $\mu$ m)
1**	A	9.42	9.60	9.47
	B	9.65	9.73	9.68
	C	9.86	9.93	9.93
	D	9.98	9.98	9.98
	E	10.01	10.08	10.01
	F	9.98	10.08	9.98
	G	9.93	9.91	9.75
	H	9.53	9.60	9.50
2***	A	9.35	8.99	8.74
	B	9.73	9.73	9.73
	C	9.86	9.91	9.83
	D	9.91	9.98	9.91
	E	9.88	9.93	9.88
	F	9.93	9.93	9.88
	G	9.70	9.75	9.73
	H	9.50	9.58	9.60

\*Refer to Figure 9 for measurement locations.

\*\* $\bar{x} = 9.82$ ;  $\sigma = 0.21$ . Values for vertical coordinates A and H were eliminated from the calculations since they were outside the useful area of the part:  
 $\bar{x} = 9.91$ ;  $\sigma = 0.13$ .

\*\*\* $\bar{x} = 9.71$ ;  $\sigma = 0.30$ . Values for vertical coordinates A and H were eliminated from the calculations since they were outside the useful area of the part:  
 $\bar{x} = 9.84$ ;  $\sigma = 0.09$ .

turn, are used to support product inspection. Two sets of working standards of each material have been sent to LASL, and they periodically will be returned to Bendix Kansas City for calibration in accordance with a recall schedule specified by Bendix calibration personnel.

Table 5. Thickness Uniformity of Copper-On-Kapton Deposits

Part	Vertical Coordinate*	Thickness for Horizontal Coordinate Indicated*		
		1 ( $\mu$ m)	2 ( $\mu$ m)	3 ( $\mu$ m)
2**	A	9.80	9.86	9.92
	B	9.82	9.92	9.90
	C	9.92	10.00	9.88
	D	9.92	10.05	10.00
	E	9.96	10.10	10.02
	F	9.92	10.02	10.02
	G	9.84	10.00	9.96
	H	9.92	9.96	9.96
	I	9.82	9.90	9.88
	J	9.77	9.86	9.80
10***	A	8.81	8.85	8.87
	B	8.88	8.96	8.99
	C	8.93	8.81	8.96
	D	8.90	9.05	8.93
	E	8.91	8.94	8.97
	F	8.90	8.91	8.96
	G	8.85	8.87	8.93
	H	8.84	8.85	8.81
	I	8.90	8.87	8.84
	J	8.88	8.91	8.87

\*Refer to Figure 9 for measurement locations.

\*\* $\bar{x} = 9.92$ ;  $\sigma = 0.08$ .

\*\*\* $\bar{x} = 8.90$ ;  $\sigma = 0.06$ .

Table 6. Density of Physical-Vapor-Deposited Copper and Aluminum

Metal	Optical Flat	Density (g/cm <sup>3</sup> )
Copper*	4	9.18
	19	9.01
	25	9.02
Aluminum**	46	2.63
	17	2.57

\*Estimated uncertainty does not exceed  $\pm 3$  percent.

\*\*Values obtained from D. M. Sherman, 2/16/77; corrections for surface roughness have not been applied; upon correction, a value of 2.71 g/cm<sup>3</sup> can be anticipated.

#### FUTURE WORK

The Bendix Metrology Laboratory will maintain the reference thickness standards of aluminum on Kapton and copper on Kapton. These standards will be used to calibrate working standards. A calibration history of each set of working standards will be kept on file and updated upon each calibration recall.

Refinement of both the calibration and data-acquisition processes has been planned. A comparison between flat physical-vapor-deposited aluminum standards and curved 0.15-percent-copper-doped aluminum is under way. This should determine whether additional physical-vapor-deposited aluminum standards should be fabricated.

## REFERENCES

<sup>1</sup>R. J. Russell, *Development of Plating Thickness Standards* (Milestone Report). UNCLASSIFIED. Bendix Kansas City: BDX-613-1709, February 1978 (Available from NTIS)

<sup>2</sup>R. J. Russell, *Development of Plating Thickness Standards for the Physical Vapor Deposition of Aluminum on Kapton* (Milestone Report). UNCLASSIFIED. Bendix Kansas City: BDX-613-1634, October 1977 (Available from NTIS)

<sup>3</sup>Richard Sard and others, editors, *Properties of Electrodeposits; Their Measurement and Significance*. Princeton, New Jersey: The Electrochemical Society, 1975 (Library of Congress No. 74-84702).

## DISTRIBUTION

	Copy
R. Bulcock, ERDA-KCAO, 1D49	1
D. F. Wright, LLL	2
A. W. Reger, SLA	3
R. L. Calkins, D/10, 2A30	4
J. F. Hadley, D/400, BN30	5
C. L. Walters, D/413, 2B30	6
W. B. Abel, D/424, BD30	7
J. S. Carson, D/424, BD30	8
G. A. McWhirt, D/421, BN30	9
R. J. Schofield, D/442, FE49	10
H. T. Barnes, D/554, BD50	11
J. D. Corey, D/554, BD50	12-13
L. Stratton, D/554, 2C44	14-16
R. P. Frohnmberg, D/800, 2A39	17
J. W. Chesney, D/812, 2D31	18
J. C. Culver, D/812, 2D31	19
W. J. Nicholson, D/812, 2D31	20
J. D. Sheeley, D/812, 2D31	21
G. J. Hale, D/814, 2C43	22
D. M. Sherman, D/814, 2C43	23
R. E. Kessler, D/865, 2C40	24

-----  
BDX-613-1805 (Rev.)

PLATING THICKNESS STANDARDS, R. J. Russell,  
UNCLAS Milestone, August 1978

Standards which are unavailable commercially  
or from the National Bureau of Standards have  
been developed to support the nondestructive  
measurement of plating thickness. Reference  
and working standards of copper on Kapton and  
aluminum on Kapton have been put into service.  
Their fabrication, measurement, certification,  
and calibration recall are discussed.

-----  
SPECIAL PROJECTS: Nondestructive Testing

PLATING THICKNESS STANDARDS, R. J. Russell,  
UNCLAS Milestone, BDX-613-1805 (Rev.),  
August 1978

Standards which are unavailable commercially  
or from the National Bureau of Standards have  
been developed to support the nondestructive  
measurement of plating thickness. Reference  
and working standards of copper on Kapton and  
aluminum on Kapton have been put into service.  
Their fabrication, measurement, certification,  
and calibration recall are discussed.

-----  
PLATING THICKNESS STANDARDS, R. J. Russell,  
UNCLAS Milestone, BDX-613-1805 (Rev.),  
August 1978

Standards which are unavailable commercially  
or from the National Bureau of Standards have  
been developed to support the nondestructive  
measurement of plating thickness. Reference  
and working standards of copper on Kapton and  
aluminum on Kapton have been put into service.  
Their fabrication, measurement, certification,  
and calibration recall are discussed.