

27
12/24/80
1. J
24 copy to NTS

① R-827

MASTER

UCID- 18860


NOTICE
PORTIONS OF THIS REPORT ARE ILLEGIBLE.
It has been reproduced from the best available copy to permit the broadest possible availability.

AN EVALUATION OF GEOPRESSURED
BRINE INJECTABILITY:
Department of Energy Pleasant Bayou No. 2 Well
Brazoria County, Texas

L. B. Owen
C. K. Blair
J. E. Harrar
R. Netherton

UCID--18860
DE81 008842

October 28, 1980




Lawrence
Livermore
Laboratory

This is an informal report intended primarily for internal or limited external distribution. The opinions and conclusions stated are those of the author and may or may not be those of the Laboratory.

Work performed under the auspices of the U.S. Department of Energy by the Lawrence Livermore Laboratory under Contract W-7405-Eng-48.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

An Evaluation of Geopressured Brine Injectability:
Department of Energy, Pleasant Bayou No. 2 Well, Brazoria County, Texas

L. B. Owen^{*}, C. K. Blair^{*}, J. E. Harrar[†] and R. Netherton[†]

^{*}Terra Tek, Inc., 420 Wakara Way, Salt Lake City, Utah 84108

[†]University of California, Lawrence Livermore National Laboratory,
Livermore, California 94550

ABSTRACT

A field evaluation of geopressured brine injectability was completed during September 22-25, 1980 at the DOE, Brazoria test site in Texas. Membrane filters, with pore sizes of 0.4- μm and 10.0- μm , were used as the basis for obtaining suspended solids data and for developing performance-life estimates of typical spent brine injection wells. Field measurements were made at 130°C and line pressures up to 3800 psig. Scale inhibited (phosphonate-polyacrylate threshold-type, carbonate scale inhibitor), prefiltered-scale-inhibited, and untreated brine were evaluated. Test results indicated that raw brine was highly injectable, while scale-inhibited brine had extremely low quality. The poor injectability of scale-inhibited brine resulted from partial precipitation of the scale inhibitor.

INTRODUCTION

New concepts for the high temperature/high pressure recovery of methane from geopressured brine have been developed by Lawrence Livermore National Laboratory (LLNL).^{1 2} The primary objective of these methane recovery processes is to preserve sufficient hydraulic energy to drive the subsequent subsurface disposal of spent brine effluents at substantial reductions in operating and maintenance costs associated with use of injection pumps. However, a key

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

element in determining the feasibility of the overall methane recovery process is the need to quantitatively establish injectability characteristics of geopressured brine at elevated temperature and pressure.

Typical geopressured wells are expected to produce in excess of 20,000 barrels of brine per day. Subsurface disposal of large quantities of "spent" brine effluent, to be cost-effective, will require control of brine quality (i.e., low suspended solids concentration), minimization of scaling and corrosion, and knowledge of the injection potential of the disposal sand. Brine disposal in conjunction with operation of the U. S. Strategic Petroleum Reserve (SPR) is a close operational analog to a geopressured system. The SPR program required long term disposal of nearly saturated NaCl brines (20-35°C) at rates of 30,000 barrels per day per well. However, SPR disposal wells were rapidly impaired and design injection rates could not be maintained. It has recently been demonstrated that SPR injection wells became impaired as a result of poor brine quality, including corrosion-generated particulates, and insufficient cleaning of the original gravel packed completions.³⁻⁴ Problems which lead to the impairment of injection wells can be recognized by implementing a properly designed brine injectability monitoring program. At the geopressured sites where carbonate scale inhibitors may be used, a real need exists to monitor brine quality to insure that inhibitor-derived pseudoscales and particulates do not cause injection well impairment.

A field evaluation was conducted at the Pleasant Bayou No. 2 well, located at the DOE-Brazoria geopressured test site south of Houston, Texas (September 22-25, 1980). The objectives of the field work were to establish the nominal injectability of spent geopressured brine as a function of temperature and pressure and estimate the useful life of wells into which spent brine is injected. Injectability data were obtained by means of in-line membrane filtration experiments.

INJECTABILITY TESTING METHODOLOGY

The most reliable method of establishing water quality in conjunction with full-scale injection tests is based on the use of membrane filters (and core samples) as analogs of the injection formation.⁵⁻¹³ The permeability of a representative membrane filter with the appropriate pore size distribution to injected water is continuously monitored. Observed permeability variations can then be interpreted in terms of the performance characteristics of a typical injection well.¹⁴⁻¹⁶ Given the injection rate, wellbore radius, length of completion interval, brine viscosity, and disposal formation hydraulic parameters, the useful lifetime of the injection well can be estimated.

Membrane filtration data reveal the matrix permeability impairment potential of injected water resulting from scale formation or deposition of suspended solids. Loss of disposal capacity resulting from insufficient disposal formation volume, pre-existing skin change, or other reservoir insufficiencies, however, cannot be directly identified by filtration tests. Similarly, factors which may favorably impact disposal capacity such as the presence of high permeability thief zones or fractures within the disposal interval can not be accounted for by the membrane filtration methodology.

Selection of membrane filters with the appropriate pore size for the work reported here was based on an empirical method described by Champlin et al,¹⁷ which permits calculation of mean formation pore size if formation porosity and permeability are known. We estimated that a disposal formation with properties as shown in Table 1 would have a mean pore diameter of 16- μm . We selected Nuclepore, polycarbonate, 10- μm pore size membrane filters as conservative analogs of shallow, high permeability disposal zones. Nuclepore, polycarbonate membrane filters with 0.4- μm pore size, were also used to obtain baseline suspended solids data and as conservative analogs of deep geopressured disposal zones where formation permeability might be less than 100 md.

TABLE 1

ASSUMED DISPOSAL FORMATION AND INJECTION PARAMETERS:
DOE'S BRAZORIA GEOPRESSURED-GEOTHERMAL TEST SITE

| | |
|---|----------------------|
| Brine Temperature | 130°C |
| Brine Salinity ¹ | 13.5 wt % NaCl |
| Brine Density ² | 1.1 g/cc |
| Brine Viscosity ³ | 0.32 cp |
| Injection Rate | 22,000 BBL/Day |
| Radius of Injection Tubing ¹ | 0.0699 m |
| Length of Injection Interval ¹ | 53 m |
| Injection Formation Permeability | 1000 md |
| Injection Formation Porosity | 20% |
| Radius of Effect | 182.9 m |
| Invasion Radius. | 3.05 m |
| Filter Cake Density ⁴ | 2.70 g/cc |
| Exposed Area of Membrane Filters | 13.2 cm ² |

References:

1. R. Batten, Fenix and Scisson, Personal Communication
2. Ref. 20
3. Ref. 21
4. Density of calcium carbonate (calcite)


TEST APPARATUS DESIGN

A schematic of the injectability test apparatus is shown in Figure 1. The test frame, based on previously field proven designs,¹⁸⁻¹⁹ was connected, as a bypass system, to the main site flowline via a suitably designed high pressure manifold. Injectability tests were carried out at constant differential pressure across the filtration membrane. Coarse and fine control valves were used to initially set and maintain differential pressure. Cumulative flow and instantaneous flowrate were obtained by direct measurement using 2-litre graduated cylinders. Flashing of the brine following passage through the membrane filter was prevented by use of a water-cooled, Inconel-600 heat exchanger upstream of the final control valve. All system piping was constructed from Inconel-600 high pressure tubing for adequate corrosion control. Valves and fittings were made of 316 stainless steel. The system was designed for in-line testing of geopressured brine at pressures and temperatures to 2000 psi and 150°C, respectively. Inclusion of the by-pass manifold permitted testing geopressured brine at wellhead pressure to 4000 psig. Prior to each run, membrane filters were evacuated by means of an on-board vacuum system to prevent partial blockage of membrane filters by entrained air. The vacuum system was also used to bleed the system of residual brine following each run. A high pressure, cartridge filter assembly was used occasionally to prefilter brine, at high temperature and pressure, prior to its passage through a membrane filter to establish the potential benefits of prefiltering brine before subsurface disposal.

BRINE SAMPLING POINTS

Injectability tests were carried out at wellhead conditions, about 5 feet downstream of the scale inhibitor injection port, immediately upstream of the gas separator and in the injection line about 70 feet downstream of the gas

Figure 1. SIMPLIFIED SCHEMATIC OF THE MEMBRANE FILTRATION
INJECTABILITY TEST APPARATUS



separator. The three sampling points are shown on the generalized Brazoria system schematic (Figure 2).

The various brine sources used in the injectability test were designated as follows:

LN- Series: Low pressure injection line (380 psig, 130°C). Sampling port on top of injection line.

MN- Series: Moderate pressure production line immediately upstream of the gas separator (800 psig, 130°C). Sampling port on side of vertical riser.

HN- Series: High pressure wellhead production line immediately upstream of choke and about 5 feet downstream of scale inhibitor injection port (3800 psig, 130°C). Sampling port on bottom of production line.

INJECTION WELL HALF-LIFE ESTIMATES


Half-life estimates for the Brazoria test site brine disposal well were calculated after the method of Barkman and Davidson¹⁴ for a constant pressure drop process. The calculated half-life is the time required for the injection rate to decline to one-half of its initial value. Disposal well impairment was calculated for the cases of well bore narrowing and invasion. Well bore narrowing results when a filter cake forms on the sand face and then builds inward eventually partially filling the well bore. The invasion model accounts for penetration of the disposal formation by fine suspended solids which ultimately form an internal filter cake within the disposal formation. For each mechanism, the half-life is given by the product:

$$T_{\frac{1}{2}} = (F)(G) \quad (1)$$

Relevant formation and injection parameters that form the basis for the half-life estimates are provided in Table 1. The F-factor is a constant given by:

Figure 2.

GENERALIZED SCHEMATIC OF DOE'S BRAZORIA GEOPRESSURED -GEOTHERMAL TEST SYSTEM



$$F = (1.723 \times 10^4) \left(\frac{\pi \cdot r_w^2 \cdot h \cdot \rho_c}{i_o \cdot w \cdot \rho_w} \right) \quad (2)$$

where: F = time to fill the wellbore with solids at the initial flow rate (years)

r_w = wellbore radius (meters)

h = injection interval (meters)

i_o = initial injection rate (STBD)

w = concentration suspended solids ($\mu\text{g/g}$)

ρ_c/ρ_w = density ratio, filter cake: brine

Estimates of the permeability of filter cakes were developed from calculation of the water quality ratio given by:

$$\frac{w}{K_c} = (8166.11) \left(\frac{1}{S^2} \right) \left(\frac{2\rho_c A^2 \Delta P}{\mu \rho_w} \right) \quad (3)$$

where: w = weight concentration of solids in water ($\mu\text{g/g}$)

K_c = filter cake permeability (md)

S = slope of cumulative volume vs. square root of time ($\text{ml}/\sqrt{\text{min}}$)

ρ_c = bulk density of filter cake (gm/cm^3)

ρ_w = density of water (gm/cm^3)

A = exposed area of filter cake (cm^2)

ΔP = total pressure differential across filter (psi)

μ = fluid viscosity (cp)

G-factors for wellbore narrowing and invasion were estimated as follows:

$$\text{Well bore narrowing: } G = 1 + \frac{1}{21n\theta} - \left(\frac{1}{\alpha} + \frac{1}{21n\theta} \right) \theta^{2(\alpha-1)/\alpha} \quad (4)$$

where: $\alpha = 0.5$

$$\theta = (r_e/r_w)^{k_c/k_f}$$

r_e = radius of effect
 r_w = well bore radius
 k_c = filter cake permeability
 k_F = formation permeability

$$\text{Invasion: } G = \left[\frac{r_a^2 \phi^2}{r_w^2} \right] \left[1 + \frac{\beta}{2 \ln \theta} - \left(\frac{1}{\alpha} + \frac{\beta}{2 \ln \theta} \right) \theta^{2(\alpha-1)/\alpha\beta} \right] \quad (5)$$

where: r_a = invasion radius
 $\beta = 1 - (k_c/k_F)$
 ϕ = fractional porosity

TEST RESULTS

Half-life estimates based on Equations (1)-(4) are summarized in Table 2. The slopes used in the water quality calculations were based on least squares regression of the filtration curves. The filtration data and the corresponding filtration curves are provided in Appendix I. Because of the limited field time available for testing, we limited most of the injectability runs to about 15 minutes. In general, this time interval was sufficient to define the linear portion of the filtration curves. A typical filtration curve indicating no invasion (negative intercept) is shown in Figure 3. Only data points indicated by solid circles were used in the regression analysis. In some cases, it was necessary to reject erratic data points (as determined by inspection of the filtration curves), which were generated as a result of severe fluctuations in line pressure and by difficulties associated with maintaining constant differential pressure. The suspended solids data indicated in Table 2 were not corrected for membrane filter elution loss because, in several attempts to measure elution loss, the weight loss membrane filter gained weight due to scale formation. However, this correction is usually very small. The scaling

Table 2.

INJECTION WELL HALF-LIFE ESTIMATES
FOR THE DOE-BRAZORIA GEOPRESSURED TEST SITE


| Run | Date (Sept, 1980) | Membrane Filter Pore Size (µm) | 1 µm Cuno Cartridge Prefilter | Pressure (PSI) | | Membrane Filter ΔP(PSI) | Temperature (°C) | | Scale Inhibitor (PPM) | Filtered Volume (ml) | Suspended Solids (mg/l) |
|-------|----------------------|-----------------------------------|-------------------------------------|----------------|--------------|-------------------------------|------------------|--------|--------------------------|-------------------------|----------------------------|
| | | | | Source | Memb. Filter | | Source | Filter | | | |
| LN-1 | 22 | 0.4 | No | 360 | 360 | 50 | 130 | 90 | 50 | 2,598 | 10.0 |
| LN-3 | 22 | 10.0 | No | 350 | 350 | 50 | 130 | 90 | 50 | 2,920 | 6.0 |
| LN-5 | 22 | 0.4 | No | 360 | 360 | 50 | 130 | 107 | 50 | 1,920 | 6.8 |
| LN-7 | 22 | 10.0 | No | 360 | 360 | 50 | 130 | 122 | 50 | 2,300 | 8.7 |
| LN-11 | 23 | 10.0 | Yes | 380 | 380 | 0.03 | 130 | 126 | 50 | 39,490 | 0.05 |
| LN-13 | 23 | 0.4 | No | 370 | 370 | 50 | 130 | 119 | 50 | 1,620 | 14.8 |
| LN-14 | 23 | 10.0 | No | 400 | 400 | 50 | 130 | 115 | 50 | 1,610 | 9.9 |
| LN-15 | 24 | 10.0 | No | 400 | 400 | 50 | 130 | 115 | 50 | 1,960 | 8.0 |
| LN-16 | 25 | 10.0 | No | 400 | 400 | 0.03 | 130 | 130 | 0 | 28,310 | 0.021 |
| MN-1 | 23 | 0.4 | No | 800 | 800 | 50 | 130 | 112 | 50 | 2,530 | 13.5 |
| MN-2 | 23 | 10.0 | No | 800 | 800 | 50 | 130 | 120 | 50 | 3,340 | 11.8 |
| MN-3 | 23 | 10.0 | Yes | 760 | 760 | 0.03 | 130 | 129 | 50 | 36,000 | 0.031 |
| HN-1 | 24 | 0.4 | No | 3800 | 400 | 50 | 130 | 120 | 50 | 2,630 | 1.4 |
| HN-2 | 24 | 10.0 | No | 3800 | 400 | 5 | 130 | 128 | 50 | 19,300 | 0.067 |
| HN-3 | 24 | 0.4 | No | 3800 | 1000 | 70 | 130 | 119 | 50 | 4,320 | 0.69 |
| HN-4 | 24 | 10.0 | No | 3800 | 1000 | 0.1 | 130 | 130 | 50 | 13,540 | 0.27 |
| HN-5 | 25 | 0.4 | No | 3800 | 1800 | 50 | 130 | 120 | 15 | 4,620 | 1.3 |
| HN-6 | 25 | 10.0 | No | 3800 | 1800 | 1 | 130 | 120 | 15 | 5,360 | 1.3 |
| HN-7 | 25 | 10.0 | No | 3800 | 1500 | 20 | 130 | 125 | 50 | 10,110 | 0.41 |
| HN-9 | 25 | 10.0 | No | 3800 | 1000 | 1 | 130 | 127 | 50 | 5,850 | 0.48 |
| HN-8 | 25 | 10.0 | No | 3800 | 1000 | 0.03 | 130 | 129 | 0 | 31,000 | 0.026 |

11

| Filtration Curve | | Water Quality (PPM/md) | kc (md) | F-Factor (22,000 B/D) | G ₁ -Factor (No Invasion) | Half-life (YRS) | G ₂ -Factor (Invasion) | Half-life (YRS) | Run |
|------------------|----------------|------------------------------|------------|--------------------------|---|----------------------|--------------------------------------|--------------------|-------|
| Intercept (ml) | Slope (mV/min) | | | | | | | | |
| - 1.4 | 624.2 | 2801.2 | 0.0032 | 0.17 | | | 0.0061 | 0.0011 | LN-1 |
| + 510.5 | 640.2 | 2662.9 | 0.0021 | 0.29 | | | 0.0038 | 0.0011 | LN-3 |
| - 91.1 | 482.9 | 4680.3 | 0.0013 | 0.25 | 3.0x10 ⁻⁵ | 1x10 ⁻⁵ | | | LN-5 |
| + 365.3 | 534.9 | 3814.5 | 0.0021 | 0.20 | | | 0.0038 | 0.0008 | LN-7 |
| -28627.2 | 13579.4 | 0.0036 | 12.8 | 34.4 | 0.27 | 9.3 | 20.8 | 717.3 | LN-11 |
| - 587.2 | 546.1 | 3659.7 | 0.0037 | 0.12 | 0.0001 | 1x10 ⁻⁵ | | | LN-13 |
| - 3.9 | 383.2 | 7432.5 | 0.0012 | 0.17 | 3.0x10 ⁻⁵ | 5x10 ⁻⁶ | | | LN-14 |
| + 71.8 | 462.1 | 5111.1 | 0.0014 | 0.22 | | | 0.0031 | 0.0007 | LN-15 |
| -23497.7 | 14853.9 | 0.0030 | 6.4 | 81.9 | 0.14 | 11.8 | 11.0 | 902 | LN-16 |
| - 770.9 | 708.7 | 2173.0 | 0.0057 | 0.13 | 0.0001 | 1.7x10 ⁻⁵ | | | MN-1 |
| - 157.1 | 740.5 | 1990.9 | 0.0054 | 0.15 | 0.0001 | 1.9x10 ⁻⁵ | | | MN-2 |
| -29990.0 | 17009.7 | 0.0023 | 12.5 | 55.5 | 0.26 | 14.7 | 20.3 | 1129 | MN-3 |
| - 325.4 | 737.7 | 2005.5 | 0.00064 | 1.23 | <1x10 ⁻⁶ | <1x10 ⁻⁶ | | | HN-1 |
| -17272.7 | 9090.9 | 1.32 | 0.046 | 25.7 | 0.0011 | 0.028 | | | HN-2 |
| - 1400.8 | 1447.2 | 729.6 | 0.00086 | 2.5 | 2x10 ⁻⁵ | 5x10 ⁻⁵ | | | HN-3 |
| +15300.0 | 833.3 | 3.14 | 0.078 | 6.4 | | | 0.14 | 0.89 | HN-4 |
| - 1582.0 | 1527.7 | 467.6 | 0.0025 | 1.3 | 0.0001 | 0.0001 | | | HN-5 |
| - 2474.0 | 740.4 | 39.8 | 0.030 | 1.3 | 0.0007 | 0.0009 | | | HN-6 |
| + 5258.6 | 944.0 | 489.9 | 0.0008 | 4.2 | | | 0.0015 | 0.0063 | HN-7 |
| + 4467.5 | 292.0 | 256.0 | 0.0017 | 3.6 | | | 0.0030 | 0.011 | HN-9 |
| -30202.8 | 15676.7 | 0.0027 | 8.9 | 66.2 | 0.20 | 12.8 | 14.9 | 985 | HN-8 |

Figure 3.

FILTRATION CURVE WITHOUT INVASION



12

was ultimately attributed to deposition of the scale inhibitor compound (15-50 ppm of a phosphonate-polyacrylate threshold-type carbonate inhibitor).

A summary of average suspended solids data for the Brazoria system is provided in Table 3. If we assume an average suspended solids concentration of 11.8 mg/l is supplied to the injection well at a brine flow rate of 22,000 BBL/day, then approximately 91 pounds of solids would be deposited in the injection well on a daily basis (16.5 tons per year). The suspended solids data suggest that about 24% of the suspended solids in the injection line are less than 10- μ m in diameter.

The test results indicated, as shown in Figures 4 and 5, that brine treated with scale inhibitor had extremely low quality even after passage through the gas separator. Brine which was prefiltered with a 1- μ m pore size Cuno cartridge filter had high quality. Ultimately it was demonstrated, by temporarily interrupting the injection of scale inhibitor, that the scale inhibitor itself was the cause of the poor injectability characteristics of the brine. Untreated brine had higher quality than prefiltered scale-inhibited brine!

Because the gauge we used was designed to measure pressures >5 psi, the indicated differential pressure across 10- μ m pore size membrane filters was zero when prefiltered scale-inhibited brine and untreated brine were evaluated. In these cases, it was therefore not possible to directly estimate injection well half-lives. The half-lives indicated in Table 2 were generated after estimates of differential pressure were developed as follows:

The permeability of a 10- μ m pore size membrane filter can be calculated from:

$$k = \frac{\mu Q L}{A \Delta P} \quad (6)$$

TABLE 3

SUMMARY OF SUSPENDED SOLIDS DATA FOR THE
DOE-BRAZORIA GEOPRESSURED TEST SITE

| <u>Brine Source</u> | <u>Membrane Filter Pore Size (μm)</u> | <u>1-mm Prefilter</u> | <u>Carbonate Scale Inhibitor (PPM)</u> | <u>Suspended Solids (mg/l)</u> |
|---|---|---------------------------|--|------------------------------------|
| Low Pressure Injection Line (400 PSIG; 130°C) | 0.4 | No | 50 | 10.8 |
| | 10.0 | No | 50 | 8.2 |
| | 10.0 | No | 0 | 0.02 |
| Moderate Pressure Pro- duction (800 PSIG; 130°C) | 0.4 | No | 50 | 13.5 |
| | 0.4 | Yes | 50 | 0.07 |
| | 10.0 | No | 50 | 11.8 |
| | 10.0 | Yes | 50 | 0.03 |
| High Pressure Wellhead (3800 PSIG; 130°C) | 0.4 | No | 50 | 1.1 |
| | 10.0 | No | 50 | 0.5 |
| | 10.0 | No | 0 | 0.03 |

Figure 4. HIGH PRESSURE WELLHEAD PRODUCTION LINE
(3800 psi; 130°C)





Figure 5. 10.0 MICRON MEMBRANE FILTRATION DATA
 LOW PRESSURE INJECTION LINE
 (380 PSI; 130C)



where: k = permeability (darcy)
 μ = viscosity (cp)
 Q = flowrate (cm³/sec)
 L = thickness (cm)
 A = cross-sectional area (cm²)
 ΔP = differential pressure (atm)

Permeability data obtained from the manufacturer for Nuclepore membrane filters for clean water at ambient temperature are shown in Figure 6. Unfortunately, flow data for 10- μ m pore size polycarbonate membrane filters are not provided. However, if we assume a flowrate of at least 2000 ml/cm²·min at a differential pressure of 1 psi, we can calculate a permeability of about 400 md for the filter. If we next assume that the permeability of the membrane filter is independent of temperature, Eq. 7 can be used to solve for differential pressure:

$$\Delta P = \frac{(0.32 \text{ cp})(42 \text{ ml/sec})(8 \times 10^{-4} \text{ cm})}{(0.4 \text{ d})(13.2 \text{ cm}^2)} \quad (7)$$

$$\Delta P = 0.03 \text{ psi}$$


Where 0.32 cp is the viscosity of brine (13.5 weight percent NaCl) at 130°C (from Ref. 21) and 42 ml/sec is the highest flowrate observed when prefiltered, scale-inhibited brine or untreated brine were evaluated with a 10- μ m pore size membrane filter.

COMPOSITION OF SUSPENDED SOLIDS

The solids collected on several of the filters were analyzed by x-ray diffraction and by energy dispersive x-ray fluorescence (EDAX) in conjunction with scanning electron microscopy. The results are summarized in Table 4. In the case of the experiments conducted when no inhibitor was being injected,

Figure 6

Clean Water Flow Rate vs. Pressure @68°F and 14.7 PSI



NUCLEPORE MEMBRANE SPECIFICATIONS

| Pore Size (μm) ¹ | Code Number | Nominal Pore Density (pores/cm ²) | Nominal Thickness (μm) | Flow Rates ² | | Bubble Point ³ (psi) | |
|---|-------------|--|--|---------------------------------|------------------------------|------------------------------------|--|
| | | | | Water ml/min/cm ² | Air l/min/cm ² | | |
| 12.0 | N1200 | 1×10^5 | 6 | >2000 | 65 | <1 | |
| 10.0 | N1000 | 1×10^5 | 8 | >2000 | 50 | <1 | |
| 8.0 | N800 | 1×10^5 | 10 | 2000 | 45 | 2 | |
| 5.0 | N500 | 4×10^5 | 10 | 2000 | 42 | 4 | |
| 3.0 | N300 | 2×10^6 | 10 | 2000 | 42 | 6 | |
| 2.0 | N200 | 2×10^6 | 10 | 2000 | 36 | 10 | |
| 1.0 | N100 | 2×10^7 | 10 | 300 | 36 | 15 | |
| 0.8 | N080 | 3×10^7 | 10 | 300 | 36 | 16 | |
| 0.6 | N060 | 3×10^7 | 10 | 80 | 16 | 25 | |
| 0.4 | N040 | 1×10^8 | 10 | 80 | 16 | 33 | |
| 0.2 | N020 | 3×10^8 | 10 | 26 | 6 | 60 | |
| 0.1 | N010 | 3×10^8 | 5 | 8 | 2.2 | >100 | |
| 0.08 | N008 | 6×10^8 | 5 | 8 | 2.2 | >100 | |
| 0.05 | N005 | 6×10^8 | 5 | 0.45 | 0.25 | >100 | |
| 0.03 | N003 | 6×10^8 | 5 | 0.03 | 0.03 | >100 | |
| 0.015 | N001 | Experimental Material — Firm specifications not yet established. | | | | | |

¹ Maximum pore diameter

² 25°C, 70 cm Hg (13.5 psi)

³ Bubble point value is the pressure required to force air through the pores of a water-wet filter.

(From Nuclepore Filtration Products for the Laboratory: Catalog LAB 30)

TABLE 4

SUMMARY OF RESULTS OF CHEMICAL ANALYSIS
OF SUSPENDED SOLIDS

| <u>Filter Number</u> | <u>Brine Conditions</u> | <u>Compound Analysis by X-Ray Diffraction</u> | <u>Elemental and Compound Analysis by EDAX-SEM</u> |
|----------------------|--------------------------------|---|---|
| HN-1 | High Pressure, Inhibitor | Large amorphous component. Some calcite | |
| HN-8 | High Pressure, No inhibitor | not analyzed | Small amount of silica |
| MN-1 | Med. Pressure, Inhibitor | Large amorphous component. Some quartz | |
| LN-13, 15 | Low Pressure, Inhibitor | Large amorphous component. Some halite | |
| LN-15 | Low Pressure, Inhibitor | not analyzed | High Cl; Med. P, Ca, Na; Low Ba, Fe. No silica seen. |
| LN-16 | Low Pressure, No inhibitor | not analyzed | Main component is silica. Low Na, Cl, Fe, S, Al, Ba (prob. BaSO ₄). No P seen. |

not enough material was collected to do a definitive x-ray diffraction analysis; however, a good indication of the composition of these solids was obtained by EDAX-SEM.

When no inhibitor was being injected (HN-8 wellhead sample and LN-16 injection line sample), the small quantity of solids were mostly silica, perhaps sand from the formation, and some particles of $BaSO_4$. When the inhibitor was being injected, a large amorphous component was present in the solids, which was rich in phosphorous, calcium, sodium, and chlorine. This is a strong indication that the phosphonate inhibitor either precipitated directly or reacted with the brine calcium to form a precipitate, and in the process occluded some of the brine NaCl. Note that no calcite could be identified in the solids from the brine being injected. None of the techniques used would have detected the acrylate component of the inhibitor formulation, but it too is known to precipitate calcium in overfeed conditions.

SIMPLIFIED HALF-LIFE ESTIMATES

In order to utilize the Barkman and Davidson method for estimating injection well half-life, it is first necessary to measure a suspended solids concentration for the water being evaluated. Field measurement of suspended solids concentration, while not difficult, is laborious. A method suggested by Huggins²² can be used to eliminate the necessity of measuring suspended solids concentrations. This method also eliminates the necessity of estimating the filter cake to brine density ratio.

The basis for simplified well bore narrowing half-life estimates (for the case of no invasion) can be developed as follows:

$$T_{\frac{1}{2}} = (F)(G)$$

For $\frac{k_c}{k_f} < 0.05$

$$G \cong 3 \left(\frac{k_c}{k_f} \right) \ln \frac{r_e}{r_w}$$

Since $F = \left(\frac{\pi r_w^2 h}{i_o} \right) \left(\frac{\rho_c}{\rho_w} \right)$

$$T_{\frac{1}{2}} = \left(\frac{k_c}{w} \right) \left(\frac{\rho_c}{\rho_w} \right) \left(\frac{\pi r_w^2 h}{i_o} \right) \left(\frac{3}{k_f} \right) \left(\ln \frac{r_e}{r_w} \right)$$

But $k_{wC} = \left(\frac{S^2 \mu}{2A^2 \Delta p} \right) \left(\frac{\rho_w}{\rho_c} \right)$

where S is the slope of the cumulative volume vs. the square root of of time curve

Substituting:

$$T_{\frac{1}{2}} = \left(\frac{S^2 \mu}{2A^2 \Delta p} \right) \left(\frac{\pi r_w^2 h}{i_o} \right) \left(\frac{3}{k_f} \right) \left(\ln \frac{r_e}{r_w} \right) \quad (8)$$

and

$$T_{\frac{1}{2}} \propto \frac{S^2}{i_o}$$

To evaluate the applicability of Eq. 8, we performed a linear regression analysis of measured filtration curve slopes (using 5 points) and associated half-lives (from Table 2) for all non-invading runs which yielded a filter cake permeability (k_c) of 0.05 md or greater. The analysis yielded a coefficient of correlation (r^2) of 0.992. The following equation was derived for estimating a half-life, given the slope ($\text{ml}/\sqrt{\text{min}}$) of a filtration curve and assuming an injection rate of 22,000 BBL/day:

$$T_{\frac{1}{2}}(\text{yrs}) = [(Slope - 8936.0)/525.0] \quad (9)$$

Use of Eqs. 8 and 9 implies that measured filtration curve slopes of 8937.5 $\text{ml}/\sqrt{\text{min}}$ and 9465 $\text{ml}/\sqrt{\text{min}}$ would correspond to half-lives of about 1 day and 1 year, respectively.

SUMMARY AND CONCLUSIONS

An apparatus was designed, fabricated, and successfully utilized to evaluate the injectability characteristics of geopressured brine at temperatures and pressures of $\leq 150^{\circ}\text{C}$ and ≤ 2000 psig, respectively. The apparatus permits measurement of suspended solids concentration and scaling potential by exposing membrane filters at in-situ, high pressure/high temperature line conditions.

Injectability tests were run at injection line conditions (130°C ; 380 psig), immediately upstream of the gas separator (130°C ; 800 psig) and at wellhead conditions just upstream of the choke (about 5 feet downstream of the scale inhibitor injection port) where line pressure was 3800 psig. Nuclepore, polycarbonate membrane filters with 0.4- μm and 10.0- μm pore size distributions were used to establish nominal suspended solids concentrations and to simulate injection into a high permeability Gulf Coast aquifer. The 10- μm pore size membrane filter is a reasonable analog of a high permeability, high porosity formation (1 darcy; 20% porosity).

Test results demonstrated conclusively that the threshold carbonate scale inhibitor, which was injected into the top of a two-phase (noncondensable gases-brine) mixture, upstream of the wellhead choke, caused precipitation of up to 15 ppm of suspended solids. The suspended solids carried through the gas separator and ultimately were deposited within the injection well and/or the injection formation. In the absence of scale inhibitor, the raw geopressured brine had extremely high quality. In fact, the raw brine without scale inhibitor had equivalent or better quality than scale-inhibited brine after filtration with a 1- μm pore size Cuno cartridge filter!

Based on these results, it can be concluded that Brazoria brine has high injectability at pressures varying from 380 to 3800 psi, even after gas

separation, provided scale control additives, if required, are used in a way that does not degrade brine quality.

It is of interest to speculate about the fact that the injection well at the Brazoria site (Pleasant Bayou No. 1) continued to accept low quality brine with a moderate rate of back pressure buildup while half-life estimates predicted an extremely short operating life for the well. A plausible explanation for this apparent anomalous behavior is related to the rather unique completion of the injection well.

The injection well was originally designed as a production well. However, problems encountered during drilling necessitated plugging of the borehole back from 15,675 feet to about 8,500 feet. The hole was then recompleted for use as a disposal well.

Our half-life estimates were based on an injection interval of about 150 feet. However, if brine was able to flow past the cement retainer, at the bottom of the completion interval, via an annulus behind the casing, then the actual injection interval would have been literally thousands of feet in length. Altering the injection interval length by a factor of 20 to 30 would be sufficient to yield much longer half-life estimates.

In the future, injection of scale inhibitor, when required, should be restricted to injection ports located on the bottom of flow lines to avoid partial evaporation and precipitation of limited solubility inhibitors. In addition, solubility (or reactivity) determinations for scale inhibitors should be made in simulated brine, at the maximum anticipated temperature of use, prior to their use in the field. Finally, such inhibitors should be injected using non-pulsating pumps so that solubility limits cannot ever be exceeded.

ACKNOWLEDGEMENTS

We thank Rick Batten and Sue Deveny of Finix and Scisson, and Paul Langston of Weatherly Engineering for their assistance with the logistical aspects of the field injectability study, and Bill Beiriger of LLNL for the chemical analyses of the solids.

Funding for this work was provided by the Department of Energy, Division of Geothermal Energy, and the Lawrence Livermore National Laboratory under Contract No. W-7405-ENG-48.

REFERENCES

1. Quong, R., Owen, L. B., Locke, F. E. and Netherton, R., 1980, Methane extraction from geopressured-geothermal brine at wellhead conditions: Trans., Geothermal Resources Council, V. 4, pp 819-822.
2. Quong, R., Owen, L. B. and Locke, F. E., 1980, Potential methods for methane extraction from geopressured brine at high temperature and pressure: SPE, 9469, Dallas, Texas.
3. Owen, L. B.: Evaluating brine injection for DOE's Strategic Petroleum Reserve Program, Energy and Technology Review, UCRL-52000-79-8, pp 1-10 (1979).
4. Owen, L. B. and Quong, R. (Editors): Improving the performance of brine injection wells at Gulf Coast Strategic Petroleum Reserve sites, UCLLL Rpt., UCRL-52829, p 545 (1980).
5. Doscher, T. M. and Weber, L: The use of the membrane filter in determining quality of water for subsurface injection, Drill and Prod. Prac., API, pp 169-179 (1957).
6. Johnston, K. H. and Castagno, J. L.: Evaluation by filter methods of the quality of waters injected in waterfloods, U. S. Bureau of Mines, Rep. 6426, p 13 (1964).
7. Farley, J. T. and Redline, D. G.: Evaluation of flood water quality in the west Montalvo field, JPT, pp 683-687 (July, 1968).
8. Jordan, C. A., Edmondson, T. A. and Jeffries-Harris, M. J.: The Bay Marchand pressure maintenance project - Unique challenges of an offshore, sea-water injection system, JPT, pp 389-396 (April, 1969).
9. McCune, C. C.: On-site testing to define injection-water quality requirements, JPT, pp 17-24 (January, 1977).
10. Quong, R., Owen, L. B. and Tardiff, G. E.: Geothermal brine injection evaluation methodology, Trans., 2nd Invitational Well-Testing Symposium, U.C.L.B.L. pp 78-80 (October, 1978).
11. Tewhey, J. D., Chan, M. A., Kasameyer, P. W. and Owen, L. B.: Development of injection criteria for geothermal resources, Trans., GRC, V. 2, pp 649-652 (1978).
12. Owen, L. B., Raber, E., Otto, C., Netherton, R., Neurath, R. and Allen, L.: An assessment of the injectability of conditioned brine produced by a reaction clarification-gravity filtration system in operation at the Salton Sea Geothermal Field, Southern California, UCLLL Rpt., UCID 18488, p 30 (1979).
13. Raber, E., Owen, L. B. and Harrar, J. E.: Using surface waters for supplementing injection at the Salton Sea Geothermal Field (SSGF), Southern California, Trans., GRC, V. 3, pp 561-564 (1979).

14. Barkman, J. H. and Davidson, D. H.: Measuring water quality and predicting well impairment, JPT, pp 865-872 (July, 1972).
15. Donaldson, E. C. and Baker, B. A.: Particle transport in sandstones, SPE 6905, p 20 (October, 1977).
16. Owen, L. B., Kasmeyer, P. W., Netherton, R. and Thorson, L.: Predicting the rate by which suspended solids plug geothermal injection wells: Proc., 3rd Annual Workshop, Geothermal Reservoir Eng., Stanford Univ. (December, 1977).
17. Champlin, J. B. F., Thomas, R. D., and Brownlow, A. D.: Laboratory testing and evaluation of porous permeable rock for nuclear waste disposal, U. S. Bureau of Mines, Rept. 6926, p 33 (1967).
18. Netherton, R. and Owen, L. B.: Apparatus for the field evaluation of geothermal effluent injection; Trans., GRC, V. 2., pp 487-490 (1978).
19. Hasbrouck, R. T., Owen, L. B. and Netherton, R.: An automated system for membrane filtration and core tests; Trans., GRC, V.3, pp 301-304 (1979).
20. Keenan, J. H., Keyes, F. G., Hill, P. G. and Moore, J. G., 1969, Steam Tables: John Wiley and Sons, p 162.
21. Matthews, C. S. and Russell, D. G., 1967, Pressure buildup and flow tests in Wells, Monograph Volume 1, H. L. Doherty Series (Society of Petroleum Engineers, Dallas, Texas).
22. Hudgins, C. M. Jr., February, 1980, Petro Tech Consultants, Inc., Personal Communication.

APPENDIX I

DOE-Brazoria Geopressured-Geothermal Test Site Injectability
Data and Filtration Curves.


| | <u>Pages</u> |
|---------------------|--------------|
| LN Series | 28-54 |
| MN Series | 55-63 |
| HN Series | 64-90 |


INJECTABILITY TEST DATA

Run: LN 1 Membrane Filter: 0.4- μ m 1- μ m Cuno Prefilter: No
 Source Press: 360 psig Run Press: 360 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 90°C
 Total Filtered Volume: 2598 ml Suspended Solids: 10.0 mg/l (9.09 μ g/g)

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | .119 | 0.34 | 100 | 840.3 |
| 2 | .415 | 0.64 | 200 | 337.8 |
| 3 | .755 | 0.87 | 300 | 294.1 |
| 4 | 1.153 | 1.07 | 400 | 251.3 |
| 5 | 1.572 | 1.25 | 500 | 238.7 |
| 6 | 2.003 | 1.42 | 600 | 232.0 |
| 7 | 2.475 | 1.57 | 700 | 211.9 |
| 8 | 2.966 | 1.72 | 800 | 203.7 |
| 9 | 3.290 | 1.81 | 900 | 308.6 |
| 10 | 3.985 | 2.00 | 1000 | 143.9 |
| 11 | 4.533 | 2.13 | 1100 | 182.5 |
| 12 | 5.107 | 2.26 | 1200 | 174.2 |
| 13 | 5.710 | 2.39 | 1300 | 165.8 |
| 14 | 6.348 | 2.52 | 1400 | 156.7 |
| 15 | 7.016 | 2.65 | 1500 | 149.7 |
| 16 | 7.742 | 2.78 | 1600 | 137.7 |
| 17 | 8.491 | 2.91 | 1700 | 133.5 |
| 18 | 9.243 | 3.04 | 1800 | 133.0 |
| 19 | 10.018 | 3.17 | 1900 | 129.0 |
| 20 | 10.852 | 3.29 | 2000 | 119.9 |
| 21 | 11.716 | 3.42 | 2100 | 115.7 |
| 22 | 12.524 | 3.54 | 2200 | 123.8 |
| 23 | 13.639 | 3.69 | 2300 | 89.7 |
| 24 | 14.771 | 3.84 | 2400 | 88.3 |
| 25 | 16.078 | 4.01 | 2500 | 76.5 |

RUN NO: LN-1






INJECTABILITY TEST DATA

Run: LN-3 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 350 psig Run Press: 350 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 95°C
 Total Filtered Volume: 2920 ml Suspended Solids: 6 mg/l (5.5 μ g/g)


| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | .372 | 0.61 | 500 | 1344.1 |
| 2 | .679 | 0.82 | 800 | 977.2 |
| 3 | .935 | 0.97 | 900 | 390.6 |
| 4 | 1.079 | 1.04 | 1000 | 694.4 |
| 5 | 1.979 | 1.41 | 1200 | 222.2 |
| 6 | 2.835 | 1.68 | 1600 | 467.3 |
| 7 | 4.072 | 2.02 | 1800 | 161.7 |
| 8 | 5.367 | 2.32 | 2000 | 154.4 |
| 9 | 6.941 | 2.63 | 2200 | 127.1 |
| 10 | 8.776 | 2.96 | 2400 | 109.0 |
| 11 | 10.664 | 3.27 | 2600 | 105.93 |
| 12 | 12.763 | 3.57 | 2800 | 95.3 |

RUN NO: LN-3



32

RUN NO: LN-3




INJECTABILITY TEST DATA


Run: LN-5 Membrane Filter: 0.4- μ m 1- μ m Cuno Prefilter: No
 Source Press:360 psig Run Press:360 psig Differential Press:50 psig
 Source Temp:130°C Run Temp:107°C
 Total Filtered Volume:1920 ml Suspended Solids: 6.8 mg/l (6.2 μ g/g)

| ITEM | Time(min) | \sqrt{t} (min) | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|------------------|-----------------------|--------------------|
| 1 | 0.56 | 0.75 | 200 | 357.1 |
| 2 | 0.91 | 0.95 | 300 | 285.7 |
| 3 | 1.30 | 1.14 | 400 | 256.4 |
| 4 | 1.70 | 1.30 | 500 | 250.0 |
| 5 | 2.19 | 1.48 | 600 | 204.1 |
| 6 | 2.79 | 1.67 | 700 | 166.7 |
| 7 | 3.45 | 1.86 | 800 | 151.5 |
| 8 | 4.21 | 2.05 | 900 | 131.6 |
| 9 | 5.02 | 2.24 | 1000 | 123.5 |
| 10 | 5.96 | 2.44 | 1100 | 106.4 |
| 11 | 7.05 | 2.66 | 1200 | 91.7 |
| 12 | 8.15 | 2.85 | 1300 | 90.9 |
| 13 | 9.50 | 3.08 | 1400 | 74.1 |
| 14 | 10.88 | 3.30 | 1500 | 72.5 |
| 15 | 12.29 | 3.51 | 1600 | 70.9 |
| 16 | 13.78 | 3.71 | 1700 | 67.1 |
| 17 | 15.32 | 3.91 | 1800 | 64.9 |

RUN NO: LN-5



RUN NO: LN-5





INJECTABILITY TEST DATA

Run: LN-7 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 360 psig Run Press: 360 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 122°C
 Total Filtered Volume: 2300 ml Suspended Solids: 8.7 mg/l (7.9 μ g/g)

| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|
| 1 | 0.09 | 0.30 | 100 | 1111.1 |
| 2 | 0.22 | 0.47 | 400 | 769.2 |
| 3 | 0.38 | 0.62 | 500 | 625.0 |
| 4 | 0.54 | 0.73 | 600 | 625.0 |
| 5 | 0.80 | 0.89 | 700 | 384.6 |
| 6 | 1.13 | 1.06 | 800 | 303.0 |
| 7 | 1.53 | 1.24 | 900 | 250.0 |
| 8 | 1.92 | 1.39 | 1000 | 256.4 |
| 9 | 2.33 | 1.53 | 1100 | 243.9 |
| 10 | 2.76 | 1.66 | 1200 | 232.6 |
| 11 | 3.29 | 1.81 | 1300 | 188.7 |
| 12 | 3.87 | 1.97 | 1400 | 172.4 |
| 13 | 4.57 | 2.14 | 1500 | 142.9 |
| 14 | 5.28 | 2.30 | 1600 | 140.9 |
| 15 | 6.22 | 2.49 | 1700 | 106.4 |
| 16 | 7.23 | 2.69 | 1800 | 99.0 |
| 17 | 8.29 | 2.88 | 1900 | 94.3 |
| 18 | 9.37 | 3.06 | 2000 | 92.6 |
| 19 | 10.47 | 3.24 | 2100 | 90.9 |
| 20 | 11.74 | 3.43 | 2200 | 78.7 |
| 21 | 13.06 | 3.61 | 2300 | 75.8 |

RUN NO: LN-7






INJECTABILITY TEST DATA

Run: LN 11 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: Yes
 Source Press: 380 psig Run Press: 380 psig Differential Press: <0.1 psig
 Source Temp: 130°C Run Temp: 126°C
 Total Filtered Volume: 39,490 ml Suspended Solids: 0.05 mg/l (0.046 μ g/g)

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) | ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.06 | 0.24 | 100 | 1666.7 | 39 | 11.45 | 3.48 | 21000 | 1351.4 |
| 2 | 0.33 | 0.57 | 1000 | 2000.0 | 40 | 12.42 | 3.52 | 21500 | 1470.6 |
| 3 | 0.40 | 0.63 | 1500 | 7142.9 | 41 | 12.75 | 3.57 | 22000 | 1515.2 |
| 4 | 0.47 | 0.69 | 2000 | 7142.9 | 42 | 13.10 | 3.62 | 22500 | 1428.6 |
| 5 | 0.62 | 0.72 | 2500 | 3333.3 | 43 | 13.39 | 3.66 | 23000 | 1724.1 |
| 6 | 1.29 | 1.14 | 4500 | 2985.1 | 44 | 13.75 | 3.71 | 23500 | 1388.9 |
| 7 | 1.59 | 1.26 | 5000 | 1666.7 | 45 | 14.12 | 3.76 | 24000 | 1351.4 |
| 8 | 1.92 | 1.39 | 5500 | 1515.2 | 46 | 14.46 | 3.80 | 24500 | 1470.6 |
| 9 | 2.24 | 1.50 | 6000 | 1562.5 | 47 | 14.77 | 3.84 | 25000 | 1612.9 |
| 10 | 2.57 | 1.60 | 6500 | 1515.2 | 48 | 15.12 | 3.89 | 25500 | 1428.6 |
| 11 | 2.80 | 1.67 | 7000 | 2173.9 | 49 | 15.46 | 3.93 | 26000 | 1470.6 |
| 12 | 3.16 | 1.78 | 7500 | 1388.9 | 50 | 15.81 | 3.98 | 26500 | 1428.6 |
| 13 | 3.51 | 1.87 | 8000 | 1428.6 | 51 | 16.08 | 4.01 | 27000 | 1851.9 |
| 14 | 3.87 | 1.97 | 8500 | 1388.9 | 52 | 16.45 | 4.06 | 27500 | 1351.4 |
| 15 | 4.15 | 2.04 | 9000 | 1785.7 | 53 | 16.80 | 4.10 | 28000 | 1428.6 |
| 16 | 4.49 | 2.12 | 9500 | 1470.6 | 54 | 17.16 | 4.14 | 28500 | 1388.9 |
| 17 | 4.83 | 2.20 | 10000 | 1470.6 | 55 | 17.46 | 4.18 | 29000 | 1666.7 |
| 18 | 5.17 | 2.27 | 10500 | 1470.6 | 56 | 17.82 | 4.22 | 29500 | 1388.9 |
| 19 | 5.45 | 2.33 | 11000 | 1785.7 | 57 | 18.17 | 4.26 | 30000 | 1428.6 |
| 20 | 5.83 | 2.41 | 11500 | 1315.8 | 58 | 18.53 | 4.30 | 30500 | 1388.9 |
| 21 | 6.15 | 2.48 | 12000 | 1562.5 | 59 | 18.82 | 4.34 | 31000 | 1724.1 |
| 22 | 6.50 | 2.55 | 12500 | 1428.6 | 60 | 19.19 | 4.38 | 31500 | 1351.4 |
| 23 | 6.82 | 2.61 | 13000 | 1562.5 | 61 | 19.54 | 4.42 | 32000 | 1428.6 |
| 24 | 7.15 | 2.67 | 13500 | 1515.2 | 62 | 19.90 | 4.46 | 32500 | 1388.9 |
| 25 | 7.50 | 2.74 | 14000 | 1428.6 | 63 | 20.20 | 4.49 | 33000 | 1666.7 |
| 26 | 7.84 | 2.80 | 14500 | 1470.6 | 64 | 20.54 | 4.53 | 33500 | 1470.6 |
| 27 | 8.11 | 2.85 | 15000 | 1851.9 | 65 | 20.95 | 4.58 | 34000 | 1219.5 |
| 28 | 8.47 | 2.91 | 15500 | 1388.9 | 66 | 21.32 | 4.62 | 34500 | 1351.4 |
| 29 | 8.82 | 2.97 | 16000 | 1428.6 | 67 | 21.94 | 4.68 | 35000 | 806.5 |
| 30 | 9.15 | 3.02 | 16500 | 1515.2 | 68 | 22.30 | 4.72 | 35500 | 1388.9 |
| 31 | 9.42 | 3.07 | 17000 | 1851.9 | 69 | 22.67 | 4.76 | 36000 | 1351.4 |
| 32 | 9.80 | 3.13 | 17500 | 1315.8 | 70 | 23.00 | 4.80 | 36500 | 1515.2 |
| 33 | 10.14 | 3.18 | 18000 | 1470.6 | 71 | 23.37 | 4.83 | 37000 | 1351.4 |
| 34 | 10.46 | 3.23 | 18500 | 1562.5 | 72 | 23.74 | 4.87 | 37500 | 1351.4 |
| 35 | 10.70 | 3.27 | 19000 | 2083.3 | 73 | 24.11 | 4.91 | 38000 | 1351.4 |
| 36 | 11.08 | 3.33 | 19500 | 1315.8 | 74 | 24.43 | 4.94 | 38500 | 1562.5 |
| 37 | 11.45 | 3.38 | 20000 | 1351.4 | 75 | 24.79 | 4.98 | 39000 | 1388.9 |
| 38 | 11.77 | 3.43 | 20500 | 1562.6 | | | | | |

RUN NO: LN-11


41
FLOWRATE, MI/MIN




CUMULATIVE FLOW, MI

RUN NO: LN-11


42



RUN NO: LN-13



RUN NO: LN-13




INJECTABILITY TEST DATA


Run: LN-13 Membrane Filter: 0.4- μ m 1- μ m Cuno Prefilter: No
 Source Press: 370 psig Run Press: 370 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 119°C
 Total Filtered Volume: 1620 ml Suspended Solids: 14.8 mg/l (13.5 μ g/g)

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.52 | 0.72 | 100 | 192.3 |
| 2 | 1.19 | 1.09 | 200 | 149.3 |
| 3 | 2.00 | 1.41 | 300 | 123.5 |
| 4 | 2.71 | 1.65 | 400 | 140.9 |
| 5 | 3.52 | 1.88 | 500 | 123.5 |
| 6 | 4.33 | 2.08 | 600 | 123.5 |
| 7 | 5.36 | 2.32 | 700 | 97.1 |
| 8 | 6.42 | 2.53 | 800 | 94.3 |
| 9 | 7.40 | 2.72 | 900 | 102.0 |
| 10 | 8.47 | 2.91 | 1000 | 93.5 |
| 11 | 9.57 | 3.09 | 1100 | 90.9 |
| 12 | 10.86 | 3.30 | 1200 | 77.5 |
| 13 | 11.95 | 3.46 | 1300 | 91.7 |
| 14 | 13.15 | 3.63 | 1400 | 83.3 |
| 15 | 14.52 | 3.81 | 1500 | 73.0 |

RUN NO: LN-14



RUN NO: LN-14



INJECTABILITY TEST DATA

Run: LN-14 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 380 psig Run Press: 380 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 112°C
 Total Filtered Volume: 1610 ml Suspended Solids: 9.9 mg/l (9 μ g/g)


| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.08 | 0.28 | 100 | 1250.0 |
| 2 | 0.56 | 0.75 | 400 | 625.0 |
| 3 | 0.98 | 0.99 | 500 | 238.1 |
| 4 | 1.56 | 1.25 | 600 | 172.4 |
| 5 | 2.40 | 1.55 | 700 | 119.1 |
| 6 | 3.62 | 1.90 | 800 | 82.0 |
| 7 | 5.40 | 2.32 | 900 | 56.2 |
| 8 | 6.82 | 2.61 | 1000 | 70.4 |
| 9 | 8.36 | 2.89 | 1100 | 64.9 |
| 10 | 9.94 | 3.15 | 1200 | 63.3 |
| 11 | 11.58 | 3.40 | 1300 | 61.0 |
| 12 | 13.41 | 3.66 | 1400 | 54.6 |
| 13 | 14.60 | 3.82 | 1460 | 84.0 |

INJECTABILITY TEST DATA


Run: LN-15 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 400 psig Run Press: 400 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 115°C
 Total Filtered Volume: 1960 ml Suspended Solids: 8.0 mg/l (7.3 μ g/g)

| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|
| 1 | 0.09 | 0.3 | 100 | 1111.1 |
| 2 | 0.73 | 0.85 | 400 | 468.8 |
| 3 | 1.24 | 1.11 | 500 | 196.1 |
| 4 | 1.78 | 1.33 | 600 | 185.2 |
| 5 | 2.38 | 1.54 | 700 | 166.7 |
| 6 | 3.06 | 1.75 | 800 | 147.1 |
| 7 | 3.77 | 1.94 | 900 | 140.9 |
| 8 | 4.50 | 2.12 | 1000 | 137.0 |
| 9 | 5.38 | 2.32 | 1100 | 113.6 |
| 10 | 6.30 | 2.51 | 1200 | 108.7 |
| 11 | 7.35 | 2.71 | 1300 | 95.2 |
| 12 | 8.40 | 2.90 | 1400 | 95.2 |
| 13 | 9.58 | 3.10 | 1500 | 84.8 |
| 14 | 10.87 | 3.30 | 1600 | 77.5 |
| 15 | 12.32 | 3.51 | 1700 | 69.0 |
| 16 | 14.08 | 3.75 | 1800 | 56.8 |

RUN NO: LN-15



RUN NO: LIH-15



INJECTABILITY TEST DATA

Run: LN-16 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 400 psig Run Press: 400 psig Differential Press: <0.1 psig
 Source Temp: 130°C Run Temp: 130°C
 Total Filtered Volume: 28,310 ml Suspended Solids: 0.021 mg/l (0.019 μ g/g)

| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|
| 1 | 0.43 | 0.66 | 1000 | 2368.4 |
| 2 | 0.93 | 0.96 | 2000 | 2000.0 |
| 3 | 1.37 | 1.17 | 3000 | 2272.7 |
| 4 | 1.78 | 1.33 | 4000 | 2439.0 |
| 5 | 2.23 | 1.49 | 5000 | 2222.2 |
| 6 | 2.66 | 1.63 | 6000 | 2325.6 |
| 7 | 3.12 | 1.77 | 7000 | 2173.9 |
| 8 | 3.52 | 1.88 | 8000 | 2500.0 |
| 9 | 4.00 | 2.00 | 9000 | 2083.3 |
| 10 | 4.40 | 2.10 | 10000 | 2500.0 |
| 11 | 4.83 | 2.20 | 11000 | 2325.6 |
| 12 | 5.23 | 2.29 | 12000 | 2500.0 |
| 13 | 5.66 | 2.38 | 13000 | 2325.6 |
| 14 | 6.07 | 2.46 | 14000 | 2439.0 |
| 15 | 6.52 | 2.55 | 15000 | 2222.2 |
| 16 | 6.87 | 2.62 | 16000 | 2857.1 |
| 17 | 7.34 | 2.71 | 17000 | 2127.7 |
| 18 | 7.73 | 2.78 | 18000 | 2564.1 |
| 19 | 8.15 | 2.85 | 19000 | 2381.0 |
| 20 | 8.56 | 2.93 | 20000 | 2439.0 |
| 21 | 8.98 | 3.00 | 21000 | 2381.0 |
| 22 | 9.41 | 3.07 | 22000 | 2325.6 |
| 23 | 9.82 | 3.13 | 23000 | 2439.0 |
| 24 | 10.24 | 3.20 | 24000 | 2381.0 |
| 25 | 10.69 | 3.27 | 25000 | 2222.2 |
| 26 | 11.12 | 3.33 | 26000 | 2325.6 |
| 27 | 11.53 | 3.40 | 27000 | 2439.0 |
| 28 | 11.96 | 3.46 | 28000 | 2325.6 |

RUN NO: LN-16

FLOWRATE, MI/Min


1000

100


10

0 5000 10000 15000 20000 25000 30000

CUMULATIVE FLOW, MI



RUN NO: LN-16



54




INJECTABILITY TEST DATA


Run: MN-1 Membrane Filter: 0.4- μ m 1- μ m Cuno Prefilter: No
 Source Press: 800 psig Run Press: 800 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 112°C
 Total Filtered Volume: 2530 ml Suspended Solids: 13.5 mg/l (12.3 μ g/g)

| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|
| 1 | 0.74 | 0.86 | 100 | 135.1 |
| 2 | 1.42 | 1.19 | 200 | 147.1 |
| 3 | 2.14 | 1.46 | 300 | 138.9 |
| 4 | 2.81 | 1.68 | 400 | 149.3 |
| 5 | 3.45 | 1.86 | 500 | 156.3 |
| 6 | 4.21 | 2.05 | 600 | 131.6 |
| 7 | 4.71 | 2.17 | 700 | 200.0 |
| 8 | 5.47 | 2.34 | 800 | 131.6 |
| 9 | 6.20 | 2.49 | 900 | 137.0 |
| 10 | 6.88 | 2.62 | 1000 | 147.1 |
| 11 | 7.62 | 2.76 | 1100 | 135.1 |
| 12 | 8.32 | 2.88 | 1200 | 142.9 |
| 13 | 9.13 | 3.02 | 1300 | 123.5 |
| 14 | 10.04 | 3.17 | 1400 | 109.9 |
| 15 | 10.90 | 3.30 | 1500 | 116.3 |
| 16 | 11.78 | 3.43 | 1600 | 113.6 |
| 17 | 12.66 | 3.56 | 1700 | 113.6 |
| 18 | 13.64 | 3.69 | 1800 | 102.0 |
| 19 | 14.61 | 3.82 | 1900 | 103.1 |
| 20 | 15.53 | 3.94 | 2000 | 108.7 |
| 21 | 16.43 | 4.05 | 2100 | 111.1 |
| 22 | 17.57 | 4.19 | 2200 | 87.7 |
| 23 | 18.80 | 4.34 | 2300 | 81.3 |
| 24 | 20.00 | 4.47 | 2400 | 83.3 |

RUN NO: MN-1



RUN NO: M1-1




INJECTABILITY TEST DATA

Run: MN-2 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 800 psig Run Press: 800 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 120°C
 Total Filtered Volume: 3340 ml Suspended Solids: 11.8 mg/l (10.7 μ g/g)


| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|
| 1 | 0.06 | 0.24 | 100 | 1666.7 |
| 2 | 0.33 | 0.57 | 400 | 1111.1 |
| 3 | 0.56 | 0.75 | 500 | 434.8 |
| 4 | 0.80 | 0.89 | 600 | 416.7 |
| 5 | 1.15 | 1.07 | 700 | 285.7 |
| 6 | 1.53 | 1.24 | 800 | 263.2 |
| 7 | 1.93 | 1.39 | 900 | 250.0 |
| 8 | 2.33 | 1.53 | 1000 | 250.0 |
| 9 | 2.79 | 1.67 | 1100 | 217.4 |
| 10 | 3.29 | 1.81 | 1200 | 200.0 |
| 11 | 3.84 | 1.96 | 1300 | 181.8 |
| 12 | 4.40 | 2.10 | 1400 | 178.6 |
| 13 | 4.95 | 2.22 | 1500 | 181.8 |
| 14 | 5.64 | 2.37 | 1600 | 144.9 |
| 15 | 6.31 | 2.51 | 1700 | 149.3 |
| 16 | 7.00 | 2.65 | 1800 | 144.9 |
| 17 | 7.73 | 2.78 | 1900 | 137.0 |
| 18 | 8.52 | 2.92 | 2000 | 126.6 |
| 19 | 9.27 | 3.04 | 2100 | 133.3 |
| 20 | 10.10 | 3.18 | 2200 | 120.5 |
| 21 | 10.99 | 3.32 | 2300 | 112.4 |
| 22 | 11.93 | 3.45 | 2400 | 106.4 |
| 23 | 12.85 | 3.58 | 2500 | 108.7 |
| 24 | 13.88 | 3.73 | 2600 | 97.1 |
| 25 | 14.88 | 3.86 | 2700 | 100.0 |
| 26 | 16.00 | 4.00 | 2800 | 89.3 |
| 27 | 17.06 | 4.13 | 2900 | 94.3 |
| 28 | 18.18 | 4.26 | 3000 | 89.3 |
| 29 | 19.33 | 4.40 | 3100 | 87.0 |
| 30 | 20.55 | 4.53 | 3200 | 82.0 |

RUN NO: MN-2

59



RUN NO: MN-2



09


INJECTABILITY TEST DATA

Run: MN-3 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: Yes
 Source Press: 750 psig Run Press: 750 psig Differential Press: <0.1 psig
 Source Temp: 130°C Run Temp: 129°C
 Total Filtered Volume: 36,000 ml Suspended Solids: 0.031 mg/l (0.028 μ g/g)


| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.08 | 0.28 | 100 | 1250.0 |
| 2 | 0.80 | 0.89 | 2000 | 2435.9 |
| 3 | 1.17 | 1.08 | 3000 | 2702.7 |
| 4 | 1.60 | 1.26 | 4000 | 2325.6 |
| 5 | 1.87 | 1.37 | 5000 | 3703.7 |
| 6 | 2.40 | 1.55 | 6000 | 1886.8 |
| 7 | 2.70 | 1.64 | 7000 | 3333.3 |
| 8 | 3.23 | 1.80 | 8000 | 1886.8 |
| 9 | 3.52 | 1.88 | 9000 | 3448.3 |
| 10 | 4.00 | 2.00 | 10000 | 2083.3 |
| 11 | 4.29 | 2.07 | 11000 | 3448.3 |
| 12 | 4.79 | 2.19 | 12000 | 2000.0 |
| 13 | 5.07 | 2.25 | 13000 | 3571.4 |
| 14 | 5.60 | 2.37 | 14000 | 1886.8 |
| 15 | 5.99 | 2.45 | 15000 | 2564.1 |
| 16 | 6.49 | 2.55 | 16000 | 2000.0 |
| 17 | 6.79 | 2.61 | 17000 | 3333.3 |
| 18 | 7.33 | 2.71 | 18000 | 1851.9 |
| 19 | 7.70 | 2.77 | 19000 | 2702.7 |
| 20 | 8.19 | 2.86 | 20000 | 2040.8 |
| 21 | 8.53 | 2.92 | 21000 | 2941.2 |
| 22 | 9.05 | 3.01 | 22000 | 1923.1 |
| 23 | 9.43 | 3.07 | 23000 | 2631.6 |
| 24 | 9.91 | 3.15 | 24000 | 2083.3 |
| 25 | 10.28 | 3.21 | 25000 | 2702.7 |
| 26 | 10.78 | 3.28 | 26000 | 2000.0 |
| 27 | 11.17 | 3.34 | 27000 | 2564.1 |
| 28 | 11.64 | 3.41 | 28000 | 2127.7 |
| 29 | 11.99 | 3.46 | 29000 | 2857.1 |
| 30 | 12.51 | 3.54 | 30000 | 1923.1 |
| 31 | 12.87 | 3.59 | 31000 | 2777.8 |
| 32 | 13.35 | 3.65 | 32000 | 2083.3 |
| 33 | 13.73 | 3.71 | 33000 | 2631.6 |
| 34 | 14.22 | 3.77 | 34000 | 2040.8 |
| 35 | 14.60 | 3.82 | 35000 | 2631.6 |
| 36 | 14.90 | 3.86 | 36000 | 3333.3 |

RUN NO: MN-3

62



RUN NO: MII-3




INJECTABILITY TEST DATA


Run: HN-1 Membrane Filter: 0.4- μ m 1- μ m Cuno Prefilter: No
 Source Press: 3800 psig Run Press: 400 psig Differential Press: 50 psig
 Source Temp: 130°C Run Temp: 120°C
 Total Filtered Volume: 2630 ml Suspended Solids: 1.4 mg/l (1.3 μ g/g)

| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|
| 1 | 0.15 | 0.39 | 100 | 666.7 |
| 2 | 1.60 | 1.26 | 400 | 666.7 |
| 3 | 1.99 | 1.41 | 500 | 256.5 |
| 4 | 2.48 | 1.57 | 600 | 204.1 |
| 5 | 3.02 | 1.74 | 700 | 185.2 |
| 6 | 3.63 | 1.91 | 800 | 163.9 |
| 7 | 4.27 | 2.07 | 900 | 156.3 |
| 8 | 4.94 | 2.22 | 1000 | 149.3 |
| 9 | 5.60 | 2.37 | 1100 | 151.5 |
| 10 | 6.35 | 2.52 | 1200 | 133.3 |
| 11 | 7.15 | 2.67 | 1300 | 125.0 |
| 12 | 7.85 | 2.80 | 1400 | 142.9 |
| 13 | 8.70 | 2.95 | 1500 | 117.7 |
| 14 | 9.19 | 3.03 | 1600 | 204.1 |
| 15 | 9.64 | 3.10 | 1700 | 222.2 |
| 16 | 10.16 | 3.19 | 1800 | 192.3 |
| 17 | 10.65 | 3.26 | 1900 | 204.1 |
| 18 | 11.27 | 3.36 | 2000 | 161.3 |
| 19 | 11.57 | 3.40 | 2100 | 333.3 |
| 20 | 12.08 | 3.48 | 2200 | 196.1 |
| 21 | 12.67 | 3.56 | 2300 | 169.5 |
| 22 | 13.59 | 3.69 | 2400 | 108.7 |
| 23 | 14.78 | 3.84 | 2500 | 84.0 |
| 24 | 15.70 | 3.96 | 2600 | 108.7 |

RUN NO: HN-1



RUN NO: HN-1




INJECTABILITY TEST DATA

Run: HN-2 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 3800 psig Run Press: 400 psig Differential Press: 5 psig
 Source Temp: 130°C Run Temp: 128°C
 Total Filtered Volume: 19,300 ml Suspended Solids: 0.067 mg/l (0.061 μ g/g)


| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|
| 1 | .30 | 0.55 | 400 | 1333.3 |
| 2 | .60 | 0.77 | 1000 | 2000.0 |
| 3 | 1.09 | 1.04 | 1500 | 1282.1 |
| 4 | 1.47 | 1.21 | 2000 | 1315.8 |
| 5 | 2.50 | 1.58 | 3000 | 970.9 |
| 6 | 3.68 | 1.92 | 4000 | 847.5 |
| 7 | 5.00 | 2.24 | 5000 | 757.6 |
| 8 | 6.17 | 2.48 | 6000 | 854.7 |
| 9 | 7.58 | 2.75 | 8000 | 1418.4 |
| 10 | 9.00 | 3.00 | 10000 | 1408.5 |
| 11 | 9.72 | 3.12 | 11000 | 1388.9 |
| 12 | 10.45 | 3.23 | 12000 | 1369.9 |
| 13 | 11.84 | 3.44 | 14000 | 1438.9 |
| 14 | 13.37 | 3.66 | 16000 | 1307.2 |

RUN NO: HN-2



RUN NO: HN-2

69




INJECTABILITY TEST DATA

Run: HN-3 Membrane Filter: 0.4- μ m 1- μ m Cuno Prefilter: No
 Source Press: 3800 psig Run Press: 1000 psig Differential Press: 70 psig
 Source Temp: 130°C Run Temp: 119°C
 Total Filtered Volume: 4320 ml Suspended Solids: 0.69 mg/l (0.63 μ g/g)


| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.16 | 0.40 | 100 | 625.0 |
| 2 | 0.42 | 0.65 | 200 | 384.6 |
| 3 | 0.65 | 0.81 | 300 | 434.8 |
| 4 | 0.95 | 0.97 | 400 | 333.3 |
| 5 | 1.26 | 1.12 | 500 | 322.6 |
| 6 | 1.55 | 1.24 | 600 | 344.8 |
| 7 | 1.84 | 1.36 | 700 | 344.8 |
| 8 | 2.15 | 1.47 | 800 | 322.6 |
| 9 | 2.50 | 1.58 | 900 | 285.7 |
| 10 | 2.86 | 1.69 | 1000 | 277.8 |
| 11 | 3.19 | 1.79 | 1100 | 303.0 |
| 12 | 3.51 | 1.87 | 1200 | 312.5 |
| 13 | 3.86 | 1.96 | 1300 | 285.7 |
| 14 | 4.21 | 2.05 | 1400 | 285.7 |
| 15 | 4.53 | 2.13 | 1500 | 312.5 |
| 16 | 4.89 | 2.21 | 1600 | 277.8 |
| 17 | 5.24 | 2.29 | 1700 | 285.7 |
| 18 | 5.57 | 2.36 | 1800 | 303.0 |
| 19 | 5.96 | 2.44 | 1900 | 256.4 |
| 20 | 6.30 | 2.51 | 2000 | 294.1 |
| 21 | 6.68 | 2.58 | 21000 | 263.2 |

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 22 | 7.02 | 2.65 | 2200 | 294.1 |
| 23 | 7.35 | 2.71 | 2300 | 303.0 |
| 24 | 7.70 | 2.77 | 2400 | 285.7 |
| 25 | 8.08 | 2.84 | 2500 | 263.2 |
| 26 | 8.45 | 2.91 | 2600 | 270.3 |
| 27 | 8.79 | 2.96 | 2700 | 294.1 |
| 28 | 9.15 | 3.02 | 2800 | 277.8 |
| 29 | 9.49 | 3.08 | 2900 | 294.1 |
| 30 | 9.86 | 3.14 | 3000 | 270.3 |
| 31 | 10.21 | 3.20 | 3100 | 285.7 |
| 32 | 10.57 | 3.25 | 3200 | 277.8 |
| 33 | 10.97 | 3.31 | 3300 | 250.0 |
| 34 | 11.32 | 3.36 | 3400 | 285.7 |
| 35 | 11.72 | 3.42 | 3500 | 250.0 |
| 36 | 12.09 | 3.48 | 3600 | 270.3 |
| 37 | 12.52 | 3.54 | 3700 | 232.6 |
| 38 | 12.92 | 3.59 | 3800 | 250.0 |
| 39 | 13.44 | 3.67 | 3900 | 192.3 |
| 40 | 13.95 | 3.73 | 4000 | 196.1 |
| 41 | 14.47 | 3.80 | 4100 | 192.3 |
| 42 | 15.00 | 3.87 | 4200 | 188.7 |

RUN NO: HN-3



RUN NO: HN-3




72

INJECTABILITY TEST DATA


Run: HN-4 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press:3800 psig Run Press:1000 psig Differential Press:0.1 psig
 Source Temp:130°C Run Temp:130°C
 Total Filtered Volume:13,540 ml Suspended Solids: 0.27 mg/l (0.25 μ g/g)

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.09 | 0.30 | 100 | 1111.1 |
| 2 | 1.33 | 1.15 | 2000 | 1532.3 |
| 3 | 1.71 | 1.31 | 3000 | 2631.6 |
| 4 | 2.18 | 1.48 | 4000 | 2127.7 |
| 5 | 2.61 | 1.62 | 5000 | 2325.6 |
| 6 | 3.10 | 1.76 | 6000 | 2040.8 |
| 7 | 3.50 | 1.87 | 7000 | 2500.0 |
| 8 | 3.95 | 1.99 | 8000 | 2222.2 |
| 9 | 4.44 | 2.11 | 9000 | 2040.8 |
| 10 | 4.90 | 2.21 | 10000 | 2173.9 |
| 11 | 5.34 | 2.31 | 11000 | 2272.7 |
| 12 | 5.80 | 2.41 | 12000 | 2173.9 |
| 13 | 6.27 | 2.50 | 13000 | 2127.7 |
| 14 | 6.77 | 2.60 | 14000 | 2000.0 |
| 15 | 7.23 | 2.69 | 15000 | 2173.9 |
| 16 | 7.70 | 2.77 | 16000 | 2127.7 |
| 17 | 8.42 | 2.90 | 17000 | 1388.9 |
| 18 | 9.42 | 3.07 | 17500 | 500.0 |
| 19 | 11.28 | 3.36 | 18000 | 268.8 |
| 20 | 12.08 | 3.48 | 18200 | 250.0 |
| 21 | 13.84 | 3.72 | 18400 | 113.6 |

RUN NO: HN-4



RUN NO: HN-4




INJECTABILITY TEST DATA


Run: HN-5 Membrane Filter: 0.4- μ m 1- μ m Cuno Prefilter: No
 Source Press:3800 psig Run Press:1800 psig Differential Press:50 psig
 Source Temp:130°C Run Temp:120°C
 Total Filtered Volume:4620 ml Suspended Solids: 1.3 mg/l (1.2 μ g/g)

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.10 | 0.32 | 100 | 1000.0 |
| 2 | 0.79 | 0.89 | 600 | 724.6 |
| 3 | 0.98 | 0.99 | 700 | 555.6 |
| 4 | 1.37 | 1.17 | 800 | 256.4 |
| 5 | 1.58 | 1.26 | 900 | 476.2 |
| 6 | 1.98 | 1.41 | 1100 | 500.0 |
| 7 | 2.23 | 1.49 | 1200 | 400.0 |
| 8 | 2.53 | 1.59 | 1300 | 333.3 |
| 9 | 3.25 | 1.80 | 1700 | 555.6 |
| 10 | 3.62 | 1.90 | 1900 | 540.5 |
| 11 | 3.85 | 1.96 | 2000 | 434.8 |
| 12 | 4.10 | 2.02 | 2100 | 400.0 |
| 13 | 4.55 | 2.13 | 2200 | 222.2 |
| 14 | 4.91 | 2.22 | 2300 | 277.8 |
| 15 | 5.30 | 2.30 | 2400 | 256.4 |
| 16 | 5.68 | 2.38 | 2500 | 263.2 |
| 17 | 9.07 | 3.01 | 3100 | 177.0 |
| 18 | 9.50 | 3.08 | 3200 | 232.6 |
| 19 | 10.00 | 3.16 | 3300 | 200.0 |
| 20 | 10.50 | 3.24 | 3400 | 200.0 |
| 21 | 10.90 | 3.30 | 3500 | 250.0 |
| 22 | 11.40 | 3.38 | 3600 | 200.0 |
| 23 | 11.93 | 3.45 | 3700 | 188.7 |
| 24 | 12.43 | 3.53 | 3800 | 200.0 |
| 25 | 12.96 | 3.60 | 3900 | 188.7 |
| 26 | 13.39 | 3.66 | 4000 | 232.6 |
| 27 | 13.81 | 3.72 | 4100 | 238.1 |
| 28 | 14.25 | 3.77 | 4200 | 227.3 |
| 29 | 14.70 | 3.83 | 4300 | 222.2 |
| 30 | 15.37 | 3.92 | 4400 | 149.3 |
| 31 | 16.03 | 4.00 | 4500 | 151.5 |
| 32 | 16.35 | 4.04 | 4600 | 312.5 |

RUN NO: HN-5



RUN NO: HN-5




78

INJECTABILITY TEST DATA

Run: HN-6 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 3800 psig Run Press: 1800 psig Differential Press: 1 psig
 Source Temp: 130°C Run Temp: 123°C
 Total Filtered Volume: 5360 ml Suspended Solids: 1.3 mg/l (1.2 μ g/g)


| ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) | ITEM | Time(min) | $\sqrt{\text{Min}}$ | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|---------------------|-----------------------|--------------------|------|-----------|---------------------|-----------------------|--------------------|
| 1 | 0.11 | 0.33 | 100 | 909.1 | 21 | 3.93 | 1.98 | 2100 | 400.0 |
| 2 | 0.34 | 0.58 | 200 | 434.8 | 22 | 4.21 | 2.05 | 2200 | 357.1 |
| 3 | 0.57 | 0.75 | 300 | 434.8 | 23 | 4.38 | 2.09 | 2300 | 588.2 |
| 4 | 0.77 | 0.88 | 400 | 500.0 | 24 | 4.61 | 2.15 | 2400 | 434.8 |
| 5 | 1.00 | 1.00 | 500 | 434.8 | 25 | 4.84 | 2.20 | 2500 | 434.8 |
| 6 | 1.20 | 1.10 | 600 | 500.0 | 26 | 5.04 | 2.24 | 2600 | 500.0 |
| 7 | 1.44 | 1.20 | 700 | 416.7 | 27 | 5.39 | 2.32 | 2800 | 571.4 |
| 8 | 1.64 | 1.28 | 800 | 500.0 | 28 | 5.87 | 2.42 | 3000 | 416.7 |
| 9 | 1.81 | 1.35 | 900 | 588.2 | 29 | 6.26 | 2.50 | 3200 | 512.8 |
| 10 | 1.99 | 1.41 | 1000 | 555.6 | 30 | 6.79 | 2.61 | 3400 | 377.4 |
| 11 | 2.16 | 1.47 | 1100 | 588.2 | 31 | 7.26 | 2.69 | 3600 | 425.5 |
| 12 | 2.40 | 1.55 | 1200 | 416.7 | 32 | 7.74 | 2.78 | 3800 | 416.7 |
| 13 | 2.51 | 1.58 | 1300 | 909.1 | 33 | 8.25 | 2.87 | 4000 | 392.2 |
| 14 | 2.66 | 1.63 | 1400 | 666.7 | 34 | 8.83 | 2.97 | 4200 | 344.8 |
| 15 | 2.84 | 1.69 | 1500 | 555.6 | 35 | 9.40 | 3.07 | 4400 | 350.9 |
| 16 | 2.97 | 1.72 | 1600 | 769.2 | 36 | 9.90 | 3.15 | 4600 | 400.0 |
| 17 | 3.16 | 1.78 | 1700 | 526.3 | 37 | 10.44 | 3.23 | 4800 | 370.4 |
| 18 | 3.31 | 1.82 | 1800 | 666.7 | 38 | 11.63 | 3.41 | 5000 | 168.1 |
| 19 | 3.48 | 1.87 | 1900 | 588.2 | 39 | 12.60 | 3.55 | 5100 | 103.1 |
| 20 | 3.68 | 1.92 | 2000 | 500.0 | 40 | 13.52 | 3.68 | 5200 | 108.7 |

RUN NO: HN-6



RUN NO: 44-8

CUMULATIVE FLOW, MI




INJECTABILITY TEST DATA

Run: HN-7 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press:3800 psig Run Press:1500 psig Differential Press:20 psig
 Source Temp:130°C Run Temp:125°C
 Total Filtered Volume:10,110 ml Suspended Solids: 0.41 mg/l (0.37 μ g/g)


| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.08 | 0.28 | 100 | 1250.0 |
| 2 | 0.87 | 0.93 | 2000 | 2405.1 |
| 3 | 2.02 | 1.42 | 4000 | 1739.1 |
| 4 | 2.69 | 1.64 | 5000 | 1492.5 |
| 5 | 4.20 | 2.05 | 6000 | 662.3 |
| 6 | 5.48 | 2.34 | 7400 | 1093.8 |
| 7 | 6.29 | 2.51 | 7600 | 246.9 |
| 8 | 7.27 | 2.70 | 7800 | 204.1 |
| 9 | 8.23 | 2.87 | 8000 | 208.3 |
| 10 | 9.54 | 3.09 | 8200 | 152.7 |
| 11 | 11.00 | 3.32 | 8400 | 137.0 |
| 12 | 12.77 | 3.57 | 8600 | 113.0 |
| 13 | 13.16 | 3.63 | 8800 | 512.8 |
| 14 | 13.60 | 3.69 | 9200 | 909.1 |
| 15 | 14.17 | 3.76 | 9400 | 350.9 |
| 16 | 15.43 | 3.93 | 9600 | 158.7 |

RUN NO: HN-7



RUN NO. 117

CUMULATIVE FLOW, MI




INJECTABILITY TEST DATA


Run: HN-8 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 3800 psig Run Press: 1000 psig Differential Press: <0.1 psig
 Source Temp: 130°C Run Temp: 129°C
 Total Filtered Volume: 31,000 ml Suspended Solids: 0.026 mg/l (0.024 μ g/g)

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 1.39 | 1.18 | 2000 | 1596.6 |
| 2 | 1.90 | 1.38 | 3000 | 1960.8 |
| 3 | 2.40 | 1.55 | 4000 | 2000.0 |
| 4 | 2.85 | 1.69 | 5000 | 2222.2 |
| 5 | 3.36 | 1.83 | 6000 | 1960.8 |
| 6 | 3.87 | 1.97 | 7000 | 1960.8 |
| 7 | 4.34 | 2.08 | 8000 | 2127.7 |
| 8 | 4.80 | 2.19 | 9000 | 2173.9 |
| 9 | 5.33 | 2.31 | 10000 | 1886.8 |
| 10 | 5.78 | 2.40 | 11000 | 2222.2 |
| 11 | 6.27 | 2.50 | 12000 | 2040.8 |
| 12 | 6.76 | 2.60 | 13000 | 2040.8 |
| 13 | 7.26 | 2.69 | 14000 | 2000.0 |
| 14 | 7.70 | 2.77 | 15000 | 2272.7 |
| 15 | 8.19 | 2.86 | 16000 | 2040.8 |
| 16 | 8.66 | 2.94 | 17000 | 2127.7 |
| 17 | 9.25 | 3.04 | 18000 | 1694.9 |
| 18 | 9.60 | 3.10 | 19000 | 2857.1 |
| 19 | 10.13 | 3.18 | 20000 | 1886.8 |
| 20 | 10.56 | 3.25 | 21000 | 2325.6 |
| 21 | 11.05 | 3.32 | 22000 | 2040.8 |
| 22 | 11.49 | 3.39 | 23000 | 2272.7 |
| 23 | 11.98 | 3.46 | 24000 | 2040.8 |
| 24 | 12.43 | 3.53 | 25000 | 2222.2 |
| 25 | 12.92 | 3.59 | 26000 | 2040.8 |
| 26 | 13.35 | 3.65 | 27000 | 2325.6 |
| 27 | 13.82 | 3.72 | 28000 | 2127.7 |
| 28 | 14.29 | 3.78 | 29000 | 2127.7 |
| 29 | 14.73 | 3.84 | 30000 | 2272.7 |
| 30 | 15.16 | 3.89 | 31000 | 2325.6 |

RUN NO: HN-8



FILTRATION CURVE WITHOUT INVASION



INJECTABILITY TEST DATA

Run: HN-9 Membrane Filter: 10.0- μ m 1- μ m Cuno Prefilter: No
 Source Press: 3800 psig Run Press: 1000 psig Differential Press: 1 psig
 Source Temp: 130°C Run Temp: 127°C
 Total Filtered Volume: 5850 ml Suspended Solids: 0.48 mg/l (0.44 μ g/g)

| ITEM | Time(min) | \sqrt{V} Min | Cumulative Volume(ml) | Flow Rate (ml/min) |
|------|-----------|----------------|-----------------------|--------------------|
| 1 | 0.06 | 0.24 | 100 | 1666.7 |
| 2 | 0.72 | 0.85 | 1000 | 1363.6 |
| 3 | 1.39 | 1.18 | 2000 | 1492.5 |
| 4 | 2.11 | 1.45 | 3000 | 1388.9 |
| 5 | 2.80 | 1.67 | 4000 | 1449.3 |
| 6 | 3.65 | 1.91 | 4800 | 941.2 |
| 7 | 4.72 | 2.17 | 5000 | 186.9 |
| 8 | 5.31 | 2.30 | 5100 | 169.5 |
| 9 | 7.12 | 2.67 | 5200 | 55.3 |
| 10 | 8.24 | 2.87 | 5300 | 89.3 |
| 11 | 10.00 | 3.16 | 5400 | 56.8 |
| 12 | 12.62 | 3.55 | 5500 | 38.2 |
| 13 | 13.73 | 3.71 | 5600 | 90.1 |
| 14 | 15.17 | 3.89 | 5700 | 69.4 |

RUN NO: 111-3


FLOWRATE, ml/min

10000

1000


100

10



0 1000 2000 3000 4000 5000 6000

CUMULATIVE FLOW, ml



DISCLAIMER

This document was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor the University of California nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial products, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government thereof, and shall not be used for advertising or product endorsement purposes.

DO NOT MICROFILM COVER

Printed in the United States of America
Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road
Springfield, VA 22161
Price: Printed Copy \$: Microfiche \$3.50

| <u>Page Range</u> | <u>Domestic Price</u> | <u>Page Range</u> | <u>Domestic Price</u> |
|-------------------|-----------------------|---------------------|-----------------------|
| 001-025 | \$ 5.00 | 326-350 | \$ 18.00 |
| 026-050 | 6.00 | 351-375 | 19.00 |
| 051-075 | 7.00 | 376-400 | 20.00 |
| 076-100 | 8.00 | 401-425 | 21.00 |
| 101-125 | 9.00 | 426-450 | 22.00 |
| 126-150 | 10.00 | 451-475 | 23.00 |
| 151-175 | 11.00 | 476-500 | 24.00 |
| 176-200 | 12.00 | 501-525 | 25.00 |
| 201-225 | 13.00 | 526-550 | 26.00 |
| 226-250 | 14.00 | 551-525 | 27.00 |
| 251-275 | 15.00 | 526-550 | 28.00 |
| 276-300 | 16.00 | 601-up ¹ | |
| 301-325 | 17.00 | | |

¹ Add 2.00 for each additional 25 page increment from 601 pages up.

Technical Information Department · Lawrence Livermore Laboratory
University of California · Livermore, California 94550

**DO NOT MICROFILM
COVER**

