

Economics of Four FGD Systems

EPRI

Keywords:

Economics Evaluations
SO₂ Scrubbers
Desulfurization
Limestone
Flue Gas Desulfurization
Cost Studies

EPRI CS-1677
Project 1180-3
Final Report
January 1981

Prepared by
Stearns-Roger Engineering Corporation
Denver, Colorado

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ELECTRIC POWER RESEARCH INSTITUTE

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Economics of Four FGD Systems

CS-1677
Research Project 1180-3

Final Report, January 1981
Work Completed, August 1980

Prepared by

STEARNS-ROGER ENGINEERING CORPORATION
4500 Cherry Creek Drive
P.O. Box 5888
Denver, Colorado 80217

Project Manager
R. W. Scheck

Project Engineer
D. G. Nold

Principal Investigators
F. Augustine
S. D. Severson
J. L. Winter

Prepared for

Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, California 94304

EPRI Project Managers
T. M. Morasky
S. M. Dalton

Desulfurization Processes Program
Coal Combustion Systems Division

ORDERING INFORMATION

Requests for copies of this report should be directed to Research Reports Center (RRC), Box 50490, Palo Alto, CA 94303, (415) 965-4081. There is no charge for reports requested by EPRI member utilities and affiliates, contributing nonmembers, U.S. utility associations, U.S. government agencies (federal, state, and local), media, and foreign organizations with which EPRI has an information exchange agreement. On request, RRC will send a catalog of EPRI reports.

~~Copyright © 1981 Electric Power Research Institute, Inc.~~

EPRI authorizes the reproduction and distribution of all or any portion of this report and the preparation of any derivative work based on this report, in each case on the condition that any such reproduction, distribution, and preparation shall acknowledge this report and EPRI as the source.

NOTICE

This report was prepared by the organization(s) named below as an account of work sponsored by the Electric Power Research Institute, Inc. (EPRI). Neither EPRI, members of EPRI, the organization(s) named below, nor any person acting on their behalf: (a) makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or (b) assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this report.

Prepared by
Stearns-Roger Engineering Corporation
Denver, Colorado

ABSTRACT

The Electric Power Research Institute contracted with Stearns-Roger Engineering Corporation to prepare an assessment of the economics of four flue gas desulfurization (FGD) systems: a conventional limestone scrubber, a cocurrent limestone scrubber, a Chiyoda Thoroughbred 121 limestone scrubber, and a Wellman-Lord scrubber. This report presents and compares the economic evaluations of each of these systems.

Using the standardized evaluation premises, Stearns-Roger developed typical FGD systems for each of the four selected processes designed to meet the latest Federal New Source Performance Standards (NSPS) promulgated 6/11/79. EPRI's Economic Premises for Electric Power Generating Systems were used as the basis for the economic criteria. Technical and cost data were developed for the treatment of flue gases from large-scale utility boilers (500 MW) burning typical high sulfur coal (4%). These data were then evaluated to test cost sensitivities to changes in coal sulfur content and plant size.

Blank Page

EPRl PERSPECTIVE

PROJECT DESCRIPTION

This final report summarizes results of a study under RP1180-3 comparing the projected economics for flue gas desulfurization (FDG) processes. Three limestone throwaway systems and one SO₂ recovery system were chosen for evaluation:

- Conventional limestone with stabilized sludge by-product
- EPRI/Tennessee Valley Authority cocurrent limestone with stabilized sludge by-product
- Chiyoda Thoroughbred 121 limestone with gypsum by-product
- Wellman-Lord with acid by-product and with elemental sulfur by-product

The cocurrent and the Chiyoda scrubbing systems were selected for economic evaluation since these two systems were shown to be technically feasible under RP1033-1 and RP536-4, respectively. Specific innovations in the design of these two scrubbing systems indicate that the systems may be cheaper to build, operate, and maintain than a conventional limestone scrubbing process. We also evaluated a regenerable scrubbing system to determine how it would compare to the three limestone systems. The Wellman-Lord scrubbing system was selected since we regard this system as commercially available.

EPRl submitted report sections to the appropriate FGD suppliers. They were requested to provide their comments on the report. Vendor comments are incorporated as received.

Previous FGD evaluations are described in EPRl Final Reports FP-272, AF-342, CS-1428, and CS-1381. Each of the four processes evaluated in this report was described in one or more of the earlier reports. In addition, TVA has also evaluated many FGD processes for the U.S. Environmental Protection Agency.

PROJECT OBJECTIVE

The objective was to evaluate the economics of four FGD scrubbing systems (three limestone throwaway processes and one sulfur recovery process) using a uniform design approach and uniform economic criteria so that results can be compared on a common basis.

PROJECT RESULTS

As in other EPRI studies, limestone-based nonregenerable processes exhibited lower capital and levelized revenue requirements compared to the regenerable process. The busbar costs presented are broken out into three cost elements: variable operating costs, fixed operating costs, and total capital requirement. For each process these major elements are further broken down so that the reader can identify what minor cost elements contribute to the total cost. For instance, this report indicates that the reason the variable costs for the Chiyoda are so low is that the cost for "raw materials" is significantly lower than the other limestone scrubbing systems evaluated.

The total capital requirements calculated for these four scrubbing systems using common site criteria and economic premises are as follows:

<u>Scrubbing System</u>	<u>Total Capital Requirement (per kW)</u>	<u>Levelized Busbar Cost (mills/kWh)</u>	
		<u>Without S Credit</u>	<u>With S Credit</u>
Conventional limestone	\$185	12.9	--
EPRI/TVA cocurrent	\$190	13.3	--
Chiyoda Thoroughbred 121	\$160	11.5	--
Wellman-Lord: (with acid plant)	\$265	19.3	15.7
(with sulfur plant)	\$245	20.3	19.0

These results should not be compared with other economic evaluations since these estimates are based on specific assumptions, site criteria, and economic premises. It is not appropriate to generalize these estimates or assume they represent manufacturer's current site-specific selling prices. The generalized cost estimates presented in this report are of value to utility personnel who require comparative

estimates for research and development planning and/or FGD process screening. The report can also serve as a guide to utility engineers who want a format to follow when preparing economic evaluations of a number of FGD scrubbing systems for cross comparison.

EPRI intends to continually update and report FGD cost estimates on a regular basis as technologies and conditions change.

Thomas M. Morasky, Project Manager
Coal Combustion Systems Division

Blank Page

ACKNOWLEDGMENTS

The assistance of several additional individuals was necessary to the preparation of this study. The authors would like to thank Mr. Don Clasen and Mr. J. C. Gibson of Chiyoda International Corporation for providing information on the CT-121 Process; Mr. J. G. Cavanaugh of Davy-McKee International (formerly Davy Powergas) for providing information on the Wellman-Lord Process; and Mr. T. M. Morasky for providing information on the EPRI/TVA Cocurrent system. In addition, we wish to acknowledge the participation of K. S. Campbell, E. W. Stenby, D. M. Shattuck, J. B. Keller, P. A. Ireland, T. M. Beech, J. B. Reisdorf, A. J. Coffern, J. S. Burnham and R. M. Wainwright, all of Stearns-Roger.

Blank Page

CONTENTS

<u>Section</u>		<u>Page</u>
1.	SUMMARY	1-1
	1.A. FGD Systems Evaluated	1-1
	1.B. Process Design Criteria	1-1
	1.C. Economic Criteria	1-3
	1.D. Levelized Busbar Power Cost	1-6
	1.E. Cost Sensitivity	1-9
	1.F. Estimate Accuracy	1-9
2.	INTRODUCTION	2-1
3.	GENERAL CRITERIA	3-1
	3.A. Process Design Criteria	3-1
	3.B. Economic Design Criteria	3-8
4.	CONVENTIONAL LIMESTONE FGD SYSTEM	4-1
	4.A. System Description	4-1
	4.B. Technical Evaluation	4-9
	4.C. Economic Evaluation	4-10
5.	EPRI/TVA COCURRENT FGD SYSTEM	5-1
	5.A. System Description	5-1
	5.B. Technical Evaluation	5-9
	5.C. Economic Evaluation	5-10
6.	CHIYODA THOROUGHbred 121 FGD SYSTEM	6-1
	6.A. System Description	6-1
	6.B. Technical Evaluation	6-10
	6.C. Economic Evaluation	6-11
7.	WELLMAN-LORD FGD SYSTEM	7-1
	7.A. System Description	7-1
	7.B. Technical Evaluation	7-15
	7.C. Economic Evaluation	7-16
	APPENDIX A Conventional Limestone System Equipment List	A-1
	APPENDIX B EPRI/TVA Cocurrent System Equipment List	B-1
	APPENDIX C Chiyoda Thoroughbred 121 System Equipment List	C-1
	APPENDIX D Wellman-Lord System Equipment List	D-1
	APPENDIX E Economics of Auxiliary Steam from Coal-Fired Power Plants	E-1
	APPENDIX F Flue Gas Desulfurization Evaluation Standard	F-1
	APPENDIX G Comments Of Process Suppliers	G-1

Blank

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
1-1 Levelized Busbar Cost Breakdown	1-2
1-2 Total Capital Requirement Breakdown	1-5
1-3 Fixed Operating Cost Breakdown	1-7
1-4 Variable Operating Cost Breakdown	1-8
1-5 Cost Versus Sulfur Content Of Coal	1-10
1-6 Cost Versus Plant Size	1-11
4-1 Conventional Limestone FGD System Process Flow Diagram	4-3
4-2 Conventional Limestone System Process Flow Balance	4-4
4-3 Plot Plan of Conventional Limestone FGD System	4-8
4-4 Conventional Limestone System Cost Versus Sulfur Content Of Coal	4-15
4-5 Conventional Limestone System Cost Versus Plant Size	4-16
5-1 EPRI/TVA Cocurrent FGD System Process Flow Diagram	5-3
5-2 EPRI/TVA Cocurrent System Process Flow Balance	5-4
5-3 Plot Plan of EPRI/TVA Cocurrent FGD System	5-8
5-4 EPRI/TVA Cocurrent System Cost Versus Sulfur Content Of Coal	5-15
5-5 EPRI/TVA Cocurrent System Cost Sensitivity Plant Size	5-16
6-1 Chiyoda Thoroughbred 121 FGD System Process Flow Diagram	6-3
6-2 Chiyoda Thoroughbred 121 Process Flow Balance	6-4
6-3 Plot Plan of Chiyoda Thoroughbred 121 FGD System	6-9
6-4 Chiyoda Thoroughbred 121 System Cost Versus Coal Sulfur Content	6-16
6-5 Chiyoda Thoroughbred 121 System Cost Versus Plant Size	6-17
7-1A Wellman-Lord FGD System Process Flow Diagram, Part 1	7-4
7-2A Wellman-Lord System Process Flow Balance, Part 1	7-5
7-1B Wellman-Lord FGD System Process Flow Diagram, Part 2	7-6
7-2B Wellman-Lord Process Flow Balance, Part 2	7-7
7-3 Wellman-Lord System Sulfur & Sulfuric Acid Plants Process Flow Diagram	7-8

<u>Figure</u>	<u>Page</u>
7-4 Plot Plan of Wellman-Lord FGD System	7-13
7-5 Wellman-Lord System Cost Versus Sulfur Content Of Coal	7-23
7-6 Wellman-Lord System Cost Versus Plant Size	7-24
E-1 Cost Breakdown 30 Year Levelized Steam Costs	E-5
E-2 Levelized Busbar Cost vs. Process Duty	E-6
E-3 Levelized Busbar Cost vs. Process Steam Flow	E-7
E-4 Heat Balance No. 1	E-16
E-5 Heat Balance No. 2	E-17
E-6 Heat Balance No. 3	E-18
E-7 Heat Balance No. 4	E-19
E-8 Heat Balance No. 5	E-20
E-9 Percent Boiler Duty to Process vs. Process Steam Flow	E-21
E-10 Percent Boiler Duty to Process vs. Turbine Cycle Heat Rate	E-22
E-11 Process Steam Flow vs. Process Heat Duty	E-23

LIST OF TABLES

<u>Table</u>	<u>Page</u>
3-1 Coal Analyses	3-3
3-2 Boiler Performance Parameters	3-3
3-3 Flue Gas Characteristics	3-4
3-4 Sulfur Dioxide Data	3-5
3-5 Raw Materials Compositions	3-7
3-6 FGD System Capital Estimate Components	3-9
3-7 Items in Process Capital Estimate	3-9
3-8 Cost Areas for Process Capital Breakdown	3-10
3-9 Operating Cost Criteria	3-16
4-1 Conventional Limestone System Process Design Criteria	4-2
4-2 Conventional Limestone System Raw Material and Utility Consumption	4-9
4-3 Conventional Limestone System Total Capital Requirement	4-12
4-4 Conventional Limestone System Operating Costs	4-13
4-5 Conventional Limestone System Levelized Busbar Cost	4-14
5-1 EPRI/TVA Cocurrent System Process Design Criteria	5-2
5-2 EPRI/TVA Cocurrent FGD System Raw Material and Utility Consumption	5-9
5-3 EPRI/TVA Cocurrent System Total Capital Requirement	5-12
5-4 EPRI/TVA Cocurrent System Operating Costs	5-13
5-5 EPRI/TVA Cocurrent System Levelized Busbar Costs	5-14
6-1 Chiyoda Thoroughbred 121 System Process Design Criteria	6-2
6-2 Chiyoda Thoroughbred 121 System Raw Material and Utility Consumption	6-8
6-3 Chiyoda Thoroughbred 121 System Total Capital Requirement	6-13
6-4 Chiyoda Thoroughbred 121 System Operating Costs	6-14
6-5 Chiyoda Thoroughbred 121 System Levelized Busbar Cost	6-15

<u>Table</u>	<u>Page</u>
7-1 Wellman-Lord System Process Design Criteria	7-3
7-2 Wellman-Lord System Raw Material and Utility Consumption	7-14
7-3 Wellman-Lord System Total Capital Requirement	7-17
7-4A Wellman-Lord System Fixed Operating Costs	7-18
7-4B Wellman-Lord System Variable Operating Costs	7-19
7-5 Wellman-Lord System Levelized Busbar Cost	7-22
E-1 Average Present Worth of Steam	E-4
E-2 30-Year Life Levelized Steam Cost	E-4
E-3 Capital Cost Breakdown, Base Case	E-13

1. SUMMARY

Capital and operating costs for four Flue Gas Desulfurization (FGD) processes have been estimated based on a consistent scope of supply and process design, and economic criteria. Although absolute values evolving from this estimate are specific to the selected criteria, the relative magnitude of each provides a more general view of the comparative costs for the four systems. A summary of the estimated levelized busbar cost for the four processes is presented in Figure 1-1. These levelized busbar costs represent the increase in cost of power production resulting from the inclusion of the FGD System in the power plant. For comparison, the 30-year levelized cost of power production without FGD is on the order of 55 mills/kWh, and the FGD systems studied raised this cost to 65-75 mills/kWh.

1.A. FGD SYSTEMS EVALUATED

Three limestone throwaway FGD systems and one SO₂ recovery FGD system were chosen for evaluation, including the following:

- Conventional Limestone
- EPRI/TVA Cocurrent
- Chiyoda Thoroughbred 121
- Wellman-Lord

The scope for all four systems included everything from the I.D. Fan discharge to the ultimate disposal area for the throwaway systems or byproduct storage for the recovery system. A pro rata share of peripheral items was also included; roads, office buildings, control rooms, shops, laboratories, etc. The FGD System cost reflects all components necessary to build a "grassroots" facility including earthwork, concrete, piping, equipment, buildings and structures, electrical, painting, instruments and controls, insulation, direct field labor, and all indirect field costs.

1.B. PROCESS DESIGN CRITERIA

The economic evaluation was based on a new 500 MW (net) pulverized coal-fired unit. The coal supply was assumed to be a 4 percent sulfur Illinois coal.




FIGURE 1-1
LEVELIZED BUSBAR COST BREAKDOWN

Boiler heat input at maximum continuous rating (MCR) was $4,862 \times 10^6$ Btu/hr based on a net plant heat rate of 9724 Btu/kWh (10,260 kJ/kWh). The unit gross output of about 540 MW assumes FGD steam consumption for 50°F (125°C) scrubbed gas reheat. The boiler heat input, and consequently the flue gas flow and sulfur dioxide production, was adjusted for FGD processes, requiring process steam in addition to reheat to maintain a net generator output of 500 MW. The adjustment for the Wellman-Lord process resulted in a boiler heat input about 5 percent higher than the limestone systems.

Sulfur dioxide removal requirement was based on the latest Federal New Source Performance Standards promulgated 6/11/79, which states that 90 percent removal is required for solid fuels that have an uncontrolled sulfur emission of greater than or equal to 0.6 lb SO₂ per million Btu input. The removal efficiency must be based on a 30-day rolling average. For this evaluation, it was assumed that all sulfur present in the coal is converted to sulfur oxides in the flue gas. (A conservative assumption, since about 5-10% of the S is captured in the fly ash and bottom ash).

The plant was assumed to be located near Kenosha, Wisconsin, at an elevation of 600 feet above mean sea level. Plant design life is 30 years with a capacity factor of 70 percent. Particulate removal was assumed to be achieved prior to the FGD System. Waste disposal of "throwaway" sludges was assumed to require landfill impoundment of dewatered, blended sludge.

1.C. ECONOMIC CRITERIA

The economic development was based on EPRI's Economic Premises for Electric Power Generating Systems dated July 1978 and amended June 1979 (see Appendix F). These premises provide guidelines for the capital investment basis, the operating cost basis, the cost of capital and the busbar power cost.

1.C.1. CAPITAL INVESTMENT BASIS

The capital investment consists of the following components:

<u>Component</u>	<u>\$/Kw</u>
Process Capital	A
General Facilities	B
Engineering and Home Office Fees	C
Project Contingency	D

<u>Component</u>	<u>\$/Kw</u>
Process Contingency	E
Sales Tax	<u>F</u>
Total Plant Investment	TPI=A+B+C+D+E+F

<u>Component</u>	<u>\$/Kw</u>
Royalty Allowance	G
Preproduction Costs	H
Inventory Capital	I
Initial Catalyst and Chemicals	J
Allowance for Funds During Construction	K
Land	<u>X</u>
Total Capital Requirement	TCR=TPI+G+H+I+J+K+X

All capital costs were based on mid-1978 dollars and mid-1979 startup.

1.C.2 TOTAL CAPITAL REQUIREMENT


A summary of the Total Capital Requirement is presented in Figure 1-2. The cost components for the three limestone systems are approximately the same, however, greater contingencies were required for the EPRI/TVA Cocurrent System and the Chiyoda Thoroughbred 121 System due to their less advanced state of development compared to the Conventional Limestone System. The Wellman-Lord System costs are considerably greater as a result of the complexity of the SO₂ recovery process.

1.C.3. COST OF CAPITAL

The cost of capital was based on an assumed 6 percent/year inflation rate and certain economic assumptions listed in the General Criteria section. The 30-year levelized fixed charge rate (LFCR) calculated from those assumptions is 18 percent/year.

1.C.4. OPERATING COST BASIS

The operating costs were divided into fixed and variable costs. The fixed costs are essentially independent of capacity factor while the variable costs are directly proportional to the amount of power produced. The fixed operating costs include operating and maintenance labor, maintenance materials, and an overhead charge for administrative and support labor.



BASIS: NEW 500 MW COAL FIRED PLANT, MIDWEST LOCATION
 30 YEAR PLANT LIFE; PRICING LEVEL MID-1978 FOR MID 1979 STARTUP
 HIGH SULFUR COAL - 4.0% SULFUR (AVG)
 CAPACITY FACTOR 70%, 6132 HRS/YR
 SO₂ EMISSION PER PROMULGATED JUNE, 1979 NSPS

FIGURE 1-2

TOTAL CAPITAL REQUIREMENT BREAKDOWN

Variable operating costs include raw materials, power, steam, and items such as cooling water and methane, i.e. essentially all consumables.

1.C.5. FIXED OPERATING COST


A summary of the Fixed Operating Costs is presented in Figure 1-3. Maintenance labor and material are the primary components of the fixed operating costs. These components are determined as a percentage of the Process Capital and therefore the fixed operating costs tend to reflect the relative magnitude of the Process Capital estimates. Operating labor is also a rather large component and reflects the higher complexity of the Wellman-Lord System requiring increased operating cost.

1.C.6. VARIABLE OPERATING COST

A summary of the Variable Operating Costs is presented in Figure 1-4. The limestone systems have equivalent steam costs but vary relative to power and raw materials. The raw material costs vary primarily the same as the differences in limestone stoichiometric ratios. The limestone system power costs reflect differences in the major contributors to power consumption, the gas-side pressure drop, and liquid-to-gas ratio. The Wellman-Lord System has a considerably higher variable operating cost than any of the limestone systems. Although raw material costs are less, steam and power are greater, and the Wellman-Lord System requires the additional component of cooling water for the SO₂ condensers and, for the sulfur plant, methane. The considerable increase in steam cost is a direct result of the substantial steam requirement for thermal decomposition to release the SO₂ from the scrubbing liquor. The power cost reflects increased complexity and a relatively high gas-side pressure drop. The cost of methane imposes a severe penalty to the Wellman-Lord system with sulfur plant alternate. The cost of methane was chosen as \$4.00 per mscf for this study, assuming unavailability of natural gas and reflecting the cost of gas derived synthetically from other feedstocks.

1.D. LEVELIZED BUSBAR POWER COST

The levelized busbar power costs for each system were determined from the estimated capital and operating costs. All costs were converted to a levelized cost in terms of mills/kWh. Appropriate levelization factors were applied to the operating costs and the fixed charge rate of 18 percent/yr was applied to the capital costs.



BASIS: NEW 500 MW COAL FIRED PLANT, MIDWEST LOCATION
 30 YEAR PLANT LIFE; PRICING LEVEL MID-1978 FOR MID 1979 STARTUP
 HIGH SULFUR COAL - 4.0% SULFUR (AVG)
 CAPACITY FACTOR 70%, 6132 HRS/YR
 SO₂ EMISSION PER PROMULGATED JUNE, 1979 NSPS

FIGURE 1-3

FIXED OPERATING COST BREAKDOWN




FIGURE 1-4

VARIABLE OPERATING COST BREAKDOWN

1.E. COST SENSITIVITY

Cost sensitivity to percent-sulfur and plant size are presented in Figures 1-5 and 1-6 for the four processes. The Wellman-Lord process cost sensitivity curves do not include a byproduct credit.

1.F. ESTIMATE ACCURACY

The accuracy of the estimates differ for absolute costs versus relative costs. It is felt that the cost estimating techniques is sufficient to produce estimates with an absolute accuracy of ± 20 percent, however, the accuracy for relative comparison of the processes is thought to be more accurate, on the order of ± 10 percent.




FIGURE 1-5
COST VERSUS SULFUR CONTENT OF COAL




FIGURE 1-6

COST VERSUS PLANT SIZE

2. INTRODUCTION

Comparison of reported costs for FGD Systems is often difficult because of varying scope of supply, differences in process and/or economic criteria, and different estimate dates. To facilitate direct cost comparison of several FGD Systems, economic evaluations have been prepared for four processes using a common process approach and common economic criteria. Three limestone throwaway processes and one SO₂ recovery process were chosen. They are as follows:

- Conventional Limestone FGD System
- EPRI/TVA Cocurrent FGD System
- Chiyoda Thoroughbred 121 FGD System
- Wellman-Lord FGD System

Economic evaluations for each system were prepared for a new 500MW coal-fired power plant in the north central United States. The plant was assumed to fire an Illinois high sulfur coal and was required to meet the latest Federal New Source Performance Standards promulgated 6/11/79. EPRI's Economic Premises for Electric Power Generating Systems were used as the basis for the economic criteria.

3. GENERAL CRITERIA

This section documents the general criteria established to maintain consistency from case to case, and with other EPRI sponsored projects and criteria. General criteria, both process and economic, presented in this section are applicable to all processes evaluated. Criteria specific to each process are presented in the individual system sections. The items discussed in this section are as follows:

- Process Design Criteria
 - Generating Plant
 - Coal and Flue Gas
 - Sulfur Dioxide Removal Requirements
 - General Equipment
 - FGD System Battery Limits
 - Raw Materials
 - Waste Disposal
- Economic Design Criteria
 - Capital Estimate Summary
 - Total Plant Investment
 - Total Capital Requirement
 - Operating Cost Summary
 - Fixed Operating Costs
 - Variable Operating Costs
 - Levelized Busbar Cost

3.A. PROCESS DESIGN CRITERIA

3.A.1. GENERATING PLANT

The generating plant chosen for this study is a new 500 MW (net), 540 MW (gross) balanced draft, pulverized coal-fired, base loaded unit. Operating conditions for the boiler are assumed to be typical of modern units. Net plant heat rate was estimated to be 9724 Btu/kWh (10,260kJ/kWh). Boiler heat input at maximum load is 5105×10^6 Btu/hr (5386 GJ/h) (maximum load assumed to be 105 percent with turbine throttle Valves Wide Open - 105 percent, VW0)

and 4862×10^6 Btu/hr (5130 GJ/h) at Maximum Continuous Rating (MCR). Plant capacity factor is 70 percent based on average plant operation 80 percent of the time at 87.5 percent load.

The plant is assumed to be located near Kenosha, Wisconsin, at an elevation of 600 feet (180m) above sea level. Atmospheric pressure used for flue gas composition and volume determination is 14.4 psia (99kPa). An ambient temperature range of -10 to 95°F (250 to 380K) was assumed. Structural criteria were those for Seismic Zone 1 as defined by the Uniform Building Code. Plant design life was assumed to be 30 years.

The plant is equipped with a separate particulate removal device (electrostatic precipitator or fabric filter) prior to the FGD System. The particulate collection device is assumed to be designed to meet applicable Federal New Source Performance Standards of $0.03 \text{ lb}/10^6 \text{ Btu}$ ($0.01\text{kg}/\text{GJ}$). The cost of the particulate collection device is not included in the FGD System estimate.

3.A.2. COAL AND FLUE GAS

The coal used as a basis for the study is a deep-mined Illinois high sulfur bituminous coal. The analysis of this coal is presented in Table 3-1. The coal selected is consistent with one used in an earlier EPRI report, "Coal-Fired Power Plant Capital Cost Estimates", EPRI Report No. AF-342 (January 1977).

Boiler performance parameters used for the calculation of flue gas flow and composition are tabulated in Table 3-2.

Combustion calculations performed with the coal analyses from Table 3-1 and the combustion parameters from Table 3-2 resulted in the flue gas composition and flow rate in Table 3-3. The values in Table 3-3 represent plant operation at maximum load (105%, VW0). Some losses in boiler efficiency and variations to coal-firing rate and excess air occur at reduced load. The variations are small, however, and for use in this study, raw material and utility consumptions are based on full load flue gas conditions proportioned to 100 percent load. Annual totals are determined by applying the capacity factor (previously defined as 70 percent).

TABLE 3-1
COAL ANALYSES

Proximate Analysis, %	
Moisture	12.0
Ash	16.0
Fixed Carbon	39.0
Volatile Matter	33.0
Ultimate Analysis, %	
Moisture	12.0
Carbon	57.5
Hydrogen	3.7
Nitrogen	0.9
Chlorine	0.1
Sulfur	4.0
Ash	16.0
Oxygen	5.8
Btu/lb (KJ/kg)	10,100 (23,500)
Sulfur Content	3.96 lb S/10 ⁶ Btu (1.70kg S/GJ)

TABLE 3-2

BOILER PERFORMANCE PARAMETERS

Excess Air	
Furnace Outlet	22%
Economizer Outlet	24%
Air Heater Outlet	39%
Particulate Removal Device Outlet	40%
FGD System Battery Limit	40%
Ambient Air Humidity	0.013 lb H ₂ O/lb Dry Air (0.013 kg H ₂ O/kg)
FGD System Inlet Flue Gas Temperature	283 ^o F (413 K)
Total Coal Sulfur Converted to SO ₂ & SO ₃	100%
Total SO ₃ as % of SO ₂	1%
Total Coal Chlorine Converted to HCl	100%
Boiler Heat Input at Maximum Load	5105 x 10 ⁶ Btu/hr (5386 GJ/h)
Boiler Efficiency	88%
Net Plant Heat Rate (with Conventional Limestone FGD System)	9724 Btu/kWh (2850 KJ/MJ)

TABLE 3-3
FLUE GAS CHARACTERISTICS

	<u>%-Volume (Wet)</u>	<u>10³ lb-mole/hr</u>	<u>10³ lb/hr</u>
O ₂	5.6	11.4	365
CO ₂	11.9	24.3	1068
SO ₂	0.3	0.6	40
SO ₃	0.003	0.006	0.51
HCl	0.007	0.014	0.52
H ₂ O	8.1	16.6	300
N ₂	<u>74.1</u>	<u>151.8</u>	<u>4251</u>
TOTAL	100.0	204.8	6025
Molecular Weight		29.42	
Moisture Content lb/lb dry gas		0.052	
Flue Gas Flow Rate @ 283°F & 29.28 in. Hg (413 K & 99kPa)			1,300,000 scfm wet (610 m ³ /s) 1,900,000 acfm (900 m ³ /s)
Fly ash (@.03 lb/10 ⁶ Btu) (0.01 kg/GJ)			153 lb/hr (69.4 kg/h)

3.A.3. SULFUR DIOXIDE REMOVAL REQUIREMENT

The latest Federal New Source Performance Standards require a 90 percent reduction in potential SO₂ emissions except when uncontrolled emissions to the atmosphere are less than 0.6 lb SO₂ per million Btu (0.3 kg SO₂/GJ) input. The 90 percent removal must be based on a 30-day rolling average. The coal analyses selected for the study requires that 90 percent removal be achieved. No credit has been given to sulfur removal in the ash. Table 3-4 illustrates sulfur dioxide production rates and removal requirements for the required 90 percent removal efficiency.

TABLE 3-4

SULFUR DIOXIDE DATA

Design Condition (105% load, VWO)	
SO ₂ Production Rate	40,400 lb/hr (18,300 kg/h)
Required SO ₂ Removal Rate	36,400 lb/hr (16,500 kg/h)
Total SO ₂ Emission	0.79 lb SO ₂ /10 ⁶ Btu (0.34 kg SO ₂ /GJ)
Maximum Continuous Rating (100% load)	
SO ₂ Production Rate	38,500 lb/hr (17,500 kg/h)
Required SO ₂ Removal Rate	34,600 lb/hr (15,700 kg/h)
Total SO ₂ Emission	0.79 lb SO ₂ /10 ⁶ Btu (0.34 kg SO ₂ /GJ)
Annual SO ₂ Quantity (70% Capacity Factor)	
SO ₂ Production	118,000 tpy (107,000 Mg/yr)
Required SO ₂ Removal	106,000 tpy (96,200 Mg/yr)

The flue gas characteristics and sulfur dioxide data in the preceding tables apply to FGD Systems requiring steam only for flue gas reheat. For FGD Systems requiring significant quantities of steam in excess of that required for reheat, a larger boiler is required to maintain 500 MW (net) generating capacity. The larger boiler required for those processes with additional steam requirements results in greater flue gas flow, sulfur production, and sulfur removal requirement. The individual sections reiterate flue gas and sulfur data for each process and reflect increased FGD System sizing due to increased steam consumption and consequent increased boiler size.

3.A.4. GENERAL EQUIPMENT

Certain equipment requirements and criteria are common to all of the FGD processes. Scrubbed gas reheat of 50F⁰ (28K) over the saturated gas temperature has been included. Reheat is provided using steam-heated ambient air. Reheat steam coils utilize both latent heat and sensible heat by subcooling the condensate to 200⁰F (370K) prior to return to the boiler feedwater cycle. Each system includes 100 percent flue gas bypass ductwork. Ducts are sized for 3600 fpm (18 m/s) gas velocity for normal operation and 4200 fpm (21 m/s) for reheat air ducts and flue gas bypass ducts.

Combined I.D./Booster Fans have been considered for all systems. The fans provide required induced draft pressure for the boiler and particulate removal device in addition to the FGD System pressure requirement. Fan inlet pressure is assumed to be - 15 inches water gauge (97.6kPa). The total flange-to-flange pressure drop of the FGD System combined with the 15-inch water gauge (3.7kPa) drop for the upstream pressure requirement determines total fan pressure requirement. Fan capital and operating costs are apportioned to the FGD System as the percentage of the total fan pressure attributable to the FGD System.

Equipment redundancy has been incorporated into all FGD Systems to increase reliability. Each FGD System includes a complete spare flue gas treatment module. Depending on sizing constraints, either four-33 percent modules or five-25 percent modules are used. Equipment in other areas is typically spared if its loss would require immediate shutdown of the system. Pumps are 100 percent spared where the loss of a single pump would require shutdown. No sparing is used where a bank of recycle pumps supply several spray levels in an absorber. Items such as tanks, bins, silos, agitators, and heat exchangers are not typically spared.

3.A.5. FGD SYSTEM BATTERY LIMITS

The FGD System battery limits are required to determine scope of necessary equipment and subsequent cost impact. For the purpose of this study, the following battery limits have been used:

- a. Flue Gas - From the I.D. Fan discharge flange to the chimney flange.
(I.D./Booster Fans costs are included as described previously.)
- b. Fly Ash (if required) - Generating plant flyash silo bottom feeder.
- c. Raw Water - Generating plant raw water system at the boundary of the FGD System and the generating plant. Supply conditions are 50 psig and 60⁰F (446kPa and 298K).
- d. Steam - Process steam is available from the Generating Plant turbine cycle at Main Steam, Cold Reheat, and Crossover extraction points. (See Appendix E) Minimum available pressures at each extraction point are expected to exceed:

Main Steam	2400 psia (16,500kPa)
Cold Reheat	250 psia (1700kPa)
Crossover	70 psia (500kPa)

- e. Electrical Power - Power supply to the FGD System is available from the Generating Plant transformer yard to the FGD Plant boundary as 34.5 KV feeders. All necessary electrical equipment for voltage reduction and distribution is included in the FGD System.
- f. Emergency Power - Sufficient emergency power is available from the Generating Plant emergency power system. An emergency power bus at the Generating Plant emergency power grid is available for the FGD System. The FGD System includes switching and distribution for critical service items.
- g. Instrument and Service Air - Instrument and Service Air requirements will be supplied within the FGD System.
- h. Solid Waste Disposal - Disposal of solid waste includes transportation and ultimate placement and disposal in an environmentally acceptable manner.

3.A.6. RAW MATERIALS

Raw materials and assumed compositions for the FGD processes are listed in Table 3-5.

TABLE 3-5

RAW MATERIAL COMPOSITIONS

Limestone -	CaCO ₃ 92 wt.% Inerts 8 wt.% or less Particle Size 3/4 inch (0.19 m)
Fixative Lime -	CaO 90 wt.% Inerts 10 wt.% or less
Soda Ash -	Na ₂ CO ₃ 99.5%

3.A.7. WASTE DISPOSAL

Waste disposal of "throwaway" limestone FGD sludges is assumed to be landfill impoundment of dewatered, blended filter cake. The Chiyoda Thoroughbred 121 effluent is dewatered using either mechanical dewatering or a "gypsum stack"

approach. The dewatered cake is then transported to a landfill without additional blending. Those systems requiring a prescrubber to remove flyash, chlorides, and SO_3 , and to presaturate the gas prior to the absorber will have an acidic purge stream which must be treated. For this study, it has been assumed that this smaller stream of prescrubber purge must be neutralized, thickened, dewatered, and blended prior to landfill disposal, similar to that for the "throwaway" sludges. Many factors affect sulfur dioxide removal efficiency in a prescrubber, including bleed rate, makeup water and fly ash metal ion content, flue gas oxygen content, prescrubber type, etc. For this study, a prescrubber SO_2 removal efficiency of 5 percent was assumed.

The following criteria are assumed for determining land requirements, equipment, and mode of operation required for disposal of "throwaway" sludges:

- a. The waste is either fully-oxidized or stabilized and fixed with lime and flyash, and is sufficiently dewatered to allow landfill disposal.
- b. The landfill disposal area is located 1 mile (1.6 km) from the FGD System.
- c. The dry waste is transported to the disposal area in off-highway trucks.
- d. The landfill disposal area average placement depth is 30 feet (9.1 m).

Additional criteria and guidance for waste disposal are available from the EPRI report, "FGD Sludge Disposal Manual," EPRI Report No. FP-977 (January 1979).

3.B. ECONOMIC DESIGN CRITERIA

The economic criteria for all evaluated FGD processes were standardized to provide consistent economic comparisons. The cost development and breakdown follow EPRI Economic Premises and are based on mid-1978 dollars with a mid-1979 plant start-up. Each of the processes was evaluated for a newly-constructed 500 MW net power plant located near Kenosha, Wisconsin. Table 3-6 lists the standard components of an EPRI estimate. A copy of the EPRI "Economic Premises for ELECTRIC POWER GENERATING SYSTEMS" is included in Appendix F.

3.B.1. CAPITAL ESTIMATE SUMMARY

The bases and items included for each component of the capital estimate are summarized below.

TABLE 3-6

FGD SYSTEM CAPITAL ESTIMATE COMPONENTS

<u>Capital Investment (year \$)</u>	<u>\$/KW</u>
Process Capital	A
General Facilities	B
Engineering and Home Office Fees	C
Project Contingency	D
Process Contingency	E
Sales Tax (Included in A)	<u>F</u>
Total Plant Investment	TPI=A+B+C+D+E+F
Royalty Allowance	G
Preproduction Costs	H
Inventory Capital	I
Initial Catalyst and Chemicals	J
AFDC (Allowance for Funds During Construction)	K
Land	<u>X</u>
Total Capital Requirement	TCR=TPI+G+H+I+J+K+X

3.B.1.a. Total Plant Investment (TPI)

A- PROCESS CAPITAL

Process Capital is the total constructed cost of on-site FGD and related facilities including direct and indirect construction costs. Table 3-7 is a listing of those items included in the estimate of process capital.

TABLE 3-7

ITEMS IN PROCESS CAPITAL ESTIMATE

Earthwork
 Concrete
 Buildings and Structures
 Process Equipment
 Piping
 Electrical
 Painting

Instruments and Controls
 Insulation
 Direct Field Labor
 Indirect Field Costs
 Payroll Taxes
 Insurance, Bonds
 Construction Supplies
 Temporary Facilities
 Construction Equipment
 Vendor Fees

The estimate of process capital is based on process development to determine equipment sizing and costs. Remaining components of the process capital estimate are factored to the installed process equipment costs based on data for projects of similar size and scope. Although different process areas would have slightly different factors for items such as concrete, buildings and structures, piping, etc., the process capital costs for each area are based on a single factor value to adjust process equipment cost to total process capital. Direct field labor and indirect costs associated with field labor account for approximately one-third of the process capital estimate.

The process capital estimate is broken down on an area basis for each process. The processing areas chosen are not all applicable for each process, but some are common to all processes. The areas are listed in Table 3-8.

TABLE 3-8
 COST AREAS FOR PROCESS CAPITAL BREAKDOWN

<u>Area</u>	<u>Description</u>
01	Raw Material Receiving and Storage
02	Feed Preparation and Storage
03	Flue Gas Scrubbing
04	Flue Gas Reheat
05	Purge Treatment
06	SO ₂ Regeneration
07	SO ₂ Processing
08	Waste Separation
09	Waste Disposal
10	Byproduct Storage
11	Flue Gas Handling
12	Waste Transfer and Placement

The equipment included in each cost area is based on the following guidelines. More detailed descriptions are included for each individual process:

- 01 Raw Material Receiving and Storage
Includes equipment required for unloading, transfer to storage, long-term storage and transfer to storage facilities prior to process utilization. Typical interfaces would be rail car or truck hopper and a day bin.
- 02 Feed Preparation and Storage
Includes day storage of raw material, feeders, preparation equipment and storage and transfer equipment for prepared raw material.
- 03 Flue Gas Scrubbing
Includes scrubbers, absorbers and all tanks, pumps, agitators, and any other ancillary equipment associated with the scrubbers and/or absorbers.
- 04 Flue Gas Reheat
Includes reheat fan, finned tube reheater coils, reheat ductwork, and reheat mix chamber.
- 05 Purge Treatment
For processes requiring treatment of a specific purge stream and preparation of the purge for disposal, all equipment associated with handling and treatment of the purge is included.
- 06 SO₂ Regeneration
Includes all equipment required to regenerate absorber blowdown for return to the absorbers and processing of SO₂ stream for interface with SO₂ Processing area. This area is applicable to regenerable processes which produce SO₂.
- 07 SO₂ Processing
Includes all equipment required to produce ultimate sulfur byproduct utilizing SO₂ stream from SO₂ Regeneration area. This can include the production of sulfur dioxide, sulfuric acid, or elemental sulfur.
- 08 Waste Separation
For throwaway processes, includes all equipment to thicken and dewater absorber blowdown stream. Also includes storage and return equipment for supernatant liquor but does not include equipment to further prepare the sludge for disposal.

- 09 Waste Disposal
Includes equipment required for further treatment the of dewatered product from waste separation to make it suitable for disposal.
- 10 Byproduct Storage
Includes equipment required for storage and delivery to transportation system of byproduct produced in SO₂ Processing area.
- 11 Flue Gas Handling
Includes I.D./Booster Fan (prorated based on P scrubber system divided by P total fan) and all ductwork from the fan to the Flue Gas Treatment area and from the Flue Gas Treatment area to the chimney, excluding the reheat associated ductwork in the Flue Gas Reheat area.
- 12 Waste Transfer and Placement
For processes with a "throwaway" solid waste, includes transportation to and final disposal of the waste product.

B- GENERAL FACILITIES OR OFF-SITE CAPITAL

The capital cost of the general facilities includes roads, office buildings, shops, laboratories, etc. EPRI guidelines for this cost item are 5 to 20 percent share of the Process Capital cost. A midpoint value of 12.5 percent of the Process Capital was chosen by Stearns-Roger for this study.

C- ENGINEERING AND HOME OFFICE FEES

An estimate of engineering and home office overhead and fees is included for costs representative of this type of plant. EPRI guidelines for this cost item are 10 to 15 percent of the Process Capital for this cost. A midpoint value of 12.5 percent was chosen by Stearns-Roger for this study. (Of this amount, approximately 10 percent is vendor engineering).

D- PROJECT CONTINGENCY

The project contingency is intended to cover additional equipment or other costs resulting from a more detailed design. The following project contingencies, as a percentage of the process capital, were chosen by Stearns-Roger for use in this study:

Conventional Limestone	5%
EPRI/TVA Cocurrent Limestone	10%
Chiyoda Thoroughbred 121 Limestone	10%
Wellman-Lord	5%

E- PROCESS CONTINGENCY

A process contingency is applied to new technology in an effort to quantify the uncertainty in the design and cost of the commercial-scale equipment. The contingency is related to the level of process development. EPRI has established guidelines which are presented in their economic premises. The process contingencies are expressed as percentages of the process capital and, based on EPRI guidelines, the following process contingencies were chosen by Stearns-Roger for use in this study:

Conventional Limestone	5%
EPRI/TVA Cocurrent Limestone	10%
Chiyoda Thoroughbred 121 Limestone	10%
Wellman-Lord	5%

F- SALES TAX

Sales Tax is included in the estimate for process capital.

3.B.1.b. Total Capital Requirement (TCR)

G- ROYALTY ALLOWANCE

The royalty allowance as established by EPRI is 0.5 percent of the process capital.

H- PREPRODUCTION COSTS

Preproduction Costs are intended to cover operator training, equipment checkout, major changes in plant equipment, extra maintenance, and inefficient use of materials during plant startup. Preproduction Costs are estimated as follows:

- One month fixed operating costs (fixed operating costs are operating and maintenance labor, administrative and support labor, and maintenance materials).
- One month of variable operating costs at full capacity (these variable operating costs include chemicals, water, and other consumables, and waste disposal charges). Full capacity estimates of the variable operating costs will assume operation at 87.5 percent load.
- 5 percent of the TPI (this charge covers expected changes and modifications to equipment required to bring the FGD System up to full capacity).

I- INVENTORY CAPITAL

The inventory capital includes the value of raw materials and other consumables on a capitalized basis. The inventory capital is estimated as follows:

One month supply of raw materials based on full capacity operation.

One month supply of other consumables (excluding water) based on full capacity operation.

Full capacity operation for inventory capital will be assumed as 100 percent load.

J- INITIAL CATALYST AND CHEMICALS

The initial cost of any catalyst or chemicals that are contained in the process equipment (other than that in storage, which is included in inventory capital) is included.

K- AFDC (ALLOWANCE FOR FUNDS DURING CONSTRUCTION)

The schedule duration for engineering, procurement, and construction of the FGD System is assumed to be 3 years.

A charge for AFDC is determined based on the time period from the center of gravity (cg) of expenditures until the plant is in commercial operation. For an interest rate of 8 percent per year, the AFDC is calculated from the TPI as follows:

$$\text{AFDC} = ((1.08)^{\text{CG}} - 1) \times (\text{TPI})$$

The center of gravity for FGD System expenditures is assumed to be 1 year. The calculation of AFDC for this study is:

$$\text{AFDC} = (0.08) \times (\text{TPI})$$

The AFDC charge is expressed in the same year dollars (mid-1978) as the total plant investment. Cost escalation is not involved.

X- LAND

Land Costs are based on a unit cost of \$5000 per acre ($\$1.24/\text{m}^2$). FGD System land requirements include the plant site area and disposal area.

3.B.2. OPERATING COST SUMMARY

Operating costs for the FGD Systems are separated into fixed and variable operating costs. Fixed operating costs include operating and maintenance labor, maintenance materials, and administrative and support labor. Factors for maintenance labor, maintenance material, and administrative and support labor costs are based on EPRI Economic Premises. Variable operating costs includes consumables such as fuel, water, chemicals, and waste disposal. Table 3-9 summarizes the criteria used for these operating costs.

3.B.3. LEVELIZED BUSBAR COST

The capital and operating costs determined for each FGD System are converted to a levelized cost using a fixed charge rate of 18 percent per year for capital costs and appropriate levelization factors (shown in Table 3-9) for operating costs. The total levelized cost of each FGD System is presented as mills per kWh. A further description of the levelization factor technique can be found in Appendix F.

TABLE 3-9
OPERATING COST CRITERIA

	<u>Unit</u>	<u>Rate</u>		
Fixed Operating Costs				
Operating labor	Man-hours	\$12.50 (mid-1978)		
Maintenance Labor	\$/yr	3.2% of Process Capital		
Maintenance Material	\$/yr	4.8% of Process Capital		
Administrative & Support Labor	\$/yr	30% of Operating and Maintenance Labor		
	<u>Unit</u>	<u>Mid-1978 Cost/Unit</u>	<u>Levelization Factor</u>	<u>30-Yr. Levelized Cost/Unit</u>
Variable Operating Costs				
Raw Water	1000 gal.	\$0.40	1.886	\$0.75
Cooling Water	1000 gal.	\$0.10	1.886	\$0.19
Power	KwH	30 mills	1.909	57 mills
Limestone	ton	\$10	1.886	\$19
Lime	ton	\$34	1.886	\$64
Soda Ash	ton	\$66	1.886	\$125
Methane (Synthetic Natural Gas, Replace- ment Cost)	10 ³ cf	\$4	1.932	\$7.70
Disposal Charges (or Credit)				
Dry Solids (Fly Ash)	ton	\$4	1.886	\$7.50
Condensate	1000 lb.	\$0.45	1.886	\$0.85
Steam, (minimum available pressures)				
70 psia	1000 lb.	---	---	\$3.49
70 to 250 psia	1000 lb.	---	---	\$4.41
Byproduct Credits				
Sulfur	Long ton	\$50	1.886	\$94
Sulfuric Acid (100%)	ton	\$40	1.886	\$75


Note: 1000 gal = 3.785 m³, ton (short) = 0.9072 ton (SI),
1000ft³ = 28.32 m³, 1000 lb = 453.6 kg

4. CONVENTIONAL LIMESTONE FGD SYSTEM

4.A. SYSTEM DESCRIPTION

4.A.1. PROCESS DESCRIPTION

Conventional Limestone Flue Gas Desulfurization is the most prevalent sulfur dioxide (SO₂) removal process in use and on order today for full scale installations. Limestone (CaCO₃) is added as the absorbent, with SO₂ removal typically taking place in a spray tower or packed tower. The CaCO₃ and SO₂ combine to form calcium sulfite (CaSO₃). Some of the CaSO₃ is oxidized to calcium sulfate (CaSO₄). The simplified overall reaction of SO₂ and CaCO₃ can be stated as:



In practice, anywhere from 20 to 80 percent of the SO₂ will form calcium sulfite (CaSO₃) rather than calcium sulfate (CaSO₄). Calcium sulfate or gypsum, as the dihydrate (CaSO₄ · 2H₂O) is called, dewateres easier, yields a smaller volume of sludge for disposal, and properly controlled, has a lower scaling tendency than CaSO₃. Calcium sulfate formation (i.e. oxidation) increases with decreasing concentration of SO₂ in the flue gas. High sulfur coals (3 to 4 percent) typically yield a product of 80 to 85 percent sulfite.

An integral component of the absorption process is a reaction tank with adequate residence time for limestone dissolution and sulfite and sulfate crystal formation. A bleed stream from the reaction tanks is taken to thickening and dewatering steps to reduce the volume of sludge for disposal. Sulfites settle more slowly and less densely than sulfates. A system high in sulfites will require a larger thickener and filtration system to handle the greater volume of sludge.

The final waste solid must be disposed of in an environmentally acceptable manner. Several sludge disposal alternatives are available including ponding

or landfill impoundment with or without fixation. Currently, there is a moderate trend toward dry landfill disposal as opposed to ponding. This study assumes landfill impoundment of a fixed sludge.

This study has assumed a conventional limestone system stoichiometry of 1.15. Although experience indicates removal efficiency greater than 90 percent is achievable with this stoichiometric ratio, a process contingency amounting to 5 percent has been included to account for the rigors of the 30-day rolling average and for the use of an open, spray tower for SO₂ scrubbing. Specific design criteria for the Conventional Limestone System are presented in Table 4-1. A process flow diagram and major stream material balance are presented in Figures 4-1 and 4-2.

TABLE 4-1

CONVENTIONAL LIMESTONE SYSTEM
PROCESS DESIGN CRITERIA

Flue Gas Flow (Max. Load)	1,900,000 acfm (900 m ³ /s)
Sulfur Dioxide Removal	90% (based on a 30-day rolling average)
Scrubber Modules	4 @ 33-1/3% capacity each (3 operating, 1 spare)
Scrubber Type	Spray Tower
Liquid-to-Gas Ratio (L/G)	80 gpm/1000 acfm (10.7 l/m ³)
Absorber Superficial Velocity	10 f/s (3m/s)
Scrubber Slurry Solids Concentration	10%
Total System Pressure Drop (Flange-to-flange)	10 in. H ₂ O (2.5kPa)
CaCO ₃ Stoichiometric Ratio	1.15 lb-mole CaCO ₃ /lb-mole SO ₂
Thickener Underflow Solids Concentration	25 wt. %
Dewatered Sludge Solids Concentration	45 wt. %

4.A.2. EQUIPMENT DESCRIPTION

Equipment required for the Conventional Limestone System is divided into several major cost and process areas as follows:

- Area 01 - Raw Material Receiving and Storage
- Area 02 - Feed Preparation and Storage
- Area 03 - Flue Gas Scrubbing
- Area 04 - Flue Gas Reheat




FIGURE 4-1
 CONVENTIONAL LIMESTONE FGD SYSTEM PROCESS FLOW DIAGRAM

STREAM NO.	1	2	3	4	5	6	7	8		
TEMP. °F.	283	283	127	127	177	127	60	382		
PRESS. IN. H ₂ O	-15	+10	+9	+4	+1	+4	0	+10		
10 ³ ACFM	1,974	611	518	524	2,153	1,049	343	529		
CO ₂ (10 ³ #/HR)	1,068	356	356	364	1,093	729	-	-		
H ₂ O "	300	100	179	179	537	358	-	-		
N ₂ "	4,251	1,417	1,417	1,417	5,469	2,834	1,218	1,218		
SO ₂ "	40	13	13	1.3	4	2.7	-	-		
O ₂ "	365	122	122	122	690	244	324	324		
TOTAL "	6,024	2,008	2,087	2,083	7,793	4,168	1,542	1,542	* intermittent	

STREAM NO.	9	10	11	12	13*	14	15	16	17	18
TEMP. °F.	432	60	200	90	70	90	90	70	126	126
GPM			240	150	90	630	210	470	10,490	11,060
SLUDGE 10 ³ #/HR	-	-	-	-	-	-	-	-	-	-
CaCO ₃ "	-	65	-	65	-	65	22	-	-	-
INERTS "	-	7	-	7	-	7	2	-	-	-
H ₂ O (STEAM) "	(121)	-	121	48	44	288	96	234	-	-
TOTAL "	121	72	121	120	44	360	120	234	5,563	5,865
% SOLIDS	-	100	0	60	0	20	20	0	10	10

STREAM NO.	19	20	21*	22	23	24	25	26	27	28
TEMP. °F.	126	125	60	60	60	60	60	60	60	60
GPM	570	1,710	90	15	490	505	95	600	10	-
SLUDGE 10 ³ #/HR	30	91	-	-	-	-	-	-	-	-
CaCO ₃ "	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	-	-	-	-	-	-	.0214
H ₂ O "	272	816	44	7	246	253	47	300	4	-
TOTAL "	302	907	44	7	246	253	47	300	4	.0214
% SOLIDS	10	10	0	0	0	0	0	0	0	100

STREAM NO.	29	30	31	32	33	34	35	36	37	38
TEMP. °F.	60	70	70	70	110	70	70	70	70	70
GPM	85	15	30	10	2,145	1,420	600	1,910	900	600
SLUDGE 10 ³ #/HR	-	-	-	-	91	-	91	-	136	91
REAGENT "	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	.021	-	-	-	-	-	-
H ₂ O "	43	7	14	4	982	710	272	956	408	272
TOTAL "	43	7	14	4	1,073	710	363	956	544	363
% SOLIDS	0	0	0	0	9	0	25	0	25	25

STREAM NO.	39	40	41	42	43	44	45	46	47	48
TEMP. °F.	70	70	60	60	80	80	60	70	70	60
GPM	300	-	325	-	-	-	115	480	935	95
SLUDGE 10 ³ #/HR	45	91	-	-	-	91	-	-	-	-
REAGENT "	-	-	-	5	-	5	-	-	-	-
INERTS "	-	-	-	-	73	73	-	-	-	-
H ₂ O "	136	111	161	-	-	111	58	240	467	48
TOTAL "	181	202	161	5	73	280	58	240	467	48
% SOLIDS	25	45	0	100	100	60	0	0	0	0

(To convert from °F to K, multiply by 5/9 and add 255.37; to convert from IN. H₂O to kPa, multiply by .2488 and add 101.325; to convert 10³ ACFM to m³/s, multiply by .4720; to convert 10³ #/HR to kg/s, multiply by .1260; to convert GPM to m³/S, multiply by 6.31 x 10⁻⁵)

FIGURE 4-2

CONVENTIONAL LIMESTONE SYSTEM PROCESS FLOW BALANCE

- Area 08 - Waste Separation
- Area 09 - Waste Disposal
- Area 11 - Flue Gas Handling
- Area 12 - Waste Transfer and Placement

An equipment list including descriptive information and cost data is presented in Appendix A.

4.A.2.a. Area 01 - Raw Material Receiving and Storage

Limestone is received in bottom dump railcars. A railcar unloading facility is provided with the capacity to unload two railcars simultaneously. A belt conveyor system and stacker transfers the limestone to a 45-day bulk storage pile. The reclaim system includes a front-end loader, with a load hopper and conveyor system to transfer limestone to the process. Fixative lime is received in pneumatic railcar or truck and is stored in a silo prior to pneumatic transfer to the process.

4.A.2.b. Area 02 - Feed Preparation and Storage

A limestone day bin and feeders supply limestone to one of two-100 percent capacity ball mills. The ball mills grind the limestone to 90 percent less than 200 mesh (74 um) and utilize a wet recycle classification loop to ensure proper size distribution to the process. The 60 percent solids slurry from the ball mills is diluted to 20 percent and stored in limestone slurry tanks prior to transfer to the absorbers.

4.A.2.c. Area 03 - Flue Gas Scrubbing

The absorber towers (three operating and one spare) are vertical spray towers with counter current contact of flue gas and calcium carbonate/scrubber slurry. Four levels of sprays are utilized. Scrubbed flue gas passes through vertical chevron mist eliminators prior to leaving the absorbers. Scrubber slurry from each absorber drains to individual agitated reaction tanks which provide adequate retention time for reaction completion and crystal growth. Makeup calcium carbonate slurry is added to the reaction tanks.

Rubber-lined slurry pumps circulate scrubber slurry to abrasion resistant spray nozzles at each spray level. Each spray level has its own recirculation pump, but the pumps are not spared. Bleed from the absorber is pumped from the reaction tanks to the Waste Separation area.

Necessary ancillary equipment items included in this area are the makeup water tank and pumps, seal water tank, filter, and pumps, and the instrument and service air compressor system.

4.A.2.d. Area 04 - Flue Gas Reheat

The scrubbed gas from the absorbers is reheated 50F⁰ (28K) in a reheat mix chamber. Ambient air is drawn via a reheat fan and is heated by finned tube steam coils which utilize both condensation and subcooling sections. The heated air is blown into the reheat mix chamber where it mixes with the scrubbed gas.

4.A.2.e. Area 08 - Waste Separation

The bleed from the scrubbers is pumped to a thickener. Flocculant is added to the thickener feed to aid settling of the scrubber slurry. The supernatant is returned to the scrubbing system via an overflow tank and pumps. The thickener underflow is pumped to a filter feed tank prior to mechanical dewatering by rotary drum vacuum filters. The filtrate is pumped back to the system while the filter cake is conveyed to the Waste Disposal area for further preparation prior to disposal. Area sumps, agitators, and pumps are also included in this area.

4.A.2.f. Area 09 - Waste Disposal

The filter cake from the vacuum filters is blended with lime and fly ash in a process mixer to form a solid waste. Fly ash is pneumatically conveyed from the plant fly ash silos to a day bin near the process mixer. The fixative reagent (lime) is pneumatically conveyed from its storage silo to day bins near the process mixer. The lime, fly ash, and scrubber waste are blended in the process mixer and conveyed by belt conveyor to a truck loading spot. A stacker is provided to pile solid waste, to allow surge capacity for periods when trucks are not operating.

4.A.2.g. Area 11 - Flue Gas Handling

Flue gas from the generating plant particulate removal system passes through one of two combined I.D./Booster Fans. The fans provide sufficient pressure for both the furnace draft and particulate removal system, as well as the flow resistance of the absorber towers and duct system to the chimney. The ductwork includes common inlet and outlet manifolds and total FGD system

bypass if required. Dampers are provided for isolation of individual absorbers for maintenance or inspection.

4.A.2.h. Area 12 - Waste Transfer and Placement

The waste solids from the process mixer are loaded onto off-highway trucks by either a shuttle loader (belt conveyor) or a front-end loader. The trucks transport the waste solids to a landfill disposal area assumed to be 1 mile (1.6km) from the plant site. A bulldozer at the disposal area spreads and compacts the waste to an average depth of 30 feet (9.1 m). The loading, transfer, and landfill area equipment operates one shift only, 5 days per week.

4.A.3. GENERAL ARRANGEMENT

Figure 4-3 shows a basic view of the general arrangement of the Conventional Limestone System. The arrangement allows for the entire FGD System to be bypassed if required, while minimizing bypass ductwork. The ductwork also allows for turning vanes at each absorber inlet to minimize flue gas maldistribution. The arrangement is not necessarily optimized but the concept is consistent with the other processes evaluated.

4.A.4. RAW MATERIAL AND UTILITY CONSUMPTION

Table 4-2 lists raw material and utility consumptions by the Conventional Limestone System at maximum load.

4.A.5. WASTE DISPOSAL

The waste sludge from the vacuum filters requires further stabilization prior to ultimate disposal. Fixative lime and flyash from the particulate collection device are blended with the sludge in a pug mill-type process mixer. The fixed sludge is more stable than the untreated sludge and is adequate for landfill impoundment. The components and maximum load quantity of blended sludge for disposal are as follows:

<u>Component</u>	<u>tph</u>	<u>wt. %</u>
Lime	2.5	2
Flyash	36.5	26
Waste Sludge	45.5	32
Water	<u>55.5</u>	<u>40</u>
Total Waste to Disposal	140	100

Note: tph (English) = .9072 t/h (SI)




FIGURE 4-3

PLOT PLAN OF CONVENTIONAL LIMESTONE FGD SYSTEM

Based on a density of 95 lb/ft³ (1500 kg/m³), the following volumes are estimated for daily, yearly and plant life sludge production:

- Daily Maximum - 2630 yd³ (2010 m³)
- Annual - 395 acre-ft (487,000 m³)
- Plant Life (30-yr.) - 11,850 acre-ft (14,620,000 m³)

TABLE 4-2

CONVENTIONAL LIMESTONE SYSTEM
RAW MATERIAL AND UTILITY CONSUMPTION
(MAXIMUM LOAD - 105%)

<u>Item</u>	<u>Quantity</u>
Limestone @ 1.15 Stoichiometric Ratio	36 t/h (9.07 kg/s)
Fixative Lime @ 3% of Dry Sludge and Fly Ash	2.5 tph (0.64 kg/s)
Raw Water	700 gpm (0.04 m ³ /s)
Steam	121,000 lb/hr (15.25 kg/s)
Power (Operating Horsepower)*	
Area 01 - Raw Material Receiving and Storage	180 hp (130 kW)
Area 02 - Feed Preparation and Storage	1150 hp (860 kW)
Area 03 - Flue Gas Scrubbing	5680 hp (4240 kW)
Area 04 - Flue Gas Reheat	800 hp (600 kW)
Area 08 - Waste Separation	700 hp (520 kW)
Area 09 - Waste Disposal	330 hp (250 kW)
Area 11 - Flue Gas Handling	4000 hp (3000 kW)
Fly Ash (Entire quantity available from plant)	36.5 tph (9.20 kg/s)

*Total power consumption equal to approximately 1.9 percent of net generating capacity.

4.B. TECHNICAL EVALUATION

Conventional limestone processes are the most common FGD systems currently in operation and under construction. Several different vendors offer limestone systems. The process can be applied to high or low sulfur coal applications. A major advantage for limestone scrubbing is the use of an abundant raw material as the absorbent. Limestone scrubbing (and lime scrubbing, which is very similar) is considered a throwaway process. Future requirements concerning the disposal of the waste sludge from limestone scrubbing may adversely affect its economic advantage relative to recovery systems.

Limestone systems are not without their problems. Scaling and plugging have occurred in nearly every limestone system to date. Better understanding of

the mechanisms of scale formation has led to design and operating improvements resulting in systems of acceptable reliability. Stoichiometric ratio's have historically been quite high, resulting in considerable absorbent being thrown away with the waste sludge. The stoichiometric ratio is the ratio of moles of CaCO_3 required to remove 1 mole of SO_2 . Ideally, the stoichiometric ratio should be 1.0. The higher the stoichiometric ratio, the higher the operating cost, because more usable limestone is lost. Additionally, the nature of the waste sludge from the process requires that additives be blended to increase its stability. The result is an even greater land requirement for the disposal area. Limestone systems typically have a high energy demand caused by the large liquid-to-gas ratios necessary to achieve the required SO_2 removal efficiencies. Continued process and equipment developments attempt to improve SO_2 removal and stoichiometric ratio, decrease scaling and plugging problems, improve disposal properties of the waste sludge, and decrease energy requirements.

Several promising approaches to improved limestone system performance and/or decreased costs include:

- 4.B.1. The addition of soluble additives to the slurry to increase limestone reactivity, utilization and SO_2 removal efficiency.
- 4.B.2. Forced oxidation of the slurry to improve waste sludge disposal characteristics.
- 4.B.3. Improved absorber design to provide better gas-liquid contact, lower pressure drop, decreased scaling tendency, and lower material cost.
- 4.B.4. Improved stoichiometry through separation processes designed to recover unused limestone prior to disposal.

Development efforts in the limestone scrubbing area point toward a continued major role in future power plant FGD use.

4.C. ECONOMIC EVALUATION

The economic evaluation of the Conventional Limestone System is presented in the following tables:

Table 4-3 Total Capital Requirement

Table 4-4 Operating Costs

Table 4-5 Levelized Busbar Cost

Cost sensitivity to coal percent-sulfur and plant size was determined by adjusting capital and operating costs and reevaluating the levelized busbar cost. Cost sensitivity to coal percent-sulfur is illustrated in Figure 4-4, and to plant size in Figure 4-5. These curves are based on two additional estimates for the system for each parameter. Costs were adjusted to values for 0.5 percent and 2.0 percent sulfur coal, and for 250MW and 1000MW plant sizes. These values, combined with the base case value, were used to plot the cost sensitivity curves.

TABLE 4-3

CONVENTIONAL LIMESTONE SYSTEM
 TOTAL CAPITAL REQUIREMENT
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 START-UP
 ILLINOIS COAL - 4% SULFUR

Process Capital

<u>Area</u>	<u>Description</u>	<u>\$/kW</u>
01	Raw Material Receiving and Storage	7.4
02	Feed Preparation and Storage	10.9
03	Flue Gas Scrubbing	42.0
04	Flue Gas Reheat	7.3
08	Waste Separation	6.8
09	Waste Disposal	3.9
11	Flue Gas Handling	32.1
12	Waste Transfer and Placement	<u>6.3</u>
	Total Process Capital	116.7
	General Facilities	14.6
	Engineering and Home Office Fees	14.6
	Project Contingency	5.8
	Process Contingency	5.8
	Sales Tax (Included in Process Capital)	<u>---</u>
	Total Plant Investment (TPI)	157.6
	Royalty Allowance	0.6
	Preproduction Costs	10.0
	Inventory Capital	0.6
	Initial Catalyst and Chemicals	0
	Allowance for Funds During Construction (AFDC)	12.6
	Land	<u>4.6</u>
	Total Capital Requirement (TCR)	186.0

TABLE 4-4

CONVENTIONAL LIMESTONE SYSTEM
OPERATING COSTS
500 MW NEW PLANT
MID-1978 COSTS, MID-1979 START-UP
ILLINOIS COAL - 4% SULFUR

<u>Fixed Operating Costs</u>	<u>1st Year (\$/yr)</u>	<u>1st Year \$/kw-Yr</u>	<u>Levelized \$/kw-Yr</u>
Operating Labor			
FGD System	\$ 896,000	1.79	3.38
Sludge Disposal	\$ 156,000	0.31	0.58
Maintenance Labor	\$1,870,000	3.74	7.05
Maintenance Material	\$2,800,000	5.60	10.56
Admin. & Support Labor	\$ 884,000	1.77	3.34
Disposal Equipment	<u>\$ 140,000</u>	<u>0.28</u>	<u>0.53</u>
Total Fixed Operating Cost	\$6,750,000	13.49	25.44
	<u>1st Year (\$/yr)</u>	<u>1st Year Mills/kWh</u>	<u>Levelized Mills/kWh</u>
<u>Variable Operating Costs</u>			
Limestone, 210,000 t/y @ \$10/ton	\$2,100,000	0.69	1.30
Fixative Lime, 14,600 t/y @ \$34/ton	\$ 496,000	0.16	0.30
Raw Water, 245,000 X 10 ³ gal/yr @ \$0.40/10 ³ gal	\$ 98,000	0.03	0.06
Steam, 700,000 x 10 ³ lb/yr (levelized cost) @ \$3.49/10 ³ lb	-----	-----	0.80
Power, 68 x 10 ⁶ kWh/yr @ 30 mills/kWh	\$2,010,000	0.66	1.26
Fly Ash (credit) 213,000 t/y @ \$4/ton	\$ (853,000)	(0.28)	<u>(0.53)</u>
Total Variable Operating Cost			3.19

Note: 1.0 t/y = 9.071 X 10² kg/y
1.0 gal = 3.785 X 10⁻³ m³

TABLE 4-5

CONVENTIONAL LIMESTONE SYSTEM
 LEVELIZED BUSBAR COST
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 START-UP
 ILLINOIS COAL - 4% SULFUR

	<u>Levelized Mills/kWh</u>
Process Capital	3.56
General Facilities	0.43
Engineering and Home Office Fees	0.43
Project Contingency	0.17
Process Contingency	<u>0.17</u>
Total Plant Investment	4.76
Royalty Allowance	0.02
Preproduction Costs	0.29
Inventory Capital	0.02
Allowance for Funds During Construction (AFDC)	0.37
Land	<u>0.04</u>
Total Capital Requirement	5.60
Fixed Operating Cost	4.15
Variable Operating Cost	<u>3.19</u>
Total Levelized Busbar Cost	12.94




FIGURE 4-4

CONVENTIONAL LIMESTONE SYSTEM
COST VERSUS SULFUR CONTENT OF COAL




FIGURE 4-5


CONVENTIONAL LIMESTONE SYSTEM
COST VERSUS PLANT SIZE

5. EPRI/TVA COCURRENT FGD SYSTEM

5.A. SYSTEM DESCRIPTION

5.A.1. PROCESS DESCRIPTION

The Electric Power Research Institute/Tennessee Valley Authority (EPRI/TVA) Cocurrent FGD System is a limestone system utilizing a cocurrent rather than a countercurrent absorber. Gas flow is downward rather than upward as in a conventional countercurrent spray tower. Limestone (CaCO_3) is added as the absorbent, with SO_2 removal taking place in the cocurrent absorber. The CaCO_3 and SO_2 combine to form calcium sulfite (CaSO_3). Some of the CaSO_3 is oxidized to calcium sulfate (CaSO_4). The simplified overall reactions of SO_2 and CaCO_3 can be stated as:



An integral component of the absorption process is a reaction tank with adequate residence time for limestone dissolution and sulfite and sulfate crystal formation. A bleed stream from the reaction tanks is taken to thickening and dewatering steps to reduce the volume of sludge for disposal.

The final waste solid must be disposed of in an environmentally acceptable manner. Several sludge disposal alternatives are available including ponding or landfill impoundment with or without fixation. Currently, there is a moderate trend toward an increase in dry landfill disposal rather than ponding. This study assumes landfill impoundment of a fixed sludge. Lime and fly ash are mixed with the dewatered solids prior to trucking to a landfill.

The EPRI/TVA Cocurrent FGD System is basically a modification of a conventional limestone system. The modification involves the type of contactor used to absorb the sulfur dioxide. Most conventional limestone systems utilize a countercurrent spray or packed tower as the SO_2 contactor. This type of contactor has the flue gas entering the bottom of the tower and flowing upward, contacting the scrubbing liquid traveling downward. Superficial gas velocities are typically limited to a maximum of about 10 fps (3 m/s) to minimize scrubbing liquid carryover and gas-side pressure

drop. Liquid-to-gas ratios of 60 to 100 gal/1000 ft³ (8 to 13 l/m³) of saturated flue gas are required, and spray nozzles or tower internals are often required to improve mass transfer and absorption efficiency. The cocurrent scrubber concept (flue gas and scrubbing liquid enter the scrubber at the top and flow downward through the absorber) is designed to provide required SO₂ removal at higher gas velocities and equivalent pressure drops compared to a countercurrent tower. The higher gas velocities in a cocurrent scrubber allow for a smaller, and consequently less expensive, absorber vessel.

Specific design criteria for the EPRI/TVA Cocurrent System are presented in Table 5-1. A process flow diagram and major stream material balance are presented in Figures 5-1 and 5-2.

TABLE 5-1

EPRI/TVA COCURRENT SYSTEM
PROCESS DESIGN CRITERIA

Flue Gas Flow (Max. Load)	1,900,000 acfm (900 m ³ /s)
Sulfur Dioxide Removal	90% (based on a 30-day rolling average)
Scrubber Modules	Four @ 33-1/3% capacity each (3 operating, 1 spare)
Scrubber Type	Cocurrent Spray Tower
Stages of Grid Packing	Six - 3-3/4" height/stage (9.52 cm)
Liquid-to-Gas Ratio (L/G)	100 gpm/1000 acfm (13 l/m ³)
Absorber Superficial Velocity	27 fps (8.2 m/s)
Scrubber Slurry Solids Concentration	10%
Total System Pressure Drop	15 in. H ₂ O (3.7 kPa)
CaCO ₃ Stoichiometric Ratio	1.3 lb-mole CaCO ₃ /lb-mole SO ₂ removed
Thickener Underflow Solids Concentration	25 wt. %
Dewatered Sludge Solids Concentration	45 wt. %

5.A.2. EQUIPMENT DESCRIPTION

Equipment required for the EPRI/TVA Cocurrent System is divided into several major process cost and areas as follows:

- Area 01 Raw Material Receiving and Storage
- Area 02 Feed Preparation and Storage




FIGURE 5-1

EPRI/TVA COCURRENT FGD SYSTEM PROCESS FLOW DIAGRAM

STREAM NO.	1	2	3	4	5	6	7	8
TEMP. °F.	283	283	127	127	177	127	60	382
PRESS. IN. H ₂ O	-15	+15	+13.5	+3.5	+1	+3.5	0	+10
10 ³ ACFM	1,974	567	478	490	1,959	1,046	320	506
CO ₂ 10 ³ #/HR.	1,068	356	356	364	1,093	729	-	-
H ₂ O "	300	100	174	174	530	348	-	-
N ₂ "	4,251	1,417	1,417	1,417	5,386	2,834	1,136	1,136
SO ₂ "	40	13	13	1.3	4	2.7	-	-
O ₂ "	365	122	122	122	668	244	302	302
TOTAL "	6,024	2,008	2,087	2,083	7,681	4,157	1,438	1,438

*intermittent

STREAM NO.	9	10	11	12	13*	14	15	16	17	18
TEMP. °F.	432	60	200	90	70	90	90	70	126	126
GPM	-	-	226	169	48	710	237	494	9,800	10430
SLUDGE 10 ³ #/HR	-	-	-	-	-	-	-	-	-	-
CaCO ₃ "	-	73	-	73	-	73	24	-	-	-
INERTS "	-	8	-	8	-	8	3	-	-	-
H ₂ O (STEAM) "	(121)	-	121	54	24	325	108	247	5,194	5,528
TOTAL "	121	81	121	135	24	407	136	247	5,194	5,528
% SOLIDS	0	100	0	60	0	20	20	0	10	10

STREAM NO.	19	20	21*	22	23	24	25	26	27	28
TEMP. °F.	126	125	60	60	60	60	60	60	60	60
GPM	630	1,890	48	7	598	606	96	708	10	-
SLUDGE 10 ³ #/HR	33	100	-	-	-	-	-	-	-	-
CaCO ₃ "	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	-	-	-	-	-	-	.0245
H ₂ O "	300	901	24	4	299	303	48	354	5	-
TOTAL "	333	1,001	24	4	299	303	48	354	5	.0245
% SOLIDS	10	10	0	0	0	0	0	0	0	100

STREAM NO.	29	30	31	32	33	34	35	36	37	38
TEMP. °F.	60	70	70	70	110	70	70	70	70	70
GPM	86	7	29	10	2,260	1,456	662	2,054	993	662
SLUDGE 10 ³ #/HR	-	-	-	-	100	-	100	-	150	100
REAGENT "	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	.025	-	-	-	-	-	-
H ₂ O "	43	4	14	5	1,028	728	300	1,027	451	300
TOTAL "	43	4	14	5	1,128	728	400	1,027	601	400
% SOLIDS	0	0	0	0	9	0	25	0	25	25

STREAM NO.	39	40	41	42	43	44	45	46	47	48
TEMP. °F.	70	70	60	60	80	80	60	70	70	60
GPM	331	-	356	-	-	-	115	542	988	108
SLUDGE 10 ³ #/hr	50	100	-	-	-	100	-	-	-	-
REAGENT "	-	-	-	5	-	5	-	-	-	-
INERTS "	-	-	-	-	73	73	-	-	-	-
H ₂ O "	150	122	178	-	-	122	58	271	494	54
TOTAL "	200	222	178	5	73	300	58	271	494	54
% SOLIDS	25	45	0	100	100	60	0	0	0	0

(To convert from °F to K, multiply by 5/9 and add 255.37; to convert from IN. H₂O to kPa, multiply by .2488 and add 101.325; to convert from 10³ ACFM to m³/s, multiply by .4720; to convert from 10³ #/HR to kg/s, multiply by .1260; to convert from GPM to m³/S, multiply by 6.31 x 10⁻⁵)

FIGURE 5-2

EPRI/TVA COCURRENT SYSTEM PROCESS FLOW BALANCE

pumps are not spared. Bleed from the absorber is pumped from the reaction mix tanks to the Waste Separation area.

Necessary ancillary equipment items included in this area are the makeup water tank and pumps, seal water tanks, filter, and pumps, and the instrument and service air compressor system.

5.A.2.d. Area 04 - Flue Gas Reheat

The scrubbed gas from the absorbers is reheated 50F⁰ (28K) in a reheat mix chamber. Ambient air is drawn via a reheat fan and is heated by finned tube steam coils which utilize both condensation and subcooling sections. The heated air is blown into the reheat mix chamber where it mixes with the scrubbed gas.

5.A.2.e. Area 08 - Waste Separation

The bleed from the scrubbers is pumped to a thickener. Flocculant is added to the thickener feed to aid settling of the scrubber slurry. The supernatant is returned to the scrubbing system via an overflow tank and pumps. The thickener underflow is pumped to a filter feed tank prior to mechanical dewatering by rotary drum vacuum filters. The filtrate is pumped back to the system while the filter cake is transferred to the Waste Disposal area for further preparation prior to disposal. Area sumps, agitators, and pumps are also included in this area.

5.A.2.f. Area 09 - Waste Disposal

The filter cake from the vacuum filters is blended with lime and fly ash in a pug mill type process mixer to form a solid waste material. Fly ash is pneumatically conveyed from the plant fly ash silos to a day bin near the process mixer. The fixative reagent (lime) is pneumatically conveyed from its storage silo to a day bin near the process mixer. The lime, fly ash, and scrubber waste are blended in the process mixer and conveyed by belt conveyor to a truck loading spot. A stacker is provided to pile solid waste to allow surge capacity when the trucks are not operating.

5.A.2.g. Area 11 - Flue Gas Handling

Flue gas from the generating plant particulate removal system passes through one of two combined I.D./Booster Fans. The fans provide sufficient pressure for both the furnace draft and particulate removal system, as well as the flow

resistance of the absorber towers and duct system to the chimney. The ductwork includes common inlet and outlet manifolds and total FGD system bypass if required. Dampers are provided for isolation of individual absorbers for maintenance or inspection.

5.A.2.h. Area 12 - Waste Transfer and Placement

The waste solids from the process mixer are loaded onto off-highway trucks by either a shuttle loader (belt conveyor) or a front-end loader. The trucks transport the waste solids to a landfill disposal area assumed to be 1 mile (1.6km) from the plant site. A bulldozer at the disposal area spreads and compacts the waste to an average depth of 30 feet (9.1 m). The loading, transfer, and landfill area equipment operates one shift only, 5 days per week.

5.A.3. GENERAL ARRANGEMENT

Figure 5-3 shows a basic view of the plant site area general arrangement of the EPRI/TVA Cocurrent System. The arrangement allows for the entire FGD System to be bypassed if required, while minimizing bypass ductwork. The ductwork manifolding allows for turning vanes at each absorber inlet to minimize flue gas maldistribution. The arrangement is not necessarily optimized but the concept is consistent with the other processes evaluated.

5.A.4. RAW MATERIAL AND UTILITY CONSUMPTION

Table 5-2 lists raw material and utility consumptions by the EPRI/TVA Cocurrent FGD System at maximum load.

5.A.5. WASTE DISPOSAL

The waste sludge from the vacuum filters requires further stabilization prior to ultimate disposal. Fixative lime and fly ash from the particulate collection device are blended with the sludge in a pug mill-type process mixer. The fixed sludge is more stable than the untreated waste and is adequate for landfill impoundment. The components and maximum load quantity of blended sludge for disposal are as follows:

<u>Component</u>	<u>t/h*</u>	<u>wt %</u>
Lime	2.5	2
Fly ash	36.5	24
Waste Sludge	50.0	33
Water	61.0	41
Total Waste to Disposal	<u>150.0</u>	<u>100</u>
*t/h = 907.2 kg/h		




FIGURE 5-3

PLOT PLAN OF EPRI/TVA COCURRENT FGD SYSTEM

TABLE 5-2

EPRI/TVA COCURRENT FGD SYSTEM
RAW MATERIAL AND UTILITY CONSUMPTION
(MAXIMUM LOAD - 105%)

<u>Item</u>	<u>Quantity</u>
Limestone @ 1.30 Stoichiometric Ratio	40.5 t/h (10.2 kg/s)
Fixative Lime @ 3% of Dry Sludge and Fly Ash	2.5 t/h (0.6 kg/s)
Raw Water	800 gpm (0.05 m ³ /s)
Steam	121,000 lb/hr (15.25 kg/s)
Power (Operating Horsepower)*	
Area 01 - Raw Material Receiving and Storage	180 hp (130 kW)
Area 02 - Feed Preparation and Storage	1345 hp (1002 kW)
Area 03 - Flue Gas Scrubbing	7665 hp (5716 kW)
Area 04 - Flue Gas Reheat	800 hp (600 kW)
Area 08 - Waste Separation	670 hp (500 kW)
Area 09 - Waste Disposal	330 hp (250 kW)
Area 11 - Flue Gas Handling	6000 hp (4500 kW)
Fly Ash (Entire quantity available from plant)	36.5 tph (9.2 kg/s)

*Total power consumption equal to approximately 2.5 percent of net generating capacity.

Based on a density of 95 lb/ft³ (1500 kg/m³), the following volumes are estimated for daily, yearly, and plant life sludge production:

Daily Maximum	2,800 yd ³ (2100 m ³)
Annual	420 acre-ft (518,000 m ³)
Plant Life	12,800 acre-ft (15,800,000 m ³)

5.B. TECHNICAL EVALUATION

The EPRI/TVA Cocurrent FGD System primarily involves an attempt to develop a more efficient and more economical absorber vessel than existing countercurrent systems. It represents a program to develop a scrubber which can provide required SO₂ removal efficiencies while operating at high superficial gas velocities and low pressure drops. This combination is attractive since it would result in a decrease in both initial capital investment and operating costs.

The cocurrent scrubber concept is presently undergoing pilot scale testwork to establish design parameters and optimize operation. Areas of design and operation being evaluated include:

- Different combinations of gas velocity, liquid-to-gas ratio, and scrubber internals, and their effect on SO₂ removal efficiency.
- Wet-elbow design required to minimize slurry carryover into the mist eliminator and reheater.
- Scrubber height required for lime and limestone dissolution.
- Plugging and scaling tendencies of the cocurrent scrubber, if any, and means to eliminate them.

The Tennessee Valley Authority, with funding from EPRI, is conducting evaluations of the cocurrent scrubber concept at the Colbert 1-MW pilot plant facility and the Shawnee Scrubber Test Facility as a 10-MW prototype. Testing at the 1-MW Colbert pilot plant was conducted to provide design data for construction of a 10-MW prototype to be operated at the Shawnee Scrubber Test Facility. The emphasis was to study gas-liquid distribution, SO₂, and particulate removal efficiencies as a function of gas velocity and liquid rates, and the effect of spray nozzle type and location and scrubber internals on SO₂ removal. Information concerning 1-MW Colbert pilot plant testing can be found in the EPRI report, "Cocurrent Scrubber Evaluation TVA's Colbert Lime-Limestone Wet-Scrubbing Pilot Plant," EPRI Report No. FP-941 (January 1979).

Testing continues of the 10-MW prototype at the Shawnee Scrubber Test Facility, and reports concerning the progress and results of the 10-MW cocurrent test program can be requested from EPRI.

5.C. ECONOMIC EVALUATION

The economic evaluation of the EPRI/TVA Cocurrent System is presented in the following tables:

Table 5-3	Total Capital Requirement
Table 5-4	Operating Costs
Table 5-5	Levelized Busbar Cost

Cost sensitivity to coal percent-sulfur and plant size was determined by adjusting capital and operating costs and reevaluating the levelized busbar cost. Cost sensitivity to coal percent-sulfur is illustrated in Figure 5-4,

and to plant size in Figure 5-5. These curves are based on two additional estimates for the system for each parameter. Costs were adjusted to values for 0.5 percent and 2.0 percent sulfur coal, and for 250MW and 1000MW plant sizes. These values, combined with the base case values, were used to plot the cost sensitivity curves.

TABLE 5-3

EPRI/TVA COCURRENT SYSTEM
 TOTAL CAPITAL REQUIREMENT
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 START-UP
 ILLINOIS COAL - 4% SULFUR

Process Capital

<u>Area</u>	<u>Description</u>	<u>\$/kW</u>
01	Raw Material Receiving and Storage	7.4
02	Feed Preparation and Storage	12.2
03	Flue Gas Scrubbing	37.9
04	Flue Gas Reheat	6.5
08	Waste Separation	7.1
09	Waste Disposal	3.8
11	Flue Gas Handling	30.2
12	Waste Transfer and Placement	<u>6.3</u>
	Total Process Capital	111.4
	General Facilities	13.8
	Engineering and Home Office Fees	13.8
	Project Contingency	11.1
	Process Contingency	11.1
	Sales Tax (Included in Process Capital)	<u>0.0</u>
	Total Plant Investment (TPI)	161.2
	Royalty Allowance	0.6
	Preproduction Costs	10.4
	Inventory Capital	0.7
	Initial Catalyst and Chemicals	0.0
	Allowance for Funds During Construction (AFDC)	12.8
	Land	<u>4.8</u>
	Total Capital Requirement (TCR)	190.4

TABLE 5-4

EPRI/TVA COCURRENT SYSTEM
OPERATING COSTS
500 MW NEW PLANT
MID-1978 COSTS, MID-1979 START-UP
ILLINOIS COAL - 4% SULFUR

<u>Fixed Operating Costs</u>	<u>1st Year (\$/Yr)</u>	<u>1st Year \$/kW-Yr</u>	<u>Levelized \$/kW-Yr</u>
Operating Labor			
FGD System	\$ 896,000	1.79	3.38
Sludge Disposal	156,000	0.31	0.58
Maintenance Labor	1,770,000	3.54	6.68
Maintenance Material	2,660,000	5.31	10.01
Admin. & Support Labor	840,000	1.68	3.17
Disposal Equipment	110,000	0.22	0.41
	<u>\$6,400,000</u>	<u>12.80</u>	<u>24.23</u>
<u>Variable Operating Costs</u>	<u>1st Year (\$/yr)</u>	<u>1st Year (Mills/kWh)</u>	<u>Levelized (Mills/kWh)</u>
Limestone, 237,000 t/y @ \$10/ton	\$2,370,000	0.77	1.45
Fixative Lime, 14,600 t/y @ \$34/ton	496,000	0.16	0.30
Raw Water, 280,000 x 10 ³ gal/yr @ \$0.40/10 ³ gal	110,000	0.03	0.06
Steam, 700,000 x 10 ³ lb/yr @ \$3.49/10 ³ lb (levelized cost)	--	--	0.80
Power, 83.9 x 10 ⁶ kWh/yr @ 30 mills/kWh	2,660,000	0.87	1.66
Fly Ash (credit), 213,000 tpy @ \$4/ton	(853,000)	(0.28)	<u>(0.53)</u>
Total Variable Operating Cost			3.74

Note: 1.0 t/y = 9.071 x 10² kg/y
1.0 gal = 3.785 x 10⁻³ m³

TABLE 5-5

EPRI/TVA COCURRENT SYSTEM
 LEVELIZED BUSBAR COST
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 START-UP
 ILLINOIS COAL - 4% SULFUR

	<u>Levelized Mills/kWh</u>
Process Capital	3.27
General Facilities	0.41
Engineering and Home Office Fees	0.41
Project Contingency	0.32
Process Contingency	<u>0.32</u>
Total Plant Investment	4.73
Royalty Allowance	0.02
Preproduction Costs	0.30
Inventory Capital	0.02
Allowance for Funds During Construction (AFDC)	0.38
Land	<u>0.14</u>
Total Capital Requirement	5.59
Fixed Operating Cost	3.95
Variable Operating Cost	<u>3.74</u>
Total Levelized Busbar Cost	13.28




FIGURE 5-4

EPRI/TVA COCURRENT SYSTEM
COST VERSUS SULFUR CONTENT OF COAL




FIGURE 5-5
EPRI/TVA COCURRENT SYSTEM
COST VERSUS PLANT SIZE


6. CHIYODA THOROUGHbred 121 FGD SYSTEM

6.A. SYSTEM DESCRIPTION

6.A.1. PROCESS DESCRIPTION

The Chiyoda THOROUGHbred 121 (CT-121) FGD Process is a limestone process designed to produce gypsum, i.e. a fully oxidized sludge. Gypsum is physically more stable than conventional limestone sludges and is easier to process and dispose. In contrast to a conventional limestone sludge, fully oxidized gypsum need not be mixed with lime and fly ash to "fix" it.

The process utilizes forced oxidation and absorption in a single absorber vessel called a Jet Bubbling Reactor (JBR). The JBR is designed to achieve required sulfur dioxide removal efficiencies at pH values (3-5 pH units) lower than in conventional wet limestone scrubbing processes. Oxidation air is injected into the JBR to promote formation of gypsum ($\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$). The JBR approach combines the absorption, oxidation, neutralization, and crystallization processes into a single vessel. The simplified overall reaction in the system is:



The chemistry is basically the same as a conventional limestone system. The design intends, however, to attain both complete oxidation of sulfite and limestone utilization approaching 100 percent.

The flue gas is cooled in the Precooler prior to introduction into the Jet Bubbling Reactor (JBR). The JBR functions as a flue gas scrubber, an oxidizer for sulfites, and a reaction crystallizer for gypsum. The flue gas is injected into the absorbent slurry through many gas spargers placed 4 to 16 inches (.10-.41 m) below the surface of the slurry. The flue gas is dispersed and forms a "jet bubbling zone" where SO_2 absorption occurs. The main body of liquid in the JBR is called a "reaction zone." The entire vessel contents are agitated mechanically and injected into the bottom of the vessel with oxidation air. The reaction zone provides for both the oxidation of sulfites and crystallization of gypsum.

The gypsum slurry bleed stream from the JBR's is transferred to a gypsum slurry tank. From this point, the gypsum slurry can either be mechanically dewatered or gravity dewatered with a gypsum stack. The gypsum stack approach is common practice in the phosphoric acid industry and requires less land area than ponding. The dewatered gypsum must be disposed of in an environmentally-acceptable manner. The dewatered gypsum from the CT-121 process is stable enough to be placed in a landfill disposal area without further blending or treatment.

If the potential of selling gypsum for wallboard manufacture exists, efforts must be made to maintain its purity. Any residual fly ash from the particulate collection device and chloride in the flue gas (as HCl) which is removed in the Precooler would have to be separately neutralized, dewatered, and disposed. The sale of gypsum for wallboard construction is site specific and normally not feasible.

Specific design criteria for the CT-121 System are presented in Table 6-1. A process flow diagram and major stream material balance are presented in Figures 6-1 and 6-2.

TABLE 6-1

CHIYODA THOROUGHbred 121 SYSTEM PROCESS DESIGN CRITERIA	
Flue Gas Flow (Max. Load)	1,900,000 acfm (900 m ³ /s)
Sulfur Dioxide Removal	90% (based on a 30-day rolling average)
Scrubber Modules	4 @ 33-1/3% capacity each (3 operating, 1 spare)
Scrubber Type	Jet Bubbling Reactor
Scrubber Slurry Solids Concentration	10% - 30%
Total System Pressure Drop (Flange-to-flange)	(15% used for material balance) 21 in. H ₂ O (5.2 kPa)
CaCO ₃ Stoichiometric Ratio	1.01 lb-mole CaCO ₃ /lb-mole SO ₂ removed
Oxidation Air Stoichiometric Ratio	4
Dewatered Sludge Solids Concentration	
- Mechanically Dewatered	85%
- Gypsum Stack Dewatered	80%




FIGURE 6-1
CHIYODA THOROUGHbred 121 FGD SYSTEM PROCESS FLOW DIAGRAM

STREAM NO.	1	2	3	4	5	6	7	8
TEMP. °F.	283	283	127	127	177	60	382	60
PRESS. IN. H ₂ O	-15	+21	+19	+4	+1	0	+10	0
10 ³ ACFM	1,974	601	506	524	2,144	345	545	35
CO ₂ (10 ³ #/HR)	1,068	356	356	365	1,095	-	-	-
H ₂ O "	300	100	179	174	537	-	-	-
N ₂ "	4,251	1,417	1,417	1,417	5,434	1,183	1,183	120
SO ₂ "	40	13	12	1.3	4	-	-	-
O ₂ "	365	122	122	122	724	359	359	36
TOTAL "	6,025	2,008	2,086	2,084	7,794	1,542	1,542	156

STREAM NO.	9	10	11	12	13	14	15	16	17	18
TEMP. °F.	432	200	127	127	127	127	60	120	120	120
GPM	-	250	10,600	90	406	1,220	-	85	130	427
SLUDGE (10 ³ #/HR)	-	-	-	-	33	98	-	-	-	-
CaCO ₃ "	-	-	-	-	0.2	0.6	59	-	59	-
INERTS "	-	-	5	trace	2.2	6.7	5	-	5	-
H ₂ O (STEAM) "	(121)	121	5,298	44	199	596	-	43	43	213
TOTAL "	121	121	5,303	44	234	701	64	43	107	213
% SOLIDS	-	-	0.1	0.1	15	15	100	-	60	-

STREAM NO.	19	20	21	22	23	24*	25**	26	27	28
TEMP. °F.	120	120	120	120	127	60	60	60	100	100
GPM	533	178	415	138	360	55	120	391	738	246
SLUDGE (10 ³ #/HR)	-	-	-	-	29	-	-	-	-	-
CaCO ₃ "	59	20	-	-	0.2	-	-	-	-	-
INERTS "	5	2	-	-	2	-	-	-	-	-
H ₂ O "	256	85	208	69	176	27	60	196	369	123
TOTAL "	320	107	208	69	207	27	60	196	369	123
% SOLIDS	20	20	-	-	15	-	-	-	-	-

STREAM NO.	29	30	31	32	33	34	35	36
TEMP. °F.	127	127	127	120	100	127	120	100
GPM	1,828	609	1,220	1,154	-	1,220	1,139	-
SLUDGE (10 ³ #/HR)	147	49	98	-	98	98	-	98
CaCO ₃ "	0.9	0.3	0.6	-	0.6	0.6	-	0.6
INERTS "	10	3.4	6.7	-	6.7	6.7	-	6.7
H ₂ O "	893	298	596	577	19	596	569	26
TOTAL "	1,051	350	701	577	124	701	569	131
% SOLIDS	15	15	15	-	85	15	-	80

(To convert from °F to K, multiply by 5/9 and add 255.37; to convert from IN. H₂O to kPa, multiply by .2488 and add 101.325; to convert from 10³ ACFM to m³/s, multiply by .4720; to convert from 10³ #/HR to kg/s, multiply by .1260; to convert from GPM to m³/s, multiply by 6.31 x 10⁻⁵)

*Intermittent flow; not included in overall water balance.

**For water balance consideration seal water was allocated to makeup water tank.

FIGURE 6-2

CHIYODA THOROUGHbred 121 PROCESS FLOW BALANCE

6.A.2. EQUIPMENT DESCRIPTION

Equipment required for the Chiyoda THOROUGHBRED 121 System is divided into several major cost and process areas as follows:

- Area 01 - Raw Material Receiving and Storage
- Area 02 - Feed Preparation and Storage
- Area 03 - Flue Gas Scrubbing
- Area 04 - Flue Gas Reheat
- Area 08 - Waste Separation
 - 1) Mechanical Dewatering Alternate
 - 2) Gypsum Stack Dewatering Alternate
- Area 11 - Flue Gas Handling
- Area 12 - Waste Transfer and Placement

An equipment list including descriptive information and cost data is presented in Appendix C.

- Area 01 - Raw Material Receiving and Storage

Limestone is received in bottom dump railcars. A railcar unloading facility is provided with the capacity to unload two railcars simultaneously. A belt conveyor system and stacker transfers the limestone to a 45-day bulk storage pile. The reclaim system includes a front-end loader with a load hopper and a conveyor system to transfer limestone to the process.

- Area 02 - Feed Preparation and Storage

A limestone day bin and feeders supply limestone to one of two 100 percent capacity ball mills. The ball mills grind the limestone to 90 percent less than 200 mesh (74 um) and utilizes a wet recycle classification loop to ensure proper size distribution to the process. The 60 percent solids slurry from the ball mills is diluted to 20 percent and stored in limestone slurry tanks prior to transfer to the absorbers.

- Area 03 - Flue Gas Scrubbing

The flue gas treatment area includes a precooler for saturating the flue gas and the Jet Bubbling Reactors (JBR) for sulfur dioxide absorption. The Precoolers are open spray chambers which saturate the gas before it enters the JBR. Rubber-lined pumps circulate liquor in the Precooler and

purge some of the recirculating liquor to the JBR for neutralization. If the system were designed to produce a marketable gypsum product, the pre-cooler purge stream would have to be separately neutralized, dewatered, and disposed to minimize fly ash and chloride content in the gypsum.

Saturated flue gas enters the JBR's where it passes through gas spargers into the scrubbing liquid, up through the vessel, and through vertical chevron mist eliminators. Level control in the JBR's is maintained by overflow to an Overflow Receiving Tank. Makeup calcium carbonate slurry is added to the JBR. An oxidation air blower injects air into the bottom of each JBR to promote oxidation. A gypsum slurry bleed is continuously pumped to the Waste Separation area.

Necessary ancillary equipment items included in this area are the makeup water tank and pumps, seal water tank, filter, and pumps, and the instrument and service air compressor system.

Area 04 - Flue Gas Reheat

The scrubbed gas from the absorbers is reheated 50F⁰ (28 K) in a reheat mix chamber. Ambient air is drawn via a reheat fan and is heated by finned tube steam coils which utilize both condensation and subcooling sections. The heated air is blown into the reheat mix chamber where it mixes with the scrubbed gas.

Area 08 - Waste Separation

The gypsum slurry bleed stream is pumped to a slurry storage tank prior to dewatering. The following two alternate dewatering approaches have been selected:

- 1) Mechanical Dewatering
- 2) Gypsum Stack Dewatering

The mechanical dewatering alternate utilizes rotary drum vacuum filters. A thickener is not required because the gypsum slurry dewateres easier than conventional limestone sludge. The filtrate is pumped to a process water storage tank for return to the scrubbing system. The filter cake is conveyed to a storage pile from which it is trucked to disposal.

The gypsum stack dewatering alternate utilizes gravity sedimentation to dewater the gypsum. Gypsum stacking is a common practice in the phosphoric acid industry. The gypsum slurry is pumped from the storage tank to a sedimentation pond on top of the gypsum stack. Gypsum settles on the stack while the clarified liquor overflows to a surge pond and is then pumped to the process water storage tank. The supernatant is then returned to the system. Dewatered gypsum is excavated and trucked to disposal.

Area sumps, agitators, and pumps are also included in this area for either alternative.

- Area 09 - Waste Disposal

The dewatered gypsum from the vacuum filters is conveyed by belt conveyor to a truck loading spot. A stacker is provided to pile solid waste to provide surge capacity for periods when trucks are not operating.

- Area 11 - Flue Gas Handling

Flue gas from the generating plant particulate removal system passes through one of two combined I.D./Booster Fans. The fans provide sufficient pressure for both the furnace draft and particulate removal system, as well as the flow resistance of the precoolers, JBR's, and duct system to the chimney. The ductwork includes common inlet and outlet manifolds and total FGD system bypass if required. Dampers are provided for isolation of individual scrubbing trains for maintenance or inspection.

- Area 12 - Waste Transfer and Placement

The dewatered gypsum from either the vacuum filters or the gypsum stack is loaded on to off-highway trucks by a front-end loader. The disposal scheme assumes truck transport of the gypsum solids to a landfill disposal area assumed to be one mile (1.6 km) from the plant site. A bulldozer at the disposal area spreads and compacts the waste to an average depth of 30 feet (9.1 m). The loading, transfer and landfill area equipment operates one shift only, five days per week. (Note: Depending on site conditions, the gypsum stack could be the landfill, thereby eliminating this area.)

6.A.3. GENERAL ARRANGEMENT

Figure 6-3 shows a basic view of the general arrangement of the CT-121 System. The arrangement allows for the entire FGD System to be bypassed, if required while minimizing bypass duct length. The ductwork manifolding also allows for turning vanes at each absorber inlet to minimize flue gas maldistribution. The arrangement is not necessarily optimized but the concept is consistent with the other processes evaluated.

6.A.4. RAW MATERIAL AND UTILITY CONSUMPTION

Table 6-2 lists raw material and utility consumptions by the CT-121 System at maximum load.

TABLE 6-2

CHIYODA THOROUGHbred 121 SYSTEM
RAW MATERIAL AND UTILITY CONSUMPTION
(Maximum Load - 105%)

<u>Item</u>	<u>Quantity</u>
Limestone @ 1.01 Stoichiometric Ratio	32 t/h (8.1 kg/s)
Raw Water	570 gpm (0.04 m ³ /s)
Steam	121,000 lb/hr (15.25 kg/s)
Power (Operating Horsepower)*	
Area 01 - Raw Material Receiving and Storage	180 hp (130 kW)
Area 02 - Feed Preparation and Storage	915 hp (682 kW)
Area 03 - Flue Gas Scrubbing	4,065 hp (3031 kW)
Area 04 - Flue Gas Reheat	800 hp (600 kW)
Area 08 - Waste Separation	400 hp (300 kW)
Area 09 - Waste Disposal	25 hp (29 kW)
Area 11 - Flue Gas Handling	8,160 hp (6080 kW)

*Total power consumption equal to approximately 2.2% of net generating capacity

6.A.5. WASTE DISPOSAL

The gypsum sludge from the vacuum filters is stable enough to be disposed and adequate for landfill impoundment. The solids content of the sludge varies slightly depending on the dewatering alternate. Percent solids concentration in the dewatered sludge is assumed to be 85 percent for mechanical dewatering and 80 percent for gypsum stack dewatering. Estimated sludge quantities at maximum load are 62 tph after mechanical dewatering and 66 tph after gypsum stack dewatering.




FIGURE 6-3

PLOT PLAN OF CHIYODA THOROUGHbred 121 FGD SYSTEM

Based on a density of 95 lb/ft³ (1500 Kg/m³), the following volumes are estimated for daily, yearly, and plant life sludge production:

Daily Maximum	-	1170 yd ³ (895 m ³)
Annual	-	176 acre-ft (217,000 m ³)
Plant Life	-	5280 acre-ft (6,510,000 m ³)

6.B. TECHNICAL EVALUATION

The Chiyoda THOROUGHbred 121 Process represents an approach to improving the conventional limestone scrubbing process by redesign of the scrubbing vessel. The change provides for a single vessel which combines the absorption, oxidation, neutralization, and crystallization processes into one vessel, the JBR.

The JBR represents a different approach to gas-liquid contacting for SO₂ removal. The contact is achieved by injecting the flue gas through gas sparger tubes which are immersed 4-16 inches (.10-.41 m) below the liquid surface of the scrubbing slurry. A "jet bubbling layer" is formed where the gas dispersion results in efficient gas-liquid contact promoting SO₂ absorption. The total gas pressure drop is the sum of the sparger liquid immersion depth plus the gas pressure drop through openings at the bottom of the spargers provided to disperse the gas bubbles. The total system pressure drop is slightly greater than most conventional limestone processes. Significant energy savings are realized, however, due to the elimination of large slurry recycle pumps which are required for conventional limestone processes' liquid-to-gas ratio requirements of 60 to 100 gallons per 1000 ACFM of gas (64-107 l/m³).

The main body of liquid in the JBR is called a "reaction zone." The reaction zone is where the oxidation of sulfites and formation of gypsum crystals occurs. Both mechanical agitation and air injection combine to continually circulate the JBR contents and promote oxidation. The liquid pH level is maintained in the range of 3 to 5 where both the oxidation reaction and neutralization reaction rates are increased. The slurry concentration is maintained between 10 and 30 wt % to provide crystal surface area for gypsum crystal growth and thereby prevent sulfate scaling. (A slurry concentration of 15 wt % was chosen for this study.) The resultant slurry has been

virtually 100 percent oxidized so all calcium-sulfur salts exist as sulfate rather than sulfite. This allows the slurry to be dewatered to 80-85 wt % solids.

The CT-121 process has been tested as a 23-MW pilot unit at the Scholz Station of Gulf Power. The testwork began in mid-1978 as a modification of the CT-101 pilot plant unit at Scholz. Preliminary test results have been encouraging, and formal test results will soon be published. Although preliminary results from this facility indicate improved process economics, the results were not available for inclusion in this study. The basis for this study does not utilize any data from the test work. Chiyoda feels confident that the process is ready for full-scale application.

The CT-121 process offers several encouraging approaches to the improvement of limestone system performance. It combines the goals of increased limestone utilization and waste sludge oxidation in a single, improved absorber design. Further testing, design and operation of a prototype or full-scale installation will be necessary to prove the CT-121 system's applicability to the nation's utility industry, but initial information indicates that it represents a promising improvement to the conventional limestone approach.

6.C. ECONOMIC EVALUATION

The economic evaluation of the Chiyoda THOROUGHbred 121 System is presented in the following tables:

Table 6-3	Total Capital Requirement
Table 6-4	Operating Costs
Table 6-5	Levelized Busbar Cost

Cost sensitivity to coal %-sulfur and plant size was determined by adjusting capital and operating costs and reevaluating the levelized busbar cost. Cost sensitivity to coal %-sulfur is illustrated in Figure 6-4 and to plant size in Figure 6-5.

The potential exists with the CT-121 System that wallboard-grade gypsum could be produced and sold rather than disposed. This approach would require additional equipment to treat the purge stream from the precoolers to avoid

contamination of the gypsum by chlorides and possibly fly ash. The sludge produced from the neutralization of the purge stream would require thickening, dewatering, and blending prior to landfill disposal, although its volume would be less than for the total gypsum produced in the base case. A detailed analysis of the process and economic implications of the marketable gypsum approach was not performed. A rough analysis of the option indicates an increased levelized busbar cost of about 0.8 mills/kWh to modify the CT-121 System to produce a marketable gypsum product.

TABLE 6-3

CHIYODA THOROUGHbred 121 SYSTEM
TOTAL CAPITAL REQUIREMENT
500 MW NEW PLANT
MID-1978 COSTS, MID-1979 STARTUP
ILLINOIS COAL - 4% SULFUR

Process Capital

<u>Area</u>	<u>Description</u>	<u>Mechanical Dewatering \$/kW</u>	<u>Gypsum Stacking \$/kW</u>
01	Raw Material Receiving and Storage	5.5	5.5
02	Feed Preparation and Storage	9.6	9.6
03	Flue Gas Scrubbing	26.7	26.7
04	Flue Gas Reheat	7.3	7.3
08	Waste Separation	5.1	3.1
09	Waste Disposal	1.1	1.1
11	Flue Gas Handling	35.3	35.3
12	Waste Transfer and Placement	<u>3.7</u>	<u>3.7</u>
	Total Process Capital	94.3	92.3
General Facilities		11.8	11.5
Engineering and Home Office Fees		11.8	11.5
Project Contingency		9.4	9.2
Process Contingency		9.4	9.2
Sales Tax (Included in Process Capital)		<u>0</u>	<u>0</u>
	Total Plant Investment (TPI)	136.7	133.8
Royalty Allowance		0.5	0.5
Preproduction Costs		8.9	8.7
Inventory Capital		0.4	0.4
Initial Catalyst and Chemicals		0.0	0.0
Allowance for Funds During Construction (AFDC)		10.9	10.7
Land		<u>2.1</u>	<u>2.3</u>
	Total Capital Requirement (TCR)	159.6	156.5

TABLE 6-4

CHIYODA THOROUGHbred 121 SYSTEM
 OPERATING COSTS
 500 MW NEW PLANT
 MID-1978 COSTS
 ILLINOIS COAL - 4% SULFUR

<u>Fixed Operating Costs</u>	Mechanical Dewatering			Gypsum Stack Alternate		
	<u>1st Yr (\$/yr)</u>	<u>1st Yr \$/kW-Yr</u>	<u>Alternate Levelized \$/kW-Yr</u>	<u>1st Yr (\$/Yr)</u>	<u>1st Yr \$/kW-Yr</u>	<u>Alternate Levelized \$/kW-Yr</u>
Operating Labor						
FGD System	\$ 807,000	1.61	3.04	\$ 807,000	1.61	3.04
Sludge Disposal	104,000	0.21	0.40	130,000	0.26	0.49
Maintenance Labor	1,510,000	3.02	5.70	1,480,000	2.95	5.56
Maintenance Material	2,260,000	4.53	8.54	2,215,000	4.43	8.35
Admin. & Support Labor	734,000	1.47	2.77	716,000	1.43	2.70
Disposal Equipment	<u>72,000</u>	<u>0.14</u>	<u>0.26</u>	<u>88,000</u>	<u>0.18</u>	<u>0.34</u>
	\$5,490,000	10.98	20.71	\$5,430,000	10.87	20.50

<u>Variable Operating Costs</u>	<u>1st Yr (\$/yr)</u>	<u>1st Yr (Mills/kWh)</u>	<u>Levelized (Mills/kWh)</u>
Limestone 187,000 t/y @ \$10/ton	\$1,870,000	0.61	1.15
Raw Water 200,000 x 10 ³ gal/yr @ \$0.40/10 ³ gal	80,000	0.03	0.06
Steam 700,000 x 10 ³ lb/yr @ \$3.49/10 ³ lb (Levelized Cost)	---	--	0.80
Power 76 x 10 ⁶ kWh/yr @ 30 mills/kWh	2,280,000	0.74	1.41
Total Variable Operating Cost			<u>3.42</u>

Note: 1.0 t/y = 9.071 x 10² kg/y
 1.0 gal = 3.785 x 10⁻³ m³

TABLE 6-5

CHIYODA THOROUGHBRED 121 SYSTEM
 LEVELIZED BUSBAR COST
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 STARTUP
 ILLINOIS COAL - 4% SULFUR

	Levelized Mills/kWh	
	<u>Mechanical Dewatering Alternate</u>	<u>Gypsum Stack Alternate</u>
Process Capital	2.77	2.71
General Facilities	0.35	0.34
Engineering and Home Office Fees	0.35	0.34
Project Contingency	0.28	0.27
Process Contingency	<u>0.28</u>	<u>0.27</u>
Total Plant Investment	4.03	3.93
Royalty Allowance	0.01	0.01
Preproduction Costs	0.26	0.26
Inventory Capital	0.01	0.01
Allowance for Funds During Construction (AFDC)	0.32	0.31
Land	<u>0.06</u>	<u>0.07</u>
Total Capital Requirement	4.69	4.59
Fixed Operating Cost	3.38	3.34
Variable Operating Cost	<u>3.42</u>	<u>3.42</u>
Total Levelized Busbar Cost	11.49	11.35




FIGURE 6-4

CHIYODA THOROUGHbred 121 SYSTEM
COST VERSUS COAL SULFUR CONTENT




FIGURE 6-5

CHIYODA THOROUGHbred 121 SYSTEM
COST VERSUS PLANT SIZE

Blank

6-18

7. WELLMAN-LORD FGD SYSTEM

7.A. SYSTEM DESCRIPTION


7.A.1. PROCESS DESCRIPTION

The Wellman-Lord FGD Process, marketed by Davy-McKee Corp., of Lakeland, Florida, is a recovery process producing a concentrated SO₂-rich off-gas which can be sold as liquid SO₂ or converted to high purity sulfuric acid or elemental sulfur. The Wellman-Lord process absorbs SO₂ by contacting the flue gas with an aqueous sodium sulfite solution. The reaction forms soluble sodium bisulfite which is regenerated to sodium sulfite, with the liberation of gaseous SO₂, in an evaporator. The regenerated sodium sulfite is returned to the absorber circuit for reuse while the SO₂ is either liquefied, converted to sulfuric acid, or converted to elemental sulfur.


The Wellman-Lord process consists of three basic steps:

- Sulfur dioxide absorption
- Absorbent regeneration and SO₂ production
- Sulfur dioxide conversion to elemental sulfur or sulfuric acid

The SO₂ is absorbed in a sodium sulfite scrubbing solution by the following simplified reaction:



Two additional reactions occur between the sodium sulfite and SO₃ or oxygen in the flue gas to form sodium sulfate:




The sodium sulfate formed must be purged from the recycle stream since it cannot be thermally decomposed in the process. A portion of the sodium bisulfite-rich absorber product solution is purged to an evaporator-crystallizer where the unwanted sulfate crystallizes at a greater rate than

the useful sodium compounds. The sodium sulfate crystallized from the purge stream is dried and stored prior to sale or disposal. The sodium associated with the purge stream must be replaced with a caustic soda or soda ash feed.


A prescrubber is required to cool and presaturate the flue gas and ensure that a minimal quantity of particulates and chlorides enter the absorption recycle stream. The prescrubber also removes some SO_3 and chlorides as well as a portion of the entering SO_2 . Chloride removal is particularly important when firing high-chloride coals to prevent the buildup of sodium chloride in the absorption-regeneration loop. The purge stream from the prescrubbers is neutralized, thickened, dewatered, and blended with fly ash and a fixative reagent. The solid waste is then disposed using the same means as lime or limestone throwaway systems, but much less volume is involved.

The sodium bisulfite-rich absorber product solution is pumped through fly ash filters to remove any remaining particulates (the filter sluice goes to the prescrubber purge neutralization system) and then proceeds to the thermal regeneration loop, except for a small portion which is purged to remove sulfates. The absorber product solution is passed through two stages of forced circulation evaporators where the sodium bisulfite is converted to sodium sulfite crystals and gaseous SO_2 . The sodium sulfite crystals are redissolved and returned to the absorbers for reuse in scrubbing. The gaseous SO_2 is concentrated in two stages of water cooled condensers. The SO_2 -rich gases leaving the secondary condenser are compressed before entering the recovery area where SO_2 is liquified or, as for this study, converted to either elemental sulfur or sulfuric acid.

The SO_2 exiting the regeneration loop can be converted to elemental sulfur via a sulfur reduction process or to sulfuric acid by a conventional contact acid process. A sulfur reduction process which has been used in this study is the Allied Chemical reduction process which includes a Claus reactor. The first stage reduces the SO_2 using natural gas to produce sulfur and hydrogen sulfide (H_2S):



The second stage involves a Claus reaction to convert the H₂S to elemental sulfur:



The sulfur produced is condensed and stored for shipment or disposal. The tail gas from the Claus reaction is incinerated and returned to the flue gas stream ahead of the absorber towers.


Sulfuric acid production can be achieved by a contact acid plant. The SO₂ gas stream is first passed through a drying tower. The high purity SO₂ gas is then oxidized to convert it to SO₃. The SO₃ is passed through an absorbing tower where the SO₃ reacts with water to form sulfuric acid (H₂SO₄) of up to 98 percent concentration. Several heat exchangers form a part of the system for temperature optimization and heat recovery.

Specific design criteria for the Wellman-Lord System are presented in Table 7-1. A process flow diagram and major stream material balance are presented in Figures 7-1A, B and Figures 7-2A, B. Simplified flow diagrams of a sulfur and a sulfuric acid plant are shown in Figure 7-3.

TABLE 7-1

WELLMAN-LORD SYSTEM
PROCESS DESIGN CRITERIA

Flue Gas Flow (Max. Load)	1,990,000 acfm (940 m ³ /s)
Sulfur Dioxide Removal	90% (based on a 30-day rolling average)
Absorber Modules	4 @ 33-1/3% capacity each (3 operating, 1 spare)
Absorber Type	Valve Tray Tower (3 trays)
Tray Recirculation Rate	3 gpm per tray/1000 acfm (0.4 l/m ³)
Absorber Superficial Velocity	10 f/s (3 m/s)
Total System Pressure Drop (Flange to flange)	24 in. H ₂ O (6.0 kPa) (Including 3 in. H ₂ O (0.7 kPa) for reheat mixing)



7-4

FIGURE 7-1A

WELLMAN-LORD FGD SYSTEM PROCESS FLOW DIAGRAM, PART 1

STREAM NO.	1	2	3	4	5	6	7	8	9						
TEMP. °F.	277	283	283	127	127	127	60	382	177						
PRESS. IN. H ₂ O	-15	+24	+24	+14	+4	+4	0	+10	+1						
10 ³ ACFM	2053	626	1253	540	551	1103	399	630	2296						
CO ₂ , 10 ³ #/HR.	1125	375	750	375	375	750	-	-	1125						
H ₂ O "	316	105	211	189	189	378	-	-	567						
N ₂ "	4478	1493	2985	1493	1493	2985	1412	1412	5890						
SO ₂ "	42	14	28	13	1	3	-	-	4						
O ₂ "	385	128	257	128	128	257	375	375	760						
TOTAL "	6347	2116	4231	2198	2186	4373	1788	1788	8347						
STREAM NO.	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
TEMP. °F.	432	200	127	127	126	60	60	90	115	75	60	80	60	75	60
GPM (PSIG)	(350)	267	5400	45	135	-	30	35	185	45	-	-	-	-	28
Na ₂ SO ₃ , 10 ³ #/HR	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
NaHSO ₃ "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Na ₂ SO ₄ "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
REAGENT "	-	-	-	-	-	2.7	-	2.7	-	-	-	-	0.7	0.7	-
SO ₂ "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SLUDGE "	-	-	-	-	-	-	-	-	8	8	8	-	-	8	-
INERTS "	-	-	-	-	-	0.3	-	0.3	-	-	-	14	-	14	-
H ₂ O "	136	136	-	23	-	-	15	15	92	20	6	-	-	6	14
TOTAL "	136	136	2780	23	68	3	15	18	100	28	14	14	0.7	29	14
% SOLIDS	0	0	<3	<3	<3	100	0	20	9	30	60	100	100	80	0
STREAM NO.	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39
TEMP. °F.	75	70	60	60	60	60	127	127	60	60	150	125	127	60	127
GPM (PSIG)	145	173	173	516	164	3	12520	1654	17	5	960	320	334	5	1000
Na ₂ SO ₃ , 10 ³ #/HR	-	-	-	-	-	-	-	-	-	-	119	40	15	-	45
NaHSO ₃ "	-	-	-	-	-	-	-	-	-	-	18	6	45	-	135
Na ₂ SO ₄ "	-	-	-	-	-	-	-	-	-	-	30	10	12	-	36
REAGENT "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SO ₂ "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SLUDGE "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
H ₂ O "	72	86	86	258	82	1	-	-	9	3	428	143	142	2	426
TOTAL "	72	86	86	258	82	1	6258	1042	9	3	595	199	214	2	642
% SOLIDS	0	0	0	0	0	0	<3	~30	0	0	28	28	33	0	33

(To convert from °F to K, multiply by 5/9, and add 255.37; to convert from IN. H₂O to kPa, multiply by .2488 and add 101.325; to convert from 10³ ACFM to m³/s, multiply by .4720; to convert from 10³ #/HR to kg/s, multiply by .1260; to convert from GPM to m³/s, multiply by 6.31 x 10⁻⁵)

FIGURE 7-2A

WELLMAN-LORD SYSTEM PROCESS FLOW BALANCE, PART 1

STREAM NO.	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54
TEMP. °F.	-	-	250	200	200	200	-	388	-	-	-	200	-	-	-
GPM (PSIG)	647	355	(15)	78	-	22	-	(200)	7	-	10	281	291	938	563
Na ₂ SO ₃ 10 ³ #/HR	29	16	-	-	-	2	2	-	-	2	-	16	16	45	27
NaHSO ₃ "	87	48	-	-	-	2	-	-	-	-	2	41	43	130	78
Na ₂ SO ₄ "	22	12	-	-	-	4	4	-	-	4	-	9	9	31	19
REAGENT "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SO ₂ "	-	-	-	-	1	-	-	-	-	-	-	-	-	-	-
SLUDGE "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
H ₂ O "	276	152	39	39	31	6	2	3	3	-	4	115	119	395	237
TOTAL "	414	227	39	39	32	14	8	3	3	6	6	181	187	601	361
% SOLIDS	33	33	0	0	0	40	70	0	0	100	38	36	36	34	34

STREAM NO.	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69
TEMP. °F.	250	200	200	200	-	200	170	170	170	170	170	85	105	-	250
GPM (PSIG)	(15)	515	-	-	375	-	-	-	-	-	-	20900	20900	310	(15)
Na ₂ SO ₃ 10 ³ #/HR	-	-	65	-	18	-	-	-	42	-	-	-	-	-	-
NaHSO ₃ "	-	-	17	-	52	-	-	-	12	-	-	-	-	-	-
Na ₂ SO ₄ "	-	-	18	-	12	-	-	-	12	-	-	-	-	-	-
REAGENT "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SO ₂ "	-	-	-	19	-	20	<1	20	-	13	33	-	-	<1	-
SLUDGE "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
H ₂ O "	257	257	42	200	158	231	172	57	29	133	190	10450	10450	155	4
TOTAL "	257	257	142	219	240	251	173	77	95	146	223	10450	10450	155	4
% SOLIDS	0	0	70	0	34	0	0	0	70	0	0	0	0	0	0

STREAM NO.	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85
TEMP. °F.	-	-	-	60	-	-	-	-	-	85	105	-	85	105	-	-
GPM	733	697	36	-	38	-	-	-	-	4575	4575	-	924	924	-	-
Na ₂ SO ₃ 10 ³ #/HR	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
NaHSO ₃ "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Na ₂ SO ₄ "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
REAGENT "	-	-	-	5	5	-	-	-	-	-	-	-	-	-	-	-
SO ₂ "	-	-	-	-	-	33	<1	33	<<1	-	-	33	-	-	<<1	33
SLUDGE "	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
INERTS "	-	-	-	<1	<1	-	-	-	-	-	-	-	-	-	-	-
H ₂ O "	366	348	18	-	18	35	5	40	32	2286	2286	8	462	462	6	2
TOTAL "	366	348	18	5	23	68	5	73	32	2286	2286	41	462	462	6	35
% SOLIDS	0	0	0	100	20	0	0	0	0	0	0	0	0	0	0	0

(To convert from °F to K, multiply by 5/9 and add 255.37; to convert from IN. H₂O to kPa, multiply by .2488 and add 101.325; to convert from 10³ ACFM to m³/s, multiply by .4720; to convert from 10³ #/HR to kg/s, multiply by .1260; to convert from GPM to m³/s, multiply by 6.31 x 10⁻⁵)

FIGURE 7-2B

WELLMAN-LORD SYSTEM PROCESS FLOW BALANCE, PART 2





FIGURE 7-3
WELLMAN-LORD SYSTEM SULFUR & SULFURIC ACID PLANTS
PROCESS FLOW DIAGRAM

7.A.2. EQUIPMENT DESCRIPTION

Equipment required for the Wellman-Lord System is divided into several major cost and process areas as follows:

- Area 01 - Raw Material Receiving and Storage
- Area 02 - Feed Preparation and Storage
- Area 03 - Flue Gas Scrubbing
- Area 04 - Flue Gas Reheat
- Area 05 - Purge Treatment
- Area 06 - SO₂ Regeneration
- Area 07 - SO₂ Processing
- Area 10 - Byproduct Storage
- Area 11 - Flue Gas Handling
- Area 12 - Waste Transfer and Placement

An equipment list including descriptive information and cost data is presented as Appendix D.

7.A.2.a. Area 01 - Raw Material Receiving and Storage

Soda ash is received in pneumatic railcar or truck and is stored as a slurry in the slurry storage tank prior to transfer to the process. Lime for prescrubber purge neutralization and fixative is also received in pneumatic railcar or truck and stored in a silo prior to pneumatic transfer to the process.

7.A.2.b. Area 02 - Feed Preparation and Storage

Sodium carbonate solution is pumped from the slurry storage tank to the process as required. A lime day bin and feeders supply lime to one of two 100 percent capacity lime slakers. The lime slurry is stored in a tank prior to pumping to the prescrubber purge neutralization tank as required.

7.A.2.c Area 03 - Flue Gas Scrubbing

The prescrubbers (3 operating and 1 spare) are low pressure drop venturi's with rubber-lined recirculation pumps. A chloride removal section with recirculation pumps is located between the prescrubbers and absorbers. The prescrubbed flue gas passes through vertical chevron mist eliminators before entering the absorbers.

The absorbers (3 operating and 1 spare) are vertical valve tray towers with three levels of trays. Each tray has its own recirculation pump. The scrubbed flue gas passes through vertical chevron mist eliminators prior to leaving the absorbers.

The spent absorber product liquor is pumped from the base of the absorbers to a common absorber product surge tank. The spent absorbent passes through a fly ash filter before entering the product surge tank. The absorber product is pumped from the surge tank to the regeneration area. An absorber feed surge tank and pumps are provided to receive regenerated absorber solution from the regeneration area prior to transfer to the absorbers.

The solution level in the absorber feed tank is maintained as high as practical, and the level in the absorber product tank is maintained as low as practical in normal operation. This mode of operation isolates the regeneration section from the effects of load swings in the generating plant, and permits routine maintenance of downstream areas to be performed without interrupting the SO₂ removal function of the absorber section.

Necessary ancillary equipment items included in this area are the makeup water tank and pumps, seal water tank, filter, and pumps, and the instrument and service air compressor system.

7.A.2.d. Area 04 - Flue Gas Reheat

The scrubbed gas from the absorbers is reheated 50F⁰ (28 K) in a reheat mix chamber. Ambient air is drawn via a reheat fan and is heated by finned tube steam coils which utilize both condensing and subcooling sections. The heated air is blown into the reheat mix chamber where it mixes with the scrubbed gas.

7.A.2.e. Area 05 - Purge Treatment

The Purge Treatment area involves the handling of two distinct purge streams. A purge stream from the prescrubber is neutralized and disposed and a purge stream from the absorber loop must be treated to remove sulfates.

The prescrubber purge streams from each prescrubber are pumped to a common purge tank. The combined purge streams are pumped to a neutralization tank where the purge is neutralized with lime. The neutralized purge stream is pumped to a thickener. The thickener overflow is returned to the system via

an overflow tank and pumps. The thickener underflow is pumped to a filter feed tank prior to mechanical dewatering by rotary drum vacuum filters. The filtrate is returned to the process. The filter cake is blended with lime and fly ash in a process mixer to form a solid waste. Fly ash is pneumatically conveyed from the plant fly ash silos to a day bin near the process. The fixative reagent (lime) is pneumatically conveyed from its storage silo to a day bin near the process mixer. The lime, fly ash, and filter cake are blended in a process mixer and conveyed to a truck loading spot. A stacker is provided to pile solid waste to provide surge capacity for periods when trucks are not operating.

The absorber sulfate purge stream is taken as a slipstream from the absorber product solution pumped to the regeneration area. The sulfate purge stream is pumped to a sulfate crystallizer which is a specially designed single-stage evaporator system. The crystallized sulfate stream is centrifuged to break up the crystals and remove trapped solution. The dewatered solids are passed through a dryer and stored in a sulfate product bin prior to removal by truck.

Area sumps, agitators, and pumps are also included in this area.

7.A.2.f. Area 06 - SO₂ Regeneration

The majority of the absorber product stream is routed to a double effect evaporator system where the sodium bisulfite (NaHSO₃) is thermally decomposed to sodium sulfite (Na₂SO₃) and sulfur dioxide (SO₂) gas. The Na₂SO₃ is sent to a dissolving tank where stripped condensate and makeup sodium carbonate (Na₂CO₃) are added. The regenerated solution is pumped back to the absorber feed surge tank in the flue gas treatment area. The SO₂-water vapor stream from the evaporators is condensed in two stages of condensers. The condensate is stripped and returned to the system in the dissolving tank. The concentrated SO₂ gas stream is compressed and delivered to the SO₂ Processing area.

7.A.2.g. Area 07 - SO₂ Processing

The concentrated SO₂ stream is processed to either sulfuric acid in a contact sulfuric acid plant or elemental sulfur in an Allied/Claus sulfur reduction plant. These plants were considered as complete units designed and supplied by a single source.

7.A.2.h. Area 10 - Byproduct Storage

Storage facilities are provided for 5-day storage of either sulfuric acid or molten sulfur depending on the SO₂ processing concept used.

7.A.2.i. Area 11 - Flue Gas Handling

Flue gas from the generating plant particulate removal system passes through one of two combined I.D./Booster Fans. The fans provide sufficient pressure for both the furnace draft and particulate removal system as well as the flow resistance of the prescrubbers, absorbers, and associated duct system to the chimney. The ductwork includes common inlet and outlet manifolds and total FGD system bypass if required. Dampers are provided for isolation of individual absorbers for maintenance or inspection.

7.A.2.j. Area 12 - Waste Transfer and Placement

The neutralized prescrubber purge stream waste solids from the process mixer are loaded on to off-highway trucks by either a shuttle loader (belt conveyor) or a front-end loader. The trucks transport the waste solids to a landfill disposal area approximately 1 mile (1.6 km) from the plant site. A bulldozer at the disposal area spreads and compacts the waste to an average depth of 30 feet (9.1 m). The loading, transfer, and landfill area equipment operates one shift only, 5 days per week.

7.A.3. GENERAL ARRANGEMENT

Figure 7-4 provides a basic view of the general arrangement of the Wellman-Lord System. The arrangement allows for the entire FGD System to be bypassed if required. The ductwork allows for turning vanes at each absorber inlet to minimize flue gas maldistribution. The arrangement is not necessarily optimized but the concept is consistent with the other processes evaluated.

7.A.4. RAW MATERIAL AND UTILITY CONSUMPTION

Table 7-2 lists raw material and utility consumptions by the Wellman-Lord System at maximum load.

7.A.5. WASTE DISPOSAL

The dewatered waste sludge from the neutralized prescrubber purge stream requires further stabilization prior to ultimate disposal. Fixative lime and fly ash from the particulate collection device are blended with the sludge in





FIGURE 7-4

PLOT PLAN OF WELLMAN-LORD FGD SYSTEM

TABLE 7-2

WELLMAN-LORD SYSTEM
RAW MATERIAL AND UTILITY CONSUMPTION
(MAXIMUM LOAD - 105%)

<u>Item</u>	<u>Quantity</u>
Soda Ash	2.5 t/h (0.63 kg/s)
Lime (Fixative and Neutralization)	1.8 t/h (0.45 kg/s)
Raw Water	525 gpm (0.03 m ³ /s)
Cooling Water	
FGD System	26,400 gpm (1.67 m ³ /s)
Sulfuric Acid Plant	4,500 gpm (0.28 m ³ /s)
Steam	439,000 lb/hr (55.3 kg/s)
Power (Operating Horsepower)*	
Area 01 - Raw Material Receiving and Storage	165 hp (123 kW)
Area 02 - Feed Preparation and Storage	50 hp (40 kW)
Area 03 - Flue Gas Scrubbing	3,700 hp (2800 kW)
Area 04 - Flue Gas Reheat	800 hp (600 kW)
Area 05 -Purge Treatment	530 hp (400 kW)
Area 06 - SO ₂ Regeneration	520 hp (390 kW)
Area 07 - SO ₂ Processing	
Sulfur Plant	.01 kWh/lb S (0.02 kWh/kg S)
Sulfuric Acid Plant	.023 kWh/lb acid (0.051 kWh/kg acid)
Area 10 - Byproduct Storage	50 hp (40 kW)
Area 11 - Flue Gas Handling	8,500 hp (6300 kW)
Steam Credit	
Sulfur Plant	20,300 lb/hr (2.56 kg/s)
Sulfuric Acid Plant	11,900 lb/hr (1.48 kg/s)
Methane (Sulfur Reduction Plant)	146 10 ³ ft ³ /hr (1.15 m ³ /s)

*Total FGD system power consumption equal to approximately 2.1 percent of net generating capacity.

a pug mill-type process mixer. The fixed sludge is more stable than the untreated sludge and is suitable for landfill impoundment. The components and maximum load quantity of blended sludge for disposal are as follows:

<u>Components</u>	<u>t/h</u>	<u>Wt %</u>
Lime	0.35	2
Fly Ash	7	49
Waste Sludge	4	28
Water	<u>3</u>	<u>21</u>
Total Waste to Disposal	14.35	100
t/h = 907.2 kg/h		

Based on a density of 95 lb/ft³ (1500 kg/m³), the following volumes are estimated for daily, yearly and plant life sludge production:

Daily Maximum - 270 yd³ (210 m³)
 Annual - 41 acre-ft (51,000 m³)
 Plant Life - 1250 acre-ft (1,540,000 m³)

7.B. TECHNICAL EVALUATION

The Wellman-Lord process is considered a wet recovery process producing a concentrated SO₂-rich off-gas which can be further processed to a saleable product. It is a fairly complex and sophisticated process, using a soluble sodium alkali to remove the SO₂ and thermal decomposition to recover an SO₂-rich off-gas. Sulfur is considered to be the most versatile end product from a storage and potential marketing viewpoint, but this option may be dependent on the availability of natural gas supplies. Processes using other reductants for the production of sulfur are in development, but are not considered commercial at this time.

Relative to limestone "throwaway processes" the Wellman-Lord process has several distinct advantages and disadvantages.

Advantages -

- The use of a soluble sodium alkali absorbent minimizes the potential for scaling and plugging in the absorber.
- A useful byproduct is recovered, minimizing disposal problems.

Disadvantages -

- It is a more complex system than the limestone systems and requires more skillful operators.
- A dry sodium sulfate/sodium sulfite purge stream is produced.
- It requires large quantities of steam either from the steam generator or an auxiliary boiler.

The Wellman-Lord process has been used successfully in several chemical process plants and oil-fired boilers. Coal-fired boiler application of the process include a 115 MW unit at Northern Indiana Public Service Company's D. H. Mitchell Station and Public Service Company of New Mexico's San Juan Station, where two 350 MW units have been completed and two 560 MW units are under construction.

7.C. ECONOMIC EVALUATION

The economic evaluation of the Wellman-Lord System is presented in the following tables:

Table 7-3 - Total Capital Requirement

Table 7-4A,B - Operating Costs

Table 7-5 - Levelized Busbar Cost

Cost sensitivity to coal %-sulfur and plant size was determined by adjusting capital and operating costs and reevaluating levelized busbar cost. Cost sensitivity to coal %-sulfur is illustrated in Figure 7-5 and to plant size in Figure 7-6.

A byproduct credit has been considered for the sale of either sulfur or sulfuric acid in the economic analysis as shown in Tables 7-4 and 7-5. The cost sensitivity curves, however, are based on no byproduct credit.

These curves are based on two additional estimates for the system for each parameter. Costs were adjusted to values for 0.5 percent and 2.0 percent sulfur coal and for 250 MW and 1000 MW plant sizes. These values, combined with the base case value, were used to plot the cost sensitivity curves.

TABLE 7-3

WELLMAN-LORD SYSTEM
TOTAL CAPITAL REQUIREMENT
500 MW NEW PLANT
MID-1978 COSTS, MID-1979 STARTUP
ILLINOIS COAL - 4% SULFUR

Process Capital

<u>Area</u>	<u>Description</u>	Byproduct Options	
		<u>Sulfuric Acid</u> <u>\$/Kw</u>	<u>Sulfur</u> <u>\$/Kw</u>
01	Raw Material Receiving and Storage	3.5	3.5
02	Feed Preparation and Storage	0.6	0.6
03	Flue Gas Scrubbing	50.1	50.1
04	Flue Gas Reheat	7.3	7.3
05	Purge Treatment	16.1	16.1
06	SO ₂ Regeneration	33.4	33.4
07	SO ₂ Processing	25.1	16.9
10	Byproduct Storage	8.0	3.1
11	Flue Gas Handling	25.4	25.4
12	Waste Transfer and Placement	<u>1.4</u>	<u>1.4</u>
	Total Process Capital	170.9	157.7
	General Facilities	21.4	19.7
	Engineering and Home Office Fees	21.4	19.7
	Project Contingency	8.5	7.9
	Process Contingency	8.5	7.9
	Sales Tax (Included in Process Capital)	<u>--</u>	<u>--</u>
	Total Plant Investment (TPI)	230.7	212.9
	Royalty Allowance	0.9	0.8
	Preproduction Costs	15.9	15.4
	Inventory Capital	0.4	0.4
	Initial Catalyst and Chemicals	--	--
	Allowance for Funds During Construction (AFDC)	18.5	17.0
	Land	<u>1.0</u>	<u>1.0</u>
	Total Capital Requirement (TCR)	267.4	247.5

TABLE 7-4A

WELLMAN-LORD SYSTEM
 FIXED OPERATING COSTS
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 STARTUP
 ILLINOIS COAL - 4% SULFUR

<u>Fixed Operating Costs</u>	<u>Sulfuric Acid Plant</u>			<u>Sulfur Plant</u>		
	<u>1st Year</u> <u>\$/Yr</u>	<u>1st Year</u> <u>\$/kW Yr</u>	<u>Levelized</u> <u>\$/kW-Yr</u>	<u>1st year</u> <u>\$/Yr</u>	<u>1st year</u> <u>\$/kW-Yr</u>	<u>Levelized</u> <u>\$/kW-Yr</u>
Operating Labor						
FGD System	\$1,410,000	2.83	5.34	\$1,410,000	2.83	5.34
Sludge Disposal	78,000	0.16	0.30	78,000	0.16	0.30
Maintenance Labor	2,730,000	5.47	10.31	2,520,000	5.04	9.51
Maintenance Material	4,090,000	8.18	15.43	3,780,000	7.56	14.26
Admin. & Support Labor	1,260,000	2.52	4.75	1,200,000	2.40	4.53
Disposal Equipment	<u>38,000</u>	<u>0.08</u>	<u>0.15</u>	<u>38,000</u>	<u>0.08</u>	<u>0.15</u>
	\$9,600,000	19.24	36.28	\$9,026,000	18.05	34.04

TABLE 7-4B

WELLMAN-LORD SYSTEM
 VARIABLE OPERATING COSTS
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 STARTUP
 ILLINOIS COAL - 4% SULFUR

Variable Operating Costs	Sulfuric Acid Plant			Sulfur Plant		
	1st Year \$/Yr	1st Year Mills/kWh	Levelized Mills/kWh	1st year \$/Yr	1st year Mills/kWh	Levelized Mills/kWh
Soda Ash - 14,100 t/y @ \$66/ton	\$ 930,000	0.30	0.57	\$ 930,000	0.30	0.57
Lime - 8800 t/y @ \$34/ton	300,000	0.10	0.19	300,000	0.10	0.19
Raw Water - 184,000 x 10 ³ /gal/yr @ \$0.40/10 ³ gal	74,000	0.02	0.05	74,000	0.02	0.05
Methane - 853,000 MCF/yr @ \$4/MCF	-	-	-	3,410,000	1.11	2.14
Cooling Water						
FGD System 9,250,000 x 10 ³ gal/yr @ \$0.10/10 ³ gal	925,000	0.30	0.57	925,000	0.30	0.57
Acid Plant 1,600,000 x 10 ³ gal/yr @ \$0.10/10 ³ gal	160,000	0.05	0.10	-	-	-

Note: 1.0 t/y = 9.071 x 10² kg/y
 1.0 gal = 3.785 x 10⁻³ m³

TABLE 7-4B (Continued)

WELLMAN-LORD SYSTEM
 VARIABLE OPERATING COSTS
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 STARTUP
 ILLINOIS COAL - 4% SULFUR

Variable Operating Costs (Continued)		Sulfuric Acid Plant			Sulfur Plant		
		Ist Year \$/Yr	Ist Year Mills/kWh	Levelized Mills/kWh	Ist year \$/Yr	Ist year Mills/kWh	Levelized Mills/kWh
Steam (Levelized Cost)							
FGD System	2,560,000 x 10 ³ lb./yr @ \$3.49/10 ³ lb	-	-	2.91	-	-	2.91
Acid Plant	120,000 x 10 ³ lb./hr @ \$3.49/10 ³ lb (credit)	-	-	(0.14)	-	-	-
Sulfur Plant	70,000 x 10 ³ lb/yr @ \$3.49/10 ³ lb (Credit)	-	-	-	-	-	(0.08)
Power							
FGD System	65 x 10 ⁶ kWh/yr @ 30 mills/kWh	1,960,000	0.64	1.22	1,960,000	0.64	1.22
Acid Plant	7.6 x 10 ⁶ kWh/yr @ 30 mills/kWh	230,000	0.07	0.14	-	-	-
Sulfur Plant	1.0 x 10 ⁶ kWh/yr @ 30 mills/kWh	-	-	-	30,000	0.01	0.02

Note: 1.0 t/y = 9.071 X 10² kg/y

TABLE 7-4B (Continued)

WELLMAN-LORD SYSTEM
 VARIABLE OPERATING COSTS
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 STARTUP
 ILLINOIS COAL - 4% SULFUR

Variable Operating Costs (Continued)	Sulfuric Acid Plant			Sulfur Plant		Levelized Mills/kWh
	1st Year \$/Yr	1st Year Mills/kWh	Levelized Mills/kWh	1st year \$/Yr	1st year Mills/kWh	
Power (Continued)						
Fly Ash 43,000 t/y @ \$4.00/ton (credit)	(172,000)	(0.06)	<u>(0.11)</u>	(172,000)	(0.06)	<u>(0.11)</u>
Total Variable Operating Cost			5.5			7.48
<u>Byproduct Credit</u>						
Sulfuric Acid (100% basis) 147,000 t/y @ \$40/ton	(\$5,880,000)	(1.92)	(3.62)			
Sulfur 43,000 t/y @ \$50/long ton	(\$2,150,000)	(0.70)	(1.32)			

Note: 1.0 t/y = 9.071 X 10² kg/y

TABLE 7-5

WELLMAN-LORD SYSTEM
 LEVELIZED BUSBAR COST
 500 MW NEW PLANT
 MID-1978 COSTS, MID-1979 STARTUP
 ILLINOIS COAL - 4% SULFUR

	<u>Levelized Mills/kWh</u>	
	Byproduct Option	
	<u>Sulfuric Acid</u>	<u>Sulfur</u>
Process Capital	5.02	4.63
General Facilities	0.63	0.58
Engineering and Home Office Fees	0.63	0.58
Project Contingency	0.25	0.22
Process Contingency	<u>0.25</u>	<u>0.22</u>
Total Plant Investment	6.78	6.23
Royalty Allowance	0.03	0.02
Preproduction Costs	0.47	0.45
Inventory Capital	0.01	0.01
Allowance For Funds During Construction (AFDC)	0.54	0.50
Land	<u>0.03</u>	<u>0.03</u>
Total Capital Requirement	7.86	7.24
Fixed Operating Cost	5.92	5.55
Variable Operating Cost	<u>5.5</u>	<u>7.48</u>
Total Levelized Busbar Cost	<u>19.3</u>	<u>20.3</u>
Byproduct Credit	<u>(3.62)</u>	<u>(1.32)</u>
Total Levelized Busbar Cost Adjusted for Byproduct Credit	15.7	19.0




FIGURE 7-5

WELLMAN-LORD SYSTEM
 COST VERSUS SULFUR CONTENT OF COAL
 (No Byproduct Credit)




FIGURE 7-6
 WELLMAN-LORD SYSTEM
 COST VERSUS PLANT SIZE
 (No Byproduct Credit)

Appendix A

CONVENTIONAL LIMESTONE SYSTEM EQUIPMENT LIST

AREA 01 - RAW MATERIAL RECEIVING AND STORAGE

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Limestone Receiving System</u>	1 Lot	\$362,000	\$362,000
Service: Limestone receiving area, - 3/4" limestone			
Includes: 1-two railcar covered spot 4-50-ton, below-rail hoppers 4-vibratory feeders, 10 HP 2-24" x 75' feed belts, 10 HP 1-24" x 200', 10% inclined belt, 10 HP 1-4000 ACFM baghouse, 10 HP			
<u>Limestone Bulk Storage Transfer System</u>	1 Lot	\$147,000	\$147,000
Service: Transfer of limestone from unloading area to bulk storage pile			
Includes: 1-24" x 100', 10% inclined belt, 10 HP 1-24" x 200' horizontal belt, 10 HP 1-24" x 150' mobile stacker, 20 HP 1-10,000 ACFM baghouse, 20 HP			
<u>Live Storage Load Hopper</u>	2	\$ 32,000	\$ 64,000
Size: 25' x 25' x 20' straight side with sloped bottom Service: -3/4" limestone Capacity: 200 tons Material: Carbon steel			
<u>Limestone Live Storage Transfer System</u>	1 Lot	\$114,000	\$114,000
Service: Transfer of limestone from bulk storage to top of limestone day bin			
Includes: 1-24" x 300', 15% inclined belt, 10 HP motor			

AREA 01 RAW MATERIAL RECEIVING AND STORAGE (Continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
2-24" x 100', feed conveyor belts, 10 HP motor 1-4000 ACFM baghouse, 10 HP motor			
<u>Fixative Reagent Storage Silo</u>	1	\$149,000	\$149,000
Dimensions: 30' dia. x 75' straight side with conical bottom			
<u>Fixative Reagent Storage Silo</u>	1	\$149,000	\$149,000
Dimensions: 30' dia. x 75' straight side with conical bottom Retention: 30 days Material of Construction: Steel-reinforced concrete Accessories: Combination rail and truck receiving spot for pneumatic unloading			
<u>Fixative Storage Silo Baghouse</u>	1	\$ 47,000	\$ 47,000
Type: Pulse-jet Air Flow: 10,000 ACFM Material: Carbon steel Blower Motor: 20 HP Accessories: Compressor and blowers			
<u>Fixative Pneumatic Conveyor System</u>	2	\$ 16,700	\$ 33,400
Type: Pneumatic Service: Granular quicklime Solids Rate: 30 TPH Air Rate: 3000 ACFM Transfer Lines: 6", 300' long Blower Motor: 50 HP			
Area 01 Total Equipment Cost = \$916,000			

AREA 02 - FEED PREPARATION AND STORAGE

<u>Limestone Day Bin</u>	4	\$ 42,000	\$168,000
Size: 16' dia. x 40' straight side, 70° cone bottom Service: -3/4" limestone Sizing Criteria: Total storage equal to 30-hr. surge at maximum continuous consumption Material: Carbon steel Accessories: Displacement filter, bin discharger			

AREA 02 FEED PREPARATION AND STORAGE (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Limestone Vibratory Feeder</u>	4	\$ 6,000	\$ 24,000
Type: Vibratory			
Service: -3/4" limestone			
Motor: 20 HP			
<u>Limestone Feeder</u>	2	\$ 10,000	\$ 20,000
Type: Weigh belt gravimetric feeder			
Service: -3/4" limestone			
Motor: 3 HP			
<u>Ball Mill & Classifier System</u>	2	\$400,000	\$800,000
Service: -3/4" limestone			
Grind: 90 wt % - 200 mesh			
Feed Rate: 36 TPH limestone			
Construction: Carbon steel with Chrome-molybdenum liner			
Motor: 1000 HP			
<u>Limestone Grind Tank</u>	2	\$ 32,500	\$ 65,000
Size: 16' dia. x 20' straight side			
Service: 60 wt % solids limestone slurry			
Material: Rubber-lined carbon steel			
Normal Level: 12'			
Accessories: Agitator bridge			
<u>Limestone Grind Tank Agitator</u>	2	\$ 5,500	\$ 11,000
Tank Size: 16' dia. x 20' straight side			
Service: 60 wt % limestone slurry			
Normal Level: 12'			
Motor: 15 HP			
<u>Limestone Grind Tank Slurry Pump</u>	2	\$ 2,000	\$ 4,000
Type: Horizontal centrifugal			
Material: Rubber-lined cast iron			
Flow: 150 GPM			
Head: 50' TDH			
Motor: 7.5 HP			
<u>Limestone Slurry Tank</u>	3	\$ 80,000	\$240,000
Size: 25' dia. x 25' straight side			
Service: 20 wt % limestone slurry			
Sizing Criteria: Total capacity to equal 8-hr. surge at maximum continuous consumption			

AREA 02 - FEED PREPARATION AND STORAGE (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Material: Carbon steel Normal Level: 20' Accessory: Agitator bridge, 50% height wear-ring			
<u>Limestone Slurry Tank Agitator</u>	3	\$ 6,000	\$ 18,000
Tank Size: 25' dia. x 25' straight side Service: 20 wt % limestone slurry Normal Level: 20' Motor: 15 HP			
<u>Limestone Slurry Pump</u>	2	\$ 3,000	\$ 6,000
Type: Horizontal centrifugal Material: Rubber-lined cast iron Flow: 630 GPM Head: 100' TDH Motor: 40 HP			

Area 02 Total Equipment Cost = \$1,360,000

AREA 03 - FLUE GAS SCRUBBING

<u>Absorber Tower</u>	4	\$970,00	\$3,880,000
Type: Vertical countercurrent spray tower Dimensions: 38' I.D. x 110' straight side with 16' diameter outlet cap Material of Construction: 317L stainless steel Internal Superficial Gas Velocity: 10 fps Mist Eliminator: Vertical chevron, 20 fps maximum design velocity			
<u>Spray Pump</u>	16	\$25,000	\$400,000
Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 11,000 GPM Head: 100' TDH Motor: 400 HP			
<u>Reaction Mix Tank</u>	4	\$160,000	\$640,000
Size: 35' dia. x 36' straight side Service: 10 wt % scrubber slurry Sizing Criteria: 6 minute retention of recirculated flow rate Material: Rubber-lined carbon steel Normal Level: 30' Accessories: Agitator bridge			

AREA 03- FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Reaction Mix Tank Agitator</u>	4	\$ 16,000	\$ 64,000
Tank Size: 36' dia. x 36' straight side Service: 10 wt % scrubber slurry Normal Level: 30' Motor: 20 HP			
<u>Makeup Water Tank</u>	1	\$ 50,000	\$ 50,000
Size: 25' dia. x 25' straight side Service: Water Sizing Criteria: 2-hr. surge capacity at estimated maximum consumption Material: Carbon steel Normal Level: 20'			
<u>Makeup Water Pump</u>	2	\$ 8,500	\$ 17,000
Type: Horizontal centrifugal Material: Cast steel Flow: 700 GPM Pressure: 125 psi Motor: 85 HP			
<u>Seal Water Tank</u>	1	\$ 22,500	\$ 22,500
Size: 15' dia. x 15' straight side Service: Water Sizing Criteria: 2-hr. surge capacity Material: Carbon steel Normal Level: 10'			
<u>Seal Water Filter Unit</u>	1	\$ 6,000	\$ 6,000
Type: Cartridge (fiber) filter Service: Makeup water Capacity: 175 GPM Power Required: 10 HP			
<u>Seal Water Pump</u>	2	\$ 1,800	\$ 3,600
Type: Horizontal centrifugal Material: Cast steel Flow: 160 GPM Pressure: 125 psi Motor: 40 HP			
<u>Instrument/Plant Air Compressor System</u>	2	\$ 90,000	\$ 180,000
Type: Multi-stage, centrifugal air compressor unit complete with control unit, motor driver, and			

AREA 03 -FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
instrument air-dryer, pre-filter, after-filter, after-cooler, and air receivers Service: Air Air-Dryer Power Consumption: 9.9 kW Motor: 700 HP			

Area 03 Total Equipment Cost = \$5,260,000

AREA 04 - FLUE GAS REHEAT

<u>Reheat Air Fan</u>	1	\$125,000	\$125,000
Conditions: 343,300 ACFM @ 10" WC 60°F air Type: Air-foil centrifugal fan with variable inlet vanes for flow control Motor: 800 HP			

<u>Reheat Steam Coil Air Heater</u>	1	\$150,000	\$150,000
Type: Finned Tube Steam Coil - includes condensing and subcooling sections Service: Air heater Duty: 125 x 10 ⁶ Btu/HR			

<u>Reheat Mix Chamber</u>	1	\$310,000	\$310,000
Service: Flue gas Material: 316L stainless steel Size: 27' x 27' x 27' total length			

<u>Reheat Duct</u>	1 Lot		\$244,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel Size: 11'-3" x 11'-3" x 25' total length			

<u>Reheat Isolation Damper</u>	1	\$ 80,000	\$ 80,000
Type: Double-louver system, opposed-blade for control/parallel blade for tight shutoff with purge air blower Service: Air and flue gas (382°F maximum temperature) Materials: Stainless steel Duct Size: 11'3" x 11'3"			

Area 04 Total Equipment Cost = \$909,000

AREA 08 - WASTE SEPARATION

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Thickener System</u> Size: 150' dia. Service: Scrubber sludge Sizing Criteria: 18 ft ² /TPD dry solids Materials: Epoxy coated carbon steel rake/bridge, carbon steel shell, concrete bottom Motor: 25 HP Accessories: Tunnel, feed launder, personnel bridge	1	\$150,000	\$150,000
<u>Flocculant System</u> Includes mixing tank, multiple metering pumps, agitator, water booster pumps, and local controls Power Required: 10 HP	1	\$ 10,000	\$ 10,000
<u>Thickener Overflow Tank</u> Size: 25' dia. x 12' straight side Service: Water Sizing Criteria: 30 min. surge capacity Material: Carbon steel Normal Level: 8'	1	\$ 33,000	\$ 33,000
<u>Thickener Overflow Pump</u> Type: Horizontal centrifugal Material: Cast steel Flow: 1900 GPM Pressure: 100 psi Motor: 200 HP	2	\$ 11,000	\$ 22,000
<u>Thickener Underflow Pump</u> Type: Progressive cavity, positive displacement Material: Cast iron housing; hardened stainless steel rotor; rubber stator Flow: 600 GPM Head: 50' TDH Motor: 15 HP	2	\$ 11,000	\$ 22,000
<u>Filter Feed Tank</u> Size: 25' dia. x 30' straight side Service: 25 wt % scrubber slurry Sizing Criteria: 4-hr. surge capacity Material: Carbon steel with reinforced	2	\$ 90,000	\$180,000

AREA 08 WASTE SEPARATION (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
polyester lining Normal Level: 15' Accessories: Agitator bridge			
<u>Filter Feed Tank Agitator</u>	2	\$ 16,500	\$ 33,000
Tank Size: 25' dia. x 30' straight side Service: 25 wt % scrubber slurry Normal Level: 20' Motor: 20 HP			
<u>Filter Feed Pump</u>	2	\$ 22,000	\$ 44,000
Type: Progressive cavity Material: Cast iron housing; hardened stainless steel rotor; rubber stator Flow: 900 GPM Pressure: 50 psi Motor: 50 HP			
<u>Vacuum Filter System</u>	3	\$105,000	\$315,000
Type: Face scraper rotary drum vacuum filter Size: 12' dia. x 12' wide cloth Sizing Criteria: 100 lb/hr/ft ² - dry solids basis Service: Scrubber sludge Accessories: Receiver, pumps, blower, and control panel Power Required: 130 HP			
<u>Filtrate Receiver Pump</u>	3	Price included in vacuum filter system	
Type: Horizontal centrifugal Material: Cast steel Flow: 325 GPM Pressure: 100' TDH Motor: 15 HP			
<u>Area Sump Pump</u>	16	\$ 2,700	\$ 43,200
Type: Vertical centrifugal Material: Rubber-lined carbon steel Flow: 100 GPM Head: 40'-60' TDH Motor: 7.5 HP			
<u>Area Sump Agitator</u>	8	\$ 1,300	\$ 10,400
For assorted area sumps of varied size and service			

AREA 08 WASTE SEPARATION (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Power Required: 1 HP ea.			
Area 08 Total Equipment Cost = \$863,000			

AREA 09 - WASTE DISPOSAL

<u>Fixative Day Bin</u>	1	\$ 21,000	\$ 21,000
Size: 16' dia. x 18' straight side, 70° cone bottom			
Service: Granular quicklime			
Sizing Criteria: 36-hr. storage capacity			
Material: Carbon steel			
Accessories: Baghouse & airlock			
<u>Fixative Weigh Feeder</u>	1	\$ 5,500	\$ 5,500
Type: Weigh belt gravimetric feeder			
Service: Granular quicklime			
Motor: 3 HP			
<u>Fly Ash Pneumatic Conveyor System</u>	2	\$ 89,000	\$178,000
Type: Pneumatic			
Service: Fly ash			
Solids Rate: 150 TPH			
Air Rate: 10,000 CFM			
Transfer Lines: 10", 700' long, abrasion resistant			
Blower Motor: 150 HP			
<u>Fly Ash Day Bin</u>	1	\$ 44,000	\$ 44,000
Size: 15' dia. x 45' straight side, 70° cone			
Service: Fly ash			
Sizing Criteria: 8-hr. storage capacity @ maximum load			
Material: Carbon steel			
Accessories: Baghouse & airlock			
<u>Fly Ash Weigh Feeder</u>	1	\$ 8,500	\$ 8,500
Type: Weigh belt gravimetric feeder			
Service: Fly ash			
Motor: 3 HP			
<u>Process Mixer System</u>	2	\$ 43,500	\$ 87,000
Type: Pug mill			
Service: Ash, sludge, sludge water, fixative lime			

AREA 09 - WASTE DISPOSAL (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Capacity: 300 Mlb/hr Motor: 150 HP			
<u>Waste Solids Conveyor</u>	2	\$13,000	\$ 26,000
Type: Belt Service: Waste solids Length: 40' Width: 24" Motor: 5 HP			
<u>Waste Solids Stacker</u>	1	\$ 59,000	\$ 59,000
Type: Inclined belt conveyor for stacking waste solids when hauling equipment not operating Service: Waste solids Length: 100' Width: 24" Motor: 10 HP			
<u>Waste Solids Shuttle Loader</u>	1	\$ 45,500	\$ 45,500
Type: Belt conveyor for direct loading of waste solids to trucks Service: Waste solids Length: 50' Width: 24" Motor: 10 HP			
<u>Waste Solids Conveyor Dust Collector</u>	2	\$ 5,000	\$ 10,000
Type: Pulse-jet fabric filter Air Flow: 1000 ACFM Material: Carbon steel Blower Motor: 3 HP			

Area 09 Total Equipment Cost = \$485,000

AREA 11 - FLUE GAS HANDLING

<u>I.D./Booster Fan</u>	2	\$415,000	\$830,000
Conditions: 950,000 ACFM @ 25" WC and 283°F Type: Armored radial tip, centrifugal fan with variable inlet vanes for flow control Motor: 5000 HP Apportioned to FGD System: 10" of 25" WC (10/25 = 0.4)		\$166,000	\$332,000

AREA 11 - FLUE GAS HANDLING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Inlet Ducting from I.D. Fan to Manifold</u>	2	\$113,000	\$226,000
Service: Flue gas Type: Circular to Rectangular Transition Materials: Carbon steel Size: 18' dia. x 75' total length			
<u>Inlet Ducting Manifold</u>	1 Lot		\$740,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel Size: Section 1 - 23' x 23' x 150' total length Section 2 - 19' x 19' x 50' total length Section 3 - 13' x 14' x 50' total length			
<u>Inlet Ducting to Scrubber Tower</u>	4	\$30,000	\$120,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel Size: 14' x 14' x 80' total length			
<u>Outlet Ducting Manifold</u>	1 Lot		\$920,000
Service: Scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: Section 1 - 21' x 21' x 100' total length Section 2 - 17' x 17' x 50' total length Section 3 - 12' x 12' x 50' total length			
<u>Outlet Ducting from Scrubber Tower</u>	4	\$142,000	\$568,000
Service: Scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: 12' x 12' x 120' total length			
<u>Bypass</u>	1	\$75,000	\$75,000
Service: Flue gas Type: Rectangular with external stiffeners			

AREA 11 - FLUE GAS HANDLING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Material: Carbon steel, acid resistant gunnite-lined Size: 22' x 22' x 25' total length			
<u>Chimney Transition</u>	1	\$150,000	\$150,000
Service: Reheated scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: 22' x 22' x 50' total length			
<u>I.D./Booster Fan Inlet Isolation Damper</u>	2	\$105,000	\$210,000
Type: Spade guillotine w/purge air Service: Flue gas (283°F) Materials: Carbon steel with stainless steel trim Duct Size: 18' diameter			
<u>Scrubber Inlet Isolation Damper</u>	4	\$ 61,000	\$244,000
Type: Duplex guillotine with purge air Service: Flue gas Materials: Carbon steel with stainless steel trim Duct Size: 14' x 14'			
<u>Scrubber Outlet Isolation Damper</u>	4	\$ 78,000	\$312,000
Type: Duplex guillotine with purge air Service: Scrubbed gas Materials: Carbon steel and nickel basemetal for wetted parts Duct Size: 12' x 12'			
<u>FGD System Bypass Damper</u>	1	\$ 90,000	\$ 90,000
Type: Double-louver, opposed blade & parallel blade w/purge air Service: Flue gas Materials: Carbon steel with stainless steel trim Duct Size: 21'3" x 21'3"			

Area 11 Total Equipment Cost = \$3,990,000

AREA 12 - WASTE TRANSFER AND PLACEMENT

<u>Waste Solids Loader</u>	1	\$165,000	\$165,000
Type: Wheel loader			

AREA 12 - WASTE TRANSFER AND PLACEMENT (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Bucket Capacity: 5 yd ³ Estimated Service Life: 10,000 hr Interim Replacement Book Life: 6 yrs Equivalent Capital Cost		\$425,000	\$425,000
<u>Waste Solids Transfer Truck</u>	4	\$220,000	\$880,000
Type: Off-highway truck Capacity: 22 yd ³ Estimated Service Life: 15,000 hr Interim Replacement Book Life: 7.5 yr Equivalent Capital Cost		\$485,000	\$1,940,000
<u>Waste Solids Landfill Bulldozer</u>	1	\$137,000	\$ 137,000
Type: Tracked bulldozer Estimated Service Life: 10,000 hr Interim Replacement Book Life: 6 yr Equivalent Capital Cost		\$353,000	\$ 353,000
Area 12 Total Equivalent Equipment Cost = \$2,720,000			

Blank

A-14

Appendix B

EPRI/TVA COCURRENT SYSTEM EQUIPMENT LIST

AREA 01 - RAW MATERIAL RECEIVING AND STORAGE

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Limestone Receiving System</u>	1 Lot	\$362,000	\$362,000
Service: Limestone receiving area, - 3/4" limestone			
Includes:			
1-two railcar covered spot			
4-50-ton, below-rail hoppers			
4-vibratory feeders, 10 HP			
2-24" x 75' feed belts, 10 HP			
1-24" x 200', 10% inclined belt, 10 HP			
1-4000 ACFM baghouse, 10 HP			
<u>Limestone Bulk Storage Transfer System</u>	1 Lot	\$147,000	\$147,000
Service: Transfer of limestone from unloading area to bulk storage pile			
Includes:			
1-24" x 100', 10% inclined belt, 10 HP			
1-24" x 200' horizontal belt, 10 HP			
1-24" x 150' mobile stacker, 20 HP			
1-10,000 ACFM baghouse, 20 HP			
<u>Live Storage Load Hopper</u>	2	\$ 32,000	\$ 64,000
Size: 25' x 25' x 20' straight side with sloped bottom			
Service: -3/4" limestone			
Capacity: 200 tons			
Material: Carbon steel			
<u>Limestone Live Storage Transfer System</u>	1 Lot	\$114,000	\$114,000
Service: Transfer of limestone from bulk storage to top of limestone day bin			
Includes:			
1-24" x 300', 15% inclined belt, 10 HP motor			
2-24" x 100', feed conveyor belts, 10 HP motor			
1-4000 ACFM baghouse, 10 HP motor			

AREA 01 - RAW MATERIAL RECEIVING AND STORAGE (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Fixative Reagent Storage Silo</u>	1	\$149,000	\$149,000
Dimensions: 30' dia. x 75' straight side with conical bottom Retention: 30 days Material of Construction: Steel-reinforced concrete Accessories: Combination rail and truck receiving spot for pneumatic unloading			
<u>Fixative Storage Silo Baghouse</u>	1	\$ 47,000	\$ 47,000
Type: Pulse-jet Air Flow: 3000 ACFM Material: Carbon steel Blower Motor: 20 HP Accessories: Compressor and blowers			
<u>Fixative Pneumatic Conveyor System</u>	2	\$ 16,700	\$ 33,400
Type: Pneumatic Service: Granular quicklime Solids Rate: 30 TPH Air Rate: 3000 ACFM Transfer Lines: 6", 300' long Blower Motor: 50 HP			

Area 01 Total Equipment Cost = \$916,000

AREA 02 - FEED PREPARATION AND STORAGE

<u>Limestone Day Bin</u>	4	\$ 48,000	\$192,000
Size: 18' dia. x 36' straight side, 70° cone bottom Service: -3/4" limestone Sizing Criteria: Total storage equal to 30-hr. surge at maximum continuous consumption Material: Carbon steel Accessories: Displacement filter, bin discharger			
<u>Limestone Vibratory Feeder</u>	4	\$ 6,000	\$ 24,000
Type: Vibratory Service: -3/4" limestone Motor: 20 HP			

AREA 02 - FEED PREPARATION AND STORAGE (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Limestone Feeder</u>	2	\$ 10,000	\$ 20,000
Type: Weigh belt gravimetric feeder Service: -3/4" limestone Motor: 3 HP			
<u>Ball Mill & Classifier System</u>	2	\$440,000	\$880,000
Service: -3/4" limestone Grind: 90 wt %, -200 mesh Feed Rate: 42 TPH limestone Construction: Carbon steel with Chrome-molybdenum liner Motor: 1200 HP			
<u>Limestone Grind Tank</u>	2	\$ 50,000	\$100,000
Size: 22' dia. x 24' straight side Service: 60 wt % solids limestone slurry Material: Rubber-lined carbon steel Normal Level: 16' Accessories: Agitator bridge			
<u>Limestone Grind Tank Agitator</u>	2	\$ 5,500	\$ 11,000
Tank Size: 22' dia. x 24' straight side Service: 60 wt % limestone slurry Normal Level: 16' Motor: 15 HP			
<u>Limestone Grind Tank Slurry Pump</u>	2	\$ 2,000	\$ 4,000
Type: Horizontal centrifugal Material: Rubber-lined cast iron Flow: 170 GPM Head: 50' TDH Motor: 7.5 HP			
<u>Limestone Slurry Tank</u>	3	\$ 87,000	\$261,000
Size: 26' dia. x 26' straight side Service: 20 wt % limestone slurry Sizing Criteria: Total capacity to equal 8-hr. surge at maximum continuous consumption Material: Carbon steel Normal Level: 21' Accessory: Agitator bridge, 50% height wear-ring			

AREA 02 FEED PREPARATION AND STORAGE (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Limestone Slurry Tank Agitator</u>	3	\$ 6,000	\$ 18,000
Tank Size: 26' dia. x 26' straight side Service: 20 wt % limestone slurry Normal Level: 21' Motor: 15 HP			
<u>Limestone Slurry Pump</u>	2	\$ 3,000	\$ 6,000
Type: Horizontal centrifugal Material: Rubber-lined cast iron Flow: 710 GPM Head: 100' TDH Motor: 40 HP			

Area 02 Total Equipment Cost = \$1,520,000

AREA 03 - FLUE GAS SCRUBBING

<u>Absorber Tower</u>	4	\$800,000	\$3,200,000
Type: Vertical cocurrent spray tower with grid packing Dimensions: 22' I.D. x 120' straight side Material of Construction: 317L stainless steel Internal Gas Velocity: 27 fps Mist Eliminator: Vertical chevron, 20 fps maximum design velocity			
<u>Spray Pump</u>	24	\$ 24,000	\$ 576,000
Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 10,000 GPM Head: 100' TDH Motor: 400 HP			
<u>Reaction Mix Tank</u>	4	\$165,000	\$ 660,000
Size: 36' dia. x 36' straight side Service: 10 wt % scrubber slurry Sizing Criteria: 6 minute retention of recirculated flow rate Material: Rubber-lined carbon steel Normal Level: 30' Accessories: Agitator bridge			
<u>Reaction Mix Tank Agitator</u>	4	\$ 16,000	\$ 64,000
Tank Size: 36' dia. x 36' straight side Service: 10 wt % scrubber slurry			

AREA 03- FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Air-Dryer Power Consumption: 9.9 kW Motor: 700 HP			

Area 03 Total Equipment Cost = \$4,780,000

AREA 04 - FLUE GAS REHEAT

<u>Reheat Air Fan</u>	1	\$125,000	\$125,000
Conditions: 343,300 ACFM @ 10" WC 60°F air			
Type: Air-foil centrifugal fan with variable inlet vanes for flow control			
Motor: 800 HP			
<u>Reheat Steam Coil Air Heater</u>	1	\$150,000	\$150,000
Type: Finned Tube Steam Coil - includes condensing and subcooling sections			
Service: Air heater			
Duty: 125 x 10 ⁶ Btu/HR			
<u>Reheat Mix Chamber</u>	1	\$310,000	\$310,000
Service: Flue gas			
Material: 316L stainless steel			
Size: 27' x 27' x 27' total length			
<u>Reheat Duct</u>	1 Lot		\$150,000

Service: Flue gas			
Type: Rectangular with external stiffeners			
Material: Carbon steel			
Size: 11'-3" x 11'-3" x 15' total length			
<u>Reheat Isolation Damper</u>	1	\$ 80,000	\$ 80,000
Type: Double-louver system, opposed-blade for control/parallel blade for tight shutoff with purge air blower			
Service: Air and flue gas (382°F maximum temperature)			
Materials: Stainless steel			
Duct Size: 11'3" x 11'3"			

Area 04 Total Equipment Cost = \$815,000

AREA 08 - WASTE SEPARATION

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Thickener System</u>	1	\$180,000	\$180,000
Size: 170' dia. Service: Scrubber sludge Sizing Criteria: 18 ft ² /TPD dry solids Materials: Epoxy coated carbon steel rake/bridge, carbon steel shell, concrete bottom Motor: 25 HP Accessories: Tunnel, feed launder, personnel bridge			
<u>Flocculant System</u>	1	\$ 10,000	\$ 10,000
Includes mixing tank, multiple metering pumps, agitator, water booster pumps, and local controls Power Required: 10 HP			
<u>Thickener Overflow Tank</u>	1	\$ 38,000	\$ 38,000
Size: 28' dia. x 12' straight side Service: Water Sizing Criteria: 30 min. surge capacity Material: Carbon steel Normal Level: 8'			
<u>Thickener Overflow Pump</u>	2	\$ 11,500	\$ 23,000
Type: Horizontal centrifugal Material: Cast steel Flow: 2055 GPM Pressure: 100 psi Motor: 200 HP			
<u>Thickener Underflow Pump</u>	2	\$ 12,000	\$ 24,000
Type: Progressive cavity, positive displacement Material: Cast iron housing; hardened stainless steel rotor; rubber stator Flow: 670 GPM Head: 50' TDH Motor: 15 HP			
<u>Filter Feed Tank</u>	1	\$137,000	\$137,000
Size: 36' dia. x 36' straight side Service: 25 wt % scrubber slurry Sizing Criteria: 4-hr. surge capacity Material: Carbon steel with reinforced			

AREA 08 WASTE SEPARATION (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
polyester lining Normal Level: 20' Accessories: Agitator bridge			
<u>Filter Feed Tank Agitator</u>	1	\$ 20,000	\$ 20,000
Tank Size: 36' dia. x 36' straight side Service: 25 wt % scrubber slurry Normal Level: 20' Motor: 20 HP			
<u>Filter Feed Pump</u>	2	\$ 23,000	\$ 46,000
Type: Progressive cavity Material: Cast iron housing; hardened stainless steel rotor; rubber stator Flow: 995 GPM Pressure: 50 psi Motor: 50 HP			
<u>Vacuum Filter System</u>	3	\$120,000	\$360,000
Type: Face scraper rotary drum vacuum filter Size: 12' dia. x 14' wide cloth Sizing Criteria: 100 lb/hr/ft ² - dry solids basis Service: Scrubber sludge Accessories: Receiver, pumps, blower, and control panel Power Required: 125 HP			
<u>Filtrate Receiver Pump</u>	3	Price included in vacuum filter system	
Type: Horizontal centrifugal Material: Cast steel Flow: 360 GPM Pressure: 100' TDH Motor: 15 HP			
<u>Area Sump Pump</u>	16	\$ 2,700	\$ 43,200
Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 100 GPM Head: 40'-60' TDH Motor: 7.5 HP			
<u>Area Sump Agitator</u>	8	\$ 1,300	\$ 10,400
For assorted area sumps of varied size and services Power Required: 1 HP ea.			

Area 08 Total Equipment Cost = \$892,000

AREA 09 - WASTE DISPOSAL

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Fixative Day Bin</u>	1	\$ 21,000	\$ 21,000
Size: 16' dia. x 18' straight side, 70° cone bottom Service: Granular quicklime Sizing Criteria: 36-hr. storage capacity Material: Carbon steel Accessories: Baghouse & airlock			
<u>Fixative Weigh Feeder</u>	1	\$ 5,500	\$ 5,500
Type: Weigh belt gravimetric feeder Service: Granular quicklime Motor: 3 HP			
<u>Fly Ash Pneumatic Conveyor System</u>	2	\$ 89,000	\$178,000
Type: Pneumatic Service: Fly ash Solids Rate: 150 TPH Air Rate: 10,000 CFM Transfer Lines: 10", 700' long, abrasion resistant Blower Motor: 150 HP			
<u>Fly Ash Day Bin</u>	1	\$ 44,000	\$ 44,000
Size: 15' dia. x 45' straight side, 70° cone Service: Fly ash Sizing Criteria: 8-hr. storage capacity @ maximum load Material: Carbon steel Accessories: Baghouse & airlock			
<u>Fly Ash Weigh Feeder</u>	1	\$ 8,500	\$ 8,500
Type: Weigh belt gravimetric feeder Service: Fly ash Motor: 3 HP			
<u>Process Mixer System</u>	2	\$ 43,500	\$ 87,000
Service: Ash, sludge, sludge water, fixative lime Capacity: 300 Mlb/hr Motor: 150 HP			
<u>Waste Solids Conveyor</u>	2	\$13,000	\$ 26,000
Type: Belt Service: Waste solids			

AREA 09 - WASTE DISPOSAL (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Length: 40' Width: 24" Motor: 5 HP			
<u>Waste Solids Stacker</u>	1	\$ 59,000	\$ 59,000
Type: Inclined belt conveyor for stacking waste solids when hauling equipment not operating Service: Waste solids Length: 100' Width: 24" Motor: 10 HP			
<u>Waste Solids Shuttle Loader</u>	1	\$ 45,500	\$ 45,500
Type: Belt conveyor for direct loading of waste solids to trucks Service: Waste solids Length: 50' Width: 24" Motor: 10 HP			
<u>Waste Solids Conveyor Dust Collector</u>	2	\$ 5,000	\$ 10,000
Type: Pulse-jet Air Flow: 1000 ACFM Material: Carbon steel Blower Motor: 3 HP			

Area 09 Total Equipment Cost = \$485,000

AREA 11 - FLUE GAS HANDLING

<u>I.D./Booster Fan</u>	2	\$460,000	\$920,000
Conditions: 950,000 ACFM @ 30" WC and 283°F Type: Armored radial tip, centrifugal fan with variable inlet vanes for flow control Motor: 6000 HP Apportioned to FGD System: 15" of 30" WC (15/30 = 0.5)		\$230,000	\$460,000
<u>Inlet Ducting from I.D. Fan to Manifold</u>	2	\$113,000	\$226,000
Service: Flue gas Type: Circular to Rectangular Transition Materials: Carbon steel Size: 18' dia. x 75' total length			

AREA 11 - FLUE GAS HANDLING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Inlet Ducting Manifold</u>	1 Lot		\$550,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel Size: Section 1 - 23' x 23' x 150' total length Section 2 - 19' x 19' x 50' total length Section 3 - 13' x 14' x 50' total length			
<u>Inlet Ducting to Cocurrent Scrubber</u>	4	\$200,000	\$800,000
Service: Flue gas Type: Rectangular Material: Carbon steel Size: 14' x 14' x 125' total length			
<u>Outlet Ducting Manifold</u>	1 Lot		\$560,000
Service: Scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: Section 1 - 21' x 21' x 85' total length Section 2 - 17' x 17' x 50' total length Section 3 - 12' x 12' x 50' total length			
<u>Outlet Ducting from Cocurrent Scrubber</u>	4	\$30,000	\$120,000
Service: Scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: 12' x 12' x 60' total length			
<u>Bypass</u>	1	\$75,000	\$75,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel, acid resistant gunnite-lined Size: 22' x 22' x 25' total length			

AREA 11 - FLUE GAS HANDLING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Chimney Transition</u>	1	\$150,000	\$150,000
Service: Reheated scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: 22' x 22' x 50' total length			
<u>I.D./Booster Fan Inlet Isolation Damper</u>	2	\$105,000	\$210,000
Type: Spade guillotine w/purge air Service: Flue gas (283°F) Materials: Carbon steel with stainless steel trim Duct Size: 18' diameter			
<u>Scrubber Inlet Isolation Damper</u>	4	\$ 61,000	\$244,000
Type: Duplex guillotine with purge air Service: Flue gas (283°F) Materials: Carbon steel with stainless steel trim Duct Size: 14' x 14'			
<u>Scrubber Outlet Isolation Damper</u>	4	\$ 78,000	\$312,000
Type: Duplex guillotine with purge air Service: Scrubbed gas Materials: Carbon steel and nickel basemetal for wetted parts Duct Size: 12' x 12'			
<u>FGD System Bypass Damper</u>	1	\$ 90,000	\$ 90,000
Type: Double-louver, opposed blade & parallel blade w/purge air Service: Flue gas Materials: Carbon steel with stainless steel trim Duct Size: 21'3" x 21'3"			

Area 11 Total Equipment Cost = \$3,800,000

AREA 12 - WASTE TRANSFER AND PLACEMENT

<u>Waste Solids Loader</u>	1	\$165,000	\$165,000
Type: Wheel loader Bucket Capacity: 5 yd ³ Estimated Service Life: 10,000 hr			

AREA 12 - WASTE TRANSFER AND PLACEMENT

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Interim Replacement Book Life: 6 yrs Equivalent Capital Cost		\$425,000	\$ 425,000
<u>Waste Solids Transfer Truck</u>	4	\$220,000	\$ 880,000
Type: Off-highway truck Capacity: 22 yd ³ Estimated Service Life: 15,000 hr Interim Replacement Book Life: 7.5 yr Equivalent Capital Cost		\$485,000	\$1,940,000
<u>Waste Solids Landfill Bulldozer</u>	1	\$137,000	\$ 137,000
Type: Tracked bulldozer Estimated Service Life: 10,000 hr Interim Replacement Book Life: 6 yr Equivalent Capital Cost		\$353,000	\$ 353,000
Area 12 Total Equivalent Equipment Cost = \$2,720,000			

Blank

B-14

Appendix C

CHIYODA THOROUGHbred 121 SYSTEM EQUIPMENT LIST

AREA 01 - RAW MATERIAL RECEIVING AND STORAGE

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Limestone Receiving System</u>	1 Lot	\$362,000	\$362,000
Service: Limestone receiving area, - 3/4" limestone			
Includes:			
1-two railcar covered spot			
4-50-ton, below-rail hoppers			
4-vibratory feeders, 10 HP			
2-24" x 75' feed belts, 10 HP			
1-24" x 200', 10% inclined belt, 10 HP			
1-4000 ACFM baghouse, 10 HP			
<u>Limestone Bulk Storage Transfer System</u>	1 Lot	\$147,000	\$147,000
Service: Transfer of limestone from unloading area to bulk storage pile			
Includes:			
1-24" x 100', 10% inclined belt, 10 HP			
1-24" x 200' horizontal belt, 10 HP			
1-24" x 150' mobile stacker, 20 HP			
1-10,000 ACFM baghouse, 20 HP			
<u>Live Storage Load Hopper</u>	2	\$ 32,000	\$ 64,000
Size: 25' x 25' x 20' tall with sloped bottom			
Service: -3/4" limestone			
Capacity: 200 tons			
Material: Carbon steel			
<u>Limestone Live Storage Transfer System</u>	1 Lot	\$114,000	\$114,000
Service: Transfer of limestone from bulk storage area to top of limestone day bin			
Includes:			
1-24" x 300', 15% inclined belt, 10 HP motor			
2-24" x 100', feed conveyor belts, 10 HP motor			
1-4000 ACFM baghouse, 10 HP motor			

Area 01 Total Equipment Cost = \$687,000

AREA 02 - FEED PREPARATION AND STORAGE

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Limestone Day Bin</u>	2	\$ 65,000	\$130,000
Size: 18' dia. x 42' straight side, 70° cone bottom Service: -3/4" limestone Sizing Criteria: Total storage equal to 30-hr. surge at maximum consumption Material: Carbon steel Accessories: Displacement filter, bin discharger			
<u>Limestone Vibratory Feeder</u>	2	\$ 6,000	\$ 12,000
Type: Vibratory Service: -3/4" limestone Motor: 20 HP			
<u>Limestone Feeder</u>	2	\$ 10,000	\$ 20,000
Type: Weigh belt gravimetric feeder Service: -3/4" limestone Motor: 3 HP			
<u>Ball Mill & Classifier System</u>	2	\$373,000	\$746,000
Service: -3/4" limestone Grind: 90 wt % -200 mesh Feed Rate: 32 TPH limestone Construction: Carbon steel with Chrome- molybdenum liner Motor: 800 HP			
<u>Limestone Grind Tank</u>	1	\$ 37,000	\$ 37,000
Size: 18' dia. x 20' straight side Service: 60 wt % solids limestone slurry Material: Rubber-lined carbon steel Normal Level: 12' Accessories: Agitator bridge			
<u>Limestone Grind Tank Agitator</u>	1	\$ 5,500	\$ 5,500
Tank Size: 18' dia. x 20' straight side Service: 60 wt % limestone slurry Normal Level: 12' Motor: 15 HP			

AREA 03 - FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Jet Bubbling Reactor</u> Type: Chiyoda design-vertical cylindrical tower Size: 58' I.D. x 33' straight side Material: Carbon steel with reinforced polyester lining Accessories: Agitator supporting bridge, gas distribution plates and gas spargers Mist Eliminator: Vertical chevron, 20 fps maximum design velocity	4	\$460,000	\$1,840,000
<u>Precooler Recirculation Pump</u> Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 10,700 GPM Head: 100' TDH Motor: 400 HP	8	\$ 25,000	\$ 200,000
<u>Jet Bubbling Reactor Agitator</u> Tank Size: 58' dia. x 33' straight side Service: 15 wt % scrubber slurry Type: Pitched blade turbine Material: Rubber-lined carbon steel Motor: 15 HP	16	\$ 7,500	\$ 120,000
<u>Jet Bubbling Reactor Overflow Receiving Tank</u> Size: 9' dia. x 12' straight side Service: 15 wt % scrubber slurry Material: Carbon steel with reinforced polyester lining Normal Level: 8' Accessories: Agitator bridge	4	\$ 13,000	\$ 52,000
<u>JBR Overflow Receiving Tank Agitator</u> Tank Size: 9' dia. x 12' straight side Service: 15 wt. % scrubber slurry Type: Pitched blade turbine Material: Rubber-lined carbon steel Normal Level: 8' Motor: 5 HP	4	\$ 5,000	\$ 20,000

AREA 03 - FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>JBR Overflow Receiving Tank Pump</u>	8	\$ 2,500	\$ 20,000
Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 360 gpm Head: 50' TDH Motor: 10 HP			
<u>Oxidation Air Blower</u>	2	\$180,000	\$360,000
Type: Centrifugal Capacity: 34,900 ACFM @ 60°F & 29.28" Hg Pressure: 10 psig Motor: 1700 HP			
<u>JBR Gypsum Blowdown Pump</u>	8	\$ 2,700	\$ 21,600
Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 410 gpm Head: 75' TDH Motor: 15 HP			
<u>Makeup Water Tank</u>	1	\$ 45,000	\$ 45,000
Size: 21' dia. x 27' straight side Service: Water Sizing Criteria: 2-hr. surge capacity at estimated maximum consumption Material: Carbon steel Normal Level: 20'			
<u>Makeup Water Pump</u>	2	\$ 6,500	\$ 13,000
Type: Horizontal centrifugal Material: Cast steel Flow: 740 GPM Pressure: 125 psi Motor: 75 HP			
<u>Seal Water Tank</u>	1	\$ 22,500	\$ 22,500
Size: 15' dia. x 15' straight side Service: Water Sizing Criteria: 2-hr. surge capacity Material: Carbon steel Normal Level: 10'			
<u>Seal Water Filter Unit</u>	1	\$ 5,000	\$ 5,000
Type: Cartridge (fiber) filter Service: Makeup water			

AREA 03 - FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Capacity: 150 GPM Power Required: 10 HP equiv.			
<u>Seal Water Pump</u>	2	\$ 1,700	\$ 3,400
Type: Horizontal centrifugal Material: Cast steel Flow: 120 GPM Pressure: 100 psi Motor: 20 HP			
<u>Instrument/Plant Air Compressor System</u>	2	\$ 90,000	\$180,000
Type: Multi-stage, centrifugal air compressor unit complete with control unit, motor driver, instrument air-dryer, pre-filter, after-filter, after-cooler and air receivers Service: Air Air-Dryer Power Consumption: 9.9 kW Motor: 700 HP			
Area 03 Total Equipment Cost = \$3,360,000			

AREA 04 - FLUE GAS REHEAT

<u>Reheat Air Fan</u>	1	\$125,000	\$125,000
Conditions: 343,000 ACFM @ 10" WC Type: Air-foil centrifugal fan with variable inlet vanes for flow control Motor: 800 HP			
<u>Reheat Steam Coil Air Heater</u>	1	\$150,000	\$150,000
Type: Finned Tube Steam Coil - includes condensing and subcooling sections Service: Air heater Duty: 125 x 10 ⁶ Btu/HR Material: Carbon steel			
<u>Reheat Mix Chamber</u>	1	\$310,000	\$310,000
Service: Flue gas Material: 316L stainless steel Size: 27' x 27' x 27' total length			
<u>Reheat Duct</u>	1 Lot		\$244,000
Service: Flue gas Type: Rectangular with external stiffeners			

AREA 04 - FLUE GAS REHEAT (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Material: Carbon steel Size: 11'-3" x 11'-3" x 25' total length			
<u>Reheat Isolation Damper</u>	1	\$ 80,000	\$ 80,000
Type: Double-louver, opposed-blade for control/parallel blade for tight shutoff with purge air blower Service: Air and flue gas (382°F maximum temperature) Materials: Stainless Steel Duct Size: 11'3" x 11'3"			
Area 04 Total Equipment Cost = \$909,000			

AREA 08 - WASTE SEPARATION

Mechanical Dewatering Alternate

<u>Filter Feed Tank</u>	1	\$260,000	\$260,000
Size: 40' dia. x 50' straight side Service: 15 wt % scrubber slurry Sizing Criteria: 4-hr. surge capacity @ maximum sludge production Material: Carbon steel with reinforced polyester lining Normal Level: 25' Accessories: Agitator bridge			
<u>Filter Feed Tank Agitator</u>	1	\$ 16,000	\$ 16,000
Tank Size: 40' dia. x 50' straight side Service: 15 wt % scrubber slurry Normal Level: 20' Motor: 25 HP			
<u>Filter Feed Pump</u>	2	\$ 34,000	\$ 68,000
Type: Progressive cavity Material: Cast iron housing; hardened stainless steel rotor; rubber stator Flow: 1800 GPM Pressure: 50 psi Motor: 125 HP			

AREA 09 - WASTE DISPOSAL (continued)

Mechanical Dewatering Alternate

<u>Gypsum Stacker</u>	1	\$ 59,000	\$ 59,000
-----------------------	---	-----------	-----------

Type: Inclined belt conveyor for stacking waste solids when hauling equipment not operating
 Service: Gypsum @ 85 wt. % solids
 Length: 100'
 Width: 24"
 Motor: 10 HP

<u>Gypsum Shuttle Loader</u>	1	\$ 45,500	\$ 45,500
------------------------------	---	-----------	-----------

Type: Belt conveyor for direct loading of gypsum to trucks
 Service: Gypsum @ 85 wt. % solids
 Length: 50'
 Width: 24"
 Motor: 10 HP

Area 09 Total Equipment Cost = \$130,000

AREA 11 - FLUE GAS HANDLING

<u>I.D./Booster Fan</u>	2	\$580,000	\$1,160,000
-------------------------	---	-----------	-------------

Conditions: 1,021,500 ACFM @ 39" WC and 283°F
 Type: Armored radial tip, centrifugal fan with variable inlet vanes for flow control
 Motor: 8,000 HP
 Apportioned to FGD System: 24" of 39" WC (24/39 = .62)

\$360,000	\$ 720,000
-----------	------------

<u>Inlet Ducting from I.D. Fan to Manifold</u>	2	\$113,000	\$ 226,000
--	---	-----------	------------

Service: Flue gas
 Type: Circular to Rectangular Transition
 Materials: Carbon steel
 Size: 18' dia. x 75' total length

<u>Inlet Ducting Manifold</u>	1 Lot	\$ 810,000
-------------------------------	-------	------------

Service: Flue gas
 Type: Rectangular with external stiffeners
 Material: Carbon steel
 Size: Section 1 - 24' x 24' x 160' total length
 Section 2 - 20' x 20' x 50' total length
 Section 3 - 14' x 14' x 50' total length

AREA 11 - FLUE GAS HANDLING

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Inlet Ducting to Precooler</u>	1	\$ 75,000	\$ 75,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel Size: 22' x 22' x 25' total length			
<u>Outlet Ducting Manifold</u>	1 Lot		\$800,000
Service: Scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: Section 1 - 21' x 21' x 140' total length Section 2 - 17' x 17' x 70' total length Section 3 - 12' x 12' x 70' total length			
<u>Outlet Ducting from Jet Bubbling Reactor</u>	4	\$110,000	\$440,000
Service: Scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: 12' x 12' x 100' total length			
<u>Bypass</u>	1	\$ 60,000	\$ 60,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel, acid resistant gunnite-lined Size: 22' x 22' x 20' total length			
<u>Chimney Transition</u>	1	\$150,000	\$150,000
Service: Reheated scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: 22' x 22' x 50' total length			
<u>I.D./Booster Fan Inlet Isolation Damper</u>	2	\$105,000	\$210,000
Type: Spade guillotine Service: Flue gas (283°F) Materials: Carbon steel with stainless steel trim Duct Size: 18' diameter			

AREA 11 - FLUE GAS HANDLING (continued)

<u>Equipment Item and Description</u>	<u>Qty.</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Precooler Inlet Isolation Damper</u>	4	\$ 61,000	\$244,000
Type: Duplex guillotine with purge air Service: Flue gas Materials: Carbon steel with stainless steel trim Duct Size: 14' x 14'			
<u>JBR Outlet Isolation Damper</u>	4	\$ 78,000	\$312,000
Type: Duplex guillotine with purge air Service: Scrubbed gas Materials: Carbon steel and nickel basemetal for wetted parts Duct Size: 12' x 12'			
<u>FGD System Bypass Damper</u>	1	\$ 90,000	\$ 90,000
Type: Double-louver, opposed blade & parallel blade with purge air Service: Flue gas Materials: Carbon steel with stainless steel trim Duct Size: 21'3" x 21'3"			
Area 11 Total Equipment Cost = \$4,140,000			

AREA 12 - WASTE TRANSFER AND PLACEMENT

<u>Waste Solids Loader</u>	1	\$ 87,000	\$ 87,000
Type: Wheel loader Bucket Capacity: 3.5 yd ³ Estimated Service Life: 10,000 hr Interim Replacement Book Life: 6 yrs Equivalent Capital Cost			
		\$223,000	\$223,000
<u>Waste Solids Transfer Truck</u>	2	\$220,000	\$440,000
Type: Off-highway truck Capacity: 22 yd ³ Estimated Service Life: 15,000 hr Interim Replacement Book Life: 7.5 yr Equivalent Capital Cost			
		\$485,000	\$970,000
<u>Waste Solids Bulldozer</u>	2	\$ 77,000	\$154,000
Type: Tracked bulldozer Estimated Service Life: 10,000 hr Interim Replacement Book Life: 6 yr Equivalent Capital Cost			
		\$200,000	\$400,000
Area 12 Total Equivalent Equipment Cost = \$1,590,000			

AREA 01 - RAW MATERIAL RECEIVING AND STORAGE (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
---------------------------------------	-----------------	------------------	-------------------

Solids Rate: 20 TPH
 Air Rate: 3,100 ACFM
 Transfer Lines: 4", 300' Length
 Blower Motor: 50 HP

<u>Fixative Storage Silo</u>	1	\$ 110,000	\$ 110,000
------------------------------	---	------------	------------

Dimensions: 25' diameter x 65'
 straight side, with
 conical bottom
 Retention: 30 days
 Material of Construction: Steel
 Reinforced Concrete
 Accessories: Unloading blower,
 pneumatic conveyor piping

<u>Fixative Silo Baghouse</u>	1	\$ 36,000	\$ 36,000
-------------------------------	---	-----------	-----------

Type: Pulse-jet
 Air Flow: 7,500 ACFM
 Material: Carbon steel
 Blower Motor: 15 HP
 Accessories: Compressor and blower

<u>Fixative Silo Screw Conveyor</u>	1	\$ 6,500	\$ 6,500
-------------------------------------	---	----------	----------

Type: Screw
 Feed Rate: 0.5 TPH
 Service: Pebble Lime
 Length: 40'
 Motor: 15 HP

<u>Fly Ash Pneumatic Conveyor</u>	1	\$ 16,700	\$ 16,700
-----------------------------------	---	-----------	-----------

Type: Pneumatic
 Service: Pebble - Granular Lime
 Solids Rate: 30 TPH
 Air Rate: 5,000 ACFM
 Transfer Lines: 4", 100' length
 Blower Motor: 50 HP

Area 01 Total Equipment Cost = \$464,000

AREA 02 - FEED PREPARATION AND STORAGE

<u>Sodium Carbonate Feed Pump</u>	2	\$ 3,000	\$ 6,000
-----------------------------------	---	----------	----------

Type: Horizontal centrifugal
 Material: Cast steel
 Flow: 50 GPM
 Head: 100' TDH
 Motor: 10 HP

AREA 02 - FEED PREPARATION AND STORAGE

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Lime Day Bin</u>	1	\$21,000	\$ 21,000
Size: 16' diameter x 18' straight side 70° cone bottom			
Service: Lime			
Material: Carbon steel			
Accessories: Baghouse and airlock			
<u>Lime Feeder</u>			
Type: Weigh belt, gravimetric feeder	1	\$ 8,000	\$ 8,000
Service: Lime			
Motor: 3 HP			
<u>Lime Slakers</u>	2	\$10,000	\$ 20,000
Service: Lime			
Feed Rate: 1.5 TPH			
Motor: 10 HP			
<u>Lime Slurry Tank</u>	1	\$20,000	\$ 20,000
Size: 12' diameter x 14' straight side			
Service: 20 wt % lime slurry			
Material: Carbon steel			
Normal Level: 10'			
Accessories: Agitator bridge, wear ring			
<u>Lime Slurry Tank Agitator</u>	1	\$ 4,000	\$ 4,000
Tank Size: 12' diameter x 14' straight side			
Service: 20 wt % lime slurry			
Normal Level: 10'			
Motor: 10 HP			
<u>Lime Slurry Pumps</u>	2	\$ 1,500	\$ 3,000
Type: Horizontal centrifugal			
Material: Rubber lined cast steel			
Flow: 50 GPM			
Head: 100' TDH			
Motor: 15 HP			

Area 02 Total Equipment Cost = \$82,000

AREA 03 - FLUE GAS SCRUBBING

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Prescrubber Towers (System)</u>	4	\$385,000	\$1,540,000
Type: Venturi Dimensions: 16' diameter x 20' straight side Material: Carbon steel shell, chlorobutyl rubber lining Gas Velocity: 60 fps inlet/outlet			
<u>Prescrubber Circulation Pumps</u>	8	\$ 15,000	\$ 120,000
Type: Horizontal centrifugal Material: Rubber-lined cast steel Flow: 5,500 GPM Head: 250' TDH Motor: 250 HP			
<u>Prescrubber Chloride Removal Circulation Pumps</u>	8	\$ 19,000	\$ 152,000
Type: Horizontal centrifugal Material: Rubber lined cast steel Flow: 12,500 GPM Head: 100' TDH Motor: 425 HP			
<u>Absorber Tower</u>	4	\$975,000	\$3,900,000
Type: Vertical tray tower Dimensions: 33' diameter x 60' overall height Material: Carbon steel, rubber lined Alloy trays Internal Gas Velocity: 10 fps			
<u>Absorber Circulation Pump</u>	12	\$ 9,000	\$ 144,000
Type: Horizontal centrifugal Material: Rubber-lined cast steel Flow: 1,700 GPM Head: 100' TDH Motor: 75 HP			
<u>Absorber Feed Pumps</u>	2	\$ 5,500	\$ 11,000
Type: Horizontal centrifugal Material: Rubber-lined cast steel Flow: 950 GPM Head: 100' TDH Motor: 40 HP			

AREA 03 - FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Absorber Feed Surge Tank</u>	1	\$310,000	\$ 310,000
Size: 75' diameter x 40' straight side Service: Regenerated sodium scrubbing solution Material: Carbon steel with reinforced polyester lining Normal Level: 20'			
<u>Absorber Product Pumps</u>	2	\$ 5,500	\$ 11,000
Type: Horizontal centrifugal Material: Rubber-lined cast steel Flow: 1000 GPM Head: 100' TDH Motor: 40 HP			
<u>Absorber Product Surge Tank</u>	1	\$310,000	\$ 310,000
Size: 75' diameter x 40' straight side Service: Spent sodium scrubbing solution Material: Carbon steel Normal Level: 20'			
<u>Precoat Tank</u>	1	\$ 1,300	\$ 1,300
Size: 6' diameter x 6' straight side Service: Precoat media slurry Material: Carbon steel Normal Level: 4' Accessories: Agitator mounting			
<u>Precoat Tank Agitator</u>	1	\$ 2,000	\$ 2,000
Tank size: 6' diameter x 6' straight side Service: Precoat media slurry Normal Level: 4' Motor: 3 HP			
<u>Precoat Pump</u>	2	\$ 1,000	\$ 2,000
Type: Horizontal centrifugal Material: Cast steel Flow: 100 GPM Head: 50 psi Motor: 7.5 HP			

AREA 03 - FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Fly Ash Filters</u>	2	\$ 10,000	\$ 20,000
Type: Cartridge Service: 3 wt % fly ash solution from prescrubbers Capacity: 1,000 gpm			
<u>Fly Ash Slurry Sump Pump</u>	2	\$ 2,800	\$ 5,600
Type: Vertical turbine Material: Rubber Lined Cast steel Flow: 5 GPM Motor: 1 HP			
<u>Fly Ash Slurry Sump Agitator</u>	1	\$ 1,300	\$ 1,300
Sump Size: 5' wide x 5' depth Service: Water Normal Level: 4' Motor: 1 HP			
<u>Makeup Water Tank</u>	1	\$52,000	\$ 52,000
Size: 25' diameter x 25' straight side Service: Water Sizing Criteria: 2-hr surge capacity at estimated maximum consumption Material: Carbon steel Normal Level: 15'			
<u>Makeup Water Pumps</u>	2	\$ 7,000	\$ 14,000
Type: Horizontal centrifugal Material: Cast steel Flow: 550 GPM Pressure: 125 psi Motor: 50 HP			
<u>Seal Water Filter Unit</u>	1	\$ 6,000	\$ 6,000
Type: Cartridge (fiber) filter Service: Makeup water Capacity: 180 GPM			
<u>Seal Water Tank</u>	1	\$22,500	\$ 22,500
Size: 15' diameter x 15' straight side Service: Water Material: Carbon steel Normal Level: 10'			

AREA 03 - FLUE GAS SCRUBBING (continued).

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Seal Water Pumps</u>	2	\$ 1,800	\$ 3,600
Type: Horizontal centrifugal Material: Cast steel Flow: 160 GPM Pressure: 125 psi Motor: 20 HP			

<u>Instrument/Plant Air Compressor Systems</u>	2	\$100,000	\$ 200,000
Type: Multi-stage, centrifugal air compressor unit, complete with control unit, motor driver, instrument air-dryer, pre-filter, after-filter, after-cooler, and air receivers. Service: Air Air Dryer Power Consumption: 9.9 kW Motor: 700 HP			

Area 03 Total Equipment Cost = \$6,800,000

AREA 04 - FLUE GAS REHEAT

<u>Reheat Air Fan</u>	1	\$125,000	\$ 125,000
Conditions: 343,000 ACFM @ 10" W.C. 60°F air Type: Air-foil centrifugal fan with variable inlet vanes for flow control Motor: 800 HP			

<u>Reheat Steam Coil Air Heater</u>	1	\$150,000	\$ 150,000
Type: Finned Tube Steam coil - includes condensing and subcooling sections Service: Air heater Duty: 125 x 10 ⁶ Btu/hr			

<u>Reheat Mix Chamber</u>	1	\$310,000	\$ 310,000
Service: Flue gas Material: 316L stainless steel Size: 27' x 27' x 27' total length			

AREA 03 - FLUE GAS SCRUBBING (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Reheat Duct</u>	1 lot		\$ 244,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel Size: 11'3" x 11'3" x 25' total length			
<u>Reheat Isolation Damper</u>	1	\$80,000	\$ 80,000
Type: Double-louver system, opposed-blade for control/parallel blade for tight shutoff with purge air blower Service: Air and flue gas (382°F maximum temperature) Materials: Stainless steel Duct size: 11'3" x 11'3"			

Area 04 Total Equipment Cost = \$909,000

AREA 05 - PURGE TREATMENT

<u>Prescrubber Purge Stream</u> <u>Prescrubber Purge Tank</u>	1	\$20,000	\$ 20,000
Size: 12' diameter x 14' straight side Service: 3 wt % solids prescrubber slurry Material: Carbon steel with chlorobutyl rubber lining Normal Level: 10' Accessories: Agitator bridge			
<u>Prescrubber Purge Tank Pump</u>	2	\$ 2,500	\$ 5,000
Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 150 GPM Head: 100' TDH Motor: 10 HP			
<u>Prescrubber Purge Tank Agitator</u>	1	\$ 3,500	\$ 3,500
Tank Size: 12' diameter x 14' straight side Service: 3 wt % prescrubber slurry Normal Level: 10' Motor: 5 HP			

AREA 05 - PURGE TREATMENT

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Prescrubber Purge Neutralization Tank</u>	1	\$ 16,000	\$ 16,000
Size: 12' diameter x 12' straight side Service: 9 wt % neutralized prescrubber slurry Material: Carbon steel with chlorobutyl rubber lining Normal Level: 8' Accessories: Agitator bridge			
<u>Prescrubber Purge Neutralization Tank Pumps</u>	2	\$ 3,000	\$ 6,000
Type: Horizontal centrifugal Material: Rubber-lined carbon steel Flow: 200 GPM Head: 100' TDH Motor: 10 HP			
<u>Prescrubber Purge Neutralization Tank Agitator</u>	1	\$ 3,500	\$ 3,500
Tank Size: 12' diameter x 12' straight side Service: Neutralized prescrubber slurry Normal Level: 8' Motor: 3 HP			
<u>Purge Treatment Thickener</u>	1	\$ 50,000	\$ 50,000
Size: 50' diameter Service: Prescrubber sludge Materials: Epoxy coated carbon steel rake/bridge, carbon steel shell, concrete bottom Motor: 15 HP Accessories: Tunnel, feed trough, personnel bridge			
<u>Flocculant System</u>	1	\$ 6,000	\$ 6,000
Includes mixing tank, multiple metering pumps, agitator, water booster pumps, and local controls Power Required: 5 HP			
<u>Thickener Overflow Tank</u>	1	\$ 9,000	\$ 9,000
Size: 10' diameter x 10' straight side Service: Water Sizing Criteria: 30 min. surge capacity Material: Carbon steel Normal Level: 6'			

AREA 05 - PURGE TREATMENT (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Thickener Overflow Pump</u>	2	\$ 2,000	\$ 4,000
Type: Horizontal centrifugal Material: Water Flow: 150 GPM Pressure: 125 psi Motor: 20 HP			
<u>Thickener Underflow Pumps</u>	2	\$ 4,000	\$ 8,000
Type: Progressive cavity Material: Cast iron housing, hardened stainless steel rotor, rubber stator Flow: 50 GPM Head: 50'TDH Motor: 10 HP			
<u>Filter Feed Tank</u>	1	\$ 7,000	\$ 7,000
Size: 10' diameter x 10' straight side Service: 25 wt % neutralized prescrubber slurry Material: Rubber lined carbon steel Normal Level: 6' Accessories: Agitator bridge			
<u>Filter Feed Tank Agitator</u>	1	\$ 3,500	\$ 3,500
Tank Size: 10' diameter x 10' straight side Service: 25 wt % neutralized prescrubber slurry Normal Level: 6' Motor: 5 HP			
<u>Filter Feed Pump</u>	2	\$ 9,000	\$ 18,000
Type: Progressive Cavity Material: Cast iron housing, hardened stainless steel rotor, rubber stator Flow: 75 GPM Pressure: 50 psi Motor: 7.5 HP			
<u>Vacuum Filter System</u>	2	\$ 45,000	\$ 90,000
Type: Face scraper drum vacuum filter Size: 3' diameter x 4' wide cloth Service: Prescrubber sludge Accessories: Receiver, pumps, blower, control panel			

AREA 05 PURGE TREATMENT (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Motor: 15 HP Sizing Criteria: 100 lb/hr/ft ² - dry solids basis			
<u>Fixative Pneumatic Conveyor System</u>	1	\$ 8,000	\$ 8,000
Type: Pneumatic Service: Granular quicklime Solids Rate: 1 TPH Air Rate: 1,000 ACFM Transfer Lines: 4" diameter x 50' length Blower Motor: 5 HP			
<u>Fixative Day Bin</u>	1	\$ 8,000	\$ 8,000
Size: 9' diameter x 12' straight side 70° Cone bottom Service: Lime Sizing Criteria: 36-hr storage capacity Material: Carbon steel Accessories: Baghouse and airlock			
<u>Fixative Weigh Feeder</u>	1	\$ 5,000	\$ 5,000
Type: Weigh belt, gravimetric feeder Service: Granular quicklime Motor: 1] HP			
<u>Fly Ash Pneumatic Conveyor System</u>	1	\$ 30,000	\$ 30,000
Type: Pneumatic Service: Fly Ash Solids Rate: 10 TPH Air Rate: 5,000 ACFM Transfer Lines: 6" 50' length, abrasion resistant Blower Motor: 40 HP			
<u>Fly Ash Day Bin</u>	1	\$ 40,000	\$ 40,000
Size: 12' diameter x 45' straight side 70° cone bottom Service: Fly ash Material: Carbon steel Accessories: Baghouse and air lock			
<u>Fly Ash Weigh Feeder</u>	1	\$ 6,000	\$ 6,000
Service: Fly Ash Motor: 1] HP Type: Weigh belt, gravimetric feeder			

AREA 05 PURGE TREATMENT (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Process Mixer System</u>	2	\$ 22,500	\$ 45,000
Type: Pug mill Service: Ash, sludge, sludge water, fixative lime Capacity: 40 Mlb/hr Motor: 40 HP			
<u>Waste Solids Conveyor</u>	2	\$ 13,000	\$ 26,000
Type: Belt Service: Waste solids Length: 40' Motor: 5 HP			
<u>Waste Solids Stacker</u>	1	\$ 59,000	\$ 59,000
Type: Inclined belt conveyor for stacking waste solids when hauling equipment not operating Service: Waste solids Length: 100' Motor: 10 HP			
<u>Waste Solids Shuttle Loader</u>	1	\$ 45,500	\$ 45,500
Type: Belt conveyor for direct loading of waste solids to trucks Service: Waste Solids Length: 50' Motor: 10 HP			
<u>Waste Solids Conveyor Dust Collector</u>	2	\$ 5,000	\$ 10,000
Type: Pulse-jet fabric filter Air Flow: 1,000 ACFM Material: Carbon steel Blower Motor: 3 HP Sulfate Purge Stream			
<u>Crystallizer Condensate Receiver</u>	1	\$ 5,500	\$ 5,500
Size: 6' diameter x 9' length Service: Condensate Material: Carbon steel Type: Pressure vessel Pressure: 15 psig			
<u>Crystallizer Liquor Tank</u>	1	\$ 11,700	\$ 11,700
Size: 10' diameter x 15' straight side Service: Sodium sulfite/sulfate solution			

AREA 05 PURGE TREATMENT (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
Material: Carbon steel Normal Level: 13' Accessories: Agitator bridge			
<u>Crystallizer Liquor Tank Agitator</u>	1	\$ 5,300	\$ 5,300
Tank Size: 10' diameter x 15' straight side Service: Sodium sulfite/sulfate solution Normal Level: 13' Motor: 7.5 HP			
<u>Crystallizer Condensate Pump</u>	1	\$ 6,000	\$ 6,000
Type: Horizontal centrifugal Material: Carbon steel Flow: 690 GPM Pressure: 50 psi Motor: 30 HP			
<u>Crystallizer Circulating Pump</u>	1	\$ 4,300	\$ 4,300
Type: Horizontal centrifugal Material: Carbon steel Flow: 275 GPM Pressure: 50 psi Motor: 15 HP			
<u>Crystallizer Liquor Pump</u>	1	\$ 4,300	\$ 4,300
Type: Horizontal centrifugal Material: Carbon steel Flow: 265 GPM Pressure: 50 psi Motor: 15 HP			
<u>Sulfate Crystallizer System</u>	1	\$980,000	\$ 980,000
Size: 16'6" diameter x 17' straight side Type: Forced circulation evaporator/ crystallizer Accessories: Heating element, circulation pump and piping			
<u>Sulfate Centrifuge</u>	1	\$ 50,000	\$ 50,000
Type: Solid bowl Material: 316 Stainless steel internals Size: 5'H x 12'L x 12'W with motor Motor: 75 HP			

AREA 05 PURGE TREATMENT (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Sulfate Centrifuge Feed Pump</u> Type: Horizontal centrifugal Material: Cast steel Flow: 265 GPM Pressure: 50 psi Motor: 15 HP	1	\$ 4,300	\$ 4,300
<u>Sulfate Surge Hopper</u> Size: 10' dia x 10' straight side with 70° cone bottom Service: Sulfate crystals Retention: Four hours	1	\$ 8,000	\$ 8,000
<u>Sulfate Dust Collector</u> Type: Pulse-jet fabric filter Air Flow: 1000 ACFM Material: Sulfate crystals Blower Motor: 3 HP	1	\$ 4,300	\$ 4,300
<u>Sulfate Outlet Hopper Feeder</u> Type: Weigh belt, gravimetric feeder Service: Sulfate crystals Motor: 3 HP	1	\$ 8,500	\$ 8,500
<u>Sulfate Product Bins</u> Size: 25' diameter x 45' straight side 70° cone bottom Material: Carbon steel Service: Sulfate crystals Retention: 30 days Accessories: Bin activators and slide gates	3	\$ 69,000	\$ 207,000
<u>Sulfate Dryer</u> Size: 4'W x 5' H x 16' L Type: Horizontal, cylindrical shell Material: 316 Stainless steel Outlet Moisture: 0.2% Motor: 25 HP	1	\$ 235,000	\$ 235,000
<u>Area Sump Pump</u> Type: Vertical centrifugal Material: Rubber-lined carbon steel Flow: 100 GPM Head: 40'-60' TDH Motor: 7.5 HP	24	\$ 2,700	\$ 64,800

AREA 05 PURGE TREATMENT (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Area Sump Agitator</u>	12	\$ 1,300	\$ 15,600

For assorted area sumps of varied
size and service
Power Required: 1 HP ea.

Area 05 Total Equipment Cost = \$2,150,000

AREA 06 - SO₂ REGENERATION

<u>Multi-Stage Evaporator System</u>	2	\$1,670,000	\$3,340,000
--------------------------------------	---	-------------	-------------

Size: 16'6" diameter x 17' straight
side
Type: Forced circulation evaporator
Accessories: Includes all associated
vacuum equipment, condensers,
heaters, preheaters,
circulation piping and pumps

<u>Condensate Stripper</u>	1	\$ 35,000	\$ 35,000
----------------------------	---	-----------	-----------

Type: Vertical Column, steam stripper
Material: Alloy 20
Service: SO₂ removal
Duty: 175,000 lb/hr
Pressure: 15 psig

<u>Condensate Stripper Pumps</u>	2	\$ 7,000	\$ 14,000
----------------------------------	---	----------	-----------

Type: Horizontal centrifugal
Material: Alloy 20
Flow: 750 GPM
Head: 200' TDH
Motor: 50 HP

<u>Stripped Condensate Cooler</u>	1	\$ 11,000	\$ 11,000
-----------------------------------	---	-----------	-----------

Type: Heat exchanger
Material: Carbon steel
Service: Condensate
Flow: 750 GPM

<u>Dissolving Tank</u>	1	\$ 45,000	\$ 45,000
------------------------	---	-----------	-----------

Size: 20' diameter x 20' straight side
Service: Sodium Sulfite/Bisulfite/
Sulfate Solution
Material: Carbon steel with reinforced
polyester lining
Normal Level: 15'
Accessories: Agitator bridge

AREA 06 - SO₂ REGENERATION (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Compressor Seal Water Filter</u>	2	\$ 15,000	\$ 30,000
Type: Cartridge (fiber) filter Service: Water Capacity: 1000 GPM			
<u>Clean Condensate Receiver</u>	1	\$ 12,000	\$ 12,000
Size: 20' diameter x 35' straight side Material: Carbon steel Service: Water Normal Level: 30'			
<u>Sour Condensate Receiver</u>	1	\$ 7,000	\$ 7,000
Size: 16' diameter x 20' straight side Material: Carbon steel Service: SO ₂ -laden water Normal Level: 15'			
<u>Vent Gas Scrubber</u>	1	\$ 10,000	\$ 10,000
Type: Vertical spray tower Size: 3' diameter x 15' straight side Service: SO ₂ fuel gas Flow: 15,000 ACFM Material: 316L stainless steel			
<u>Vent Gas Scrubber Circulation Pump</u>	1	\$ 3,500	\$ 3,500
Type: Horizontal centrifugal Material: Cast steel rubber lined Service: Lime slurry Flow: 70 GPM Motor: 3 HP			

Area 06 Total Equipment Cost = \$4,430,000

AREA 07 - SO₂ PROCESSING

<u>Sulfuric Acid Plant</u>	1		\$9,000,000
----------------------------	---	--	-------------

Includes equipment as shown on sulfuric acid plant process flow diagram and all appurtenances necessary for complete sulfuric acid (93 wt %) production of 614 TPD (66° Be). Feed stream of 15.5 TPH of SO₂ gas supplied by regeneration loop.
(Area 06)

AREA 07 - SO₂ PROCESSING (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Sulfur Plant</u>	1		\$6,000,000

Includes complete equipment package as shown on sulfur plant process flow diagram for production of 169 LTPD sulfur. Feed supplied by SO₂ regeneration loop (Area 06) at 16.5 TPH SO₂ gas.

AREA 10 - BYPRODUCT STORAGE

<u>Sulfuric Acid Storage Facility</u>	1	\$ 400,000	\$ 400,000
---------------------------------------	---	------------	------------

Size: 50' diameter x 40' straight side
Service: 93 wt % H₂SO₄ (66° Be)
Material: Carbon steel
Retention: 5 day storage at maximum production
Accessories: Includes all piping and miscellaneous appurtenances for complete tank storage and transfer facility.

AREA 10 - BYPRODUCT STORAGE

<u>Sulfur Storage Facility</u>	1	\$ 410,000	\$ 410,000
--------------------------------	---	------------	------------

Earth pit storage of molten sulfur. Transfer from sulfur production unit to pit via one quarter mile 6" line steam jacketed with 8" surrounding line. Three slip tube loading arms (two truck and one rail loader on swivel joint).

AREA 11 - FLUE GAS HANDLING

<u>I.D./Booster Fan</u>	2	\$515,000	\$1,030,000
-------------------------	---	-----------	-------------

Conditions: 950,000 ACFM @ 36" WC and 283°F

Type: Armored radial tip, centrifugal fan with variable inlet vanes for flow control

Motor: 7,000 HP

Apportioned to FGD System: 21" of 36" WC (21/36 = .583) \$300,000 \$600,000

AREA 11 - FLUE GAS HANDLING (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Inlet Ducting from I.D. Fan to Manifold</u>	2	\$113,000	\$226,000
Service: Flue gas Type: Circular to rectangular transition Materials: Carbon steel Size: 18' dia. x 75' total length			
<u>Inlet Ducting Manifold</u>	1 Lot		\$870,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel Size: Section 1-23'x 23'x 160' total length Section 2-19'x 19'x 75' total length Section 3-13'x 14'x 75' total length			
<u>Bypass</u>	1	\$100,000	\$400,000
Service: Flue gas Type: Rectangular with external stiffeners Material: Carbon steel, acid resistant gunnite-lined Size: 14'x 14'x 160' total length			
<u>Chimney Transition</u>	1	\$150,000	\$150,000
Service: Reheated, scrubbed gas Type: Rectangular with external stiffeners Material: Carbon steel, reinforced polyester lined Size: 23' x 23' x 50' total length			
<u>Inlet Ducting to Prescrubber</u>	4	\$ 30,000	\$120,000
Service: Flue gas Type: Rectangular with external stiffeners Materials: Carbon steel Size: 14' x 14' x 80' total length			
<u>Outlet Ducting Manifold</u>	1 lot		\$ 900,000
Service: Scrubbed gas Type: Rectangular with external stiffeners Materials: Carbon steel reinforced polyester lined Duct Size: Section 1-22'x 22'x 150' total length Section 2-19'x 19'x 60' total length Section 3-14'x 14'x 60' total length			

AREA 11 - FLUE GAS HANDLING (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Outlet Ducting from Absorber</u>	4	\$ 34,000	\$136,000

Service: Scrubbed gas
Type: Rectangular with external stiffeners
Materials: Carbon steel, reinforced
polyester lined
Duct Size: 13' x 13' x 50' total length

<u>I.D. Booster Fan Inlet Isolation Damper</u>	2	\$105,000	\$210,000
--	---	-----------	-----------

Type: Spade guillotine
Service: Inlet flue gas (283°F)
Materials: Carbon steel with stainless
steel trim
Duct Size: 18' diameter

<u>Prescrubber Inlet Isolation Damper</u>	4	\$ 65,000	\$260,000
---	---	-----------	-----------

Type: Duplex guillotine with
purge air
Service: Flue gas (283°F)
Materials: Carbon steel with stainless
steel trim
Duct Size: 14' x 14'

<u>Absorber Outlet Isolation Damper</u>	4	\$ 82,000	\$328,000
---	---	-----------	-----------

Type: Duplex guillotine
Service: Scrubbed gas (127°F)
Materials: Carbon steel and nickel
base metal for wetted parts
Duct Size: 13' x 13'

<u>FGD System Bypass Damper</u>	1	\$90,000	\$ 90,000
---------------------------------	---	----------	-----------

Type: Double louver - opposed blade
Service: Flue gas (283°F)
Materials: Carbon steel with stainless
steel trim
Duct Size: 21'6" x 21'6"

Area 11 Total Equipment Cost = \$4,300,000

AREA 12 - WASTE TRANSFER AND PLACEMENT

<u>Waste Solids Loader</u>	1	\$ 55,000	\$ 55,000
----------------------------	---	-----------	-----------

Type: Wheel loader
Bucket capacity: 1-3/4 yd³
Estimated Service Life: 10,000 hr.
Interim Replacement Book Life: 6 yrs
Equivalent Capital Cost

		\$142,000	\$ 142,000
--	--	-----------	------------

AREA 12 - WASTE TRANSFER AND PLACEMENT (continued)

<u>Equipment Item and Description</u>	<u>Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
<u>Waste Solids Transfer Truck</u>	1	\$220,000	\$ 220,000
Type: Off-highway truck Capacity: 22 yd ³ Estimated Service Life: 15,000 hr Interim Replacement Book Life: 7.5 yr Equivalent Capital Cost		\$485,000	\$ 485,000
<u>Waste Solids Landfill Bulldozer</u>	1	\$ 36,600	\$ 36,600
Type: Tracked bulldozer Estimated Service Life: 10,000 hr. Interim Replacement Book Life: 6 yr Equivalent Capital Cost		\$ 94,000	\$ 94,000
Area 12 Total Equivalent Equipment Cost = \$720,000			

Blank

D-22

Appendix E
ECONOMICS OF AUXILIARY STEAM FROM COAL-FIRED POWER PLANTS

1. INTRODUCTION AND SUMMARY

1.A. INTRODUCTION

Within any coal-fired power plant numerous demands exist for process steam. The plants may carry a combination of loads including flue gas reheat, flue gas desulfurization, steam coil air heaters, soot blowing, and space heating. Therefore, determination of the least costly source of this steam becomes a major concern. The ultimate use of the steam, however, has no bearing on its cost. The operating characteristics of a typical 540 MW gross power plant cycle were used to assess the relative merits of various sources of this process steam. Such an assessment implies the enumeration, evaluation, and quantification of all relevant costs.

1.A.1 OBJECTIVES

This study was conducted to analyze, from an economic basis, various methods of obtaining process steam from a coal-fired power plant. Primary objectives were to:

1. determine sensitivity of steam cost to steam source, i.e. pressure,
2. determine sensitivity of steam cost to steam flow rate,
3. determine sensitivity of steam cost to condensate return point, and
4. establish unit cost factors for steam.

1.A.2. SCOPE

The following criteria were established to define the limits of this study:

1. A typical 540 MW gross/500 MW net, 2400 psig/1000⁰F RH, power plant cycle was used.
2. The consumption of the process steam was limited to an amount equivalent to 15 percent of the boiler duty. Requirements for more than this amount would probably be in the realm of cogeneration power plant applications.
3. The plant will be located near Kenosha, Wisconsin, and will utilize pulverized Illinois bituminous coal.

4. Further plant description can be obtained from the EPRI report, AF-342, "Coal Fired Power Plant Capital Cost Estimates," prepared by Bechtel Power Corporation, January 1977.
5. Three different quantities of process steam were studied equivalent to 5, 10, and 15 percent of turbine cycle heat input (boiler duty). A process condensate return temperature of 200⁰F was assumed.
6. Three options were studied for obtaining steam:
 - Main steam from the boiler, 250 to 2415 psia
 - Extraction steam from the cold reheat line, 70 to 250 psia
 - Extraction steam from the crossover line, less than 70 psia
7. Three options were studied for process condensate disposal:
 - Return to the deaerator
 - Return to the condenser
 - No return (Discard)

The steam sources and disposal points described above were those which are usually found in current power plant cycles. This study did not consider higher, more complex levels of integration such as steam extraction within the high, intermediate, or low pressure turbines.

1.B. SUMMARY

Based on economic analyses performed for each alternative, the following conclusions were reached:

1. The cost of steam is directly related to the pressure at the extraction point. The extraction point for process steam should always be the one with the lowest pressure which fulfills process requirements. Table E-1 and E-2 illustrate this point.
2. The cost of process steam is relatively insensitive to variations in the amount of flow extracted. Figures E-1, E-2, and E-3 illustrate the insensitivity of steam cost to flow quantity. Figure E-1 also illustrates the proportions of the steam cost applicable to capital, fuel, and operation and maintenance (O&M).
3. For condensate returned at 200⁰F, the most economical point of return is the deaerator. If the condensate return temperature varies significantly from 200⁰F, additional studies should be performed to determine the most economical return point.

4. The results indicate that the cost of process steam decreases as the extraction point approaches the end of the turbine cycle, i.e. low pressure turbine exhaust. Process steam uses which do not require a specific pressure could benefit from lower pressure extraction steam.

Extraction of low pressure steam was not considered in this study since it would involve special design turbines. Additionally, as pressure at a proposed extraction point decreases, the volume for a specific quantity of steam increases. The cost of piping the low pressure steam to the process use location would become significant.

TABLE E-1
AVERAGE PRESENT WORTH OF STEAM

Return Point Source	\$/1000#/hr			\$/10 ⁶ /Btu/hr*		
	No Return	Condenser	Deaerator	No Return	Condenser	Deaerator
Main Steam 250 to 2415 psia	439,800	396,700	391,500	340,400	307,000	303,000
Cold Reheat 70 to 250 psia	304,800	261,700	254,800	271,500	233,000	277,000
Crossover Less than 70 psia	249,700	209,100	201,500	209,100	175,100	168,700

*Btu/hr based on utilization of process steam enthalpy from extraction point value to 200^oF condensate.

TABLE E-2
30-YR LEVELIZED STEAM COST
(7/1/79 → 7/1/09)

<u>Extraction Point</u>	<u>Point of Return</u>	<u>30-Yr Levelized Steam Cost \$/1000 lb</u>
Main Steam	Not Returned	7.61
Main Steam	Condenser	6.86
Main Steam	Deaerator	6.77
Cold Reheat	Not Returned	5.27
Cold Reheat	Condenser	4.53
Cold Reheat	Deaerator	4.41
Crossover	Not Returned	4.32
Crossover	Condenser	3.62
Crossover	Deaerator	3.49




FIGURE E-1

COST BREAKDOWN
30 YEAR LEVELIZED STEAM COSTS




FIGURE E-2
LEVELIZED BUSBAR COST VS. PROCESS DUTY




FIGURE E-3
LEVELIZED BUSBAR COST VS. PROCESS STEAM FLOW

2. ANALYSIS PROCEDURE

2.A. IDENTIFICATION OF ALTERNATES

There are three areas in the extraction and return of process steam which offer distinct alternatives, including quantity, point of extraction, and point of condensate return.

2.A.1. QUANTITY OF STEAM EXTRACTED

The quantities of steam selected for study were 5, 10, and 15 percent of boiler duty based on the boiler duty determination at 80 percent load.

2.A.2. POINT OF EXTRACTION

The three extraction points considered were main steam (250 to 2415 psia), cold reheat (70 to 250 psia), and crossover (less than 70 psia) steam lines.

2.A.3. CONDENSATE RETURN POINT

The three options for return of condensate are to return it to the condenser, return it to the deaerator, and to discard it.

The 3 x 3 x 3 matrix which follows illustrates the possible combinations.

<u>Steam Quantity As Percent of Boiler Duty</u>	<u>Extraction Point</u>	<u>Condensate Return Point</u>
5%	Main Steam (250 to 2415 psia)	No Return
10%	Cold Reheat (70 to 250 psia)	Condenser
15%	Crossover (less than 70 psia)	Deaerator

The same power plant configuration without extraction of process steam was evaluated as a base case. Added to the 27 possible combinations described above, this produced the 28 alternatives considered. This base case provided a reference point, and any increase in cost relative to this base can be attributed to generation of the auxiliary steam. Thus, throughout the report, the figure " Δ " indicates increase over the base case.

2.B. GENERAL CRITERIA

In addition to the scope guidelines stated, detailed assumptions were made concerning construction and operation of the model plant. These assumptions served as analysis guidelines.

1. The model plant operated at a 70 percent load factor (derived as the product of 80 percent annual operation and 87.5 percent load for the entire 30 year life of the facility).
2. The costs associated with reducing the extraction steam pressure to any specific process demand pressure were considered negligible.
3. The cost of coal for this plant was assumed to be $\$1/10^6$ Btu on July 1, 1978, per EPRI premises.

2.C. GENERAL DESCRIPTION OF METHODOLOGY

A present worth cost for each option was determined through the following steps:

1. The turbine cycle was computer simulated and a boiler duty determined at 80 percent load for each of the 28 options.
2. From the boiler duty calculated in Step 1, an annual cost of fuel was calculated.
3. The final annual cost was determined by adding other items such as labor, maintenance, and overhead to Step 2.
4. The size of the plant, excluding the turbine, had to be increased to maintain the net steam flow to the turbine. The capital cost of the enlarged plant was determined as an exponential ratio to the base case plant cost. The factor used was the ratio of the boiler steam flows raised to the 0.8 power.
5. The final capital cost of the plant was determined by adding any component costs which, for a particular scheme, might not scale up accurately. An example was the additional water treatment costs required for any scheme which did not return the condensate from the process to the cycle.
6. The final PW cost for each alternative was derived using present worth calculation methods defined in this section.
7. The results were then presented graphically to show the costs of specific options versus the base case with respect to process steam and heat consumption.

2.D. TURBINE CYCLE DEVELOPMENT

The steam cycle investigated was assumed to be a typical 540 MW (gross) coal-fired power plant. The specific cycle chosen was a General Electric 7 heater cycle with 2400 psig/1000^oF throttle conditions, 1000^oF reheat temperature, tandem compound, four flow, 30-inch last stage bucket (TC4F-30LSB) turbine. This turbine was assumed to have a 2-inch Hg Abs back pressure at normal operating conditions. The General Electric turbine was chosen to be representative and the turbine cycle would be applicable to other turbine vendors. The final results of the study are not vendor-specific.

For the purposes of this study, the cycle performance parameters for all cases were determined at the 80 percent load condition. Load changes from about 70 to 100 percent have little impact on boiler and turbine efficiency.

When determining the cycle heat rates, "Condensate Return to Condenser" and "No Condensate Return" are equivalent. The differences between these two modes of operation are accounted for in condenser-cooling tower duty and make-up water treatment.

The turbine cycle calculations were performed using the Stearns-Roger heat balance program D135. This program has previously been verified in comparisons with the manufacturer's heat balances submitted on actual designs. The program was verified for this study by comparison of heat rates given in General Electric's manual "Heat Rates for Fossil Reheat Cycles Using General Electric Steam Turbine-Generators, 150,000 KW and Larger" (GET-2050C, February 1974).

The generator load was held constant at 80 percent load (432,000 KW), while the process steam extraction locations, condensate return points, and flow rates were varied. The effects on turbine cycle heat rate were determined for each case. Turbine cycle heat rate was utilized as the overall cycle performance indicator. However, since generator output was held constant throughout this study, a study of boiler duty would have yielded the same results. Typical turbine cycle heat balances are illustrated as Figures E-4 through E-8.

Heat rate can be defined as follows:

$$HR_{TC} = BD/kW_g; \text{ Turbine Cycle Heat Rate}$$

$HR_{NP} = (BD/NB) \times (1/kW_n)$; Net Plant Heat Rate

$HR_{GP} = (BD/NB) \times (1/kW_g)$; Gross Plant Rate

Also:

$N_{TC} = 3412.14/HR_{TC}$; Turbine Cycle Efficiency

$N_{NP} = 3412.14/HR_{NP}$; Net Plant Efficiency

$N_{GP} = 3412.14/HR_{GP}$; Gross Plant Efficiency

where

HR = Heat Rate in Btu/kW-hr

BD = Total Boiler Duty (heat to the cycle), Btu/hr

kW_g = Generator gross terminal output, kW

kW_n = Generator net terminal output, kW, i.e., gross output less plant auxiliary power

NB = Boiler Efficiency, decimal

The boiler duty calculations for this study were performed as follows:

$$BD = W_{TH} (H_{TH} - H_{FFW}) + W_{RH} (H_{HRH} - H_{CRH}) + W_{aux} (H_{aux} - H_{FFW})$$

where

W_{TH} = Throttle steam flow, lbs/hr

H_{TH} = Throttle enthalpy, Btu/lb

H_{FFW} = Final Feedwater enthalpy, Btu/lb

W_{RH} = Reheater steam flow, lbs/hr

H_{HRH} = Hot reheat enthalpy, Btu/lb

H_{CRH} = Cold reheat enthalpy, Btu/lb

W_{aux} = Respective flows for auxiliary steam - Flow to the steam jet air ejector or flow to the process (if applicable), lbs/hr

H_{aux} = Respective enthalpy for the auxiliary flow above, Btu/lb

The heat and mass flow for the 28 alternatives are tabulated in Table A-1.

2.E. OPERATING COST DETERMINATION

The operating cost for each alternative studied was developed from the cycle performance parameters discussed previously. Calculation of the steam cycle yielded a boiler duty at 80 percent load which served as the basis for fuel cost determination. The following equation was used to calculate the annual cost of fuel:

$$FC_a = (BD \div NB) \times T \times FC$$

where

FC_a = Annual cost of fuel, \$/yr

NB = Boiler efficiency, decimal. The efficiency was taken at 80 percent load and was assumed to be a constant value of 88 percent.

T = Hours per year of plant operation. The hours per year were based on an 87.5 percent availability; therefore, the value $.875 \times 8760$ hrs/yr = 7665 hrs/yr was used.

FC = Fuel costs, \$/Btu. As specified in "Economic Premises for Electric Power Generating Systems" a fuel cost of $\$1/10^6$ Btu was used.

The other elements included in the annual operating costs were operation and maintenance, fixed and variable costs, and overhead. The base derivation of these costs were taken from the EPRI report entitled "Technical Assessment Guide," EPRI PS-866-SR, June 1978.

For those alternatives where the condensate was not returned to the system, the additional O&M costs incurred were included since significant additional water treatment expenditures were necessary.

2.F. CAPITAL COST DETERMINATION

The capital cost for each alternative was developed from the cycle performance parameters discussed previously. The calculation of the steam cycle yielded the boiler superheat outlet steam flow at 80 percent load. The flow was then scaled up to 100 percent load. This produced the capacity of the boiler and power plant based on steam flow alternative. From a base itemized cost list (Table E-3), for a similar 540 MW gross plant without process steam extraction, each alternative's capital costs were determined by scaling. The capital cost scaling factor used was the ratio of the flow rate of the alternative case to that of the base case raised to the 0.8 power. The base cost list was taken from the report "Coal-Fired Power Plant Capital Cost Estimates", EPRI AF-342. Cost for a FGD System is not included in the base itemized cost list.

All components of the base case were scaled except the turbine/generator which, along with the plant load, remained constant. In several cases,

TABLE E-3
CAPITAL COST BREAKDOWN, BASE CASE

ITEM	10^6 \$ (7/1/76)	
1	Steam Generator System	55.2
2	Turbine/Generator	25.2
3	Condenser and Auxiliaries	2.1
4	Other Rotating Equipment	6.5
5	Heaters and Exchangers	1.8
6	Tanks, Drums, Vessels	0.8
7	Water Treatment and Chemical Feed	1.3
8	Coal and Ash Handling	4.4
9	Electrostatic Precipitator	14.3
10	Stack with Lining and Lights	2.3
11	Miscellaneous Concrete	8.7
12	Miscellaneous Structural	7.9
13	Architecture and Finish	3.9
14	Earthwork	7.9
15	Piles and Caisson	4.0
16	Site Improvements	4.9
17	Miscellaneous Mechanical including Insulation and Lagging	4.2
18	HVAC	0.8
19	Piping	20.8
20	Instrumentation and Controls	5.2
21	Electrical including TR ^S , Switchgear, MCC	5.2
22	Electrical including Conduit, Cable, Trays, Wire and Switchyard	16.8
23	Field Distributables	18.4
24	Engineering and Fees (@ 7% of Total)	20.8
25	Contingency (@ 12% of Total)	36.5
26	7% Other Costs (1 through 25)	<u>19.6</u>
	TOTAL (TPI - Total Plant Investment)	<u>299.5</u>

additional capital costs were added when a particular component increased in size out of proportion to the remainder of the plant. An example of this is those alternatives that do not return the condensate and therefore require additional water treatment capacity.

2.G. PRESENT WORTH ANALYSIS

In order to perform a meaningful cost comparison of the various methods of obtaining process steam, evaluations were made on a present worth (7-1-79 dollars) basis. Equations and economic factors used to perform this evaluation are presented below.

Design Start Date: 7-1-74
 Operation Start Date: 7-1-79
 Plant Life: 30 years
 Escalation (except fuel): 60%
 Escalation, Fuel: 6.2%
 Investment Return (MAR): 10%

$$\begin{aligned}
 PW_{(7-1-79)} &= (TCR \times FCR \times SPWF) \\
 &\quad + (FYOM_{(1-1-78)} \times EF_1 \times PWSF_6) \\
 &\quad + (FYFL_{(7-1-78)} \times EF_2 \times PWSF_{6.2}) \\
 TCR &= CI_{(7-1-76)} \times ECE + AFDC + Land + Inventory \\
 &\quad EF_3 \\
 AFDC_{(7-1-79)} &= CI_{(7-1-76)} \times ECE \times AIDC \\
 &\quad EF_3
 \end{aligned}$$

where

$PW_{(7-1-79)}$ = Total present worth cost, 7-1-79, \$
 TCR = Total capital requirement, \$
 SPWF = Series present worth factor, 10% for 30 years = 9.4270
 FCR = Fixed charge rate = 0.18
 FYOM₍₁₋₁₋₇₈₎ = First year operations and maintenance, 1-1-78, \$
 EF₁ = Escalation factor to bring FYOM costs up to 7-1-79 = (1.06)^{1.5}
 FYFL₍₇₋₁₋₇₈₎ = First year fuel costs, 7-1-78, \$
 EF₂ = Escalation factor to bring FYFL costs up to 7-1-79 = 1.062
 PWSF₆ = Present worth summation factor corresponding to an escalation rate of 6.0%. Similar to the series present worth factor except for escalation allowance = 17.7775

$PWSF_{6.2}$ = Present worth summation factor corresponding to an escalation rate of 6.2% = 18.2133

CI (7-1-76) = Capital investment 7-1-76, \$

EF_3 = Escalation factor to change the equivalent CI to 7-1-74 = $(1.06)^2$

ECE = A 21.27% escalation applied to a capital estimate of 7-1-74 which is escalated to 7-1-79 under a typical construction payment S-curve schedule = 1.2127

AFDC = Allowance for funds during construction, 7-1-79, \$

Land = \$5000/acre x 500 acres = $\$2.5 \times 10^6$, 7-1-79

Inventory = $\$5 \times 10^6$, 7-1-79. (Initial coal pile, etc.)

AIDC - A factor to account for the interest paid during construction which is accumulated by 7-1-79 = .1397 (Based on a typical construction payment S-curve schedule which corresponds to a cg of approximately 1.7 years).

2.H. PROCESS STEAM COST DETERMINATION

After evaluating the present worth cost differential for each of the alternates, it was desirable to convert the values to a 30-year levelized cost on a unit basis. The 30-year levelized process steam costs can be determined using the following equation and economic factors:

$$LSC = \frac{\Delta \text{ PW}}{SPWF \times 8760 \times 0.7}$$


where

LSC = Thirty year levelized cost of steam, \$1000/lb. (7/1/1979-7/1/2009)

Δ PW = Increased present worth of a given alternate case over the base case, 7-1-79, \$

SPWF = Series present worth factor, 10% for 30 years = 9.4270

The preceding analysis determines the cost of steam excluding profit. If steam were sold to an outside user, profit would have to be considered when determining LSC.




HEAT BALANCE NO. 1
 CUSTOMER: EPRI
 UNIT: 500 MW (NOM) 540 MW (GR)
 OPERATING CONDITIONS: 80% LOAD
 GE, TC4F-30 LSB TURBINE
 C-21141 X00025

SYMBOL NOTATION
 W = FLOW - LB/HR
 P = PRESSURE - PSIA
 F = TEMPERATURE - °F
 H = ENTHALPY - BTU/LB

GENERATOR OUTPUT = 432,000 KW
 FIXED LOSSES = 1,726 KW
 GEN. LOSSES = 5,646 KW
 HEAT RATE = 7,923 BTU/104-KW-HR
 GUARANTEED UNIT RATING = 540,000 KW

FIGURE E-4

E-17







FIGURE E-6






FIGURE E-8





FIGURE E-9
PERCENT BOILER DUTY TO PROCESS vs. PROCESS STEAM FLOW



EPRI - 540MW GROSS, MODEL PLANT
 HEAT RATE vs. BOILER DUTY TO PROCESS - 80% LOAD

FIGURE E-10

PERCENT BOILER DUTY TO PROCESS vs. TURBINE CYCLE HEAT RATE




FIGURE E-11
 PROCESS STEAM FLOW VS. PROCESS HEAT DUTY

Blank

E-24

Appendix F

FLUE GAS DESULFURIZATION EVALUATION STANDARD

A proposed evaluation standard for economic assessment of flue gas desulfurization (FGD) systems is presented here in two sections. The first section (Part 1) defines the various components of capital and operating costs and presents a standardized format for their development and presentation. The second section (Part 2) details a standard specification for a base-case nonproprietary limestone slurry FGD system with provision for consistent adaptation for other cases or processes.

Part 1

STANDARD FOR FGD CAPITAL AND OPERATING COST PRESENTATION AND ECONOMIC EVALUATION

This portion of the standard is contained in the following amended EPRI document Economic Premises for Electric Power Generations Systems - Complete Plant Utility Financing (July 26, 1978) FGD Amendment (September 1978).

ECONOMIC PREMISES FOR
ELECTRIC POWER GENERATING SYSTEMS
COMPLETE PLANT UTILITY FINANCING
(REFERENCE DATE: JULY 26, 1978)

FLUE GAS DESULFURIZATION AMENDMENT JUNE 1979

A. CAPITAL REQUIREMENTS (An example format for presenting projected capital requirements is shown in Table A-1.)

1. Total Plant Investment

The total plant investment is the sum of:

- (a) Process (or On-Site) Capital
- (b) General Facilities (or Off-Site) Capital
- (c) Engineering and Home Office Fees
- (d) Project Contingency
- (e) Process Contingency

These items are discussed below.

Process Capital

Process capital is the total constructed cost of all onsite FGD and related facilities, including all direct and indirect construction costs. Utility capital for items such as FGD water makeup treatment will be included along with prorata capital distribution for power plant items such as ID fans (for that portion of their load required for the FGD system).

All sales taxes should be included. When possible, the process capital costs should be broken down by major plant section (e.g., raw materials receipt, storage, and preparation, gas path systems, and waste separation and placement). The specific section breakdown should be agreed upon with the EPRI project manager. The capital cost detail should break down the total process capital into factory materials (equipment), field materials, and field labor.

The process design basis, the scope definition for the FGD system, and an indication of the quality of the mechanical design (materials of construction, equipment redundancy) must be referenced.

General Facilities
or Offsite Capital

The capital cost of the offsite facilities is to be given explicitly in the report. The offsite facilities include a prorata share of roads, office buildings, shops, laboratories, etc., and generally are in the range of 5 to 20 percent of the onsite capital cost. Raw material and byproduct storage systems are not to be included in the onsite capital costs and are not part of the offsite facilities. The cost basis for the offsites will be established by the contractor with the concurrence of the EPRI project manager. Sales taxes should be included where applicable.

Engineering and Home
Office Overhead
Including Fee

The contractor will include an estimate of the engineering and home office overhead and fee that are considered representative of this type of plant. These fees may be included in the process capital and general facility capital costs if the contractor's cost-estimating system incorporates estimates of these fees as a part of the equipment costs. The capital cost summary table must indicate where these fees have been included (10 to 15 percent of the process capital is typical for these fees).

Project Contingency

A capital cost contingency factor should be developed by the contractor for each segregated portion of the FGD system. This is a project contingency factor that is intended to cover additional equipment or other costs that would result from a more detailed design of a definitive project at an actual site. Table A-5 at the end of this appendix presents guidelines for relating the project contingency to the level of design/estimating effort. Thus, by specifying the project contingency, the level of design/estimating effort and precision can be inferred. The contingency factors developed for each plant section should be explicitly shown in the report.

Process Contingency

This is a capital cost contingency applied to new technology in an effort to quantify the uncertainty in the design and cost of the commercial-scale equipment. The following guidelines are provided to aid in assigning process contingency allowances to various sections of the plant.

<u>State of Technology Development</u>	<u>Percentage of Installed Section Cost</u>
New concept with limited data	25% and up
Concept with bench-scale data available	15-25%
Small pilot plant data (e.g., 1-10 MW size) available	10-15%
A full-size module (100 MW) has been successfully operated for a period of one year	5-10%
The process is used commercially in similar or identical service to that proposed	0-5%

The process contingency should be shown separately for each major plant section.

2. Total Capital Requirement

The total capital requirement for a regulated utility includes all capital necessary to complete the entire project. These items include:

- (a) Total Plant Investment
- (b) Prepaid Royalties
- (c) Preproduction (or startup) Costs
- (d) Inventory Capital
- (e) Initial Chemical and Catalyst Charge
- (f) Allowance for Funds During Construction (AFDC)
- (g) Land

These items are discussed below.

Total Plant Investment

Defined in Item 1, above.

Prepaid Royalties

See Table A-4 at the end of this appendix for definition

Preproduction Costs

The preproduction costs are intended to cover operator training, equipment checkout, major changes in plant equipment, extra maintenance, and inefficient use of

fuel and other materials during plant startup. The preproduction costs are estimated as follows:

- (a) One month of fixed operating costs (fixed operating costs are operating and maintenance labor, administrative and support labor, and maintenance materials).
- (b) One month of variable operating costs at full capacity (these variable operating costs include chemicals, water, and other consumables and waste disposal charges).
- (c) Five percent of total plant investment (this charge covers expected changes and modifications to equipment that will be needed to bring the plant up to full capacity).

Inventory Capital

The value of inventories of raw materials, other consumables, and byproducts is capitalized and included in the inventory capital account. The inventory capital is estimated as follows:

- (a) One month's supply of raw materials based on full-capacity operation
- (b) One month's supply of other consumables (excluding water) based on full-capacity operation

Initial Chemicals and Catalyst Charge

The initial cost of any catalyst or chemicals that are contained in the process equipment (other than that in storage, and thus covered in inventory capital) is also included.

Allowance for Funds During Construction (AFDC)

An AFDC charge is computed based on the time period from the center of gravity (cg) of expenditures until the plant is in commercial operation. The interest rate is eight percent per year. The AFDC is then calculated from the total plant investment (TPI) as shown below:

$$\text{AFDC} = [(1.08)^{\text{cg}} - 1] (\text{TPI})$$

Numerical Example

$$\text{TPI} = \$100$$

$$\text{cg} = 2 \text{ years}$$

$$\text{AFDC} = [(1.08)^2 - 1] (100) = \$16.6$$

The center of gravity time period (cg) is to be estimated by the contractor. Representative centers of gravity for several types of power plants are shown in the following table:

<u>Type of Plant</u>	<u>Total Design- Construction Time</u>	<u>cg</u>
Pulverized Coal Fired (1000 MW)	5 years	2 years
Oil Fired Combined Cycle (500 MW)	3 years	1 year
Combustion Turbine Unit (75 MW)	2 years	0.5 year

Since the AFDC charge is to be expressed in the same year dollars as the total plant investment, cost escalation (inflation) is not included. The particular year used must be specified. It will normally be the first year of operation. Table A-6 at the end of this appendix gives an example of an AFDC calculation based on a construction cash flow schedule.

Land

Land costs are site-specific and variable. See Table A-4 for a land cost.

B. CAPACITY FACTOR

For EPRI evaluation purposes, the following capacity factors (CF) are suggested as design values:

<u>Type of Plant</u>	<u>Design Capacity Factor</u>
Base	70%
Intermediate	30%
Peaking	10%

A design capacity factor of 70 percent is normally used as indicated in Table A-4. The CF is assumed to be constant over the life of the plant (i.e., levelized).

C. OPERATING COST BASIS

The operating costs are to be estimated on a first operating year basis. The costs will also be presented on a 30-year levelized basis (details are given in the following section).

The operating costs are divided into fixed and variable costs. The fixed costs are essentially independent of capacity factor and are generally expressed in \$/kW-yr based on design capacity. The variable costs are directly proportional to the amount of power produced (capacity factor) and are generally expressed in mills/kWh.

An example format for presenting first year operating costs is presented in Table A-2,

1. Fixed Operating Costs

Fixed operating costs include the following:

- (a) Operating Labor
- (b) Maintenance (may also have a variable component)
- (c) Overhead Charges

These items are discussed below.

Operating Labor

The contractor will estimate the number of operating jobs (OJ) that are required to operate the plant. The operating labor charges (OLC) are then computed using the average labor rate (ALR) as follows:

$$OLC = \frac{(OJ) \times (ALR) \times (8760 \text{ hr/yr})}{(\text{Full capacity of plant in kW})}$$

The average labor rate includes payroll burden and is given in Table A-4 at the end of this appendix.

Maintenance Costs

Annual maintenance costs for new technologies are often estimated as a percentage of the installed capital cost of the pertinent facilities. The percentage varies widely depending on the nature of the processing conditions and the type of design. Maintenance costs in the ranges shown below are representative.

<u>Type of Processing Conditions</u>	<u>Maintenance Percentage of Process (or offsite) Capital Cost/Yr</u>
Corrosive (fouling and abrasive slurries)	6.0 - 10 (& higher)
Severe (solids handling high temperature)	4.0 - 6 (& higher)
Clean (noncorrosive or foul- ing liquids and gases only)	2.0 - 4
Offsite facilities & steam/ electrical systems	1.5

The maintenance costs will be developed by the contractor with concurrence of the EPRI project manager.

The maintenance costs should be separately expressed as maintenance labor and maintenance materials. A maintenance labor/materials ratio of 40/60 may be used for this breakdown if other information is not available.

Overhead Charges

The only overhead charge included in the power plant studies is a charge for administrative and support labor, which is taken as 30 percent of the operating and maintenance labor.

General and administrative expenses are not included.

2. Variable Operating Costs

Consumables

Variable operating costs includes fuel, water, chemicals, waste disposal, etc. The first-year values to use for these items are given in Table A-4 at the end of this appendix.

Variable Maintenance Charges

A variable component of the maintenance cost should be included if there is a basis for estimating how maintenance costs vary with capacity factor.

3. Byproduct Credits

Byproduct credits (if any) are based on values given in Table A-4.

4. Levelized Operating Costs

Inflation will tend to increase the operating costs (in current dollars) over the life of the plant. In EPRI analyses, a long-term inflation rate of six percent per year is assumed in estimating the cost of capital (discussed in a following section) and in estimating the life-cycle revenue requirements for other expenses. To represent these varying revenue requirements for fixed and variable costs (including fuel), a single "levelized" value is computed using the "present worth" concept of money. Based on the following assumptions,

Inflation rate = 6%/year

Discount rate = 10%/year,

the 30-year levelization factor (LF) for operating and maintenance (O&M) costs (excluding fuel) is 1.886 (see Chapter V of the EPRI Technical Assessment Guide [TAG] for further detail).

$$30\text{-year levelized O\&M} = 1.886 \times (\text{1st year O\&M})$$

The 30-year LF for fuel is given in Table A-4.

D. COST OF CAPITAL

The cost of capital is based on an assumed six percent per year inflation rate and the following assumptions:

Debt/Equity Ratio	50/50
Debt Cost	8%/yr
Preferred Stock Ratio	15%
Preferred Stock Cost	8.5%/yr
Common Stock Ratio	35%
Common Stock Cost	13.5%/yr
Weighted Cost of Capital	10%/yr
Federal + State Income Tax Rate	50%
Property Taxes and Insurance	2%/yr
Investment Tax Credit	0
Book Life	30 yr
Tax Life	20 yr
Iowa Type S ₁ Retirement Dispersion	

The 30-year levelized fixed charge rate (LFCR) calculated from the above assumptions is eighteen percent per year. For more information see Chapter V of the Technical Assessment Guide (TAG).

Levelized Fixed Charges (30-year plant)

The levelized fixed charges (LFC) are based on the total capital requirement (TCR) and are computed as follows:

$$LFC = \frac{(LFCR) (TCR)}{(\text{plant size in kW})} = \$/kW\text{-yr}$$

Where LFCR = 0.18

Levelized Fixed Charges (interim replacements)

If major portions of the plant have a short life (5 to 10 years), and would have to be capitalized as interim replacements, a fixed-charge rate consistent with the shorter life must be applied to these capital items. The contractor should obtain the proper fixed-charge rate in this case from the EPRI project manager.

E. EFFECT OF FGD ON
POWER COST

The component of FGD cost in the cost of electricity from a power plant is not a single value but varies with the plant capacity factor. Therefore, the power cost should be presented in the form of a "Power Cost Sensitivity Curve" plot as defined below.

Power Cost Sensitivity
Curve

Vertical axis = FGD component of electric power cost (mills/kWh).

Horizontal axis = capacity factor (0 to 100%)

Thirty-year levelized costs are used. An example is shown in Figure A-1. The contractor will prepare this curve for the power generation option being evaluated.

The range of capacity factors for which the design/cost estimate are reasonably valid should be represented by a solid curve. A dashed curve can be used to indicate the cost trends outside the design range.

Numerical Power Cost

For convenience of discussion, a levelized cost of power for the design capacity factor will be calculated, using the 30-year levelized fixed charges, O&M charges, and fuel charges. A sample format for presenting this cost calculation is shown in Table A-3.




Figure A-1
SENSITIVITY OF FGD CONTRIBUTION TO POWER COST
TO CHANGES IN CAPACITY FACTOR

Table A-1

XYZ PROCESS

PROJECTED CAPITAL REQUIREMENTS

Unit size (MW net):
 Capacity factor:
 Coal (sulfur content):
 Pricing level:
 SO₂ emission limit:

	\$/kW
Raw Material Receiving & Storage Feed Preparation & Storage Flue Gas Treatment Flue Gas Reheat Waste Separation Waste Disposal SO ₂ Regeneration Flue Gas Supply SO ₂ Reduction Product Storage	
Total Process Capital General Facilities Engineering & H.O., Fees Project Contingency Process Contingency	
Total Plant Investment Royalty Allowance Preproduction Cost Inventory & Initial Chemicals Interest during Construction Land	
TOTAL CAPITAL REQUIREMENT	

Levelized fixed charges - mills/kWh

Table A-2

XYZ PROCESS

PROJECTED FIRST YEAR OPERATING COST

Basis:

Unit size (MW net):
 Capacity factor:
 Coal (sulfur content):
 Pricing level:
 SO₂ emission limit:

	Unit	Unit Rate (\$)	Annual Quantity	Annual Cost (\$x1000)
Operating Labor	Manhour			
Maintenance Labor				
Maintenance Material				
Admin./Support				
Total Fixed O&M Cost				
Utilities				
Steam	10 ⁶ Btu			
Water	10 ³ gal			
Electricity	kWh			
Fuel Oil	gal			
Natural Gas	10 ³ ft ³			
Chemicals-Limestone	ton			
Lime	"			
Soda Ash	"			
Magnesium Oxide	"			
Coke	"			
Anthracite	"			
Antioxidant	lb			
Other Consumables				
Waste Disposal	ton			
Total Variable O&M Cost				
TOTAL FIRST YEAR OPERATING COST				

Levelized Operating Cost - mills/kWh

Table A-3
 XYZ PROCESS
 LEVELIZED REVENUE REQUIREMENTS

Basis:
 Unit size (MW net):
 Capacity factors:
 Coal (Sulfur content):
 Pricing level:
 SO₂ emission limit:

	Levelized mills/kWh
Process Capital General Facilities Engineering, H.O., Fees Contingency Total Capital Requirement	
Preproduction Inventory & Misc. AFDC Land	
Total Plant Investment	
Operating & Admin Labor Maintenance Labor & Mat.	
Total Fixed O&M Cost	
Utilities Steam Water Electricity Chemicals & Consumables Waste Disposal	
Total Variable O&M Cost	
TOTAL LEVELIZED REVENUE REQUIREMENTS	

Table A-4

ECONOMIC VARIABLES

Design Capacity Factor

70% for Base Load, 30% for Intermediate Load, 10% for Peak Load

Capital Investment Items

Paid-up Royalties: 0.5% of Process Capital

Operating Labor (Mid 1978 \$)

First Year: \$12.50/manhour (This labor rate is based on a direct labor charge of \$9.25/hr plus a 35% payroll burden.)

Labor Inflation Rate: 6%/year

Purchased Materials (Delivered Cost), Chicago Area

	<u>Mid-1978 \$</u>	<u>Price Escalation Rate/Yr (Including Inflation)</u>	<u>30-Year Levelization Factor (LF)</u>
Coal	\$1.00/10 ⁶ Btu	-	-
Fuel Oil (No.6)	\$0.40/gal	6.1%	1.909
Steam	\$2.50/10 ⁶ Btu	6.1%	1.909
Electric Power	\$0.03/kWh	6.1%	1.909
Process Water	\$0.40/10 ³ gal(a)	6.0%	1.886
Cooling Water	\$0.10/10 ³ gal	6.0%	1.886
Natural Gas	\$4.00/10 ³ ft ³	6.1%	1.909
Coke	\$35.00/ton	6.0%	1.886
Anthracite	\$56.85/ton	6.0%	1.886
Lime	\$34.00/ton	6.0%	1.886
Limestone	\$10.00/ton	6.0%	1.886
Soda Ash	\$65.00/ton	6.0%	1.886
Magnesium Oxide	\$250.00/ton	6.0%	1.886
Citric Acid, 50%	\$800.00/ton	6.0%	1.886

Disposal Charges

Sludge	\$8.50/ton (dry basis)	6.0%	1.886
Dry, Granular Solids	\$4.00/ton	6.0%	1.886

Byproduct Credits

Sulfuric Acid	No credit	----	----
Sulfur	No credit	----	----

Land Cost

\$5000/acre

(a) This is a raw water acquisition charge only. Intake structures, treating, and pumping costs are to be included in plant capital and O&M.

Table A-5

DESIGN AND COST ESTIMATE CLASSIFICATIONS

Item	Design/ Estimate Description	Project Contingency Range	Design Information Required	Cost Estimate Basis		
				Major Equipment	Other Materials	Labor
Class I	Simplified	20% to 30%	General site conditions, geographic location and plant layout. Process flow/operation block diagram. Product output capacities.	By overall project or section-by-section based on capacity/cost graphs, ratio methods, and comparison with similar work completed by the contractor, with material adjusted to current cost indices and labor adjusted to site conditions.		
Class II	Preliminary	15% to 20%	As for Type Class I plus engineering specifics, e.g.: Major equipment specifications. Preliminary P&I flow diagrams.	Recent purchase costs (including freight) adjusted to current cost index.	By ratio to major equipment costs on plant parameters	Labor/material ratios for similar work, adjusted for site conditions and using expected average labor rates.
Class III	Detailed	10% to 15%	Complete process design. Engineering design usually 20% - 40% complete. Project construction schedule. Contractual conditions and local labor conditions. Actual site defined	Firm quotations adjusted for possible price escalation with some critical items committed. Pertinent taxes and freight included.	Firm unit cost quotes or current billing costs) based on detailed quantity takeoff.	Estimated man-hour units (including assessment) using expected labor rate for each job classification.
Class IV	Finalized	5% to 10%	As for Class III - with engineering essentially complete.	As for Class III - with most items committed.	As for Class III - with material on approximately 100% firm basis.	As for Class III - some actual field labor productivity may be available.

Table A-6

EXAMPLE OF AFDC CALCULATION FROM THE CONSTRUCTION PERIOD CASH FLOW

Example

Total Plant Investment (TPI) = \$100 (year 1 \$)

Construction Expenditure Schedule (Assumed)

<u>Year</u>	<u>\$ (year 1 \$)</u>
1	5
2	15
3	30
4	35
5	15

Assuming expenditures are uniform over a given year, the effective interest rate for the first year is one-half the annual interest rate (using annual end-of-year compounding).

Annual Interest Rate = 8%

Calculation of AFDC

5 x (1.04) (1.08) ⁴	=	7.07
15 x (1.04) (1.08) ³	=	19.65
30 x (1.04) (1.08) ²	=	36.39
35 x (1.04) (1.08)	=	39.31
15 x (1.04)	=	<u>15.60</u>
Total (TPI + AFDC)		118.02

$$\text{Center of Gravity (cg)} = \frac{\log \left(\frac{\text{AFDC}}{\text{TPI}} + 1 \right)}{\log (1.08)}$$

$$\text{cg} = \frac{\log \left(\frac{18.02}{100} + 1 \right)}{\log (1.08)} = 2.15 \text{ years}$$

Therefore, 2.15 years is the center of gravity (cg) for the construction expenditure schedule shown above.

Appendix G

COMMENTS OF PROCESS SUPPLIERS

Prior to publication of this report, the suppliers and developers of the processes presented in sections 4 through 7 of the report were given an opportunity to review the process description and cost estimate of their particular process. The process descriptions were subsequently revised to reflect changes requested by the process suppliers.

In some cases, the process suppliers did not fully agree with the cost estimates presented herein for their particular process. However, the cost estimates were not changes because such changes would have meant that the estimates were no longer representative of a consistent, comparative methodology. Instead, each process supplier was given an opportunity to present their cost estimate comments, if any, in this Appendix.

COMMENTS OF TENNESSEE VALLEY AUTHORITY

General TVA comments concerning the draft report "Economics of Four FGD Systems" prepared by Stearns-Roger Engineering Corporation for EPRI.

Process Design

1. Both the cocurrent and the conventional limestone systems are designed with 100% redundancy in the limestone preparation area, 33-1/3% scrubber redundancy and provisions for full bypass. The need for this degree of grinding redundancy and bypass are questionable. In contrast, recirculation pumps are not spared.
2. Scrubber layout for the systems is not conventional. Although the report states that the arrangement is consistent for all processes evaluation, it is in general a more costly arrangement, particularly for the conventional limestone and cocurrent limestone processes. This arrangement essentially eliminates the advantages of cocurrent scrubbing in regard to layout of ductwork and simplicity of reheater design (ground level).
3. Scrubber heights of 110' and 120' for conventional and cocurrent limestone scrubbers appear to be out of line with normal practices.
4. Separate slurry recirculation pumps are indicated for each slurry distribution point for the conventional and cocurrent limestone processes. A more conventional less expensive design uses a single header feeding all slurry distribution locations.
5. Limestone systems designed for forced oxidation within the scrubber loop produce a disposable gypsum by-product which is preferable to blended sludge. This by-product is comparable to the by-product from the CT-121 process.
6. Storage of limestone slurries at a concentration of 20% solids may be more difficult than storage at 60% solids.

7. The following data related to limestone consumption and waste disposal are given in the report:

<u>Process</u>	<u>Stoichiometry</u>	<u>Solids concentration</u> <u>% by weight</u>		<u>Waste disposal</u> <u>rate, tph</u>
		<u>Thickener underflow</u>	<u>dewatered sludge</u>	
Conventional limestone scrubbing	1.15	25	45	140
Cocurrent limestone scrubbing	1.30	25	60	122.5

A stoichiometry of 1.15 for 90% SO₂ removal using conventional limestone scrubbing is optimistic based on results at Shawnee. Also, based on Shawnee results, there is no significant difference in dewatering characteristics of cocurrent and conventional limestone sludges.

Economics

1. It would have been valuable to include additional tables in the report displaying the projected breakdowns for the cost sensitivity variations in the same format as Tables 4-3 through 4-5. It would also have been helpful to display the projected field material costs (piping, foundation, structure, etc.) for each area.
2. Relative Total Process Capital and Total Capital Requirement costs for the conventional and cocurrent limestone processes are reversed solely as a result of using different project and process contingency factors for the two processes.
3. Recent TVA in-house evaluations comparing economics of conventional limestone scrubbing using forced oxidation, cocurrent limestone scrubbing using forced oxidation, and Chiyoda 121 processes result in the following relative ranking in order of increasing revenue requirements: (1) Cocurrent (2) Chiyoda CT-121, and (3) conventional scrubbing.

DAVY McKEE COMMENTS

Davy McKee Corporation must take exception to the economic analysis presented in this report. The economics of the Wellman-Lord process have been reported from several independent sources in recent years, and while we have not always concurred with all of the details and methodology, we have been able to identify and reconcile these results with our own analysis. We have not been able to do so in this report.

We recognize that in preparing studies of this kind, differences in criteria, methodology, and reporting format are to be expected. We also recognize that these differences make direct comparisons between different studies difficult. The Total Capital Requirement estimated in this report is so much greater than any previously reported independent study and our own estimates, however, that the differences cannot be attributed to criteria, methodology or format.

Our major concern lies in the reported Total Process Capital. We have estimated the base case system using the study criteria and the most recent equipment quotations obtained from purchases made for current projects and in the preparation of lump sum proposals for other projects. We have used the sulfuric acid case for comparative purposes, and estimate the Total Process Capital to be \$105/KW as compared to the \$170.9/KW contained in this report.

Applying the factors assumed by EPRI to develop Total Plant Investment and Total Capital Requirement results in a Total Capital Requirement of \$166.6/KW as compared to the \$267.4/KW reported by EPRI.

While some differences in basic criteria exist such as a slightly lower sulfur content in the coal (3.5% vs. 4.0%) and higher allowable emission levels (1.2#/MBtu vs. .79#/MBtu), we call attention to the data published in the paper "Economics and Energy Requirements of Sulfur Oxides Control Processes," by G.G. McGlamery, T.W. Tarkington and S.V. Tomlinson of TVA. This paper was presented at the March 1979 Flue Gas Desulfurization Symposium in Las Vegas. In this analysis a Total Capital Investment of \$71,448,000 is reported, or \$142.9/KW as compared

to the \$267.4/KW reported in the EPRI study. We do not believe the aforementioned criteria differences account for the Capital Investment differences.

In brief, we believe the capital cost estimates are high by at least 60%. This difference is, of course, further reflected in the levelized busbar cost data.

In an attempt to reconcile this large difference in Total Process Capital estimates we have noted several departures in design features from what we would consider a preferred design.

1. The design used in this report includes extensive treatment of the pre-scrubber effluent by neutralization with lime, the addition of fly ash and chemical fixative to produce a sludge similar to that of the limestone throwaway effluent for disposal. While this option is technically feasible, and consistent with the treatment of throwaway process sludge, our experience has been that other options are available requiring less extensive treatment facilities. In none of the Wellman-Lord systems installed or in design at this time has such extensive treatment been required.

2. For all existing utility installations to date, Davy McKee has selected a square tile lined concrete design for the absorbers incorporating common walls between units. This decision has been reviewed in detail as each installation was designed, and in every case proven to be the most economical design as compared to other options, including the carbon steel shell with rubber lining design proposed in this study.

3. The general arrangement of the absorbers shown in Fig. 7-4 is not typical of existing or planned projects. This fact was noted in our comments to the contractor on our initial review of the first draft of the report, and a more typical layout was proposed. We believe our arrangement results in better gas distribution, reduced land requirements and lower costs.

We note two specific items in the economic data which we feel require comment.

1. The costs given for area 07 and 10 for the sulfuric acid option we believe are inconsistent with the costs presented for the sulfur option. We find reasonable agreement with the sulfur option costs, but our experience has indicated that the acid option has always been lower in cost than the sulfur option. We believe the indicated acid option costs are high by a factor of 2.

2. No by-product credit is given for the sulfate salt cake produced in the Wellman-Lord crystallizer section. We recognize that the value of this credit is somewhat more difficult to establish than the sulfur or acid product, but operators of existing Wellman-Lord plants have all been successful in marketing this material. We suggest that \$25/ton can be reasonably expected.

In conclusion, we do not believe that the incorporation of the specific design and economic details outlined in these comments will resolve the large difference between our analysis, other independent studies and the analysis in this report. We do not take exception to the economic premises and parameters selected by EPRI in preparing this report, as we believe the knowledgeable reader recognizes the need for a reasonable degree of commonality in making comparative reviews, and that such commonality limits to some extent the economic and technical options available to the purchaser and designer of a specific plant. In the area of equipment and erection costs (represented in this study as Total Process Capital), however, we believe our experience in the purchase and erection of similar plants qualifies our exception to the analysis presented in this report.

We regret that time and resources to fully resolve the apparent differences have not been available to us. We appreciate the opportunity to present our concerns and wish it were not necessary to do so. Our only interest is that the economics of our Wellman-Lord process be reasonably presented, and do not believe this report does so.

CHIYODA INTERNATIONAL CORPORATION'S COMMENTS

At the request of EPRI, Chiyoda International Corporation has reviewed Sections 3 and 6 of this report and offers the following comments in an effort to ensure an accurate representation of the Chiyoda Thoroughbred 121 (CT-121) Flue Gas Desulfurization technology and to bring to the reader's attention any discrepancies between the CT-121 technology presented herein and the CT-121 technology currently being offered commercially to the electric utility industry. For the reader's convenience the page number and paragraph of the subject matter for which the comments are directed are identified.

Page 3-13, Paragraphs D and E

CT-121 is being offered commercially to the electric utility industry on a lump sum competitive bid basis. We, therefore, believe that there can be no more uncertainty in CT-121's cost as opposed to any of the systems evaluated in this report. We, therefore, believe it is inappropriate to assign a higher contingency to CT-121. We believe that a contingency may be justified and applicable to a system under development, but not a system such as CT-121 which is fully developed with a fixed design.

Page 6-2, Paragraph 3

It should be noted that CT-121 by-product gypsum, in addition to its use in the manufacture of wallboard, is also suitable for use as a retarder in the manufacture of Portland cement or as a fertilizer or soil conditioner. These additional uses can be important market outlets, especially for smaller power plants or in cases in which transportation costs of the by-product gypsum rules out its use in the manufacture of wallboard. It should also be noted that although transportation costs make the sale of gypsum site specific, there are still considerable opportunities for its sale.

Page 6-3, Figure 6-1

Figure 6-1 illustrates the use of a filter splitter box and progressive cavity pumps for gypsum slurry service for the Gypsum Stacking and Mechanical Dewatering alternates. Although this can be considered a viable application, our preference, based on our commercial experience, is to use a splitter pipe header and centrifugal pumps.

Page 6-7, Paragraph 1

"Gypsum stacking" is an ultimate disposal technique which takes full advantage of the rapid settling and inherent stability of the CT-121 by-product gypsum. This method of disposal was developed by industry to eliminate the need for mechanical dewatering equipment, trucking costs, and to reduce land requirements to minimize overall disposal costs. The phosphate industry which produces huge quantities of gypsum, as well as other industries such as the nonferrous smelter (tailings), and sugar refining (limestone precipitate) industries which also produce huge quantities of solid waste, all use the "stacking" disposal technique which consists of pumping the solid wastes in slurry form to the ultimate disposal site where solid wastes settle out and the process liquors recycled to the process. Therefore, we do not visualize "gypsum stacking" merely as a means to dewater gypsum as presented herein, but rather an ultimate disposal method which takes full advantage of the rapid settling and stability of CT-121 gypsum to minimize overall disposal costs. For all of these industries, the "stacking" method of disposal has been determined the most cost effective means of permanently disposing huge quantities of by-product solid waste.

Page 6-8, Table 6-2

Table 6-2 shows power consumption as 2.2 percent of net generating capacity. This compares with our estimate of 1.8 percent.

Page 6-10, Paragraph 4

In paragraph 4 it is mentioned that the pH and slurry concentrations in the Jet Bubbling Reactor are maintained in the range of 3 to 5 and 10 to 30 weight percent, respectively. We believe that some misunderstanding may result from this description

of how these parameters are controlled. For both of these parameters, a single and optimum control point will be specified depending on site specific design criteria. We believe the report intended to describe the relative insensitivity of pH and slurry concentration.

Page 6-11, Paragraph 1

One of the major points to be considered in a technical evaluation pertains to the ease in which the FGD system by-product can be dewatered. Therefore, we believe that it is important that the dewatering characteristics of CT-121 by-product gypsum be clarified, particularly with respect to how these characteristics impact on the size and operability of filtration equipment.

The crystal size and configuration and the high settling and cake forming rates of CT-121 gypsum permits the use of a rotary vacuum filter designed specifically for free filtering materials. We have experienced filtration rates of up to 5,600 pounds per hour per square foot for sludges produced by conventional lime or limestone scrubbing systems. This high filtration rate impacts greatly on the size of filtration equipment. A conservative sizing criteria of 2,000 pounds per hour per square foot results in a drum size of four feet diameter by four feet wide for the 500 MW application considered in this report. This compares with a conventional filter which would require a drum size of fourteen feet diameter by twelve feet wide. In addition to a significant reduction in size, the filter itself is greatly simplified compared with conventional rotary drum vacuum filters. This is especially true with respect to internal piping. For rotary vacuum filters designed for free filtering materials, such as CT-121 gypsum, the internal piping is reduced to a single pipe. The result is a considerably higher effective vacuum across the filter cake.

Page 6-13, Table 6-3

We are not in a position to comment on the accuracy of the estimated capital requirement as the information provided was not intended for such an analysis and the estimated costs developed for the individual processes are not intended to reflect the absolute costs, but rather relative costs to be used for comparison purposes only. However, we can make some general observations: (1) the Total Process Capital compared with actual and similar commercial offerings is very high; (2) project and process contingencies are high compared to other systems under consideration

(refer to our comment for page 3-13, paragraphs D and E): (3) the costs included in this report are based on information which was available in February 1979. As such, they do not reflect recent and significant refinements to the technology which impact favorably on total system cost.

Page 6-14, Table 6-4

As for total capital requirements discussed above, we are not in a position to comment on the accuracy of the operating costs presented in Table 6-4. However, we can make the following general observations: (1) Operating and maintenance labor is excessive. We would expect that operating and maintenance costs for CT-121 would be considerably less than for the other systems considered due to simplicity of design and operation (no slurry recycle pump, thickeners and ancillary equipment) and improved process chemistry (complete oxidation of sulfite and sulfate and high limestone utilization) made possible by operation at a slightly lower pH and the use of gypsum seed crystals. Lower operating and maintenance costs is one of the most significant cost advantages of the CT-121 technology. (2) We would expect the "gypsum stack" alternate to be the least costly method of disposal based on pumping gypsum slurry directly to the disposal site as opposed to dewatering by "gypsum stacking" and then trucking to the disposal site which is the basis on which the disposal costs presented are based. The disposal costs presented in Table 6-4 for the "gypsum stack" alternate are essentially inflated by the costs incurred in handling and transporting the dewatered gypsum to the disposal site. Based on our "gypsum stacking" experience, we visualize only a part-time job for operation of a "gypsum stack" for the 500 MW application under study. Even for very large "gypsum stacking" operations, such as in the phosphate industry, only one or two men per day shift are required.