

NOTICE
CERTAIN DATA
CONTAINED IN THIS
DOCUMENT MAY BE
DIFFICULT TO READ
IN MICROFICHE
PRODUCTS.

DOE/PC/79796--T28

DOE/PC/79796--T28

DE92 041299

ENHANCING THE USE OF COALS BY
GAS REBURNING-SORBENT INJECTION

DE-FC22-87PC 79796

Environmental Monitoring Report
Quarterly Report No. 8
For the Period
April 1 - June 30, 1992

Prepared for
U.S. Department of Energy
Gas Research Institute
State of Illinois Department of
Energy and Natural Resources

Prepared by
Energy and Environmental Research Corporation
18 Mason
Irvine, California 92718

July 27, 1992

MASTER

JUL 31 1992

TABLE OF CONTENTS

1.0	INTRODUCTION	1
2.0	ENVIRONMENTAL MONITORING	12
2.1	Compliance Monitoring	12
2.1.1	Hennepin	12
2.1.2	Lakeside	12
2.2	Supplemental Monitoring	13
2.2.1	Hennepin	13
2.2.2	Lakeside	13
3.0	DATA DISCUSSION	15
3.1	Compliance Monitoring	15
3.1.1	Hennepin	15
3.1.2	Lakeside	15
3.2	Supplemental Monitoring	16
3.2.1	Hennepin	16
3.2.2	Lakeside	16
4.0	PERMIT STATUS	17
4.1	Hennepin	17
4.2	Lakeside	17
5.0	MODIFICATIONS TO MONITORING PLAN	18
5.1	Hennepin	18
5.2	Lakeside	18
Table 1	Hennepin Project Monitoring in Phases I and II	4
Table 2	Hennepin Project Monitoring in Phase III	5
Table 3	Lakeside Project Monitoring in Phases I and II	8
Table 4	Lakeside Project Monitoring in Phase III	10
Table 5	Continuous Emission Monitoring Data for Gaseous Emissions	14

APPENDIX A: Hennepin Discharge Monitoring and Coal Analysis Reports

APPENDIX B: Lakeside Discharge Monitoring and Excess Opacity Reports

APPENDIX C: Hennepin Draft NPDES Permit

1.0 INTRODUCTION

Clean Coal Technology implies the use of coal in an environmentally acceptable manner. Coal combustion results in the emission of two types of acid rain precursors: oxides of sulfur (SO_x) and oxides of nitrogen (NO_x). This Clean Coal Technology project will demonstrate a combination of two developed technologies to reduce both NO_x and SO_x emissions: gas reburning and calcium based dry sorbent injection. The demonstrations will be conducted on two pre-NSPS utility boilers representative of the U.S. boilers which contribute significantly to the inventory of acid rain precursor emissions: tangentially and cyclone fired units. Because of cost growth and lack of available funding, no further work has been done after Phase I at site B; the wall fired unit.

Gas reburning is a combustion modification technique that consists of firing 80-85 percent of the fuel (corresponding to the total heat release) in the lower furnace. Reduction of NO_x to molecular nitrogen (N_2) is accomplished via the downstream injection of the remaining fuel requirement in the form of natural gas (which also reduces the total SO_x emissions). In a third stage, burnout air is injected at lower temperatures in the upper furnace to complete the combustion process without generating significant additional NO_x .

Dry sorbent injection consists of injecting calcium based sorbents (such as limestone, dolomite, or hydrated lime) into the combustion products. For sulfation of the sorbent to CaSO_4 , an injection temperature of about 1230°C is optimum, but calcium-sulfur reactions can also take place at lower temperatures. Thus, the sorbent may be injected at different locations, such as with the burnout air, at the exit from the superheater, or into the ducting downstream of the air heater with H_2O added for humidification. The calcium sulfate or sulfite products are collected together with unreacted sorbent and fly ash by the electrostatic precipitator. The specific goal of this project is to demonstrate NO_x and SO_x emission reductions of 60 percent and 50 percent, respectively, on two coal fired utility boilers having the design characteristics mentioned above.

At the inception of the project, Host Site Agreements were signed by EER and three utility companies in the State of Illinois: Site A, Illinois Power Company (Hennepin Unit 1, 71MW (net) tangentially fired boiler in Hennepin); Site B, Central Illinois Light Company (Edwards Unit 1, 117 MW (net) front wall fired boiler in Bartonville); and Site C, City Water Light and Power (Lakeside Unit 7, 33 MW (net) cyclone fired boiler in Springfield).

Funding for this project is provided by the Department of Energy (DOE), the Gas Research Institute (GRI), and the State of Illinois Department of Energy and Natural Resources (ENR)--the other funding participants. GRI and ENR are responsible for funding approximately one-third and one-sixth, respectively, of the total project costs.

To achieve the objectives of the project, it is conducted in the following three phases at each site:

Phase I: Design and Permitting

Phase II: Construction and Startup

Phase III: Operation, Data Collection, Reporting and Disposition

Phase I work has been completed for all three sites. Because of cost growth and lack of available funding, no further work has been done after Phase I at Site B, the wall fired unit. At Site A, Phase II has been completed and Phase III long-term tests are currently underway. Site C is currently in Phase II of the program.

In accordance with the cooperative agreement, EER has prepared an Environmental Monitoring Plan to verify that no adverse environmental impacts would be associated with the project, to determine if projected emission control levels are being met, and to maintain a data base for future development of GR-SI technology. Tables 1 through 4 show the environmental monitoring to be conducted at Sites A and C, (Hennepin and Lakeside) during Phases I, II and III of the project.

The following section provides a description of the monitoring which has been conducted during the previous quarter at the host sites. A discussion of the monitoring results is presented in Section 3. Section 4 provides a status report of permits obtained for the project at each facility, and Section 5 discusses any proposed changes in the original monitoring plan based on available information.

TABLE 1. HENNEPIN PROJECT MONITORING IN PHASES I AND II

MEASUREMENT	SAMPLE TYPE	FREQUENCY	LOCATION
COMPLIANCE			
<u>WATER</u>			
Flow Rate	single reading estimate	once/	existing ash pond discharge
pH	grab sample	wk	existing ash pond discharge
Total Suspended Solids	24 hr composite	once/wk	existing ash pond discharge
Oil and Grease	grab sample	once/wk	existing ash pond discharge
		twice/mo	
<u>GASEOUS EMISSIONS</u>			
Coal Composition	24 hr composite	daily	coal hopper
sulfur, ash, Btu, moisture			
Coal Flow	24 hr composite	daily	coal feed belt
SUPPLEMENTAL			
<u>WATER</u>			
General Use Water Quality Standards	composite	once	Illinois River - 100 ft upstream and downstream of ash pond discharge
<u>GASEOUS EMISSIONS</u>			
NO _x	continuous	(1)	economizer inlet
CO	continuous	(1)	economizer inlet
O ₂	continuous	(1)	economizer inlet
SO ₂	continuous	(1)	economizer inlet
<u>WORKER HEALTH</u>			
Hearing		once (2)	TBD
Pulmonary Function		once (2)	TBD
TSP		once (2)	TBD

1. Two-week period in Phase I.
2. Must occur prior to initiation of Phase III.

TABLE 2. HENNEPIN PROJECT MONITORING IN PHASE III-page 1 of 3

MEASUREMENT	SAMPLE TYPE	FREQUENCY	LOCATION
COMPLIANCE			
WATER			
Flow Rate	24 hr total	daily	ash pond discharge
pH	grab sample	once/wk	ash pond discharge
Total Suspended Solids	24 hr composite	once/wk	ash pond discharge
Oil and Grease	grab sample	once/mo	ash pond discharge
Groundwater (pH, TDS, S, B, Mn, Ca, Chloride, Nitrate, Nitrite, Sulfite, Sulfate)	grab sample	(1)	groundwater monitoring wells
GASEOUS EMISSIONS			
Coal Composition	24 hr composite	daily	coal hopper
(sulfur, ash, Btu, moisture)			
Coal Flow	24 hr composite	daily	coal feed belt
SUPPLEMENTAL			
WATER			
III. River General Use Water Quality Standards (35 Ill. Adm. Code 302)	grab sample	once (4)	Illinois River - 100 ft upstream and downstream of ash pond discharge
Sluice water analyses(2)	grab sample	monthly (3)	ash sluice line to existing ash pond
GASEOUS EMISSIONS			
NO _x	extractive probe/ chemiluminescent	(8) continuous	stack breeching
SO _x	extractive probe/ NDUV	(8) continuous	stack breeching
CO	extractive probe/ NDIR	(8) continuous	stack breeching
CO ₂	extractive probe/ NDIR	(8) continuous	stack breeching
O ₂	extractive probe/ paramagnetic	(8) continuous	stack breeching
HC	extractive probe/ FID	(8) continuous	stack breeching

TABLE 2. HENNEPIN PROJECT MONITORING IN PHASE III
page 2 of 3

MEASUREMENT	SAMPLE TYPE	FREQUENCY	LOCATION
<u>GASEOUS EMISSIONS</u>			
Particulate Loading	Method 17	(4)	ESP inlet
	Method 5	(4)	ESP outlet
	cascade impactors	(4)	ESP inlet and outlet
<u>Particle Size Distribution</u>			
Resistivity	cyclonic flow probe	(4)	ESP inlet
	extractive	(5)	stack breeching
<u>SOLID BY-PRODUCTS</u>			
Ash (6)	composite of	(7)	bottom ash hopper, economizer, and ESP hoppers #1 and #2
<u>WORKER HEALTH</u>			
Hearing	N/A	once/yr	TBD
Pulmonary Function	N/A	once/yr	TBD
TSP	N/A	once/yr	TBD
<u>AIR</u>			
Noise	single reading	once (4)	near equipment installation
Ambient Dust	single reading-Hi-Volume Sampler	once (4)	upwind and downwind of sorbent silo

TABLE 2. FOOTNOTES- HENNEPIN PROJECT MONITORING IN PHASE III
page 3 of 3

1. Monitoring will occur once prior to GR-SI operation, quarterly until the program is completed, and quarterly through closure and post-closure periods.

2. Water will be analyzed for arsenic, barium, boron, cadmium, chromium, iron, lead, mercury, oil and grease, pH, selenium, silver, sulfates, TDS, TSS, zinc, and flow rate.

3. Sampling will be conducted once prior to Phase III, then monthly for the first six months of long-term testing.

4. Measurements will be taken once prior to Phase III, then once during long term testing.

5. Samples will be collected once prior to Phase III, and once during long-term testing. Additional testing will then be done if the N₂O concentration is greater than 5 ppm.

6. Ash will be monitored for mineral analysis, free CaO, total organic carbon, sulfate, COD, phenol, cyanide, nitrate, chloride sulfide, specific gravity, fineness, pozzolanic activity, soundness, PAH and pH. Paint filter and TCLP tests will also be conducted.

7. Sampling will be conducted once prior to Phase III. During long-term testing sampling and analysis will be conducted monthly for the first 3 months.

8. Sampling will occur once prior to Phase III, and CEM data will be reported during long-term testing.

TABLE 3. LAKESIDE PROJECT MONITORING IN PHASES I AND II
page 1 of 2

MEASUREMENT	SAMPLE TYPE	FREQUENCY	LOCATION
COMPLIANCE			
WATER			
Flow Rate	single reading estimate	once/wk	ash pond discharge
pH	grab sample	twice/wk	ash pond discharge
Total Suspended Solids	24 hr composite	twice/wk	ash pond discharge
Oil and Grease	grab sample	twice/mo	ash pond discharge
Flow Rate	single reading estimate	once/wk	outfall 008
pH	grab sample	once/wk	outfall 008
Total Suspended Solids	8 hr composite	once/wk	outfall 008
Oil and Grease	grab sample	once/wk	outfall 008
Iron	8 hr composite	once/wk	outfall 008
GASEOUS EMISSIONS			
Opacity	in-situ optical	continuous	stack
SUPPLEMENTAL			
GASEOUS EMISSIONS			
NOx	extractive probe/ chemiluminescent	continuous (2)	air heater inlet
CO	extractive probe/ NDIR	continuous (2)	air heater inlet
O2	extractive probe/ paramagnetic	continuous (2)	air heater inlet
SO2	extractive probe/ NDUV	continuous (2)	air heater inlet
CO2	extractive probe/ NDIR	continuous (2)	air heater inlet
HC	extractive probe/ FID	continuous (2)	air heater inlet
Particulate Loading	Method 17	see note 2	ESP inlet
	Method 5	see note 2	ESP outlet
Particle Size	cascade impactors	see note 2	ESP inlet and outlet
Distribution	cyclonic flow probe	see note 2	ESP inlet
Resistivity	extractive	see note 2	air heater inlet
N2O			

TABLE 3. LAKESIDE PROJECT MONITORING IN PHASES I AND II
page 2 of 2

MEASUREMENT	SAMPLE TYPE	FREQUENCY	LOCATION
SUPPLEMENTAL			
<u>WATER</u>			
pH, sulfates	grab sample	once	sluice line discharge
pH, sulfates	grab sample	once	sluice water intake (Lake Springfield)
<u>SOLID BY-PRODUCTS</u>			
Ash (1)	grab sample	(2)	Ash Hoppers
<u>WORKER HEALTH</u>			
Hearing	NA	once (3)	TBD
Pulmonary Function	N/A	once (3)	TBD
TSP	N/A	once (3)	TBD
<u>AIR</u>			
Noise	single reading	once (3)	near equipment installation
Ambient Dust	single reading	once (3)	near coal pile

1. Ash will be monitored for the following parameters: mineral analysis, TCLP, total organic carbon, cyanide chloride, sulfide, specific gravity, fineness, PAH, and pH.
2. Measurements will be taken once during Phase I.
3. Must occur prior to initiation of Phase III.

TABLE 4. LAKESIDE PROJECT MONITORING IN PHASE III
page 1 of 2

MEASUREMENT	SAMPLE TYPE	FREQUENCY	LOCATION
COMPLIANCE			
WATER			
Flow Rate	single reading estimate	once/wk	ash pond discharge
pH	grab sample	twice/wk	ash pond discharge
Total Suspended Solids	24 hr composite	twice/wk	ash pond discharge
Oil and Grease	grab sample	twice/mo	ash pond discharge
Flow Rate	single reading estimate	once/mo	outfall 008
pH	grab sample	once/wk	outfall 008
Total Suspended Solids	8 hr composite	once/wk	outfall 008
Oil and Grease	grab sample	once/wk	outfall 008
Iron	8 hr composite	once/wk	outfall 008
GASEOUS EMISSIONS			
Opacity	in-situ optical	continuous	stack
SUPPLEMENTAL			
WATER			
pH, sulfate	grab sample	see note 1	sluice line discharge
pH, sulfate	grab sample	see note 1	sluice water intake (Lake Springfield)
GASEOUS EMISSIONS			
NO _x	extractive probe/ chemiluminescent	continuous	air heater inlet
SO _x	extractive probe/ NDUV	continuous	air heater inlet
CO	extractive probe/ NDIR	continuous	air heater inlet
CO ₂	extractive probe/ NDIR	continuous	air heater inlet
O ₂	extractive probe/ paramagnetic	continuous	air heater inlet
HC	extractive probe/ FID	continuous	air heater inlet
Particulate Loading	Method 17	see note 1	ESP inlet
	Method 5	see note 1	ESP outlet

TABLE 4. LAKESIDE PROJECT MONITORING IN PHASE III, continued

MEASUREMENT	SAMPLE TYPE	FREQUENCY	LOCATION
GASEOUS EMISSIONS			
Particle Size	cascade impactors	see note 1	ESP inlet and outlet
Distribution	cyclonic flow probe	see note 1	ESP inlet
Resistivity	extracive	see note 2	air heater inlet
N ₂ O			
SOLID BY-PRODUCTS			
Ash	grab sample	see note 3	ESP hopper
WORKER HEALTH			
Hearing	N/A	once/yr	TBD
Pulmonary Function	N/A	once/yr	TBD
AIR			
Noise	single reading	once (1)	near equipment installation
Ambient Dust	single reading	once (1)	near coal pile

1. Measurements take once during Phase III long-term testing.
2. N₂O measurements taken once during long-term testing. Additional testing will then be done if the N₂O concentration is greater than 5 ppm.
3. Ash sampling will be conducted monthly for the first three months of the long-term testing period.

2.0 ENVIRONMENTAL MONITORING

Both compliance and supplemental monitoring was conducted at the Hennepin site during the previous quarter. At the Lakeside site, only compliance monitoring was conducted during the previous quarter. The monitoring results from Hennepin and Lakeside are presented in the following sections.

2.1 Compliance Monitoring

Compliance monitoring is that monitoring required by Federal, State or local authorities.

2.1.1 Hennepin

The compliance monitoring conducted at Hennepin during the quarter which directly influences this project includes NPDES permit monitoring, coal quality reports, and groundwater monitoring data. Illinois Power submits NPDES Discharge Monitoring Reports to the Illinois EPA, on a monthly basis. Coal quality reports are submitted to Illinois EPA on a quarterly basis. Copies of the discharge monitoring and coal quality reports for April, May, and June are included in Appendix A of this report. Groundwater monitoring results for this quarter were unavailable; they will be reported in the October, 1992 quarterly report.

2.1.2 Lakeside

The compliance monitoring conducted at Lakeside during the quarter which directly influences this project includes NPDES permit monitoring and gaseous emissions opacity reports. Copies of the NPDES and excess opacity reports for April, May, and June are included in Appendix B of this report.

2.2 Supplemental Monitoring

2.2.1 Hennepin

The supplemental monitoring reported during this quarter consisted only of Continuous Emission Monitor daily averages for SO₂, NO_x, CO₂, CO, O₂, and HC. The results of the continuous emission monitoring are outlined in Table 5.

2.2.2 Lakeside

No supplemental monitoring was conducted at Lakeside during this quarter.

Table 5. Continuous Emission Monitoring Data for Gaseous Emissions*

Emissions Process:	CEMs O ₂ % Dry	CO ppm @ 3% O ₂	CO ₂ % @ 3% O ₂	NO _x ppm @ 3% O ₂	NO _x lb/mBtu	SO ₂ ppm @ 3% O ₂	SO ₂ lb/mBtu	HC ppm @ 3% O ₂	Duration in Hours
Baseline w/ OFA Off	6.15	8.2	15.5	409	0.557	2753	5.25	3.2	1.0
Baseline w/ OFA On	6.32	3.5	15.5	299	0.495	2763	5.27	2.6	18.3
Gas Reburn ***	6.38	4.4	14.6	227	0.304	2352	4.40	2.7	8.6
Sorbent Injection	6.41	21.5	15.5	377	0.514	1556	2.97	1.5	18.9
Gas Reburn w/Sorbent Injection ***	5.97	61.6	14.6	194	0.260	1337	2.51	1.5	77.7

- CEM averages were taken under following process conditions: baseline with overfire air off, baseline with overfire air on, gas reburning, sorbent injection, and gas reburning with sorbent injection.
- CEMs Sampling was performed at the stack breeching.
- Data include:
 - (1) Results from parametric runs under a variety of test conditions, and
 - (2) Results obtained during load following operation
 During load swings, due to sluggish boiler combustion controls, the excess air levels deviate significantly from the set point which affects NO_x and CO levels.

3.0 DATA DISCUSSION

3.1 Compliance Monitoring

3.1.1 Hennepin

The discharge monitoring reports for April through June indicated that no effluents were discharged from the ash pond to the Illinois River. The gaseous emissions for the coal composition did not exceed the regulatory emission rate of 17,050 lbs. of SO₂ per hour. The average lbs. of SO₂ per MBTU for this quarter was 5.30, based on the coal analysis. The GR-SI demonstration program substantially reduced the SO₂ emissions during the process operational hours.

3.1.2 Lakeside

The discharge monitoring reports for the ash pond outfall structure and the coal pile runoff during the months of April through June indicate that the ash pond outfall did not exceed the NPDES permit limitations. The coal pile runoff did not produce a discharge stream during this quarter.

The gaseous emissions opacity reports for April through June indicate that the opacity limit of 30 percent was exceeded during each of the three months. April exceedances were due startup, shutdown, precipitator failure, maintenance repairs, or unknown causes. Excess opacity readings in May were attributed to startup, shutdown, unit trip, precipitator field trip, air damper malfunction, and switching precipitator fields. June excess opacity measurements were due to startup, shutdown, precipitator malfunction, or unknown causes.

3.2 Supplemental Monitoring

3.2.1 Hennepin

Continuous Emission Monitoring averages were taken under the following process conditions: baseline with over fire air off; baseline with over fire air on; gas reburning, sorbent injection, gas reburning with sorbent injection. These averages show that there was a 53 percent reduction in NO_x from baseline with overfire air off, when implementing gas reburning with sorbent injection. In addition, there was a 51 percent reduction in SO₂ from baseline with overfire air off, when implementing gas reburning with sorbent injection.

3.2.2 Lakeside

No supplemental monitoring was conducted at Lakeside during this quarter.

4.0 PERMIT STATUS

Permits have been obtained for construction and operation of the GR-SI system at Hennepin. At Lakeside, construction is in progress, and operating permits have not been obtained yet. The following sections describe the permits obtained at each host site.

4.1 Hennepin

IP applied for a construction permit for the GR-SI project at Hennepin on July 7, 1989, and Illinois Environmental Protection Agency granted that permit on October 18, 1989. A modification to the construction permit for operation of the GR-SI demonstration for a period of 270 days was requested. This permit was granted June 21, 1990. A permit also was required to install the pH adjustment system for the GR-SI ash transport water to the existing ash pond. This permit was granted on July 25, 1990. Negotiations between Illinois Power, the Illinois EPA, and the U.S. EPA has resulted in the issuance of a revised draft Hennepin NPDES permit. During August, compliance monitoring will be performed on the unit's air emissions per requirements of the draft permit. A copy of this draft permit is included in Appendix C of this report.

4.2 Lakeside

On January 8, 1990, CWLP submitted a PSD permit application for the GR-SI demonstration at Lakeside Unit 7. On July 5, 1990, CWLP granted the Illinois Environmental Protection Agency a waiver from its statutory deadline to review the permit application (180 days) for a period of 120 days. Permit approval was received November 16, 1990. EER is in the process of applying for a Special Waste Permit through the Christian County Landfill for the future disposal of the Lakeside fly ash waste stream. A pre-permit for the disposal of special waste at the Christian County Landfill was obtained on March 18, 1992.

5.0 MODIFICATIONS TO MONITORING PLAN

5.1 Hennepin

There are no recommended modifications to the proposed monitoring plan as outlined in Table 1 and 2.

5.2 Lakeside

There are no recommended modifications to the proposed monitoring plan as listed in Tables 3 and 4.

APPENDIX A

DISCHARGE MONITORING REPORT

ILLINOIS POWER COMPANY

ADDRESS 500 South 27th Street
Decatur, IL 62525
PHONE (217) 424-6831

Unit Agency of Administration, Section 1042, Disclosure of this Information
Solicitor 1919, Chapter 111 1/2. Section 1042, Disclosure of this Information

100

PAGE 5 OF 6

88

DISCHARGE MONITORING REPORT

ILLINOIS POWER COMPANY

500 South 27th Street
Decatur, IL 62525
(217) 424-6811

111	111	111
51	51	51
111	111	111
51	51	51
111	111	111

MINIMUM PRICE IN RUPEES

Hennepin Power Plant Ash Lagoon 1 & 3 Discharge

* No discharge in May, 1992.

		LONGITUDE
		LATITUDE
	SIC	

10	912	015	011
11	912	015	011
12	912	015	011
13	912	015	011
14	912	015	011

NAME OF PRINCIPAL EXECUTIVE OFFICER Chairman	NAME OF THE OFFICER Vice-President	DATE 11/11/01	I certify that I am familiar with the information contained in this report and that is the best of my knowledge and belief such information is true, complete, and accurate.		
	W.	MM	YEAR	MO	DAY
Connelly	W.	11	11	01	

This Agency is authorized to receive this Information under Illinois Revised Statutes, 103/2, Chapter 111 1/2, Section 1042.2, Section 1042.2, Disclosure of Certain Information to the Public, which provides that an agency may receive an oral disclosure up to \$10,000.00 per disclosure.

PAGE 5 OF 6

ILLINOIS POWER COMPANY
HENNEPIN POWER STATION
COAL ANALYSIS REPORT FOR THE FERID 040192 TO 043092
FOR THE VENDOR : COAL TO BUNKERS

SAMPLE DATE	TONS TO BUNKERS	%	MOISTURE (AR)	%	ASH (AR)	%	SULFUR (AR)	BTU/LB (DRY)	BTU/LB (DR)	BTU/LB (H.A.F.)	STU/LB (H.A.F.)	STU/LB (H.A.F.)	UNIT	FOUNDS	202	202 LIMIT EXCEEDED	
													STU/LB	COAL	STU/LB	PER UNIT	
04/01/92	545.00	13.28	10.29	2.94	10.99	12.53	14.251	14.532	5.26								
04/02/92	714.99	13.22	9.54	2.91	10.49	12.617	14.174	14.429	5.19								
04/03/92	572.69	14.63	10.08	2.85	10.704	12.539	14.217	14.494	5.13								
04/04/92	1,585.09	12.91	10.22	2.91	10.907	12.524	14.189	14.454	5.29								
04/05/92	1,591.09	14.15	10.49	2.95	10.592	12.455	14.188	14.462	5.29								
04/06/92	571.69	14.47	11.52	2.76	10.455	12.225	14.129	14.416	5.15								
04/07/92	1,209.99	12.98	11.63	3.15	10.754	12.344	14.243	14.551	5.71								
04/08/92	603.69	15.19	11.99	2.96	10.393	12.241	14.252	14.563	5.55								
04/09/92	1,555.09	14.57	11.86	2.93	10.504	12.295	14.277	14.536	5.44								
04/10/92	1,503.09	13.98	10.63	3.91	10.704	12.445	14.128	14.426	5.46								
04/11/92	1,563.09	13.97	10.55	3.09	10.761	12.503	14.258	14.533	5.44								
04/12/92	2,557.69	15.57	10.12	2.68	10.543	12.591	14.295	14.477	5.22								
04/13/92	1,559.99	13.56	10.41	2.92	10.799	12.484	14.294	14.476	5.27								
04/14/92	1,611.09	13.98	10.64	2.73	10.684	12.421	14.174	14.452	5.35								
04/15/92	1,178.99	12.57	10.90	2.95	10.874	12.438	14.297	14.489	5.29								
04/16/92	667.09	13.44	10.31	2.79	10.829	12.519	14.292	14.466	5.22								
04/17/92	692.09	12.82	11.12	3.14	10.817	12.498	14.221	14.515	5.63								
04/18/92	516.09	12.55	10.50	3.31	10.925	12.493	14.215	14.505	5.91								
04/19/92	1,717.09	13.03	10.55	2.52	10.872	12.500	14.225	14.501	5.24								
04/20/92	1,748.09	13.07	10.66	2.90	10.831	12.457	14.209	14.475	5.24								
04/21/92	1,736.09	13.07	10.96	2.84	10.921	12.563	14.293	14.469	5.67								

WEIGHTED AVERAGES FOR THE PERIOD 040192 TO 043092

TOTAL TONS	MOISTURE (AR)	ASH (AR)	SULFUR (AR)	BTU/LB (DRY)	BTU/LB (DR)	BTU/LB (H.A.F.)	UNIT	COAL	BTU/LB	BTU/LB	BTU/LB (H.A.F.)	BTU/LB (H.A.F.)	UNIT	COAL	BTU/LB	BTU/LB	BTU/LB (H.A.F.)	BTU/LB (H.A.F.)
							STU/LB	STU/LB	STU/LB	COAL	STU/LB	COAL	STU/LB	COAL	STU/LB	COAL	STU/LB	COAL
25,278.09	13.73	10.80	2.93	10.754	12.455	14.219	14.438	5.34										

END OF REPORT RUN ON 05/05/92 AT 16:10:50

ILLINOIS POWER COMPANY
HEMINGWAY POWER STATION
COAL ANALYSIS REPORT FOR THE PERIOD 050192 TO 053192
FOR THE VENDOR : COAL TO BUNKERS

UNIT	FOUND		202		302		UNIT	
	COAL	WATER	PER CENT					
1	14.412	16.57	16.550	14.416	14.335	14.417	14.412	14.335
2	14.455	16.65	16.64	14.464	14.540	14.527	14.452	14.519
3	14.524	16.72	16.71	14.520	14.513	14.519	14.520	14.513
4	14.562	16.72	16.70	14.561	14.553	14.549	14.560	14.553
5	14.637	16.75	16.73	14.635	14.627	14.623	14.634	14.627
6	14.633	16.75	16.73	14.631	14.625	14.621	14.632	14.625
7	14.634	16.75	16.73	14.632	14.626	14.622	14.631	14.626
8	14.635	16.75	16.73	14.633	14.627	14.623	14.632	14.627
9	14.636	16.75	16.73	14.634	14.628	14.624	14.633	14.628
10	14.637	16.75	16.73	14.635	14.629	14.625	14.634	14.629
11	14.638	16.75	16.73	14.636	14.630	14.626	14.635	14.630
12	14.639	16.75	16.73	14.637	14.631	14.627	14.636	14.631
13	14.640	16.75	16.73	14.638	14.632	14.628	14.637	14.632
14	14.641	16.75	16.73	14.639	14.633	14.629	14.638	14.633
15	14.642	16.75	16.73	14.640	14.634	14.630	14.641	14.634
16	14.643	16.75	16.73	14.641	14.635	14.631	14.642	14.635
17	14.644	16.75	16.73	14.642	14.636	14.632	14.643	14.636
18	14.645	16.75	16.73	14.643	14.637	14.633	14.644	14.637
19	14.646	16.75	16.73	14.644	14.638	14.634	14.645	14.638
20	14.647	16.75	16.73	14.645	14.639	14.635	14.646	14.639
21	14.648	16.75	16.73	14.646	14.640	14.636	14.647	14.640
22	14.649	16.75	16.73	14.647	14.641	14.637	14.648	14.641
23	14.650	16.75	16.73	14.648	14.642	14.638	14.649	14.642
24	14.651	16.75	16.73	14.649	14.643	14.639	14.650	14.643
25	14.652	16.75	16.73	14.650	14.644	14.640	14.651	14.644
26	14.653	16.75	16.73	14.651	14.645	14.641	14.652	14.645
27	14.654	16.75	16.73	14.652	14.646	14.642	14.653	14.646
28	14.655	16.75	16.73	14.653	14.647	14.643	14.654	14.647
29	14.656	16.75	16.73	14.654	14.648	14.644	14.655	14.648
30	14.657	16.75	16.73	14.655	14.649	14.645	14.656	14.649
31	14.658	16.75	16.73	14.656	14.650	14.646	14.657	14.650
32	14.659	16.75	16.73	14.657	14.651	14.647	14.658	14.651
33	14.660	16.75	16.73	14.658	14.652	14.648	14.659	14.652
34	14.661	16.75	16.73	14.659	14.653	14.649	14.660	14.653
35	14.662	16.75	16.73	14.660	14.654	14.650	14.661	14.654
36	14.663	16.75	16.73	14.661	14.655	14.651	14.662	14.655
37	14.664	16.75	16.73	14.662	14.656	14.652	14.663	14.656
38	14.665	16.75	16.73	14.663	14.657	14.653	14.664	14.657
39	14.666	16.75	16.73	14.664	14.658	14.654	14.665	14.658
40	14.667	16.75	16.73	14.665	14.659	14.655	14.666	14.659
41	14.668	16.75	16.73	14.666	14.660	14.656	14.667	14.660
42	14.669	16.75	16.73	14.667	14.661	14.657	14.668	14.661
43	14.670	16.75	16.73	14.668	14.662	14.658	14.669	14.662
44	14.671	16.75	16.73	14.669	14.663	14.659	14.670	14.663
45	14.672	16.75	16.73	14.670	14.664	14.660	14.671	14.664
46	14.673	16.75	16.73	14.671	14.665	14.661	14.672	14.665
47	14.674	16.75	16.73	14.672	14.666	14.662	14.673	14.666
48	14.675	16.75	16.73	14.673	14.667	14.663	14.674	14.667
49	14.676	16.75	16.73	14.674	14.668	14.664	14.675	14.668
50	14.677	16.75	16.73	14.675	14.669	14.665	14.676	14.669
51	14.678	16.75	16.73	14.676	14.670	14.666	14.677	14.670
52	14.679	16.75	16.73	14.677	14.671	14.667	14.678	14.671
53	14.680	16.75	16.73	14.678	14.672	14.668	14.679	14.672
54	14.681	16.75	16.73	14.679	14.673	14.669	14.680	14.673
55	14.682	16.75	16.73	14.680	14.674	14.670	14.681	14.674
56	14.683	16.75	16.73	14.681	14.675	14.671	14.682	14.675
57	14.684	16.75	16.73	14.682	14.676	14.672	14.683	14.676
58	14.685	16.75	16.73	14.683	14.677	14.673	14.684	14.677
59	14.686	16.75	16.73	14.684	14.678	14.674	14.685	14.678
60	14.687	16.75	16.73	14.685	14.679	14.675	14.686	14.679
61	14.688	16.75	16.73	14.686	14.680	14.676	14.687	14.680
62	14.689	16.75	16.73	14.687	14.681	14.677	14.688	14.681
63	14.690	16.75	16.73	14.688	14.682	14.678	14.689	14.682
64	14.691	16.75	16.73	14.689	14.683	14.679	14.690	14.683
65	14.692	16.75	16.73	14.690	14.684	14.680	14.691	14.684
66	14.693	16.75	16.73	14.691	14.685	14.681	14.692	14.685
67	14.694	16.75	16.73	14.692	14.686	14.682	14.693	14.686
68	14.695	16.75	16.73	14.693	14.687	14.683	14.694	14.687
69	14.696	16.75	16.73	14.694	14.688	14.684	14.695	14.688
70	14.697	16.75	16.73	14.695	14.689	14.685	14.696	14.689
71	14.698	16.75	16.73	14.696	14.690	14.686	14.697	14.690
72	14.699	16.75	16.73	14.697	14.691	14.687	14.698	14.691
73	14.700	16.75	16.73	14.698	14.692	14.688	14.699	14.692
74	14.701	16.75	16.73	14.699	14.693	14.689	14.700	14.693
75	14.702	16.75	16.73	14.700	14.694	14.690	14.701	14.694
76	14.703	16.75	16.73	14.701	14.695	14.691	14.702	14.695
77	14.704	16.75	16.73	14.702	14.696	14.692	14.703	14.696
78	14.705	16.75	16.73	14.703	14.697	14.693	14.704	14.697
79	14.706	16.75	16.73	14.704	14.698	14.694	14.705	14.698
80	14.707	16.75	16.73	14.705	14.699	14.695	14.706	14.699
81	14.708	16.75	16.73	14.706	14.700	14.696	14.707	14.700
82	14.709	16.75	16.73	14.707	14.701	14.697	14.708	14.701
83	14.710	16.75	16.73	14.708	14.702	14.698	14.709	14.702
84	14.711	16.75	16.73	14.709	14.703	14.699	14.710	14.703
85	14.712	16.75	16.73	14.710	14.704	14.700	14.711	14.704
86	14.713	16.75	16.73	14.711	14.705	14.701	14.712	14.705
87	14.714	16.75	16.73	14.712	14.706	14.702	14.713	14.706
88	14.715	16.75	16.73	14.713	14.707	14.703	14.714	14.707
89	14.716	16.75	16.73	14.714	14.708	14.704	14.715	14.708
90	14.717	16.75	16.73	14.715	14.709	14.705	14.716	14.709
91	14.718	16.75	16.73	14.716	14.710	14.706	14.717	14.710
92	14.719	16.75	16.73	14.717	14.711	14.707	14.718	14.711
93	14.720	16.75	16.73	14.718	14.712	14.708	14.719	14.712
94	14.721	16.75	16.73	14.719	14.713	14.709	14.720	14.713
95	14.722	16.75	16.73	14.720	14.714	14.710	14.721	14.714
96	14.723	16.75	16.73	14.721	14.715	14.711	14.722	14.715
97	14.724	16.75	16.73	14.722	14.716	14.712	14.723	14.716
98	14.725	16.75	16.73	14.723	14.717	14.713	14.724	14.717
99	14.726	16.75	16.73	14.724	14.718	14.714	14.725	14.718
100	14.727	16.75	16.73	14.725	14.719	14.715	14.726	14.719
101	14.728	16.75	16.73	14.726	14.720	14.716	14.727	14.720
102	14.729	16.75	16.73	14.727	14.721	14.717	14.728	14.721
103	14.730	16.75	16.73	14.728	14.722	14.718	14.729	14.722
104	14.731	16.75	16.73	14.729	14.723	14.719	14.730	14.723
105	14.732	16.75	16.73	14.730	14.724	14.720	14.731	14.724
106	14.733	16.75	16.73	14.731	14.725	14.721	14.732	14.725
107	14.734	16.75	16.73	14.732	14.726	14.722	14.733	14.726
108	14.735	16.75	16.73	14.733	14.727	14.723	14.734	14.727
109	14.736	16.75	16.73	14.734	14.728	14.724	14.735	14.728
110	14.737	16.75	16.73	14.735	14.729	14.725	14.736	14.729
111	14.738	16.75	16.73	14.736	14.730	14.726	14.737	14.730
112	14.739	16.75	16.73	14.737	14.731	14.727	14.738	14.731
113	14.740	16.75	16.73	14.738	14.732	14.728	14.739	14.732
114	14.741	16.75	16.73	14.739	14.733	14.729	14.740	14.733
115	14.742	16.75	16.73	14.740	14.734	14.730	14.741	14.734
116	14.743	16.75	16.73	14.741	14.735	14.731	14.742	14.735
117	14.744	16.75	16.73	14.742	14.736	14.732	14.743	14.736
118	14.745	16.75	16.73	14.743	14.737	14.733	14.744	14.737
119	14.746	16.75	16.73	14.744	14.738	14.734	14.745	14.738
120	14.747	16.75	16.73	14.745	14.739	14.735	14.746	14.739
121	14.748	16.75	16.73	14.746	14.740	14.736	14.747	14.740
122	14.749	16.75	16.73	14.747	14.741	14.737	14.748	14.741
123	1							

卷之三

Tribute to Prof. Dr. S. S. Sankaranarayanan 141

ILLINOIS POWER COMPANY
HENNEPIN POWER STATION
COAL ANALYSIS REPORT FOR THE PERIOD 060172 TO 063972
FOR THE VENDOR : COAL TO BUNKERS
(COMPLETED SAMPLES)

SAMPLE DATE	TONS TO BUNKERS	MOISTURE (AR)	ASH (AR)	SULFUR (AR)	BTU/LB (DRY)	BTU/LB (H.A.F.)	BTU/LB (DRY)	BTU/LB (H.A.F.)	UNIT COAL BTU/LB	UNIT COAL BTU/LB	FOUND 502	FOUND 502	ABOVE 5.3 FOUND 502
06/01/72	992.90	12.52	10.93	2.99	10,942	12,354	14,163	14,443	14,456	14,456	5.38	5.38	
06/02/72	662.00	12.86	11.78	2.97	10,755	12,343	14,179	14,451	14,453	14,453	5.39	5.39	
06/03/72	12.51	12.51	10.53	3.02	10,731	12,343	14,176	14,449	14,455	14,455	5.47	5.47	
06/04/72	1,514.00	13.62	10.91	3.02	10,625	12,381	14,171	14,456	14,456	14,456	5.51	5.51	
06/05/72	1,469.00	14.59	9.93	2.88	10,634	12,510	14,156	14,429	14,429	14,429	5.23	5.23	
06/06/72	1,295.93	14.65	9.73	2.88	10,666	12,496	14,135	14,397	14,397	14,397	5.27	5.27	
06/07/72	1,647.00	14.70	10.59	2.94	10,541	12,531	14,131	14,408	14,408	14,408	5.44	5.44	
06/08/72	1,545.00	14.65	10.32	3.04	10,632	12,454	14,153	14,445	14,445	14,445	5.53	5.53	
06/09/72	1,647.00	11.14	10.32	3.06	11,140	12,533	14,172	14,438	14,438	14,438	5.39	5.39	
06/10/72	2,128.00	12.72	10.17	3.05	10,759	12,515	14,159	14,425	14,425	14,425	5.41	5.41	
06/11/72	1,364.00	12.99	10.44	2.96	10,897	12,568	14,212	14,483	14,483	14,483	5.30	5.30	
06/12/72	1,766.00	13.41	10.75	2.93	10,735	12,432	14,195	14,471	14,471	14,471	5.25	5.25	
06/13/72	1,772.00	13.52	11.19	2.96	10,676	12,345	14,179	14,469	14,469	14,469	5.41	5.41	
06/14/72	1,775.00	12.81	10.63	3.04	10,842	12,425	14,161	14,438	14,438	14,438	5.47	5.47	
06/15/72	1,775.00	13.04	11.16	3.01	10,769	12,362	14,204	14,472	14,472	14,472	5.37	5.37	
06/16/72	3,327.00	13.04	11.16	3.01	10,769	12,318	14,193	14,475	14,475	14,475	5.33	5.33	
06/17/72	1,774.00	12.92	10.96	2.99	10,755	12,371	14,213	14,494	14,494	14,494	5.35	5.35	
06/18/72	1,581.00	13.78	10.79	2.93	10,721	12,435	14,187	14,462	14,462	14,462	5.28	5.28	
06/19/72	1,594.00	12.46	10.69	2.98	10,903	12,454	14,187	14,462	14,462	14,462	5.47	5.47	
06/20/72	1,557.00	13.73	10.50	2.92	10,793	12,515	14,250	14,527	14,527	14,527	5.26	5.26	
06/21/72	1,622.00	12.55	10.39	2.96	10,759	12,543	14,233	14,503	14,503	14,503	5.26	5.26	
06/22/72	1,623.00	12.55	10.39	2.96	10,759	12,503	14,138	14,399	14,399	14,399	5.26	5.26	
06/23/72	1,716.00	12.74	10.74	2.99	10,910	12,576	14,242	14,507	14,507	14,507	5.17	5.17	
06/24/72	1,592.00	13.20	10.15	2.89	10,915	12,603	14,262	14,526	14,526	14,526	5.11	5.11	
06/25/72	3,406.00	13.15	10.16	2.87	10,945	12,553	14,232	14,501	14,501	14,501	5.23	5.23	
06/26/72	1,451.00	12.21	10.21	2.85	10,766	12,576	14,232	14,501	14,501	14,501	5.23	5.23	
06/27/72	1,626.00	12.74	10.21	2.85	10,766	12,553	14,232	14,501	14,501	14,501	5.23	5.23	
06/28/72	1,899.00	12.23	10.15	2.95	11,021	12,557	14,201	14,469	14,469	14,469	5.40	5.40	
06/29/72	1,937.00	12.59	10.55	2.97	10,977	12,500	14,213	14,486	14,486	14,486	5.39	5.39	
06/30/72	2,172.00	12.76	10.67	3.01	10,922	12,520	14,265	14,544	14,544	14,544	5.37	5.37	

WEIGHTED AVERAGES FOR THE PERIOD 060172 TO 063972

TOTAL TONS	MOISTURE (AR)	ASH (AR)	SULFUR (AR)	BTU/LB (DR)	BTU/LB (H.A.F.)	UNIT COAL BTU/LB	LBS. 502 PER METU
43,900.00	13.17	19.53	2.97	10,833	12,475	14,197	14,471

END OF REPORT RUN ON 07/07/72 AT 11:25:34

APPENDIX B

DISCHARGE MONITORING REPORT

PERMITTEE NAME: City Water, Light & Power
ADDRESS: Seventh & Monroe
Springfield, IL 62757
PHONE: (217) 786-4052

12-3	LL	SI
14-16	IL. 0024767 PERMIT NUMBER	
17-19	004	DIS
	SIC	

REPORTING PERIOD	FROM
YEAR	12
MO	04
DAY	01

32.371

This Agency is authorized to require this information under Illinois Revised Statutes, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 per day of violation and termination of the contract.

12 - 5

卷五 - 12

DISCHARGE MONITORING REPORT

PERMITTEE NAME: City Water, Light & Power
ADDRESS: Seventh & Monroe
PHONE: (217) 786-4052
Springfield, IL 62757

ADDRESS PHONE

COMMENTS

No discharge during this period.

123.

14 [16]	IL 0024767 PERMIT NUMBER
---------	-----------------------------

LATITUDE	LONGITUDE

(14-16)		(17-19)	
IL 0024767		008	LATITUDE
PERMIT NUMBER		DIS	LONGITUDE
IL	ST	SIC	

REPORTING PERIOD	FROM	9-12	01	4	01	TO
	YEAR	YEAR	MO	DAY		YE

9	2	0	15	0	1
				MO	DAY
YEAR					

REPORTING PERIOD	FROM	9	2	0	4	9	1	TO
	YEAR	YEAR	MO	MO	DAY	DAY		

This Agency is authorized to require this information under Illinois Revised

1577008-
LASI

PAGE 9 OF 12

S. *Scutellaria*

certify that I am familiar with the information contained

NAME OF PRINCIPAL EXECUTIVE OFFICER		CONDITION	TITLE OF THE OFFICER
-	-	-	-

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMENTS
DISCHARGE MONITORING REPORT

1

PERMITTEE NAME: City Water, Light & Power
ADDRESS: Seventh & Monroe
Springfield, IL 62757
PHONE: (217) 786-4038

11-11
16-16
17-17
12-12
13-13
14-14
15-15
16-16
17-17
18-18
19-19
20-20
21-21
22-22
23-23
24-24
25-25
26-26
27-27
28-28
29-29
30-30
31-31
32-32
33-33
34-34
35-35
36-36
37-37
38-38
39-39
40-40
41-41
42-42
43-43
44-44
45-45
46-46
47-47
48-48
49-49
50-50
51-51
52-52
53-53
54-54
55-55
56-56
57-57
58-58
59-59
60-60
61-61
62-62
63-63
64-64
65-65
66-66
67-67
68-68
69-69
70-70
71-71
72-72
73-73
74-74
75-75
76-76
77-77
78-78
79-79
80-80
81-81
82-82
83-83
84-84
85-85
86-86
87-87
88-88
89-89
90-90
91-91
92-92
93-93
94-94
95-95
96-96
97-97
98-98
99-99
100-100
101-101
102-102
103-103
104-104
105-105
106-106
107-107
108-108
109-109
110-110
111-111
112-112
113-113
114-114
115-115
116-116
117-117
118-118
119-119
120-120
121-121
122-122
123-123
124-124
125-125
126-126
127-127
128-128
129-129
130-130
131-131
132-132
133-133
134-134
135-135
136-136
137-137
138-138
139-139
140-140
141-141
142-142
143-143
144-144
145-145
146-146
147-147
148-148
149-149
150-150
151-151
152-152
153-153
154-154
155-155
156-156
157-157
158-158
159-159
160-160
161-161
162-162
163-163
164-164
165-165
166-166
167-167
168-168
169-169
170-170
171-171
172-172
173-173
174-174
175-175
176-176
177-177
178-178
179-179
180-180
181-181
182-182
183-183
184-184
185-185
186-186
187-187
188-188
189-189
190-190
191-191
192-192
193-193
194-194
195-195
196-196
197-197
198-198
199-199
200-200
201-201
202-202
203-203
204-204
205-205
206-206
207-207
208-208
209-209
210-210
211-211
212-212
213-213
214-214
215-215
216-216
217-217
218-218
219-219
220-220
221-221
222-222
223-223
224-224
225-225
226-226
227-227
228-228
229-229
230-230
231-231
232-232
233-233
234-234
235-235
236-236
237-237
238-238
239-239
240-240
241-241
242-242
243-243
244-244
245-245
246-246
247-247
248-248
249-249
250-250
251-251
252-252
253-253
254-254
255-255
256-256
257-257
258-258
259-259
260-260
261-261
262-262
263-263
264-264
265-265
266-266
267-267
268-268
269-269
270-270
271-271
272-272
273-273
274-274
275-275
276-276
277-277
278-278
279-279
280-280
281-281
282-282
283-283
284-284
285-285
286-286
287-287
288-288
289-289
290-290
291-291
292-292
293-293
294-294
295-295
296-296
297-297
298-298
299-299
300-300
301-301
302-302
303-303
304-304
305-305
306-306
307-307
308-308
309-309
310-310
311-311
312-312
313-313
314-314
315-315
316-316
317-317
318-318
319-319
320-320
321-321
322-322
323-323
324-324
325-325
326-326
327-327
328-328
329-329
330-330
331-331
332-332
333-333
334-334
335-335
336-336
337-337
338-338
339-339
340-340
341-341
342-342
343-343
344-344
345-345
346-346
347-347
348-348
349-349
350-350
351-351
352-352
353-353
354-354
355-355
356-356
357-357
358-358
359-359
360-360
361-361
362-362
363-363
364-364
365-365
366-366
367-367
368-368
369-369
370-370
371-371
372-372
373-373
374-374
375-375
376-376
377-377
378-378
379-379
380-380
381-381
382-382
383-383
384-384
385-385
386-386
387-387
388-388
389-389
390-390
391-391
392-392
393-393
394-394
395-395
396-396
397-397
398-398
399-399
400-400
401-401
402-402
403-403
404-404
405-405
406-406
407-407
408-408
409-409
410-410
411-411
412-412
413-413
414-414
415-415
416-416
417-417
418-418
419-419
420-420
421-421
422-422
423-423
424-424
425-425
426-426
427-427
428-428
429-429
430-430
431-431
432-432
433-433
434-434
435-435
436-436
437-437
438-438
439-439
440-440
441-441
442-442
443-443
444-444
445-445
446-446
447-447
448-448
449-449
450-450
451-451
452-452
453-453
454-454
455-455
456-456
457-457
458-458
459-459
460-460
461-461
462-462
463-463
464-464
465-465
466-466
467-467
468-468
469-469
470-470
471-471
472-472
473-473
474-474
475-475
476-476
477-477
478-478
479-479
480-480
481-481
482-482
483-483
484-484
485-485
486-486
487-487
488-488
489-489
490-490
491-491
492-492
493-493
494-494
495-495
496-496
497-497
498-498
499-499
500-500
501-501
502-502
503-503
504-504
505-505
506-506
507-507
508-508
509-509
510-510
511-511
512-512
513-513
514-514
515-515
516-516
517-517
518-518
519-519
520-520
521-521
522-522
523-523
524-524
525-525
526-526
527-527
528-528
529-529
530-530
531-531
532-532
533-533
534-534
535-535
536-536
537-537
538-538
539-539
540-540
541-541
542-542
543-543
544-544
545-545
546-546
547-547
548-548
549-549
550-550
551-551
552-552
553-553
554-554
555-555
556-556
557-557
558-558
559-559
560-560
561-561
562-562
563-563
564-564
565-565
566-566
567-567
568-568
569-569
570-570
571-571
572-572
573-573
574-574
575-575
576-576
577-577
578-578
579-579
580-580
581-581
582-582
583-583
584-584
585-585
586-586
587-587
588-588
589-589
590-590
591-591
592-592
593-593
594-594
595-595
596-596
597-597
598-598
599-599
600-600
601-601
602-602
603-603
604-604
605-605
606-606
607-607
608-608
609-609
610-610
611-611
612-612
613-613
614-614
615-615
616-616
617-617
618-618
619-619
620-620
621-621
622-622
623-623
624-624
625-625
626-626
627-627
628-628
629-629
630-630
631-631
632-632
633-633
634-634
635-635
636-636
637-637
638-638
639-639
640-640
641-641
642-642
643-643
644-644
645-645
646-646
647-647
648-648
649-649
650-650
651-651
652-652
653-653
654-654
655-655
656-656
657-657
658-658
659-659
660-660
661-661
662-662
663-663
664-664
665-665
666-666
667-667
668-668
669-669
670-670
671-671
672-672
673-673
674-674
675-675
676-676
677-677
678-678
679-679
680-680
681-681
682-682
683-683
684-684
685-685
686-686
687-687
688-688
689-689
690-690
691-691
692-692
693-693
694-694
695-695
696-696
697-697
698-698
699-699
700-700
701-701
702-702
703-703
704-704
705-705
706-706
707-707
708-708
709-709
710-710
711-711
712-712
713-713
714-714
715-715
716-716
717-717
718-718
719-719
720-720
721-721
722-722
723-723
724-724
725-725
726-726
727-727
728-728
729-729
730-730
731-731
732-732
733-733
734-734
735-735
736-736
737-737
738-738
739-739
740-740
741-741
742-742
743-743
744-744
745-745
746-746
747-747
748-748
749-749
750-750
751-751
752-752
753-753
754-754
755-755
756-756
757-757
758-758
759-759
760-760
761-761
762-762
763-763
764-764
765-765
766-766
767-767
768-768
769-769
770-770
771-771
772-772
773-773
774-774
775-775
776-776
777-777
778-778
779-779
780-780
781-781
782-782
783-783
784-784
785-785
786-786
787-787
788-788
789-789
790-790
791-791
792-792
793-793
794-794
795-795
796-796
797-797
798-798
799-799
800-800
801-801
802-802
803-803
804-804
805-805
806-806
807-807
808-808
809-809
810-810
811-811
812-812
813-813
814-814
815-815
816-816
817-817
818-818
819-819
820-820
821-821
822-822
823-823
824-824
825-825
826-826
827-827
828-828
829-829
830-830
831-831
832-832
833-833
834-834
835-835
836-836
837-837
838-838
839-839
840-840
841-841
842-842
843-843
844-844
845-845
846-846
847-847
848-848
849-849
850-850
851-851
852-852
853-853
854-854
855-855
856-856
857-857
858-858
859-859
860-860
861-861
862-862
863-863
864-864
865-865
866-866
867-867
868-868
869-869
870-870
871-871
872-872
873-873
874-874
875-875
876-876
877-877
878-878
879-879
880-880
881-881
882-882
883-883
884-884
885-885
886-886
887-887
888-888
889-889
890-890
891-891
892-892
893-893
894-894
895-895
896-896
897-897
898-898
899-899
900-900
901-901
902-902
903-903
904-904
905-905
906-906
907-907
908-908
909-909
910-910
911-911
912-912
913-913
914-914
915-915
916-916
917-917
918-918
919-919
920-920
921-921
922-922
923-923
924-924
925-925
926-926
927-927
928-928
929-929
930-930
931-931
932-932
933-933
934-934
935-935
936-936
937-937
938-938
939-939
940-940
941-941
942-942
943-943
944-944
945-945
946-946
947-947
948-948
949-949
950-950
951-951
952-952
953-953
954-954
955-955
956-956
957-957
958-958
959-959
960-960
961-961
962-962
963-963
964-964
965-965
966-966
967-967
968-968
969-969
970-970
971-971
972-972
973-973
974-974
975-975
976-976
977-977
978-978
979-979
980-980
981-981
982-982
983-983
984-984
985-985
986-986
987-987
988-988
989-989
990-990
991-991
992-992
993-993
994-994
995-995
996-996
997-997
998-998
999-999
1000-1000

COMMENTS

NAME OF PRINCIPAL EXECUTIVE OFFICER	TITLE	NAME	TITLE	DATE	I certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief such information is true, complete, and accurate.		
					PRINCIPAL EXECUTIVE OFFICER	DATE	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
Frasco, Lynn A.	General Manager, Public Utilities	Frasco, Lynn A.	General Manager, Public Utilities	10-10-1981			
LAST FIRST	TITLE	LAST FIRST	TITLE	YEAR MO DAY			
16334422779	16334422779	16334422779	16334422779	16334422779			

DISCHARGE MONITORING REPORT

PERMITTEE NAME: City Water, Light & Power
ADDRESS: Seventh & Monroe
PHONE: (217) 786-4038
Springfield, IL 62757

IL	0024767	PERMIT NUMBER
ST		DIS
ST		008
IL	0024767	(14-161)
ST		(11-191)
ST		SIC

REPORTING PERIOD: FROM **9/12/01** TO **01/01/02**
 YEAR **MO** DAY **DAY**

LONGITUDE	LATITUDE

9	12	0	15	0	1
YEAR	MO	DAY			
YEAR	MO	DAY			

I certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, the information is true, complete and accurate.

OFFICER OR AUTHORIZED AGENT PAGE 9 OF 12

This Agency is authorized to require this information under Illinois Revised Statutes, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information

Wp 5:12-0093/179

PERMITEE NAME: City Water, Light & Power
 ADDRESS: Seventh & Monroe
 Springfield, IL 62757
 PHONE: (217) 786-4038

COMMENTS

12-31	14-181	12-31	14-181
IL	0024767	IL	
ST	PERMIT NUMBER	SIC	LATITUDE
		DIS	LONGITUDE
(20-21)	(20-21)	(22-23)	(24-31)

REPORTING PERIOD: FROM 02 06 01 TO 02 07 01
 YEAR MO DAY

PARAMETER	3 card only (38-41)			4 card only (46-48)			4 card only (46-51)			102 103 CONCENTRATION (154-151)			102 103 FREQUENCY OF ANALYSIS			SAMPLE TYPE		
	MINIMUM	AVERAGE	MAXIMUM	UNITS	NO EX	MINIMUM	AVERAGE	MAXIMUM	UNITS	NO EX	MINIMUM	AVERAGE	MAXIMUM	UNITS	NO EX	MINIMUM	AVERAGE	MAXIMUM
Flow	5.194	6.091	6.629	MGD		7.8		8.3						1/7		1/7	EST	
pH						6.0		9.0						2/7		2/7	GRAB	
Total Suspended Solids						5	14	30						2/7		2/7	COMP	
Oil and Grease						1	2	2						2/7		2/7	COMP	
Boron						15	30	30	mg/1					2/30		2/30	GRAB	
Copper						1	2	2						2/30		2/30	GRAB	
Silver						5.9	6.0	6.1	mg/1					2/30		2/30	GRAB	

NAME OF PRINCIPAL EXECUTIVE OFFICER: General Manager, Public Utilities
 Frasco, Lynn A.
 LAST FIRST MI

TITLE: DATE: 1/22/79
 1/22/79

This Agency is authorized to require this information under Illinois Revised Statutes, 1979, Chapter 111 1/2, Section 1042. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 per

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
 D. Frasco

PAGE 5 OF 12

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM COMMUNIS
DISCHARGE MONITORING REPORT

PERMITTEE NAME: City Water, Light & Power
ADDRESS: Seventh & Monroe
Springfield, IL 62757
PHONE: (217) 786-4038
PERMIT NUMBER: IL 0024767
DIS

REPORTING PERIOD: FROM 9/2/06/01 TO 9/2/07/01
YEAR MO DAY

COMMENTS
No discharge during this period.

PARAMETER	QUANTITY (148-53)			CONCENTRATION (148-51)			FREQUENCY OF ANALYSIS			SAMPLE TYPE
	MINIMUM	AVERAGE	MAXIMUM	NO EX	MINIMUM	AVERAGE	MAXIMUM	UNITS	NO EX	
Flow				MGD						EST.
PH										EST.
Total Suspended Solids					6.0	9.0				GRAB
Oil and Grease										COMP
Total Iron										COMP
Dissolved Iron										COMP
NAME OF PRINCIPAL EXECUTIVE OFFICER	General Manager	DATE	I certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief such information is true, complete, and accurate.							Signed
LAST NAME, FIRST NAME, MI	Public Utilities	YEAR	MO	DAY						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: Lakeside

Month/Year: April 1992

Day	Start-End	Component	Cause	Corrective Action Taken
4/1/92	12:00A	Clock Board	Loose Wire	
4/30/92	23:54	Transmissometer		

IEPA contacted & notified on inoperativeness
of Lakeside Opacity Monitor.

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: Lakeside

Month/Year: April 1992

Opacity Limit: 30%

BOILER HOURS

Unit #7 - 720

Unit #8 - 720

Day	Start	Opacity %	Cause	Corrective Action Taken
-----	-------	-----------	-------	-------------------------

Data Not Available

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 31

Month/Year: April 1992

Day	Start-End	Component	Cause	Corrective Action Taken
1/1/92	12:00-08:50	Chart Recorder	Paper Jam	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: 31

Month/Year: April 1992

Opacity Limit: 30%

Day	Start	Opacity %	Cause	Corrective Action Taken
4-6	08:54	42.0	Unknown	
	09:00	42.0	"	
4-11	02:24	68.0	Maintenance Repair	
	02:30	44.0	on boiler forcing	
	02:36	31.0	precip. off.	
	03:12	41.0	"	
4-12	12:00	63.0	Startup	
	:06	54.0	"	
	:12	45.0	"	
	:18	61.0	"	
	:24	65.0	"	
	:30	67.0	"	
	:36	68.0	"	
	:42	71.0	"	
	:48	73.0	"	
	:54	75.0	"	
	13:00	76.0	"	
	:06	78.0	"	
	:12	75.0	"	
	:18	79.0	"	
	:24	78.0	"	
	:30	77.0	"	
	:36	76.0	"	
	:42	74.0	"	
	:48	72.0	"	
	:54	69.0	"	
	14:00	66.0	"	
	:06	63.0	"	
	:12	60.0	"	
	:18	57.0	"	
	:24	53.0	"	
	:30	50.0	"	
	:36	47.0	"	
	:42	44.0	"	
	:48	42.0	"	
	:54	39.0	"	
	15:00	36.0	"	
	:06	48.0	"	
	:12	67.0	"	
	:18	59.0	"	
	:24	44.0	"	

Day	Start	Opacity %	Cause	Corrective Action Taken
4-12	15:30	46.0	Startup	
	:36	43.0	"	
	:42	40.0	"	
	:48	50.0	"	
	:54	41.0	"	
	16:00	43.0	"	
	:06	32.0	"	
	:42	43.0	"	
	:48	35.0	"	
	18:42	47.0	"	
	:48	43.0	"	
	:54	32.0	"	
	19:00	46.0	"	
	:06	71.0	"	
	:12	60.0	"	
	:18	66.0	"	
	:24	64.0	"	
	:30	64.0	"	
	:36	65.0	"	
	:42	68.0	"	
	:48	77.0	"	
	:54	74.0	"	
	20:00	71.0	"	
	:06	67.0	"	
	:12	67.0	"	
	:18	67.0	"	
	:24	67.0	"	
	:30	67.0	"	
	:36	57.0	"	
4-24	20:36	37.0	Shutdown	
4-26	01:00	45.0	Startup	
	:06	79.0	"	
	:12	85.0	"	
	:18	53.0	"	
	:24	37.0	"	
	:30	35.0	"	
	:36	34.0	"	
	:42	33.0	"	
	:48	32.0	"	
	:54	31.0	"	

Excess Opacity Report

Unit 31 - April 1992

Page -3-

Day	Start	Opacity %	Cause	Corrective Action Taken
4-26	02:36	61.0	Startup	
	:42	53.0	"	
	:48	49.0	"	
	:54	47.0	"	
	03:00	48.0	"	
	04:00	51.0	"	
	:06	70.0	"	
	:12	73.0	"	
	:18	67.0	"	
	:24	36.0	"	
	:30	45.0	"	
	:36	41.0	"	
	:42	38.0	"	
	:48	37.0	"	
	:54	35.0	"	
	05:06	35.0	"	
	:12	34.0	"	
	06:00	38.0	"	
	:12	43.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 32

Month/Year: April 1992

Day	Start-End	Component	Cause	Corrective Action Taken
-----	-----------	-----------	-------	-------------------------

N O N E

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: 32

Month/Year: April 1992

Opacity Limit: 30%

Day	Start	Opacity %	Cause	Corrective Action Taken
4-6	08:30	72.0	Precipitator Malfunction	
	:36	72.0	"	
	:42	72.0	"	
	:48	72.0	"	
	:54	72.0	"	
4-27	16:42	55.0	Unknown	
	24:36	40.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 33

Month/Year: April 1992

Day	Start-End	Component	Cause	Corrective Action Taken
-----	-----------	-----------	-------	-------------------------

UNIT OUTAGE

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: 33

Month/Year: April 1992

Opacity Limit: 30%

Day	Start	Opacity %	Cause	Corrective Action Taken
-----	-------	-----------	-------	-------------------------

UNIT OUTAGE

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: Lakeside

Month/Year: May 1992

Day	Start-End	Component	Cause	Corrective Action Taken
1	12:00A- 4	Transmissometer	Cal Fail	Measured stack & recalibrated instrument
29	09:24-11:00	Opacity Recorder	Stuck in Cal	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Jnit: Lakeside

Month/Year: April 1992

Opacity Limit: 30%

BOILER HOURS

Unit #7 - 619

Unit #8 - 608

Day	Start	Opacity %	Cause	Corrective Action Taken
-13	18:54	41.0	Unit 7 Trip	
	19:00	74.0	"	
	:06	74.0	"	
	:12	66.0	"	
-17	12:18	64.0	Precip. field tripped	Reset field
	:24	76.0	"	
	:30	32.0	"	
-18	11:18	31.0	Unknown	
-21	21:36	41.0	Equip. Malf./Air	Placed in manual
	:42	46.0	Damper	control until repairs
	:48	42.0	"	were completed
	22:00	57.0	"	"
	:06	76.0	"	"
	:12	61.0	"	"
	:24	36.0	"	"
	:48	47.0	"	"
	:54	37.0	"	"
	23:00	31.0	"	"
	:06	42.0	"	"
	:12	55.0	"	"
	:18	40.0	"	"
-29	18:54	63.0	Startup 7&8	
	19:30	74.0	"	
	:36	80.0	"	
	:42	80.0	"	
	:48	78.0	"	
	:54	71.0	"	
	20:00	75.0	"	
	:06	75.0	"	
	:12	76.0	"	
	:18	78.0	"	
	:24	79.0	"	
	:30	71.0	"	
	:36	63.0	"	
	:42	61.0	"	
	:48	55.0	"	
	:54	52.0	"	

cess Opacity Report

keside - May 1991

ge -2-

Day	Start	Opacity %	Cause	Corrective Action Taken
29	21:00	52.0	Startup 7&8	
	:06	34.0	"	
	:12	31.0	"	
	:18	45.0	"	
	:24	47.0	"	
	:30	42.0	"	
	:36	37.0	"	
	:42	41.0	"	
	:48	34.0	"	
	22:24	40.0	"	
	:30	57.0	"	
	:36	57.0	"	
	:42	48.0	"	
	:48	54.0	"	
	:54	42.0	"	
	23:00	35.0	"	
	:24	39.0	"	
	:36	32.0	"	
	:42	50.0	"	
	:54	34.0	"	
-30	00:36	37.0	Startup 7&8	
	:54	43.0	"	
	01:12	32.0	"	
	:30	45.0	"	
	:54	42.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 31

Month/Year: May 1992

Day	Start-End	Component	Cause	Corrective Action Taken
-----	-----------	-----------	-------	-------------------------

N O N E

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: 31

Month/Year: May 1992

Opacity Limit: 30%

Day	Start	Opacity %	Cause	Corrective Action Taken
-11	00:06 :12	49.0 58.0	Switched Precip. Fields "	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

nit: 32

onth/Year: May 1992

Start-End	Component	Cause	Corrective Action Taken
-----------	-----------	-------	-------------------------

N O N E

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Jnit: 32

Month/Year: May 1992

Opacity Limit: 30%

ay	Start	Opacity %	Cause	Corrective Action Taken
-12	00:06	50.0	Switched Precip. Fields	
	:12	89.0	"	
-21	02:48	62.0	Startup	
	03:00	33.0	"	
	:06	36.0	"	
	06:54	60.0	"	
	07:00	64.0	"	
	:06	54.0	"	
	:12	47.0	"	
	:18	52.0	"	
	:24	63.0	"	
	:30	65.0	"	
	:36	59.0	"	
	:42	55.0	"	
	:48	53.0	"	
	:54	53.0	"	
	08:00	53.0	"	
	:06	35.0	"	
	:42	59.0	"	
	09:12	70.0	"	
	:18	89.0	"	
	10:36	35.0	"	
5-25	08:54	71.0	Startup	
	09:00	40.0	"	
	:06	49.0	"	
	:12	49.0	"	
	:18	46.0	"	
	:24	43.0	"	
	:30	40.0	"	
	:36	36.0	"	
	11:12	31.0	"	
5-29	10:00	79.0	Startup	
	:06	73.0	"	
	:12	58.0	"	
	:18	53.0	"	
	:24	49.0	"	
	:30	41.0	"	
	:36	49.0	"	

cess.Opacity Report

It 32 - May 1992

ge -2-

Day	Start	Opacity %	Cause	Corrective Action Taken
29	10:42	41.0	"	
	:48	37.0	"	
	:54	36.0	"	
	11:00	33.0	"	
	:06	32.0	"	
	:12	31.0	"	
	:18	31.0	"	
	:30	32.0	"	
	:36	38.0	"	
	13:30	85.0	"	
	:36	47.0	"	
	:42	37.0	"	
	15:18	39.0	"	
	:24	56.0	"	
	:30	51.0	"	
	:36	51.0	"	
	:42	54.0	"	
	:48	84.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 33

Month/Year: May 1992

Day	Start-End	Component	Cause	Corrective Action Taken
/20	15:00-20:00	Opacity Recorder	Paper Jam	
/23	22:54	Transmissometer	Malfunctioning chopper	Replaced motor &
/26	12:00		motor	recalibrated

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: 33

Month/Year: May 1992

Opacity Limit: 30%

	Start	Opacity %	Cause	Corrective Action Taken
1	04:18	43.0	Startup & Shutdown after outage	
	:24	43.0	"	
	:30	31.0	"	
	:36	55.0	"	
	:42	40.0	"	
	:48	35.0	"	
	:54	33.0	"	
	05:00	35.0	"	
	:06	33.0	"	
	:12	32.0	"	
	:18	37.0	"	
	:24	32.0	"	
	:30	32.0	"	
	:36	32.0	"	
	:42	31.0	"	
	:48	31.0	"	
	:54	31.0	"	
	06:00	31.0	"	
	:06	30.0	"	
	:12	30.0	"	
	:18	30.0	"	
	:24	30.0	"	
	:30	30.0	"	
	:36	30.0	"	
	:42	30.0	"	
	:48	30.0	"	
	:54	30.0	"	
	07:00	33.0	"	
	:06	99.0	"	
	:12	99.0	"	
	:18	61.0	"	
	:24	31.0	"	
	:30	30.0	"	
	:36	53.0	"	
	:42	31.0	"	
	:48	30.0	"	
	:54	30.0	"	
	08:00	30.0	"	
	:06	30.0	"	
	:12	30.0	"	
	:18	30.0	"	
	:24	30.0	"	
	:30	30.0	"	

Day	Start	Opacity %	Cause	Corrective Action Taken
11	08:36	30.0	Startup & Shutdown after outage	
	:42	29.0	"	
	:48	29.0	"	
	:54	29.0	"	
	09:00	29.0	"	
	:06	34.0	"	
	:12	34.0	"	
	:18	32.0	"	
	:24	32.0	"	
	:30	32.0	"	
	:36	32.0	"	
	:42	32.0	"	
2	05:00	26.0	"	
	:06	37.0	"	
	:12	31.0	"	
	:18	30.0	"	
	:24	30.0	"	
	:30	30.0	"	
	:36	30.0	"	
	:42	30.0	"	
	:48	30.0	"	
	:54	30.0	"	
	06:00	30.0	"	
	:12	30.0	"	
	:18	30.0	"	
	:24	30.0	"	
	:30	30.0	"	
	:36	30.0	"	
	:42	30.0	"	
	:48	30.0	"	
	:54	30.0	"	
	07:00	30.0	"	
	:06	30.0	"	
	:12	30.0	"	
	:18	30.0	"	
	:24	30.0	"	
	:30	29.0	"	
	:36	29.0	"	
	:42	29.0	"	
	:48	29.0	"	
	:54	29.0	"	
	08:00	29.0	"	
	:06	29.0	"	
	:12	29.0	"	

Access Opacity Report
Unit 33 - May 1992
Page -3-

Day	Start	Opacity %	Cause	Corrective Action Taken
-12	08:18	29.0	Startup & Shutdown after outage	
	:29	29.0	"	
	:30	29.0	"	
	:36	29.0	"	
	:42	29.0	"	
	:48	29.0	"	
	:54	29.0	"	
	09:00	29.0	"	
	:06	29.0	"	
	:12	29.0	"	
	:18	29.0	"	
	:24	29.0	"	
	:30	29.0	"	
-15	12:18	47.0	Startup	
	:24	82.0	"	
	:30	73.0	"	
	:36	33.0	"	
	:42	27.0	"	
	:48	23.0	"	
	14:42	23.0	"	
	:48	25.0	"	
	18:24	21.0	"	
	19:48	21.0	"	
	20:00	24.0	"	
	21:36	21.0	"	
	:42	22.0	"	
	22:18	23.0	"	
	:54	21.0	"	
-16	00:06	22.0	Startup	
	:12	22.0	"	
	:18	22.0	"	
	01:42	21.0	"	
	:48	21.0	"	
	:54	21.0	"	
	02:00	21.0	"	
	12:18	23.0	"	
	:24	23.0	"	
	:30	23.0	"	
	:36	23.0	"	
	:42	23.0	"	
	:48	23.0	"	
	:54	23.0	"	

cess Opacity Report

it 38 - May 1992

ge -4-

Day	Start	Opacity %	Cause	Corrective Action Taken
16	13:00	23.0	Startup	
	:06	23.0	"	
	:12	22.0	"	
	14:06	23.0	"	
18	21:36	31.0	"	
	:42	82.0	"	
	:48	77.0	"	
	:54	73.0	"	
	22:00	68.0	"	
	:06	75.0	"	
	:12	51.0	"	
	:18	45.0	"	
	:24	47.0	"	
	:30	42.0	"	
	:36	42.0	"	
	:42	36.0	"	
	:48	35.0	"	
	:54	47.0	"	
	23:00	48.0	"	
	:06	33.0	"	
	:12	30.0	"	
	:18	30.0	"	
	:24	32.0	"	
	:30	29.0	"	
	:36	26.0	"	
	:42	28.0	"	
	:48	76.0	"	
	:54	59.0	"	
19	00:00	35.0	Startup	
	:06	40.0	"	
	:12	43.0	"	
	:18	32.0	"	
	:24	21.0	"	
	03:30	24.0	"	
	:36	23.0	"	
	:42	41.0	"	
	:48	41.0	"	
	:54	41.0	"	
	04:00	41.0	"	
	:06	45.0	"	
	:12	46.0	"	
	:18	44.0	"	
	:24	42.0	"	
	04:48	45.0	"	
	:54	45.0	"	

cess Opacity Report

it 33 - May 1992

ge -5-

Day	Start	Opacity %	Cause	Corrective Action Taken
19	05:00	41.0	Startup	
	:06	39.0	"	
	:12	39.0	"	
	:18	39.0	"	
	:24	39.0	"	
	:30	37.0	"	
	:36	29.0	"	
	06:24	26.0	"	
	:30	67.0	"	
	:36	30.0	"	
	:48	28.0	"	
	07:18	44.0	"	
	:24	61.0	"	
	:30	48.0	"	
	:36	45.0	"	
	13:18	46.0	"	
	:24	37.0	"	
	:30	46.0	"	
	:36	30.0	"	
	:42	25.0	"	
	:48	35.0	"	
	:54	22.0	"	
	14:06	28.0	"	
	:12	24.0	"	
	:18	22.0	"	
	15:00	29.0	"	
	:06	87.0	"	
	:12	77.0	"	
	:18	73.0	"	
	:24	69.0	"	
	:30	30.0	"	
	:36	26.0	"	
	:42	30.0	"	
	:48	32.0	"	
	:54	40.0	"	
	16:00	42.0	"	
	:06	39.0	"	
	:12	39.0	"	
	:18	25.0	"	
	:24	21.0	"	
	:30	25.0	"	
	:36	65.0	"	
	:42	55.0	"	
	:48	66.0	"	
	:54	63.0	"	

ess, Opacity Report
t 33 - May 1992
e -6-

Day	Start	Opacity %	Cause	Corrective Action Taken
19	17:00	63.0	Startup	
	:06	66.0	"	
	:12	72.0	"	
	:18	75.0	"	
	:24	75.0	"	
	:30	80.0	"	
	:36	83.0	"	
31	16:42	74.0	Startup	
	:48	93.0	"	
	:54	85.0	"	
	17:00	79.0	"	
	:06	90.0	"	
	:12	100.0	"	
	:18	100.0	"	
	:24	100.0	"	
	:30	55.0	"	
	:36	38.0	"	
	:42	35.0	"	
	:48	31.0	"	
	:54	48.0	"	
	18:00	33.0	"	
	:06	43.0	"	
	:12	36.0	"	
	:18	42.0	"	
	:24	33.0	"	
	:30	32.0	"	
	:36	37.0	"	
	:42	55.0	"	
	:48	50.0	"	
	:54	53.0	"	
	19:00	53.0	"	
	:06	46.0	"	
	:12	32.0	"	
	:18	28.0	"	
	:24	28.0	"	
	:30	28.0	"	
	:36	27.0	"	
	:42	28.0	"	
	:48	33.0	"	
	:54	29.0	"	
	20:00	28.0	"	
	:06	24.0	"	
	:12	23.0	"	
	:18	36.0	"	
	:24	50.0	"	

cess Opacity Report
it 33 - May 1992
ge -7-

Day	Start	Opacity %	Cause	Corrective Action Taken
31	20:30	88.0	Startup	
	:36	83.0	"	
	:42	25.0	"	
	:48	22.0	"	
	:54	22.0	"	
	21:00	22.0	"	
	:06	21.0	"	
	:30	21.0	"	
	:36	21.0	"	
	:42	22.0	"	
	:48	22.0	"	
	:54	44.0	"	
	22:00	51.0	"	
	:06	88.0	"	
	:12	90.0	"	
	:18	96.0	"	
	:24	30.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: Lakeside

Month/Year: June 1992

Start-End	Component	Cause	Corrective Action Taken
-----------	-----------	-------	-------------------------

N O N E

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: Lakeside

Month/Year: June 1992

Opacity Limit: 30%

BOILER HOURS

Unit #7 - 199

Unit #8 - 141

Day	Start	Opacity %	Cause	Corrective Action Taken
-16	00:42	39.0	Startup 7&8	
	:48	56.0	"	
	:54	55.0	"	
	01:00	50.0	"	
	:06	45.0	"	
	:12	43.0	"	
	:18	41.0	"	
	:24	42.0	"	
	:30	44.0	"	
	:36	47.0	"	
	:42	49.0	"	
	:48	50.0	"	
	:54	50.0	"	
	02:00	50.0	"	
	:06	47.0	"	
	:12	62.0	"	
	:18	75.0	"	
	:24	74.0	"	
	:30	72.0	"	
	:36	70.0	"	
	:42	67.0	"	
	:48	64.0	"	
	:54	62.0	"	
	03:00	68.0	"	
	:06	49.0	"	
	:12	42.0	"	
	:18	38.0	"	
	:24	34.0	"	
	:30	44.0	"	
	:36	50.0	"	
	:42	45.0	"	
	:48	73.0	"	
	:54	33.0	"	
	04:00	38.0	"	
	:06	47.0	"	
	:12	66.0	"	
	:18	58.0	"	
	05:00	51.0	"	
	:06	46.0	"	
	:12	34.0	"	
	:42	50.0	"	
	:54	41.0	"	
	06:24	36.0	"	

cess Opacity Report
keside - June 1992
ge -2-

Day	Start	Opacity %	Cause	Corrective Action Taken
-16	08:48	38.0	"	
	09:30	31.0	"	
	10:18	57.0	"	
	:24	63.0	"	
	:30	60.0	"	
	:36	45.0	"	
-24	03:12	62.0	Startup 7	
	:18	52.0	"	
	05:54	41.0	"	
	06:00	55.0	"	
	:06	58.0	"	
	:12	47.0	"	
	:18	40.0	"	
	:24	37.0	"	
	:30	34.0	"	
	:36	33.0	"	
	07:00	32.0	"	
	:06	62.0	"	
	:12	48.0	"	
	:18	39.0	"	
	:24	32.0	"	
	:30	31.0	"	
	:48	46.0	"	
	:54	35.0	"	
	08:12	57.0	"	
	:18	51.0	"	
	:24	53.0	"	
	:36	36.0	"	
	:48	55.0	"	
	:54	33.0	"	
	09:00	57.0	"	
	:06	49.0	"	
	:12	51.0	"	
	:18	35.0	"	
	:24	49.0	"	
	:30	57.0	"	
	:36	75.0	"	
	:42	73.0	"	
	:48	72.0	"	
	:54	50.0	"	
6-29	05:48	48.0	Startup 7	
	:54	56.0	"	
	06:00	31.0	"	
	:30	42.0	"	
	07:18	34.0	"	
	:36	31.0	"	

Excess Opacity Report

akeside - June 1992

Page -3-

Day	Start	Opacity %	Cause	Corrective Action Taken
-29	07:42	55.0	Startup 7	
	08:06	35.0	"	
	:30	47.0	"	
	:36	54.0	"	
	:54	40.0	"	
	21:12	60.0	Shutdown 7	
	:18	36.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 31

Month/Year: June 1992

Day	Start-End	Component	Cause	Corrective Action Taken
-----	-----------	-----------	-------	-------------------------

N O N E

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: 31

Month/Year: June 1992

Opacity Limit: 30%

Day	Start	Opacity %	Cause	Corrective Action Taken
5-5	07:36	46.0	Unknown	
	:42	44.0	"	
	:48	37.0	"	
	:54	33.0	"	
	08:00	31.0	"	
6-21	20:48	31.0	Shutdown	
	:54	49.0	"	
	21:00	33.0	"	
6-24	15:36	54.0	Startup	
	:42	35.0	"	
6-25	06:06	31.0	Startup	
	:12	57.0	"	
	:18	57.0	"	
	:24	42.0	"	
	11:24	33.0	"	
	12:24	54.0	"	
6-29	22:00	49.0	Startup	
	:06	60.0	"	
	:12	57.0	"	
	:18	55.0	"	
	:24	53.0	"	
	:30	57.0	"	
	:36	41.0	"	
	:42	31.0	"	
	23:12	54.0	"	
	:24	59.0	"	
	:30	55.0	"	
	:36	53.0	"	
	:42	54.0	"	
	:48	46.0	"	
	:54	31.0	"	

Excess Opacity Report

Unit 31 - June 1992

Page -2-

Day	Start	Opacity %	Cause	Corrective Action Taken
6-30	00:18	52.0	Startup	
	:24	50.0	"	
	:30	49.0	"	
	:36	48.0	"	
	:42	47.0	"	
	09:24	45.0	"	
	:30	50.0	"	
	:36	48.0	"	
	:48	31.0	"	
	05:30	60.0	"	
	:36	63.0	"	
	:42	61.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 32

Month/Year: June 1992

Day	Start-End	Component	Cause	Corrective Action Taken
			NON E	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

Unit: 32

Month/Year: June 1992

Opacity Limit: 30%

Day	Start	Opacity %	Cause	Corrective Action Taken
6-2	14:36	42.0	Startup	
	:42	40.0	"	
	:48	41.0	"	
	:54	36.0	"	
	15:00	36.0	"	
6-5	06:36	42.0	Shutdown	
	:42	42.0	"	
	07:12	45.0	"	
	:18	52.0	"	
	:24	61.0	"	
	:30	56.0	"	
	:36	46.0	"	
	15:00	55.0	"	
	:06	79.0	"	
	:12	79.0	"	
	:18	35.0	"	

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

**UNIT OPACITY CEM
DOWNTIME REPORT**

Unit: 33

Month/Year: June 1992

Day	Start-End	Component	Cause	Corrective Action Taken
6/22	09:00-16:00	Opacity Recorder	Stuck in Cal.	
6/26	00:00	Transmissometer	Malfunctioning	Replaced Board
6/29	2-10:00			

**CITY WATER, LIGHT & POWER
3100 Stevenson Drive**

EXCESS OPACITY REPORT

it: 33

nth/Year: June 1992

acity Limit: 30%

Start	Opacity %	Cause	Corrective Action Taken
00:06	21.0		
:12	21.0		
:18	21.0		
:24	21.0		
:30	21.0		
:36	22.0		
:42	22.0		
:48	23.0		
:54	23.0		
01:00	23.0		
:06	23.0		
:12	23.0		
:18	24.0		
:24	24.0		
:30	24.0		
:36	24.0		
:42	24.0		
:48	24.0		
:54	24.0		
02:00	24.0		
:06	24.0		
:12	24.0		
:18	24.0		
:30	24.0		
:36	35.0		
:42	25.0		
:48	25.0		
:54	25.0		
03:00	24.0		
:06	25.0		
:12	25.0		
:18	25.0		
:24	25.0		
:30	25.0		
:36	25.0		
:42	25.0		
:48	25.0		
:54	25.0		

cess Opacity Report
 it 33 - June 1992
 ge -2-

Day	Start	Opacity %	Cause	Corrective Action Taken
-6	04:00	25.0		
	:06	25.0		
	:12	25.0		
	:18	25.0		
	:24	25.0		
	:30	25.0		
	:36	25.0		
	:42	25.0		
	:48	25.0		
	:54	25.0		
	05:00	25.0		
	:06	25.0		
	:12	25.0		
	:18	25.0		
	:24	26.0		
	:30	26.0		
	:36	24.0		
	:42	24.0		
	:48	24.0		
	:54	22.0		
	06:06	22.0		
	:12	22.0		
	:24	22.0		
	:30	22.0		
	:36	21.0		
	:42	22.0		
	:48	21.0		
	07:00	21.0		
	17:42	23.0	Precip. Malfunction	Reset field
	:48	23.0	"	"
	18:00	22.0	"	"
-21	05:00	65.0	Startup	
	:06	65.0	"	
	:12	88.0	"	
	:24	63.0	"	
	:30	63.0	"	
	:36	22.0	"	
	:42	22.0	"	
	:48	61.0	"	
	:54	61.0	"	
	06:00	66.0	"	
	:06	66.0	"	
	:12	63.0	"	
	:18	63.0	"	
	:24	73.0	"	
	:30	73.0	"	
	:36	61.0	"	

Process Opacity Report
Lot 33 - June 1992
Page -3-

Day	Start	Opacity %	Cause	Corrective Action Taken
21	06:42	61.0	Startup	
	:42	61.0	"	
	:48	65.0	"	
	:54	65.0	"	
	07:00	44.0	"	
	:06	44.0	"	
	:12	44.0	"	
	:18	44.0	"	
	:24	30.0	"	
	:30	30.0	"	
	:36	30.0	"	
	:42	30.0	"	
	:48	26.0	"	
	:54	26.0	"	
	08:00	27.0	"	
	:06	27.0	"	
	:12	28.0	"	
	:18	28.0	"	
	:24	26.0	"	
	:30	26.0	"	
	:36	25.0	"	
	:42	25.0	"	
	:48	25.0	"	
	:54	25.0	"	
	09:00	25.0	"	
	:06	25.0	"	
	:12	25.0	"	
	:18	25.0	"	
	:24	25.0	"	
	:30	25.0	"	
	:36	25.0	"	
	:42	25.0	"	
	:48	25.0	"	
	:54	21.0	"	
	10:00	30.0	"	
	:06	30.0	"	
	:12	21.0	"	
	:18	21.0	"	
	:24	21.0	"	
	:30	21.0	"	
	:36	21.0	"	
	:42	21.0	"	
	:48	21.0	"	
	11:36	22.0	"	
	:42	22.0	"	
	:48	23.0	"	
	:54	23.0	"	

cess Qpacity Report
it 33 - June 1992
ge -4-

Day	Start	Opacity %	Cause	Corrective Action Taken
21	12:00	22.0	Startup	
	:06	24.0	"	
	:12	22.0	"	
	:18	22.0	"	
	:36	22.0	"	
	:42	22.0	"	
	:48	34.0	"	
	:54	34.0	"	
	13:00	27.0	"	
	:06	27.0	"	
	:12	22.0	"	
	:18	22.0	"	
	:24	21.0	"	
	:30	21.0	"	
	:36	21.0	"	
	:42	21.0	"	
	:48	21.0	"	
	:54	21.0	"	
	14:00	21.0	"	
	:06	21.0	"	
	:12	82.0	"	
	:18	82.0	"	
	:48	26.0	"	
	:54	26.0	"	
	19:24	44.0	"	
	:30	44.0	"	
	:36	66.0	"	
	:42	66.0	"	

APPENDIX C

DRAFT

NPDES Permit No. IL0001554

Illinois Environmental Protection Agency

Division of Water Pollution Control

2200 Churchill Road

P.O. Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Reissued (NPDES) Permit

Expiration Date: July 1, 1997

Issue Date:
Effective Date:

Name and Address of Permittee:

Illinois Power Company
500 South 27th Street
Post Office Box 511
Decatur, Illinois 62525-1805

Facility Name and Address:

Illinois Power Company
Hennepin Power Plant
Hennepin, Illinois 61327
Putnam County

Discharge Number and Name:

No. 001 Condenser Cooling Water
No. 001(a) Boiler Blowdown
No. 001(b) Intake Screen Backwash
No. 001(c) Roof Drain Discharge
No. 003 Ash Lagoon #2 and #4 Discharge
No. 005 Ash Lagoon #1 and #3 Discharge
No. 005(a) Chemical Metal Cleaning Waste Treatment System Effluent

Receiving Waters

Illinois River

In compliance with the provisions of the Illinois Environmental Protection Act, Subtitle C Rules and Regulations of the Illinois Pollution Control Board, and the FWPRA, the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Thomas G. McSwiggin, P.E.
Manager, Permit Section
Division of Water Pollution Control

TGM:TRK:jd/0495E/3

DRAFT

Page 2

NPDES Permit No. IL0001554

Effluent Limitations and Monitoring

PARAMETER	LOAD LIMITS 1bs/day		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE		
	30 DAY AVG.	DAILY MAX.	30 DAY AVG.	DAILY MAX.				
1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:								
<u>Outfall(s): 001 Condenser Cooling Water</u>								
This discharge consists of: 1. Condenser Cooling Water 2. House Service Water 3. Boiler Blowdown 4. Intake Screen Backwash 5. Roof Drain Discharge								
Flow					Approximate Flow 153.26 MGD 7.0 MGD 0.027 MGD 0.258 MGD Intermittent	24-Hour Total		
Total Residual Chlorine	See Special Condition No. 3				1/Week	*		
Temperature	See Special Condition No. 4				Daily	Continuous		
*See Special Condition No. 3								
<u>Outfall(s): 001(a) Boiler Blowdown</u>								
Flow					Approximate Flow 0.027 MGD			
Total Suspended Solids	15.0	30.0			1/Week	Single Reading- Estimate		
					1/Week	24-Hour Composite		

DRAFT

Page 3

NPDES Permit No. IL0001554

Effluent Limitations and Monitoring

PARAMETER	LOAD LIMITS lbs/day		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVG.	DAILY MAX.	30 DAY AVG.	DAILY MAX.		

1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall(s): 001(b) Intake Screen Backwash

Approximate Flow
0.26 MGD

Flow 1/Week Single
Reading Estimate

So as to minimize adverse impacts, for purposes of this permit, the intake structure operation and maintenance shall include, but not be limited to, the following:

1. Outer bar racks shall be routinely cleaned and collected debris properly disposed.
2. The traveling screens shall commence operating whenever the head loss across the screens exceeds four (4) inches.
3. The traveling screens shall be operated at least once per 8 hour shift, provided, however, that this requirement shall be inapplicable when the generating units are not operating.

Outfall(s) 001(c) Roof Drain Discharge

This discharge consists of:
1. Power Block Building Roof Drains

Approximate Flow
Intermittent

See Standard Condition No. 17

DRAFT

NPDES Permit No. IL0001554

Effluent Limitations and Monitoring

PARAMETER	LOAD LIMITS 1bs/day		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVG.	DAILY MAX.	30 DAY AVG.	DAILY MAX.		

1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall(s): 003 Ash Lagoon #2 and #4 Discharge

This discharge consists of:

1. Unit 2 Bottom Ash and Fly Ash	Approximate Flow 2.9 MGD
2. Demineralizer Regenerate Wastes	0.035 MGD
3. Unit 2 Non-chemical Metal Cleaning Washwater	Intermittent
4. Unit #1 and Unit #2 Ash Hopper Overflow**	0.20 MGD
5. Fly Ash Air Separator Overflow	Intermittent
6. Ash Hopper Tank Emergency Overflow	Intermittent
7. Demineralizer Room Floor Drainage	Intermittent
8. Power Block Building Floor Drains and Sump Discharges	0.1 MGD
9. Reverse Osmosis Unit Concentrate	0.036 MGD

Flow		1/Week	Single Reading Estimate
pH	See Special Condition No. 1	1/Week	Grab

Total Suspended Solids	15.0	30.0	1/Week	24 Hour*** Composite
------------------------	------	------	--------	-------------------------

Oil and Grease	15.0	20.0	2/Month	Grab
----------------	------	------	---------	------

**This wastestream may be discharged to the East (Outfall 003) or West (Outfall 005) Ash Pond System.

***See Special Condition No. 6

DRAFT

Page 5

NPDES Permit No. IL0001554

Effluent Limitations and Monitoring

PARAMETER	LOAD LIMITS 1bs/day		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVG.	DAILY MAX.	30 DAY AVG.	DAILY MAX.		

1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall(s): 005 Ash Lagoon #1 and #3 Discharge

This discharge consists of:

1. Unit #1 Bottom Ash and Fly Ash Transport Water
2. Unit #1 and #2 Ash Hopper Overflow****
3. Coal Breaker Building Drain Sump
4. Illinois River Dredge Spoils
5. Unit #1 Non-chemical Metal Cleaning Washwater
6. Chemical Metal Cleaning Waste Treatment System Effluent
7. Coal Pile Runoff
8. Unit #1 and Unit #2 Ash Line Low Point Drainoff
9. Crib House Sump
10. Well Water Drain Line
11. Water Treatment Plant Sump
12. Boiler Drum Chemical Tank Drainage
13. Gas Reburning/Sorbent Injection Waste

Approximate Flow
0.21 MGD
0.2 MGD
Intermittent
Intermittent
Intermittent
Intermittent
Intermittent
Intermittent
Intermittent
Intermittent
Intermittent
0.96 MGD

Flow				1/Week	Single Reading Estimate
pH	See Special Condition No. 1			1/Week	Grab
Total Suspended Solids		15.0	30.0	1/Week	24 Hr**** Composite
Oil and Grease		15.0	20.0	2/Month	Grab

****This wastestream may be directed to the East Ash Pond System (Outfall 003).

**** See Special Condition No. 6

DRAFT

Page 6

NPDES Permit No. IL0001554

Effluent Limitations and Monitoring

PARAMETER	LOAD LIMITS lbs/day		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVG.	DAILY MAX.	30 DAY AVG.	DAILY MAX.		
1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:						
Outfall(s): 005(a) Chemical Metal Cleaning Waste Treatment System Effluent						
Flow					Approximate Flow Intermittent	
Iron (Total)			1.0		Daily When 24 Hour Discharging Total	
Copper (Total)			1.0		Daily When 24 Hour Discharging Composite	

DRAFT

NPDES Permit No. IL0001554

Special Conditions

1. The pH shall be in the range 6.0 to 9.0.
2. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.
3. A. During times when the condenser cooling water is chlorinated intermittently, total residual chlorine (TRC) may not be discharged from the station for more than three hours per day or from any single generating unit's main cooling condensers for more than two hours per day. The discharge limit is 0.2 mg/l, measured as an instantaneous maximum.
 1. Continuous TRC monitoring throughout a representative chlorination period shall be performed once per week in the cooling water discharge flume during the respective chlorination period of one condenser half allowing for lag time between the initiation of chlorination and the time of sampling. For continuous chlorine monitoring, analytical data from only two representative monitoring periods each month need be reported on the monthly discharge monitoring report. The time of sampling, the time and duration of the chlorine dosing period, and the amount of chlorine applied shall be reported.
 2. If continuous monitoring cannot be performed, a minimum of three grab samples shall be collected in the discharge flume at five minute intervals or less, once per week during a representative chlorination period, allowing for lag time between the initiation of chlorination and the time of sampling, to develop a chlorine concentration curve. The time of sampling, the time and duration of the chlorine dosing period, and the amount of chlorine applied shall be reported.
- B. During times when the condenser cooling water is chlorinated continuously, the discharge limit is 0.05 mg/l, measured as an instantaneous maximum.
- C. Chlorination of house service water is authorized by this permit, provided that the discharge limits above are not exceeded at Outfall 001.
4. Discharge of wastewater from this facility must not alone or in combination with other sources cause the receiving stream to violate the following thermal limitations at the edge of the mixing zone which is defined by Section 302.211, Illinois Administrative Code, Title 35, Chapter 1, Subtitle C, as amended:
 - A. Maximum temperature rise above natural temperature must not exceed 5°F (2.78°C).
 - B. Water temperature at representative locations in the main river shall not exceed the maximum limits in the following table during more than one (1) percent of the hours in the 12-month period ending with any month. Moreover, at no time shall the water temperature at such locations exceed the maximum limits in the following table by more than 3°F (1.67°C). (Main river temperatures are temperatures of those portions of the river essentially similar to and following the same thermal regime as the temperatures of the main flow of the river.)

	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>	<u>Apr.</u>	<u>May</u>	<u>June</u>	<u>July</u>	<u>Aug.</u>	<u>Sept.</u>	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>
°F	60	60	60	90	90	90	90	90	90	90	90	60
°C	15.6	15.6	15.6	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	15.6

- C. At times when the river water intake temperature is less than or equal to 41°F, the discharge temperature shall not exceed the intake temperature by more than 18°F.
5. There shall be no discharge of polychlorinated biphenyl compounds.
6. If inclement weather prohibits the collection of a 24-hour composite sample for five consecutive days, sampling shall consist of a grab sample.
7. Illinois Power Company has complied with Section 302.211(f) of Title 35, Chapter 1, Subtitle C: Water Pollution Regulations and Section 316(a) of the CWA by demonstrating that thermal discharge from Hennepin Power Plant has not caused and cannot reasonably be expected to cause significant ecological damage to the Illinois River as approved by the IPCB in PCB 78-3 on 10/10/78. Pursuant to 35 ILCS 316(a) and CWA 302.211(f), no additional monitoring or

DRAFT

Page 8

NPDES Permit No. IL0001554

Special Conditions

8. Illinois Power Company's demonstration for the Hennepin Power Plant in accordance with Section 316(b) of the CWA has been approved by this Agency by letter dated December 29, 1978. It is determined that no additional intake monitoring or modification is being required for reissuance of this NPDES permit.
9. Standard Condition No. 9 shall not constitute a waiver of any constitutional rights of the permittee.
10. The provisions contained in Standard Condition No. 17 shall not prejudice permittee's right to obtain or be granted a reasonable time in which to comply, but in no event shall such time be later than any applicable Federal or State of Illinois statutory or regulatory compliance date, in connection with any modification made pursuant thereto.
11. Standard Condition 11(a) of Attachment H is rewritten as follows:

An application submitted by a corporation shall be signed by a principal executive officer of at least the level of vice president, or his duly authorized representative, if such representative is responsible for the overall operation of the facility from which the discharge described in the application form originates. In the case of a partnership or a sole proprietorship, the application shall be signed by a general partner or the proprietor, respectively. In the case of a publicly owned facility, the application shall be signed by either the principal executive officer, ranking elected official, or other duly authorized employee.

12. Standard Condition 11(b) of Attachment H is rewritten as follows:

Pursuant to 40 CFR 122.22(b) all reports required by permits, other information requested by the Director, and all permit applications submitted for Group II storm water discharges under 122.26(b)(3) shall be signed by a person described in 40 CFR 122.22(a), or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described in paragraph (a) of this section;
- (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) and
- (3) The written authorization is submitted to the Director.

13. Disposal of GR-SI Residues in the West Ash Pond System shall be monitored and limited in accordance with the following Best Management Practices Plan:

- a) Authorization to dispose GR-SI Residues in the West Ash Pond System is granted only for the term of the demonstration project. The Agency shall be notified on the date the demonstration project begins.
- b) The raw residue transport water shall be pH adjusted to approximately 9.0 prior to discharge into the West Ash Pond System using carbon dioxide, acetic acid or other approved chemicals which will not contribute chlorides or sulfates to the wastestream.
- c) Groundwater monitoring shall be conducted during the demonstration project and for six months thereafter. Quarterly sampling of all four existing downgradient wells for Boron, Calcium, Chloride, Manganese, Nitrate, Nitrite, pH, Sulfate, Sulfite and Total Dissolved Solids is required. Analytical data shall be submitted to the Agency within 60 days after sample collection. The first samples shall be collected upon commencement of the demonstration project.
- d) Modeling or dye tracing to identify the West Ash Pond System effluent mixing characteristics with the Illinois River shall be conducted and the point in the river where the sulfate water quality standard will be met identified. This information shall be submitted to the Agency within six months after commencement of the demonstration

DRAFT

Page 9

NPDES Permit No. IL0001554

Special Conditions

14. Sludge generated by the pretreatment of chemical metal cleaning waste in the chemical metal cleaning waste treatment tank at Hennepin Power Plant may be disposed of on the active area of the coal pile at the Hennepin Power Plant within the following guidelines:

1. Chemical metal cleaning waste treatment tank sludge shall not exceed the Toxicity Characteristic regulatory levels when subjected to the Toxicity Characteristic Leaching Procedure for the 25 organic constituents and 8 metals regulated under the Toxicity Characteristic Rule (FR Vol. 55, No. 61/March 29, 1990, 11798-11877).
2. Sludge shall be applied on the active area of the coal pile.
3. Sludge shall be applied on the active area of the coal pile at a controlled rate to prevent coal pile runoff.
4. Sludge application shall not be permitted if the coal pile has been wetted by rainfall within the 24-hour period preceding the intended application time.
5. Sludge application shall not be permitted on the coal pile during precipitation or when precipitation is imminent.
6. The filter cake from the portable sock filter may be disposed on site with the sludge generated by the chemical metal cleaning wastewater treatment process.
7. Sludge or filter cake which is a hazardous waste shall not be placed on the coal pile.

This Special Condition does not relieve the permittee of any State or federal requirements for management of hazardous waste. Documentation to support a hazardous waste determination pursuant to 40 CFR 262.11 shall be maintained by the permittee.

15. The permittee shall record monitoring results on Discharge Monitoring Report Forms using one such form for each discharge each month.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 15th day of the following month, unless otherwise specified by the permitting authority.

Discharge Monitoring Reports shall be mailed to the IEPA at the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
2200 Churchill Road
Springfield, Illinois 62706

Attention: Compliance Assurance Section

16. Within 180 days after the beginning of a discharge from the ash ponds (Outfalls 003 and 005), a 2 C application form shall be completed as required by 40 CFR 122.21(g)(7) and submitted to IEPA. The monitoring must include at least three samples for the required metals, ammonia, and cyanide. This permit may be modified, following public notice and opportunity for hearing, based on the monitoring results if necessary to prevent violations of water quality standards.

17. During the time period of the GR-SI demonstration project, the following additional monitoring shall be done on Outfall 005 if a discharge from this outfall occurs:

a. Chemical-Specific Testing

On a quarterly basis, a grab sample of the discharge shall be analyzed for the following parameters, and the results reported with the Discharge Monitoring Report for the month in which the samples are collected:

Antimony	Nickel
Arsenic	Selenium
Beryllium	Silver
Cadmium	Thallium
Chromium	Zinc
Copper	Sulfates
	Total Dissolved Solids

DRAFT

NPDES Permit No. IL0001554

Special Conditions

b. Biomonitoring

The permittee shall prepare a preliminary plan for biomonitoring and submit the plan to IEPA for review and approval within 90 days of the effective date of this permit. The permittee shall begin biomonitoring of the effluent discharge within 90 days after approval of the biomonitoring plan or other such date as contained in the Agency's notification letter.

1. Acute Toxicity — Standard definitive acute toxicity tests shall be run on two trophic levels of aquatic species representative of the aquatic community of the receiving stream. Except as noted here and in the IEPA document "Effluent Biomonitoring and Toxicity Assessment," testing must be consistent with Methods for Measuring the Acute Toxicity of Effluents to Aquatic Organisms EPA-600/4-85-013. Unless substitute tests are pre-approved, the following tests are required:

- a. Invertebrate 48-hour static LC₅₀ Bioassay using Ceriodaphnia.
 - b. Fish 96-hour static renewal LC₅₀ Bioassay using fathead minnow.

2. Testing Frequency — The above tests shall be conducted on a monthly basis for three months within 90 days following approval of the biomonitoring plan or other such date as contained in the Agency's notification (approval) letter. Results shall be reported according to EPA-600/4-85/014, Section 10, Report Preparation, and shall be submitted to IEPA within 1 week of becoming available to the permittee.

Should the results of any two months of sampling indicate toxicity for each month, the permittee shall submit within 90 days of the second toxicity event a plan for a toxicity identification evaluation (TIE) to the Agency. The Agency should be contacted at that time.

3. Toxicity Assessment — Should the review of the results of the biomonitoring program identify toxicity, the Agency may require that the permittee prepare a plan for toxicity reduction evaluation and identification. This plan shall include an evaluation to determine which chemicals have a potential for being discharged in the plant wastewater, a monitoring program to determine their presence or absence and to identify other compounds which are not being removed by treatment, and other measures as appropriate. The permittee shall submit to the Agency its plan for toxicity reduction evaluation within 90 days following notification by the Agency. The permittee shall implement the plan within 90 days or other such date as contained in a notification letter received from the Agency.

The Agency may modify this permit during its term to incorporate additional requirements or limitations based on the results of the biomonitoring. In addition, after review of the monitoring results, the Agency may modify this permit to include numerical limitations for specific pollutants. Modifications under this condition shall follow public notice and opportunity for hearing.

c. Benthic and Sediment Monitoring

Within 90 days after the effective date of this permit, the permittee shall prepare a plan for benthic and sediment monitoring of the receiving stream in the immediate vicinity of Outfall 005, and submit the plan to IEPA for review and approval. The monitoring program should be designed to document any instream chemical or biological impacts from the discharge, and should include monitoring prior to, during, and after discharges associated with the GR-SI project.

18. During the winter season (December 1 - March 15), a summary of winter operating conditions shall be prepared. The summary shall include daily average and maximum "Delta T" and discharge temperatures, and shall be submitted to IEPA for review by May 15 of each year.

ATTACHMENT H

Standard Conditions

Definitions

Act means the Illinois Environmental Protection Act, Ch. 111 1/2 Ill. Rev. Stat. Sec. 1001, 1051 as Amended.

Agency means the Illinois Environmental Protection Agency.

Board means the Illinois Pollution Control Board.

Clean Water Act (formerly referred to as the Federal Water Pollution Control Act) means Pub. L. 92-500, as amended, 33 U.S.C. 1251 et seq.

NPDES (National Pollutant Discharge Elimination System) means the national program for issuing, modifying, revoking and renewing, terminating, monitoring and enforcing permits, and promulgating and enforcing pretreatment requirements, under Sections 307, 402, 318 and 405 of the Clean Water Act.

USEPA means the United States Environmental Protection Agency.

Daily Discharge means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

Maximum Daily Discharge Limitation (daily maximum) means the highest allowable daily discharge.

Average Monthly Discharge Limitation (30 day average) means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Discharge Limitation (7 day average) means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best Management Practices (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste dispersal, or drainage from raw material storage.

Aliquot means a sample of specified volume used to make up a total composite sample.

Grab Sample means an individual sample of at least 100 milliliters collected at a randomly-selected time over a period not exceeding 15 minutes.

24 Hour Composite Sample means a combination of at least 8 sample aliquots of at least 100 milliliters, collected at periodic intervals during the operating hours of a facility over a 24-hour period.

8 Hour Composite Sample means a combination of at least 3 sample aliquots of at least 100 milliliters, collected at periodic intervals during the operating hours of a facility over an 8-hour period.

Flow Proportional Composite Sample means a combination of sample aliquots of at least 100 milliliters collected at periodic intervals such that either the time interval between each aliquot or the volume of each aliquot is proportional to either the stream flow at the time of sampling or the total stream flow since the collection of the previous aliquot.

- (1) Duty to comply. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action, permit termination, revocation and resuscitation, modification, or for denial of a permit renewal application. The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions. Even if the permit has not yet been modified to incorporate the requirement:
 - (2) Duty to resuscify. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. If the permittee submits a proper application as required by the Agency no later than 180 days prior to the expiration date, this permit shall continue in full force and effect until the final Agency decision on the application has been made.
 - (3) Need to halt or reduce activity not a defense. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
 - (4) Duty to mitigate. The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
 - (5) Proper operation and maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

(6) Permit actions. This permit may be modified, revoked and resuscitated, or terminated for cause by the Agency pursuant to 40 CFR 122.82. The filing of a request by the permittee for a permit modification, revocation and resuscitation, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

(7) Property rights. This permit does not convey any property rights of any sort, or any exclusive privilege.

(8) Duty to provide information. The permittee shall furnish to the Agency within a reasonable time, any information which the Agency may request to determine whether cause exists for modifying, revoking and resuscitating, or terminating this permit, or to determine compliance with the permit. The permittee shall also furnish to the Agency, upon request, copies of records required to be kept by this permit.

(9) Inspection and entry. The permittee shall allow an authorized representative of the Agency, upon the presentation of credentials and other documents as may be required by law, to:

- (a) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and;
- (d) Sample or monitor at reasonable times, for the purpose of assuring permit compliance, or as otherwise authorized by the Act, any substances or parameters at any location.

(10) Monitoring and records.

- (a) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (b) The permittee shall retain records of all monitoring information, including all calibration and maintenance records, and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of this permit, measurement, report or application. This period may be extended by request of the Agency at any time.
- (c) Records of monitoring information shall include:
 - (1) The date, exact place, and time of sampling or measurements;
 - (2) The individual(s) who performed the sampling or measurements;
 - (3) The detailed analyses were performed;
 - (4) The individual(s) who performed the analyses;
 - (5) The analytical techniques or methods used; and
 - (6) The results of such analyses.

(d) Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. Where no test procedure under 40 CFR Part 136 has been approved, the permittee must submit to the Agency a test method for approval. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to ensure accuracy of measurements.

(11) Signatory requirement. All applications, reports or information submitted to the Agency shall be signed and certified.

- (a) Application. At permit applications shall be signed as follows:
 - (1) For a corporation, by a principal executive officer or at least the level of vice president or a person or position having overall responsibility for environmental matters for the corporation;
 - (2) For a partnership or sole proprietorship, by a general partner or the proprietor, respectively; or
 - (3) For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official.

(b) Reports. All reports required by permits, or other information requested by the Agency shall be signed by a person described in paragraph (a) or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described in paragraph (a), and
- (2) The authorization specifies either an individual or a position responsible for the overall operation of the facility from which the discharge originates, such as a plant manager, superintendent or person of equivalent responsibility, and
- (3) The written authorization is submitted to the Agency.

(d) Changes of Authorization. If an authorization under (b) is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of (b) must be submitted to the Agency prior to or together with any reports, information, or applications to be signed by an authorized representative.

(12) Reporting requirements.

(a) Planned Changes. The permittee shall give notice to the Agency as soon as possible of any planned physical alterations or additions to the permitted facility.

(b) Anticipated noncompliance. The permittee shall give advance notice to the Agency of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

(c) Compliance schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

(d) Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.

- (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR).
- (2) If the permittee monitors any pollutant more frequently than required by the permit, using test procedures approved under 40 CFR 136 or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
- (3) Calculations for all limitations which require averaging of measurements shall unless an arithmetic mean unless otherwise specified by the Agency in the permit.

(e) Twenty-four hour reporting. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause, the period of noncompliance, including exact dates and times; and if the noncompliance has not been corrected, the anticipated time it is expected to continue, and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. The following shall be included as information which must be reported within 24 hours:

- (1) Any unanticipated bypass which exceeds any effluent limitation in the permit.
- (2) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Agency in the permit to be reported within 24 hours.

The Agency may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

(f) Other noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs (12)(c), (d), or (e), at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph (12)(e).

(g) Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Agency, it shall promptly submit such facts or information.

(13) Transfer of permits. A permit may be automatically transferred to a new permittee if:

- (a) The current permittee notifies the Agency at least 30 days in advance of the proposed transfer date.
- (b) The notice includes a written agreement between the existing and new permittees containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittees, and
- (c) The Agency does not notify the existing permittee and the proposed new permittee of its intent to modify or revoke and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement.

(14) All manufacturing, commercial mining, and structural dischargers must notify the Agency as soon as they know or have reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant identified under Section 307 of the Clean Water Act which is not limited in the permit if that discharge had exceeded the highest of the following notification levels:

 - (1) One hundred micrograms per liter (100 ug/l)
 - (2) Two hundred micrograms per liter (200 ug/l for strontium and alyconite, five hundred micrograms per liter (500 ug/l for 2,4-dinitrophenol and for 2-methyl 4,6-dinitrophenol, and one milligram per liter (1 mg/l for ammonia)
 - (3) Five (5) times the maximum concentration value reported for that pollutant in the NPDES permit application, or
 - (4) The level established by the Agency in this permit.

- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant which was not reported in the NPDES permit application.

(15) All Publicly Owned Treatment Works (POTWs) must provide adequate notice to the Agency of the following:

- (a) Any new introduction of pollutants into that POTW from an indirect discharger which would be subject to Sections 301 or 308 of the Clean Water Act if it were directly discharging those pollutants, and
- (b) Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- (c) For purposes of this paragraph, adequate notice shall include information on (i) the quantity and quantity of effluent introduced into the POTW, and (ii) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

(16) If the permit is issued to a publicly owned or publicly regulated treatment works, the permittee shall require any industrial user of such treatment works to comply with federal requirements concerning:

- (1) User charges pursuant to Section 204(b) of the Clean Water Act, and applicable regulations appearing in 40 CFR 25.
- (2) Toxic pollutant effluent standards and pretreatment standards pursuant to Section 307 of the Clean Water Act, and
- (3) Inspection monitoring and entry pursuant to Section 308 of the Clean Water Act.

(17) If an applicable standard or limitation is promulgated under Section 301(b)(2)(C) and (D), 304(b)(2), or 307(a)(2) and that effluent standard or limitation is more stringent than any effluent limitation in the permit, or controls a pollutant not listed in the permit, the permit shall be promptly modified or revoked, and resubmitted to conform to that effluent standard or limitation.

(18) Any authorization to construct issued to the permittee pursuant to 35 U.S. Admin. Code 308.154 is hereby incorporated by reference as a condition of this permit.

(19) The permittee shall not make any false statement, representation or certification in any application, record, report, plan or other document submitted to the Agency or the USEPA, or required to be maintained under this permit.

(20) The Clean Water Act provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act is subject to a civil penalty not to exceed \$10,000 per day of such violation. Any person who willfully or negligently violates permit conditions implementing Sections 301, 302, 306, 307, or 308 of the Clean Water Act is subject to a fine of not less than \$2,500, nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both.

(21) The Clean Water Act provides that any person who falsified, tampered with, or knowingly renders inaccurate any monitoring device or method required to be maintained under permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

(22) The Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit shall, including monitoring reports or reports of compliance or non-compliance, shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

(23) Collected screening, summit, dredge, and other solids shall be disposed of in such a manner as to prevent entry of those wastes (or runoff) from the wastes) into waters of the State. The proper authorization for such disposal shall be obtained from the Agency and is incorporated as part hereof by reference.

(24) In case of conflict between these standard conditions and any other conditions included in this permit, the other conditions shall govern.

(25) The permittee shall comply with, in addition to the requirements of the permit, all applicable provisions of 35 U.S. Admin. Code, Subtitle C, Subtitle D, Subtitle E, and all applicable orders of the Agency.

(26) The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit is held invalid, the remaining provisions of this permit shall continue in full force and effect.

END

**DATE
FILMED**

12 / 22 / 92

