

4D

BNWL-2180 Vol. I
UC-12

**A User's Manual
for the BNW-I Optimization
Code for Dry-Cooled
Power Plants**

Volume I

January 1977

**Prepared for the Energy Research
and Development Administration
under Contract EY-76-C-06-1830**

 **Battelle**
Pacific Northwest Laboratories

BNWL-2180 Vol. I

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

The views, opinions and conclusions contained in this report are those of the contractor and do not necessarily represent those of the United States Government or the United States Energy Research and Development Administration.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE
for the
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION
Under Contract EY-76-C-06-1830

Printed in the United States of America
Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road
Springfield, Virginia 22151
Price: Printed Copy \$____*; Microfiche \$3.00

*Pages	NTIS Selling Price
001-025	\$4.50
026-050	\$5.00
051-075	\$5.50
076-100	\$6.00
101-125	\$6.50
126-150	\$7.00
151-175	\$7.75
176-200	\$8.50
201-225	\$8.75
226-250	\$9.00
251-275	\$10.00
276-300	\$10.25

3 3679 00052 3086

BNWL-2180
UC-12

A USER'S MANUAL FOR THE BNW-I OPTIMIZATION
CODE FOR DRY-COOLED POWER PLANTS

VOLUME I

by
David J. Braun
Daniel J. Braun
Warren V. De Mier
Duane W. Faletti
Lawrence E. Wiles

January 1977

BATTELLE
Pacific Northwest Laboratories
Richland, Washington 99352



PREFACE

This document has been issued in four volumes to facilitate handling. Volume I is a narrative description of the code algorithms, as well as logic, input and output information. Volumes II through IV are appendices of Volume I, providing listings of the BNW-I optimization code for each of three dry-cooled heat rejection systems. These are:

Volume II - Metal Finned Tube Versions of the BNW-I Computer Code

Volume III - Plastic System Versions of the BNW-I Computer Code

Volume IV - Ammonia System Versions of the BNW-I Computer Code

Complete distribution has been given only to Volume I. Copies of one or more of the other three volumes may be obtained by writing the National Technical Information Service, U.S. Department of Commerce, 5281 Port Royal Road, Springfield, VA, 22151.



FOREWORD

The Dry Cooling Tower Development Program at Battelle, Pacific Northwest Laboratory was initiated with a program scope that included the following near-term and ultimate emphases.

Near-Term Objectives:

- Develop economic and performance models for cost optimization of total heat rejection systems using dry cooling.
- Analysis of, and dissemination of experience on, existing dry-cooled plant performance.
- Demonstrate certain features of existing technology equipment to provide confidence for specification by utilities.

Ultimate Objective:

- Promote water conservation through industry use of dry cooling by developing and demonstrating the reliability of lower-cost systems. The development of advanced dry/wet systems is also considered to be within this scope.

Over the past two years the following documents have been issued, reporting the results of the work toward these objectives.

Cost optimization of dry-cooled heat rejection systems:

A REVIEW AND ASSESSMENT OF ENGINEERING ECONOMIC STUDIES OF DRY COOLED ELECTRICAL GENERATING PLANTS. B. C. Fryer, BNWL-1976, March 1976.

HEAT TRANSFER AND PRESSURE DROP CHARACTERISTICS OF DRY TOWER EXTENDED SURFACES. PART I: HEAT TRANSFER AND PRESSURE DROP DATA. PFR Engineering Systems, Inc., PFR 7-100, March 1976.

HEAT TRANSFER AND PRESSURE DROP CHARACTERISTICS OF DRY TOWER EXTENDED SURFACES. PART II: DATA ANALYSIS AND CORRELATION. PFR Engineering Systems, Inc., PFR 7-102, June 1976.

Analysis of performance of existing dry-cooled plants:

DRY COOLING TOWER PROGRAM: RESULTS OF INDUSTRIAL CONTACTS THROUGH AUGUST 1974. BNWL-1878, November 1, 1974.

A SURVEY OF MATERIALS AND CORROSION PERFORMANCE IN DRY COOLING APPLICATIONS. A. B. Johnson, Jr., D. R. Pratt and G. E. Zima, BNWL-1958, March 1976.

EUROPEAN DRY COOLING TOWER OPERATING EXPERIENCE. J. G. DeSteele and K. Simhan, BNWL-1995, March 1976.

MATHEMATICAL AND EXPERIMENTAL INVESTIGATIONS ON DISPERSION AND RECIRCULATION OF PLUMES FROM DRY COOLING TOWERS AT WYODAK POWER PLANT IN WYOMING. Y. Onishi and D. S. Trent, BNWL-1982, February 1976.

Advanced dry (dry/wet) cooled systems:

PRELIMINARY EVALUATION OF WET/DRY COOLING CONCEPTS FOR POWER PLANTS. W. V. Loscutoff, BNWL-1969.

COMPATIBILITY OF AMMONIA WITH CANDIDATE DRY COOLING SYSTEM MATERIALS. D. R. Pratt, BNWL-1992, April 1976.

SCALE FORMATION IN DELUGED DRY COOLING SYSTEMS. D. R. Pratt, BNWL-2060, March 1976.

AMMONIA AS AN INTERMEDIATE HEAT EXCHANGE FLUID FOR DRY COOLED TOWERS. R. T. Allemann, B. M. Johnson and G. C. Smith, BNWL-SA-5997, September 1976.

A group of reports (including this report) has recently been issued. This group serves the dual purpose of developing cost optimization models for dry cooling systems based on available technology and comparing the results of analyzing the costs of these systems with the projected cost of several advanced dry and dry/wet systems. Included in this group are:


AN ENGINEERING AND COST COMPARISON OF THREE DIFFERENT ALL-DRY COOLING SYSTEMS. B. C. Fryer, D. W. Faletti, Dan J. Braun, David J. Braun and L. E. Wiles, BNWL-2121, September 1976.

A STUDY OF THE COMPARATIVE COSTS OF FIVE WET/DRY COOLING TOWER CONCEPTS. F. R. Zaloudek, R. T. Allemann, D. W. Faletti, B. M. Johnson, H. L. Parry, G. C. Smith, R. D. Tokarz, and R. A. Walter, BNWL-2122, September 1976.

DRY COOLING OF POWER GENERATING STATIONS: A SUMMARY OF
THE ECONOMIC EVALUATION OF SEVERAL ADVANCED CONCEPTS VIA
A DESIGN OPTIMIZATION STUDY AND A CONCEPTUAL DESIGN AND
COST ESTIMATE. B. M. Johnson, R. T. Allemann, D. W. Faletti,
B. C. Fryer and F. R. Zaloudek, BNWL-2120, September 1976.

COSTS AND COST ALGORITHMS FOR DRYING COOLING TOWER SYSTEMS.
P. A. Ard, C. H. Henager, D. R. Pratt and L. E. Wiles,
BNWL-2123, September 1976.

A USER'S MANUAL FOR THE BNW-I OPTIMIZATION CODE FOR
DRY-COOLED POWER PLANTS. David J. Braun, Dan J. Braun,
Warren V. De Mier, D. W. Faletti and L. E. Wiles, BNWL-2180,
January 1977.



ACKNOWLEDGMENTS


This report contains an account of work sponsored by the Division of Nuclear Research and Applications of ERDA under the Dry Cooling Tower Program at Battelle, Pacific Northwest Laboratory (PNL). The project was completed under the direction of Mr. Ira Helms, Project Officer; Dr. W. F. Savage, Manager of the Advanced Concepts Evaluation Branch of ERDA; and B. M. Johnson, Manager of the Dry Cooling Tower Project at PNL.

The authors gratefully acknowledge Dr. B. C. Fryer's leadership and effort throughout the code development task.

The information provided by Dott. Ing. Carlo Rocco and Vincenzo Leonelli of Italimpianti, Genoa, Italy, and by Professor Carlo Roma of the University of Rome on the natural draft system currently under development by Italimpianti was of invaluable assistance in our evaluation of the induced draft PLASTIC system.

Acknowledgments are also due to the following cooling tower manufacturers and their representatives for their interest during this study: M. Larinoff and E. C. Smith of Hudson Products, and R. Landon and R. Cates of The Marley Company.


Many manufacturers of components for cooling tower systems were contacted during this study and provided essential cost information that was incorporated into the cost algorithms and estimates. This information is the basis of the comparisons made herein. We acknowledge this vital contribution to the study, although any mistakes in interpretation and formulation of this information are the responsibility of PNL.



SUMMARY

This User's Manual provides information on the use and operation of three versions of BNW-I, a computer code developed by Battelle, Pacific Northwest Laboratory (PNL) as a part of its activities under the ERDA Dry Cooling Tower Program. These three versions of BNW-I were used as reported elsewhere to obtain comparative incremental costs of electrical power production by two advanced concepts (one using plastic heat exchangers and one using ammonia as an intermediate heat transfer fluid) and a state-of-the-art system.

The computer program offers a comprehensive method of evaluating the cost savings potential of dry-cooled heat rejection systems and components for power plants. This method goes beyond simple "figure-of-merit" optimization of the cooling tower and includes such items as the cost of replacement capacity needed on an annual basis, and the optimum split between plant scale-up and replacement capacity, as well as the purchase and operating costs of all major heat rejection components. Hence, the BNW-I code is a useful tool for determining potential cost savings of new heat transfer surfaces, new piping or other components as part of an optimized system for a dry-cooled power plant.



CONTENTS

VOLUME I

PREFACE	iii
FOREWORD	v
ACKNOWLEDGMENTS	ix
SUMMARY	xi
1.0 INTRODUCTION	1
2.0 PHYSICAL DESCRIPTION OF THE THREE COOLING SYSTEMS	3
2.1 SOA COOLING SYSTEM	3
2.1.1 Condenser	5
2.1.2 Piping	5
2.1.3 Cooling Tower	5
2.2 PLASTIC HEAT EXCHANGER COOLING SYSTEM	6
2.3 AMMONIA DRY COOLING SYSTEM	6
2.3.1 Condenser/Reboiler	8
2.3.2 Piping	8
2.3.3 Cooling Tower	8
3.0 PLANT DESIGN OVERVIEW AND BASIS	9
3.1 UTILITY MODEL	9
3.2 STEAM SUPPLY AND PLANT SCALING	10
3.3 COSTING METHOD	13
3.4 OPTIMIZATION	14
4.0 CALCULATIONAL PROCEDURE	19
4.1 METAL FINNED TUBE (SOA) SYSTEM	19
4.1.1 Condenser Design and Costing	23
4.1.2 Heat Exchanger Design and Costing (COSTEX)	25
4.1.3 Fan System Selection (FAN)	26
4.1.4 Piping Design and Cost Algorithm Outline	28
4.1.5 Plant Scaling Due to Dry Cooling	31
4.1.6 Dry-Cooled Power Plant Performance and Incremental Cost for a Yearly Temperature Profile (NOVART, VARIT)	34
4.2 PLASTIC SYSTEM	36

4.3	AMMONIA (NH ₃) SYSTEM	36
4.3.1	Condenser/Reboiler Design and Costing	41
4.3.2	Incremental Cost of the Dry Cooling System for the Power Plant Operating Over the Yearly Temperature Profile (NOVART, VARIT)	43
5.0	COMPUTER PROGRAMS	45
5.1	GENERAL INFORMATION	45
5.2	INPUT	48
5.2.1	SOA Model Input Description	50
5.2.2	Plastic Model Input Description	58
5.2.3	NH ₃ Model Input Description	66
5.3	OUTPUT	74
5.3.1	SOA Model Output	74
5.3.2	Plastic Tube Model Output	90
5.3.3	NH ₃ Model Output	102
	REFERENCES	119
	APPENDIX A - HEAT TRANSFER AND PRESSURE DROP CORRELATIONS AND DATA BASE	A-1
	APPENDIX B - PIPING SYSTEM	B-1
	APPENDIX C - OPTIMIZATION TECHNIQUE	C-1
	APPENDIX D - SELECTION OF COMPLETE AND INCOMPLETE TOWER GROUPS	D-1

VOLUME II

	APPENDIX E - METAL FINNED TUBE VERSION OF THE BNW-I COMPUTER CODE	E-1
--	--	-----

VOLUME III

	APPENDIX F - PLASTIC VERSION OF THE BNW-I COMPUTER CODE	F-1
--	---	-----

VOLUME IV


	APPENDIX G - AMMONIA VERSION OF THE BNW-I COMPUTER CODE	G-1
--	---	-----

FIGURES

2-1	Indirect Dry Cooling System with Surface Condenser and Mechanical Draft Tower	3
2-2	Temperature Relationships for SOA and PLASTIC Heat Exchanger Cooling Systems	4
2-3	Ammonia Coolant Dry Cooling System	6
2-4	Temperature Relationships for Ammonia Coolant Dry Cooling System	7
3-1	Heat Rate Versus Back Pressure--Fossil Turbines	11
3-2	Typical Annual Performance of a Dry Cooled Plant	12
3-3	Dry Cooling System Computer Optimization	17
4-1	BNW-I Program Flow Diagram	20
4-2	Typical Piping System Configuration	28
4-3	Subroutine CALC Flow Diagram (Ammonia Version)	38
5-1	Sample Input for SOA Model	48
5-2	Sample Input for PLASTIC Model	49
5-3	Sample Input for NH ₃ Model	49
5-4	SOA Model Sample Output	79
5-5	PLASTIC Tube Model Sample Output	92
5-6	NH ₃ Model Sample Output	106

TABLES

3-1	Computer Analysis - Major Cooling System Parameters and Options	15
5-1	Subroutines Containing Constraint-Imposing Variables	46



A USER'S MANUAL FOR THE BNW-I OPTIMIZATION
CODE FOR DRY-COOLED POWER PLANTS

1.0 INTRODUCTION

This report provides information on BNW-I, a computer code developed by Battelle, Pacific Northwest Laboratory (PNL) as part of its activities under the ERDA Dry Cooling Tower Program. BNW-I was used in other studies⁽¹⁾ to obtain comparisons of the incremental cost (referred to as a zero-cost cooling system) of three all-dry cooling systems:


- the state-of-the-art indirect system (SOA);
- an advanced concept using plastic tube heat exchangers (PLASTIC);
- an advanced concept using ammonia as an intermediate heat transfer fluid (NH_3).

These studies showed that both the PLASTIC and the NH_3 systems had potential for significant cost savings.⁽¹⁾

This User's Manual provides information on the use and operation of three versions of BNW-I used to study the all-dry systems listed above. The primary purpose of this report is to provide the reader with the information required to use the BNW-I code, i.e., to prepare the input required and to interpret the output.

In addition, this report covers the following topics:

- physical descriptions of the three systems
- the rationale used to optimize the cost of electricity
- calculational procedures
- basis for the performance and cost models.



2.0 PHYSICAL DESCRIPTION OF THE THREE COOLING SYSTEMS

General descriptions of the SOA, PLASTIC, and NH_3 cooling systems are provided in Sections 2.1 through 2.3. The descriptions are for each system operating at steady-state at full load. Startup, shutdown, load change, and system operational changes to accommodate meteorological changes for various plant operating modes are not considered.

2.1 SOA COOLING SYSTEM

The SOA cooling system modeled by the SOA code is illustrated in Figure 2-1. It is an indirect system with induced mechanical draft and a single-pressure surface condenser.





FIGURE 2-1. Indirect Dry Cooling System with Surface Condenser and Mechanical Draft Tower

The cooling process is best described with the aid of the temperature relationship diagram in Figure 2-2. Turbine exhaust steam is condensed at constant temperature on the outside of the condenser tubes. Water entering the condenser tubes is heated, then carried through the supply piping to the cooling tower. The increase in water temperature is termed the range of water. The water temperature approaches the steam saturation temperature; the difference is termed the "terminal temperature difference," or TTD. At the cooling tower, the water cools while simultaneously heating the air as it passes over the finned tubes in the tower. This change in air temperature is termed the range of the air. The cooled water is then returned via piping to the condenser inlet. The heated air is discharged to the environment by the induced draft fans. A short description of the components of the SOA cooling system as contained in the computer code will now be presented.

The increase in water temperature is termed the range of water. The water temperature approaches the steam saturation temperature; the difference is termed the "terminal temperature difference," or TTD. At the cooling tower, the water cools while simultaneously heating the air as it passes over the finned tubes in the tower. This change in air temperature is termed the range of the air. The cooled water is then returned via piping to the condenser inlet. The heated air is discharged to the environment by the induced draft fans. A short description of the components of the SOA cooling system as contained in the computer code will now be presented.



- T_{SAT} = TURBINE EXHAUST TEMPERATURE
- TTD = TERMINAL TEMPERATURE DIFFERENCE
- ITD = INITIAL TEMPERATURE DIFFERENCE
- T_A = AMBIENT DRY BULB DESIGN TEMPERATURE

FIGURE 2-2. Temperature Relationships for SOA and Plastic Heat Exchanger Cooling Systems

2.1.1 Condenser

The SOA code considers a single-pressure surface condenser only. Investigation of multipressure surface condensers would require modification of the computer program.

2.1.2 Piping

The piping consists of main supply and return lines, tower distribution lines, headers, and pump station piping. The cost data used in the codes presented in this report are for carbon steel piping and fittings. The main supply and return piping and the tower distribution lines are considered to be below ground. The headers are considered to be above ground. The vertical inline pumps draw water from an open reservoir. A complete description of the piping layouts and algorithms is presented in Reference 2; Appendix B gives an abbreviated description.

2.1.3 Cooling Tower

The cooling towers are circular with vertical tube heat exchangers and induced draft fans. If desired, louvers can be provided for air flow control and hail protection. Similarly, fan diffuser stacks can be provided. The fan system consists of the fans, motors, gear boxes and electrical wiring. The fan blades are fiberglass. The gear boxes are single-speed bevel gear type. The fans have manually adjustable pitch blades.

Versions of the BNW-I code applicable to rectangular cooling towers with horizontal tubes were also developed and used.⁽¹⁾

All three versions of the code can be used to model the tower configurations where the heat exchanger bundles are arranged in deltas (typically 60°) on the periphery of the towers.

2.2 PLASTIC HEAT EXCHANGER COOLING SYSTEM

The plastic heat exchanger cooling system is basically the same as the SOA system with the metal finned tubes replaced with plastic tubes. Details of plastic heat exchanger fabrication may be found in References 2 and 3.

Bare tube heat transfer models are used for the heat exchanger bundles of the PLASTIC system. Correlations for calculating the air-side heat transfer coefficients for both staggered and inline bare tube arrangements are included in Appendix A.

2.3 AMMONIA DRY COOLING SYSTEM

The ammonia dry cooling system, illustrated in Figure 2-3, differs from SOA systems in two ways. First, ammonia replaces water as the coolant. Second, a condenser/reboiler is used in place of the standard condenser.




FIGURE 2-3. Ammonia Coolant Dry Cooling System

The cooling process can be explained by referring to Figures 2-3 and 2-4. Turbine exhaust steam is condensed at constant temperature on the outside of the condenser/reboiler tubes. Slightly subcooled liquid ammonia

entering the condenser/reboiler tubes is first heated to saturation temperature, then partially boiled at constant temperature as it traverses the length of the tubes. A mixture of liquid and vapor ammonia (typically 50 to 80 percent quality, depending on the design) enters the separator, where the vapor is routed to the tower supply piping and the liquid is collected for recirculation to the condenser/reboiler. The vapor flows through the supply piping at near-saturation conditions. However, there is a pressure drop in the piping system from frictional effects. Because of the physical characteristics of ammonia vapor, this pressure drop is accompanied by a drop in temperature (TTD2). At the tower, the vapor is condensed inside the metal finned tubes at constant temperature. The condensed ammonia is then collected and returned to the condenser/reboiler. The basic terminology remains the same as for the SOA system except that the parameter, $RANGE_{Water}$, is eliminated and replaced by the vapor supply piping temperature drop, TTD2. Because of the economic trade-offs, the $RANGE_{Air}$, is larger for the ammonia system than for the SOA or PLASTIC systems.




FIGURE 2-4. Temperature Relationships for Ammonia Coolant Dry Cooling System

2.3.1 Condenser/Reboiler

The condenser/reboiler is similar to the SOA condenser in general appearance. However, the water boxes are replaced with high pressure headers and the tube sheets are much thicker. Tubes of two types can be modeled: conventional smooth tubes of aluminum or stainless steel, or enhanced tubes which improve steam-side and ammonia-side heat transfer processes. With the enhanced tubes, the size of the condenser/reboiler is about the same as for a conventional condenser. With conventional tubes, the condenser/reboiler is significantly larger. Only horizontal tube arrangements with ammonia on the tube side are modeled. Other arrangements, including vertical tubes and/or ammonia on the shell side, are optional possibilities that could be evaluated by inserting appropriate cost and performance algorithms into the code.

2.3.2 Piping

The piping in the ammonia system is significantly different from that in the water systems. First, the diameter is typically smaller, particularly in the return line. Second, for a given diameter, the ammonia piping must be considerably thicker (neglecting corrosion allowances) to accommodate the higher pressure.

2.3.3 Cooling Tower

The ammonia cooling system considered consists of vertical tube, one-pass heat exchangers. Ammonia vapor enters the top of the heat exchangers, and condenses as it flows down the inside of the finned tubes. This is in contrast to the two-pass SOA and PLASTIC systems in which water enters and exits the heat exchangers at the bottom of the vertical tube heat exchanger.

3.0 PLANT DESIGN OVERVIEW AND BASIS

The plant is designed to minimize the power production costs of an idealized utility system using a dry-cooled plant. The "cost" of dry cooling is defined as an incremental increase in power production costs compared to the cost of producing power with a plant having a zero-cost cooling system and a conventional turbine that operates at 3.5 in. Hg.

3.1 UTILITY MODEL

The idealized utility consists of one dry-cooled, base loaded power plant with a gas turbine complement^(a) to provide power at higher ambient temperatures. (The reference plant requires no gas turbines complement because its turbine back pressure is constant at 3.5 in. Hg.) This idealized utility operates in an on-off mode. It supplies full power at a constant level when in the "on" mode and no power during the "off" mode. The fraction of time that the idealized utility is in the "on" mode is equal to the capacity factor. No real-life utility operates in this manner. However, the idealized utility used here can be viewed as a portion of a real utility, because the actual utility has a number of plants that supply the required power when one or more of the base loaded plants are down for either scheduled or unscheduled maintenance.

The base loaded dry-cooled plant is capable of supplying the entire power requirement of the utility plus the power requirements of the fans and pumps of its cooling system up to its "design temperature". Above the design temperature, the power output of the dry-cooled plant falls off because of rising turbine back pressure; the power deficit is made up by gas turbines. The size of the gas turbine contingent is determined by the power deficit of the dry-cooled plant (which is always operated "valve wide open") at the highest ambient temperature.

(a) Other sources of replacement energy such as hydro or cycling plants can be simulated by appropriate changes in the capital and fuel costs used as inputs to the program.

The dry-cooled plant can produce more than the utility's power requirements below the design temperature. Because no market exists for this power, no credit is taken for this excess capacity. However, credit is given for reduced base plant fuel consumption resulting from the lower turbine back pressures during periods of lower-than-design ambient temperature.

3.2 STEAM SUPPLY AND PLANT SCALING

Both steam supply scaling and plant scaling are used in designing the plant. The steam supply system is scaled separately to meet the additional steam requirements of the dry-cooled plant's steam turbine at rated back pressure. This additional steam requirement arises from the difference in heat rate between

- a) the reference base plant conventional turbine, and
- b) the turbine selected for use in the power plant being designed (conventional, modified conventional, and high back pressure).

The difference in heat rate factors is shown graphically in Figure 3-1, where the difference being discussed is between Point 0 and Point 1 or 1'. Point 0 gives the heat rate factor and rated back pressure of the conventional turbine used in the reference plant. Points 1 and 1' are the heat rate factors at the rated back pressure for the modified conventional and high back pressure turbines, respectively. Steam supply scaling refers to increasing the size of the steam supply to compensate for the increase in heat rate between Points 0 and 1, or between Points 0 and 1'.

Plant scaling refers to increasing the size of the entire plant, including the steam supply system and the heat rejection system, so that the net power output of the plant (equal to the gross power output minus the requirements for cooling system fans and pumps) equals the utility's requirements at the design temperature.

Plant scaling is accomplished in two steps. The first step involves scaling only the plant size (including the steam supply system) up or down to account for the difference in turbine heat rates at plant design conditions (i.e., at the design temperature) and at rated back pressure. This can result in a decrease or increase in plant size depending on whether the

design turbine back pressure is greater or less than the rated back pressure of the steam turbine. This process has nothing to do with the reference base plant conventional turbine, only the turbine used in the design plant. In Figure 3-1, the heat rate factors are shown as Points 1 and 2 (for a modified conventional turbine) or Points 1' and 2' (for the high back pressure turbine).




FIGURE 3-1. Heat Rate Versus Back Pressure-- Fossil Turbines

The second step involves scaling up the plant and the dry cooling tower system to provide power for the cooling system fans and pumps. The relationships between the reference plant power output and the gross and net power output of the dry-cooled plant are shown on Figure 3-2. Point 2 on Figure 3-2 corresponds to Point 2 of Figure 3-1. When the plant is scaled up in size, none of the operating parameters is changed. Therefore, the power plants represented by Points 2 and 3 in Figure 3-2 have the same turbine design back pressure. The only difference between the two plants is that the scaled-up plant produces not only the power required by the utility system, but power for the fans and pumps of the dry cooling tower. Because the heat

rejection load of the dry cooling towers has increased, the physical dimensions of the towers are scaled up to handle this increase in heat rejection.




FIGURE 3-2. Typical Annual Performance of a Dry Cooled Plant

In both steps, the power plant is scaled up or down linearly. The dry cooling tower system in the second step is also scaled linearly. Therefore, second order effects were not taken into account by this particular scaling process; for example, the increased plant size required to produce power for the slightly larger cooling system is neglected.

A trade-off exists between plant scaling and the size of the gas turbine contingent. The optimization process takes this trade-off into account.

3.3 COSTING METHOD

The incremental cost of dry cooling includes the following capital items:

- a) cooling system equipment and installation costs (including indirect costs such as profit, overhead and engineering)
- b) increased steam supply system cost
- c) change in plant cost due to difference between the turbine rated back pressure and the turbine design back pressure
- d) increased base plant costs for supplying power to auxiliaries
- e) gas turbine capital costs.

The incremental costs of dry cooling include the following fuel costs:

- a) increased base plant fuel required for producing power for the pumps and fans
- b) difference in the amount of base plant fuel required for the dry-cooled plant versus that of the reference plant operating at 3.5 in. Hg back pressure
- c) gas turbine fuel.

Operation and maintenance costs are calculated as a percentage of the cooling system capital cost. No operation and maintenance costs are applied to the gas turbines.

Items and related costs not included within these codes are:

- 1) cover gas system
- 2) cooling system instrumentation costs
- 3) cooling loop water treatment costs.

The incremental cost is expressed in mills/kWh by

$$C = \frac{FCR (\text{capital costs}) + \text{Fuel Costs} + OM}{CF \times 24 \times 365 \times 1000 \times P}$$

where

FCR is the fixed charge rate

OM is the operations and maintenance cost

CF is the capacity factor (fraction of the year that the plant operates)

P is the power output, kilowatts

and the capital, fuel, and operation and maintenance costs (OM) are as given above.

All costs are in January 1976 dollars. Interest during construction and inflation prior to or during construction is not considered. Effects of the dry cooling system's construction schedules and their impact on the balance of plant construction schedule are also not considered. The uncertainty involved in defining these items appears to outweigh any additional understanding obtained by including them in a comparative analysis.

The heat transfer and the pressure drop correlations used by BNW-I are presented in Appendix A. Cost algorithms were developed for the components of the dry-cooled plant cooling system. These algorithms are described in detail in Reference 2. A brief description of the piping algorithms is presented in Appendix B.

3.4 OPTIMIZATION

Optimization of a dry cooling system involves:

- a) selecting values for the set of independent parameters which fix the design, after which all other dependent parameters (including incremental power production costs) can then be calculated; and
- b) repeating this process until the lowest incremental power production cost is obtained.

The computer optimization involves parameters of four types:

1. internally optimized independent parameters;
2. internally optimized dependent parameters;
3. externally optimized independent parameters; and,
4. external fixed parameters.

A list of the major parameters and options in each of the above groups is given in Table 3-1.

The external fixed parameters are those which are imposed on the analysis. They are generally fixed at a given site for a particular plant. However, the investigator may vary these "fixed" parameters when comparing the cost of dry cooling for nuclear plants with coal plants, or evaluating cost differences at different sites. The effect of changes in fuel costs, capacity factors, etc., can also be investigated by varying these parameters.

TABLE 3-1. Computer Analysis - Major Cooling System Parameters and Options

	INTERNALLY OPTIMIZED INDEPENDENT	INTERNALLY OPTIMIZED DEPENDENT	EXTERNALLY OPTIMIZED INDEPENDENT	EXTERNAL FIXED
I HEAT EXCHANGER	<ol style="list-style-type: none"> FRONTAL AREA WIDTH /LENGTH RATIO 	<ol style="list-style-type: none"> TUBE LENGTH* NUMBER TUBES IN DEPTH* TOTAL TUBES, (BUNDLE NUMBER), OR OVERALL SIZE 	<ol style="list-style-type: none"> UNIT GEOMETRY (TUBE OD, TUBE PITCH, FIN PITCH, FIN HEIGHT, STAGGERED VS IN-LINE, ETC) TUBE AND FIN MATERIAL FIN TYPE SPACER MATERIAL AND TYPE HEADER TYPE 	
II FAN SYSTEM		<ol style="list-style-type: none"> NUMBER BLADE DIAMETER* BLADE ANGLE* NUMBER OF BLADES* FAN POWER 	<ol style="list-style-type: none"> VELOCITY RECOVERY VS NO VELOCITY RECOVERY 	
III TOWER		<ol style="list-style-type: none"> NUMBER* (CIRCULAR) DIAMETER (CIRCULAR) 		
IV PIPING AND PUMP		<ol style="list-style-type: none"> PUMP POWER PIPE LENGTHS PIPE DIAMETER 	<ol style="list-style-type: none"> DESIGN VELOCITY PIPE WALL THICKNESS PIPING TEMPERATURE DROP 	
V CONDENSER (SOA AND PLASTIC)		<ol style="list-style-type: none"> TUBE LENGTH TUBE NUMBER 	<ol style="list-style-type: none"> TERMINAL TEMPERATURE DIFFERENCE TUBE MATERIAL TUBE DIAMETER DESIGN VELOCITY 	
V' CONDENSER/REBOILER (NH ₃)	<ol style="list-style-type: none"> TERMINAL TEMPERATURE DIFFERENCE (NH₃) 	<ol style="list-style-type: none"> TUBE NUMBER 	<ol style="list-style-type: none"> TUBE LENGTH TUBE MATERIAL TUBE DIAMETER TUBE TYPE EXIT QUALITY 	
VI TURBINE	<ol style="list-style-type: none"> DESIGN TURBINE EXHAUST TEMPERATURE* 		<ol style="list-style-type: none"> TURBINE TYPE 	
VII COMMON TO TWO OR MORE COMPONENTS	<ol style="list-style-type: none"> CAPACITY RATIO (WATER/AIR) RANGE OF WATER* RANGE OF AIR (NH₃) 	<ol style="list-style-type: none"> AIR MASS FLOW RATE (RANGE OF AIR) WATER MASS FLOW RATE TOWER INITIAL TEMPERATURE DIFFERENCE (ITD)* 	<ol style="list-style-type: none"> RATIO OF TOWER ROOF AREA TO FAN SWEEPED AREA DESIGN AMBIENT TEMPERATURE DELTA VRS NON-DELTA HEAT EXCHANGER CIRCULAR VRS RECTILINEAR TOWER ARRANGE 	
VIII BASE PLANT				<ol style="list-style-type: none"> FUEL COST PLANT COST HEAT RATE CAPACITY FACTOR FIXED CHARGE RATE SIZE
IX CAPACITY LEVELING				<ol style="list-style-type: none"> ENERGY PENALTY CHARGES CAPACITY PENALTY CHARGES
X SITE				<ol style="list-style-type: none"> METEOROLOGY

*OPTIONAL TREATMENT AS EXTERNALLY FIXED PARAMETER

The externally optimized independent parameters or options are those optimized by changing one or more parameters or options at a time and observing the resultant changes in costs and cooling system design. This includes simple factors such as the effect of fin spacing, as well as more complex elements such as delta heat exchanger arrangements.

For a given set of external parameters, there are five internally optimized independent parameters. Once these five independent parameters are specified, all other system design and operating dependent parameters can be calculated. Several different combinations of five parameters could have been used in lieu of those in Table 3-1. However, combinations shown in Table 3-1 are those used in the MIT study⁽⁴⁾ that served as one reference for the work described herein.

This particular set of parameters makes solving for the dependent parameters rather straightforward with a minimum of time-consuming iterative implicit calculations. However, this approach results in heat exchanger designs with a non-integer number of tube rows in the direction of air flow. Usually, this can be circumvented by applying constraints to the optimization analysis. However, difficulties can still result in attempting to arrive at optimized cooling systems which have an integer number of tube rows. For continuous matrix heat exchangers, the non-integer tube row problem does not exist. However, SOA, PLASTIC, and NH_3 systems investigated employ integer tube row heat exchangers. This is particularly important in the case of SOA systems utilizing two-pass heat exchangers where exchangers of interest are 2, 4, or 6 rows deep, resulting in relatively large discrete changes in the number of tube rows. In single-pass NH_3 systems, the problem is less severe. In PLASTIC systems, the problem is insignificant because exchangers with as many as 30 tube rows are typical.

The BNW-I computer program contains an optimization technique to determine which combination of internal dependent parameters results in the minimum incremental power production costs associated with dry cooling. This optimization technique, developed by Andeen and Glicksman of MIT,⁽⁴⁾ is described in Appendix C.

The input to the program is illustrated in Figure 3-3. General output information is also indicated.




FIGURE 3-3. Dry Cooling System Computer Optimization



4.0 CALCULATIONAL PROCEDURE

The optimization of a dry cooling tower heat rejection system is accomplished by varying five independent variables to obtain the minimum incremental cost. The independent variables are varied according to the optimization routine developed by MIT⁽⁴⁾ and discussed in Section 3 and Appendix C. Once these variables have been determined, the design and costing of the dry cooling tower system is carried from there.

The dry cooling tower code consists of two distinct parts:

- optimization
- design and costing of dry cooling towers.

The two parts of the code interact as shown in Figure 4-1. The optimization part of the code selects the values of the five independent parameters:

1. total frontal area of the heat exchanger - AFRON
2. width/length ratio of the heat exchanger - WLRAT
3. temperature range of water flowing through the heat exchanger - RANGE
4. steam exit temperature of the turbine - T1
5. heat capacity ratio of water to air flowing through the heat exchanger - CWARA

These variables are supplied to the design and costing portion of the code.

4.1 METAL FINNED TUBE (SOA) SYSTEM

The following is a discussion of the calculation procedure used in design and costing of the metal finned tube dry cooling towers. The discussion is subdivided into major categories describing specific calculations dealing with a particular aspect of the design or costing of the dry cooling towers. The subroutine in which a major portion of the computation is carried out is given in parentheses.




FIGURE 4-1. BNW-I Program Flow Diagram

SOA Dry Cooling Tower System Design (CALC)

Given a value for each of the five independent variables, the heat exchanger dimensions are determined by the stepwise calculational procedure shown below.

1. Given the exit temperature of the steam turbine, the turbine back pressure is calculated.
2. The heat rate factor and turbine efficiency is determined at the above back pressure.
3. Knowing the turbine efficiency and plant size, the heat input from the steam supply system and the heat rejected by the dry cooling towers is calculated.
4. The mass flow rate of air and water through the heat exchanger is determined.
5. Heat exchanger effectiveness and number of transfer units (NTU) are determined.
6. Heat exchanger dimensions per foot are calculated.
7. Air-side Reynolds number at the minimum cross-sectional area of the heat exchanger is determined.
8. Air-side friction factor and heat transfer coefficient are found (if Briggs, Robinson and Young's correlations^(5,6) are chosen for use by setting input parameter FFHX equal to FRICH0).
9. Fin efficiency is determined.
10. Heat exchanger width is calculated by one of the following methods, depending on heat exchanger tube length options:
 - a. Length fixed - Width a function of heat exchanger tube length and frontal area (AFRON);

- b. Length allowed to vary - Width a function of the independent parameters of heat exchanger width length ratio (WLRAT) and heat exchanger frontal area (AFRON).

11. Number of tubes in width of the heat exchanger is determined.

START OF LOOP

Calculate Number of Tubes in Depth

12. Reynolds number of water flowing through the tubes is determined.
13. Water-side heat transfer coefficient is calculated.
14. Overall surface efficiency (fin effectiveness consideration) is found.
15. Overall heat transfer coefficient based on the air-side surface area is determined.
16. Number of heat exchanger tubes in depth is calculated.
17. Check if number of tubes in depth have converged.

END OF LOOP

18. Limit the number of tubes in depth to a specified range of values from input to the code (optional).
19. Velocity of the water through the tubes is found.
20. Length of heat exchanger tubes is determined.
21. Water-side friction factor is calculated.
22. Pressure drop through the heat exchanger tubes is determined.
23. Air-side hydraulic diameter is calculated.
24. Air-side friction factor using PFR correlations^(1,8) (if PFR correlations are chosen for use by setting input parameter FFHX equal to PFR) is found.
25. Pressure drop through the heat exchanger is calculated.
26. Heat exchanger costing (Section 4.1.2) is performed.
27. Fan system design and costing (Section 4.1.3) is performed.

29. Piping and pumping system design and costing (Section 4.1.4) is performed.
30. The plant is scaled up to account for off-design conditions, fan and pump power (Section 4.1.5).
31. The following yearly performance parameters of the power plant and dry cooling tower (Section 4.1.6) are calculated:
 - a. turbine outlet temperature
 - b. turbine back pressure
 - c. turbine heat rate factor
 - d. temperature range of water passing through the heat exchanger
 - e. terminal temperature difference of the condenser
 - f. log mean temperature difference of the heat exchanger
 - g. initial temperature difference of the heat exchanger
 - h. power output from the plant to the electrical transmission network
 - i. cost to produce power over the entire range of ambient air temperatures
 - j. total yearly incremental power production cost.
32. Return to optimization procedure subroutine (SHOT, SERCH, or XTEND) which called subroutine CALC.

4.1.1 Condenser Design and Costing

The power plant condenser is a single-pressure surface condenser, designed according to Heat Exchanger Institute standards. The design is based on five parameters:

- temperature of steam exiting the turbine at plant design conditions;
- temperature range of cooling water passing through the condenser;
- temperature difference between water leaving the condenser and steam exiting the turbine;
- tube size; and
- nominal water velocity through the tubes.

The costing of the surface condenser is based on Westinghouse cost data for shells and tubing.⁽²⁾

4.1.1.1 Condenser Design (SPDES)

The surface condenser design is accomplished by calculating the following values in the sequence shown.

1. Initial temperature difference between steam and cooling water entering the condenser
2. Inlet, exit and average temperature of water in the condenser
3. Log mean temperature difference of the condenser

START OF LOOP

Size the Condenser

4. Guess the water velocity through the tubes
5. Overall heat transfer coefficient based on velocity of water through the tubes
6. Surface area per shell
7. Length of flow path per shell
8. Number of passes per shell
9. Tube length to nearest foot
10. Velocity of water through the tubes
11. Check if velocity is close to the previous value

END OF LOOP

12. Number of tubes per shell
13. Total condenser heat transfer area
14. Pressure drop across the condenser.

4.1.1.2 Condenser Costing (SURCON)

The surface condenser is costed by the following calculations performed in sequence:

1. Selection of tubing cost arrays to be used for costing (choice depends upon tubing materials specified)
2. Total length of tubing required
3. Cost discount rate on total amount of tubing based on quantity purchased
4. Tubing length penalty for the length of tube chosen
5. Total cost of the tubing material
6. Shell cost of the condenser
7. Field erection costs
8. Total cost of the condenser.

4.1.2 Heat Exchanger Design and Costing (COSTEX)

The heat exchanger bundle costing is based on the algorithms and cost models given in Reference 2. The cost of the heat exchanger bundle is broken down into several subcomponents:

- header
- tubing
- tubing sealant
- spacers
- bundle frame
- bundle assembly.

The total weight of the heat exchanger bundles consists of the weight of the heat exchanger materials and the water contained inside the tubing and the headers. The cost and weight of the heat exchanger bundles are calculated in the following order:

1. liner tubing costs
2. weight of fins

3. cost of bonding the fins to the tubing
4. protective coating costs
5. cost of the tubing and the fins
6. tubing spacer costs
7. end preparation costs
8. total cost of the cooling surface
9. header and nozzle costs, based on values calculated for
 - a. number of bundles in entire cooling tower system
 - b. number of tubes per bundle
 - c. header depth and width
 - d. header costs.
10. bundle assembly and frame costs
11. weight of heat exchanger bundles, consisting of
 - a. material weight of heat exchanger bundle
 - b. weight of water in heat exchanger bundle
12. total cost of the heat exchanger.

4.1.3 Fan System Selection (FAN)

The selected fan system is that which has the minimum annual capital and energy costs. The type of fan selected is specified in terms of:

- blade diameter
- hub diameter
- number of blades per fan
- blade angle.

Each fan system consists of a number of fans having the same diameter and number of blades. They all operate at the same blade angle. The cost for each fan system investigated is determined.

The number and diameter of circular towers are determined from the total fan swept area, the fan packing factor and the heat exchanger width. Knowing the total cost of the fan system and the circular tower structures, the annual cost of these two components can be determined. On this basis, the optimum fan system is determined.

The fan selection is performed as follows:

1. Determine the volumetric flow rate of the fan system using the mass flow rate of air through the heat exchanger, inlet temperature, and plant site elevation.
2. Choose fan to be analyzed (fan diameter, number of blades, blade angle).
3. Determine number of fans, volumetric flow rate through each fan and total pressure drop across each fan.
4. Determine horsepower required by each fan.
5. Determine number and diameter of towers.
6. Determine fan motor and electrical costs.
7. Calculate capital, stack, and shipping and assembly costs to determine fan system total capital cost.
8. Calculate fan system annual cost (the sum of the annual capital and energy costs).
9. Calculate annual costs for the foundation and structure needed for fans.
10. Total annual cost of the fan and fan system structure and foundation is calculated, then stored or dropped, depending on its value relative to the lowest cost of the previous fans. If the value is lower, the parameters of the fan system are saved.
11. Return to Step 2 and repeat the above process until all desired fan diameters have been investigated.

4.1.4 Piping Design and Cost Algorithm Outline

The piping design and cost algorithm performs two basic functions. First, it calculates the cost of all piping and pumps between the condenser and the heat exchanger bundles. Second, it determines the pressure drop in the piping system so that the total system pumping power requirements can be determined. Figure 4-2 represents a typical piping system layout. For additional details, see Appendix B. The algorithm is outlined on the following pages.




FIGURE 4-2. Typical Piping System Configuration

1. Input:
 - a. total flow of coolant
 - b. design velocity
 - c. number and diameter of circular towers
 - d. distance from condenser to towers
 - e. width of tube bundle
 - f. water-side pressure drop in heat exchanger and condenser.
2. Divide the total flow by the number of towers (bundles) to obtain the flow to each tower.
3. $I = 1$ (I is an index that applies to successive sections of the main supply header).
4. Determine the required diameter of header section 1, based on the coolant flow rate and the coolant design velocity.
5. It is assumed that pipe is available in size increments of six inches. Select DIAMETER (I) from the next largest incremental size.
6. If $I = 1$, go to 9.
7. It has been assumed that reducer prices apply whether the reduction is 6, 12, or 18 inches. This is based on a standard reducer length of two feet and an included angle of $22\ 1/2^\circ$. If DIAMETER (I) is not less than DIAMETER ($I-1$) by the size of the reduction (an input value which can be either 6, 12, or 18 inches) then set DIAMETER (I) equal to DIAMETER ($I-1$). In any other case, DIAMETER (I) = DIAMETER ($I-1$)-the reduction.
8. If a reduction has been made, then determine a reducer cost.
9. Determine the cost of pipe and a tee for header section I .
10. Determine the equivalent length of pipe and the true velocity of flow in header section I .

11. Determine the pressure drop in header section I.
12. Subtract out the flow to one tee branch. Determine the flow remaining in header Section I + 1.
13. If the flow remaining equals zero, go to 15.
14. $I = I + 1$, go to 4.
15. Determine miscellaneous costs of such items as valves, expansion joints, bundle fittings, etc.
16. If the quadrant header has been designed, then go to 19.
17. The quadrant header is designed similarly to the main circulation header. The total number of tube bundles and the flow to each quadrant and to each tube bundle can be determined from the input conditions.
18. Reset the index $I = 1$ and go to 4.
19. Size the tower distribution piping according to the design velocity and the flow to each tower and to each quadrant.
20. The total length of pipe for the four distribution lines between the tower distribution header and each quadrant is assumed to be 3.25 times the tower diameter. Determine the cost of this pipe and all other tower distribution pipe, fittings and valves.
21. Determine the equivalent length and the pressure drop for the tower distribution piping.
22. Determine the equivalent length and the pressure drop for the pump station.
23. Sum the pressure drops for the entire cooling system.
24. Pump station costs are determined from the total flow and the total system dynamic head loss.
25. Sum all costs for the supply and return piping.

4.1.5 Plant Scaling Due to Dry Cooling

4.1.5.1 Steam System Scaling (SSCALE)

The steam supply system of the power plant is scaled up so that the specified power output of the plant will be produced at the rated back pressure of the steam turbine. This accounts for the increased heat rate of the steam turbine being used over that of the reference plants conventional turbine rated at 3.5 in. Hg back pressure. This computation is carried out once for each set of input conditions.

The incremental cost due to scaling up the steam supply system is calculated in the following order:

1. Heat rate factor of the dry cooled plant turbine at rated back pressure
2. Plant cost as a result of steam supply system scale-up
3. Incremental costs of steam supply system due to a change in size of the steam supply system to meet increased steam requirements of the turbine.

4.1.5.2 Plant Scaling (SCALP)

The plant and dry cooling towers are scaled up or down linearly to account for two factors:

- the turbine back pressure at design conditions does not correspond to the rated back pressure of the dry cooled plant turbine, and
- part of the total power output of the dry cooled plant is used to supply the power requirements of the fan and pumping systems.

The following points on the heat rate factor curve are used in describing the scaling of the plant and dry cooling towers (See Figures 3-1 and 3-2). At each of these points, the heat rate factor, plant size and plant costs are determined.

Point 0 - Conventional turbine operating at rated back pressure of 3.5 in. Hg

Point 1 - Steam turbine operating at rated back pressure

Point 2 - Steam turbine operating at system design turbine back pressure with power output of turbine generator equal to the design power output

Point 3 - Steam turbine operating at system design turbine back pressure with the power output of plant equal to the design power output

The difference between Points 2 and 3 is that the plant has been scaled up to accommodate the power requirements of the cooling system fans and pumps. Between Points 1 and 2, the power plant has been scaled up or down to account for an increase or decrease in the heat rate factor.

The curves shown were taken from Reference 1. One is provided to the code as a third-order curve fit depending on which turbine has been selected for use.

Two scaling factors are calculated for use in scaling the plant and dry cooling towers. The purpose of each scaling factor is given separately below:

1. HRFA21 - Scale plant to account for difference in heat rate factor of the turbine at rated back pressure and design back pressure.
2. YFPP1 - Scale plant and dry cooling system to provide power for the dry cooling system fans and pumps at the turbine design back pressure.

The scaling factors are determined in the following sequence of calculations:

1. Scaling factor from Point 1 to Point 2 to account for change in heat rate factor
2. Power output of turbine at rated back pressure (Point 1) giving required power output at the design back pressure (Point 2).

3. Plant cost at design conditions, including the steam supply and plant back pressure scaling to Point 2.
4. Incremental cost of scaling up plant due to increased heat rate factor.
5. Scaling factor for the plant and dry cooling tower to meet pump and fan power requirements.
6. Gross power output of the fully scaled plant when operated at the rated back pressure (Point 1 of Figure 3-1) which meets the power requirements of the fans and pumps and the power output of the plant at the design back pressure (Point 2).
7. Total power output at Point 3.
8. Plant cost at Point 3, excluding the dry cooling tower cost.
9. Incremental cost of plant due to dry cooling if the plant operates at design conditions only.

Having calculated the scaling factor to go from Point 2 to Point 3 (YFPPI), the plant and dry cooling towers are scaled up to meet the increased heat rejection load. This is accomplished in the following sequence of calculations.

1. The following independent parameters are scaled up linearly:
 - a. mass flow rate of water
 - b. mass flow rate of air
 - c. heat exchanger frontal area
 - d. width of the heat exchanger.
2. Design and cost the condenser for increased water flow rate and heat load (Sections 4.1.1 and 4.3.1).
3. Scale the heat exchanger width and number of tubes in width.
4. Scale the fan and pumping system.
5. Scale the heat exchanger weight.

6. Calculate the incremental cost of fuel for the steam supply system due to dry cooling.
7. Scale the land and piping costs.
8. Scale the cost of the tower structure, foundation and plenum.
9. Calculate the hail and louver screen costs.
10. Sum the total capital cost of the dry cooling towers.
11. Calculate the total incremental cost of dry cooling, which is based upon the dry cooled plant operating at design conditions (unused in optimization procedure):
 - a. yearly capital cost of the dry cooling towers^(a)
 - b. yearly maintenance cost of the dry cooling towers^(a)
 - c. incremental cost of plant due to dry cooling tower heat rejection
 - d. yearly capital cost of the piping and pumping system^(a)
 - e. yearly capital cost of the surface condenser^(a)
 - f. incremental cost of fuel for the power plant with a dry cooling tower heat rejection system.

4.1.6 Dry-Cooled Power Plant Performance and Incremental Cost for a Yearly Temperature Profile (NOVART, VARIT)

Subroutine NOVART calculates the performance parameters of the plant and dry cooling towers over a yearly temperature profile. These are, in turn, used to calculate the incremental power production costs of the dry-cooled plant. NOVART is called for each set of independent parameters as NOVART but only for the optimum dry cooling tower design. It provides a printout of performance parameters and incremental costs of the dry-cooled plant.

^(a) Yearly cost for capital is equal to the fixed charge rate times the capital cost.

The performance of the power plant and the dry cooling tower is determined as a function of the yearly temperature profile which is an input to the code. Calculation of plant and dry cooling tower performance is based on no change in air-side velocity through the heat exchanger from the design conditions. Therefore, the air-side heat transfer coefficient is constant.

The calculations are performed in the following sequence:

1. Calculate thermal efficiency of the turbine at the design point of the plant.
2. Calculate thermal efficiency of the turbine at the rated back pressure.

START OF LOOP

Calculate Exit Temperature of Steam Turbine
as a Function of Ambient Air Temperature

3. Guess turbine exit temperature.
4. Calculate thermal efficiency of steam turbine for the specified exit temperature of the turbine.
5. Calculate temperature range of water flowing through the heat exchanger.
6. Calculate terminal temperature difference between the water and the steam entering the surface condenser.
7. Calculate exit temperature of the steam turbine based on the previous estimate.
8. Check if exit temperature has converged.

END OF LOOP

9. Calculate total power output of steam turbine for a particular ambient air temperature.
10. Calculate power output of plant to electrical power transmission network at a particular ambient air temperature.
11. Calculate cost of fuel for gas turbine makeup power at a particular ambient air temperature.

12. Calculate incremental cost of fuel for steam supply system due to steam turbine operating at off-design conditions.
13. Calculate capital cost of gas turbine used for makeup power when ambient air temperature is greater than design air temperature.
14. Calculate incremental cost of producing power at a particular ambient air temperature.
15. Calculate summation of incremental power production costs.

4.2 PLASTIC SYSTEM

The calculational procedure for the plastic tube advanced concept is very similar to that for the SOA system. However, the procedure differs in two areas:

1. calculation of the air-side heat transfer surface area and heat transfer coefficient, and
2. costing of the heat exchanger bundle.

The air-side heat transfer surface area per foot is less complicated to determine for the bare tubes of the PLASTIC concept than for the metal-finned tubes of the SOA system. The air-side heat transfer coefficient for the bare tubes of the PLASTIC system is determined by a set of correlations (Appendix A) taken from the literature. There is a set of correlations for each tube arrangement with each correlation covering a range of Reynolds numbers.

Because the PLASTIC code deals with heat exchangers having bare tubes, the costing algorithm for the heat exchanger differs from the SOA algorithm. The algorithm used for costing the plastic tube heat exchanger bundles is given in Reference 2.

4.3 AMMONIA (NH₃) SYSTEM

The calculational procedure used to design the ammonia cooling system is described here. The procedure begins after choosing five independent parameters by the pattern and gradient search routines developed by MIT⁽⁴⁾ and detailed in Appendix C.

The five independent parameters determining the design of the ammonia cooling system are:

1. saturation temperature of steam leaving the turbine
2. temperature range of the air through the heat exchanger
3. temperature difference between the ammonia and saturated steam in the condenser/reboiler
4. total frontal area of the heat exchanger
5. width/length ratio of the heat exchanger.

NH₃ Dry Cooling Tower System Design (CALC)

All information required by this procedure not provided by the independent parameters is provided by the input (see Section 3.4). The steps of the calculation procedure are outlined below. Figure 4-3 illustrates the procedure in flow diagram form.

1. The heat rejected by the plant is determined by using saturation temperature of the steam leaving the turbine to find the turbine back pressure, which is then used to find the efficiency of the plant. The efficiency is then used along with the plant size to determine the heat rejected by the plant.
2. The properties of air and NH₃ are determined by using the temperature range of the air, the saturation temperature of the steam, and the temperature difference in the condenser/reboiler.
3. Using properties of the air and NH₃, the amount of heat rejected by the plant, and the range of the air, the mass flow rates of NH₃ and air are calculated.
4. The width and length of the heat exchanger are calculated from the frontal area and the width-to-length ratio of the heat exchanger.
5. The design of the condenser/reboiler is performed by using the heat rejected by the plant, the steam temperature, and the temperature difference between the steam and the NH₃ (see Section 4.3.1).




FIGURE 4-3. Subroutine CALC Flow Diagram (Ammonia Version)

6. The tower system design, consisting of the number of towers, the tower diameter, and the tube depth of the heat exchanger is determined by a double iteration loop. This calculation procedure consists of the following steps:
 - (1) Determination of the number of transfer units (NTU) in the heat exchanger using the temperature range of the air, temperature of the ammonia vapor leaving the condenser/reboiler and an estimate of the temperature drop of the NH_3 ammonia in the piping going from the condenser/reboiler to the towers.
 - (2) Calculation of the air-side heat transfer coefficient of the tubes in the heat exchanger from a knowledge of the air mass flow rate, the heat exchanger frontal area, and the tubing unit geometry.
 - (3) The fin and surface efficiency of the heat exchanger tubes is calculated as a function of the air-side heat transfer coefficient.
 - (4) The inside heat transfer coefficient is determined by an iteration loop that finds the depth of the heat exchanger. The following steps are contained in the loop:
 - (i) An estimate of the heat exchanger depth is used to determine the liquid Reynolds number in the tubes, which is then used to find the inside heat transfer coefficient.
 - (ii) The overall heat transfer coefficient is determined from the air-side and inside heat transfer coefficients and the surface efficiency of the outside surface.
 - (iii) Using the number of transfer units (NTUs), the air mass flow rate, and the overall heat transfer coefficient the depth of the heat exchanger is determined. If the depth does not agree with the estimated tube depth in (i), a new depth is estimated and steps (i) through (iii) are performed again.

- (5) Knowing the tube depth of the heat exchanger and the air-side Reynolds number, the pressure drop across the heat exchanger is calculated.
 - (6) The heat exchanger cost is determined from its size (see Section 4.1.2).
 - (7) Using the pressure drop and the frontal area of the heat exchanger, the least costly fan diameter, number of blades, and blade angle are determined. Once the type of fan is chosen, the number of fans and the number and diameter of the towers are calculated. (see Section 4.1.3).
 - (8) Using the number and diameter of the towers, the supply piping is designed and the temperature drop of the NH_3 vapor is determined. (Calculational procedure for the design of the supply piping is similar to the procedure in Section 4.1.4, except NH_3 vapor is the fluid designed for instead of water.)
 - (9) If the temperature drop in Step (8) differs significantly from the temperature drop used in Step (1), the temperature drop of Step (8) is used in Step (1) and the procedure is repeated.
7. After the tower system is known, the return piping is designed and the pressure drop of the ammonia liquid returning from the towers is calculated. (Calculational procedure for the return piping is similar to the procedure in Section 4.1.4, except NH_3 is the liquid being designed for instead of water.)
 8. The pressure drop of the two-phase flow of ammonia in the heat exchanger tubes is calculated.
 9. The pressure drop throughout the entire NH_3 loop is calculated along with the horsepower required for the pump power.
 10. The plant is scaled up to obtain the designated output of the plant including the pump and fan power. Costs of the cooling system are also scaled up (see Section 4.1.5).

11. The incremental cost of operating the power plant with the cooling system over the entire year is calculated (see Section 4.3.2).

4.3.1 Condenser/Reboiler Design and Costing

4.3.1.1 Condenser/Reboiler Design (SPDES)

Subroutine SPDES determines the size of the condenser/reboiler on the basis of:

- the designated temperature difference between the saturated steam and ammonia
- the amount of heat to be transferred
- the temperature of the steam
- the length of the tubes, and
- exit quality of the ammonia leaving the condenser/reboiler tubes.

The design of the condenser/reboiler is done by a double iteration loop using correlations for the steam- and ammonia-side heat transfer coefficients to determine the temperature drops across both fluid boundaries and the average bulk velocity of the ammonia inside the condenser tubes. Once these values are found, the size of the condenser/reboiler is determined along with the system performance parameters.

The condenser/reboiler design is determined in the following sequence:

START OF LOOP I

Determine Average Velocity of NH_3 through
Condenser/Reboiler Tubes

1. Calculate the forced convection coefficient by using a guess for the velocity of ammonia in the tubes.

START OF LOOP II

Determine Temperature Drop across Fluid
Layers and Condenser Tube Wall

- 2.1 Calculate the heat flux through the outside tube wall by estimating the temperature drop on the inside fluid boundary and the forced convection coefficient.
- 2.2 Calculate the temperature drops across the steam condensate and the tube wall by the use of the heat flux through the wall.
- 2.3 Determine the total temperature drop caused by the estimation of the ammonia side temperature drop and then determine a new estimate for the ammonia side temperature drop and return to Step 2.1 until the total temperature drop converges to the desired value.

END OF LOOP II

3. Using the heat flux previously determined a new ammonia velocity is calculated. This new velocity is used in Step 1 and the same steps are repeated from there on until the velocity does not vary from its previous value by a certain percentage.

END OF LOOP I

4. Using the heat flux from Step 3 and the amount of heat transferred through the condenser/reboiler per unit time the outside heat transfer area and the overall, outside, and inside heat transfer coefficients are determined.
5. Using the velocity in the tubes, the pressure drop incurred by the ammonia flowing through the tubes of the condenser/reboiler is calculated.

4.3.1.2 Condenser/Reboiler Costing (SURCON)

Subroutine SURCON costs the components (shell, tubes, accessories) of the condenser/reboiler through a modification of the code for a water-side condenser so that boiling ammonia can be handled on the inside of the tube. The cost of field erection of the condenser/reboiler

is also added into the total cost of the system. The modified code is set up to handle regular condenser tubing and enhanced tubing (enhanced heat transfer).

The calculations performed by subroutine SURCON proceed according to the following sequence:

1. Select tubing cost arrays to be used in costing.
2. Calculate total length of tubing required in the condenser/reboiler.
3. Determine the cost discount rate based on the total amount of tubing.
4. Determine the penalty for the length of tubing chosen.
5. Calculate the total cost of the tubing material.
6. Calculate the shell cost of the condenser/reboiler.
7. Calculate the field erection costs of the condenser/reboiler.
8. Determine the total cost of the condenser/reboiler.

4.3.2 Incremental Cost of the Dry Cooling System for the Power Plant Operating Over the Yearly Temperature Profile (NOVART and VARIT)

The incremental cost of operating a dry cooled plant over the entire year is determined by finding the operating conditions of the plant as a function of a yearly ambient temperature profile for the plant site. The performance of the plant is calculated on the basis of unchanged effectiveness of the tower heat exchanger and overall heat transfer coefficient in the condenser/reboiler.

The two routines proceed in the sequence shown below.

1. Determine the thermal effectiveness for the plant at both the design and rated back pressure of the low-pressure turbine.
2. Select the ambient air temperature at which the plant is operating from an ambient temperature array that approximates the yearly temperature profile at the plant site.
3. Estimate the saturation temperature of the steam in the condenser/reboiler using the ambient temperature.

4. Using the saturation temperature, calculate the turbine back pressure. The back pressure is then used to determine the thermal efficiency of the steam turbine and the amount of heat rejected from the plant.
5. The temperature difference in the condenser/reboiler, the pressure and temperature drops in the supply piping, and the range of the air in the heat exchanger are determined from the amount of heat rejected from the plant.
6. Using the temperature drop in the supply piping, the temperature difference in the condenser/reboiler, the range of the air, and the ambient temperature, a new steam saturation temperature is calculated.
7. If the steam saturation temperature of Step 5 varies from the saturation temperature used in Step 3 by a certain percentage, the new temperature is used as the new estimate for the saturation temperature and the procedure from Step 3 on is repeated.
8. The total power output of the steam turbine, the power output of the plant to the electrical power transmission network, the cost for auxiliary power, the increased fuel cost of the plant, and the capital cost of the auxiliary power are determined for the ambient temperature chosen, given the true saturation temperature.
9. Calculate the incremental cost of operating the power plant with the dry cooling system at the ambient temperature chosen. The cost is then multiplied by the percent of the year that the ambient temperature exists to obtain a portion of the yearly incremental power production cost.
10. Repeating Steps 2 through 9 for an ambient temperature array that approximates the yearly temperature profile of the plant site, a set of incremental power production costs is obtained.
11. Sum the set of incremental power production costs from Step 9 to obtain the incremental power production costs of operating the plant over the entire year.

5.0 COMPUTER PROGRAMS

This section describes the computer programs developed for the three dry cooling tower cost optimizations.

5.1 GENERAL INFORMATION

The dry cooling tower cost optimization models are coded in FORTRAN-IV EXTENDED. They were compiled and executed on a CDC-7600 computer under the SCOPE 2.1.3 System. Central memory requirements (octal words) are approximately 61000 for the PLASTIC tube model, 74000 for the NH₃ model, and 76000 for the SOA metal fin tube model. Execution time ranges from one to sixty or more seconds, depending upon the nearness of starting point to the final conditions and especially upon such factors as the number and severity of the constraints imposed (for example, heat exchanger geometry, turbine outlet temperature, range, number of different fans to be considered). Execution time is strongly affected by the number of different fans to be considered, as specified by the input parameters LFB and LFE (see card type S1 in Input Description). If the model is restricted to fans of only one diameter, execution time may be less than five seconds instead of the forty or more required if all fan diameters are considered.

Particular care should be used to avoid overconstraining the model. Experience has shown that the optimization scheme may fail to converge or may converge to a false minimum if the constraints are too numerous or too severe. Input variables which impose constraints and thus could interfere with optimization are:

- turbine outlet temperature constraints (TLIM, TFIX);
- water range^(a) (RFIX);
- minimum air-side pressure drop (XDEPA);
- heat exchanger depth and length limits (DEEPL, FIXL);
- total number of towers (TOWMAX); and
- the minimum number of towers per group (TOWMIN).

Of these constraints, only XDEPA was present in the optimization routines (SHOT, CHNGE, SERCH, XTEND) in their original form. All other constraints

^(a) does not exist in the ammonia version

have been incorporated in the development of the current code. The subroutines in which these variables are active, and the mechanisms through which they function to impose constraints, are summarized in Table 5-1.

TABLE 5-1. Subroutines Containing Constraint-Imposing Variables

<u>Subroutine</u>	<u>Variable</u>	<u>Mechanism</u>
CALC	DEEPL	Discard current trial point. Return to calling routine and begin new trial
	FIXL	Set length to FIXL instead of calculating it from the width/length ratio
SERCH	TFIX, RFIX	Trial values of turbine temperature or range are set to TFIX or RFIX
	TLIM	Trial values of turbine temperature exceeding TLIM are set equal to TLIM
	XDEPA	If air-side pressure drop is less than XDEPA, call subroutine CHNGE for two-variable search.
SHOT	TFIX, RFIX, TLIM	Same as in subroutine SERCH
	XDEPA	If pressure drop is less than XDEPA, reduce frontal area of heat exchanger
CHNGE	TFIX, RFIX, TLIM	Same as in subroutine SERCH
	XDEPA	Make two-point search by changing a variable different from that being changed by SERCH
XTEND	TFIX, RFIX, TLIM	Same as in subroutine SERCH
	XDEPA	Do not consider this point as a new starting point. Pick another one.
FAN	TOWMAX, TOWMIN	If total number of towers exceeds TOWMAX or if the number of towers per group is less than TOWMIN, reject this trial point by setting incremental cost to unreasonably high value (1×10^{38})

The complex interaction of variables in the system being optimized makes it extremely difficult to predict which constraints are likely to cause problems in any one case. In general, an unconstrained case should be run before any attempt is made to apply constraints.

Formal proof of correctness has not been attempted for the programs described here. However, comparison of computed costs of dry cooling system components with costs reported in the literature shows good agreement. Furthermore, the results of runs covering a range of system designs show no spurious results. In the course of code development, a number of potential problem areas were noted, most of them concerned with failure of the program to recognize physically impossible conditions. Corrective actions and warning messages have been incorporated in all problem areas which were found. As an aid to visualizing the interrelationships among subprograms, subroutine linkage charts in Appendixes E, F, and G indicate which subroutines may call or be called by others.

5.2 INPUT

All input to the programs is by punched cards. Sample input listings are shown in Figures 5-1 through 5-3 for the SOA, PLASTIC and NH₃ systems, respectively. The circled symbols on the figures are used as cross references to corresponding cards in later discussion of input/output.

```

(A1) ***
      ***
      ***
      EXAMPLE RUN - METAL FIN SOA VERSION
(A2)
(B1) 50.      50.      95.      1.      300000.  20.      80.
(C1) 100. 95.  85.  75.  65.  55.  45.  35.  .0015.0100.0285.0822.0913.1096.1119.5650
(C2)
(D1) 1000.    .4      .65      .174     .01      1.      4410.    40.
(E1) 81.      24.      440.     0.      146.65   121000.  30.
(E2) 1.611    1.464    1.614    1.210    1.331    1.210    1.464
(F1) 3.5      1.      -.0049   .002675  -.0001125 MF1
(G1) .85      125.
(H1) 1.      0.      153.     0.      2.      0.      0.      0.
(H2) .90
(I1) 1.74     1.00     7.03     0.00     2.22     2.50     0.55     4.60
(J1) TABLE  2.      12.      1.      5.
(J2) 12.     18.     12.     500.
(K1) 2.572   2.227   2.572   .082     2.572   .018
(L1) 1.00     .930    20.     STEEL WELDED 31.
(M1) DOUBLE FOOTED ALUMINUM 118.
(N1) 0.      0.      .55     .2      2.40
(P1) FORM REMOVABLE GALVANIZED.625
(Q1) 0.      2.      .5      20.     5.625   .48     5.
(R1) 2.      7.      1.      18.     .95     5.      ADMIRALTY
(S1)
(T1) PFR
  
```

FIGURE 5-1. Sample Input for SOA Model

```

(A1) ***
      ***
      ***
      EXAMPLE RUN - PLASTIC TUBE VERSION
(A2)
(B1) 50.0 50.0 1.00 5.0JE05 20.0 80.00
(C1) 100. 95. 85. 75. 65. 55. 45. 35. .0015.0100.0285.0822.0913.1096.1119.5650
(C2)
(D1) 1000. .4 .65 .174 .01 1. 4410. 40.
(E1) 81. 24. 440. 0. 146.65 121000. 30.
(E2) 1.611 1.464 1.614 1.21 1.331 1.21 1.464
(F1) 3.5 1. -.0049 .002675 -.0001125
(G1) 0.85 125.
(H1) 1.0 0.0 153.0 0.0 2.00 0.0
(H2) 0.9
(I1) 1.74 1.0 7.03 0.0 2.22 2.5 .55 4.6
(J1) TABLE 2. 12. 1. 1.5
(J2) 12.00 18. 12. 500.0
(K1) 0.5000 0.43301 0.5000 STAGGERED 2 60.0
(L1) 0.2500 0.2000 20.00 POLYETHYLENE 0.2910
(M1) POLYCARBONATE .25 .25 2.5 .5 .284 .04
(N1) 0.00 0.00 0.40
(P1) FORM REMOVABLE GALVANIZED.625
(Q1) 0.00 0.00 0.050 20.0 5.625 0.000 5.0
(R1) 2.00 7.00 1.00 18.00 0.950 5.00 ADMIRALTY
(S1) 55 88
(U1) $READIN NUCLASE=0 $END

```

FIGURE 5-2. Sample Input for PLASTIC Model

```

(A1) ***
      ***
      ***
      EXAMPLE RUN - AMMONIA VERSION
(A2)
(B1) 50. 50. 105. 3. 300000. 20. 80.0 3.7
(C1) 100. 95. 85. 75. 65. 55. 45. 35. .0015.0100.0285.0822.0913.1096.1119.5650
(C2)
(D1) 1000. .4 .65 .174 .01 1. 4410. 40.
(E1) 81. 24. 440. 0. 146.65 121000. 30.
(E2) 1.611 1.464 1.614 1.210 1.331 1.210 1.464
(F1) 3.5 1. -.0049 .002675 -.0001125
(G1) .85
(H1) 1.0 0. 153. 6. 2.0 6.
(H2) .90
(I1) 1.74 1.0 0.00 1.82 2.22 2.5 .55 4.6
(J1) EQUATION 1. 12. 1. 5. 90.
(J2) 15. 0. 0. 500.
(J3) 150. 0. 0.
(K1) 2.822 2.444 2.822 .082 2.572 .018
(L1) 1. .93 20. STEEL WELDED 31.
(M1) DOUBLE FOOTED ALUMINUM 118.
(N1) 0. 0. .55 .2 2.4
(P1) FORM REMOVABLE GALVANIZED 1.125
(Q1) 0. 2. .5 20. 10.15 .48 5.
(R1) 2. 1. 1. 12. 118. 5. LINDE AL12
(R2) 1. 50. .8
(R3) 1
(S1) 55 88
(T1) PFR

```

FIGURE 5-3. Sample Input for NH₃ Model

5.2.1 SOA Model Input Description

```

C
C           INPUT DESCRIPTION
C           FOR BNWL METAL FIN ROUND DCT
C
C-----*-----*
C*** ** ** **          D E C E M B E R  1 0   1 9 7 6          *-----*-----*
C
C           IN THE DESCRIPTIONS BELOW THE SYMBOL (DF) MEANS
C           DECIMAL FRACTION
C
C-----
C
C
C           T
C           Y
C CARD      NAME OF P
C TYPE COLUMNS  FORMAT  VARIABLE E      DESCRIPTION AND (UNITS)
C-----
C
C  A1      1-80  (8A10)  DESCR(I) R  COMMENTS OR CASE DESCRIPTION TO BE
C                                     PRINTED AT TOP OF FIRST OUTPUT PAGE.
C                                     ANY NUMBER OF TYPE A1 CARDS MAY BE
C                                     USED BUT A BLANK A1 CARD IS NOT
C                                     ALLOWED.
C
C.....
C
C  A2      1-80      BLANK IN ALL COLUMNS.  ONE TYPE A2 CARD ONLY
C
C.....
C.....
C
C  B1      1-10  (E10.0,  TSTAR   R  LOWEST DESIGN TEMPERATURE TO USE
C                                     (DEGREES F)
C
C          11-20  E10.0,  TEND    R  HIGHEST DESIGN TEMPERATURE TO USE
C                                     (DEGREES F)
C
C          21-30  E10.0,  VAS(1)  R  INITIAL VALUE FOR TURBINE OUTLET
C                                     TEMPERATURE (DEGREES F)
C
C          31-40  E10.0,  VAS(3)  R  INITIAL VALUE FOR CWARA, RATIO OF
C                                     MCP WATER / MCP AIR (DF)
C
C          41-50  E10.0,  VAS(4)  R  INITIAL VALUE FOR AFRON, AIR SIDE
C                                     FRONTAL AREA (SQ FT)
C
C          51-60  E10.0,  VAS(5)  R  INITIAL VALUE FOR WLRAT, RATIO OF
C                                     HEAT EXCHANGER WIDTH/LENGTH (DF)
C
C          61-70  E10.0,  FIXL    R  LENGTH OF HEAT EXCHANGER (FT).
C                                     IF THE ABSOLUTE VALUE OF FIXL=0.
C                                     THEN THE PROGRAM WILL CALCULATE
C                                     THE LENGTH.
C
C          71-75  F5.0,  DEEPL   R  LIMITING VALUE FOR NUMBER OF TUBES
C                                     IN DEPTH FOR HEAT EXCHANGER.
C                                     (NUMBER OF TUBES)
C
C
C                                     IF THE ABSOLUTE VALUE OF DEEPL = 0.0
C                                     THEN THE PROGRAM WILL COMPUTE THE

```


DEPTH WITH NO CONSTRAINTS

IF POMDPL IS BLANK OR ZERO THEN A POSITIVE VALUE FOR DEEPL IMPLIES A CONSTRAINT OF EQUAL TO OR GREATER THAN DEEPL, WHILE A NEGATIVE VALUE FOR DEEPL IMPLIES A CONSTRAINT OF EQUAL TO OR LESS THAN DEEPL.

76-80 F5.0) POMDPL R TOLERANCE ON DEEPL. NOTE THAT A ZERO OR BLANK IS NOT INTERPRETED AS ZERO TOLERANCE. (SEE DEFINITION OF DEEPL)

C.....
C.....

C1 1-40 (8F5.0) TA(I) R TEMPERATURES REPRESENTATIVE OF TPER(I) FRACTION OF YEAR (DEGREES F) C A U T I O N - HIGHEST TA MUST BE FIRST

41-80 8F5.0) TPER(I) R FRACTION OF YEAR OVER WHICH TEMPERATURE TA(I) IS TYPICAL. (DF)

C.....

C2 1-40 (8F5.0) TA(I) R CONTINUATION OF TA(I) FOR I= 9 TO 16

41-80 8F5.0) TPER(I) R CONTINUATION OF TPER(I)

NOTE - A TYPE C2 CARD IS REQUIRED EVEN IF BLANK.

C.....
C.....

D1 1-10 (E10.0) PSIZE R BASE PLANT SIZE (MEGAWATTS)

11-20 E10.0) TEFF R BASE THERMAL EFFICIENCY (DF)

21-30 E10.0) CAPF R CAPACITY FACTOR (DF)

31-40 E10.0) FCR R FIXED CHARGE RATE (DF)

41-50 E10.0) PER R RATIO MAINTENANCE COST TO CAPITAL COST (DF)

51-60 E10.0) CCM R CONSTRUCTION COST MULTIPLIER (DF)

61-70 E10.0) ELEV R SITE ELEVATION ABOVE SEA LEVEL (FT)

71-80 E10.0) ROOFL R ROOF LOAD (LB/SQ FT)

C.....
C.....

E1 1-10 (E10.0) FCOS R FUEL COST (CENTS/MMBTU)

11-20 E10.0) PWCOS R REPLACEMENT POWER COST (MILLS/KWH)

21-30 E10.0) PLANC R POWER PLANT CONSTRUCTION COST (\$/KW)

C	31-40	E10.0,	COSTL	R	COST OF LAND (\$/SQ FT)	
C	41-50	E10.0,	CSSPKW	R	COST OF STEAM SUPPLY (\$/KW)	
C	51-60	E10.0,	CAPCHG	R	CAPACITY CHARGE (\$/MEGAWATT)	
C	61-70	E10.0,	HPCST	R	COST OF ELECTRIC MOTORS (\$/HP)	
C	71-80	E10.0)	CTURB	R	EXTRA TURBINE COST BECAUSE OF NUCLEAR POWER PLANT (\$/KW)	
C					
C	E2	1-10	(E10.0,	POHBAF	R	INDIRECT COST FACTORS FOR - BUNDLE ASSEMBLE AND FRAME
C		11-20	E10.0,	POHFAN	R	FANS
C		21-30	E10.0,	POHLEC	R	ELECTRICAL
C		31-40	E10.0,	POHCIR	R	CIRCULATION PIPING
C		41-50	E10.0,	POHCND	R	CONDENSER
C		51-60	E10.0,	POHSTC	R	STRUCTURE
C		61-70	E10.0)	POHSCL	R	SCREENS AND LOUVERS
C					
C	F1	1-10	(F10.0,	RBP	R	TURBINE RATING BACK PRESSURE (INCHES OF MERCURY)
C		11-70	4F15.3)	TPO(1)	R	COEFFICIENTS FOR THIRD ORDER POLY- NOMIAL FOR HEAT RATE AS A FUNCTION OF TURBINE BACK PRESSURE.
C					
C	G1	1-10	(E10.0,	EFFP	R	EFFICIENCY OF PUMPS (DF)
C		11-20	E10.0)	DPRESS	R	PIPING DESIGN PRESSURE (PSI)
C					MAY BE	
C					50.	
C					75.	
C					125.	
C					
C	H1	1-10	(E10.0,	VELREC	R	CONTROL VARIABLE. =1 FOR VELOCITY RECOVERY =0 FOR NO VELOCITY RECOVERY
C		11-20	E10.0,	XDEPA	R	MINIMUM AIR SIDE PRESSURE DROP THRU HEAT EXCHANGER (LB FORCE/SQ FT)
C		21-30	E10.0,	TLIM	R	MAXIMUM STEAM TEMPERATURE FOR THE TURBINE (DEGREES F).

	41-50	F10.0,	NTUB	R	NUMBER OF TUBES THRU PLATE FINS
	51-60	F10.0)	SS	R	SUPPORT SPACING (FT)
C.....					
J2	1-10	(E10.0,	DESVEL	R	DESIGN WATER VELOCITY FOR PIPING (FT/SEC)
	11-20	E10.0,	REDUCE	R	MINIMUM STEP CHANGE IN PIPE DIAMETER FOR TOWER PIPING (INCHES) MAY BE 6, 12, OR 18
	21-30	E10.0,	QREDUCE	R	MINIMUM STEP CHANGE IN PIPE DIAMETER FOR QUADRANT HEADERING . (INCHES) MAY BE 6, 12, OR 18
	31-40	E10.0)	DIST	R	DISTANCE FROM TOWER TO CONDENSER ROOM (FT)
C.....					
C.....					
K1	1-10	(E10.0,	XW	R	TUBE TRANSVERSE PITCH (NORMAL TO AIR FLOW) (INCHES)
	11-20	E10.0,	XD	R	TUBE PITCH IN DIRECTION OF AIR FLOW (INCHES)
	21-30	E10.0,	XDG	R	TUBE DIAGONAL PITCH (INCHES)
	31-40	E10.0,	SF	R	FIN SPACING (INCHES)
	41-50	E10.0,	DFIN	R	FIN DIAMETER (INCH(S)
	51-60	E10.0,	THFIN	R	FIN THICKNESS (INCHES)
	61-70	E10.0)	DANGLE	R	BASE ANGLE FOR DELTA HEAT EXCHANGER (DEGREES)
C.....					
C.....					
L1	1-10	(F10.0,	ODL	R	HX LINER OUTSIDE DIAMETER (INCHES)
	11-20	F10.0,	DI	R	HX LINER INSIDE DIAMETER (INCHES)
	21-30	F10.0,	GAGLIN	R	GAGE OF HX LINER TUBE (MAY BE 22. 20. 19. 18. 17. 16. 15. 14.5 14. 13. 12. 11. 10.)
	31-50	2A10,	TUBMAT, XTUBMA	R R	LINER MATERIAL. MUST BEGIN IN COL 31
MAY BE -					
ADMIRALTY					
COPPER					
CU-10 NI					
CU-30 NI					

ALUMINUM
 STEEL WELDED
 STEEL SEAMLESS
 WELDED SST

51-60 F10.0) CONL R THERMAL CONDUCTIVITY OF LINER MATERIAL (BTU/(HR SQFT DEG F/ FT))

M1 1-20 (2A10, FINTYP, XFINTY R TYPE OF FIN. MUST START IN COLUMN 1

MAY BE -
 STRAIGHT FIN
 SINGLE FOOT
 DOUBLE FOOT
 EMBEDDED
 EXTRUDED
 PLATE

21-30 A10, FINMAT R FIN MATERIAL. MUST START IN COL. 21

MAY BE -
 ALUMINUM
 STEEL

31-40 F10.0) CONF R THERMAL CONDUCTIVITY OF FIN MATERIAL (BTU/(HR SQFT DEG F/FT))

M1 1-10 (E10.0, CFB R FIN BONDING COST (\$/SQ FT)

11-20 E10.0, COATC R FIN PROTECTIVE COATING COST (\$/SQFT)

21-30 E10.0, ZINCC R ZINC COST FOR SPACERS (\$/LB)

31-40 E10.0, CASTC R FIXED CASTING COST FOR SPACERS (\$/SPACER)

41-50 E10.0) EPREPC R END PREPARATION COST (\$/TUBE)

P1 1-20 (2A10, HEDTYP, XHEDTY R HEADER TYPE. MUST START IN COLUMN 1.

MAY BE -
 WELD REMOVABLE
 WELD PLUG
 FORM REMOVABLE
 FORM PLUG

21-30 A10, HEDMAT R HEADER MATERIAL. MUST START IN COLUMN 21. MAY BE -

ALUMINUM

STEEL
GALVANIZED

	31-40	E10.0)	TW	R	THICKNESS OF HEADER MATERIAL, INCHES
				
G1	1-10	(E10.0,	CRJ	R	COST OF ROLLED JOINT, TUBE TO HEADER (\$/TUBE)
	11-20	E10.0,	CWJ	R	COST OF WELDED JOINT, TUBE TO HEADER (\$/TUBE)
	21-30	E10.0,	CHH	R	TUBE AND PLUG HOLE PREPARATION COST (\$/HOLE)
	31-40	E10.0,	CN	R	NOZZEL AND ATTACHING COST (\$/HOLE)
	41-50	E10.0,	CMW	R	COST OF HEADER MACHINING AND WELDING (\$/FT)
	51-60	E10.0,	CST	R	STRUCTURAL STEEL COST (\$/LB)
	61-70	E10.0)	CBJ	R	COST OF BOLTED HEADER JOINT (\$/FT)
				
R1	1-10	(E10.0,	XNS	R	NUMBER OF CONDENSER SHELLS
	11-20	E10.0,	VELN	R	NOMINAL DESIGN VELOCITY THRU CONDENSER TUBES (FT/SEC)
	21-30	E10.0,	GDC	R	CONDENSER TUBE O.D. (INCHES)
	31-40	E10.0,	GA	R	CONDENSER TUBE WALL GAGE. MAY BE 12. 14. 16. 18. 20. 22. 24.
	41-50	E10.0,	FC	R	CLEANLINESS FACTOR (DF)
	51-60	E10.0,	TTD	R	TERMINAL TEMPERATURE DIFFERENCE (DEGREES F)
	61-80	2A10)	CONMAT, CONMA2	R R	CONDENSER TUBING MATERIAL. MUST START IN COLUMN 61. MAY BE - ADMIRALTY CU-10 NI 304 S/S WELDED
				
S1	1-5	(I5,	LFB	I	LFB AND LFE SPECIFY FIRST AND LAST POSITION TO BE CONSIDERED IN THE TABLE OF FANS. DEFAULT VALUES ARE LFB=1 AND LFE=133
	6-10	I5,	LFE	I	

5.2.2 Plastic Model Input Description

```

C
C          I N P U T   D E S C R I P T I O N
C
C          F O R   B N W I   P L A S T I C   C I R C U L A R   T O W E R
C
C  *--*--*--*--*--*
C          D E C E M B E R   1 0   1 9 7 5
C          *--*--*--*--*
C
C          *   I N   T H E   D E S C R I P T I O N S   B E L O W   T H E   S Y M B O L   ( D F )   M E A N S
C          D E C I M A L   F R A C T I O N
C
C
C          -----
C
C          T
C          Y
C  C A R D          N A M E   O F   P
C  T Y P E  C O L U M N S  F O R M A T  V A R I A B L E  E          D E S C R I P T I O N   A N D   ( U N I T S )
C          -----
C
C  A 1      1-80   (8A10)   D E S C R ( 1 )  R   C O M M E N T S   O R   C A S E   D E S C R I P T I O N   T O   B E
C
C          P R I N T E D   A T   T O P   O F   F I R S T   O U T P U T   P A G E .
C
C          A N Y   N U M B E R   O F   T Y P E   A 1   C A R D S   M A Y   B E
C
C          U S E D   B U T   A   B L A N K   A 1   C A R D   I S   N O T
C
C          A L L O W E D .
C
C
C  .....
C  .....
C
C  A 2      1-80          B L A N K   I N   A L L   C O L U M N S .   O N E   T Y P E   A 2   C A R D   O N L Y
C
C  .....
C  .....
C
C  B 1      1-10   (E10.0,  T S T A R      R   L O W E S T   D E S I G N   T E M P E R A T U R E   T O   U S E
C
C          ( D E G R E E S   F )
C
C          11-20   E 10.0,  T E N D      R   H I G H E S T   D E S I G N   T E M P E R A T U R E   T O   U S E
C
C          ( D E G R E E S   F )
C
C          21-30   E 10.0,  V A S ( 1 )  R   I N I T I A L   V A L U E   F O R   T U R B I N E   O U T L E T
C
C          T E M P E R A T U R E   ( D E G R E E S   F )
C
C          31-40   E 10.0,  V A S ( 3 )  R   I N I T I A L   V A L U E   F O R   C W A R A ,   R A T I O   O F
C
C          M C P   W A T E R   /   M C P   A I R   ( D F )
C
C          41-50   E 10.0,  V A S ( 4 )  R   I N I T I A L   V A L U E   F O R   A F R O N ,   A I R   S I D E
C
C          F R O N T A L   A R E A   ( S Q   F T )
C
C          51-60   E 10.0,  V A S ( 5 )  R   I N I T I A L   V A L U E   F O R   W L R A T ,   R A T I O   O F
C
C          H E A T   E X C H A N G E R   W I D T H / L E N G T H   ( D F )
C
C          61-70   E 10.0,  F I X L      R   L E N G T H   O F   H E A T   E X C H A N G E R   ( F T ) .
C
C          I F   T H E   A B S O L U T E   V A L U E   O F   F I X L = 0 .
C
C          T H E N   T H E   P R O G R A M   W I L L   C A L C U L A T E
C
C          T H E   L E N G T H .
C
C          71-80   E 10.0)  D E E P L     R   L I M I T I N G   V A L U E   F O R   N U M B E R   O F   T U B E S
C
C          ( N U M B E R   O F   T U B E S )
C
C
C          I F   T H E   A B S O L U T E   V A L U E   O F   D E E P L = 0 . 0
C
C          T H E N   T H E   P R O G R A M   W I L L   C O M P U T E   T H E
C
C          D E P T H   W I T H   N O   C O N S T R A I N T S
C

```


C					INDIRECT COST FACTORS FOR -
C	E2	1-10	(E10.0)	POHBAF	R BUNDLE ASSEMBLE AND FRAME
C		11-20	E10.0)	POHFAN	R FANS
C		21-30	E10.0	POHLEC	R ELECTRICAL
C		31-40	E10.0	POHCIR	R CIRCULATION PIPING
C		41-50	E10.0	POHCND	R CONDENSER
C		51-60	E10.0)	POHSTC	R STRUCTURE
C		51-70	E10.0)	POHSCL	R SCREENS AND LOUVERS
C					
C					
C	F1	1-10	(F10.0)	RBP	R TURBINE RATING BACK PRESSURE (INCHES OF MERCURY)
C		11-70	4F15.8)	TPO(I)	R COEFFICIENTS FOR THIRD ORDER POLYNOMIAL FOR HEAT RATE AS A FUNCTION OF TURBINE BACK PRESSURE.
C					
C					
C	G1	1-10	(E10.0)	EFFP	R EFFICIENCY OF PUMPS (DF)
C		11-20	E10.0)	DPRESS	R PIPING DESIGN PRESSURE (PSI) MAY BE 50. 70. 125.
C					
C					
C					
C					
C					
C	H1	1-10	(E10.0)	VELREC	R CONTROL VARIABLE. =1 FOR VELOCITY RECOVERY =0 FOR NO VELOCITY RECOVERY
C		11-20	E10.0)	XDEPA	R MINIMUM AIR SIDE PRESSURE DROP THRU HEAT EXCHANGER (LB FORCE/SQ FT)
C		21-30	E10.0)	TLIM	R MAXIMUM STEAM TEMPERATURE FOR THE TURBINE (DEGREES F). ASSUMED 180 IF FIELD IS BLANK OR 0.
C		31-40	E10.0)	TOWMIN	R THE MINIMUM ALLOWABLE NUMBER OF TOWERS PER GROUP. ASSUMED 1 IF NOT SPECIFIED
C		41-50	E10.0)	PFACT	R PACKING FACTOR, RATIO OF CIRCULAR TOWER ROOF AREA TO FAN SWEEP AREA (DF)
C		51-60	E10.0)	TFIX	R FIXED TURBINE OUTLET TEMPERATURE (F)

```

C
C
C
C      61-70   E10.0,  RFIX   R  FIXED RANGE (F).  ENTRY IS IGNORED
C                                     IF BLANK OR ZERO
C
C      71-80   E10.0)  TOWMAX R  MAXIMUM ALLOWABLE NUMBER OF TOWERS.
C                                     ASSUMED 9999 IF BLANK OR ZERO
C
C
C.....
C.....
C
C  H2      1-10   E10.0   GBEFF   R  FAN GEARBOX EFFICIENCY
C
C.....
C.....
C
C  I1      1-10   (E10.0,  CPM     R  PLENUM COST ($/LB)
C
C      11-20   E10.0,  WPL     R  WEIGHT OF PLENUM MATERIAL (LB/SQ FT)
C
C      21-30   E10.0,  CLUVR   R  COST OF LOUVERS ($/SQ FT)
C
C      31-40   E10.0,  CHAILS  R  COST OF HAIL SCREENS ($/SQ FT)
C
C      41-50   E10.0,  UCS     R  UNIT COST OF STACK $/LB
C
C      51-60   E10.0,  UWS     R  UNIT WT OF STACK LB/CU FT
C
C      61-70   E10.0,  CVM     R  FAN RING MATERIAL UNIT COST $/LB
C
C      71-80   E10.0)  WFV     R  UNIT WT OF STRAIGHT CYLINDER LB/SQ FT
C
C
C.....
C.....
C
C  J1      1-20   (2A10,  NTUCAL  I  CONTROL VARIABLE FOR SPECIFYING THE
C                                     METHOD TO BE USED TO CALCULATE NTU.
C                                     NTUCAL MUST BEGIN IN COLUMN 1.
C                                     CROSS-FLOW
C                                     COUNTER FLOW
C                                     TABLE
C
C                                     CROSS FLOW OR COUNTER FLOW CAUSES
C                                     CALCULATION OF NTU BY EQUATIONS.
C                                     TABLE CAUSES TABLE LOOKUP OF NTU.
C
C      21-30   F10.0,  HXNP    R  NUMBER OF PASSES THRU HEAT EXCHANGER
C
C      31-40   F10.0,  WB      R  HEADER LENGTH (FEET)
C
C      41-50   F10.0,  NTUB    R  NUMBER OF TUBES THRU PLATE FINS
C
C      51-60   F10.0)  SS      R  SUPPORT SPACING (FT)
C
C.....
C.....
C
C      71-80   (E10.0,  DESVEL  R  DESIGN WATER VELOCITY FOR PIPING
C                                     (FT/SEC)

```

	11-20	E10.0,	REDUCE	R	MINIMUM STEP CHANGE IN PIPE DIAMETER FOR TOWER PIPING (INCHES) MAY BE 6, 12, OR 18
	21-30	E10.0,	QREDUCE	R	MINIMUM STEP CHANGE IN PIPE DIAMETER FOR QUADRANT HEADERING. (INCHES) MAY BE 6, 12, OR 18
	31-40	E10.0)	DIST	R	DISTANCE FROM TOWER TO CONDENSER ROOM (FT)
				
				
K1	1-10	(F10.0,	XW	R	TUBE TRANSVERSE PITCH (NORMAL TO AIR FLOW) (INCHES)
	11-20	F10.0,	XD	R	TUBE PITCH IN DIRECTION OF AIR FLOW (INCHES)
	21-30	F10.0,	XDG	R	TUBE DIAGONAL PITCH (INCHES)
	31-40	A10,	TUBARG	R	TUBE ARRANGEMENT. MUST BEGIN IN COLUMN 1. MAY BE- STAGGERED INLINE ASSUMED TO BE STAGGERED IF OMITTED
	41-50	A10,	HCCALC	R	CONTROL VARIABLE TO SELECT METHOD TO BE USED IN CALCULATING FRICTION FACTOR AND HEAT TRANSFER COEFFICIENT FOR AIR FLOWING ACROSS STAGGERED TUBES. MAY BE 1 OR 2 (ASSUMED 2 IF BLANK) HCCALC=1 SPECIFIES MCADAMS RELATIONSHIP FOR HEAT TRFR AND FOR FRICTION FACTOR HCCALC=2 SPECIFIES MCADAMS RELATIONSHIP FOR FRICTION FACTOR AND ZUKAUSKAS RELATIONSHIP FOR HEAT TRANSFER COEFF. HCCALC IS IGNORED IF TUBARG = INLINE
	51-60	F10.0)	DANGLE	R	BASE ANGLE FOR DELTA HEAT EXCHANGER (DEGREES)
				
				
L1	1-10	(F10.0,	ODL	R	HX LINER OUTSIDE DIAMETER (INCHES)
	11-20	F10.0,	DI	R	HX LINER INSIDE DIAMETER (INCHES)
	21-30	F10.0,	GAGLIN	R	GAGE OF HX LINER TUBE (MAY BE 22. 20. 19. 18. 17. 16. 15. 14.5 14. 13. 12. 11. 10.)


```

C.....
C
C  Q1    1-10  (E10.0,  CRJ    R  COST OF ROLLED JOINT, TUBE TO HEADER
C                                     ($/TUBE)
C
C      11-20  E10.0,  CWJ    R  COST OF WELDED JOINT, TUBE TO HEADER
C                                     ($/TUBE)
C
C      21-30  E10.0,  CHH    R  TUBE AND PLUG HOLE PREPARATION COST
C                                     ($/HOLE)
C
C      31-40  E10.0,  CN     R  NOZZEL AND ATTACHING COST ($/HOLE)
C
C      41-50  E10.0,  CMW    R  COST. OF HEADER MACHINING AND WELDING
C                                     ($/FT)
C
C      51-60  E10.0,  CST    R  STRUCTURAL STEEL COST ($/LB)
C
C      61-70  E10.0)  CBU    R  COST OF BOLTED HEADER JOINT ($/FT)

```

```

C.....
C.....
C
C  R1    1-10  (E10.0,  XNS    R  NUMBER OF CONDENSER SHELLS
C
C      11-20  E10.0,  VELN   R  NOMINAL DESIGN VELOCITY THRU CONDENSER
C                                     TUBES (FT/SEC)
C
C      21-30  E10.0,  ODC    R  CONDENSER TUBE O.D. (INCHES)
C
C      31-40  E10.0,  GA     R  CONDENSER TUBE WALL GAGE. MAY BE
C                                     12. 14. 16. 18. 20. 22. 24.
C
C      41-50  E10.0,  FC     R  CLEANLINESS FACTOR (DF)
C
C      51-60  E10.0,  TTD    R  TERMINAL TEMPERATURE DIFFERENCE
C                                     (DEGREES F)
C
C      61-80  2A10)  CONMAT, R          CONDENSER TUBING MATER-
C                                     CONMA2 R          IAL. MUST START IN
C                                     COLUMN 61. MAY BE -
C
C                                     ADMIRALTY
C                                     CU-10 NI
C                                     304 S/S WELDED

```

```

C.....
C.....
C
C  S1    1-5    (15,    LFB    I  LFB AND LFE SPECIFY FIRST AND LAST
C      6-10    15,    LFE    I  POSITION TO BE CONSIDERED IN THE
C                                     TABLE OF FANS. DEFAULT VALUES ARE
C                                     LFB=1 AND LFE=153

```

DIAMETER	IFAN	LFAN
24.	1	27
26.	28	54
28.	55	88

5.2.3 NH₃ Model Input Description

```

C          INPUT DESCRIPTION
C          FOR BNWL METAL FIN ROUND DCT AMMONIA
C          DECEMBER 10 1976          *-*-*-*-*
C
C          *** **
C          IN THE DESCRIPTIONS BELOW THE SYMBOL (DF) MEANS
C          DECIMAL FRACTION
C
C          -----
C          CARD          NAME OF P
C          TYPE COLUMNS  FORMAT  VARIABLE E      DESCRIPTION AND (UNITS)
C          -----
C          A1      1-80  (8A10  DESCR(I) R  COMMENTS OR CASE DESCRIPTION TO BE
C          PRINTED AT TOP OF FIRST OUTPUT PAGE.
C          ANY NUMBER OF TYPE A1 CARDS MAY BE
C          USED BUT A BLANK A1 CARD IS NOT
C          ALLOWED.
C          .....
C          A2      1-80  BLANK IN ALL COLUMNS. ONE TYPE A2 CARD ONLY
C          .....
C          .....
C          B1      1-10  (E10.0, TSTAR   R  LOWEST DESIGN TEMPERATURE TO USE
C          (DEGREES F)
C          11-20  E10.0, TEND     R  HIGHEST DESIGN TEMPERATURE TO USE
C          (DEGREES F)
C          21-30  E10.0, VAS(1)   R  INITIAL VALUE FOR TURBINE OUTLET
C          TEMPERATURE (DEGREES F)
C          31-40  E10.0, VAS(3)   R  INITIAL VALUE FOR TTD1, TERMINAL
C          TEMPERATURE DIFFERENCE (DEGREES F)
C          41-50  E10.0, VAS(4)   R  INITIAL VALUE FOR AFRON, AIR SIDE
C          FRONTAL AREA (SQ FT)
C          51-60  E10.0, VAS(5)   R  INITIAL VALUE FOR wLRAT, RATIO OF
C          HEAT EXCHANGER WIDTH/LENGTH (DF)
C          61-70  E10.0, FIXL     R  LENGTH OF HEAT EXCHANGER (FT).
C          IF THE ABSOLUTE VALUE OF FIXL=0.
C          THEN THE PROGRAM WILL CALCULATE
C          THE LENGTH.
C          71-75  F5.0,  DEEPL    R  LIMITING VALUE FOR NUMBER OF TUBES
C          IN DEPTH FOR HEAT EXCHANGER.
C          (NUMBER OF TUBES)
C

```


IF THE ABSOLUTE VALUE OF DEEPL = 0.0
 THEN THE PROGRAM WILL COMPUTE THE
 DEPTH WITH NO CONSTRAINTS

IF POMDPL IS BLANK OR ZERO THEN A
 POSITIVE VALUE FOR DEEPL IMPLIES A
 CONSTRAINT OF EQUAL TO OR GREATER
 THAN DEEPL, WHILE A NEGATIVE VALUE
 FOR DEEPL IMPLIES A CONSTRAINT OF
 EQUAL TO OR LESS THAN DEEPL.

76-80 F5.0) POMDPL R TOLERANCE ON DEEPL. NOTE THAT A ZERO
 OR BLANK IS NOT INTERPRETED AS ZERO
 TOLERANCE. (SEE DEFINITION OF DEEPL)

C1 1-40 (8F5.0, TA(I) R TEMPERATURES REPRESENTATIVE OF
 TPER(I) FRACTION OF YEAR (DEGREES F)

41-80 8F5.0) TPER(I) R FRACTION OF YEAR OVER WHICH TEMPERA-
 TURE TA(I) IS TYPICAL. (DF)
 C A U T I O N - HIGHEST TA
 MUST BE FIRST

C2 1-40 (8F5.0, TA(I) R CONTINUATION OF TA(I) FOR I= 9 TO 16

41-80 8F5.0) TPER(I) R CONTINUATION OF TPER(I)

NOTE - A TYPE C2 CARD IS REQUIRED EVEN IF BLANK.

D1 4-10 (E10.0, PSIZE R BASE PLANT SIZE (MEGAWATTS)

11-20 E10.0, TEFF R BASE THERMAL EFFICIENCY (DF)

21-30 E10.0, CAPF R CAPACITY FACTOR (DF)

31-40 E10.0, FCR R FIXED CHARGE RATE (DF)

41-50 E10.0, PER R RATIO MAINTENANCE COST TO CAPITAL
 COST (DF)

51-60 E10.0, CCY R CONSTRUCTION COST MULTIPLIER (DF)

61-70 E10.0, ELEV R SI E ELEVATION ABOVE SEA LEVEL (FT)

71-80 E10.0) ROOFL R ROOF LOAD (LB/SQ FT)

E1 1-10 (E10.0, FCOS R FUEL COST (CENTS/MMBTU)

11-20 E10.0, PWCOS R REPLACEMENT POWER COST (MILLS/KWH)

	21-30	E10.0,	PLANC	R	POWER PLANT CONSTRUCTION COST (\$/KW)
	31-40	E10.0,	COSTL	R	COST OF LAND (\$/SQ FT)
	41-50	E10.0,	CSSPKW	R	COST OF STEAM SUPPLY (\$/KW)
	51-60	E10.0,	CAPCHG	R	CAPACITY CHARGE (\$/MEGAWATT)
	61-79	E10.0,	HPCST	R	COST OF ELECTRIC MOTORS (\$/HP)
	71-80	E10.0)	CTURB	R	ADDITIONAL TURBINE COST BECAUSE OF NUCLEAR POWER PLANT (\$/KW)
.....					
					INDIRECT COST FACTORS FOR -
E2	1-10	(E10.0,	POHBAF	R	BUNDLE ASSEMBLE AND FRAME
	11-20	E10.0,	POHFAN	R	FANS
	21-30	E10.0	POHLEC	R	ELECTRICAL
	31-40	E10.0	POHCIR	R	CIRCULATION PIPING
	41-50	E10.0	POHCND	R	CONDENSER
	51-60	E10.0,	POHSTC	R	STRUCTURE
	61-70	E10.0)	POHSCL	R	SCREENS AND LOUVERS
.....					
F1	1-10	(F10.0,	RBP	R	TURBINE RATING BACK PRESSURE (INCHES OF MERCURY)
	11-70	4F15.3)	TPO(I)	R	COEFFICIENTS FOR THIRD ORDER POLYNOMIAL FOR HEAT RATE AS A FUNCTION OF TURBINE BACK PRESSURE.
.....					
G1	1-10	E10.0	EFFP	R	EFFICIENCY OF PUMPS (DF)
.....					
H1	1-10	(E10.0,	VELREC	R	CONTROL VARIABLE. =1 FOR VELOCITY RECOVERY =0 FOR NO VELOCITY RECOVERY
	11-20	E10.0,	XDEPA	R	MINIMUM AIR SIDE PRESSURE DROP THRU HEAT EXCHANGER (LB FORCE/SQ FT)
	21-30	E10.0,	TLIM	R	MAXIMUM STEAM TEMPERATURE FOR THE TURBINE (DEGREES F). ASSUMED 180 IF FIELD IS BLANK OR 0.
	31-40	E10.0,	TOWMIN	R	THE MINIMUM ALLOWABLE NUMBER OF


```

C .....
C
C J2   1-10 (F10.0, DESVEL R DESIGN VELOCITY (LIQUID) FOR PIPING
C                               (FT/SEC)
C
C       11-20 F10.0, REDUCE R MINIMUM STEP CHANGE IN PIPE DIAMETER
C                               FOR LIQUID PHASE TOWER PIPING (INCH-
C                               ES)
C                               MAY BE 6, 12, OR 18
C
C       21-30 F10.0, QREDUCE R MINIMUM STEP CHANGE IN PIPE DIAMETER
C                               FOR LIQUID PHASE QUADRANT HEADERING
C                               (INCHES)
C                               MAY BE 6, 12, OR 18
C
C       31-40 F10.0) DIST R DISTANCE FROM TOWER TO CONDENSER
C                               ROOM (FT)
C .....
C
C J3   1-10 (F10.0, DESVELV R DESIGN VELOCITY (VAPOR) FOR PIPING.
C                               (FT/SEC)
C
C       11-20 F10.0, REDUCEV R MINIMUM STEP CHANGE IN PIPE DIAMETER
C                               FOR VAPOR PHASE TOWER PIPING
C                               (INCHES)
C                               MAY BE 6, 12, OR 18
C
C       21-30 F10.0) QREDUCV R MINIMUM STEP CHANGE IN PIPE DIAMETER
C                               FOR VAPOR PHASE QUADRANT HEADERING
C                               (INCHES)
C                               MAY BE 6, 12, OR 18
C .....
C .....
C
C K1   1-10 (E10.0, XW R TUBE TRANSVERSE PITCH (NORMAL TO AIR
C                               FLOW) (INCHES)
C
C       11-20 E10.0, XD R TUBE PITCH IN DIRECTION OF AIR FLOW
C                               (INCHES)
C
C       21-30 E10.0, XDG R TUBE DIAGONAL PITCH (INCHES)
C
C       31-40 E10.0, SF R FIN SPACING (INCHES)
C
C       41-50 E10.0, DFIN R FIN DIAMETER (INCHES)
C
C       51-60 E10.0, THFIN R FIN THICKNESS (INCHES)
C
C       61-70 E10.0) DANGLE R BASE ANGLE FOR DELTA HEAT EXCHANGER
C                               (DEGREES)
C .....
C .....
C
C L1   1-10 (F10.0, ODL R HX LINER OUTSIDE DIAMETER (INCHES)
C       11-20 F10.0, DI R HX LINER INSIDE DIAMETER (INCHES)
C
C       21-30 F10.0, GAGLIN R GAGE OF HX LINER TUBE (MAY BE

```



```

C .....
C P1 1-20 (2A10, HEDTYP, R HEADER TYPE. MUST START IN COLUMN 1.
C XHEDTY R MAY BE -
C WELD REMOVABLE
C WELD PLUG
C FORM REMOVABLE
C FORM PLUG
C
C 21-30 A10, HEDMAT R HEADER MATERIAL. MUST START IN
C COLUMN 21. MAY BE -
C ALUMINUM
C STEEL
C
C 31-40 F10.0) TW R THICKNESS OF HEADER MATERIAL
C (INCHES)
C .....
C .....
C Q1 1-10 (E10.0, CRJ R COST OF ROLLED JOINT, TUBE TO HEADER
C ($/TUBE)
C
C 11-20 E10.0, CWJ R COST OF WELDED JOINT, TUBE TO HEADER
C ($/TUBE)
C
C 21-30 E10.0, CHH R TUBE AND PLUG HOLE PREPARATION COST
C ($/HOLE)
C
C 31-40 E10.0, CN R NOZZEL AND ATTACHING COST ($/HOLE)
C
C 41-50 E10.0, CMW R COST OF HEADER MACHINING AND WELDING
C ($/FT)
C
C 51-60 E10.0, CST R STRUCTURAL STEEL COST ($/LB)
C
C 61-70 E10.0) CBJ R COST OF BOLTED HEADER JOINT ($/FT)
C .....
C .....
C R1 1-10 (E10.0, XNS R NUMBER OF CONDENSER SHELLS
C
C 11-20 E10.0, VELN R NOMINAL DESIGN VELOCITY THRU CONDEN-
C SER TUBES (FT/SEC)
C
C 21-30 E10.0, ODC R CONDENSER TUBE O.D. (INCHES)
C
C 31-40 E10.0, GA R CONDENSER TUBE WALL GAGE. MAY BE
C 12. 14. 16. 18. 20. 22. 24.
C
C 41-50 E10.0, TKCT R THERMAL CONDUCTIVITY OF CONDENSER
C TUBING
C (BTU/(HR SQFT DEG F/FT))
C
C 51-60 E10.0, ITD2GE R TERMINAL TEMPERATURE DIFFERENCE
C ESTIMATE
C (DEGREES F)
C
C 61-80 2A10) CONMAT, R CONDENSER TUBING MATER-

```


5.3 OUTPUT

Complete output from typical runs of each model are presented and described in the following subsections.

5.3.1 SOA Model Output

Complete output from a typical run of the SOA model is shown in Figure 5-4. The circled numbers on the figure correspond to the numbers in parentheses in this section. The output report is divided into the following sections:

- (100) through (300) Input Summary
- (400) through (500) Plant scaling for increased steam, and for fans and pumps
- (600) through (700) Heat Exchanger
 - (800) Piping
 - (900) Condenser
 - (1000) Fans
- (1100) through (1200) Plant performance as a function of ambient temperature
- (1300) Cost summary

(100) Output printed by subroutine SETUP.

This line begins a card-by-card summary of input data. Any cards preceding the first blank card are printed as title or description cards. After the first blank card the values are printed as they are read, and the variable name is printed immediately below the value. The line tags A1, B1, etc. correspond to the Card Type designations used in the Input Description (see Section 5.2.1). Variable names printed here are defined in Section 5.2.1. Every input variable read by the program appears in this summary.

(200) through (230) Output printed by subroutine INPSUM

Some of the more frequently changed input parameters are summarized here with more descriptive labels than are given in the preceding summary.

- (205) The options summarized here are those selected by the variables FIXL, DEEPL AND POMDPL on Card Type B1; VELREC and TLIM on Card Type H1; and NTUCAL on Card Type J1.
- (210) The starting point in the search for an optimum is specified by T1, CWARA, AFRON, and WLRAT. These correspond to the values of VAS(1), VAS(3), VAS(4) and VAS(5) on Card Type B1. (The initial value for the temperature range of the water is determined internally by the code.)
- (220) Input data pertaining to the turbine are summarized here.
- (230) Unit costs and costing factors from Card Types D1 and E1 are reported here.
- (300) Output printed by Main Program.
TD is the design temperature (°F) used in calculations for this case. The design temperature of the plant is the air temperature at which the power plant and cooling towers are designed to give a net power of PSIZE.
- (400) Output printed by subroutine OUT2.
This report is printed upon return from subroutine SSCALE, after the steam supply system is scaled to allow for increased heat rate at the rating back pressure. The term HRFAC1 is the heat rate factor at the rating back pressure, RBP.
- (500) Output printed by subroutine OUT4.
Values reported here are intermediate results after the plant is scaled for increased steam, but before it is scaled for fan and pump power requirements. HRFAC2 is the heat rate factor at the indicated design backpressure. PLANC2 is the plant cost; PSIZ12 is the plant size needed at rating back pressure to provide the specified plant power output (PSIZE on Card Type D1) at design back pressure. $PSIZ12 = PSIZE * (HRFAC2/HRFAC1)$. SPBP is the cost differential incurred in scaling the plant to allow for the difference between design conditions and base plant conditions (conventional turbine at rated back pressure).

(550) Output printed by subroutine OUT4.

The information reported here is for the plant after scaling to provide for additional power to drive fans and pumps. The scaling factor, S.F., is the ratio PSIZE/(PSIZE power required by fans and pumps). PSIZ13 corresponds to PSIZ12 above, but now the fan and pump power requirements are included. PSIZ13 = (PSIZ12) x (S.F.). The power PTOTAL is the size of the scaled plant. PTOTAL = (PSIZE) x (S.F.). PLANC3 is the plant cost per kilowatt, excluding fan and pump capital costs, at design conditions. SPC is the plant cost excluding fans and pumps. SPCD is the differential cost of the plant due to the use of a dry cooling tower as a heat rejection system. It is the difference in cost between the plant using a conventional turbine at rated back pressure and the plant using a nonconventional turbine at plant design conditions.

(600) Output printed by subroutine RPTHXD.

This report summarizes the input data pertaining to heat exchanger design, materials, and unit costs. Values are entered on Card Type K1, L1, M1, P1, and Q1.

(700) through (760) Output printed by subroutine RPTHXC.

The heat exchanger design, operating conditions, performance characteristics and costs are reported here.

(710) Fluid flow and heat transfer characteristics are summarized.

The term CWARA is the ratio of MC_p of water to MC_p of air. CWARA corresponds to VAS(3) on Card Type B1.

(720) Heat exchanger geometry terms reported here are defined as

$$AFTR = \frac{\text{Fin Area}}{\text{Total Area for Heat Transfer}}$$

$$ALPHA = \frac{\text{Heat Transfer Area (ft}^2\text{)}}{\text{Unit Volume of Heat Exchanger (ft}^3\text{)}}$$

$$SIGMA = \frac{\text{Free Flow Area}}{\text{Frontal Area}}$$

$$\frac{FITCO}{ATOT} = \frac{\text{Finned Tube Cost (\$)}}{\text{Heat Transfer Area (ft}^2\text{)}}$$

- (730) Weights of major dry cooling tower components are reported.
- (740) The option selected for NTU calculation is shown here, based on NTUCAL input on Card Type J1.
- (750) Fluid flow rates and heat exchanger geometry previously printed repeated here for convenience.
- (760) An itemized list of costs associated with fabricating, shipping and installing the heat exchanger is printed.
- (800) Output printed by subroutine RPRT1.
Piping costs are itemized separately for circulation piping, quadrant piping, and distribution piping. Pump and piping costs are reported in thousands of dollars ($\$ *10^{**3}$). For a complete description of the pump and piping, see Appendixes B and D.
- (900) Output printed by subroutine RPRT2.
Condenser design and costing are reported in this section.
- (1000) Output printed by subroutine RPTFAN.
Fan geometry, costs, and design conditions are reported here. Design condition values reported in the column labeled ADJUSTED are for air reduced to standard conditions. The space labeled DRIVE SYSTEM is reserved for future use. In its present form, the model assumes a spiral bevel drive system only.
- (1100) Output printed by subroutine VARIT.
System performance and costs are reported for one year of operation at times and temperatures specified on Card Types C1 and C2. Abbreviations used in column headings are:
- HX - heat exchanger
 - ITD - initial temperature difference
 - LMTD - log mean temperature difference
 - CAP - capacity
 - TEMP - temperature
 - PCT - percent
 - TTDP - terminal temperature difference (condenser).

(1200) Output printed by main program.

FINAL INCREMENTAL COST is the total of the entries in PORTION OF INCREMENTAL POWER COST column. Units are mills/kWh. Capacity charge of gas turbine is computed by the expression

$$\text{CAPACITY CHARGE} = (\text{CAPCHG})(\text{PSIZE}-\text{PGEN}),$$

where

PGEN is the power generated at highest ambient temperature;

(PSIZE-PGEN) is the replacement capacity (kW);

CAPCHG is the cost of replacement capacity (\$/kW);

PSIZE and CAPCHG are input values on Card Types D1 and E1.

(1300) Output printed by subroutine SUMCOS.

Major cost components are summarized here. Costs reported under the heading CAPITAL COST SUMMARY (1340) are in dollars; those reported under UNIT ENERGY COST SUMMARY are in mills/kWh. The ENERGY PENALTY (1350) is the summation of the products of two columns in the performance cost table (1100), that is, (COST TO REPLACE LOST CAP) x (PCT TIME AT AMBIENT TEMP). Similarly, the ADDITIONAL BASE PLANT FUEL (1360) is the summation of the products (CHANGE IN FUEL COST) x (PCT TIME AT AMBIENT TEMPERATURE). OPERATION AND MAINTENANCE unit cost (1370) is based on the cooling system capital cost and the input variable PER (Card Type D1), which is simply the ratio of maintenance cost to capital cost. The calculation is made in subroutine SCALP. The final TOTAL (1380) is the same as the FINAL INCREMENTAL COST reported in the preceding table (1200).

(10) 3M41 DRY COILING TOWER MODEL -- METAL FIN TUBE, CIRCULAR TOWER VERSION. THIS RUN MADE 03/17/77 13.40.02

 (A) ***

 EXAMPLE RUN - METAL FIN SOA VERSION

(8)	50.000000	50.000000	95.000000	1.000000	300000.00	27.000000	80.000000	-0.000000	-0.000000	FIXL	DEEPL	PUMDPL
	TSTAR	TEVS	VAS(1)	VAS(3)	VAS(4)	VAS(5)	FIX	DEEPL	PUMDPL			
(9)	100.0	95.0	75.0	55.0	35.0	.0100	.0285	.0915	.1096	.1119	.5050	
	TA(1)	TA(3)	TA(4)	TA(5)	TA(6)	TA(7)	TA(8)	TA(9)	TA(10)	TA(11)	TA(12)	TA(13)
(10)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0000	0.0000	0.0000	0.0000	0.0000
	TA(9)	TA(10)	TA(11)	TA(12)	TA(13)	TA(14)	TA(15)	TA(16)	TA(17)	TA(18)	TA(19)	TA(20)
(11)	100.0000	40000000	65000000	17400000	10000000E=J1	1.0000000	4410.0000	40.000000				
	SIZE	TEFF	CAMP	FCR	PER	CCM	ELEV	RJDFL				
(12)	91.000000	24.000000	440.00000	0.	CSSTL	121000.00	30.000000	-0.	CTUM8			
	PCJS	PCDS	PLANC			CAPCHG	WPCST					
(13)	1.6110000	1.4640000	1.5140000	1.2100000	1.3310000	1.2100000	1.4640000	1.4640000				
	PCRAF	PCRAF	PCALEC	PCHEIR	PCACND	PCMSTC	PCMSLL					
(14)	3.50	1.000000	0.000000E=02	0.26750000E=02	0.11230000E=03							
	TPD(1)	TPD(2)	TPD(3)	TPD(4)	TPD(5)							
(15)	95000000	125.00000										
	DEPS	CPRESS										
(16)	1.0000000	0.	150.00000	0.	2.0000000	0.	0.	0.	0.	0.	0.	0.
	VELREC	VEDEPA	LIM	TUMWIN	PFACI	IPFIX	RFIX	10MRAF				
(17)	20000000											
	GAFF											
(18)	1.7400000	1.0000000	7.0300000	0.	2.2200000	2.5000000	0.55000000	4.6000000				
	SM	WPL	CUVZ	CHALLS	JCS	JMS	CVX	RFV				
(19)	1.000000	2.000000	12.000000	1.000000	5.0000000							
	NTJCAL	WNS	WNS	NTJ3	SS							
(20)	12.000000	18.000000	12.000000	500.00000								
	REVEL	REDUCE	DIST									
(21)	2.5720000	2.2270000	2.5720000	0.2200000E=01	2.5720000	0.18000000E=01	0.	DANGLE				
	KA	KN	KDG	SP	DRIN	TMFIN						
(22)	1.000000	0.930000	20.000000	STEEL	WELDED							
	TOL	DI	GABLIN	TUBWA								
(23)	0.000000	0.000000	119.00000									
	ALUMINUM	FINMET	CUVF									
(24)	0.	0.	0.000000	0.2000000	0.4000000	0.4000000	0.4000000	0.4000000				
	COALC	ZINCC	CASTC	EPREPC								
(25)	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000				
	GA	WELMET	WELMET	WELMET	WELMET	WELMET	WELMET	WELMET				

FIGURE 5-4. SOA Model Sample Output

(01)	0.	CAJ	2,000,000.00	CMJ	20,000,000.00	5,625,000.00	4,400,000.00	5,000,000.00
					CN	CMW	EST	CRJ
(02)	2,000,000.00	XVS	7,000,000.00	VELN	18,000,000.00	.950,000.00	5,000,000.00	ADMIRALTY
					GA	FC	ITU	COMBAT
(03)	0.	LAB	0	0				
			LPE	WEXT				
(04)	0.	PPR	0	0				
			FF4x					

FIGURE 5-4. Continued

(200) INPUT SUMMARY AND CASE DESCRIPTION

(205) OPTIONS SELECTED FOR THIS RUN

(210) STARTING CONDITIONS

UPPER LIMIT ON TURBINE TEMP 153.0 F
 FRICTION FACTOR AND HT TRFR COEFF BY DEF
 EXCHANGER DEPTH UNCONSTRAINED
 EXCHANGER LENGTH FIXED AT 80. FEET
 RUN WITH VELOCITY RECOVERY
 NTH CALCULATION IS BY TABLE

TURBINE OUTLET TEMPERATURE, T1 95.000 F
 CAPACITY RATIO, CMRA 1.000
 FRONTAL AREA, AFROA 30000.
 WIDTH TO LENGTH RATIO, -LRAT 20.000

COEFFICIENTS FOR POLYNOMIAL CURVE FIT
 A0 A1 A2 A3 A4
 1.00000E+00 -4.90000E-03 2.67500E-03 -1.12500E-04

(220) HEAT RATE FACTOR AS FUNCTION OF BACKPRESSURE (INCHES OF MERCURY)
 TURBINE RATING BACKPRESSURE 3.50 INCHES OF MERCURY
 SITE ELEVATION 4010. FEET ABOVE SEA LEVEL

(230) UNIT COSTS AND COSTING FACTORS

FUEL	91.000 CENTS/KWHRTU	POWER PLANT CONSTRUCTION	440.000 \$/KW	FIXED CHARGE RATE	.174
LABOR	0.000 \$/30 FT	REPLACEMENT POWER	20.000 MILLS/KWH	CAPACITY FACTOR	.550
WATER	50.000 \$ / HP	STEAM SUPPLY	146.650 \$/KW TURBINE OUTPUT	BASE THERMAL EFFICIENCY	.400
		CAPACITY CHARGE	121000.000 \$/KW	CONSTRUCTION COST MULTIPLIER	1.000
				MAINT COSTS /CAPITAL COSTS	.010

FIGURE 5-4. Continued

300 TO USED IN THE FOLLOWING CALCULATIONS IS = 50,000
 IN PIPING ROUTINE NUMBER OF TUBERS PER GROUP 20 WAS REJECTED
 IN PIPING ROUTINE NUMBER OF TUBERS PER GROUP 20 WAS REJECTED
 400 STEAM SUPPLY SCALING TO COMPENSATE FOR INCREASED HEAT RATE AT RATING BACKPRESSURE. TOP = 3.50 IN. HG HR FACT = 1.010795
 STEAM SUPPLY COST DIFFERENTIAL \$ 150133. TURBINE COST DIFFERENTIAL U. \$/KW
 PLANT COST INCLUDING STEAM SUPPLY AND TURBINE \$ 44158133. PLANT UNIT COST INCLUDING STEAM SUPPLY AND TURBINE 442. \$

500 CONDITIONS AFTER SCALING PLANT AND STEAM SUPPLY (BEFORE SCALING FOR FANS AND PUMPS) HR FACT = .9986032
 PSI212 = 989.2547 **
 PLANC2 = 436.8382 3/4"
 SPBR = 3161742.42 \$
 PACK PRESSURE = 1.495081 IN. HG
 SAT TEMPERATURE = 100.000000 DEG F

WATER FLOW RATE 202803420.
 AIR FLOW RATE 345014251.
 PUMP POWER 6199.50275
 FAN POWER 16796.9964
 HE SURFACE AREA 31107612.9
 FRONTAL AREA 445600.000
 A/D/T/LENGTH RATIO 89.7812503
 A/D/T 25005
 A/D/T 5592.50000
 CONDENSER WT TRFR AREA 550939.414
 NO. CONDENSER TUBES 58328.0000
 CONDENSER TUBE LENGTH 36.0000000
 WATER VELOCITY 7.0000000
 LB MASS / HR
 LB MASS / HR
 KILOWATTS
 KILOWATTS
 SQ FT
 TUBES
 FEET
 SQ FT TOTAL
 FT.
 FT/SEC

550 SCALING FOR FAN AND PUMP WATER REQUIREMENTS
 WATER FLOW RATE 207575964.
 AIR FLOW RATE 364902015.
 PUMP POWER 6335.52773
 FAN POWER 17192.2592
 HE SURFACE AREA 52310572.9
 FRONTAL AREA 457111.975
 A/D/T/LENGTH RATIO 71.4237461
 A/D/T 25658
 A/D/T 5713.89968
 CONDENSER WT TRFR AREA 263927.779
 NO. CONDENSER TUBES 59721.3527
 CONDENSER TUBE LENGTH 36.0000000
 WATER VELOCITY 7.0000000
 LB MASS / HR
 LB MASS / HR
 KILOWATTS
 KILOWATTS
 SQ FT
 TUBES
 FEET
 SQ FT TOTAL
 FT.
 FT/SEC

SCALING FACTOR 1.02333779
 P SIZE 1000.00000
 PSI213 1012633961
 P/D/TAL 1023.53779
 PLANC3 447.120412 3/4"
 SPC 447120412.
 SPED 7120411.77 \$

FIGURE 5-4. Continued

NON-DELTA HEAT EXCHANGER DESCRIPTION

SUPPORT SPACING 5.000 FEET
 TUBE PITCH NORMAL TO AIR FLOW 2.572 INCH
 TUBE PITCH IN DIRECTION OF AIR FLOW 2.227 INCH
 TUBE DIAGONAL PITCH 2.572 INCH
 LIVER GAGE 25.0
 LIVER MATERIAL STEEL WELDED
 LIVER THERMAL CONDUCTIVITY 31.000
 LIVER TUBING OUTSIDE DIAMETER 1.0000 INCH
 LIVER TUBING INSIDE DIAMETER .9300 INCH

UNIT COST

FIN ROUNDS \$ 0.
 PROTECTIVE COATING \$ 0.
 ZINC FOR SPACERS \$.8500 /LB
 SPACER CASTING \$ 1.2000 /EA
 END PREPARATION \$ 2.000 /TUBE
 LIVER TUBING \$ 1.32011 /FT
 PROTECTIVE COATING \$ 0.
 FINNING \$.51691 /FT
 STUNNED TUBE \$.24102 /FT
 TUBE SPACERS \$.50063 /FT
 HEADER MATERIAL (GALVANIZED) \$.570/LB
 ROLLED JOINT, TUBE TO HEADER \$ 0.000/TUBE
 WELDED JOINT, TUBE TO HEADER \$ 2.000/TUBE
 TUBE AND PLUG HOLE PREPARATION \$.500/MOLE
 NOZZEL AND ATTACHING \$ 20.000/MOLE
 BOLTED HEADER JOINT \$ 5.000/FT
 HEADER MACHINING AND WELDING \$ 5.625/FT
 STRUCTURAL STEEL \$.480/LB

HEAT EXCHANGER

37.5 FANS 2.0 PASS

AIR WATER

REYNOLDS NUMBER 7.8536E+03 4.7500E+04
 VELOCITY (FT/SEC) 1.7134E+01 4.5265E+00
 PRESSURE DROP (LBS FORCE/SQ IN) 1.1282E+02 6.0600E+00
 HEAT TRANS COEFF (BTU/HR SQ FT DEG F) 7.2333E+03 1.0844E+03
 FRICTION FACTOR 6.5016E+01 5.3578E+03
 INLET TEMPERATURE (F) 5.0000E+01 9.5600E+01
 EXIT TEMPERATURE (F) 7.5240E+01 7.0359E+01
 RANGE (F) 2.5240E+01 2.5240E+01
 CARRA 1.0000E+00
 NTU 1.3110E+00
 OVERALL U (BTU/HR SQ FT DEG F) 5.2059E+00
 EFFECTIVENESS .5535
 FIN EFFICIENCY .8545

WT OF WATER 2450855. LB
 WT OF TUBES 6522364. LB
 WT OF FRAME 1739062. LB
 WT OF HEADER 933762. LB
 WT OF STRUCT 6737737. LB
 PCFB LOAD 18264479. LB

AFR 94034152
 LPA 184.71115
 SIGMA .07222706

HTC/ATDT .12456394

NTU EFFECTIVENESS CORRELATION USED

FIGURE 5-4. Continued

(150) AIR FLOW RATE 20737693 LBM/42
 AIR FLOW RATE 86900013 LBM/42
 TUBES IN DEPTH 3.27 TUBES (5713.9 FT DEEP)
 TUBES ACROSS FRONT 26550 TUBES (5713.9 FT WIDE)

(160) COILING SURFACE \$ 1171437.
 HEADER AND NOZZEL \$ 1861126.
 BUNDLE ASSEMBLY AND FRAME \$ 3439761.
 PLENUM \$ 206970.
 LOUVERS \$ 4704550.
 MAIL SCREENS \$ 0.
 STRUCTURE \$ 5151023.
 FOUNDATION \$ 481939.
 HEAT EXCH. SHIP AND ERECT \$ 2041032.

LENGTH 90 FEET
 FRONTAL AREA 457111 SQ FEET
 SURFACE AREA 52310572 SQ FT

FIGURE 5-4. Continued

.....
 (600) PIPING 125 PSI DESIGN PRESSURE

CIRCULAR TOWERS 12 TOWER GROUPS 1
 TOWERS PER GROUP 12 TOWERS IN INCOMPLETE GROUP 0

CIRCULATION PIPING TO EACH TOWER GROUP

HEADER SECTION	DIAMETER (INCHES)	LENGTH (FEET)	COST IN 10**3 DOLLARS FOR		
			PIPE	TEES	REDUCERS EXPANSION FLANGES JOINTS(1) (3)
1	120.	573.	920.	93.	0.
2	120.	0.	0.	85.	45.
3	120.	222.	317.	93.	75.
4	102.	0.	0.	51.	0.
5	102.	222.	271.	51.	0.
6	102.	0.	0.	61.	29.
7	84.	222.	202.	40.	0.
8	84.	0.	0.	40.	0.
9	84.	222.	202.	40.	17.
10	66.	0.	0.	21.	0.
11	66.	222.	144.	23.	8.
12	66.	0.	0.	3.	0.

COST OF CIRCULATION PIPING FOR EACH TOWER GROUP \$5597. \$100**3
 COST OF CIRCULATION PIPING FOR INCOMPLETE GROUP \$ 0. \$100**3

TOTAL COST OF CIRCULATION PIPING \$5597. \$100**3

TOWER PIPING

TOWER DIAMETER 149. FEET
 DIAMETER OF PIPE FROM CIRCULATION HEADER TO TOWER DISTRIBUTION HEADER 36. INCHES
 DIAMETER OF TOWER DISTRIBUTION PIPE 18. INCHES
 COST OF DISTRIBUTION PIPING PER TOWER \$ 297. \$100**3

TOTAL COST OF TOWER DISTRIBUTION PIPING \$3562. \$100**3

FIGURE 5-4. Continued

QUADRANT PIPING

HEADER SECTION	DIAMETER (INCHES)	LENGTH (FEET)	COST IN 1000 DOLLARS FOR		
			PIPE	TEES	REDUCERS
1	18.0	0.0	0.0	1.3	0.0
2	18.0	9.4	.8	1.3	0.0
3	18.0	9.4	.9	1.3	0.0
4	18.0	9.4	.8	1.3	0.0
5	18.0	9.4	.8	1.3	0.0
6	18.0	9.4	.8	1.3	0.0
7	18.0	9.4	.8	1.3	0.0
8	18.0	9.4	.8	1.3	0.0
9	18.0	9.4	.8	1.3	0.0
10	18.0	9.4	.8	1.2	0.0

TUBES PER BUNDLE 182
 BUNDLES PER QUADRANT 10
 COST OF HEADERS PER QUADRANT \$ 62. #10**3

TOTAL COST OF QUADRANT HEADERS \$2970. #10**3

PUMP STATION

DESIGN VELOCITY 12. FPS
 FLOW PER BUNDLE 449. GPM
 FLOW PER QUADRANT 5075. GPM
 FLOW PER TOWER 33901. GPM
 FLOW PER TOWER GROUP 408409. GPM
 FLOW IN INCOMPLETE GROUP 0. GPM

FOR EACH TOWER GROUP 59. FEET
 DYNAMIC HEAD 1951. #10**3
 PUMP COST \$ 719. #10**3
 PUMP FITTINGS COST \$ 1679. #10**3
 PUMP STATION COST \$ 159. #10**3

PUMP ELECTRICAL COSTS \$ 159. #10**3

COST OF PUMP STATIONS \$1679. #10**3

TOTAL PIPING SYSTEM COSTS \$18366. #10**3

FIGURE 5-4. Continued

(1000) F A N S

FANS EQUIPPED WITH VELOCITY RECOVERY DIFFUSERS

--- DRIVE SYSTEM ---

--- FAN GEOMETRY ---

HUB DIAMETER 13.00 FEET
 BLADE DIAMETER 60.00 FEET
 BLADE ANGLE 16.00 DEGREES
 NUMBER OF BLADES/FAN 12.00
 NUMBER OF FANS 37.

--- FAN COSTS ---

BLADE AND HUB COST/FAN \$ 50730.
 MOTOR COST/FAN \$ 34770.
 SPEED REDUCER DRIVE COST/FAN \$ 44726.
 STACK COST/FAN \$ 52359.
 ELECTRICAL COST/FAN \$ 55530.

--- ANNUAL OPERATIONAL COSTS \$ 3455600.

--- DESIGN CONDITIONS ---

VOLUMETRIC FLOW RATE/FAN (ACTUAL) 6366745. CU FT/MIN
 TOTAL VOLUMETRIC FLOW RATE 240077512. CU FT/MIN
 TOTAL AIR PRESSURE DROP (IF H.A.) .41765 PSI
 PRESSURE DROP ACROSS H.A. MUNDLE .01128 PSI
 MIN. RECOVERABLE VELOCITY HEAD .00537 PSI
 TORQUE PER FAN 619. HP
 FAN POWER REQUIREMENTS 22925. HP
 (ADJUSTED)

.02112
 .01350
 .00762
 730.

FIGURE 5-4. Continued

.....
 (10) CONDENSER

--- DESIGN CONDITIONS ---

STEAM TEMPERATURE 100.0 F
 INLET WATER TEMPERATURE 70.0 F
 EXIT WATER TEMPERATURE 95.6 F
 LWS MEAN TEMPERATURE DIFFERENCE 14.0 F

--- DESIGN OPERATING CONDITIONS ---

OVERALL HEAT TRANSFER COEFFICIENT 662.46 BTU/HR SQ FT DEG F
 AVERAGE WATER VELOCITY THRU COND 7.00 FT/SEC
 PRESSURE DROP THRU CONDENSER 1107.1 LB/SQ FT
 CONDENSER EFFECTIVENESS .835

--- CONDENSER DESCRIPTION ---

NUMBER OF SHELLS 2
 HEAT TRANSFER AREA PER SHELL .27548E+06 SQ FT
 NUMBER OF PASSES PER SHELL 2
 TUBE LENGTH 36 FEET
 NUMBER OF TUBES PER SHELL 29174

--- CONDENSER COSTS ---

TUBING MATERIAL \$ 2104226.92 (ADMINISTRATIVE)
 SHELLS \$ 2405250.30
 FIELD ERECTION \$ 1833317.35
 TOTAL COST OF CONDENSER \$ 6342794.

FIGURE 5-4. Continued

AMBIENT TURBINE		HEAT		HX		HX		POWER		CHANGE IN		COST TO		POWER COST		PCT TIME		PORTION OF			
TEMP	OUTLET	BACK	RATE	LMTD	ITD	GENERATED	FUEL COST	IN	DEG F	MEGAWATTS	MILLS/KWH	LOST CAP	REPLACE	TEMP	AT AMBIENT	TEMP	AT AMBIENT	INCREMENTAL	POWER COST		
DEG F	DEG F	IN, DEG	DEG F	DEG F	DEG F	DEG F	MILLS/KWH	DEG F	DEG F	DEG F	MILLS/KWH	MILLS/KWH	MILLS/KWH	PERCENT	MILLS/KWH	PERCENT	MILLS/KWH	MILLS/KWH	MILLS/KWH	MILLS/KWH	
100.0	153.0	5.12	1.0763	26.435	5.237	21.33	48.00	927.337	.16221	1.7439	4.3944	.150	.65916E-02								
95.0	147.5	7.02	1.0526	26.148	5.194	19.69	47.50	942.409	.16221	1.3422	4.0327	1.000	.40327E-01								
90.0	142.0	8.92	1.0289	25.861	5.151	10.38	47.00	956.883	.16221	.74961	3.4501	2.950	.98326E-01								
85.0	136.5	10.82	1.0052	25.574	5.108	1.03	46.50	971.357	.16221	.40980	3.0593	8.220	.25107								
80.0	131.0	12.72	0.9815	25.287	5.065	20.64	46.00	985.831	.16221	.17075	2.6212	9.130	.25756								
75.0	125.5	14.62	0.9578	25.000	5.022	20.49	45.50	999.305	.16221	.58852E-01	2.6894	10.960	.29475								
70.0	120.0	16.52	0.9341	24.713	4.979	20.34	45.00	1011.060	.16221	0.	2.6030	11.190	.29576								
65.0	114.5	18.42	0.9104	24.426	4.936	18.29	44.50	1022.141	.16221	0.	2.6357	50.500	1.4092								
60.0	109.0	20.32	0.8867	24.139	4.893																

(100) FINAL INCREMENTAL COST 2.7340
 CAPACITY CHARGE \$ 8792162.84

FIGURE 5-4. Continued

CAPITAL COST SUMMARY

	CAPITAL COST	ENERGY COST	SUMMARY
COOLING SYSTEM CAPITAL			
TOWER	61166631.		1,657,94
HEAT EXCHANGER	1350553.		
PUMPS	205770.		
TUBES	1764556.		
WALL SCREENS	0.		
RAY SYSTEM	1166124.		
STRUCTURE	5151423.		
FOUNDATION	445939.		
PIPING			
CONDENSER	14295233.		4,555,01
CAPACITY PENALTY	5492056.		1,453,05
PLANT SCALING			
STEAM SUPPLY	1502054.		4,000,00
BASE PLANT	5517427.		1,384,21
(LAV)			
TOTAL CAPITAL COST			
	77865525.		2,579,04
ENERGY PENALTY			
		7120412.	1,820,75
ADDITIONAL BASE PLANT FUEL			
		5742143.	1,453,05
OPERATION AND MAINTENANCE			
			153034
TOTAL			
			2,734,00

FIGURE 5-4. Continued

5.3.2 PLASTIC Tube Model Output

A complete output report from a typical run of the PLASTIC model is shown in Figure 5-5. The description of the metal fin tube output (Section 5.3.1) applies to the plastic tube model output with two exceptions:

1. The line tags A1, B1, etc., correspond to card type designations used in the Input Description for the PLASTIC model (Section 5.2.2).
2. The term AFTR is omitted from the geometry terms in report section (720) since it is meaningless for tubes without fins.

(P1)	FJM REMOVABLE REOTYP	GA-VANIZED REDMAT	.5250000 TM				
(O1)	3. CRJ	CMJ	.5000000E-01 SM	20.000000 CM	5.6250000 CM	0. CSJ	5.0000000 CBJ
(R1)	2.0000000 RVS	7.0000000 VEN	1.0000000 JDC	14.000000 GA	.95000000 FC	5.0000000 TTC	ADMIRALTY COMBAT
(S1)	LRA LPE	R9 MEXPT					

FIGURE 5-5. Continued

(200) INPUT SUMMARY AND CASE DESCRIPTION

(205) OPTIONS SELECTED FOR THIS RUN

 (210) STARTING CONDITIONS

OPER LIMIT ON TURBINE TEMP 153.0 F
 EXCHANGER DEPTH UNCONSTRAINED
 EXCHANGER LENGTH FIXED AT 80. FEET
 RUN WITH VELOCITY RECOVERY
 NTU CALCULATION IS BY TABLE
 TUBE ARRANGEMENT STAGGERED

TURBINE OUTLET TEMPERATURE, T1 96.000 F
 CAPACITY RATIO, CMAX 1.000
 FRONTAL AREA, AFRON 50000.
 WIDTH T1 LENGTH RATIO, ALM1 20.000

(220) HEAT RATE FACTOR AS FUNCTION OF BACKPRESSURE (INCHES OF MERCURY) A0 A1 A2 A3 A4
 TURBINE RATING BACKPRESSURE 3.50 INCHES OF MERCURY 1.0000E+00 -4.9000E-03 2.6750E+03 -1.1250E+04
 SITE ELEVATION 4010. FEET ABOVE SEA LEVEL

COEFFICIENTS FOR POLYNOMIAL CURVE FIT
 A0 A1 A2 A3 A4

(230) UNIT COSTS AND COSTING FACTORS

FUEL	81.000 CENTS/WHSTU	PUMP PLANT CONSTRUCTION	400.000 \$/KA	FIXED CHARGE RATE	.174
LAND	0.000 \$/SQ FT	REPLACEMENT POWER	24.000 MILLS/KWH	CAPACITY FACTOR	.650
WATERS	50.000 \$ / HP	STEAM SUPPLY	145.650 \$/KA TURBINE OUTPUT	BASE THERMAL EFFICIENCY	.400
		CAPACITY CHARGE	121000.000 \$/KA	CONSTRUCTION COST MULTIPLIER	1.000
				MAINT COSTS /CAPITAL COSTS	.010

FIGURE 5-5. Continued

300) TO USED IN THE FOLLOWING CALCULATIONS IS = 50,000

IN PIPING ROUTINE NUMBER DEBITMERS PER GROUP NO WAS REJECTED

IN PIPING ROUTINE NUMBER DEBITMERS PER GROUP NO WAS REJECTED

IN PIPING ROUTINE NUMBER DEBITMERS PER GROUP NO WAS REJECTED

IN PIPING ROUTINE NUMBER DEBITMERS PER GROUP NO WAS REJECTED

IN PIPING ROUTINE NUMBER DEBITMERS PER GROUP NO WAS REJECTED

IN PIPING ROUTINE NUMBER DEBITMERS PER GROUP NO WAS REJECTED

400) STEAM SUPPLY SCALING TO COMPENSATE FOR INCREASED HEAT RATE AT RATING BACKPRESSURE. RBPB 3.50 IN. HG IMPACTOR 1.010795

STEAM SUPPLY COST DIFFERENTIAL \$ 1583133. PLANT UNIT COST INCLUDING STEAM SUPPLY 441.5833\$/KW

STEAM SUPPLY UNIT COST 1583133. \$/KW

PLANT UNIT COST INCLUDING STEAM SUPPLY 441.5833\$/KW

500) CONDITIONS AFTER SCALING PLANT AND STEAM SUPPLY (BEFORE SCALING FOR FANS AND PUMPS)

HRPACTOR .9098632

PSIZ128 989.2547 MM

PLANC28 436.63M2 \$/KW

SPBPB=3161792.42 \$

BACK PRESSURES 1.985081 IN. HG

SAT TEMPERATURE 100.600000 DEG F

WATER FLOW RATE 201203109. LB MASS / HR

AIR FLOW RATE 626105977. LB MASS / HR

PUMP POWER 5994.79062 KILOWATTS

FAN POWER 9231.45232 KILOWATTS

WX SURFACE AREA 24985212.0 SQ FT

FRONTAL AREA 581400.000 SQ FT

WIDTH/LENGTH RATIO 92.4752500

HEIGHT 177420 FEET

CONDENSER HT TRFR AREA 582072.919 SQ FT TOTAL

NO. CONDENSER TUBES 58476.7000

CONDENSER TUBE LENGTH 36.0000000 FT.

WATER VELOCITY 5.92955599 FT/SEC

550) SCALING FOR FAN AND PUMP OTHER REQUIREMENTS

WATER FLOW RATE 204311593. LB MASS / HR

AIR FLOW RATE 695312227. LB MASS / HR

PUMP POWER 6076.35350 KILOWATTS

FAN POWER 9343.33595 KILOWATTS

WX SURFACE AREA 23370376.9 SQ FT

FRONTAL AREA 600519.210 SQ FT

WIDTH/LENGTH RATIO 93.8311266

HEIGHT 190158 FEET

CONDENSER HT TRFR AREA 560593.616 SQ FT TOTAL

NO. CONDENSER TUBES 59377.5923

CONDENSER TUBE LENGTH 36.0000000 FT.

WATER VELOCITY 6.92955599 FT/SEC

SCALING FACTOR 1.01541970

PSIZ1 1000.00000 MM

PSIZ13 1004.50875 MM

PTOTAL 1015.41970 MM

PLANC3 443.574121 \$/KW

SPEC 443574121 \$

SPCD 3574121.05 \$

FIGURE 5-5. Continued

(600) 60.0 DEGREE DELTA HEAT EXCHANGER DESCRIPTION

SUPPORT SPACING 1.500 FEET SEAL PLATE THKNS .250 INCH
 TUBE PITCH NORMAL TO AIR FLOW .500 INCH SEAL PLATE DENSITY .284 LB/CCU IN.
 TUBE PITCH IN DIRECTION OF AIR FLOW .433 INCH ELASTICER THKNS .500 INCH
 TUBE DIAGONAL PITCH .500 INCH ELASTICER DENSITY .040 LB/CCU IN.
 LINER GAGE 20.0

LINER MATERIAL POLYETHYLENE
 LINER THERMAL CONDUCTIVITY .291
 LINER TUBING OUTSIDE DIAMETER .2500 INCH HEADER TYPE FORM REMOVABLE
 LINER TUBING INSIDE DIAMETER .2000 INCH HEADER LENGTH 12.000 FEET

*** UNIT COST ***

SPACER CASTING \$ 0. /EA
 END PREPARATION \$ 0. /TUBE
 SEAL PLATE \$.2500 /LB
 FRAME COST \$.3000 /LB
 LINER TUBING \$.58782E-02/FT
 TUBE SPACERS \$.51450E-02/FT

HEADER MATERIAL (GALVANIZED) \$.570/LB
 ROLLED JOINT, TUBE TO HEADER \$ 0.000/TUBE
 WELDED JOINT, TUBE TO HEADER \$ 0.000/TUBE
 TUBE AND PLUG HOLE PREPARATION \$.050/HOLE
 NOZZEL AND ATTACHING \$ 20.000/HOLE
 BOLTED HEADER JOINT \$ 5.000/FT
 HEADER MACHINING AND WELDING \$ 5.625/FT
 STRUCTURAL STEEL \$ 0.000/LB

(700) HEAT EXCHANGER 176.9 PAVS 2.0 MASS

(710) AIR

REYNOLDS NUMBER 1.03558E+03 3.90412E+03
 VELOCITY (FT/SEC) 9.96182E+00 1.73186E+00
 PRESSURE DROP (LBS FORCE/SQ IN) 8.67673E-03 7.70340E+00
 HEAT TRFR COEFF (BTU/HR SQ FT DEG F) 1.54015E+01 6.86147E+02
 FRICTION FACTOR 1.20487E-01 1.00442E-02
 INLET TEMPERATURE (F) 5.00000E+01 9.56000E+01
 EXIT TEMPERATURE (F) 5.15467E+01 7.31591E+01
 RANGE (F) 3.15467E+01 2.34409E+01

CHARA
 NU 1.24000E+00
 OVERALL U (BTU/HR SQ FT DEG F) 2.56282E+00
 EFFECTIVENESS 1.43831E+01
 FIN EFFICIENCY .6918
 0.0000

FIGURE 5-5. Continued

(700) WT OF WATER 6243624. LB
 AT OF TUBES 2635936. LB
 AT OF FRAME 12711698. LB
 AT OF HEADER 2235298. LB
 AT OF STRUCT 6897815. LB
 RTT: LOAD 24020766. LB (40.00 LB/SQ FT)

(700) A-PH 43.531420
 SIGMA .50000000

FITCJ/ATJ .49012871E-01

(700) TABLE WT: EFFECTIVENESS CORRELATION USED

(700) WATER FLOW RATE 20031193 L3M/42
 AIR FLOW RATE 68331326 L3M/42
 TUBES IN DEPTH 26.98 TUBES (1.0 FT DEEP)

TUBES ACROSS FRONT 140155 TUBES (7506.5 FT WIDE)

LENGTH 40. FEET

FRONTAL AREA 500319 SQ FEET
 SURFACE AREA 23370376 SQ FT

(700) COOLING SURFACE \$ 5702405.
 HEADER AND NOZZEL \$ 4401470.
 BUNDLE ASSEMBLY \$ 2758714.
 BUNDLE FRAME \$ 3493400.
 SEALING ELASTICER \$ 226436.
 PLENUM \$ 178528.
 LOUVERS \$ 3090250.
 MAIL SCREENS \$
 STRUCTURE \$ 5334435.
 FOUNDATION \$ 775737.
 HEAT EXCH BSHIP AND ERECT \$ 1962479.

FIGURE 5-5. Continued

.....
 (600) PIPING 125 PSI DESIGN PRESSURE

CIRCULAR TOWERS 5 TOWER GROUPS 1
 TOWERS PER GROUP 5 TOWERS IN INCOMPLETE GROUP 0

CIRCULATION PIPING TO EACH TOWER GROUP

HEADER SECTION (INCHES)	LENGTH (FEET)	COST IN 1000'S DOLLARS FOR		
		PIPE	TEES	REDUCERS EXPANSION FLANGES JOINTS(1) (3)
1 120.	519.	842.	53.	0.
2 120.	0.	0.	83.	75.
3 102.	353.	431.	51.	29.
4 84.	0.	0.	0.	17.
5 66.	358.	222.	31.	0.

COST OF CIRCULATION PIPING FOR EACH TOWER GROUP 1015. 01003
 COST OF CIRCULATION PIPING FOR INCOMPLETE GROUP 0 0. 01003

TOTAL COST OF CIRCULATION PIPING 1015. 01003

TOWER PIPING

TOWER DIAMETER 245. FEET
 DIAMETER OF PIPE FROM CIRCULATION 245. FEET
 HEADER TO TOWER DISTRIBUTION HEADER 54. INCHES
 DIAMETER OF TOWER DISTRIBUTION PIPE 30. INCHES
 COST OF DISTRIBUTION PIPING PER TOWER 832. 01003

TOTAL COST OF TOWER DISTRIBUTION PIPING 83139. 01003

FIGURE 5-5. Continued

QUADRANT PIPING

COST IN 10**3 DOLLARS FOR
PIPE TEES REDUCERS

HEADER SECTION	DIAMETER (INCHES)	LENGTH (FEET)	PIPE	TEES	REDUCERS
1	30.0	0.0	0.0	2.5	0.0
2	30.0	1.6	.2	2.5	0.0
3	30.0	1.5	.2	2.5	0.0
4	30.0	1.5	.2	2.5	0.0
5	30.0	1.5	.2	2.5	0.0
6	30.0	1.5	.2	2.5	0.0
7	30.0	1.5	.2	2.5	0.0
8	30.0	1.5	.2	2.5	0.0
9	30.0	1.5	.2	2.5	0.0
10	30.0	1.6	.2	2.5	0.0
11	30.0	1.5	.2	2.5	0.0
12	30.0	1.5	.2	2.5	0.0
13	30.0	1.5	.2	2.5	0.0
14	30.0	1.5	.2	2.5	0.0
15	30.0	1.5	.2	2.5	0.0
16	30.0	1.5	.2	2.5	0.0
17	30.0	1.5	.2	2.5	0.0
18	18.0	3.0	.3	1.3	0.0
19	18.0	3.0	.3	1.3	0.0
20	18.0	3.0	.3	1.3	0.0
21	18.0	3.0	.3	1.3	0.0
22	18.0	3.0	.3	1.3	0.0
23	18.0	3.0	.3	1.3	0.0
24	18.0	3.0	.3	1.3	0.0
25	18.0	3.0	.3	1.3	0.0
26	18.0	3.0	.3	1.3	0.0
27	18.0	3.0	.3	1.3	0.0
28	18.0	3.0	.3	1.3	0.0
29	18.0	3.0	.3	1.3	0.0
30	18.0	3.0	.3	1.3	0.0
31	18.0	3.0	.3	1.2	0.0

PUMP STATION

DESIGN VELOCITY 12. FPS
 FLOW PER QUADRANT 451. GPM
 FLOW PER QUADRANT 20190. GPM
 FLOW PER TOWER 8071. GPM
 FLOW PER TOWER GROUP 40345. GPM
 FLOW TO INCOMPLETE GROUP 0. GPM

FOR EACH TOWER GROUP 57. FEET
 DYNAMIC HEAD
 PUMP COST \$ 0. *10**3
 PUMP FITTINGS COST \$ 0. *10**3
 PUMP STATION COST \$1550. *10**3

PUMP ELECTRICAL COSTS \$ 158. *10**3

COST OF PUMP STATIONS \$1654. *10**3

TOTAL PIPING SYSTEM COSTS \$13243. *10**3

FIGURE 5-5. Continued

.....
 (900) CONDENSER

--- DESIGN CONDITIONS ---

STEAM TEMPERATURE 100.0 F
 INLET WATER TEMPERATURE 70.2 F
 EXIT WATER TEMPERATURE 95.6 F
 LWS MEAN TEMPERATURE DIFFERENCE 11.1 F

--- DESIGN OPERATING CONDITIONS ---

OVERALL HEAT TRANSFER COEFFICIENT 65.34 BTU/HR SQ FT DEG F
 AVERAGE WATER VELOCITY (HR) COND 4.9 F/SEC
 PRESSURE DROP THRU CONDENSER 1097.1 LB/52 FT
 CONDENSER EFFECTIVENESS .836

--- CONDENSER DESCRIPTION ---

HEAT TRANSFER AREA PER SHELL .2754E+06 SQ FT
 NUMBER OF PASSES PER SHELL 2
 TUBE LENGTH 36 FEET
 NUMBER OF TUBES PER SHELL 27252

--- CONDENSER COSTS ---

TUBING MATERIAL \$ 210455.92 (AJ)MELTY
 SHELLS \$ 200401.79
 FIELD ERECTION \$ 103702.31
 TOTAL COST OF CONDENSER \$ 514559.02

FIGURE 5-5. Continued

(1000) P A V 9

FANS EQUIPPED WITH VELOCITY RECOVERY DIFFUSERS

--- DRIVE SYSTEM ---

--- FAN GEOMETRY ---

HUB DIAMETER 5.51 FEET
 BLADE DIAMETER 29.00 FEET
 BLADE ANGLE 10.00 DEGREES
 NUMBER OF BLADES/FAN 5.00
 NUMBER OF FANS 179.

--- DESIGN CONDITIONS ---

VOLUMETRIC FLOW RATE/FAN (ACTUAL) 103393. CU F/MIN
 TOTAL VOLUMETRIC FLOW RATE 18208228. CU F/MIN
 TOTAL AIR PRESSURE DROP OF FAN .01858 PSI
 PRESSURE DROP ACROSS 4 X DUCT .00389 PSI
 NON-RECOVERABLE VELOCITY HEAD .00370 PSI
 TORQUE PER FAN 73. HP
 FAN POWER REQUIREMENTS 12339. HP

--- FAN COSTS ---

BLADE AND HUB COST/FAN 1 5954.
 MOTOR COST/FAN 1 3137.
 SPEED REDUCER COST/FAN 1 2156.
 STACK COST/FAN 1 16107.
 ELECTRICAL COST/FAN 1 15620.

--- ANNUAL OPERATIONAL COSTS \$ 2622501.

DES F	DEG F	OUTLET TEMP	TURBINE	HEAT RATE	BACK PRESSURE	FAN RANGE	HX TIDP	HX LMTD	HX DEG F	ITD DEG F	POWER GENERATED	CHANGE IN FUEL COST	COST TO REPLACE AT AMBIENT TEMP	PCT TIME AT AMBIENT TEMP	INCREMENTAL POWER COST	PORTION OF INCREMENTAL POWER COST
100.0	153.0	8.12	1.0783	26.545	5.237	17.96	48.00	927.914	.10311	1.7301	4.0808	.150	.60912E-02			
95.0	147.5	7.09	1.0596	25.395	5.159	17.75	47.50	942.966	.10611	1.3712	3.7020	1.000	.37020E-01			
90.0	142.0	6.06	1.0410	24.245	5.081	17.54	47.00	958.018	.10911	.79327	3.1240	2.850	.89035E-01			
85.0	136.5	5.03	1.0224	23.095	5.003	17.33	46.50	973.070	.11211	.40556	2.7363	8.230	.23493			
80.0	131.0	4.00	1.0038	21.945	4.925	17.12	46.00	988.122	.11511	.16939	2.5001	9.130	.28228			
75.0	125.5	3.07	1.0015	20.795	4.847	16.91	45.50	1003.174	.11811	.0	0.	10.960	.25998			
70.0	120.0	2.14	1.0015	19.645	4.769	16.70	45.00	1018.226	.12111	0.	0.	11.190	.25998			
65.0	114.5	1.21	1.0015	18.495	4.691	16.49	44.50	1033.278	.12411	0.	0.	56.500	1.3086			
60.0	109.0	0.28	1.0015	17.345	4.613	16.28	44.00	1048.330	.12711	0.	0.	0.	0.			

(1000) FINAL INCREMENTAL COST 2.4136
 CAPACITY CHARGE \$ 6722420.7

FIGURE 5-5. Continued

C A P I T A L C O S T S U M M A R Y

J O I N T E N E R G Y C O S T S U M M A R Y

(100)

C O O L I N G S Y S T E M C A P I T A L	57214936.	1.748544
TURBINE	37314614.	1.14020
HEAT EXCHANGER	1455823.	0.27624
PIPING	175524.	0.54553E=01
VALVES	300250.	0.94433E=01
RAIL SCREENS	U.	U.
FAN SYSTEM	912153.	0.276745
STRUCTURE	533435.	0.165012
FOUNDATION	775737.	0.23703E=01
PIPING	1344820.	0.410914
CONDENSER	545554.	0.147204
CAPACITY PENALTY	9722424.	0.266544
PLANT SCALING	3574121.	0.104220
STEAM SUPPLY	1390271.	0.445463E=01
BASE PLANT	1943851.	0.566235E=01
LAND	U.	U.

(100) TOTAL CAPITAL COST	2.12417
(150) ENERGY PENALTY	0.91462E=01
(160) ADDITIONAL BASE PLANT FUEL	0.97009E=01
(170) OPERATION AND MAINTENANCE	0.100483
(180) TOTAL	2.41359

FIGURE 5-5. Continued

5.3.3 NH₃ Model Output

Complete output from a typical run of the NH₃ model is shown in Figure 5-6. The circled numbers on the figure correspond to the numbers in parentheses in this section. The output report is divided into the following sections:

- (100) through (300) Input Summary
- (400) through (500) Plant scaling for increased steam, and for fans and pumps
- (600) through (700) Heat Exchanger
 - (800) Piping
 - (900) Condenser
 - (1000) Fans
- (1100) through (1200) Plant performance as a function of ambient temperature
- (1300) Cost summary

(100) Output printed by subroutine SETUP.

This line begins a card-by-card summary of input data. Any cards preceding the first blank card are printed as title or description cards. After the first blank card the values are printed as they are read, and the variable name is printed immediately below the value. The line tags A1, B1, etc. correspond to the Card Type designations used in the Input Description (see Section 5.2.3). Variable names printed here are defined in the Input Description section. Every input variable read by the program appears in this summary.

(200) through (230) Output printed by subroutine INPSUM

Some of the more frequently changed input parameters are summarized here with more descriptive labels than are given in the preceding summary.

(205) The options summarized here are those selected by the variables FIXL, DEEPL AND PQMDPL on Card Type B1; VELREC and TLIM on Card Type H1; and NTUCAL on Card Type J1.

(210) The starting point in the search for an optimum is specified by T1, TTD1, AFRON, and WLRAT. These correspond to the values of VAS(1), VAS(3), VAS(4) and VAS(5) on Card Type B1. (The initial value for the temperature range of the air is determined internally by the code.)

(220) Input data pertaining to the turbine are summarized here.

(230) Unit costs and costing factors from Card Types D1 and E1 are reported here.

(300) through (600)

These output report sections are as described in Section 5.3.1.

(700) through (760) Output printed by subroutine RPTHXC.

The heat exchanger design, operating conditions, performance characteristics and costs are reported here.

(710) Fluid flow and heat transfer characteristics are summarized. The term TTD1 is terminal temperature difference, and corresponds to VAS(3) on Card Type B1.

(720) Heat exchanger geometry terms reported here are defined as

$$AFTR = \frac{\text{Fin Area}}{\text{Total Area for Heat Transfer}}$$

$$ALPHA = \frac{\text{Heat Transfer Area (ft}^2\text{)}}{\text{Unit Volume of Heat Exchanger (ft}^3\text{)}}$$

$$SIGMA = \frac{\text{Free Flow Area}}{\text{Frontal Area}}$$

$$\frac{FITCO}{ATOT} = \frac{\text{Finned Tube Cost (\$)}}{\text{Heat Transfer Area (ft}^2\text{)}}$$

(730) Weights of major dry cooling tower components are reported.

(740) The option selected for NTU calculation is shown here, based on NTUCAL input on Card Type J1.

(750) Fluid flow rates and heat exchanger geometry previously printed are repeated here for convenience.

(760) An itemized list of costs associated with fabricating, shipping and installing the heat exchanger.

(800) Output printed by subroutine RPTSUP.

Supply piping costs are itemized separately for circulation piping, quadrant piping, and distribution piping. Pump and piping costs are reported in thousands of dollars (\$ *10**3).

(850) Output printed by subroutine RPTRET. A cost report for the return piping system is provided here.

(900) through (1300)

These sections of the output are as described in Section 5.3.1.

(N1) C65	0.	CDATC	.53000000	ZINCC	2.40000000	EBREPC
FORM REMOVABLE						
(P1) HEDT1B		GALVANIZED	1.12500000	TA		
(Q1) CRJ	2.00000000	CHJ	.53000000	CHH	10.13000000	CHH
(R1) XNS	1.00000000	VELV	1.33000000	JJC	118.00000000	TKCT
(R2) XNS	50.00000000	TLA	.80000000	XJUALY		
(R3) LINJR						
(S1) LFB						
DEF						
(T1) FR4K						

FIGURE 5-6. Continued

(200) INPUT SUMMARY AND CASE DESCRIPTION

(205)
 OPTIONS SELECTED FOR THIS RUN

 (210) STARTING CONDITIONS

UPPER LIMIT ON TURBINE TEMP 153.0 F
 FRICTION FACTOR AND 41 TAPER COEFF BY 9FR
 EXCHANGER DENTH CONSTRAINED TO .5E. 3.7 TUBES
 EXCHANGER LENGTH FIXED AT 40. FEET
 RUN WITH VELOCITY RECOVERY
 VED CALCULATION IS BY EQUATION
 TURBINE OUTLET TEMPERATURE, T1 102.0000
 TERMINAL TEMPERATURE DIFFERENCE T1-T2 3.0000
 FRONTAL AREA AREA 30.0000
 WIDTH TO LENGTH RATIO 0.4000

(210) COEFFICIENTS FOR POLYNOMIAL CURVE FIT
 A1 A2 A3 A4
 HEAT RATE FACTOR AS FUNCTION OF BACKPRESSURE (INCHES OF MERCURY) 1.000000E+01 -4.900000E-03 2.875000E-03 -1.125000E-04
 TURBINE DATING BACKPRESSURE 3.50 INCHES OF MERCURY
 SITE ELEVATION 0010. FEET ABOVE SEA LEVEL

(220) UNIT COSTS AND COSTING FACTORS

.....
 FIVE 51,000 CENTS/MMBTU POWER PLANT CONSTRUCTION 400,000 \$/KW
 LANS 0,000 1/50 FT REPLACEMENT POWER 24,000 MILLS/KWH
 WATERS 30,000 \$ / HP STEAM SUPPLY 145,850 \$/KW TURBINE DUMP
 CAPACITY CHARGE 121000,000 \$/MW
 FIXED CHARGE RATE .174
 CAPACITY FACTOR .650
 BASE THERMAL EFFICIENCY .4000
 CONSTRUCTION COST MULTIPLIER 1.0000
 MAINT COSTS /CAPITAL COSTS .0100

FIGURE 5-6. Continued

300) TO USED IN THE FOLLOWING CALCULATIONS IS = 50.000

400) STEAM SUPPLY SCALING TO COMPENSATE FOR INCREASED HEAT RATE AT RATING BACKPRESSURE. RBPP 3.50 IN. HG HPFAC18 1.010795
 STEAM SUPPLY COST DIFFERENTIAL \$ 1563133. TURBINE COST DIFFERENTIAL 0.3/KW
 PLANT COST INCLUDING STEAM SUPPLY AND TURBINE \$ 441563133. PLANT UNIT COST INCLUDING STEAM SUPPLY AND TURBINE 002.3

500) CONDITIONS AFTER SCALING PLANT AND STEAM SUPPLY (BEFORE SCALING FOR FANS AND PUMPS) HPFAC28 1.0000499
 PSIZ128 989.6629 MM
 PLANC28 437.1069 3/4K
 SP888-2893239.72 \$
 BACK PRESSURE 2.117190 IN. HG
 SAT TEMPERATURE 102.800000 DEG F

AMMONIA FLOW RATE 10700122.2 LB MASS / HR
 HEAT REJECTED 512419205E+10 BTU/HR
 AIR FLOW RATE 509948215. LB MASS / HR
 PUMP POWER 327.957958 KILOWATTS
 FAN POWER 14037.1252 KILOWATTS
 HX SURFACE AREA 37436708.2 SQ FT
 FRONTAL AREA 213000.000 SQ FT
 DIST/LENGTH RATIO 42.6582500
 AIDT4 1.9510 TUBES
 AIDT4 3012.5000 FEET
 CONDENSER WT TUBE AREA 332419.977 SQ FT TOTAL
 NO. CONDENSER TUBES 40674.0000
 CONDENSER TUBE LENGTH 50.000000 FT.
 AMMONIA VELOCITY .751707637 FT/SEC

500) SCALING FOR FAN AND PUMP POWER REQUIREMENTS

AMMONIA FLOW RATE 10356070.5 LB MASS / HR
 HEAT REJECTED 510945454E+10 BTU/HR
 AIR FLOW RATE 515537572. LB MASS / HR
 PUMP POWER 332.747692 KILOWATTS
 FAN POWER 14261.7035 KILOWATTS
 HX SURFACE AREA 37962327.4 SQ FT
 FRONTAL AREA 275979.820 SQ FT
 DIST/LENGTH RATIO 43.2739412
 AIDT4 14722 TUBES
 AIDT4 3452.23530 FEET
 CONDENSER WT TUBE AREA 500172.705 SQ FT TOTAL
 NO. CONDENSER TUBES 41266.9310
 CONDENSER TUBE LENGTH 50.000000 FT.
 AMMONIA VELOCITY .751707537 FT/SEC

SCALING FACTOR 1.010574485
 PSIZE 1000.00000 MM
 PSIZ13 1004.26960 MM
 PTDIAL 1014.57445 MA
 PLANC3 443.077349 3/4K
 SPC 443077349 \$
 SPCD 3477349.25 \$

FIGURE 5-6. Continued

⑥00 NON-OBELITA HEAT EXCHANGER DESCRIPTION

SUPPORT SPACING 5.000 FEET
 TUBE PITCH NORMAL TO AIR FLOW 2.822 INCH
 TUBE PITCH IN DIRECTION OF AIR FLOW 2.440 INCH
 TUBE DIAGONAL PITCH 2.822 INCH
 LIVER GAGE 20.0
 LIVER MATERIAL STEEL WELDED
 LIVER THERMAL CONDUCTIVITY 31.000
 LIVER TUBING OUTSIDE DIAMETER 1.0000 INCH
 LIVER TUBING INSIDE DIAMETER .9300 INCH

*** UNIT COST ***

FIN ROUNDS \$ 0. /50 FT
 PROTECTIVE COATING \$ 0. /50 FT
 ZINC FOR SPACERS \$ 5500 /LB
 SPACER CASTING \$ 2000 /EA
 END PREPARATION \$ 2,400 /TUBE
 LIVER TUBING \$ 32411 /FT
 PROTECTIVE COATING \$ 0. /FT
 FINNING \$ 51691 /FT
 FINNED TUBE \$ 94102 /FT
 TUBE SPACERS \$ 57440 /FT
 HEATER MATERIAL (GALVANIZED) \$ 570/LB
 PULLED JOINT, TUBE TO HEADER \$ 0.000/TUBE
 WELDED JOINT, TUBE TO HEADER \$ 2.000/TUBE
 TUBE AND PLUG HOLE PREPARATION \$ 4500/HOLE
 NOZZEL AND ATTACHING \$ 20.000/HOLE
 BOLTED HEADER JOINT \$ 5.000/FT
 HEATER MACHINING AND WELDING \$ 10.130/FT
 STRUCTURAL STEEL \$ 460/LB

FINNED TUBE \$ 94102 /FT
 TUBE SPACERS \$ 57440 /FT

⑦00 HEAT EXCHANGER

127.2 FANS 1.0 PASS

⑦00 AIR AMMONIA

REYNOLDS NUMBER 9.67437E+03
 VELOCITY (FT/SEC) 1.06005E+01
 PRESSURE DROP (LBS FORCE/SQ IN) 1.46142E-02
 HEAT TRSR COEFF (BTU/HR SQ FT DEG F) 7.60942E+00
 FRICTION FACTOR 7.12148E-01
 INLET TEMPERATURE (F) 5.00000E+01
 EXIT TEMPERATURE (F) 8.49400E+01
 RANGE (F) 3.49400E+01
 (T2) 3.49000E+00
 NTU 1.43942E+00
 OVERALL U (BTU/HR SQ FT DEG F) 5.63490E+00
 EFFECTIVENESS .7627
 FIN EFFICIENCY .8447

FIGURE 5-6. Continued

(700) ALPHA .26834152
 ALPHA 154.72710
 SIGMA .52845074

(700) WT OF AMMONIA
 WT OF TUBES
 WT OF FRAME
 WT OF HEADER
 WT OF STRUT
 RCIP LOAD

102579. LB
 4735531. LB
 1249901. LB
 1104316. LB
 4062237. LB
 11079153. LB (40.00 LB/80 FT)

FITCJATOT .12516534

EQUATION (700) WTU EFFECTIVENESS CORRELATION USES

(700) AMMONIA FLOW RATE 10356070 LBW/4R
 AIR FLOW RATE 615537571 LBW/4R
 TUBES IN DEPTH 4.30 TUBES (9 FT DEEP)
 TUBES ACROSS FRONT 14722 TUBES (3462.2 FT WIDE)

LENGTH NO. FEET
 FRONTAL AREA 275374 SQ FEET
 SURFACE AREA 3792327 SQ FT

(700) COOLING SURFACE \$ 8695739.
 -HEADER AND NOZZEL \$ 1789607.
 BUNDLE ASSEMBLY AND FRAME \$ 2135848.
 PLENUM \$ 125971.
 LOJVERS \$ 0.
 -TAIL SCREENS \$ 738004.
 STRUCTURE \$ 3782724.
 FOUNDATION \$ 323090.
 -HEAT EXCH SHIP AND ERECT \$ 1314543.

FIGURE 5-6. Continued

.....
 (800) SUPPLY PIPING

CIRCULATION PIPING

HEADER	DIAMETER (INCHES)	LENGTH (FEET)	COST IN 10*** DOLLARS FOR			
			PIPE	TEES	REDUCERS	EXPANSION FLANGES JOINT(1) (3)
1	78.0	593.5	1240.1	92.9	84.1	79.5
2	72.0	3.0	0.0	80.2	68.2	
3	66.0	271.6	426.3	67.4	52.3	
4	54.0	3.0	0.0	44.3	26.7	
5	48.0	271.6	228.4	33.7	16.9	
6	36.0	3.0	0.0	16.1	0.0	

TOTAL COST OF CIRCULATION SUPPLY PIPING \$2659. *10***

QUADRANT SUPPLY PIPING

HEADER	DIAMETER (INCHES)	LENGTH (FEET)	COST IN 10*** DOLLARS FOR			
			PIPE	TEES	REDUCERS	
1	18.0	0.0	0.0	1.4	0.0	0.0
2	18.0	9.4	.9	1.4	0.0	0.0
3	18.0	9.4	.9	1.4	0.0	0.0
4	18.0	9.4	.9	1.4	0.0	0.0
5	18.0	9.4	.9	1.4	.8	
6	12.0	10.3	.7	.7	0.0	0.0
7	12.0	10.3	.7	.7	0.0	0.0
8	12.0	10.3	.7	.7	0.0	0.0
9	12.0	10.3	.7	.7	0.0	0.0
10	12.0	10.3	.7	.7	0.0	0.0
11	12.0	10.3	.7	.7	.3	
12	5.0	11.1	.4	.3	0.0	

FITTINGS COST PER BUNDLE \$.340 *10***

COST OF SUPPLY HEADERS PER QUADRANT \$ 25.5 *10***

TOTAL COST OF QUADRANT SUPPLY HEADERS \$ 612. *10***

FIGURE 5-6. Continued

TOWER SUPPLY PIPING

NUMBER OF TOWERS 6
TOWER DIAMETER 184. FEET
DIAMETER OF PIPE FROM CIRCULATION HEADER TO TOWER DISTRIBUTION PIPE 36. INCHES
DIAMETER OF TOWER DISTRIBUTION PIPE 10. INCHES
COST OF DISTRIBUTION PIPING PER TOWER \$ 284. *10**3

TOTAL COST OF TOWER DISTRIBUTION PIPING \$1705. *10**3

MAJOR DESIGN VELOCITY 150. FPM
MASS FLOW RATE 1.070E+07 LB/HR
CONDENSER OUTLET TEMPERATURE 99.40 DEG. F
HEAT EXCHANGER INLET TEMPERATURE 95.41 DEG. F
SUPPLY PIPING PRESSURE DROP 1665.1 PSF
SUPPLY PIPING DYNAMIC HEAD 2535.3 FEET

TOTAL SUPPLY PIPING SYSTEM COST \$ 6021. *10**3

FIGURE 5-6. Continued

.....
 (850) RETURN PIPING

CIRCULATION PIPING

HEADER	DIAMETER (INCHES)	LENGTH (FEET)	PIPE	COST IN 1000'S DOLLARS FOR		
				TEES	REDUCERS	EXPANSION FLANGES JOINT(1) (3)
1	36.0	590.5	429.0	21.7	11.4	16.1
2	30.0	0.0	0.0	12.8	0.0	16.0
3	30.0	271.6	134.4	12.8	6.8	
4	24.0	0.0	0.0	3.9	0.0	
5	20.0	271.6	72.0	3.9	2.2	
6	18.0	0.0	0.0	1.6	0.0	

TOTAL COST OF CIRCULATION RETURN PIPING \$ 610.00000

QUADRANT RETURN PIPING

HEADER	DIAMETER (INCHES)	LENGTH (FEET)	COST IN 1000'S DOLLARS FOR		
			PIPE	TEES	REDUCERS
1	12.0	0.0	0.0	0.0	0.0
2	12.0	10.3	0.0	0.0	0.0
3	5.0	11.1	0.5	0.0	0.0
4	5.0	11.1	0.5	0.0	0.0
5	5.0	11.1	0.5	0.0	0.0
6	5.0	11.1	0.5	0.0	0.0
7	5.0	11.1	0.5	0.0	0.0
8	5.0	11.1	0.5	0.0	0.0
9	5.0	11.1	0.5	0.0	0.0
10	5.0	11.1	0.5	0.0	0.0
11	5.0	11.1	0.5	0.0	0.0
12	5.0	11.1	0.5	0.0	0.0

FITTINGS COST PER BUNDLE \$.78500000

COST OF RETURN HEADERS PER QUADRANT \$ 21.200000

TOTAL COST OF QUADRANT RETURN HEADERS \$ 508.00000

FIGURE 5-6. Continued

TOWER RETURN PIPING
 TOWER DIAMETER 180. FEET
 DIAMETER OF PIPE FROM CIRCULATION
 HEADER TO TOWER DISTRIBUTION HEADER 18. INCHES
 DIAMETER OF TOWER DISTRIBUTION PIPE 12. INCHES
 COST OF DISTRIBUTION PIPING PER TOWER \$ 100. *10**3
 TOTAL COST OF TOWER DISTRIBUTION PIPING \$ 865. *10**3

LIQUID DESIGN VELOCITY 15. FPS
 MASS FLOW RATE 1.01E+07 3M/HR
 RETURN PIPING PRESSURE DROP 430.1 PSF
 RETURN PIPING DYNAMIC HEAD 14.6 FEET

TOTAL RETURN PIPING SYSTEM COST \$ 2115. *10**3

P U M S

PUMP COST	\$	250.*10**3	
PUMP FITTINGS	\$	330.*10**3	
PUMP ELECTRICAL	\$	149.*10**3	
			PUMP STATION \$ 837.*10**3
SEPARATOR COST	\$	1211.*10**3	

FIGURE 5-6. Continued

(900) CONDENSER

--- DESIGN CONDITIONS ---

STEAM TEMPERATURE 102.8 F
 AMMONIA TEMPERATURE 97.4 F
 INLET AMMONIA VELOCITY .75 FT/SEC
 OUTLET AMMONIA VELOCITY 32.71 FT/SEC
 PRESSURE DROP THRU CONDENSER 227.0, 5/33 FT

--- CONDENSER DESCRIPTION ---

NUMBER OF SHELLS 2
 HEAT TRANSFER AREA PER SHELL 28621 SQ FT
 NUMBER OF PASSES PER SHELL 1
 TUBE LENGTH 50 FEET
 NUMBER OF TUBES PER SHELL 20337

(1000) FANS

FANS EQUIPPED WITH VELOCITY RECOVERY DIFFUSERS

--- DRIVE SYSTEM ---

--- FAN GEOMETRY ---
 TUB DIAMETER 60.31 FEET
 BLADE DIAMETER 28.00 FEET
 BLADE ANGLE 19.00 DEGREES
 NUMBER OF BLADES/FAN 6.00
 NUMBER OF FANS 127.

--- FAN COSTS ---

BLADE AND TUB COST/FAN \$ 6966.
 MOTOR COST/FAN \$ 6727.
 SPEED REDUCER DRIVE COST/FAN \$ 19690.
 STACK COST/FAN \$ 15107.
 ELECTRICAL COST/FAN \$ 27636.

--- ANNUAL OPERATIONAL COSTS \$ 3272937.

THE NUMBER OF TIME NO FAN WAS FOUND 5
 THE NUMBER OF TIMES LOCK ESCAPE WAS REQUIRED 0

--- DESIGN OPERATING CONDITIONS ---

OVERALL HEAT TRANSFER COEFFICIENT 2430.09 BTU/M² HR SQ FT DEG F
 STEAM HEAT TRANSFER COEFFICIENT 5093.04 BTU/M² HR SQ FT DEG F
 AMMONIA HEAT TRANSFER COEFFICIENT 13216.35 BTU/M² HR SQ FT DEG F
 WALL HEAT TRANSFER COEFFICIENT 11316.65 BTU/M² HR SQ FT DEG F
 FORCED CONVECTION COEFFICIENT 367.88 BTU/M² HR SQ FT DEG F

--- CONDENSER COSTS ---

TUBING MATERIAL \$ 4805842.01 (LUNDE ALI2
 SHELLS \$ 2179258.70
 FIELD ERECTION \$ 1088218.55
 TOTAL COST OF CONDENSER \$ 8073309.

--- DESIGN CONDITIONS ---

(ACTUAL)
 VOLUMETRIC FLOW RATE/FAN 1317879. CU FT/MIN
 TOTAL VOLUMETRIC FLOW RATE 165264334. CU FT/MIN
 TOTAL AIR PRESSURE DROP IN M.A. .02059 PSI
 PRESSURE DROP ACROSS M.A. BUNDLE .01461 PSI
 NON-RECOVERABLE VELOCITY HEAD .00597 PSI
 MOTOR/BLADE/FAN 130. MP
 FAN POWER REQUIREMENTS 18824. HP

.02500
 .01761
 .00726
 183.

FIGURE 5-6. Continued

(1100) AMBIENT TEMPERATURE		HEAT RATE		BACK PRESSURE FACTOR		RANGE		HX LTDP		HX LMTD		HX ITO		POWER GENERATED		CHANGE IN FUEL COST		COST TO REPLACE		POWER COST AT AMBIENT		PCT TIME PORTION OF INCREMENTAL		
TEMP	OUTLET	FACTOR	IN. HG	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	DEG F	
100.0	152.0	1.0761	5.10	35.574	3.559	25.40	47.93	929.766	.10458	1.7096	3.7414	.150	.50121E+02	3.3943	1.000	3.3943E-01	3.3943	1.000	3.3943E-01	3.3943	1.000	3.3943E-01	3.3943	1.000
95.0	147.6	1.0599	7.10	36.242	3.527	25.21	47.53	943.230	.10458	1.3625	2.825	2.450	2.450	2.8268	2.450	2.450E-01	2.8268	2.450	2.450E-01	2.8268	2.450	2.450E-01	2.8268	2.450
90.0	137.1	1.0444	5.04	35.702	3.474	24.84	46.92	966.790	.10458	.79703	2.456	46.33	46.33	982.758	.10458	.41391	.17700	.41391	.17700	2.4056	5.220	5.220E-01	2.4056	5.220
75.0	127.0	1.0178	4.16	35.335	3.434	24.56	46.33	992.758	.10458	.41391	2.456	46.33	46.33	992.758	.10458	.17700	.41391	.17700	2.4056	5.220	5.220E-01	2.4056	5.220	
65.0	117.1	1.0079	3.19	35.104	3.416	24.39	46.02	992.625	.10458	.17700	2.456	46.02	46.02	992.625	.10458	.41391	.17700	.41391	2.4056	5.220	5.220E-01	2.4056	5.220	
55.0	107.6	1.0023	2.43	34.940	3.404	24.34	45.99	999.236	.10458	.41391	2.456	45.99	45.99	999.236	.10458	.17700	.41391	.17700	2.4056	5.220	5.220E-01	2.4056	5.220	
45.0	98.3	1.0000	1.85	34.813	3.397	24.26	45.77	1001.176	.09436	0.	2.0237	45.77	45.77	1001.176	.09436	0.	2.0237	45.77	1001.176	2.0237	11.190	11.190E-01	2.0237	11.190
35.0	89.2	.9981	1.41	34.643	3.394	24.22	45.71	1002.495	.09436	0.	2.0146	45.71	45.71	1002.495	.09436	0.	2.0146	45.71	1002.495	2.0146	55.500	55.500E-01	2.0146	55.500

(1200) FINAL INCREMENTAL COST 2.1149

CAPACITY CHARGE \$ 4624165.25

FIGURE 5-6. Continued

C A P I T A L C O S T S U M M A R Y

J U N I T E N E R G Y C O S T S U M M A R Y

(300)


C O O L I N G S Y S T E M C A P I T A L	48193339.	1.47290
TOWER	29945029.	.884510
HEAT EXCHANGER	13341736.	.438262
PUMPS	125971.	.384947E-02
TUBES	0.	0.
WALL SCREENS	738034.	.225523E-01
FAN SYSTEM	9943930.	.295928
STRUCTURE	3782725.	.115594
FOUNDATION	323084.	.987325E-02
PIPING	10219210.	.312284
CONDENSER	2051300.	.275094
CAPACITY PENALTY	0.	0.
PLANT SCALING	3477349.	.263541
STEAM SUPPLY	1399924.	.495957E-01
BASE PLANT	1397426.	.576769E-01
LAV	0.	0.

(340) TOTAL CAPITAL COST	1.84270
(350) ENERGY PENALTY	.937157E-01
(360) ADDITIONAL BASE PLANT FUEL	.939232E-01
(370) OPERATION AND MAINTENANCE	.040443E-01
(380) TOTAL	2.11501

FIGURE 5-6. Continued


REFERENCES

1. B. C. Fryer et al., An Engineering and Cost Comparison of Three Different All-Dry Cooling Systems. BNWL-2121, Battelle, Pacific Northwest Laboratories, Richland, WA 99352, September 1976.
2. P. A. Ard et al., Costs and Cost Algorithms for Dry Cooling Tower Systems. BNWL-2123, Battelle, Pacific Northwest Laboratories, Richland, WA 99352, September 1976.
3. F. R. Zaloudek et al., A Study of the Comparative Costs of Five Wet/Dry Cooling Tower Concepts. BNWL-2122, Battelle, Pacific Northwest Laboratories, Richland, WA 99352, September 1976.
4. B. R. Andeen and L. R. Glicksman, Dry Cooling Towers for Cooling Plants. Technical Report 73047-1, Engineering Project Laboratory, Department of Mechanical Engineering, Massachusetts Institute of Technology, Cambridge, MA, February 1972.
5. K. K. Robinson and D. E. Briggs, "Pressure Drop of Air Flowing Across Triangular Pitch Banks of Finned Tubes." Chemical Engineering Progress Symposium Series. 62(64): 1966.
6. D. E. Briggs and E. H. Young, "Convection Heat Transfer and Pressure Drop of Air Flowing Across Triangular Pitch Banks of Finned Tubes." Chemical Engineering Progress Symposium Series. 59(41): 1963.
7. Heat Transfer and Pressure Drop Characteristics of Dry Tower Extended Surfaces, Part I: Heat Transfer and Pressure Drop Data. PFR Engineering Systems, Inc., Marina del Rey, CA, March 1, 1976.
8. Heat Transfer and Pressure Drop Characteristics of Dry Tower Extended Surfaces, Part II: Data Analysis and Correlation. PFR Engineering Systems Inc., Marina del Rey, CA, June 15, 1976.
9. J. P. Rossie et al., Economics of the Use of Surface Condensers with Dry-Type Cooling Systems for Fossil-Fueled and Nuclear Generating Plants. R. W. Beck and Associates, Denver, CO, December 1973.



APPENDIX A

HEAT TRANSFER AND PRESSURE DROP
CORRELATIONS AND DATA BASE



APPENDIX A

HEAT TRANSFER AND PRESSURE DROP CORRELATIONS AND DATA BASE

HEAT TRANSFER COEFFICIENT AND FRICTION FACTOR FOR METAL FINNED TUBE HEAT EXCHANGERS

The performance of the metal finned tube heat exchanger is determined using the water-side and air-side heat transfer coefficients and friction factors. The performance is also influenced by the thermal resistance of the tube wall and fin, air-side and water-side fouling, and contact resistance at the liner-fin interface. For given values of the water and air flow rates and heat exchanger size, the prediction of the heat transfer coefficients and friction factors establishes the pumping power, fan power, and total heat load of the heat exchanger.

WATER-SIDE

The water-side performance parameters are calculated from established correlations discussed below.

Friction Factor

The friction factor is predicted from the Blasius equation⁽¹⁾ for flow in a circular conduit. The Blasius equation generally applies to the turbulent flow regime for Reynolds numbers up to 10^5 . The range of Reynolds numbers observed in the parametric studies was 3×10^4 to 7×10^4 , well within the limits of the Blasius equation. Other correlations are programmed for Reynolds numbers below 200 and above 10^5 , but such conditions have not been shown to be economically attractive.

To evaluate the Reynolds numbers, the range of tube inside diameters was 0.680 to 1.908 inches. The optimized water velocity in the tubes ranged between 1.0 and 7.0 feet per second with the lower velocities characteristic of the larger diameter tubes.

Heat Transfer Coefficient

The water-side heat transfer coefficient is predicted with the Dittus-Boelter correlation⁽⁷⁾ for turbulent flow in tubes. This correlation is applicable to Reynolds numbers greater than 10^4 , a condition that was met for all observed cases in the parametric studies.

AIR-SIDE

The air-side performance parameters are not as well established as their water-side counterparts. The performance of a particular finned tube may vary significantly from the performance that would be predicted from any of the available correlations. This causes substantial concern because the performance of the heat exchanger, and thus, the accuracy of the economic analysis, is dominated by the air-side conditions.

It is the purpose of this section to present the two sets of correlations that were available for the optimization studies. The correlations will be evaluated by comparing them against each other and by comparing the performance predictions against actual finned tube experimental data. One set of correlations uses a friction factor developed by Briggs & Robinson⁽²⁾ and a heat transfer coefficient developed by Briggs & Young.⁽³⁾ The other set of correlations was developed by PFR Engineering Systems, Inc.,⁽⁴⁾ at the request of PNL. The PFR correlations were used exclusively in the parametric studies of SOA and ammonia loop all-dry cooling systems using the metal finned tube heat exchanger. Both sets of air-side performance correlations apply only to staggered rows of finned tubes. Emphasis has been given to the analysis of the staggered tube arrangement because it has been shown to be economically more acceptable than the inline arrangement.^(4,5)

In addition to developing the correlations, the PFR study was commissioned to collect performance data and to develop a figure of merit for the selection of finned tubes. The collection and review of finned tube air-side performance data is possibly the most thorough work of its kind available.⁽⁶⁾ The PFR correlation was developed in consideration of all of this data.

The meaning of a "figure-of-merit" is that one could determine the economically optimum or near optimum finned tube unit geometry by considering only the performance of the finned tube, that is, without consideration of the economics of the entire cooling system. The attempt at PNL to develop a reliable and meaningful figure-of-merit has been unsuccessful. It is now evident that it is difficult, if not impossible, to successfully disassociate the economics of any one component from the remainder of the cooling system.

Friction Factor

Briggs and Robinson Correlation⁽²⁾

The friction factor correlation developed by Briggs and Robinson is

$$f = 18.93 \left(\frac{P_t}{D_r}\right)^{-0.927} \left(\frac{P_t}{P_d}\right)^{.515} Re_r^{-.316} \quad (1)$$

where

P_t = tube pitch normal to air flow

D_r = root diameter

P_d = tube pitch measured on diagonal between staggered tubes

Re_r = Reynolds number based on root diameter and the velocity at minimum cross section.

See Figure A-1 for a pictorial definition of these terms.

The friction factor was defined according to

$$f = \frac{\rho g_c \Delta P}{N G_m^2} \quad (2)$$

where

ρ = air density

g_c = gravitational constant

ΔP = pressure drop across heat exchanger

N = tube rows in direction of air flow

G_m = air mass velocity at minimum cross section normal to direction of flow.





FIGURE A-1. Finned Tube Unit Geometry and Tube Pitch Parameters

The correlation, equation (1), applies to staggered tube arrangements. For equilaterally spaced tubes, the ratio of P_t/P_d is unity.

The range and variety of unit geometry variables for which the correlation was developed are relatively small. The range of the unit geometry variables was: root diameter (0.734 in. to 1.610 in.); fin diameter (1.561 in. to 2.750 in.); fin height (0.414 in. to 0.570 in.); fin thickness (0.0158 in. to 0.0235 in.); fin spacing (0.0729 in. to 0.1086 in.); and fins per inch (7.90 to 10.94). The tube pitch was varied between 1.687 inches and 4.500 inches with equilateral and isosceles arrangements being considered. Although the range of values is considered somewhat restricted, the near optimum unit geometry, as determined by the parametric studies, is bracketed by these values.

PFR Correlation

The friction factor correlations developed by PFR Engineering Systems, Inc., (4) are:

$$f = \left(\frac{150}{Re_h} + \frac{1.8}{Re_h \cdot 2} \right) \left(\frac{P_1}{D_h} \right)^{.35} \quad \text{for } \frac{P_1}{D_h} > 4, \quad (3)$$

and

$$f = 13.6 Re_h^{-.3} \left(\frac{P_1}{D_h} \right)^{-.42} \quad \text{for } \frac{P_1}{D_h} \leq 4, \quad (4)$$

where

Re_h = Reynolds number based on hydraulic diameter and the velocity at minimum cross section

P_1 = tube pitch in direction of air flow

D_h = hydraulic diameter

PFR used the following equation to define friction factor:

$$f = \frac{2 \rho g_c \Delta P}{N G_m^2} \quad (5)$$

The terms in the equation (5) were defined with equation (2). The correlations developed by PFR were multiplied by one-half so that they would be defined on a basis identical to that of the Briggs and Robinson correlation; that is $f = \rho g_c \Delta P / N G_m^2$. This allowed the comparison of the correlations.

The hydraulic diameter is defined as

$$D_h = \frac{4L}{N} \frac{A_c}{A_t} \quad (6)$$

where

- L = depth of heat exchanger from leading edge of the first row of tubes to trailing edge of last row of tubes
- A_c = minimum flow area between tubes normal to direction of air flow
- A_t = heat transfer area per foot of finned tube
- N = tube rows in direction of flow.

The PFR correlation was developed in order to include a large amount of data from many sources into a comprehensive, accurate correlation. An extensive quantity of data was reviewed to filter out the data that was considered to have been taken under questionable conditions. For example, friction factor data obtained from any module having less than five transverse tube rows was considered to have unacceptable edge effects. Some of the data was reanalyzed so that all the data could be reported on a common basis. All unit geometries were given equal weighting in the development of the correlation. The range of unit geometry variables was: root diameter (0.188 in. to 2.000 in.); fin diameter (0.375 in. to 3.250 in.); fin height (0.094 in. to 0.875 in.); fin thickness (0.008 in. to 0.080 in.); fin spacing (0.025 in. to 0.200 in.); and fins per inch (4.0 to 30.0).

Comparison of Friction Factor Correlations

The basic difference between the two friction factor correlations is the defining length for the Reynolds number. The PFR correlation uses hydraulic diameter. The hydraulic diameter is based upon the root diameter and the fin geometry parameters including fin thickness, fins per inch, and

fin height. Briggs and Robinson use the root diameter which is the only unit geometry variable that appears explicitly in their correlation. While the Briggs and Robinson correlation does not explicitly include the effects of the fin geometry, changes in these parameters will cause a change in the friction factor predicted by the correlation. For example, if the fin thickness were increased and all other variables were unchanged, the air velocity through the minimum cross section would increase because of the increased restriction of the flow path. The velocity increase would result in a higher Reynolds number and, therefore, a slightly lower friction factor. The velocity increase would show up most dramatically as an increase in the air-side pressure drop.

While the use of the hydraulic diameter yields a correlation that is more explicitly sensitive to changes in some unit geometry variables, it is not certain that it yields a superior correlation. This may be especially true when the correlation is applied to near optimum unit geometries. Recall that the range of unit geometry variables which were used to develop the Briggs and Robinson correlation encompassed the near optimum values. The interest here is primarily in the near optimum unit geometries. In view of this emphasis, it is possible that the Briggs and Robinson correlation could be, in fact, the better correlation to use in this analysis. In other words, it could be postulated that in order to achieve general applicability, the PFR correlation was developed with a sacrifice in accuracy for specific unit geometries. Therefore, one should not draw conclusions regarding the applicability of either correlation based solely on the functional form.

To evaluate how the correlations compare, friction factors have been calculated for the near optimum unit geometry (NOUG) and for several other surfaces. These are compared in Table A-1 for a root diameter Reynolds number of 10^4 , which is near optimum. (The PFR correlation can be converted to a root diameter Reynolds number form by replacing Re_h by $Re_r D_h / D_r$.)

These surfaces were selected from the PFR report on the basis of their approach to the near optimum unit geometry. The surfaces and the corresponding data are from several sources, including Briggs and Robinson (surfaces 75B

TABLE A-1. Comparison of Friction Factors
 Calculated from the Two Avail-
 able Correlations Against Actual
 Finned Tube Data from Reference 6

<u>Surface*</u>	<u>Briggs & Robinson</u>	<u>PFR</u>	<u>Actual Data</u>
NOUG	.458	.771	--
75B	.363	.403	.331
78E	.512	.581	.430
80	.454	.558	.473
83	.513	.611	.704
84	.614	.803	.775
85	.509	.597	.743
86	.428	.620	.494
97	.400	.422	.395
108D	.542	.866	.613
109C	.404	.562	.394
120A	.518	.572	.840
143A	.456	.620	.467
144	.441	.855	.612
145A	.462	.689	.685
201	.513	.606	.756

*The surface numbers apply the the page numbers in
 the PFR report. (6)

and 78E). Surface 97 is the only surface that is not equilateral; the tube pitch in the direction of air flow (P_l) is 1.75 inches while the tube pitch normal to air flow (P_t) is 1.56 inches. Surfaces 144 and 145A are the closest available to an optimum unit geometry, while surface 143A is also very close.

The PFR friction factor exceeds the data for eleven of the fifteen observed cases. The Briggs and Robinson friction factor exceeds the data only four times. On this basis and by observing the result for the near optimum unit geometry one can conclude that the PFR correlation is significantly more conservative in terms of friction factor. If one were to develop a cooling system design using air flow characteristics predicted by a correlation, then the PFR correlation would be the likely choice. But, with the significant variation between the data and the correlations it can be concluded that the only way to obtain a reliable performance prediction, such as would be required in the actual design of a power plant cooling system, is to test the candidate finned tube under conditions similar to that of the proposed application.

Even though the friction factors are considerably different, the differences in the cooling system designs using either correlation are very subtle. Table A-2 presents optimized designs using either correlation with a near optimum set of input variables. The fan power is proportional to the product of the friction factor, the tube rows in depth, and the cube of the air velocity. Since the PFR friction factor is relatively high, the fan power must be kept down by reducing the tube rows in depth and the velocity. Reducing the velocity by only 15 percent reduces the cube of the velocity by nearly 40 percent. Both designs presented in Table A-2 require about the same heat transfer area. Therefore, the reduced heat exchanger depth for the PFR design results in a greater overall heat exchanger width which is reflected as an increase in the number of towers while the tower diameter remained nearly constant.

TABLE A-2. Comparison of Cooling System Designs Developed from the PFR Correlations and the Correlations of Briggs and Robinson and Briggs and Young

Tube Description: Liner OD = 1.00 in.
 Fin OD = 2.57 in.
 Fins/Inch = 10.0
 Fin Thickness = 0.018 in.
 Wrap-On Aluminum Fins
 Carbon Steel Liner

DESIGN PARAMETERS	Air-Side Performance Correlation	
	PFR	Briggs & Robinson
Air Flow Rate, 10^8 lb/hr	8.65	7.54
Air Range, °F	25.2	28.9
Air Velocity, ft/sec	17.1	20.1
Friction Factor	0.850	0.473
$\Delta P_{\text{air,HX}}$, psi	0.0113	0.0126
$\Delta P_{\text{air,discharge}}$, psi	0.0064	0.0071
Fan Power, MWe	17.2	16.3
Fans Number/Dia, ft	37/60	31/60
Water Flow Rate, 10^8 lb/hr	2.08	2.10
Water Range, °F	25.2	24.9
Pump Power, MWe	6.35	6.15
LMTD, °F	20.4	18.6
ITD, °F	45.6	45.6
h , Btu/hr/ft ² /°F	7.23	7.62
U , Btu/hr/ft ² /°F	5.21	5.36
HX Heat Transfer Area, 10^6 /ft ²	52.3	56.6
HX Width/Length, ft/ft	5710/80	4260/80
HX Depth Rows	3.27	4.74
Total HX Tubes	87200	94100
Towers Number/Dia, ft	12/148	8/166
<u>COST SUMMARY</u>		
Cooling System, mills/kWh	1.95	1.80
Capacity, mills/kWh	0.27	0.27
Scaling, mills/kWh	0.22	0.20
Energy, mills/kWh	0.09	0.09
Base Fuel, mills/kWh	0.15	0.15
O&M, mills/kWh	0.11	0.10
Total Incr. Cost, mills/kWh	2.80	2.61

The difference in air velocities and tower configuration between designs using the different correlations results in different fan system requirements. As a consequence of these basic differences in the trade-offs that determine the optimum designs, the incremental power production cost for a design developed with the PFR correlation is calculated to be about seven percent higher than when the Briggs and Robinson correlation is used. When comparing the metal finned tube systems (SOA and ammonia) to the plastic systems, this cost difference should be kept in mind. Use of the Briggs and Robinson correlation would widen the gap between the costs of the ammonia system and the plastic system.

Heat Transfer Coefficient

Briggs and Young Correlation

The correlation for the heat transfer coefficient developed by Briggs and Young is

$$h = 0.134 \frac{k}{D_r} Pr^{.333} \left(\frac{s}{l}\right)^{.200} \left(\frac{s}{t}\right)^{.1134} Re_r^{.681} \quad (7)$$

where

k = thermal conductivity of air

D_r = root diameter

Pr = Prandtl number of air

s = spacing between fins

l = fin height

t = fin thickness

Re_r = Reynolds number based on root diameter and air velocity at minimum cross section.

This correlation applies to both equilateral and isosceles staggered tube arrangements as it was concluded by Briggs and Young that tube pitch had a negligible effect upon heat transfer.

As with the Briggs and Robinson correlation for friction factor, this correlation was developed from an investigation of a relatively narrow range of unit geometry variables. However, the ranges include the near

optimum unit geometry. The range of the unit geometry variables was: root diameter (.438 in. to 1.610 in.); fin diameter (.737 in. to 2.750 in.); fin height (0 in. to .656 in.); fin thickness (0.13 in. to .080 in.); fin spacing (.035 in. to .117 in.); and fins per inch (6.3 to 19.5). The tube pitch was varied between .964 inches and 4.370 inches.

PFR Correlation

The heat transfer correlation developed by PFR is

$$h = 0.290 \frac{k}{D_r} Pr^{.333} \left(\frac{A_o}{A_r}\right)^{-.17} Re_r^{.633} \quad (8)$$

where

k = thermal conductivity of air

D_r = root diameter

Pr = Prandtl number of air

A_o/A_r = ratio of total finned tube area to base tube area

Re_r = Reynolds number based on root diameter and air velocity at minimum cross section.

This correlation applies to both equilateral and isosceles staggered tube arrangements. Notice that the Reynolds number is defined here with the root diameter whereas the friction factor correlation of PFR uses a Reynolds number based on hydraulic diameter.

The data used in the development of the heat transfer correlation was screened in a fashion similar to that for the friction factor correlation. For example, all the tubes in the tube bank must have been heated in order to obtain usable heat transfer data; any other heating arrangement was considered to be unacceptable.

The range of unit geometry variables used to develop this correlation is about the same as is presented for the PFR friction factor, except in some cases where some finned tube data compiled by PFR was lacking in either heat transfer data or friction factor data. Regardless, the range of unit geometry is significantly broader here than the Briggs and Young heat transfer work. Similar arguments apply as to whether or not this is

actually an improvement. That is, to achieve a correlation applicable to such a wide range of conditions, there may be a sacrifice of accuracy for specific unit geometries.

Comparison of Heat Transfer Correlations

An indication of the acceptability of either correlation is how they compare against each other and against actual data. Both correlations include the effects of fin thickness, fin pitch, and fin height, as well as the other pertinent variables. This was not the case with the friction factor correlations as the Briggs and Robinson correlation did not explicitly include the effect of these unit geometry variables.

Table A-3 compares heat transfer coefficients for a Reynolds number of 10^4 for the same surfaces as were compared for friction factor. In this case, surfaces have been excluded because heat transfer data were not available. These surfaces were chosen for comparison on the basis of their approach to the near optimum unit geometry (NOUG).

The agreement between the correlations and the data is obviously quite good. It appears that either correlation would be highly adequate for a generalized parametric study of this kind.

TABLE A-3. Comparison of Heat Transfer Coefficients Calculations Against Actual Finned Tube Data from Reference 6

<u>Surface</u>	<u>B&Y</u>	<u>PFR</u>	<u>Actual Data</u>
NOUG	8.54	8.16	--
80	10.01	10.66	9.43
83	9.80	9.70	9.13
84	6.30	6.40	6.75
85	8.85	8.82	7.92
86	9.32	9.94	8.88
97	16.23	16.41	21.11
143A	10.75	11.34	11.45
144	6.57	7.05	7.79
145A	9.27	9.37	9.98
201	8.85	8.82	9.19

The relatively high heat transfer coefficient of surface 97 in Table A-1 shows that this surface also has one of the lowest friction factors. This would seem to make surface 97 an ideal surface. However, surface 97 has the smallest root diameter (0.630 in.) and shortest fins (0.404 in.) of all the surfaces used in the comparison. This makes the heat transfer area per foot of finned tube relatively small. The cost of a unit of finned tube surface area is, therefore, relatively high.⁽⁷⁾ The trade-offs that determine the optimum unit geometry go further than the simple trade-off between the unit cost and the performance of the surface. The trade-offs are dealt with more thoroughly in Section 6.2 of this report. As a result of considerations of unit cost and performance, as well as considerations of all other economic trade-offs, surface 97 is not necessarily superior to the others on an economic basis.

DISCUSSION

The parametric optimization studies indicate which value of a certain parameter results in the economically optimum cooling system design. By studying this parameter over a range of values on either side of the optimum it is possible to determine the sensitivity of costs and cooling system design to changes in this parameter. Determination of the optimum and the design and cost trends about the optimum of each independent parameter form the results of this study. It is generally true that similar trends and optimums are observed regardless of which set of air-side performance correlations has been used. This holds as long as each correlation is applied within the ranges of the variables for which it was developed.

For the purposes of development of an accurate code, it was difficult to assess which set of correlations would be more acceptable. If the attempt was to design a cooling system that was guaranteed to have a minimum heat rate capability, then one would certainly use actual data after scoping the problem using the more conservative PFR correlations. However, it is the purpose of the code to evaluate the relative economics of different designs. To do this most effectively, it would be necessary to have the same degree of

conservatism as it affects the cost of power in all the cost models, physical models, assumptions, and correlations. This same conservatism would have to be applied to the descriptions of the advanced systems also. It is not realistic to expect that this could be done. The best available models were used with the hope that the conservatism in any one model was not so unbalanced that it would prevent an accurate identification of the true optimum. In this regard, either set of air-side performance correlations is probably acceptable.

HEAT TRANSFER COEFFICIENT AND FRICTION FACTOR CORRELATIONS
FOR PLASTIC TUBE HEAT EXCHANGERS

Heat transfer coefficient and friction factor correlations used in the optimization of a plastic tube dry cooling tower system for an electric generation plant are presented in this section. In the optimization procedure used for this system, the correlations presented here were the basis for determining the size of the cooling tower system and the mode in which it operated. The total cost of the system is highly dependent upon the values obtained from these correlations.

The heat transfer and pressure drop correlations presented here fall into two categories: air-side and water-side. The air-side is further subdivided into inline or staggered tube spacing (pitch) categories.

The nomenclature for these correlations is on page A-22.

WATER-SIDE

Friction Factor

The water-side pressure drop is determined through the use of a Fanning friction factor relationship for smooth tubes. The Fanning pressure drop equation is used in the following form:

$$\Delta p = 4f \frac{L}{D} (\rho V^2 / 2g_c) \quad (9)$$

The friction factor is provided by correlations covering three Reynolds number ranges:

- Laminar Range, ($0 < Re < 2000$):

$$f = 16/Re \quad (10a)$$

- Transitional ($2000 < Re < 1 \times 10^5$):

$$f = 0.0791/(Re)^{0.25} \quad (10b)$$

- Turbulent ($Re > 1 \times 10^5$):

$$f = 0.046/(Re)^{0.20} \quad (10c)$$

The water flow rate for the optimum plastic tubed system is in the transitional flow regime.

Heat Transfer Coefficient

The water-side heat transfer coefficient is estimated through the use of the Dittus-Boelter correlation⁽⁸⁾ or the laminar flow relationship of W. Nusselt⁽⁹⁾ depending on the flow regime of the cooling water.

Those relationships are expressed in the following form:

- Dittus-Boelter correlation (transitional-turbulent, $Re > 2400$):

$$h = 0.023(Re)^{0.80}(Pr)^{0.40} \text{ k/D} \quad (11a)$$

- Nusselt Relationship (laminar, $Re < 2400$):

$$h = 3.66 \text{ k/D} \quad (11b)$$

For the range of parameters selected, the Reynolds number and velocities through the tubes vary from 3000 to 5000 and 1.00 to 4.00 ft/sec, respectively. This is in the region of transitional flow. The heat transfer coefficient is highly dependent upon the state of turbulence of the cooling water in the tube. The turbulent flow is preferred because it gives a higher heat transfer coefficient for only a slight increase in pressure drop. This is the case which is most likely to exist due to the high amount of turbulence which will exist in the headers. Only when the Reynolds number of the tube flow is below 2400 is Equation (11b) used.

AIR-SIDE

A literature search on the subject of air side heat transfer coefficient and friction factor through banks of bare tubes was provided to the Dry Cooling Tower Program at PNL by Dr. Knudson of Oregon State University. Reference 10 provided the most complete information. Prior to this literature search, correlations provided in Reference 11 had been used as the basis for the analysis.

Pressure Drop

The air-side pressure drop through a bank of tubes is determined through the use of a Fanning friction factor relationship,

$$\Delta p = 4fN(\rho V_{\max}^2 / 2g_c) \quad (12)$$

The friction factor for both the inline and staggered tube arrangement were obtained from McAdams. (11)

Incorporation of information from Reference 9 into the optimization code would have required converting friction factor data from graphic to tabular form. Because this would have introduced an additional error into the computation scheme, the decision was made to use McAdams' information in the optimization code.

Staggered Tube Arrangement

The friction factor relationship provided by McAdams for a staggered tube arrangement is

$$f = (0.25 + \frac{0.1175}{(X_T - 1)^{1.08}}) (Re_{\max})^{-0.16}. \quad (13a)$$

Inline Tube Arrangement

Inline tube arrangement friction factor is provided by

$$f = (0.044 + \frac{0.08X_L}{(X_T - 1)^N}) (Re_{\max})^{-0.15} \quad (13b)$$

in which $N = 0.43 + (1.13/X_L)$.

In the above relationships, X_L is the ratio of the longitudinal pitch to the tube outside diameter. X_T is the ratio of the transverse pitch to tube outside diameter. All pitches are measured from centerline to centerline.

Equations (13a) and (13b) are based on data which cover a Reynolds number range of 2000 to 4×10^4 .

For the range of parameters selected in the optimization of the plastic tube advanced concept, the air-side Reynolds number varied from 500 to 5000. The air velocity at the minimum cross-sectional flow area ranged from 7.0 to 15.0 feet per second. The Reynolds number range lies within the laminar and transitional flow regimes.

The Reynolds number range straddles the lower limit of the friction factor relationships for both staggered and inline tube arrangements. To verify that these relationships give friction factors within a reasonable limit of actual data in the region less than 2000, they were compared against Zukauskas' data.⁽¹⁰⁾ It was found that down to a Reynolds number of 500, friction factors calculated by equations (13a) and (13b) were within acceptable limits of actual data.

Heat Transfer Coefficient

The air-side heat transfer correlations for a bank of bare tubes are taken from McAdams⁽¹¹⁾ and Zukauskas.⁽¹⁰⁾ The Zukauskas correlations appear to be based on more complete data than those of McAdams. Although both sets of correlations are provided in the optimization code, only Zukauskas' correlations were used in the optimization of the plastic tube advanced concept.

Staggered Tube Arrangement

McAdams recommends the relationship below for gases flowing normal to banks of staggered tubes for a Reynolds number from 2000 to 32000:

$$h = 0.33(\text{Pr})^{0.33}(\text{Re})^{0.60} \text{ k/D} \quad (14)$$

Zukauska recommends the following set of relationships for determining the heat transfer rates in banks of tubes:

- Laminar, $10 < \text{Re} < 100$:

$$h = 0.90(\text{Re})^{0.40} (\text{Pr})^{0.36} \text{ k/D} \quad (15a)$$

- Transitional, $1000 < Re < 2 \times 10^5$:

For $a/b < 2$,

$$h = 0.35(a/b)^{0.2}(Re)^{0.60}(Pr)^{0.36} k/D \quad (15b)$$

For $a/b > 2$,

$$h = 0.40(Re)^{0.60}(Pr)^{0.36} k/D \quad (15c)$$

- Turbulent, $Re > 2 \times 10^5$:

$$h = 0.022(Re)^{0.84}(Pr)^{0.36} k/D \quad (15d)$$

The Reynolds number region from 100 to 1000 is a transitional flow regime from laminar to turbulent, which is not covered by any correlation in Zukauskas' article. For completeness, correlations were derived for this region through use of an equation of the following form:

$$h = c(Re)^m(Pr)^{0.36} k/D$$

The constants c and m were determined by forcing this equation to fit values obtained at Re of 100 and 1000 by equations (15a-c). The resulting equations are:

- $100 < Re < 1000$

For $a/b < 2$,

$$h = c(Re)^m(Pr)^{0.36} k/D. \quad (16a)$$

where

$$c = 0.3755(100)^{(-0.02 \log_{10} (a/b))}$$

$$m = 0.58983 + 0.2 \log_{10} (a/b)$$

For $a/b \geq 2$,

$$h = 0.28(Re)^{0.65}(Pr)^{0.36} k/D \quad (16b)$$

Inline Tube Arrangement

Only one set of correlations is used for the heat transfer in an inline tube bundle. These were taken from Zukauskas.⁽¹⁰⁾ Again, the region from a Reynolds number of 100 to 1000 was not covered by a specific relationship. A relationship was derived from data obtained from adjacent correlations.

- Laminar, $10 < Re < 100$:

$$h = 0.80(Re)^{0.40}(Pr)^{0.36} \text{ k/D} \quad (17a)$$

- Transitional:

For $100 < Re < 1000$,

$$h = 0.293(Re)^{0.618}(Pr)^{0.36} \text{ k/D} \quad (17b)$$

For $1000 < Re < 2 \times 10^5$,

$$h = 0.27(Re)^{0.63}(Pr)^{0.36} \text{ k/D} \quad (17c)$$

- Turbulent, $Re > 2 \times 10^5$,

$$h = 0.021(Re)^{0.84}(Pr)^{0.36} \text{ k/D.} \quad (17d)$$

The range of Reynolds numbers found to be optimum for the plastic tube advanced concept is from 500 to 5000. This range includes the region in which heat transfer correlations were not available from Zukauskas. As described earlier, this region was accommodated by relationships derived from data obtained from adjacent correlations.

NOMENCLATURE

- f - Fanning friction factor
- h - heat transfer coefficient (Btu/hr-ft²-°F)
- k - thermal conductivity (Btu/hr-ft-°F)
- μ - viscosity (lbm/ft-hr)
- C_p - specific heat (Btu/lbm-°F)
- ρ - density (lbm/ft³)
- V - velocity (ft/sec)
- L - tube length
- D - diameter
- N - number of tubes in depth
- g_c - gravitational constant
- a - transverse pitch
- b - longitudinal pitch
- X_T - a/D
- X_L - b/D
- Re - ρVD/μ
- Pr - C_pμ/k
- Nu - hD/k

HEAT TRANSFER COEFFICIENT AND FRICTION FACTOR
CORRELATIONS FOR THE AMMONIA COOLING LOOP

CONDENSER/REBOILER

The condenser/reboiler is similar in design to that of a conventional water shell and tube condenser. The differences are:

- ammonia instead of water passes through the tubes, and
- header wall thickness is increased to provide sufficient strength to withstand the pressure of the ammonia.

Condenser designs were considered with the smooth tubing used in commercial condensers built and used today and with enhanced tubing. The enhanced tubes have better heat transfer coefficients obtained by use of sintered metal on the inside surface and by use of a proprietary outside surface developed by LINDE Division of Union Carbide.

The nomenclature for correlations given in this section is found on page A-36.

Heat Transfer Correlations

Smooth Tubing

The design of the condenser/reboiler with smooth tubing is accomplished by determining the number and length of tubes in the condenser. This is done by finding the average overall coefficient for a specific temperature difference, heat load, and tube length. To find the overall coefficient the average inside and outside heat transfer coefficients of the horizontal tubes must be determined. The outside coefficient must take into account steam velocity, condensate film thickness, and condensate film buildup and removal due to splashing down from one tube to the next in a bank of tubes. The following correlation, used to handle these effects, was derived by Nusselt⁽¹²⁾ and modified by Kern.

$$h_s = .728 \left(\frac{g \rho_L (\rho_L - \rho_v) k_L^3 h_{fg}}{D_o \mu_L \Delta T_s} \right)^{1/4} \left(\frac{1}{N} \right)^{1/6} \quad (18)$$

The original equation by Nusselt was derived with the number of tubes in depth (N) in the tube bank taken to the 1/4 power. Kern later modified the equation by changing it to the 1/6 power so that conditions in the condenser could be better predicted.

The steam-side coefficient obtained from equation (12) by the optimization code typically ranges from 1000 to 1500 Btu/hr-°F-ft² for the smooth tubing.

The inside heat transfer coefficient of the smooth tubing is composed of the sum of nucleate boiling and forced convection heat transfer:

$$h_i = h_{fc} + h_B \quad (19)$$

The forced convection coefficient in equation (19) is found by the correlation developed by Dittus-Boelter:⁽⁸⁾

$$h_{fc} = .023 Re_L^{.8} Pr_L^{.4} k_L/D_i \quad (20)$$

The range of values obtained from this correlation by the optimization code is from 200 to 500 Btu/hr-°F-ft² with liquid inlet velocities into the tubes varying from 0.5 ft/sec to 1.5 ft/sec. The boiling coefficient is obtained from the correlation developed by Rohsenow:⁽¹³⁾

$$h_B = (Cp_L/h_{fg}(.015)Pr_L^{1.7})^3 \frac{\mu_L h_{fg} \Delta T_a^2}{\sqrt{\frac{\sigma}{\rho_L - \rho_V}}} \quad (21)$$

The boiling coefficient ranges from 800 to 1200 Btu/hr-°F-ft² in the optimization code.

Enhanced Tubing

Design of the condenser/reboiler with enhanced tubing is done by the same method as for smooth tubing. Different heat transfer correlations are used to obtain the inside and outside coefficients of the horizontal tubes. The correlations used for the enhanced surfaces are derived from experimental data obtained from Union Carbide Corporation, LINDE Division. The correlations are derived from two data points of heat flux versus temperature difference.

The steam-side correlation is derived from experimental data⁽¹⁴⁾ for steam condensing at one atmosphere on the outside of a single horizontal tube. The correlation is used for pressures below one atmosphere with the assumption that the effect of pressure does not have a large influence on the condensation coefficient. The influence of condensate film buildup due to the film of one tube falling on another tube in a tube bank is taken care of by adding to the experimental correlation the relationship for the tube bank depth (N) from equation (18). The following correlation is used to describe the condensation process.

$$h_s = 16700 \Delta T_s^{-.572} \left(\frac{1}{N}\right)^{1/6} \quad (22)$$

The steam-side coefficients obtained by the code from equation (22) range in values from 3000 to 6000 Btu/hr-°F-ft².

The heat transfer correlation for the ammonia-side of the enhanced tubing includes, as before, the effect of two processes; nucleate boiling and forced convection heat transfer. It is assumed that the forced convection correlation does not change from equation (21). The boiling correlation does change with the change in the tubing. The boiling correlation used was developed from experimental data⁽¹⁴⁾ for a piece of the enhanced surface heated in a pool of ammonia so that boiling occurred at different temperatures of the surface. The correlation takes the form:

$$h_B = 18000 \Delta T_a^{1.72}. \quad (23)$$

The boiling coefficients obtained from equation (23) by the optimization code range in values from 14,000 to 20,000 Btu/hr-°F-ft².

Pressure Drop Correlations

Smooth Tubing

The correlation used to determine the pressure drop in the smooth tubes of the condenser/reboiler was developed by Lockhart and Martinelli⁽¹⁵⁾ for two-phase flow:

$$\Delta P = \phi_L^2 f_L \frac{L}{D_i} \frac{G_L^2}{\rho_L} \quad (24)$$

The Martinelli function (ϕ_L) is provided by a curve fit of the Lockhart-Martinelli parameter (X):

$$X = f_L G_L^2 \rho_V / f_V G_V^2 \rho_L \quad (25)$$

The Fanning friction factor (f) is provided by four separate correlations covering three different regimes of flow. The regimes are differentiated by four ranges of Reynolds numbers.

- Laminar Regime ($0 < Re \leq 1600$)
 $f = 16/Re \quad (26)$

- Transition Regime ($1600 < Re \leq 3950$)
 $f = .01 \quad (27)$

- Turbulent Regime ($3950 < Re \leq 52,000$)
 $f = .0791/Re^{.25} \quad (28)$

- Turbulent Regime ($52,000 \leq Re$)
 $f = .046/Re^{.20} \quad (29)$

The flow regime usually found by the code is the turbulent flow regime. The pressure drops are within one-half to two pounds per square inch.

Enhanced Tubing

The method used to determine the pressure drop through the enhanced tubes of the condenser/reboiler is the same as for the smooth tubes.

TOWER

Arrangements

The arrangements of the tower depend on the type of flow inside the tube of the tower. The type of flow also affects the cost of the heat exchangers, the tower structure, and the piping to and in the towers. The two types of flow in the tubes are countercurrent and cocurrent.

Countercurrent Flow

The flow arrangement in the dry cooling tower in the inside of the tubes is important in terms of cost. If a counterflow arrangement as

shown in Figure A-2 could be used, the cost associated with the structure and the piping could be greatly reduced as shown by a probable structural and piping arrangement in Figure A-3. One problem with counterflow situations is that entrainment of liquid (flooding) at the liquid-vapor interface can occur if certain conditions are present. For ammonia with its low surface tension and high vapor density, the condition of flooding does occur at low superficial vapor velocities (2-3 ft/sec) which requires that the length of a one-inch diameter tube be not above 17 feet in the tower if flooding is not to occur. Because the tubing in the tower would be longer than the minimum nonflooding length and because of the uncertainty of what happens to the inside heat transfer coefficient (enhancement or degeneration) when flooding occurs, the countercurrent flow scheme was not pursued any further.




FIGURE A-2. Countercurrent Flow

Cocurrent Flow

The three cocurrent flow conditions possible in a condensation process are shown in Figures A-4 through A-6. The stratified flow condition in Figure A-4 results when low vapor velocities occur in the tubes which are either sloped or horizontal. Figure A-5 shows annular flow which occurs when high vapor velocities are prevalent in horizontal tubes and low and high vapor velocities in vertical tubes. Figure A-6 shows annular flow with mist in the vapor core which occurs at very high vapor velocities in

both horizontal and vertical tubes. The last situation does not occur in an air-cooled condensation process because of the high heat transfer rate needed to obtain high vapor velocities.




FIGURE A-3. Probable Structural and Piping Arrangement for Countercurrent Flow




FIGURE A-4. Stratified Flow




FIGURE A-5. Annular Flow




FIGURE A-6. Annular Flow with Mist

Tower Configuration

Two types of towers can be used when cocurrent flow is on the inside of the tubes. One is the rectilinear tower, shown in Figure A-7, which can handle both horizontal and sloped tubing. Because all or some of the weight of the heat exchanger plus the coolant must be supported by the structure of the tower, the structural cost for the rectilinear towers is greater than for the round tower. As shown in Figure A-8, the round tower supports the heat exchanger along the tower periphery, decreasing the structural cost.

When the rectilinear tower was investigated for the SOA system, it was found slightly more costly than the circular tower. So the analysis for the SOA system was mainly done with circular towers. When the difference between the circular and the rectilinear towers for the PLASTIC system was evaluated, a definite savings with the circular towers was realized.




FIGURE A-7. Rectangular Tower

Because the major part of the analysis for the SOA and the PLASTIC systems was done with the circular tower, it was decided to analyze the NH_3 system with circular towers. The NH_3 system was not analyzed with rectilinear towers.

Heat Transfer Correlations - Tower Heat Exchanger

Air-Side

The air-side heat transfer correlations are the same as those described for the metal finned tube system.

Ammonia-Side

Because the condensation of ammonia only takes place in the vertical section of the tubes of the heat exchanger, three flow regimes must be modeled to find the correct heat transfer coefficient. All the regimes

depend on the thickness of the average condensate layer and the velocity of the vapor entering the tube. This depends on whether gravity or vapor shear is the predominating force.




FIGURE A-8. Circular Tower

When the average condensate thickness is small and the velocity of the vapor is low (gravity force predominates over the vapor shear force) the resulting laminar film condensation can be predicted with the classical analysis of Nusselt as embodied in the following equation.

$$h_i = 1.47 K_L (g \sin \theta \rho_L (\rho_L - \rho_V) / \mu_L^2)^{1/3} / (\text{Re}_L (1 - X_0))^{1/3} \quad (30)$$

If the condensate thickness is large or the velocity of the vapor is of medium velocity (gravity force still predominates over the vapor shear

force) the resulting turbulent film condensation can be predicted by the correlation developed by Kirkbride:^(16,17)

$$h_i = .0077 K_L (g \sin \theta \rho_L (\rho_L - \rho_V) / \mu_L^2)^{1/3} (Re_L (1 - X_0))^{.4} \quad (31)$$

When the annular ring of condensate is mainly controlled by the vapor shear force (predominating over the gravity force), the correlation by Boyko and Kruzhilin⁽¹⁸⁾ was used for the turbulent liquid film heat transfer coefficient:

$$h_i = .024 K_L Re_L^{.8} Pr_L^{.43} / D_i \frac{\sqrt{1 + (\rho_L/\rho_V - 1)X_i} + \sqrt{1 + (\rho_L/\rho_V - 1)X_0}}{2} \quad (32)$$

The range of values found by the optimization code for the inside coefficient is from 1000 to 1600 Btu/hr-°F-ft². The Reynolds number based on the liquid varies from 5000 to 15,000 with the entering vapor velocity ranging from 10 to 20 feet per second. The correlation most often used by the code to define the inside coefficient is equation (31).

Pressure Drop Correlation - Tower Heat Exchanger

The two-phase pressure drop in the tubes of the heat exchanger is found by the same set of equations as for the pressure drop in the condenser/reboiler. The only difference is that the Martinelli function (ϕ_L) is provided by a functional relationship of the Lockhart-Martinelli parameter (X) and not as a curve fit of the parameter.

PIPING

Pressure Drop Correlations

The pressure drop correlations in the optimization code are used to calculate the pressure drops for the supply and return piping. The supply piping transports vapor while the return line transports liquid.

The pressure drop in the vapor line is found on an incremental basis where each length of pipe of a particular diameter is divided into ten sections. The pressure drop across each section is calculated; then new vapor properties are found to be used to find the pressure drop in the next section.

The pressure drop in the liquid line is calculated for the whole length of pipe of one specific diameter.

Supply Piping

The pressure drop in the supply piping of the cooling loop is calculated by using the Fanning equation:

$$\Delta P = 4f_v \frac{L}{D_i} \frac{G_v^2}{2\rho_v} \quad (33)$$

The pressure drops found by the optimization code vary from approximately 10 to 20 pounds per square inch.

Return Piping

The pressure drop in the return piping is also calculated by using the Fanning equation.

$$\Delta P = 4f_L \frac{L}{D_i} \frac{G_L^2}{2\rho_L} \quad (34)$$

The pressure drops for the return piping vary from about 2 to 6 pounds per square inch.

Temperature Drop Correlation

Shown in Figure A-9 is a pressure-enthalpy diagram of the vapor dome for ammonia and a typical cycle ammonia passes through when it goes around the cooling loop. The diagram shows five important points of the cycle. Point A to Point B shows what happens to the ammonia in the condenser/reboiler. Point C to Point D shows the condensation of ammonia in the tower.

Point B to Point C is what occurs in the piping from the condenser/reboiler to the dry tower. The process is controlled by the pressure drop in the pipeline. Since the transfer of heat through the pipe walls is negligible and no pumping is done on the vapor the process through the pipe is isenthalpic. With the flow being isenthalpic and having a pressure drop the ammonia encounters a temperature drop from the beginning to the end of the supply piping.




FIGURE A-9. Pressure-Enthalpy Diagram of Ammonia Vapor Dome

The pressure and temperature drops are calculated along the main piping and the quadrant supply runs by dividing the pipes into ten sections and calculating the pressure drop for each section. The temperature drop is calculated for each section of pipe by using the new pressure at the end of each section and a curve fit of the saturation line of pressure versus temperature.

$$P = a + bT + cT^2 \quad (35)$$

The optimization code typically calculates a temperature drop of the vapor from 3 to 5°F.

NOMENCLATURE

- g - acceleration of gravity (ft/hr^2)
- ρ_L - density of liquid (lbm/ft^3)
- ρ_V - density of vapor (lbm/ft^3)
- K_L - thermal conductivity of liquid ($\text{Btu/hr-}^\circ\text{F-ft}$)
- h_{fg} - heat of vaporization (Btu/lbm)
- D_o - outside diameter of tube (in)
- D_i - inside diameter of tube (in)
- μ_L - viscosity of liquid (lbm/ft-hr)
- N - number of tubes in depth
- ΔT_s - temperature difference between saturated steam and tube surface ($^\circ\text{F}$)
- h_i - inside heat transfer coefficient of tube ($\text{Btu/hr-}^\circ\text{F-ft}$)
- h_{fc} - inside heat transfer coefficient of tube due to forced convection ($\text{Btu/hr-}^\circ\text{F-ft}^2$)
- h_B - inside heat transfer coefficient of tube due to boiling ($\text{Btu/hr-}^\circ\text{F-ft}^2$)
- Re_L - liquid Reynolds number
- Pr_L - liquid Prandtl number
- Cp_L - liquid specific heat ($\text{Btu/lbm-}^\circ\text{F}$)
- ΔT_a - temperature difference between saturated ammonia and inside tube surface, ($^\circ\text{F}$)
- σ - surface tension of liquid (lb/ft)
- ΔP - pressure drop (lb/ft^2)
- ϕ_L - Martinelli function
- X - Lockhart-Martinelli parameter
- f_L - liquid friction factor

f_v - vapor friction factor

L - length of pipe (ft)

G_L - mass flux of liquid ($\text{lbm}/\text{ft}^2\text{-hr}$)

G_v - mass flux of vapor ($\text{lbm}/\text{ft}^2\text{-hr}$)

θ - angle of tubes from the horizontal


X_o - quality of fluid leaving tubes

X_i - quality of fluid entering tubes

APPENDIX A REFERENCES


1. H. Schlichting, Boundary Layer Theory. McGraw-Hill Book Co., New York, NY, 1968.
2. K. K. Robinson and D. E. Briggs, "Pressure Drop of Air Flowing Across Triangular Pitch Banks of Finned Tubes." Chemical Engineering Progress Symposium Series. 62(64): 1966.
3. D. E. Briggs and E. H. Young, "Convection Heat Transfer and Pressure Drop of Air Flowing Across Triangular Pitch Banks of Finned Tubes." Chemical Engineering Progress Symposium Series. 59(41): 1963.
4. Heat Transfer and Pressure Drop Characteristics of Dry Tower Extended Surfaces, Part II: Data Analysis and Correlation. PFR Engineering Systems Inc., Marina del Rey, CA, June 15, 1976.
5. C. Weierman, J. Taborek and W. J. Marner, Comparison of the Performance of Inline and Staggered Banks of Tubes with Segmented Fins. Heat Transfer Research, Inc., Alhambra, CA, August 1975.
6. Heat Transfer and Pressure Drop Characteristics of Dry Tower Extended Surfaces, Part I: Heat Transfer and Pressure Drop Data. PFR Engineering Systems, Inc., Marina del Rey, CA, March 1, 1976.
7. P. A. Ard, C. H. Henager, D. R. Pratt and L. E. Wiles, Cost Analysis and Algorithms for Dry Cooling Tower Systems. BNWL-2123, Battelle, Pacific Northwest Laboratories, Richland, WA 99352, November 1976.
8. F. W. Dittus and L. M. K. Boelter, Univ. Calif., Pubs. Eng. 2: 443, 1930.
9. W. Z. Nusselt, "Die Abhängigkeit der Wärmeübergangszahl Von der Rohrlänge." Zeitschr. V. D. I. 54: 1910.
10. A. Zukauskas, "Heat Transfer from Tubes in Crossflow." Academy of Sciences of the Lithuanian SSR, republished in Advances in Heat Transfer, Volume 8. The Academic Press, 1972.
11. W. A. McAdams, Heat Transmission. McGraw-Hill Book Co., New York, NY, 1954.
12. W. Z. Nusselt, Ver. Dent. Ing. 60: 541, 569, 1916.
13. W. M. Rohsenow, "Heat Transfer with Boiling." Modern Developments in Heat Transfer. Pp. 85-158, 1963.
14. Heat Rejection by Dry Cooling in Steam Electric Power Stations. LINDE Division, Union Carbide, New York, NY, April 1976.

15. R. W. Lockhart and R. C. Martinelli, "Proposed Correlations for Isothermal Two-Phase, Two-Component Flow in Pipes." Chem. Eng. Prog. 45: 39, 1949.
16. C. G. Kirkbride, Trans. Am Inst. Chem. Engrs. 30: 170-186, 1933-1934.
17. C. G. Kirkbride, Ind. Eng. Chem. 26: 425-428, 1934.
18. L. D. Boyko and G. N. Kruzhilin, Int. Jour. Heat and Mass Transfer. 10: 361-373, 1967.



APPENDIX B

PIPING SYSTEM DESCRIPTION



APPENDIX B

PIPING SYSTEM DESCRIPTION

Two cooling tower arrangements were considered for dry type cooling systems: circular towers and rectilinear towers. Only circular towers are described here; a computer description of cost algorithms is presented elsewhere.⁽¹⁾ Circular towers are characterized by vertical tube bundles. For a 1000-MWe power station there would typically be several circular towers supplied from one main header. The rectilinear tower could have the tube bundles anywhere from horizontal to vertical, although most designs show the tube bundles to be within a few degrees of horizontal. A single rectilinear tower would be supplied by one main header.

A piping system design and cost model were developed for a cooling system using water, and for one using ammonia, as the primary coolant. A one-pass vertical heat exchanger was chosen for the ammonia system. With vapor entering at the top of the tube bundle it facilitates condensate collection. Thus, the ammonia lends itself to the circular tower arrangement. To compare the ammonia and water systems on an equivalent basis, emphasis was also placed on the analysis of circular towers for the water systems. In addition, a piping system model was developed for rectilinear towers using water.

Significant leakage of ammonia or water, or possible freezing of the water would necessitate draining the coolant from the heat exchanger and storing it until the problems were corrected. Such a drain and refill system has not been included in the piping model for the following reasons:

- Cost data on some of the required components was thought to be inadequate, particularly with regard to the storage tanks.
- The warmer meteorological sites such as Phoenix, Miami and San Francisco would not require freeze protection of the water system.
- Because there was little operating history on this subject, it was not clear what capacity would be required at any particular site.

A drain and refill system with capacity to store the entire volume of coolant could add as much as 20 percent to the cost of the piping system. If the attempt were to optimize the cooling system for a particular site that required a drain and refill system of known capacity, then the costs should be included because they would influence the design. However, such site-specific issues have not been included in these algorithms, and the drain and refill system was excluded from all the designs.

CIRCULAR TOWERS

In developing the piping system model for circular towers, four separate subsystems were identified. These were termed the pump station, quadrant piping, tower distribution piping and main circulation piping. They are identified in Figure B-1, drawn for a four-tower arrangement. The piping layout shown is representative of the configuration modeled in the piping system design and cost algorithm. This figure represents either the supply piping from the condenser to the heat exchangers or the return piping from the heat exchangers to the condenser. Only one is shown because, for our purposes, it was assumed that the layout of the supply and return piping could be essentially identical. Some adjustments are necessary, however, because the pump station is assumed to be included in the return piping. Also, for ammonia systems the supply coolant is a vapor and the return coolant is a liquid. The different densities and allowable design velocities result in different pipe sizes for the supply and return piping of the ammonia systems. A slightly different quadrant piping arrangement is required for the ammonia. This is discussed below.




FIGURE B-1. Piping Subsystems for Circular Towers

PUMP STATION

The pump station for the water system is in the return line of the main circulation piping. It is assumed to be 50 feet in length from inlet to outlet. Two vertical inline pumps provide the capacity of the main circulation line. At the outlet of each pump is a motor-operated valve and an expansion joint. Other appropriate pipe and fittings are included in the pump station costs. No auxiliary pumping capacity is provided.

QUADRANT PIPING

The flow to each tower is distributed to four quadrants regardless of tower size. The supply and return quadrant interface with the tower distribution piping at opposite ends of the quadrant. Figure B-2 shows the quadrant headering for the water system, modeled with a two-pass heat exchanger. This enables the supply and return quadrant headers to be located at ground level. The ammonia system is modeled with a one-pass heat exchanger. The supply vapor is piped to the top of the quadrant where it is distributed to the heat exchanger bundles. The ammonia condensate is collected in a return header similar to the return header of a water system.




FIGURE B-2. Quadrant Headering for Water System

The quadrant header includes pipe, reducers and a tee at each tube bundle. The pipe and flanges connecting the header tees to the bundles are added to the quadrant headering cost.

TOWER DISTRIBUTION PIPING

The tower distribution piping is composed of the pipe and fittings from the tower distribution point to the quadrant headers. The flow is routed to each quadrant through the tower distribution header. Cooling system control is maintained by motor-operated valves located in the supply and return lines to each quadrant.


MAIN CIRCULATION PIPING

The main circulation piping includes the pipe and fittings from the condenser outlet flange to the distribution point for each circular tower. This piping is assumed to be entirely underground. The interface between the condenser and the piping system is a flanged expansion joint. The straight

run of pipe from the condenser also includes the tees at each tower distribution point and appropriately sized reducers. The distribution point of the last tower is equipped with an elbow.


REFERENCE

1. P. A. Ard et al., Cost Analysis and Algorithms for Dry Cooling Tower Systems. BNWL-2123, Battelle, Pacific Northwest Laboratories, Richland, WA 99352, September 1976.



APPENDIX C

OPTIMIZATION TECHNIQUE



APPENDIX C

OPTIMIZATION TECHNIQUE

As mentioned in Section 3.0, an optimization technique developed by Andeen and Glicksman⁽¹⁾ was used to determine the values of the five internally independent variables which give minimum incremental cost. Only minor changes were made to the subroutines incorporating the MIT optimization technique; these changes, described in Section 5.1, are related to system constraints, not to the optimization procedure. The basic optimization technique was not changed. However, major changes were made in the computational logic, cost algorithms, etc.

Approval was obtained from Dr. Glicksman to publish that portion of Reference 1 dealing with the optimization routine used in the BNW-I codes. The prose and flow charts of the subroutines are reproduced in this appendix.

VERBATIM DESCRIPTION OF MIT OPTIMIZATION TECHNIQUE

With a given heat exchanger surface, a given design temperature, cost data, and power generation, the heat transfer and cost equations may be reduced to five variables which can be varied independently and which must be optimized:


T_1	steam cycle output temperature ($^{\circ}\text{F}$) at the low pressure turbine
RANGE	change in temperature ($^{\circ}\text{F}$) of the water while passing through the cooler
CWARA	ratio of the heat capacity of water to that of air, where heat capacity of a fluid is the product of its specific heat and its mass flow rate
AFRON	the air side frontal area (ft^2) of the heat exchanger
WLRAT	ratio of width to length of AFRON, length being the tube length

Thus the cost of adding the dry cooling tower to the power plant is a function of these five variables. The problem, or the optimization process, is to minimize this cost for given values of $\text{TD}^{(a)}$ and, by comparison, to choose the TD with the least cost.


In order to explain the minimizing procedure used, let us consider a simplified case. Assume cost is a function of only two independent variables. Hence, cost may be pictured as a surface in three-dimensional space. Figure IV-1A shows this surface in a three-dimensional sketch. Figure IV-1B shows the same figure, with lines of constant cost projected on the plane defined by variables 1 and 2, the horizontal plane of Figure IV-1A.

^(a) PNL NOTE: TD is design temperature

C's - LINES OF CONSTANT COST - $C_1 < C_2 < C_3 < C_4$



Three-Dimensional Visualization
Figure IV-1A



Two-Dimensional Visualization
with Constant Cost Loci
Figure IV-1B


FIGURE IV-1. Cost as a Function of Two Variables

For any given starting point, the minimum may be approached by: (1) holding variable 1 fixed (e.g. staying in plane A of Figure IV-2A and finding the minimum costs, point 2 on plane A); (2) holding variable 2 fixed, staying in plane B, and finding a second minimum, point 3, plane B; and (3) continuing the process indefinitely, thus "spiraling in" on the absolute minimum. Figure IV-2B illustrates this same process in a two-dimensional projection of Figure IV-2A.


However, if the surface is not as well-behaved as that drawn in Figure IV-2, but has multiple minimal points as in Figure IV-3 the search procedure may end by "minimizing" in a relative minimum trough. To avoid such relative minima, two approaches have been taken: (1) the cost is evaluated at multiple points and the lowest cost point is used as the starting point for the minimizing procedure. This is a sort of "shotgun" approach, sampling many points chosen to represent a cross-section of reasonable values. A minimum of 687 initial points are checked. (2) the cost is evaluated at discrete, incremental step changes in the variable's magnitude. Both positive and negative step changes are searched for points of minimum cost. If lower cost is not determined by the initial step size, the step size is diminished and the process is checked again. Hence the step size decreases as the minimum is approached.

The use of the shotgun approach affords a starting point somewhere in the proximity of the minimum, while the second approach allows the search procedure to step over, or out of, non-minimum troughs.

Imposed restrictions must also be considered. For example, flow abnormalities through the heat exchanger may be experienced as a result of external conditions such as wind. An air stream flowing over a surface of heat exchanger creates locations of both high and low external pressures. A location of increased external pressure will experience an enhancement of air flow through the exchanger, while a point of decreased external pressure will be "starved" of flow. Hence, depending on the shape of the heat exchanger, improperly directed wind could nullify or greatly hinder local air flows through the exchanger. As flow abnormalities tend to reduce the effectiveness of the heat exchanger, it is desirable to reduce flow abnormalities.




Three-Dimensional Visualization
Figure IV-2A




Two-Dimensional Visualization
Figure IV-2B

FIGURE IV-2. Minimization Technique on Simple Surface



Three-Dimensional Visualization
Figure IV-3A



Two-Dimensional Visualization
Figure IV-3B

FIGURE IV-3. Minimization Technique on Simple Surface

Initially the air velocities (VAIR) through the exchanger were maintained above a specified minimum. It was hypothesized that a high VAIR would minimize the effects of the ambient air velocity. However, specifying a minimum VAIR penalizes heat exchanger configurations having an inherently high air side friction. Specifying a minimum VAIR is the same as specifying a very high air side pressure drop for configurations with high friction factors. This in turn requires a much larger fan power to create this air side pressure drop. A more logical requirement is a minimum air side pressure drop, DELPA, through the heat exchanger. Since the driving force for the air flow is the pressure differential, as long as the maintained pressure differential is greater than an external differential caused by wind, flows through the exchanger will not be greatly affected. Note that this allows the "high friction" configurations to adopt lower values of VAIR, so long as DELPA is above a minimum, thereby saving on fan power.

To approximate the pressure differential caused by wind, consider the case of potential non-viscous flow around a cylinder. This would be analogous to wind blowing around a chimney or a heat exchanger of cylindrical configuration. Pressures caused by a wind of 20 mph would range from a pressure increase of 1.02 lbf/ft^2 at the stagnation point to a decrease of 3.06 lbf/ft^2 at a point 90° from the wind direction. In the present optimization runs, the minimum air side pressure drop ($\text{DELPA}_{\text{min}}$) was specified as 4.0 lbf/ft^2 . Since flow rate is directly proportional to the square root of the pressure differential, a heat exchanger designed for a 4 psf minimum pressure drop and being subjected to 20 mph winds would experience approximately a 10% increase of flow at the point facing the wind (stagnation point) and approximately a 50% reduction in flow at a point 90° from the direction of the wind. Computer runs made without pressure drop restrictions optimize at air pressure drops of about 1 psf. Such a design in a 20 mph wind would experience a 40% increase in flow at the stagnation point, and a reversal of flow at a point 90° to the wind direction. There would also be a point

of no flow somewhere between these two extremes. This definitely indicates a need for the pressure drop restriction. Flow irregularities may be further minimized by specifying a higher minimum pressure drop, an input variable to the optimization program.^(a)

Pictorially, restrictions on the air velocity or tube length pass a plane or surface through the three-dimensional cost surface, eliminating from consideration certain areas of the cost surface. As illustrated in Figure IV-4, the eliminated points may well include the absolute minimum, making some other point (point B) the desired minimum.

Simple restrictions on the value of the variables may lead to incorrect answers if only the minimization procedure of Figure IV-2 is used. For example, in Figure IV-4, suppose the search started at point 1 with variable #1 being fixed. Attempting to reach planar minimum C, variable #2 is stopped at point 2 by the restriction on DELPA. Now holding variable #2 constant, variable #1, attempting to reach planar minimum D, cannot pass point 2 either. The search procedure could not proceed further, and would evaluate point 2 as the minimum. To arrive at B, both variables are allowed to change simultaneously, thus proceeding down line 2B towards B. In the five-variable case,

$$\text{DELPA} = f(T_1, \text{RANGE}, \text{CWARA}, \text{AFRON}, \text{WLRAT})$$

So long as this function, or DELPA is maintained constant, we are at liberty to modify the variables which compose the function. Thus, if RANGE and AFRON are variables #1 and #2 respectively in Figure IV-4 an increase in range accompanied by a decrease in AFRON will move down line 2B towards B, while keeping DELPA fixed.

Since one can also expect to encounter sub-minimal troughs while moving along line 2B, a step size procedure similar to that in Figure IV-2 is used. Again, the step size diminishes as the minimum is approached.

^(a) PNL chose minimum pressure drop values well below the economically optimum values (in effect, no pressure drop constraint was applied).




FIGURE IV-4. Minimization with Imposed Restrictions

In order both to widen the initial search range and to more accurately determine a starting point, the shotgun method has been changed in the following manner: The original one-step shotgun has been replaced with a multi-step shotgun. Initially, a starting point is prescribed by specifying values for the five variables, and a sequence of 432 points in the vicinity of the starting point are checked. The point of lowest cost with a DELPA greater than $DELPA_{min}$ is taken, and becomes the initializing point for the next procedure. Holding four of the five variables constant, the cost is evaluated, taking extreme values of the fifth variable both above and below the values searched by the initial shotgun. This is sequentially done for each variable. If the minimum of one of these "extended" valued costs is at least 1% less than the minimum cost as calculated in the initial shotgun, this point becomes the prescribed point, and a new initial shotgun is performed about this point. If no new minimum is found by checking the extremes, the minimum cost point determined by the initial shotgun becomes the initial point for a second, "finer", shotgun check. This second shotgun search is "finer" in that the points checked are closer to the "initializing point" than in the "coarse" shotgun. This is the so-called "double shotgun" method.

This double shotgun method is pictured in Figure IV-5 for a two-variable case. Point 1 is the initial prescribed starting point. The first shotgun search investigates those points designated as circles, and yields point 2 as the minimum cost point. Extreme values, the diamonds, are then checked for lower cost points. Finding none in this case, a "finer" shotgun pattern is searched about point 2, yielding 3 as a lower cost point. Point 3 then becomes the starting point for the search procedure as described in Figure IV-2.

Expanding the process from two variables to five is like working in six-dimensional space rather than three-dimensional: pictorially clumsy, but not conceptually difficult. It merely entails sequentially holding all variables but one constant, while finding the planar minima, and repeating the process a given number of times. If an imposed restriction is encountered, the variable is allowed to change simultaneously with, in turn, each of the other variables.




FIGURE IV-5. Double Shotgun Initializing Method

MIT SUBROUTINES

FUNCTION OF SUBROUTINES

SHOT Tests multiple points. Performs "shotgun" search.

EXTEND Tests extreme values of minimal cost point, as determined from "coarse" shotgun.

SERCH Seeks minimum by means of one variable search method.

CHNGE Seeks minimum when pressure drop restriction encountered by two variable search method.

VARIT Evaluates system performance and cost, considering average annual temperature fluctuations.


CALC Calculates cost for a given set of five variables.

STORE Stores variable and calculated values of minimum cost.


REFERENCE

1. B.R. Andeen and L. R. Glicksman, Dry Cooling Towers for Cooling Plants. Technical Report 73047-1, Engineering Project Laboratory, Department of Mechanical Engineering, Massachusetts Institute of Technology, Cambridge, MA, February 1972..

FLOW DIAGRAM OF SUBROUTINE CALLING




MAIN PROGRAM




TD = DESIGN TEMPERATURE


SHOT




XTEND




SERCH




CHNGE




CALC



VARIT




STORE



APPENDIX D

SELECTION OF COMPLETE AND
INCOMPLETE TOWER GROUPS



APPENDIX D

SELECTION OF COMPLETE AND INCOMPLETE TOWER GROUPS

A tower group is composed of a number of circular towers that are supplied by a main circulation header.

The number of circular towers per tower group is determined by consideration of the total coolant flow rate, the total number of circular towers, the largest pipe available for the main circulation header, and the design velocity for the coolant. The design velocity determines the maximum flow that can be transported through the largest pipe. This flow is compared against the flow to each circular tower to determine the largest integer number of towers that can be supplied through a common header. This is the number of towers per tower group.

Should the total number of towers be less than the number of towers per tower group, the tower group is considered to have the lower number of towers. If the total number of towers is an integer multiple of the calculated number of towers per tower group, there is that number of complete and identical tower groups. If the total number of towers otherwise exceeds the number of towers per tower group, a so-called "extra tower group" or "incomplete tower group" is created. For example, suppose there are seven towers with five towers forming a complete group, the two extra towers would form the incomplete group. Suppose there are thirteen towers with five towers in a complete group. There would be two complete groups with three towers in the incomplete group. The difference between a complete and incomplete tower group is in the main circulation header and pump station. The pump station of the incomplete group would have less total flow rate and its size and cost would be adjusted accordingly. The header pipe sizes for the incomplete group will be smaller although the header lengths will be identical. However, the header pipe diameters for the incomplete group will correspond to the diameters of the end headers of the complete group. For example, if

there are five towers per group and two towers in an incomplete group, then the pipe diameter of the first and second header sections of the incomplete group will be the same as the pipe diameters of the fourth and fifth header sections of the complete group.

The distance between the condenser and the boundary of the tower group is the same for both the complete and incomplete group.

It has been assumed that the "incomplete group" problem does not apply to the ammonia system. It was believed that for any reasonable design the total flow could be transported through the largest available pipe. Thus, there would be no need to provide for the extra towers. However, for plant sizes larger than 1000 MWe or for below optimum design velocities of the coolant this may not be true. Problems could result that have not been provided for in the code logic.

DISTRIBUTION

<u>No. of Copies</u>		<u>No. of Copies</u>
	<u>OFFSITE</u>	Energy Research and Development Administration N. Gerstein Chief, Special Projects Branch Division of Nuclear Research and Application Washington, DC 20545
	Energy Research and Development Administration A. A. Churm Chicago Patent Group 9800 South Cass Avenue Argonne, IL 60439	Energy Research and Development Administration W. E. Mott Director, Energy Control Technology Division of Biomedical and Environmental Research Washington, DC 20545
	Energy Research and Development Administration Office of Assistant General Counsel for Patents Washington, DC 20545	Energy Research and Development Administration G. A. Newby Assistant Director Division of Nuclear Research and Application Washington, DC 20545
27	ERDA Technical Information Center	Allied Chemical Company B. R. Dickey 550 2nd Street Idaho Falls, ID 83401
	Energy Research and Development Administration I. Helms Advanced Concepts Evaluation Branch - F-309 Division of Nuclear Research and Application Washington, DC 20545	Allis-Chalmers Power Systems, Inc. J. S. Joyce 1135 South 70th Street West Allis, WI 53214
	Energy Research and Development Administration W. F. Savage Chief, Advanced Concepts Evaluation Branch Division of Nuclear Research and Application Washington, DC 20545	Aluminum Company of America E. T. Wanderer Alcoa Technical Center Alcoa Center, OH 45069
	Energy Research and Development Administration D. C. Bauer Director, Division of Nuclear Research and Application Washington, DC 20545	American Electric Power H. J. Janzon 2 Broadway New York, NY 10004
10	Energy Research and Development Administration R. B. Morrow Special Projects Branch Division of Nuclear Research and Application Washington, DC 20545	Arizona Public Service Co. T. Woods 2121 W. Cheryl Drive Phoenix, AZ 85021

No. of
Copies

Babcock & Wilcox
M. W. Peterson
Fossil Power Division
20 South Van Buren
Barberton, OH 44203

Baltimore Aircoil Co., Inc.
E. Schinner
P.O. Box 7322
Baltimore, MD 21227

Baltimore Gas & Electric Co.
G. C. Creel
Gas & Electric Building
Baltimore, MD 21203

Battelle-Geneva
J. P. Budliger
7 Route De Drizi
1227 Geneva, SWITZERLAND

Bechtel Corporation
P. Leung
P.O. Box 60860
Terminal Annex
Los Angeles, CA 90060

Bechtel Corporation
G. R. Retti
P.O. Box 3965
San Francisco, CA 94119

R. W. Beck and Associates
J. P. Rossie
400 Prudential Plaza
Denver, CO 80202

Black Hills Power and Light
Company
B. Westre
P.O. Box 1400
Rapid City, SD 57701

California State Energy
Resources Conservation
and Development Commission
L. E. Stamets
1111 Howe Avenue
Sacramento, CA 95825

No. of
Copies

Carolina Power & Light Co.
J. Sell
336 Fayetteville Street
Raleigh, NC 27602

Catalytic Construction Corp.
J. Morse
P.O. Box 11402
Charlotte, NC 28029

Combustion Engineering
H. H. Osborn
Air Preheater Company
Wellsville, NY 14895

Commonwealth Edison
R. H. Holyoak
One First Plaza
P.O. Box 767
Chicago, IL 60690

Consolidated Edison Co.
of New York, Inc.
W. A. Messner
4 Irving Place
New York, NY 10003

Consolidated Edison Co.
of New York, Inc.
C. L. Newman
4 Irving Place
New York, NY 10003

Cornell University
F. K. Moore
Ithaca, NY 14850

Curtiss-Wright Corporation
R. J. Haberski
One Passaic Street
Wood Ridge, NJ 07075

Duke Power Company
S. K. Blackley
P.O. Box 2178
Charlotte, NC 28201

Dynatech Company
E. Guyer
99 Erie Street
Cambridge, MA 02139

No. of
Copies

Ecodyne Cooling Products Co.
J. K. Swindt
Santa Rosa, CA 95403

Electric Power Research
Institute
J. Maulbetsch
3412 Hillview Avenue
P.O. Box 10412
Palo Alto, CA 94304

Environmental Protection Agency
M. Maxwell (MD-61)
IERL-RTP
Research Triangle Park, NC 27711

Environmental Protection Agency
F. H. Rainwater
Pacific Northwest Water
Laboratory
200 S.W. 35th Street
Corvallis, OR 97330

Environmental Sciences and
Services
W. Hoydisch
44-33 37th Street
Long Island City, NY 11101

Exxon Research Center
J. G. Stevens
Bldg. 1, Rm. 2048
P.O. Box 8
Linden, NJ 07036

Foster Wheeler Energy Co.
E. L. Damon
110 S. Orange Avenue
Livingston, NJ 07039

Franklin Institute
A. M. Rubin
Twentieth & Parkway
Philadelphia, PA 19103

No. of
Copies

GEA Airexchangers, Inc.
B. Davis
46 Worthington Drive
Maryland Heights, MD 63043

General Atomic Company
A. C. Eulberg
P.O. Box 81608
San Diego, CA 92138

General Electric Co.
E. H. Miller
Large Steam Turbine Division
300 Nott Street
Schenectady, NY 12301

General Motors Corp.
R. K. Shah
Harrison Radiator Division
Lockport, NY 14094

Gilbert Associates, Inc.
J. F. Sebald
525 Lancaster Avenue
Reading, PA 19603

Heat Transfer Research Inc.
J. E. Taboric
1000 S. Fremont Avenue
Alhambra, CA 91802

Hudson Products
M. W. Larinoff
6855 Horwin Drive
Houston, TX 77036

Hudson Products
E. C. Smith
6855 Horwin Drive
Houston, TX 77036

No. of
Copies

Ingersoll-Rand
W. R. Scott, Jr.
Phillipsburg, NJ 08865

Italimpianti - Societa
Italiana Impianti p.a.
C. Rocco
Piazza, Piccapietra 9
18121 Genoa, ITALY

Los Angeles Department of
Water and Power
J. L. Mulloy
111 N. Hope Street
Los Angeles, CA 90012

Louisiana Power & Light Co.
R. J. Meyer
142 Delaronde Street
New Orleans, LA 70174

The Charles T. Main Co.
E. S. Miliaras
Southeast Tower
Prudential Center
Boston, MA 02199

The Marley Co.
R. Landon
5800 Fox Ridge Drive
Mission, KS 66202

Massachusetts Institute of
Technology
L. R. Glicksman
77 Massachusetts Avenue
Cambridge, MA 02139

Massachusetts Institute of
Technology
M. W. Golay
77 Massachusetts Avenue
Cambridge, MA 02139

Massachusetts Institute of
Technology
R. Harleman
Department of Civil Engineering
77 Massachusetts Avenue
Cambridge, MA 02139

No. of
Copies

McDonnell Douglas Astronautics Co.
S. O'Hare
5301 Bolsa Avenue
Huntington Beach, CA 92647

Montana Power Co.
R. Hofacher
40 E. Broadway
Butte, MT 59701

New York University
W. G. Hoydysn
University Heights
New York, NY 10453

Niagara Blower
W. Kals
405 Lexington Avenue
New York, NY 10017

Northeast Utilities
R. H. Meyer
P.O. Box 270
Hartford, CT 06101

Oak Ridge National Laboratory
J. W. Michel
OTEC Heat Exchange Project
Activity
Box Y
Oak Ridge, TN 37830

Oregon State University
L. P. Davis
Department of Mechanical
Engineering
Corvallis, OR 97330

Oregon State University
C. E. Wicks
Department of Chemical
Engineering
Corvallis, OR 97330

Oregon State University
J. G. Knudson
Engineering Experiment
Station
Corvallis, OR 97330

No. of
Copies

Pacific Gas & Electric
A. A. Ariey
77 Beale Street
San Francisco, CA 94106

Pacific Gas & Electric
F. F. Mautz
77 Beale Street
San Francisco, CA 94106

Pacific Power & Light Co.
P. G. Humphries
Public Service Bldg.
Portland, OR 97204

Pennsylvania Power & Light
D. G. Pfeiffer
2 North Ninth Street
Allentown, PA 18101

PFR Engineering Systems, Inc.
T. Rozenmann
Suite 832
4676 Admiralty Way
Marina del Rey, CA 90291

Prof. Ing. Carlo Roma
Piazza delle Muse 8
Rome, ITALY

Power Generation Cooling
Systems
G. L. Henderson
4714 - 52nd Street S.
Seattle, WA 98118

Public Service of Colorado
R. F. Walker
5900 E. 39th Avenue
Denver, CO 80207

Public Service of New Mexico
J. D. Maddox
Corporate Planning Dept.
Albuquerque, NM 87103

No. of
Copies

Research Cottrell
G. E. Collins
Hamon Cooling Tower Division
Box 750
Bound Brook, NJ 08805

Reynolds Aluminum Co.
R. Lindberg
Reynolds Metallurgical
Research Laboratory
Richmond, VA 23261

San Diego Gas & Electric
R. G. Lacy
101 Ash Street
San Diego, CA 92107

Seattle City Light
R. L. Skone
1015 Third Ave.
Seattle, WA 98104

Southern California Edison
F. A. McCracken
2244 Walnut Grove Avenue
Rosemead, CA 91770

P. Sporn
Consultant Engineer
74 Trinity Pl., Suite 511
New York, NY 10006

Stanford University
A. L. London
Department of Mechanical
Engineering
Stanford, CA 94305

Stearns and Rogers
J. Y. Parce
700 S. Ash Street
Denver, CO 80222

Stone & Webster Engineering
Corp.
D. H. Guild
225 Franklin Street
Boston, MA 02107

No. of
Copies

Tampa Electric Co.
H. I. Wilson
P.O. Box 111
Tampa, FL 33601

Texas Electric Service Co.
W. Keel
115 W. Seventh Street
Fort Worth, TX 76102

Tucson Gas & Electric
A. A. Ward
220 W. 6th Street
Tucson, AZ 85701

Union Carbide Corp.
J. Bartz
Linde Division
61 East Park Drive
Tonawanda, NY 14150

Union Carbide Corp.
G. J. Kidd
ORGDP - K-25
P.O. Box D
Oak Ridge, TN 37803

Union Carbide Corp.
F. Notaro
Linde Division
61 East Park Drive
Tonawanda, NY 14150

United Engineers &
Constructors
G. A. Engleson
1401 Arch Street
Philadelphia, PA 19105

University of Bremen
K. Simhan
Bremen, WEST GERMANY

University of Iowa
J. F. Kennedy
Hydraulic Research Institute
Iowa City, IA 52240

No. of
Copies

University of Kentucky
T. E. Eaton
Mechanical Engineering
Department
Lexington, KY 40506

Utah Power & Light
J. H. Hutchinson
1407 W. N. Temple
Salt Lake City, UT 84103

Virginia Electric & Power Co.
S. Ragone
700 E. Franklin Street
Richmond, VA 23261

Washington State University
J. T. Kimball
College of Engineering
Pullman, WA 99163

Washington Water Power Co.
D. L. Olson
E. 1411 Mission Avenue
Spokane, WA 99202

West Associates
G. H. Soule
Sierra Pacific Power Co.
100 E. Moana Lane
Reno, NV 89510

Western States Water Council
J. A. Barnett
Executive Director
220 South 2nd East
Suite 200
Salt Lake City, UT 84111

Westinghouse Electric Corp.
G. J. Silvestri
Steam Turbines Division - G108
Lester Branch
Box 9175
Philadelphia, PA 19113

No. of
Copies

No. of
Copies

Westinghouse Electric Corp.
K. A. Oleson
Steam Turbines Division - G108
Lester Branch
Box 9175
Philadelphia, PA 19113

L. E. Wilkinson
Consultant
6582 Ganon Street, S.E.
Salem, OR 97301

ONSITE

ERDA Richland Operations Office
Energy Programs Division

H. E. Ransom

Westinghouse Hanford Company
Hanford Engineering Develop-
ment Laboratory

J. Fletcher

74 Battelle-Northwest

R. T. Allemann
D. J. Braun
J. W. Currie
D. E. Deonigi
R. L. Dillon
D. W. Dragnich
R. L. Drake
D. W. Faletti
J. W. Finnigan
T. J. Foley
B. C. Fryer
J. D. Goodenough
J. J. Hauth
A. J. Haverfield
C. H. Henager
A. B. Johnson
W. S. Kelly
R. S. Kemper
C. J. Knoll
W. V. Loscutoff

Battelle-Northwest (cont)

R. P. Marshall
D. E. Olesen
Y. Onishi
H. L. Parry
L. T. Pederson
H. C. Riches
J. R. Sheff
G. C. Smith
J. S. Stoakes
A. M. Sutey
R. D. Tokarz
D. S. Trent
M. Vagins
R. A. Walter
R. L. Watts
R. D. Widrig
L. E. Wiles
F. R. Zaloudek
File - B. M. Johnson (30)
Technical Information (5)
Technical Publications

