

RECORD COPY

Fast Flux Test Facility Performance Monitoring Management Information February 1989

Prepared for the U.S. Department of Energy
Assistant Secretary for Nuclear Energy



Westinghouse
Hanford Company

Richland, Washington

Hanford Operations and Engineering Contractor for the
U.S. Department of Energy under Contract DE-AC06-87RL10930

~~Proposed and Use of Document. This document was prepared for use within the U.S. Department of Energy and its contractors. It is to be used only to perform, direct, or integrate work under U.S. Department of Energy contracts. This document is not approved for public release until reviewed.~~

~~Patent Status. This document copy, since it is transmitted in advance of patent clearance, is made available in confidence solely for use in performance of work under contracts with the U.S. Department of Energy. This document is not to be published nor its contents otherwise disseminated or used for purposes other than specified above before patent approval for such release or use has been secured, upon request, from the U.S. Department of Energy, Patent Attorney, Richland Operations Office, Richland, WA.~~

J. D. Andale 9/21/2016

Approved for Public Release;
Further Dissemination Unlimited

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Printed in the United States of America

Fast Flux Test Facility Performance Monitoring Management Information February 1989

D. J. Newland

Date Published
March 1989

Prepared for the U.S. Department of Energy
Assistant Secretary for Nuclear Energy



**Westinghouse
Hanford Company** P.O. Box 1970
Richland, Washington 99352

Hanford Operations and Engineering Contractor for the
U.S. Department of Energy under Contract DE-AC06-87RL10930

~~**Purpose and Use of Document:** This document was prepared for use within the U.S. Department of Energy and its contractors. It is to be used only to perform, direct, or integrate work under U.S. Department of Energy contracts. This document is not approved for public release until reviewed.~~

~~**Patent Status:** This document copy, since it is transmitted in advance of patent clearance, is made available in confidence solely for use in performance of work under contracts with the U.S. Department of Energy. This document is not to be published nor its contents otherwise disseminated or used for purposes other than specified above before patent approval for such release or use has been secured, upon request, from the U.S. Department of Energy, Patent Attorney, Richland Operations Office, Richland, WA.~~

D. J. Newland 9/21/2016
**Approved for Public Release,
Further Dissemination Unlimited**

CLASSIFICATION/UCNI REVIEW

TO: Document Clearance/Processing and Distribution


SUBJECT: Review of WHC- SP - 6081 - 15

This document contains neither CLASSIFIED nor UCNI material.

This document is CLASSIFIED at the following level and category and may not be released:

<u>Level</u>	<u>Category</u>
<input type="checkbox"/> Top Secret	<input type="checkbox"/> Restricted Data
<input type="checkbox"/> Secret	<input type="checkbox"/> Formerly Restricted Data
<input type="checkbox"/> Confidential	<input type="checkbox"/> National Security Information

This document contains UCNI material and any release must be in accordance with DOE approved distribution lists.


(Authorized Derivative Classifier and
Authorized Reviewing Official)

3/8/85

(Date)

Please submit this completed form and document for distribution to:

Document Clearance/Processing and Distribution
L8-15

FOREWARD

The purpose of this report is to provide management with performance data on key performance indicators selected from the FFTF Early Warning System performance indicators. This report contains the results for key performance indicators divided into two categories of "overall" and "other". The "overall" performance indicators, when considered in the aggregate, provide one means of monitoring overall plant performance. Overall performance indicators are listed in Table 1. The "other" performance indicators, listed in Table 2, are considered useful management tools for assessing the specific areas they address.

The data should be used in conjunction with the results of other management assessment activities to focus improvement efforts. Use of these key performance indicators as a group is stressed, since focusing on a single indicator or a narrow set of indicators can be counterproductive both to safety and to long-term performance improvement.

Any concerns regarding the accuracy or analysis of the specific indicator should be addressed to the responsible manager identified on the figure. This report must be reviewed with the understanding that both the design and the mission are different for FFTF compared to commercial power reactors.

FFT^F PLANT MANAGER'S ASSESSMENT

FEBRUARY 1989

The plant operated smoothly at full power throughout the month of February. This raised the FFT^F Operational Efficiency Factor (OEF) to 98.4%, which is well above the 96% goal.

With no lost work day injuries occurring now for thirteen straight months and with the continued decrease of the plant lifetime average personnel radiation exposure, most overall performance indicators reflect excellent FFT^F operation in spite of staff shortages and high workloads.

The protective maintenance backlog decreased significantly this month. Continued rise in corrective maintenance backlog indicators reinforces the need for planning and scheduling older work packages to ensure a favorable work-off rate.

Please route your copy of this report to your staff and direct any questions or comments to J. E. Truax (376-0758).

D. J. Newland


D. J. Newland
FFT^F Plant Manager

TABLE 1
OVERALL PERFORMANCE INDICATORS


<u>FIGURE</u>	<u>PERFORMANCE INDICATOR</u>	<u>AREA</u>
1	Capacity Factor	OPS
2	Unplanned Automatic Scrams	OPS
3	Forced Outages	OPS
4	Unusual Occurrence Reports	OPS
5	Personnel Radiation Exposure	RADCON
6	Industrial Safety Statistics	INDSAF
7	Corrective Maintenance Workoff Rate	MAINT

Capacity Factor

Annual Capacity Factor



Annual Capacity Factor



Purpose


To monitor the plant's ability to perform at rated power. Capacity Factor is defined as the actual EFPD divided by the product of the calendar days in the reporting period times the Maximum Dependable Capacity (MDC) for the period. The MDC for CDE cycles is 1.0. For cycles prior to September 1986, the MDC was 0.973.

Assessment


The Capacity Factor for the month of February was 100.0%.

Unplanned Automatic Scrams

Monthly



Annual



Purpose


To monitor the number of unplanned automatic scrams that occur while the reactor is critical. Unplanned means that the scram was not part of a planned operation or test. Unplanned automatic scrams include, for example, automatic scrams resulting from a transient, an equipment failure, a spurious signal, or human error.

Assessment


There were no unplanned automatic scrams during the month of February.

Forced Outages

Monthly



Annual



Purpose


To monitor the percentage of time that the reactor was not available for irradiation testing due to a forced shutdown. A forced shutdown is one that would not have been completed in the absence of the condition for which corrective action was taken. Test outages are not considered forced shutdowns.

Assessment


There were no forced outages during the month of February.

Unusual Occurrence Reports

Monthly



Annual



Purpose


To monitor the number of Unusual Occurrence Reports (UOR). A UOR is an event outside normal operations that causes or risks serious injury to personnel, serious threat to the environment, or has significant effect upon safety, reliability or cost of FFTF or FFTF programs.

Assessment


There were no Unusual Occurrence Reports during the month of February.

Personnel Radiation Exposure

Quarterly Man-Rem Exposure



Annual Man-Rem Exposure



Purpose


To monitor the quarterly radiation exposure to the FFTF radiation workers. Due to the very low exposures, data is collected and reported quarterly. Annually and semi-annually reported exposures are included in the fourth quarter statistics for 1988.

Assessment


Plant personnel radiation exposure during the fourth quarter of 1988 remained low. The highest individual exposure was 70 mrem. With 285 radiation workers reporting on an annual, semi-annual or quarterly basis at FFTF, the average exposure was less than 4 mrems per worker per quarter.

Industrial Safety Statistics

Monthly Injuries



Annual Case Rates



Purpose


To monitor the number of recordable and lost work day injuries. The lost work day injury incident rate (the number of lost time injuries per 200,000 employee-hours) and the recordable injury incident rate (the number of OSHA recordable injuries per 200,000 employee-hours) are also monitored for permanent site personnel.

Assessment

There were no OSHA recordable injuries at FFTF during the month of February.

Corrective Maintenance Workoff Rate

Corrective Maintenance Backlog Greater Than Three Months Old



Purpose

To monitor the rate of completion of corrective maintenance items. This chart indicates the efficiency of the FFTF work control process and the staff's ability to follow through on the disposition, scheduling, field work, and close out of corrective maintenance.

Assessment


The backlog greater than three months made a slight increase to 46.0% during the month of February. Efforts are being focused on reducing this to less than 43% by the start of the S11A outage. Backlog work packages are being worked on overtime as needed to ensure success. However, attention needs to continue to be centered on planning and scheduling older work packages to ensure we remain below 43%.

TABLE 2
OTHER PERFORMANCE INDICATORS


<u>FIGURE</u>	<u>PERFORMANCE INDICATOR</u>	<u>AREA</u>
8	Total Operations Staffing	OPS
9	Qualified Plant Operators	OPS
10	Qualified Control Room Operators	OPS
11	Reportable Events	OPS
12	Outage Planning Performance (In Review)	MAINT
13	Corrective Maintenance Backlog	MAINT
14	Protective Maintenance Performance	MAINT
15	Modification Status	ENG
16	Temporary Modification Status	ENG
17	Essential Drawing Status	ENG
18	Tagouts	OPS
19	Staffing Status	PERS
20	(TBD)	
21	Solid Radioactive Waste	RADCON
22	Liquid Radioactive Waste	RADCON
23	Skin Contaminations	RADCON
24	Safety/Quality Commitments	QA
25	FFT Operating Histogram	OPS
26	Annual Operational Performance	OPS

Total Operations Staffing

Crew Staffing



Crew Staffing



Purpose


To monitor the operating crew staffing by tracking the total number of people assigned to operating crews. This is an indicator of the ability of Operations to support current and future plant activities. Some of the assigned operators may be in training or awaiting clearances prior to being assigned operating duties.

Assessment


The total number of operators for the month of February was 74, well below the desired level of staffing. An action plan is in place to address the short fall. While this short fall does not affect the safety of plant operations, the ability of Operations to support extra work loads imposed by plant outages and non-routine tasks requires higher use of overtime.

Qualified Plant Operators

Crew Plant Staffing



Crew Plant Staffing



Purpose


To monitor the number of key personnel who are qualified outside the control room. This is an indicator of the number of field operators available to support plant activities and operate the plant safely and efficiently.

Assessment


The number of qualified plant operators for the month of February was 28. This increase will improve the ability of Operations to support non-routine activities, such as the upcoming outage.

Qualified Control Room Operators

Crew Control Room Staffing



Crew Control Room Staffing



Purpose


To monitor the number of key non-supervisory personnel qualified to stand watch in the control room. It is an indication of the knowledge and experience level of Operations personnel and reflects the ability of the organization to safely and efficiently operate the plant.

Assessment


The total number of qualified control room operators for the month of February was 34. While the safety of operations is not affected, use of overtime is required to support non-routine evolutions.

Reportable Events

Monthly Reportable Events



Annual Reportable Events




Purpose

To monitor the number of Event Fact Sheets (EFS) and Critiques. An Event Fact Sheet records any significant unplanned event that may or may not be reportable as a Critique or Unusual Occurrence Report (UOR). A Critique is an evaluation of those events that do not meet the criteria for a UOR, but require investigation beyond that identified in an EFS.

Assessment

There were seven Event Fact Sheets and no Critiques written this month.

Outage Planning Performance




Purpose

This indicator is being revised for issue with March's data.

Assessment

Corrective Maintenance Backlog

Total Corrective Maintenance Backlog




Purpose
To monitor the overall material condition of the FFTF. Corrective maintenance is defined as activity that repairs, restores, or modifies plant equipment to restore it to the intended design condition or function.

Assessment

The total corrective maintenance backlog increased to 528 items during the month of February. While this increase presently helps to reduce our percentage greater than three months old, it also means that from now on we will have a larger backlog to deal with.

Protective Maintenance Performance

Protective Maintenance Items Deferred




Purpose

To monitor the number of protective maintenance (PMP and ICR) items that have been deferred. It illustrates the organization's ability to schedule and complete routine maintenance.

Assessment

The protective maintenance backlog is currently at 1.30%. This is down from 1.95% recorded earlier in the month. Efforts continue to reduce the backlog to 1.2% by working overtime and dispositioning problems in the field.

Modification Status



Purpose

To monitor the number of plant modifications that are active in the Plant Tracking System (PTS). It illustrates the organization's ability to design, implement and closeout changes in the plant.

Assessment

The total number of outstanding modifications increased during February. A new goal has been set at less than 250 modification packages outstanding. The decrease in the number of modifications in the "pre-release" and "post-review" categories is encouraging and is a reflection of concentration in this area. However, the increased focus on the preventive and corrective maintenance backlog has reduced the ability to work off non-corrective maintenance modifications.


Feb 1989

R. D. Redekopp

376-9668

Figure 15

Temporary Modification Status



Purpose


To monitor the number of modifications that are not permanent. It also monitors the organization's ability to complete the documentation and provide permanent changes to the FFTF.

Assessment

The total number of temporary modifications has continued to climb. Thirteen temporary modifications are being readied for ILRT in S11B. Three temporary modifications are in closeout. The remaining ten should be evaluated for need or conversion to permanent modifications.

Essential Drawing Status

2420 Essential Drawing Sheets



Purpose


To monitor the number of essential drawing sheets on which changes have not been incorporated within thirty working days after completion of the field work package.

Assessment

It appears that a working level of 5 sheets is a normal backlog. A target to maintain the month to month level less than 10 sheets is reasonable.

Tagouts

Tagouts Greater Than Six Months Old




Purpose

To monitor tagouts which have been in place for six months or longer. This is an indicator of the plant equipment which has been unavailable or in reduced status for at least six months.

Assessment

The goal was changed from 20 down to 10 this month. Achieving this goal will significantly increase the long term availability of plant equipment. The number of tagouts in place for six months or longer during February was 12.

Direct Staffing



Purpose


To monitor the number of direct staff. The number of direct staff is obtained from monthly manpower reports.

Assessment


The number of FFTF direct staff remained essentially the same through February, slightly below the planning level.

Solid Radioactive Waste

Monthly Volume



Annual Volume



Purpose


To monitor the volume of solid radioactive waste that is shipped off the FFTF site. Solid radioactive waste generated from the FFTF, IEM cell, and MASF are included in the totals.

Assessment


There were no shipments of solid radioactive waste during the month of February.

Liquid Radioactive Waste

Monthly



Annual



Purpose


To monitor the volume of liquid radioactive waste shipped from storage tank T-103 to the railroad tank car for shipment off the FFTF site.

Assessment


There were no shipments of liquid radioactive waste during the month of February.

Skin Contaminations

Monthly



Annual



Purpose


To monitor the number of recordable and significant (reportable) skin contamination events. A recordable skin contamination event is any event with detectable contamination levels above 2000 dpm/ probe area beta-gamma and/or 500 dpm/probe area alpha (not to include radon/thoron isotopes). A significant (reportable) skin contamination event is any event with detectable contamination levels above 50,000 dpm/probe area beta-gamma-alpha.

Assessment


There were no skin contamination events in the 400 area during the month of February.

Safety/Quality Commitments

Nonconformance Reports



Action Items



Purpose


To monitor the number of NonConformance Reports (NCR) and action items resulting from reportable events, critiques, and UOR's. The number of overdue action items is also monitored to measure responsiveness to completing identified action items.

Assessment

The number of open NCR's dropped by 2 from 29 to 27 at the end of February.

Action items, both total and overdue, remained fairly constant in February.


FFTF Operating Histogram



Operating Statistics

	Cycle 1	Cycle 2	Cycle 3	Cycle 4	Cycle 5	Cycle 6	Cycle 7	Cycle 8	Cycle 9	Cycle 10 (2/28/89)
EFPD For Cycle:	101.5	100.5	101.5	109.5	122.7	134.0	122.8	63.0	341.8	372.7
Total Plant EFPD At End Of Cycle:	134.3	234.8	336.3	445.8	568.5	702.5	825.3	888.3	1230.1	1602.8
Cycle Capacity Factor (%):	50.3	83.1	93.5	99.5	93.5	74.9	90.3	38.9	86.6	79.6
Availability Factor (%):	53.0	90.6	99.0	100.0	94.6	78.5	94.6	57.9	89.6	83.0
Number Of Experiments:	61	64	57	51	51	41	31	19	44	34
Maximum Fuel Burnup At End Of Cycle (Mwd/MT):	35,000	60,000	81,000	105,000	129,000	135,000	154,700	154,700	165,600	188,400

Annual Operational Performance



	1982	1983	1984	1985	1986	1987	1988
Capacity Factor (%):	40.5	56.9	66.4	71.0	46.2	76.5	78.5
Availability Factor (%):	42.8	61.1	67.6	73.0	56.8	78.7	81.2
Operational Efficiency Factor (%):	63.5	97.6	92.6	98.0	98.1	100.0	98.9

* Reporting Began At Start Of Cycle : On April 16, 1982

DISTRIBUTION

FFT/F PERFORMANCE MONITORING MANAGEMENT INFORMATION

S. O. Arneson	B3-57	R. Lange	DOE-HQ
W. H. Arnold	H5-59	G. R. Lockard	N2-03
D. E. Bailey	DOE-HQ	P. C. Miller	N2-04
Q. L. Baird	N1-72	J. Montano	N2-51
J. R. Bell	R3-60	D. J. Newland	N2-51
R. A. Bennett	N2-32	R. C. Nichols	B3-02
P. B. Bourne	L0-11	J. E. Nolan	B3-01
H. N. Bowers	L6-57	R. E. Peterson	R2-30
N. C. Boyter	B4-52	R. D. Redekopp	N2-33
W. H. Caplinger	N1-71	L. H. Rice	L5-57
G. D. Carpenter	R2-85	D. E. Simpson	B3-51
N. R. Dahl	N2-04	R. G. Slocum	R2-34
E. W. Gerber	L5-58	R. N. Smith	N2-50
E. F. Gray	N2-35	D. J. Swaim (2)	N2-34
R. A. Hunter	DOE-HQ	J. E. Truax	N2-51
M. S. Karol	A6-55	J. B. Waldo (2)	N2-57
R. H. Koga/T.C. Varljen	B3-07	R. L. Watts	L6-52
M. K. Korenko	L5-56	Corres. Processing (4)	L8-15
W. J. McShane	H5-60		

March 1989