

SELECTED HANFORD REACTOR AND  
SEPARATIONS OPERATING DATA FOR 1960-1964

Hanford Environmental Dose  
Reconstruction Project

S. P. Gydesen

September 1992

Letter report prepared for the  
Technical Steering Panel and the  
Centers for Disease Control under  
Contract Number [REDACTED] (CDC)/18620(BNW)

Battelle  
Pacific Northwest Laboratories  
Richland, Washington 99352

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

## SUMMARY

The primary objective of the Hanford Environmental Dose Reconstruction (HEDR) Project is to estimate the radiation dose that populations and individuals could have received as a result of emissions from Hanford Site operations since 1944, with descriptions of the uncertainties inherent in such estimates. A secondary objective is to make project documentation and Hanford-originated references used in the reports available to the public. Hanford-originated documents of potential interest and/or use to the HEDR Project are made publicly available through the U.S. Government's National Technical Information Service and placed in the U.S. Department of Energy Richland Field Office (RL) Public Reading Room in Richland, Washington.

Project work is conducted under several tasks, among which is the Source Terms Task. Under this task, estimates of radioactive emissions from Hanford facilities since 1944 are developed. These estimates are based on historical measurements and production information. The Information Resources Task identifies and retrieves historical production operating information for developing source terms.

The purpose of this letter report is to reconstruct from available information that data which can be used to develop daily reactor operating history for 1960-1964. The information needed for source team calculations (as determined by the Source Terms Task Leader) were extracted and included in this report. The data on the amount of uranium dissolved by the separations plants (expressed both as tons and as MW) is also included in this compilation. A forthcoming letter report will address daily operating information for the separations processes from 1944-1972.

## GLOSSARY

E Metal	uranium isotopically enriched to 0.94% or 1.75% U-235 by weight
I & E	tubular slug (fuel element), internally and externally cooled
KER	experimental loops at KE Reactor
KMWD	1000 megawatt days
kW	kilowatts
94 Metal	uranium isotopically enriched to 0.94% U-235 by weight
MWD	megawatt days
Normal U	naturally occurring uranium approximately 99.28% U-238 and 0.72% U-235
Ton	2000 pounds

CONTENTS

SUMMARY . . . . .	iii
GLOSSARY . . . . .	v
INTRODUCTION . . . . .	1
QUALITY ASSURANCE AND DATA QUALITY OBJECTIVES . . . . .	3
OPERATING DATA . . . . .	5
REFERENCES . . . . .	7
APPENDIX A - OPERATING DATA FOR 1960 . . . . .	A.1
APPENDIX B - OPERATING DATA FOR 1961 . . . . .	B.1
APPENDIX C - OPERATING DATA FOR 1962 . . . . .	C.1
APPENDIX D - OPERATING DATA FOR 1963 . . . . .	D.1
APPENDIX E - OPERATING DATA FOR 1964 . . . . .	E.1

## INTRODUCTION

The objective of the Hanford Environmental Dose Reconstruction (HEDR) Project is to estimate the radiation dose that individuals could have received as a result of emissions from nuclear operations at the U.S. Department of Energy's (DOE's) Hanford Site since operations began in 1944. The HEDR Project is managed and conducted by Battelle Pacific Northwest Laboratories under the direction of an independent Technical Steering Panel.

The Information Resources Task within the HEDR Project is charged with the responsibility of ensuring that Hanford-originated documents of use in meeting project objectives are found and made available in a timely manner to HEDR Project staff and the public. Project information needs center around 1) information necessary to estimate doses people may have received and 2) information requested by the public on operations and radioactive material releases. The first objective has priority.

Two types of information are needed: 1) facilities operation information necessary to calculate amounts of radioactive materials generated and released to the environment and 2) monitoring information indicating concentrations of radioactive materials in the environs and how those concentrations were measured or calculated.

Calculating source terms is the first step in dose estimation. Much of the information in documents located and provided by Information Resources Task staff is used to develop the source term--the quantities of radionuclides that were released to the environment and the dates of release from various Hanford operations. The quantities of radionuclides available for release at any time are a function of the irradiation history of the fuel, the time elapsed since the fuel was removed from the reactor, and the amount of irradiated fuel being dissolved.

This report addresses data for the years 1960-1964. An earlier report (Gydesen 1992) identifies daily reactor operating reports for the years 1944-1959 and 1965-1971.

## QUALITY ASSURANCE AND DATA QUALITY OBJECTIVES

Data quality objectives (DQO) were established in FY 1992 task plans for the Information Resources Task. For this activity, completeness and representativeness were the only data quality objectives identified in the task plan. The approach to achieve these objectives is to use the search tree process to review currently available subject, author, periodical and serial indices of archival documents for those of interest to the project. Achievement of these data quality objectives was to be addressed at the completion of each search effort or report.

Completeness and representativeness were included as data quality objectives to ensure that any discovery of additional information would not alter the project reconstructed results. Achievement of these DQOs has been satisfied by the internal peer reviews performed by the source term task leader and the line manager of the author. The line manager's review ensures that the development of the search trees was adequate and sufficient for this particular activity and the source term task leader's review ensures that the required information has been provided to perform the necessary reconstructed release information required for the source term model. Additionally, a surveillance was performed by the quality engineer verifying that there is objective evidence in the files supporting the destruction of the daily operating documents and that the internal reviews performed were sufficient to address the achievement of the data quality objective.

## OPERATING DATA

The last known copy of the five reactor operating reports for 1960 through 1964 (DeNeal 1961-1965) was destroyed in 1969 (Gydesen 1992). The data critical to HEDR Source Term Task needs can be developed from information extracted from the 1960 Reactor Branch monthly reports (Plum 1961-1965) and selected unclassified data extracted from the Monthly Production reports (Travis 1960-1965).

The tables in the five appendixes that follow were photocopied directly from the reports cited above. The full citations and notes about the availability of these source documents are included in the "References" section of this report. Only those portions needed for source term calculations (as determined by the Source Terms Task Leader) were extracted and included in this report. The legibility of the tables varies, depending on the quality of the copy from which they were made. Nonetheless, to avoid introduction of errors when working with large collections of numbers and to hold publication costs to a minimum, the tables have not been retyped.

## REFERENCES

(a) DeNeal, D. L. 1961. 100 Areas Daily Reports for 1960. HW-63287, General Electric Co., Hanford Atomic Products Operation, Richland, Washington.

(a) DeNeal, D. L. 1962. 100 Areas Daily Reports for 1961. HW-68050, General Electric Co., Hanford Atomic Products Operation, Richland, Washington.

(a) DeNeal, D. L. 1963. 1962 Daily Reports-100 Areas. HW-72063 RD, General Electric Co., Hanford Atomic Products Operation, Richland, Washington.

(a) DeNeal, D. L. 1964. 1963 Daily Reports-100 Areas. HW-75932 RD, General Electric Co., Hanford Atomic Products Operation, Richland, Washington.

(a) DeNeal, D. L. 1965. 1964 Daily Reactor Reports. HW-80182 RD, General Electric Co., Hanford Atomic Products Operation, Richland, Washington.

Gydesen, S. P. 1992. Letter Report: Title Listing of Daily Operating Data on Hanford Single-Pass Reactors, 1944-1971. PNL-7998 HEDR, Pacific Northwest Laboratory, Richland, Washington.

Plum, R. L. 1961. Monthly Reports--January through December 1960--Reactor Branch. HAN-74591 DEL, U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

Plum, R. L. 1962. Monthly Reports--January through December 1961--Reactor Branch. HAN-77681 DEL, U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

Plum, R. L. 1963. Monthly Reports--January through December 1962--Reactor Branch. HAN-80948 DEL, U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

Plum, R. L. 1964. Monthly Reports--January through December 1963--Production Reactor Operations Branch. HAN-84216 DEL, U.S. Atomic Energy Commission, Richland Operations Office, Richland, Washington.

Plum, R. L. 1965. Monthly Reports--January through December 1964--Production Reactor Operations Branch. HAN-87470 DEL, U.S. Atomic Energy Commission, Richland Operations Office, Richland, Washington.

---

(a) All copies were destroyed in 1969.

(a) Travis, J. E. 1960a. Monthly Production Report, January 1960. HAN-74610 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960b. Monthly Production Report, February 1960. HAN-74898 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960c. Monthly Production Report, March 1960. HAN-75171 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960d. Monthly Production Report, April 1960. HAN-75436 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960e. Monthly Production Report, May 1960. HAN-75701 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland Washington.

(a) Travis, J. E. 1960f. Monthly Production Report, June 1960. HAN-75959 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960g. Monthly Production Report, July 1960. HAN-76226 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960h. Monthly Production Report, August 1960. HAN-76495 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960i. Monthly Production Report, September 1960. HAN-76700 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1960j. Monthly Production Report, October 1960. HAN-76955 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

---

(a) These monthly production reports contain virtually no text, only data tables and graphical presentations. They remain classified in their entirety as they present weapon information and classified shipment data. Selected unclassified information useful to source term development has been extracted and is included in this letter report. These production reports can be made available to individuals who have the appropriate level of security clearance and need-to-know by contacting the HEDR Project Office in Richland, Washington.

(a) Travis, J. E. 1960k. Monthly Production Report, November 1960. HAN-77199 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961a. Monthly Production Report, December 1960. HAN-77447 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961b. Monthly Production Report, January 1961. HAN-77727 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961c. Monthly Production Report, February 1961. HAN-77983 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961d. Monthly Production Report, March 1961. HAN-78242 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961e. Monthly Production Report, April 1961. HAN-78542 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961f. Monthly Production Report, May 1961. HAN-78835 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961g. Monthly Production Report, June 1961. HAN-79089 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961h. Monthly Production Report, July 1961. HAN-79343 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961i. Monthly Production Report, August 1961. HAN-79652 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

---

(a) These monthly production reports contain virtually no text, only data tables and graphical presentations. They remain classified in their entirety as they present weapon information and classified shipment data. Selected unclassified information useful to source term development has been extracted and is included in this letter report. These production reports can be made available to individuals who have the appropriate level of security clearance and need-to-know by contacting the HEDR Project Office in Richland, Washington.

(a) Travis, J. E. 1961j. Monthly Production Report, September 1961. HAN-79904 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961k. Monthly Production Report, October 1961. HAN-80190 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1961l. Monthly Production Report, November 1961. HAN-80401 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962a. Monthly Production Report, December 1961. HAN-80668 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962b. Monthly Production Report, January 1962. HAN-80986 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962c. Monthly Production Report, February 1962. HAN-81282 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962d. Monthly Production Report, March 1962. HAN-81566 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962e. Monthly Production Report, April 1962. HAN-81839 (SECRET-RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962f. Monthly Production Report, May 1962. HAN-82147 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962g. Monthly Production Report, June 1962. HAN-82385 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

---

(a) These monthly production reports contain virtually no text, only data tables and graphical presentations. They remain classified in their entirety as they present weapon information and classified shipment data. Selected unclassified information useful to source term development has been extracted and is included in this letter report. These production reports can be made available to individuals who have the appropriate level of security clearance and need-to-know by contacting the HEDR Project Office in Richland, Washington.

(a) Travis, J. E. 1962h. Monthly Production Report, July 1962. HAN-82636 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962i. Monthly Production Report, August 1962. HAN-82917 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962j. Monthly Production Report, September 1962. HAN-83174 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962k. Monthly Production Report, October 1962. HAN-83474 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1962l. Monthly Production Report, November 1962. HAN-83690 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1963a. Monthly Production Report, December 1962. HAN-83914 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1963b. Monthly Production Report, January 1963. HAN-84100 Rpt 1 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1963c. Monthly Production Report, February 1963. HAN-84100 Rpt 2 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1963d. Monthly Production Report, March 1963. HAN-84100 Rpt 3 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1963e. Monthly Production Report, April 1963. HAN-84100 Rpt 4 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford Operations Office, Richland, Washington.

---

(a) These monthly production reports contain virtually no text, only data tables and graphical presentations. They remain classified in their entirety as they present weapon information and classified shipment data. Selected unclassified information useful to source term development has been extracted and is included in this letter report. These production reports can be made available to individuals who have the appropriate level of security clearance and need-to-know by contacting the HEDR Project Office in Richland, Washington.

(a) Travis, J. E. 1963f. Monthly Production Report, May 1963. HAN-84100  
Rpt 5 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1963g. Monthly Production Report, June 1963. HAN-84100  
Rpt 6 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1963h. Monthly Production Report, July 1963. HAN-84100  
Rpt 7 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1963i. Monthly Production Report, August 1963. HAN-84100  
Rpt 8 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1963j. Monthly Production Report, September 1963.  
HAN-84100 Rpt 9 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission,  
Hanford Operations Office, Richland, Washington.

(a) Travis, J. E. 1963k. Monthly Production Report, October 1963. HAN-84100  
Rpt 10 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1963l. Monthly Production Report, November 1963. HAN-84100  
Rpt 11 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Hanford  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964a. Monthly Production Report, December 1963. HAN-84100  
Rpt 12 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964b. Monthly Production Report, January 1964. HAN-87520  
Rpt 1 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964c. Monthly Production Report, February 1964. HAN-87520  
Rpt 2 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

---

(a) These monthly production reports contain virtually no text, only data tables and graphical presentations. They remain classified in their entirety as they present weapon information and classified shipment data. Selected unclassified information useful to source term development has been extracted and is included in this letter report. These production reports can be made available to individuals who have the appropriate level of security clearance and need-to-know by contacting the HEDR Project Office in Richland, Washington.

(a) Travis, J. E. 1964d. Monthly Production Report, March 1964. HAN-87520  
Rpt 3 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964e. Monthly Production Report, April 1964. HAN-87520  
Rpt 4 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964f. Monthly Production Report, May 1964. HAN-87520  
Rpt 5 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964g. Monthly Production Report, June 1964. HAN-87520  
Rpt 6 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964h. Monthly Production Report, July 1964. HAN-87520  
Rpt 7 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964i. Monthly Production Report, August 1964. HAN-87520  
Rpt 8 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964j. Monthly Production Report, September 1964.  
HAN-87520 Rpt 9 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission,  
Richland Operations Office, Richland, Washington.

(a) Travis, J. E. 1964k. Monthly Production Report, October 1964. HAN-87520  
Rpt 10 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1964l. Monthly Production Report, November 1964. HAN-87520  
Rpt 11 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

(a) Travis, J. E. 1965. Monthly Production Report, December 1964. HAN-87520  
Rpt 12 (SECRET RESTRICTED DATA), U.S. Atomic Energy Commission, Richland  
Operations Office, Richland, Washington.

---

(a) These monthly production reports contain virtually no text, only data tables and graphical presentations. They remain classified in their entirety as they present weapon information and classified shipment data. Selected unclassified information useful to source term development has been extracted and is included in this letter report. These production reports can be made available to individuals who have the appropriate level of security clearance and need-to-know by contacting the HEDR Project Office in Richland, Washington.

APPENDIX A

OPERATING DATA FOR 1960

URANIUM IN TONS  
1960

WIND AND SPECIAL MATERIALS  
1960

(1) Purex dissolved all of this

Extracted from Travis 1960b, pages 5 and 7.

	COMPARATIVE PILE PERFORMANCE				JAN 1960				TOTAL
	B	C	D	E	H	I	K	M	
Maximum Power Level, MW	1.685	2.000	2.710	3.730	3.730	3.730	3.810	18.365	18.365
Maximum Power Level During Month, MW	1.685	2.050	2.620	3.525	3.525	3.525	3.810	18.355	18.355
Average Power Level While Operating, MW	2.540	2.743	2.555	2.624	2.624	2.624	2.507	16.776	16.776
Maximum Tube Power, MW	2.195	2.228	2.170	2.300	2.179	2.179	2.175	16.520	16.520
Effective Central Tubes	2.440	2.665	2.460	2.525	2.460	2.460	2.505	25.000	25.000
Time Operated Efficiency, %	81.7	79.9	76.4	88.9	73.1	82.1	85.3	82.2	82.2
Operational Limitation	1.290	1.276	1.218	1.250	1.210	1.210	1.215	1.520	1.520
NU Produced During Month, total	39.016	43.153	36.738	42.897	35.906	42.897	35.925	131.699	131.699
Normal Solid	1.676	1.721	1.672	1.721	1.636	1.636	12.531	55.086	55.086
Normal I&E	22.216	20.261	20.655	22.998	23.501	22.998	23.510	92.212	92.212
94 Metal	2.906	6.772	2.231	6.559	2.369	6.559	7.128	51.603	51.603
Plutonium Produced, grams	29.957	33.263	27.381	32.315	30.577	32.315	32.454	82.783	82.783
Uranium In Reactor At Month End, tons	211.1	226.3	217.5	238.4	222.6	222.6	223.2	655.3	655.3
Normal Solid	92.0	61.2	73.5	75.8	65.1	75.8	76.1	207.3	207.3
Normal I&E	176.0	152.1	161.5	172.4	156.6	172.4	175.1	272.8	272.8
94 Metal	15.1	33.0	5.1	20.2	22.9	20.2	22.7	45.1	45.1
Uranium Discharged During Month, tons	67.1	64.8	71.6	64.5	66.5	64.5	65.7	172.1	172.1
Normal Solid	6.2	5.1	6.5	6.7	6.2	6.5	6.3	21.9	21.9
Normal I&E	50.0	32.3	46.7	46.7	46.3	46.7	46.3	125.9	125.9
94 Metal	2.9	7.1	6.1	2.9	2.9	6.1	6.1	18.6	18.6
Average Discharge Concentration	720	657	719	653	657	719	653	676	676
Normal Solid	656	650	656	652	652	656	652	659	659
Normal I&E	650	650	650	652	652	650	652	659	659
94 Metal	650	650	650	652	652	650	652	659	659

Extracted from Travis 1960a, page 10.

Reactor Outages 1960

Reactor outages for the month of January are as follows:

B REACTOR

Date Down	Date Up	Outage Hours	Remarks
12/30	1/1	42.6	Removal of a stuck I&E 94 metal production test rupture from tube 1764.
1/10	1/11	35.8	Removal of an I&E regular metal rupture from tube 3268 and charge-discharge.
1/21	1/24	77.0	Removal of a stuck I&E regular metal rupture from tube 1686 and charge-discharge.
1/24	1/25	19.8	Removal of a stuck I&E regular metal rupture from tube 2676.
1/31	Still Down		Removal of an I&E regular metal rupture from tube 1575.

C REACTOR

1/3	1/4	33.7	Removal of an I&E regular metal rupture from tube 2168.
1/14	1/16	40.6	Removal of an I&E regular metal rupture from tube 2171. Thermocouples were installed on vertical rows 51 thru 57.
1/21	1/23	37.4	Removal of an I&E regular metal rupture from tube 2576 and charge-discharge.
1/24	1/26	38.1	Removal of a stuck I&E regular metal rupture from tube 3861 and charge-discharge.

D REACTOR

1/4	1/9	117.9	Completed scheduled charge-discharge and tube replacement.
1/9	1/9	1.9	Venturi change in tubes 1991 and 2491.

---

Extracted from Plum 1961, January, pages 2-5.

D REACTOR (cont.)

1/25 1/27 52.3 Removal of pump shaft fragment (from No. 7 pump at 190 Bldg.) from crossheader screens and front face fittings and charge-discharge.\*

1/31 Still Down Temperature control due to a faulty ball valve on a PCCF Tube.

DR REACTOR

1/10 1/11 37.3 Removal of an I&E regular metal rupture from tube 1570. Completed charge-discharge and maintenance.

1/21 1/22 44.9 Leak testing. Tube 2185 was replaced.

1/24 1/24 0.3 Panellit trip.

1/24 1/24 0.2 Panellit trip.

F REACTOR

1/4 1/9 115.3 Water leak. Charge-discharge and tube replacement. Installation of crossheader differential gauges.

1/23 1/25 39.1 Removal of a stuck I&E regular metal rupture from tube 1182 and charge-discharge.

1/25 1/25 1.4 Manually tripped due to insufficient rods for control.

H REACTOR

1/9 1/10 32.7 Charge-discharge following maintenance on front face cap. Replaced ten leaking rear pigtails.

\* Shaft fragments were dislodged on 1/15 at the time No. 7 pump was being started up following impeller replacement. Cause of fail has not yet been determined.

II REACTOR (cont.)

1/20	1/22	52.7	Removal of a stuck I&E regular metal rupture from tube 2981. Charge-discharge and tube replacement.
1/23	1/23	3.8	Adjustment of gas composition.
1/23	1/23	0.7	Panellit trip.
1/26	1/28	40.5	Leak testing and replacement of tube 1960. Removal of a stuck I&E regular metal rupture from tube 3183.
1/28	1/28	0.6	Panellit trip.

III REACTOR

1/11	1/13	44.9	Removal of a solid regular metal rupture from tube 4345. Charge-discharge and tube replacement.
1/13	1/13	6.0	Poison discharge. A delay of about 2.5 hours was experienced due to the malfunction of a "C" elevator relay.
1/25	1/27	46.9	Removal of a stuck I&E regular metal rupture from tube 2052. Charge-discharge.
1/27	1/27	0.9	Beckman trip due to a surge on instrument power supply.
1/27	1/28	3.3	Poison discharge.
1/31	Still Down		Trip due to a faulty dump valve on KER Loop 2.

IV REACTOR

1/4	1/5	38.9	Panellit trip due to an I&E regular metal rupture from tube 3075 and charge-discharge.
1/6	1/6	2.9	Poison discharge.
1/22	1/24	6.4	Removal of an I&E regular metal rupture from tube 3866 and charge-discharge.
1/25	1/25	4.4	Poison discharge.

COMPARATIVE PILE PERFORMANCE FEB 1960									
B	C	D	DR	P	H	FE	KW	TOTAL	
Maximum Power Level To Date, MW	1,730	2,050	1,765	1,780	1,555	3,800	3,310	26,700	
Maximum Power Level During Month, MW	1,730	2,070	1,765	2,050	2,050	3,900	3,510	36,324	
Average Power Level While Operating, MW	2,594	2,711	1,639	1,523	1,659	3,772	3,598	36,324	
Maximum Tube Power, KW	2,190	2,200	1,167	1,089	1,236	2,450	2,416	24,166	
Maximum Central Tubes	2,450	2,455	1,450	1,555	1,450	2,530	2,535	24,175	
Effective Central Tubes	76.4	73.0	86.7	69.2	69.3	70.1	70.3	62.5	
Time Operated Efficiency, %	76.4	73.0	86.7	69.2	69.3	70.1	70.3	62.5	
Operational Limitation	2,280	2,200	1,573	1,268	1,268	1,450	1,450	2,520	
MWD Produced During Month, total	3,457	3,456	11,376	20,769	33,922	39,265	76,577	379,937	
Normal Solid	3,452	3,454	6,699	6,009	2,917	2,917	2,917	64,134	
Normal I&E	3,452	3,454	31,627	22,050	22,050	22,050	22,050	62,057	
9t Metal	3,452	3,454	2,577	2,480	2,480	2,480	2,480	22,237	
Plutonium Produced, grams	35,590	30,574	35,591	36,507	35,591	36,507	68,463	355,565	
Uranium In Reactor At Month End, tons	238.8	236.1	246.9	238.7	231.4	222.2	183.3	1,166.2	
Normal Solid	239.1	231.2	235.5	235.4	235.4	235.4	235.4	1,205.3	
Normal I&E	237.4	232.9	263.3	257.9	257.9	257.9	257.9	1,252.4	
9t Metal	24.4	21.3	20.1	26.1	23.1	21.7	21.7	21.7	
Uranium Discharged During Month, tons	72.9	90.1	81.1	81.9	81.9	81.9	81.9	324.2	
Normal Solid	71.1	2.1	7.1	7.1	7.1	7.1	7.1	22.2	
Normal I&E	61.9	61.7	61.7	61.7	61.7	61.7	61.7	57.7	
9t Metal	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	
Average Discharge Concentration	7.1	6.6	7.2	6.7	6.7	6.7	6.7	6.7	
Normal Solid	7.1	6.6	7.2	6.7	6.7	6.7	6.7	6.7	
Normal I&E	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	
9t Metal	6.7	6.7	6.7	6.7	6.7	6.7	6.7	6.7	

Extracted from Travis 1960b, page 10.

Reactor Outages      1960

B REACTOR

Date Down	Date Up	Outage Hours	Remarks
1/31	2/2	38.8	Removal of an I&E regular metal rupture from tube 1575 and miscellaneous maintenance.
2/2	2/2	3.1	Investigated the high water exit on tube 1564.
2/9	2/11	40.1	Panellit trip and charge-discharge.
2/11	2/11	21.6	Removal of an I&E regular metal rupture from tube 3880.
2/21	2/29	73.9	Removal of a stuck I&E regular metal rupture from tube 3284 and charge-discharge.

C REACTOR

2/4	2/5	39.9	Removal of a stuck I&E regular metal rupture from tube 2875. Seven zirconium tubes were installed.
2/6	2/7	29.2	Removal of a stuck I&E regular metal rupture from tube 2276.
2/7	2/7	4.0	Poison discharge.
2/10	2/12	63.5	Removal of a stuck I&E regular metal rupture from tube 1478 and charge-discharge.
2/13	2/13	3.1	Poison discharge.
2/14	2/15	28.5	Removal of a stuck I&E regular metal rupture from tube 0765. Retubed three channels.
2/15	2/15	.9	Panellit trip.
2/29	Still Down		Removal of an I&E regular metal rupture from tube 3087. Charge-discharge is in progress.

D REACTOR

1/31	2/2	45.2	Temperature control due to a faulty ball valve on a PCCF tube. Miscellaneous maintenance work performed.
2/21	2/24	65.9	Scheduled charge-discharge, tube replacement and trip-out tests.

DR REACTOR

2/1	2/1	.4	Panellit trip due to a faulty light socket in the PCCF control system.
2/1	2/3	45.4	PCCF charging machine hung up while attempting to discharge ball valve tube 2173. Completed leak testing.
2/3	2/3	1.4	High pressure Panellit trip.
2/4	2/4	.7	Unexplained trip on No. 1 safety circuit.
2/11	2/13	37.3	Charge-discharge following the correction of a loose Venturi assembly.
2/13	2/13	.3	Panellit trip, probably due to solid aluminum charge seating in the tube.
2/18	2/23	127.6	Loose Venturi on tube 3467. Charge-discharge and leak testing.
2/24	2/24	1.5	Continuation of trip-out testing.

F REACTOR

2/1	2/6	134.9	Scheduled charge-discharge and maintenance.
2/6	2/7	29.2	Manual trip due to insufficient control rods.
2/25	2/29	80.7	Removal of a stuck I&E regular metal rupture from tube 1985. Charge-discharge.

H REACTOR

2/8	2/10	36.4	Removal of a solid regular metal rupture from tube 0755 and an I&E regular metal rupture from tube 0770. Charge-discharge.
2/10	2/10	1.0	Investigation of by-pass indications in the safety circuit.
2/11	2/11	.2	Unexplained Panellit trip.
2/11	2/12	33.0	Removal of an I&E regular metal rupture from tube 3661.
2/13	2/13	3.8	Removal of a stuck I&E regular metal rupture from tube 0884.
2/13	2/13	.3	Panellit trip due to a rear pigtail failure.
2/16	2/17	32.6	Removal of an I&E regular metal rupture from tube 2978. Charge-discharge. (Further inspection of the metal discharged from tube 0770 (due to a suspected rupture) on 2/8/60 confirmed the presence of an I&E regular metal rupture.
2/17	2/17	1.6	Low pressure Panellit trip due to a rear cap leak on tube 2370.
2/17	2/17	2.8	Low pressure Panellit trip due to a rear cap leak on tube 2675.
2/22	2/24	34.3	Removal of a stuck I&E regular metal rupture from tube 2673. Charge-discharge.

KE REACTOR

1/31	2/2	35.3	Tripped due to a faulty dump valve on KER Loop 2, and miscellaneous maintenance.
2/7	2/9	32.7	Tripped due to a suspected cluster fuel element failure in Loop 1. Charge-discharge.

KE REACTOR (cont.)

2/21	2/22	33.1	Removal of a solid regular metal rupture from tube 5556. Charge-discharge.
2/22	2/23	7.1	Removal of a solid regular metal rupture from tube 4645.
2/23	2/25	37.9	Water leak testing.
2/25	2/25	10.9	Indications of a water leak on the near side. Tube 4651 was found to be leaking and was replaced.
2/25	2/25	.7	Unexplained Panellit trip.
2/26	2/26	.7	Removal of an I&E E-metal rupture from tube 1151.

KW REACTOR

2/5	2/6	34.5	Removal of an I&E regular metal rupture from tube 3890 and charge-discharge.
2/23	2/25	60.2	Removal of an I&E regular metal rupture from tube 2459 and charge-discharge.
2/26	2/26	22.6	Removal of a stuck I&E regular metal rupture from channel 2483.
2/27	2/27	4.7	Poison discharge.

URANIUM IN TONS  
1960

	REACTORS			SEPARATIONS		
	Charged March April	Inventory March April	Discharged March April	Inventory In Cooling March April	Discharged March April	Dissolved March April
<u>Normal U</u>	<u>452</u>	<u>540</u>	<u>2,085</u>	<u>2,085</u>	<u>461</u>	<u>540</u>
Solid	59	53	497	496	68	55
UE	396	487	1,588	1,593	393	485
					<u>2,239</u>	<u>2,037</u>
					<u>Normal U</u>	
						<u>24 Metal</u>
<u>24 Metal</u>	<u>71.5</u>	<u>73.5</u>	<u>217.8</u>	<u>219.4</u>	<u>68.8</u>	<u>72.1</u>
Solid	0	0	4.1	3.3	0.6	0.7
UE	71.5	73.5	213.7	216.1	68.2	71.4
					<u>330.8</u>	<u>326.8</u>
<u>Depleted U</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
					<u>8.5</u>	<u>8.5</u>

MWD AND SPECIAL MATERIALS  
1960

	REACTORS			SEPARATIONS		
	Charged or Produced March April	Inventory In Reactor March April	Inventory In Cooling March April	Discharged March April	Inventory In Cooling March April	Dissolved March April
<u>MWD</u>	<u>426,276</u>	<u>423,137</u>				
Normal	369,776	369,081	740,972	743,931	366,122	1,464,060
94 Metal	56,500	54,056	92,355	91,048	52,505	254,921
Depleted					55,363	247,094
						2,728
						<u>2,728</u>
						<u>203,956</u>
						<u>589</u>
						<u>28,544</u>
						<u>61,228</u>

Extracted from Travis 1960d, pages 4 and 6.

MacAdam Power Level To Date, MW  
MacAdam Power Level During Month, MW  
Average Power Level While Operating, MW  
MacAdam Tube Power, KW  
Ineffective Central Tubes  
Time Operated Efficiency, %  
Operational Limitations

Quantity Produced During Month, total  
Normal Solid  
Normal TSE  
Other Metal

Plutonium Produced, grams  
Uranium In Reactor At Month End, tons  
Normal Solid  
Normal I.M.  
9% Metal

Uranium Discharged During Month, tons

Average Discharge Concentration  
Normal Solid  
Normal Taf  
9% Metal

(1) new record

Extracted from Travis 1961c, page 7.

Reactor Outages 1960

Reactor outages for the month of March are as follows:

B Reactor

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
3/3	3/6	74.2	Leak testing.
3/13	3/14	37.7	Removal of a stuck I&E regular metal rupture in tube 2184. Charge-discharge.
3/22	3/23	36.0	Panellit trip when rear pigtail broke off of tube 3667. Charge-discharge and miscellaneous maintenance.

C Reactor

2/29	3/2	49.7	Removal of an I&E regular metal rupture in tube 3087, and charge-discharge.
3/2	3/2	0.5	Panellit trip due to an oscillating gage.
3/2	3/2	4.0	Poison discharge.
3/4	3/5	30.5	A heat imbalance caused by VSR #35 dropping. Charge-discharge.
3/17	3/19	35.5	Removal of an I&E 94 metal rupture from tube 0566. Charge-discharge and maintenance.
3/19	3/19	2.5	Repair of two faulty thermocouples.
3/29	3/31	33.5	Removal of a stuck I&E regular metal rupture from tube 2567. Charge-discharge.

D Reactor

3/3	3/5	34.3	Removal of a suspected I&E regular metal (mixer) rupture in tube 4187 and charge-discharge. The rupture was not confirmed.
3/21	3/25	85.5	Removal of an I&E regular metal rupture in tube 3563. Charge-discharge and maintenance.
3/25	3/27	35.4	Removal of an I&E regular metal rupture in tube 1463, and maintenance.

---

Extracted from Plum 1961, March, pages 2-4.

DR Reactor

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
3/9	3/11	38.5	Leak testing.
3/22	3/23	44.1	Removal of an I&E regular metal rupture in tube 3877. Charge-discharge.
3/25	3/26	32.0	Removal of an I&E 94-metall rupture from tube 0859.

F Reactor

3/1	3/3	48.3	Removal of an I&E regular metal rupture in tube 2369 and charge-discharge.
3/3	3/3	3.7	Panellit trip due to a tubular dummy in the nozzle at the rear pigtail.
3/9	3/11	52.1	Leak testing and charge-discharge.
3/28	Still Down		Removal of an I&E regular metal rupture in tube 3873 and charge-discharge.

H Reactor

3/2	3/5	67.1	Leak testing and charge-discharge.
3/11	3/12	34.1	Power failure caused by the failure of No. 2 process pump at F. Charge-discharge and maintenance.
3/12	3/13	2.1	Panellit trip due to a Hoke valve being partially closed.
3/15	3/17	41.6	Leak testing and charge-discharge.
3/31	3/31	0.5	High pressure Panellit trip on tube 1464.
3/31	Still Down		Removal of an I&E regular metal rupture in tube 1464.

KE Reactor

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
3/10	3/12	49.0	Panellit trip due to the failure of a pump servicing single pass tubes 4557 and 4863. Charge-discharge.
3/19	3/21	30.0	Power loss trip. Charge-discharge.
3/23	3/24	30.9	Removal of a solid regular metal rupture in tube 2044. Charge-discharge.

KW Reactor

3/11	3/13	66.2	Removal of an I&E regular metal rupture in tube 2060 and charge-discharge.
3/13	3/14	21.2	Removal of an I&E regular metal rupture in tube 2562.
3/15	3/15	6.0	Poison discharge.
3/17	3/18	38.0	Removal of an I&E regular metal rupture in tube 3557 and charge-discharge.

Maximum Power Level To Date, MW  
 Maximum Power Level During Month, MW  
 Average Power Level While Operating, MW  
 Maximum Tube Power, MW  
 Effective Central Tubes  
 Time Operated Efficiency, %  
 Operational Limitation

Produced During Month, total  
Normal Solid  
Normal Ink  
94 Metal

Plutonium Produced, grams	Uranium In Reactor At Month End, tons
Molar Solid	
Normal Y-2K	
94% Metal	

Uranium Discharged During Month, tons

Average Discharge Concentration  
Normal Solid  
Normal I&E  
94 Metal

(1) NEW RECORD

Extracted from Travis 1961d, page 7.

Reactor Outages      1960

Reactor outages for April, 1960 are as follows:

B REACTOR

Date Down	Date Up	Outage Hours	Remarks
4/4	4/9	125.3	Scheduled charge-discharge, tube replacement and Ball 3X work.
4/9	4/9	3.5	High temperature indicated on tube 2180. Investigation revealed a faulty thermocouple.
4/26	4/29	73.5	Removal of a stuck I&E regular metal rupture from tube 0668 and charge-discharge.

C REACTOR

4/1	4/1	0.6	Removal of an I&E regular metal rupture from tube 2588.
4/9	4/10	32.6	Removal of an I&E regular metal rupture from tube 1275 and charge-discharge.
4/11	4/11	0.3	Panellit trip.
4/11	4/13	32.1	Panellit trip; insufficient reactivity. Miscellaneous maintenance performed.
4/19	4/25	147.7	Removal of a stuck I&E E-metal rupture from tube 1380, charge-discharge and scheduled maintenance.

D REACTOR

4/10	4/13	61.1	Water leak and charge-discharge.
------	------	------	----------------------------------

DR REACTOR

4/1	4/2	37.1	Water leak.
4/12	4/14	37.8	Charge-discharge and miscellaneous maintenance following a trip originating with a transformer failure at 190 Building.
4/30	Still Down		Removal of an I&E E-metal rupture from tube 0774.

F REACTOR

3/28	4/1	83.6	Removal of a stuck I&E regular metal rupture from tube 3873. Charge-discharge and tube replacement.
4/3	4/4	33.8	Removal of a stuck I&E regular metal rupture from tube 1169.
4/8	4/10	38.0	Removal of a stuck I&E regular metal rupture from tube 1569 and charge-discharge.
4/26	4/28	40.8	Removal of an I&E regular metal rupture from tube 3683 and charge-discharge.

H REACTOR

3/31	4/4	83.8	Removal of an I&E regular metal rupture from tube 1464 and charge-discharge.
4/4	4/4	0.8	High pressure Panellit trip.
4/4	4/4	0.2	Panellit trip due to poison only partially flushing from a ball valve tube.
4/18	4/20	54.6	Water leak and charge-discharge.
4/23	4/24	34.9	Leak testing.

KE REACTOR

4/1	4/2	37.1	Tripped due to loss of No. 6 high-lift pump and charge-discharge.
4/8	4/9	31.5	Unexplained trip of HCR's and charge-discharge.
4/23	4/25	43.5	Tripped by a rupture in KER Loop 4, and charge-discharge.
4/26	4/26	0.6	Tripped due to a faulty thermocouple on Loop 4 heat exchanger.
4/27	4/29	29.8	Trip caused by a faulty grounding circuit in the Loop 3 heat exchanger temperature measuring system, and insufficient reactivity.

KW REACTOR

4/6	4/7	34.4	Removal of an I&E E-metal rupture from tube 2548 and charge-discharge.
4/28	4/30	56.9	Removal of a stuck I&E regular metal rupture from tube 1385 and charge-discharge.

URANIUM IN TONS  
1960

	REACTORS				SEPARATIONS			
	Charged May	Inventory In Reactor May	Discharged June	Inventory In Cooling May June	Charged May	Inventory In Reactor May	Discharged June	Dissolved May June
<u>Normal U</u>	<u>380</u>	<u>636</u>	<u>2,088</u>	<u>2,060</u>	<u>381</u>	<u>665</u>	<u>2,121</u>	<u>2,394</u>
Solid	53	62	491	477	57	77		
Lev	327	574	1,597	1,583	324	588		
<u>94 Metal</u>	<u>64.8</u>	<u>74.5</u>	<u>217.7</u>	<u>231.0</u>	<u>66.6</u>	<u>61.2</u>	<u>355.1</u>	<u>409.3</u>
Solid			1.4	1.1	2.0	0.3		
Lev	64.8	74.5	216.3	229.9	64.6	60.9		
<u>Depleted U</u>							<u>8.5</u>	<u>8.5</u>

(a) Corrected figure  
MWD AND SPECIAL MATERIALS  
1960

	REACTORS				SEPARATIONS			
	Charged or Produced May	Inventory In Reactor June	Discharged June	Inventory In Cooling May June	Charged May	Inventory In Reactor May	Discharged June	Dissolved May June
<u>MWD</u>	<u>44,863</u>	<u>43,918</u>						
Normal	395,36	380,089	875,021	807,484	264,255	447,626	1,392,056	1,559,013
94 Metal	59,518	59,829	98,550	111,238	52,016	47,141	269,972	306,616
Depleted							2,728	2,728

(1) Redox dissolved 90,790 MWD of this.

Extracted from Travis 1960f, pages 4 and 6.

COMPARATIVE PILE PERFORMANCE MAY 1960									
E	C		D		DR		H		NW
	DR	DR	F	H	KE				
Maximum Power Level To Date, MW	1.730	2.082	1.765	1.875	1.825	1.850	1.850	1.850	3.850
Maximum Power Level During Month, MW	1.650	1.950	1.765	1.755	1.705	1.650	1.570	1.570	3.600
Average Power Level While Operating, MW	1.635	1.852	1.601	1.586	1.604	1.755	1.755	1.755	3.557
Maximum Tube Power, KW	2.146	2.132	2.159	2.086	1.986	1.921	1.921	1.921	2.453
Effective Central Tubes	2.145	2.100	2.150	2.150	2.150	2.150	2.150	2.150	2.450
Time Operated Efficiency, %	88.6	88.5	88.2	88.2	88.1	89.1	89.1	89.1	90.4
Operational Limitation	21.523	21.493	21.023	21.023	21.023	21.023	21.023	21.023	21.023
HM Produced During Month, total	14.987 <sup>1</sup>	19.656	16.319	15.554	14.276	13.222	13.222	13.222	15.165 <sup>2</sup>
Normal Solid	14.667	16.720	14.469	13.963	13.859	12.822	12.822	12.822	15.602
Normal KE	5.863	5.375	5.252	5.252	5.830	5.322	5.322	5.322	5.777
% Metal	14.263	9.371	2.588	4.665	3.777	7.239	7.239	7.239	5.526
Plutonium Produced, grams	36.734	39.541	31.800	31.732	36.463	35.222	34.360	34.360	34.337
Uranium In Reactor At Month End, tons	212.9	226.9	207.6	229.3	220.2	225.7	225.7	225.7	230.1
Normal Solid	52.2	44.2	42.3	42.4	42.4	42.4	42.4	42.4	42.4
Normal KE	27.2	25.2	25.2	25.2	25.2	25.2	25.2	25.2	25.2
% Metal	21.9	26.6	9.1	23.0	25.4	22.3	22.3	22.3	21.7
Uranium Discharged During Month, tons	23.7	25.7	25.1	25.1	25.1	27.0	27.0	27.0	27.4
Normal Solid	2.9	2.9	2.9	2.9	2.9	2.6	2.6	2.6	2.6
Normal KE	2.7	2.7	2.7	2.7	2.7	2.5	2.5	2.5	2.5
% Metal	2.7	2.7	2.7	2.7	2.7	2.9	2.9	2.9	2.9
Average Discharge Concentration	763	638	743	743	690	697	697	697	729
Normal Solid	635	594	722	722	642	675	675	675	729
Normal KE	636	632	725	725	632	698	698	698	729

卷之三

Extracted from Travis 1960e, page 8.

Reactor Outages 1960

Reactor outages for the month of May are as follows:

B Reactor

Date Down	Date Up	Outage Hours	Remarks
5/10	5/10		Trip due to faulty relay in emergency power circuit.
5/10	5/12		Maintenance completed after insufficient reactivity.
5/12	5/12	1.1	Repair of a faulty thermocouple in tube 2875.
5/12	5/12	0.3	Panellit trip due to an oscillating gauge on Row No. 17.
5/30	Still Down		Removal of a stuck I&E E-metal rupture in tube 0967.

C Reactor

5/3	5/4	32.0	Removal of an I&E E-metal rupture in tube 2287. Charge-discharge.
5/5	5/6	35.9	Removal of an I&E E-metal rupture in tube 2780.
5/14	5/14	0.4	High Panellit trip on gauge 3962.
5/20	5/21	31.8	Removal of an I&E E-metal rupture from tube 1792. Charge-discharge.

D Reactor

5/1	5/3	64.3	Removal of an I&E regular metal rupture in tube 1366. Charge-discharge.
5/13	5/14	38.3	Repairs of ruptured export water line.
5/20	5/30	36.0	Miscellaneous maintenance and charge-discharge.

DR Reactor

4/30	5/2	34.2	Removal of an I&E regular metal rupture from tube 0774. Charge-discharge.
5/13	5/14	41.7	Repairs on ruptured export water line.
5/20	5/21	35.8	Replacement of leaking tube 2672 and further leak testing.
5/22	5/22	0.6	Replacement of front face nozzle cap on 0764.
5/28	Still Down		Removal of an I&E E-metal rupture from tube 3858 and charge-discharge.

F Reactor

5/16	5/18	46.0	Removal of an I&E regular metal rupture from tube 2887 and charge-discharge.
5/20	5/21	36.0	Removal of tube 0977 which had a split rear Van Stone.
5/22	5/22	0.4	Tripped due to malfunction of No. 51 relay which caused a loss of No. 7 pump at the 120 Building.

II Reactor

5/11	5/11	0.2	Panellit trip.
5/11	5/13	46.5	Removal of an I&E regular metal rupture from tube 3171 and charge-discharge.
5/24	5/26	47.6	Leak testing and charge-discharge.
5/26	5/26	1.3	Panellit trip when a rear face cap came loose on 0963.
5/26	5/26	0.9	Tightened a loose rear cap on 2279.
5/28	5/28	0.2	Leaking rear pigtail on tube 0490.
5/28	5/30	34.5	Severed rear pigtail on tube 0490.
5/30	Still Down		Water leak.

KE Reactor

5/14	5/16	48.0	Removal of a stuck I&E regular metal rupture from tube 1661 and charge-discharge.
5/16	5/16	2.2	High activity trip on Loop 3 due to a rupture in tube 3565.

KW Reactor

5/3	5/4	18.8	Beckman trip and insufficient reactivity Removal of a solid regular metal rupture from tube 0484.
5/17	5/18	33.3	Panellit trip due to rolling gauges and charge-discharge.
5/31	Still Down		Panellit trip on tube 0280.

---

Extracted from Plum 1961, May, pages 2-4.

1 New hardware.  
Extracted from Travis 1960f, page 7.

Reactor Outages 1960

Reactor outages for June, 1960 are as follows:

B REACTOR

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
5/30	6/2	72.5	Concluded rupture removal. Charge-discharge and tube replacement.
6/2	6/2	0.8	Panellit trip.
6/7	6/7	0.2	Panellit trip.
6/7	6/9	45.4	Panellit trip. Insufficient reactivity. Charge-discharge and miscellaneous maintenance.
6/26	6/27	29.6	Panellit trip. Insufficient reactivity. Charge-discharge and maintenance.

C REACTOR

6/3	6/5	43.8	Scheduled charge-discharge.
6/5	6/5	0.7	Panellit trip.
6/6	6/6	0.2	Panellit trip.
6/6	6/8	30.6	Panellit trip. Insufficient reactivity. Miscellaneous maintenance.
6/8	6/8	0.3	Panellit trip.
6/18	6/20	29.2	Removal of an I&E 94-metall rupture from tube 2456. Charge-discharge.
6/20	6/21	17.8	Removal of a stuck I&E regular metal rupture from tube 1889. Charge-discharge and tube replacement.
6/28	6/28	0.3	Power loss relay trip when a pump was being removed from service at 190 (due to the failure of a wear ring on the impeller assembly).
6/29	6/30	30.0	Temperature control and tube replacement.

---

Extracted from Plum 1961, June, pages 2-4.

D Reactor

6/9	6/11	48.7	Removal of an I&E 9 $\frac{1}{4}$ -metal rupture from tube 3964. Charge-discharge.
6/12	6/13	31.7	Temperature and pressure increase on tube 1074 when a spline cap insert became unscrewed and washed downstream.

IR Reactor

5/28	6/1	101.3	Concluded rupture removal. Charge-discharge and tube replacement
6/1	6/1	0.4	Tripped by low flow on the IR-1 loop.
6/2	6/2	0.2	Panellit trip when a jumper was inadvertently removed from gauge 2973.
6/17	6/19	38.0	Removal of a solid regular metal rupture from tube 2155. Charge-discharge and maintenance.
6/30	Still down		Tripped when a wire between Panellit gauges was inadvertently removed while attempting to remove a leaking gauge. Insufficient reactivity.

F Reactor

6/2	6/3	35.3	Removal of an I&E regular metal rupture from tube 2471. Charge-discharge.
6/20	6/21	38.7	Scheduled charge-discharge and maintenance.
6/24	6/26	48.0	Leak testing. Tube and Venturi replacements.

---

Extracted from Plum 1961, June, pages 2-4.

H Reactor

5/30	6/1	30.2	Completed leak testing and tube replacement.
6/1	6/1	0.8	Loose rear cap on tube 4357.
6/1	6/2	17.8	Removal of an I&E regular metal rupture from tube 1583. Charge-discharge.
6/3	6/4	29.5	Removal of a stuck solid regular metal rupture from tube 3553.
6/7	6/8	35.6	Leak testing and charge-discharge.
6/16	6/18	34.4	Removal of a stuck I&E regular metal rupture from tube 2178. Charge-discharge.
6/18	6/19	26.4	Leak testing and tube replacement.
6/26	Still down		Scheduled charge-discharge, tube replacement, and Ball 3X work.

K Reactor

6/6	6/8	58.5	Scheduled charge-discharge.
-----	-----	------	-----------------------------

KI Reactor

5/31	6/2	46.7	Charge-discharge following Panellit trip.
------	-----	------	---

---

Extracted from Plum 1961, June, pages 2-4.

U R A N I U M   I N   T O N S

	Reactors						Separations	
	Charged July	Inventory August	In Reactor July	In Reactor August	Discharged July	Discharged August	Inventory In Cooling July	Inventory In Cooling August
<u>Normal U</u>	<u>526</u>	<u>490</u>	<u>2,053</u>	<u>2,046</u>	<u>533</u>	<u>508</u>	<u>2,376</u>	<u>2,119</u>
Solid	75	57	462	440	90	79		
125	51	443	1,591	1,605	443	429		
							<u>Normal U</u>	
							Purex	<u>63</u>
							Reflex	72
							24 Metal	40
<u>24 Metal</u>	<u>20.0</u>	<u>66.2</u>	<u>234.9</u>	<u>255.3</u>	<u>86.2</u>	<u>65.8</u>	<u>495.5</u>	<u>255.0</u>
Solid			0.9	0.9	0.3	0		
125	90.0	66.2	234.0	234.4	85.9	65.8	Reflex	0

MWD AND SPECIAL MATERIALS  
1960

	Charged or Produced		Inventory In Reactor		Reactors		Inventory In Cooling		July		August	
	July	August	July	August	July	August	July	August	July	August	July	August
Normal	49,171	418,771										
94 Metal	51,614	360,903	795,850	812,699	363,248	344,054	1,604,628	1,406,611	343,887	542,938	0	0
Depleted	57,557	57,874	102,492	111,899	66,303	48,527	372,919	421,330	2,728	2,728	0	0

1 or 4%, Radar dissolved 27.5% W.D.

Extracted from *Travis 1960h*, pages 4 and 6.

COMPARATIVE PILE PERFORMANCE JULY 1960									
B	C	D	DR	P	H	KF	RW	TOTAL	
Maximum Power Level To Date, MW	2,080	1,765	1,835	1,850	3,800	3,840	19,765		
Maximum Power Level During Month, MW	1,685	1,675	1,690	1,675	3,590	3,650	17,570		
Average Power Level While Operating, MW	1,567	1,792	1,556	1,618	1,622	1,638	3,443		
Maximum Tube Power, KW	2,122	1,365	1,215	1,039	1,233	1,066	1,390		
Effective Central Tubes	1,172	1,720	1,170	1,565	1,435	1,630	2,500		
Time Operated Efficiency, %	78.5	72.8	89.3	69.3	78.6	86.2	79.3		
Operational Limitation	1,085	93.5	93.5	1,233	93.5	1,333	1,430		
WID Produced During Month, total	39,638	43,607	35,189	45,047	33,607	35,071	35,211		
Normal Solid	14,236	14,221	5,327	7,158	2,685	6,018	12,534		
Normal I&E	14,457	30,021	27,125	30,355	27,888	31,379	63,092		
94 Metal	14,907	8,458	2,239	7,501	2,007	7,551	23,353		
Plutonium Produced, grams	32,188	35,180	38,524	36,652	31,675	31,938	73,926		
Uranium In Reactor At Month End, tons	356.1	227.3	261.0	226.2	211.2	216.7	145.9		
Normal Solid	50.4	11.1	69.2	61.7	11.4	22.6	70.8		
Normal I&E	270.6	253.6	167.5	233.7	183.2	192.2	326.9		
94 Metal	25.1	32.6	20.0	30.3	21.2	24.9	45.9		
Uranium Discharged During Month, tons	56.1	62.2	55.6	59.4	59.0	54.5	155.2		
Normal Solid	6.6	6.0	15.2	20.6	5.0	14.5	13.4		
Normal I&E	15.7	24.3	21.9	24.3	2.2	18.2	121.4		
94 Metal	2.3	2.3	2.3	2.3	2.2	2.2	22.1		
Average Discharge Concentration	747	660	676	641	535	714	732		
Normal Solid	675	624	755	760	635	600	693		
Normal I&E	626	696	910	506	698	525	753		
94 Metal	767	753	753	753	753	753	768		

Extracted from Travis 1960g, page 7.

Reactor Outages 1960

Reactor outages for the month of July are as follows:

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
7/10	7/13	55.8	Removal of a stuck I&E regular metal rupture in tube 1265, and charge-discharge.
7/23	7/25	46.4	Removal of a stuck I&E regular metal rupture in tube 1383.
7/26	7/28	35.1	Tripped when No. 8 pump was lost due to a burned-out motor coil.
<u>C REACTOR</u>			
7/9	7/11	59.4	Removal of an I&E E-metal rupture from tube 2072, charge-discharge, and raw-water export line tie-in.
7/24	7/28	98.0	Scheduled charge-discharge and installation of 50 zircaloy process tubes.
7/28	7/28	2.5	Removal of a solid regular metal rupture from tube 2252.
<u>D REACTOR</u>			
7/9	7/15	135.5	Scheduled charge-discharge and tube replacement.
7/21	7/21	0.2	Panellit trip due to a ruptured Bourdon tube on gauge 1779.
7/21	7/22	32.3	Temperature control following a Panellit trip
7/22	7/22	0.5	Tripped by a 190 power failure while attempting to put a pump on the line.

---

Extracted from Plum 1961, July, pages 2-4.

7/29	7/29	0.2	Panellit trip due to a ruptured Bourdon tube on gauge 3695.
7/29	7/31	33.6	Removal of an I&E E-metal rupture from tube 3660, and miscellaneous maintenance.
7/31	7/31	0.3	Panellit trip due to a stuck toggle valve plunger.

DR REACTOR

6/30	7/2	33.6	Charge-discharge following a Panellit trip.
7/12	7/14	45.9	Panellit trip due to a stuck I&E E-metal rupture from tube 0677, and charge-discharge.
7/31	Still down		Removal of an I&E regular metal rupture from tube 2665, and charge-discharge.

F REACTOR

7/12	7/19	178.0	Scheduled charge-discharge, tube replacement, and maintenance.
7/20	7/22	45.6	Water leak.

H REACTOR

6/26	7/2	155.9	Concluded scheduled charge-discharge, tube replacement and Ball 3X work.
7/2	7/2	0.3	Unexplained Panellit trip.
7/14	7/17	76.6	Removal of a stuck solid regular metal rupture from tube 2352, charge-discharge, and leak testing.
7/17	7/17	1.0	Change Venturi on tube 2456.
7/20	7/23	48.4	Leak testing and charge-discharge.
7/26	7/26	0.4	Installation of a holding plate on the front face cap of tube 4371 when one of the three lugs was found to be missing.

---

Extracted from Plum 1961, July, pages 2-4.

KE REACTOR

7/3	7/6	71.9	Trip due to a rupture in KER Loop 2, and charge-discharge.
7/7	7/8	24.2	Tripped due to a rupture in KER Loop 1.
7/15	7/16	32.0	Temperature trip on KER Loop 4 heat exchanger.
7/16	7/16	4.6	Tripped by malfunction of water cross-tie by-pass switch.
7/17	7/18	26.5	Panellit trip caused by loss of No. 1 low-lift pump unit due to high temperature on the motor winding.

KW REACTOR

7/4	7/7	70.4	Panellit trip due to an I&E regular metal rupture from tube 2974.
7/17	7/19	32.1	Unexplained Panellit trip. Charge-discharge and miscellaneous maintenance were performed.

COMPARATIVE PILE PERFORMANCE									
1960					1960				
B		C		D	IR		F		H
Maximum Power Level To Date, MW	1,730	2,080	1,765	1,035	1,835	1,890	3,900	3,040	19,765
Maximum Power Level During Month, MW	1,610	1,865	1,655	1,665	1,650	1,575	3,470	3,550	17,170
Average Power Level While Operating, MW	1,601	1,925	1,571	1,554	1,575	1,631	3,169	3,243	16,172
Maximum Tube Power, MW	1,108	1,063	1,105	1,053	1,150	1,015	1,396	1,408	
Effective Central Tubes	1,480	1,705	1,515	1,555	1,625	1,625	2,435	2,495	
Time Operated Efficiency, %	79.8	91.2	85.2	85.4	87.4	86.7	73.4	84.0	84.5
Operational Limitation	93.5%	100.0%	93.5%	93.5%	115.0%	93.5%	112.0%	113.0%	
MHD Produced During Month, total	39,659	53,304 <sup>1</sup>	41,501	36,616	42,660	43,859	72,057	87,081	118,777
Normal Solid	6,237	6,912	6,159	5,677	3,276	2,055	4,998	10,247	12,761
Normal IRF	31,441	32,365	32,569	26,125	35,707	33,779	57,386	315,112	315,112
9L Metal	3,981	10,227	2,773	6,314	3,675	8,025	9,953	12,926	57,874
Plutonium Produced, grams	32,198	42,639	36,111	29,810	36,965	35,108	64,692	77,939	351,792
Uranium In Reactor At Month End, tons	260.2	227.4	246.7	225.3	210.4	222.0	142.6	145.0	2,280.1
Normal Solid	50.6	51.1	65.2	60.9	61.2	22.7	59.3	96.4	135.5
Normal IRF	170.5	153.9	167.9	135.3	182.1	155.4	339.6	300.4	1,605.1
9L Metal	19.1	32.4	9.6	30.5	17.1	31.9	43.7	42.2	235.5
Uranium Discharged During Month, tons	21.3	16.5	66.2	36.6	36.2	13.6	160.8	180.7	573.9
Normal Solid	1.9	7.5	5.2	8.8	2.6	0.9	34.6	13.6	79.1
Normal IRF	16.0	27.1	26.3	2.1	30.2	36.2	103.3	155.3	428.8
9L Metal	1.1	13.9	2.7	5.4	3.1	4.5	22.9	21.8	66.0
Average Discharge Concentration	750	686	750	684	745	732	566	719	636
Normal Solid	702	732	709	733	648	612	659	702	685
Normal IRF	852	656	796	835	869	653	759	736	

<sup>1</sup> New record.  
Extracted from Travis 1960th, page 7.

## Reactor Outages 1960

Outages for the month of August are as follows:

### B REACTOR

Date Down	Date Up	Outage Hours	Remarks
8/6	8/8	42.7	Panellit trip due to a loose jumper on Row 35. Tube 3090 was replaced due to a water leak and charge-discharge work was performed.
8/27	Still Down		Scheduled charge-discharge, tube replacement and downcomer modification.

### C REACTOR

8/10	8/12	42.2	Removal of an I&E E-metal rupture from tube 3578 and charge-discharge.
8/12	8/12	0.3	Unexplained Panellit trip.
8/13	8/13	0.5	Two unexplained Panellit trips.
8/24	8/24	0.2	Panellit trip on tube 3285, probably due to the spline cap insert working loose.

### D REACTOR

8/1	8/1	0.7	Removal of an I&E E-metal rupture from tube 0770.
8/7	8/9	56.5	Removal of an I&E E-metal rupture from tube 2060.
8/9	8/10	18.8	Removal of an I&E E-metal rupture from tube 2262.
8/21	8/22	34.1	Tripped by power-supply loss while attempting to restore power to annunciator system. Charge-discharge work was performed.

---

Extracted from Plum 1961, August, pages 2-4.

D REACTOR

Date Down	Date Up	Outage Hours	
7/31	8/2	35.2	Concluded charge-discharge and maintenance following rupture removal.
8/7	8/7	0.7	Tripped by loop 1 when the building air compressor failed, dropping the air pressure below the loop trip point.
8/7	8/8	30.7	Concluded a small charge-discharge and maintenance during period of insufficient reactivity following loop trip.
8/11	8/12	18.0	Tube 2165 was replaced due to a rear Van Stone leak.
8/12	8/13	1.5	Manual trip for temperature control on tube 4055.
8/13	8/13	1.2	Repaired a leak in the front connector on tube 0677.
8/19	8/19	0.6	Unexplained flux monitor trip while flushing poison.
8/26	8/26	0.6	Leak in inlet hose connector on No. 8 HCR.

F REACTOR

8/12	8/14	68.4	Manual trip for temperature control, leak testing, and charge-discharge.
8/14	8/14	2.0	Unexplained Panellit trip.
8/30	Still Down		Scheduled charge-discharge and high-tank flushing.

H REACTOR

8/11 8/15 95.5 Removal of an I&E regular metal rupture from tube 2558, charge-discharge and leak testing.  
8/16 8/16 3.0 Changed Venturis on six tubes.  
8/16 8/16 0.2 Tripped when PCCF tube 0386 was valved to low-flow prior to jumpering the Panellit gauge.

K/E REACTOR

8/3 8/4 41.1 Removal of an I&E E-metal rupture from tube 1548 and charge-discharge.  
8/4 8/4 0.3 Unexplained Panellit trip on tube 4291.  
8/5 8/5 0.6 Tripped by low-flow on KER Loop 1 during a pump chv  
8/5 8/5 0.4 Unexplained Panellit trip.  
8/7 8/9 31.7 Removal of a rupture from KER Loop 2.  
8/19 8/20 19.9 Removal of an I&E regular metal rupture from tube 3271.  
8/21 8/22 28.9 Removal of a rupture from KER Loop 1.  
8/23 8/23 2.1 Removal of a solid regular metal rupture from tube 4844.  
8/24 8/25 30.8 Removal of a solid regular metal rupture from tube 4943 and charge-discharge.  
8/27 8/28 31.4 Panellit trip on tube 5085 due to a ruptured spline cap seal.

K/W REACTOR

8/9 8/11 80.0 Scheduled charge-discharge and installation of a new No. 1 low-lift pump motor and impeller of greater pumping capacity.  
8/19 8/20 31.1 Removal of an I&E E-metal rupture from tube 0005.  
8/23 8/24 31.6 Removal of a small bolt from No. 13 cross-header screen, detected by abnormal Panellit readings.

URANIUM IN TONS  
1960

	REACTORS			SEPARATORS		
	Charged Sept.	In Reactor Oct.	Discharged Sept. Oct.	Inventory In Coolant Sept. Oct.	Inventory 2,377 2,377	Dissolved Sept. Oct.
Normal U	614	522	2,042	616	563	
Solid	46	14	477	78	42	
14%	568	545	1,675	538	521	
Scrap						
94% Metal	87.3	85.3	235.9	86.6	75.2	
Solid	0	0	0.7	0.6	0.1	
14%	87.3	85.3	235.2	86.5	75.1	
Scrap						
Depleted U						

MUD AND SPECIAL MATERIALS  
1960

	REACTORS			SEPARATORS		
	Charged or Produced Sept.	Inventory In Reactor Oct.	Discharged Sept. Oct.	Inventory In Cooling Sept. Oct.	Disolved Sept. Oct.	
MUD	425,472	420,617				
Normal	366,408	361,895	750,792	723,004	428,815	1,447,920
94% Metal	59,064	58,762	102,392	103,453	68,511	475,619
Depleted						

Extracted from Travis 1960j, pages 3 and 5.

COMPARATIVE PALE PERFORMANCE SEP 1960									
B	C	D	E	F	G	H	I	KW	Total
Maximum Power Level To Date, MW	2,080	1,765	2,035	2,825	1,890	3,840	3,800	18,705	
Maximum Power Level During Month, MW	1,675	1,655	1,660	1,675	1,675	3,585	3,605	17,435	
Maximum Power Level While Operating, MW	1,508	1,809	1,577	1,569	1,613	1,596	1,575	16,880	
Average Power Level, MW	1,305	1,094	1,075	1,072	1,138	1,030	1,114	1,420	
Maximum Tube Power, KW	1,485	1,700	1,500	1,440	1,600	2,505	2,520		
Effective Central Tubes	78.6	79.5	67.7	77.7	90.6	91.5	91.5	63.0	
Fine Operated Efficiency, %	93.5%	1100%	93.5%	95.0%	93.5%	93.5%	93.5%	11.30MW	
Operational Limitation									
WAD Produced During Month, total	35,570	43,156	32,078	36,563	43,811	41,658	42,988	425,412	
Normal Solid	28,156	4,076	4,445	5,375	3,323	2,715	20,191	38,913	
Normal T&E	3,350	30,697	25,442	25,329	36,567	32,210	68,560	327,586	
% Metal		8,357	2,111	5,789	7,961	7,669	13,630	116,137	59,064
Plutonium Produced, grams	29,577	35,466	26,633	30,154	36,203	32,262	38,657	82,665	361,917
Uranium In Reactor At Month End, tons	201.3	227.4	216.2	221.6	239.4	211.9	112.9	113.9	2,277.3
Normal Solid	168.9	61.1	61.7	53.2	29.2	19.3	81.0	81.0	1,600.9
Normal T&E	213.7	253.6	175.1	114.2	163.0	156.7	340.3	311.2	1,635.0
% Metal	16.7	32.5	9.1	20.2	27.1	35.9	13.1	18.7	235.9
Uranium Discharged During Month, tons	76.0	110.1	57.0	317.5	53.9	16.2	76.2	163.4	702.6
Normal Solid	9.1	7.4	20.0	211.2	3.5	7.0	2.1	21.9	76.2
Normal T&E	59.6	86.3	63.6	119.1	65.6	3.9	65.3	107.2	537.6
% Metal	7.3	16.7	3.4	31.2	2.8	5.3	3.1	31.3	56.8
Average Discharge Concentration	760	682	619	695	775	717	795	715	
Normal Solid	694	650	615	725	669	552	720	698	694
Normal T&E			616	1,022	908			734	789
% Metal									

Extracted from Travis 19601, page 7.

Reactor Outages 1960

Reactor outages for September are as follows:

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
----------------------	--------------------	-------------------------	----------------

B REACTOR

8/27	9/3	177.8	Charge-discharge, tube replacement, high tank flushing, rear face decontamination and downcomer modification.
9/4	9/4	1.2	Tripped due to insufficient control rod to achieve turnaround.
9/11	9/12	42.8	Water leak.
9/18	9/20	38.2	Water leak.
9/20	9/20	1.7	Replaced two front connectors leaking at fittings.

C REACTOR

9/4	9/8	99.1	Scheduled charge-discharge, leak testing and miscellaneous maintenance.
9/23	9/25	48.6	Removal of an I&E regular metal rupture from tube 1486 and charge-discharge.

D REACTOR

9/4	9/5	38.6	Water leak and charge-discharge.
9/12	9/18	157.7	Scheduled charge-discharge, tube replacement, ball 3X modifications and downcomer modification.
9/24	9/25	36.2	Removal of an I&E regular metal rupture from tube 1960 and charge-discharge.

---

Extracted from Plum 1961, September, pages 2 and 3.

DR REACTOR

9/8	9/11	84.5	Charge-discharge and tube replacement
9/19	9/20	35.6	Water leak.
9/25	9/27	40.6	Removal of an I&E E-metal rupture from tube 0684, and charge-discharge.

F REACTOR

8/30	9/3	93.2	Charge-discharge, high tank flushing, and leak testing.
------	-----	------	--

H REACTOR

9/6	9/9	57.3	Charge-discharge and high tank flushing.
9/13	9/14	35.8	Water leak.
9/15	9/15	0.2	Panellit trip.
9/29	9/29	0.2	Panellit trip.

KE REACTOR

9/9	9/11	39.7	Leak on front header of KER Loop 3, charge- discharge, and the installation of the foundation cooling system.
-----	------	------	---

KW REACTOR

9/6	9/8	35.7	Panellit trip and charge-discharge.
9/29	9/30	45.6	Scheduled charge-discharge.

COMPARATIVE PILE PERFORMANCE OCT 1960									
B	C	D	E	F	G	H	I	KW	TOTAL
Maximum Power Level To Date, KW	2,130	2,080	1,765	1,035	1,825	1,800	3,800	3,840	38,765
Maximum Power Level During Month, KW	2,725	1,950	1,690	1,725	1,725	1,690	3,735	3,700	37,935
Average Power Level While Operating, KW	1,507	1,035	1,652	1,665	1,505	1,504	3,630	3,447	36,575
Maximum Tube Power, KW	1,137	1,135	1,124	1,082	1,273	938	2,438	2,460	
Effective Central Tubes	2,518	2,720	1,500	1,530	1,475	1,550	2,475	2,590	
Time Operated Efficiency, %	75.7	80.2	69.5	65.3	67.1	75.5	86.1	86.9	78.0
Operational Limitation	113000	113500	93,500	92,000	93,500	93,500	115000	115000	
WID Produced During Month, total	37,521	45,667	45,836	33,521	33,124	36,580	92,900	92,900	
Normal Solid	3,736	5,307	5,325	5,031	5,053	5,053	6,752	6,752	
Normal I&E	27,563	32,414	37,113	23,757	27,022	26,637	70,066	70,066	
9 <sub>4</sub> Metal	3,552	8,946	2,393	5,234	6,771	6,771	20,022	20,022	
Plutonium Produced, grams	30,430	36,460	37,405	28,231	28,205	28,205	86,953	86,953	
Uranium In Reactor At Month End, tons	211.0	227.3	215.2	221.6	238.6	225.6	182.5	183.4	222.1
Normal Solid	171.4	171.1	157.1	153.2	20.0	15.4	52.5	79.6	378.3
Normal I&E	171.9	153.3	186.0	211.2	189.9	162.6	236.5	235.4	1659.8
9 <sub>4</sub> Metal	28.7	22.9	9.1	35.2	18.7	35.6	16.4	18.1	244.0
Uranium Discharged During Month, tons	97.3	15.9	51.6	1.3	88.2	119.2	225.5	47.6	638.1
Normal Solid	55.7	0	12.4	0	9.7	3.2	5.7	6.3	142.4
Normal I&E	41.2	6.1	39.1	0.2	73.3	135.5	105.1	31.7	520.5
9 <sub>4</sub> Metal	2.9	9.8	2.7	1.1	5.2	10.5	32.1	9.6	75.2
Average Discharge Concentration	722	653	613	746	730	763	726	721	714
Normal Solid	652	605	619	756	639	721	650	611	687
Normal I&E				670	707	749	755	692	768

Extracted from Travis 1960j, page 6.

Reactor Outages 1960

Reactor outages for the month of October, 1960, are as follows:

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
10/4	10/7	76.8	Leak testing, tube replacement, and charge-discharge completed.
10/17	10/19	59.6	Leak testing and tube replacement.
10/22	10/23	14.7	Leak testing. A delay of about 5 hours was experienced when one hopper of 3-X balls was inadvertently dropped.
<u>C REACTOR</u>			
10/9	10/9	0.4	Panellit trip
10/9	10/11	39.9	Removal of an I&E-E metal rupture from tube 1656, charge-discharge and leak testing.
10/12	10/12	0.4	Panellit trip due to pressure increase on spline cap tube 0890.
10/17	10/22	106.6	Scheduled charge-discharge and miscellaneous maintenance.
<u>D REACTOR</u>			
10/19	10/22	62.1	Scheduled charge-discharge and tube replacement.
10/22	10/22	2.2	Panellit trip.
10/31	Still down		Water leak. Charge-discharge in progress.

---

Extracted from Plum 1961, October, pages 2-4.

DR REACTOR

10/3	10/5	38.4	Completed leak testing and maintenance work during a period for cooling over-heated bearings in gas loop compressor.
10/5	10/5	.5	Unexplained trip.
10/6	10/7	32.2	Removal of an I&E-E metal rupture from tube 0681.
10/24	Still down		Chute liner replacement and Ball 3-X modification. Five tubes were successfully over-bored.

F REACTOR

10/1	10/7	157.9	Scheduled charge-discharge and tube replacement and maintenance.
10/9	10/11	32.8	Panellit trip due to a ruptured rear pigtal. Miscellaneous maintenance performed.
10/23	10/25	51.4	Removal of an I&E-E metal rupture from tube 0778. Concluded rupture removal and charge-discharge and miscellaneous maintenance.

H REACTOR

10/10	10/16	164.6	Scheduled charge-discharge and tube replacement.
10/16	10/16	1.6	Repair of a broken wire which prevented the movement of two top rows of HCR's.
10/17	10/17	0.7	Correct rear cap leaks.
10/22	10/24	37.8	Removal of an I&E-E metal rupture from tube 3292 and an I&E regular metal from tube 1260.

KE REACTOR

10/4	10/7	55.2	Scheduled charge-discharge.
10/26	10/28	47.8	Charge-discharge following a Panellit trip.
10/28	10/28	0.7	Unexplained Panellit trip..

KW REACTOR

10/13	10/15	3.5	Removal of an I&E-E metal rupture from tube 4585 and charge-discharge.
10/15	10/16	22.6	Removal of an I&E regular metal rupture from tube 2864.
10/19	10/20	39.3	Tripped by overload relay on #6 low lift pump motor.

URANIUM : TONS

1960

		REACTORS				SEPARATIONS			
		Charged Nov. Dec.	Inventory In Reactor Nov. Dec.	Discharged Nov. Dec.	In Cooling	Inventory Nov. Dec.	In Cooling Nov. Dec.	Disolved Nov. Dec.	
<u>Normal U</u>									
<u>Solid</u>		<u>576</u>	<u>530</u>	<u>2,038</u>	<u>2,033</u>	<u>678</u>	<u>55</u>	<u>1,873</u>	
<u>1M</u>		<u>28</u>	<u>22</u>	<u>347</u>	<u>305</u>	<u>60</u>	<u>64</u>	<u>1,85</u>	
<u>Scrap</u>		<u>448</u>	<u>508</u>	<u>1,691</u>	<u>1,728</u>	<u>418</u>	<u>471</u>	<u>None</u>	
<u>94 Metal</u>								<u>94 Metal</u>	
<u>Solid</u>		<u>74.0</u>	<u>88.5</u>	<u>242.3</u>	<u>241.3</u>	<u>75.5</u>	<u>81.4</u>	<u>602.0</u>	
<u>1M</u>				<u>0.6</u>	<u>0.6</u>	<u>0</u>	<u>0</u>	<u>617.4</u>	
<u>Scrap</u>				<u>241.7</u>	<u>240.7</u>	<u>75.5</u>	<u>89.4</u>		
<u>Depleted U</u>									
								<u>94.5 76.8</u>	

MWD : ND SPECIAL MATERIALS

		REACTORS				SEPARATIONS			
		Charged or Produced Nov. Dec.	Inventory In Reactor Nov. Dec.	Discharged Nov. Dec.	In Cooling Nov. Dec.	Inventory In Cooling Nov. Dec.	Disolved Nov. Dec.	In Cooling Nov. Dec.	Disolved Nov. Dec.
<u>MWD</u>		<u>656,165</u>	<u>671,436</u>						
<u>Normal</u>		<u>392,004</u>	<u>405,537</u>	<u>777,348</u>	<u>818,803</u>	<u>337,660</u>	<u>364,082</u>	<u>1,254,474</u>	<u>488,854</u>
<u>94 Metal</u>		<u>64,161</u>	<u>65,899</u>	<u>110,076</u>	<u>105,802</u>	<u>57,518</u>	<u>70,168</u>	<u>462,704</u>	<u>402,056</u>
<u>Depleted</u>								<u>2,728</u>	<u>58,786</u>
								<u>2,728</u>	<u>71,754</u>

Extracted from Travis 1961a, pages 4 and 6.

	COMPARATIVE PILE PERFORMANCE NOV 1960			
	B	C	D	E
Maximum Power Level To Date, MW	2,050	1,765 <sup>1</sup>	1,655	1,690
Maximum Power Level During Month, MW	1,950	1,765 <sup>1</sup>	1,525	1,655 <sup>1</sup>
Average Power Level While Operating, MW	1,677	1,529	1,576	1,673
Average Power Level, MW	1,660	1,319	1,235	1,656
Maximum Tube Power, MW	2,161	2,160	2,155	2,150
Effective Central Tubes	1,625	1,625	1,550	2,570
Time Operated Efficiency, %	86.3	67.7	82.1	90.4
Operational Limitation	2,160	93.5	60.0	1,500
MM Produced During Month, total	50,711	46,355	36,898	100,359
Normal Solid	46,718	46,483	46,599	8,757
Normal I&F	36,250	37,075	36,228	72,458
9t Metal	9,533	2,817	6,071	64,161
Plutonium Produced, grams	35,510	42,697	31,358	89,236
Uranium In Reactor At Month End, tons	211.0	227.1	215.7	162.2
Normal Solid	161.1	151.4	121.3	72.8
Normal I&F	215.6	193.4	193.5	221.1
9t Metal	15.1	32.3	28.5	17.1
Uranium Discharged During Month, tons	12.3	67.6	44.9	52.9
Normal Solid	12.2	9.1	36.5	50.7
Normal I&F	35.7	48.0	35.1	42.1
9t Metal	2.4	20.5	2.1	2.1
Average Discharge Concentration	737	726	726	777
Normal Solid	690	768	693	707
Normal I&F	861	682	881	655
9t Metal				744
				TOTAL
				20,955
				3,910 <sup>1</sup>
				3,910 <sup>1</sup>
				18,720
				3,701
				17,737
				1,445
				2,535
				85.3
				1,520

<sup>1</sup> New record.

Extracted from Travis 1960k, page 7.

Reactor Outages 1960

Outages for the month of November are as follows:

B REACTOR

Date Down	Date Up	Outage Hours	Remarks
11/6	11/8	46.3	Charge-discharge and rupture removal.
11/8	11/8	3.2	Panellit trip due to plugging of cone screen in tube 3992.
11/14	11/16	36.6	IE regular metal rupture in Tube 1166.
11/30	Still down		An IE regular metal rupture in tube 3563.

C REACTOR

Date Down	Date Up	Outage Hours	Remarks
11/6	11/10	88.3	Charge-discharge and rupture removal. Two channels were successfully overbored 0.550" from the front flange to the graphite.
11/11	11/11	0.1	Panellit trip due to a faulty gauge.
<u>D REACTOR</u>			
From 10/31-11/1	11/2	53.5	Charge-discharge and leak testing.
11/12	11/15	60.0	Charge-discharge and rupture removal.

DR REACTOR

From 10/24-11/1	11/3	236.9	Scheduled ball 3X revisions and chute liner and mattress plate replacement.
11/17	11/18	35.3	Leak testing.
11/18	11/18	1.0	Change venturi on tube 0757.
11/19	11/18	1.6	Panellit trip due to heat shift.
11/20	11/21	36.2	Solid regular metal rupture in tube 1122.

Extracted from Plum 1961, November, pages 2-4.

11/21 11/22 1.9 Manual trip due to insufficient rods for control.

11/22 11/22 1.1 Solid regular metal rupture in tube 2455.

I REACTOR

11/13 11/13 70.1 Rupture removal and charge-discharge.

11/16 11/16 1.0 Adjustment of shielding on air channel 2083.

11/19 11/21 38.1 Leak Testing.

11/30 Still down I&E regular metal rupture in tube 1677.

II REACTOR

Date Down	Date Up	Outage Hours	Remarks
11/7	11/8	34.5	Charge-discharge following a Panellit trip.
11/9	11/9	0.5	Unexplained Panellit trip.
11/10	11/9	0.2	Unexplained Panellit trip on row 11.
11/10	11/9	0.2	Unexplained Panellit trip on row 12.
11/9	11/9	0.2	" " " " "
11/10	11/11	32.1	Leak testing following a Panellit trip.
11/19	11/19	0.2	Unexplained Panellit trip.
11/19	11/30	32.3	Miscellaneous maintenance following a Panellit trip.
11/27	11/27	0.2	Unexplained Panellit trip on Gauge 3056.
11/28	11/29	33.1	Leak testing.

HE REACTOR

11/11	11/12	46.6	Charge-discharge and rupture removal.
11/27	11/30	71.6	Rupture removal. A rewound motor was installed on "2 low lift pump and three 1706 single-pass tubes were installed.

HM REACTOR

11/11	11/14	60.8	Charge-discharge following rupture removal.
11/14	11/14	0.6	Open two Gamma monitor sample lines.

COMPARATIVE FILE PERFORMANCE DEC. 1960

B	C	D	E	H			IV	TOTAL
				F	G	H		
Maximum Power Level To Date, MW	2,090	1,810	1,855	1,835	1,900	1,895	4,000	29,170
Maximum Power Level During Month, MW	2,090	1,810	1,785	1,835	1,900	1,895	4,000	29,060
Maximum Power Level During Month, MW	1,779	1,722	1,713	1,725	1,760	1,834	3,872	28,092
Average Power Level While Operating, MW	1,203	1,221	1,209	1,171	1,233	1,158	1,525	1,530
Maximum Tube Power, MW	1,720	1,695	1,590	1,610	1,660	2,500	2,570	
Effective Central Tubes	82.2	77.3	92.6	89.4	92.5	76.3	86.3	84.9
Time Operated Efficiency, %	121085	121085	121585	121585	121585	121585	121585	121585
Operational Limitation								
H2O Produced During Month, total	13,788	16,321	50,576	67,533	15,524	52,355	61,233	203,666
Normal Solid	6,045	6,338	16,612	21,795	7,460	17,322	16,969	7,699
Normal T2F	35,120	32,521	12,958	26,350	39,106	60,122	65,238	80,853
94 Metal	1,313	5,462	3,477	7,388	1,453	20,631	21,306	25,064
Plutonium Produced, grams	36,113	36,716	11,704	36,697	31,521	11,243	72,806	91,793
Uranium In Reactor At Month End, tons	211.1	226.5	211.0	222.6	221.3	221.3	142.6	142.5
Normal Solid	141.7	151.1	151.2	156.5	156.5	156.5	156.5	156.5
Normal T2F	19.4	21.5	20.7	20.7	20.7	20.7	20.7	20.7
94 Metal								
Uranium Discharged During Month, tons	69.1	115.6	73.9	55.5	63.3	31.1	86.0	163.7
Normal Solid	64.2	64.1	64.2	64.3	64.3	64.3	64.3	64.3
Normal T2F	58.0	58.2	58.2	58.3	58.3	58.3	58.3	58.3
94 Metal	5.5	21.0	21.0	10.1	10.1	10.1	10.1	10.1
Average Discharge Concentration	736	688	764	710	800	1,050	752	735
Normal Solid	666	665	753	832	657	959	569	672
Normal T2F	859				865	970	711	765
94 Metal								

Extracted from Travis 1961a, page 7.

Reactor Outages 1960

Outages for the month of December are as follows:

B REACTOR

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
11/30	12/3	65.3	Removal of an I&E regular metal rupture from tube 3566 and miscellaneous maintenance.
12/18	12/19	35.9	Removal of an I&E regular metal rupture from tube 1559.
12/21	12/23	44.1	Leak testing and replacement of tubes 1276 and 2379.

C REACTOR

12/4	12/8	89.4	Scheduled charge-discharge and maintenance. Two channels were successfully overbored.
12/14	12/15	33.7	Removal of an I&E E metal rupture from tube 0957.
12/25	12/27	41.8	Removal of an I&E E metal rupture from tube 2276.
12/29	12/29	0.4	Leaking front pigtail.
12/30	12/30	0.3	An unexplained Beckman trip.

D REACTOR

12/12	12/15	55.2	Scheduled charge-discharge.
-------	-------	------	-----------------------------

DR REACTOR

12/11	12/13	41.8	Removal of a solid regular metal rupture from tube 4090 and charge-discharge.
12/22	12/23	36.9	Leaking tube 3275 was replaced.

F REACTOR

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
11/30	12/2	47.4	Removal of an I&E regular metal rupture from tube 1677 and charge-discharge.
12/3	12/3	1.5	Open gamma monitor sample line.
12/3	12/4	21.9	Water leak - a gasket leak on tube 0854 was corrected and a new Van Stone was formed on tube 0964.
12/17	12/19	54.6	Removal of an I&E regular metal rupture from tube 2861 and charge-discharge and maintenance.

H REACTOR

12/26	12/29	55.8	Removal of a stuck I&E regular metal rupture in tube 1472 and charge-discharge.
12/29	12/29	0.3	Unexplained Panellit trip.

KE REACTOR

12/7	12/8	42.8	Removal of an I&E metal rupture from tube 5369. Installed two single pass tubes for 1706 system.
12/8	12/9	3.0	Replaced venturis in two tubes.
12/9	12/9	6.2	Tripped due to a rupture in loop 3. (PT-IP-309A).
12/10	12/12	36.4	Removal of an I&E regular metal rupture from tube 3476.
12/15	12/17	34.7	Removal of an I&E regular metal rupture from tube 1351, charge-discharge and miscellaneous maintenance.
12/18	12/18	0.5	Tripped due to a ruptured spline cap seal on tube 4588.

KE REACTOR cont.

<u>Date Down</u>	<u>Date UP</u>	<u>Outage Hours</u>	<u>Remarks</u>
12/18	12/19	31.6	Miscellaneous maintenance following a high pressure Panellit trip.
12/20	12/20	0.4	Adjusted shielding in two vertical rod channels.
12/21	12/22	31.0	Removal of an I&E regular metal rupture from tube 5055.

KW REACTOR

12/4	12/5	41.1	Removal of an I&E E metal rupture from tube 5359. Charge-discharge.
12/21	12/23	60.6	Removal of an I&E E metal rupture from tube 5261.

---

Extracted from Plum 1961, December, pages 3-5.

APPENDIX B

OPERATING DATA FOR 1961

UAVAKIUM IN TOS  
/961

	SEPARATIONS					
	REACTORS			DISTILLATION		
	Charged Jan. 26th	Inventory Jan. 26th	In Reactor Jan. 26th	Discharged Jan. 26th	Inventory Jan. 26th	Distilled Jan. 26th
Normal U	596	636	2,015	2,002	615	1,982
Solid	13	13	271	240	48	44
U3	583	623	1,744	1,762	567	605
						Normal U
						Purex
						445
						404
						24 Metal
24 Metal	88.5	86.4	234.1	261.2	75.9	72.3
Solid	0	0	0.4	0	0.3	0.4
U3	88.5	86.4	253.7	261.2	75.6	78.9

WWD AND SPECIAL MATERIALS 1961

COMPARATIVE FILE PERFORMANCE - JAN 1961

	B	C	D	DR	P	R	IR	IV	TOTAL
Maximum Power Level To Date, MW	1,260	2,135	1,840	1,855	1,950	1,920	6,030	6,000	29,170
Maximum Power Level During Month, MW	1,860	2,135	1,840	1,855	1,850	1,855	6,030	6,000	29,125
Average Power Level While Operating, MW	1,759	2,021	1,750	1,755	1,755	1,755	3,802	3,800	18,451
Maximum Tube Power, KW	1,226	1,221	1,240	1,268	1,257	1,260	1,580	1,560	
Effective Central Tubes	1,515	1,735	1,520	1,590	1,460	1,523	2,545	2,560	
Time Operated Efficiency, %	78.1	87.5	75.3	73.5	80.3	65.5	85.2	86.3	79.5
Operational Limitation	12330W	12205W	12184	1150W	1275W	93.5°C	1500°C	1500°C	
MWD Produced During Month, total	4,256.1	5,527	40,873	39,819	44,274	34,721	100,361	109,112	466,159
Normal Solid	3,822	5,124	2,713	2,052	1,573	1,392	5,899	7,156	29,544
Normal I&E	34,428	38,204	25,219	31,184	36,253	26,545	79,971	86,356	370,975
9L Metal	6,271	11,209	2,936	6,613	4,353	6,974	14,554	15,600	65,550
Plutonium Produced, grams	34,865	43,123	33,638	33,573	36,511	26,024	88,349	94,218	370,520
Uranium In Reactor At Month End, tons	200.0	227.4	243.4	221.7	237.5	215.1	141.2	143.0	2269.1
Normal Solid	10.1	11.1	25.7	21.0	18.7	16.0	51.3	53.8	270.7
Normal I&E	180.9	152.3	206.3	169.7	197.0	162.7	336.3	337.7	171.1
9L Metal	29.3	34.3	31.1	31.0	19.8	38.4	50.6	49.5	231.2
Uranium Discharged During Month, tons	81.3	15.7	79.2	126.5	56.3	21.5	211.1	173.5	690.8
Normal Solid	6.5	7.5	11.7	6.6	3.2	1.1	6.9	11.3	67.5
Normal I&E	72.9	8.2	62.3	115.5	50.9	5.8	126.7	135.6	567.3
9L Metal	5.9		5.1	6.4	2.6	6.3	13.3	26.6	75.9
Average Discharge Concentration									
Normal Solid	728	633	703	728	716	761	719	710	760
Normal I&E	675	880	827	792	655	765	706	711	717
9L Metal									825

B REACTOR - JAN 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
1/8	1/13	120.6	Scheduled charge-discharge, tube replacement, and miscellaneous maintenance.
1/26	1/28	12.2	Probologging and miscellaneous maintenance following the repair of a pigtail leak.
1/29	1/29	0.5	Repaired front pigtail leak on tube 4092.

C REACTOR

1/9	1/9	0.2	Unexplained Panellit trip.
1/17	1/21	81.1	Scheduled charge-discharge and overboring of three process tube channels.

D REACTOR

1/13	1/17	101.7	Removal of an I&E regular metal rupture from tube 1366. Charge-discharge, tube replacement and installation of 200 reamed front face nozzles.
1/21	1/22	38.1	Removal of an I&E regular metal (Bumper) rupture from tube 2676.
1/26	1/28	43.9	Removal of I&E regular metal (Bumper) rupture from tube 2878. Installed 18 $\frac{1}{4}$ overbored front nozzles.

DR REACTOR

1/5	1/8	69.5	Scheduled charge-discharge.
1/8	1/8	0.7	Panellit trip
1/10	1/12	38.9	Low pressure water trip due to improper valving at 190 Building. Leak testing and miscellaneous maintenance.
1/12	1/12	1.2	Tripped due to a faulty vertical rod relay.
1/16	1/18	39.0	Leak testing. Replaced leaking tube 3973 and installed 63 reamed nozzles.
1/28	1/30	46.9	Removal of and I&E E-metal rupture from tube 2657.

FR REACTOR

1/2	1/4	35.1	Low pressure Panellit trip on gauge 0955. Removal of an I&E regular metal rupture from tube 0868 and charge-discharge.
1/13	1/15	56.6	Leak testing.
1/29	Still down		Scheduled charge-discharge and tube re- placement.

II REACTOR

1/9	1/15	117.4	Removal of an I&E regular metal rupture from tube 3781. One to two tubes of irradiated metal (I&E-E) were discharged onto the rear face elevator when the elevator moved from the "up" to "down" position during the discharge operation. A total of 59 I&E E-metal pieces were removed from discharge elevator. Installed 195 reamed front face nozzles.
1/16	1/18	36.0	Corrected Parker fitting leak on tube 1377.
1/18	1/18	0.5	Installed bayonet in air channel 1463.
1/18	1/19	1.2	Repair broken lug ring on front nozzle 1386.
1/19	1/20	25.0	A period of insufficient reactivity.
1/23	1/25	34.5	Removal of an I&E regular metal rupture from tube 0982. Charge-discharge and miscellaneous maintenance.
1/31	Still down		Removal of an I&E regular metal rupture from tube 3379. Charge-discharge and miscellaneous maintenance.

III REACTOR

1/13	1/17	76.5	Removal of an I&E regular metal rupture from tube 3167. Charge-discharge and maintenance.
1/19	1/21	33.9	Charge-discharge and maintenance following a loop trip. Four partial NCR's were installed and No. 4 low-lift motor was replaced with a rewound upgraded motor.

IV REACTOR

1/23	1/26	72.5	Removal of an I&E E metal rupture from tube 3090 and scheduled charge-discharge. A suspected I&E regular metal rupture discharged from tube 5384 on 1/23 was confirmed.
------	------	------	---

COMPARATIVE PILE PERFORMANCE - FEB 1961

	B	C	D	DR	F	H	EB	KW	TOTAL
Maximum Power Level To Date, KW	1,670 <sup>1</sup>	2,180 <sup>1</sup>	1,925 <sup>1</sup>	1,925 <sup>1</sup>	1,925	1,925	1,925	1,925	19,750
Maximum Power Level During Month, KW	1,670	2,180	1,915	1,925	1,815	1,900	1,930	1,930	19,745
Average Power Level While Operating, KW	1,783	2,072	1,964	1,871	1,755	1,699	2,505	3,930	18,439
Maximum Tube Power, KW	1,235	1,258	1,255	1,220	1,253	1,184	1,300	1,500	2,560
Effective Central Tubes	1,529	1,733	1,523	1,551	1,452	1,605	1,450	2,550	2,550
Time Operated Efficiency, %	85.3	81.0	81.9	94.3	72.1	63.4	84.6	92.8	82.3
Operational Limitation	1,230	1,236	1,265	1,240	1,275	1,256	1,580	1,580	1,580
WD Produced During Month, total	42,580	47,017	43,761	49,426 <sup>1</sup>	35,410	29,455	83,027	103,248	433,924
Normal Solid	3,309	3,301	2,942	2,258	1,023	681	4,637	6,154	24,005
Normal T&E	31,975	33,716	38,196	38,912	30,757	22,510	68,174	81,731	346,265
9t Metal	4,296	9,500	3,323	8,256	3,630	7,073	12,216	15,360	63,654
Plutonium Produced, grams	34,606	38,162	36,434	40,015	29,328	24,883	72,310	92,205	367,913
Uranium In Reactor At Month End, tons	226.0	225.9	212.7	221.8	229.4	216.9	140.9	140.6	226.1
Normal Solid	23.4	36.5	19.7	21.0	24.3	14.4	16.0	51.1	229.5
Normal T&E	182.5	151.1	211.7	169.7	206.2	255.4	244.1	320.1	1762.4
9t Metal	20.1	35.3	11.3	31.1	19.9	47.7	17.7	46.8	261.2
Uranium Discharged During Month, tons	70.0	161.9	62.7	62.7	76.2	142.4	217.5	87.0	727.9
Normal Solid	6.9	26.2	6.0	0	4.3	1.7	5.1	6.0	53.9
Normal T&E	57.0	128.1	32.8	0.2	65.0	136.1	116.9	68.7	634.7
9t Metal	6.2	19.8	3.9	0.1	6.9	16.6	25.5	12.3	79.3
Average Discharge Concentration	722	708	733	710	651	757	585	710	711
Normal Solid	715	762	755	729	709	768	767	767	764
Normal T&E	719	702	729	712	655	756	761	767	767
9t Metal	1,035	725	720	710	655	735	674	674	674

<sup>1</sup> Low record.

Extracted from Travis 1961c, page 6

REACTOR OUTAGES - FEB 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
2/21.	2/25	98.9	Removal of an I&E regular metal rupture from tube 1686. Charge-discharge and miscellaneous maintenance.
<u>C REACTOR</u>			
2/2	2/4	49.1	Removal of an I&E regular metal rupture from tube 3275. Charge-discharge and miscellaneous maintenance.
2/25	2/28	78.5	Removal of an I&E regular metal rupture from tube 2361. Charge-discharge and miscellaneous maintenance.
<u>D REACTOR</u>			
2/12	2/17	108.4	Removal of an I&E E-metal rupture from tube 4072. Charge-discharge and miscellaneous maintenance.
<u>DR REACTOR</u>			
2/2	2/4	38.1	Tripped by the gas loop when cooling water pressure to the heat exchanger was lost. Miscellaneous maintenance performed.
<u>F REACTOR</u>			
1/29	2/1	75.9	Scheduled charge-discharge and tube replacement.
2/15	2/18	87.0	Leak testing, charge-discharge and tube replacement.
2/19	2/22	62.2	Leak testing.
2/28	Still down		Water leak. Charge-discharge and miscellaneous maintenance.

Extracted from Plum 1962, February 1961, pages 3 and 4.

II REACTOR

1/31	2/1	37.9	Charge-discharge and leak testing following rupture removal.
2/5	2/10	117.5	Water leak, charge-discharge and maintenance. Installed 171 overbored nozzles.
2/11	2/11	0.3	Repositioned front cap on tube 1155 that was not fully engaged on lug rings.
2/12	2/14	41.9	Removal of an I&E E-metal rupture from tube 1173. Tube replacement and miscellaneous maintenance.
2/20	2/22	66.2	Leak testing.

KE REACTOR

2/1	2/3	47.8	Repair of No. 1 high-lift pump (wearing ring became displaced, causing some internal damage to the pump) and charge-discharge.
2/23	2/25	53.0	Scheduled charge-discharge. A 1500 h.p. motor was installed for #5 low-lift pump.
2/25	2/25	2.2	Low pressure Panellit trip on tube 4665.
2/25	2/25	0.3	Panellit trip.

KW REACTOR

2/11	2/13	41.5	Removal of an I&E E-metal rupture from tube 1686. Charge-discharge and maintenance.
------	------	------	---

U R A N I U M   I N   T O N S  
1961

REACTORS						SEPARATIONS					
Charged Mar.	Charged Apr.	Inventory Mar.	Inventory Apr.	In Reactor Mar.	In Reactor Apr.	Discharged Mar.	Discharged Apr.	In Cooling Mar.	In Cooling Apr.	Dissolved Mar.	Dissolved Apr.
<u>Normal U</u>	<u>422</u>	<u>603</u>	<u>1,976</u>	<u>1,926</u>	<u>448</u>	<u>652</u>	<u>2,051</u>	<u>2,375</u>	<u>Normal U</u>		
<u>94 Metal</u>	<u>108.8</u>	<u>106.4</u>	<u>271.8</u>	<u>271.0</u>	<u>98.3</u>	<u>81.0</u>	<u>622.9</u>	<u>595.4</u>	<u>Purex</u>	<u>65</u>	<u>324</u>

M W D   A N D   S P E C I A L   M A T E R I A L S  
1961

REACTORS						SEPARATIONS					
Charged or Produced Mar.	Charged or Produced Apr.	Inventory In Reactor Mar.	Inventory In Reactor Apr.	Discharged Mar.	Discharged Apr.	Inventory In Cooling Mar.	Inventory In Cooling Apr.	Dissolved Mar.	Dissolved Apr.		
<u>MWD</u>	<u>324,947</u>	<u>52,855</u>									
<u>Normal</u>	<u>368,743</u>	<u>380,594</u>	<u>739,004</u>	<u>665,867</u>	<u>314,333</u>	<u>454,131</u>	<u>1,460,426</u>	<u>1,600,780</u>	<u>69,321</u>	<u>230,860</u>	
<u>94 Metal</u>	<u>66,204</u>	<u>71,841</u>	<u>103,021</u>	<u>113,064</u>	<u>76,181</u>	<u>61,793</u>	<u>455,830</u>	<u>457,712</u>	<u>77,303</u>	<u>89,646</u>	

Extracted from Travis 1961e, pages 4 and 6.

COMPARATIVE FILE PERFORMANCE - MAR 1961

B	C	D	DR	F	H	S	KW	TOTAL
Maximum Power Level To Date, MW	1,895	2,120	1,915	1,925	1,935	1,955	6,115	20,035
Maximum Power Level During Month, MW	1,395	2,160	1,935	1,925	1,935	1,955	6,115	20,035
Average Power Level While Operating, MW	1,733	1,271	1,071	1,764	1,300	1,036	3,018	18,603
Maximum Tube Power, KW	1,253	1,240	1,265	1,230	1,299	1,138	1,560	1,550
Effective Central Tubes	1,510	1,710	1,510	1,490	1,465	1,615	2,515	2,585
Time Operated Efficiency, %	72.8	76.0	83.0	77.7	68.5	82.3	72.6	75.9
Operational Limitation	1,265	1,236	1,265	1,240	1,300	1,200	1,580	1,580
WUD Produced During Month, total	35,176	46,511	46,280	42,679	35,154	46,917	87,621	434,267
Normal Solid	2,405	3,304	3,471	3,169	3,824	3,186	4,771	19,237
Normal IRE	22,586	33,359	42,878	34,626	33,537	33,581	69,785	319,446
9t Metal	4,185	9,888	3,731	6,884	3,503	12,050	12,388	66,204
Plutonium Produced, grams	32,329	39,304	39,297	33,316	31,755	36,673	76,962	369,033
Uranium In Reactor At Month End, tons	233.2	226.9	211.5	221.0	231.1	209.8	139.4	2217.8
Normal Solid	39.4	29.6	21.7	9.8	11.3	8.5	12.9	185.0
Normal IRE	187.3	162.1	218.1	180.6	205.9	112.0	350.6	1791.3
9t Metal	20.3	35.2	11.7	30.6	23.9	59.3	47.7	271.8
Uranium Discharged During Month, tons	133.0	22.2	77.0	53.5	73.9	32.7	104.1	546.8
Normal Solid	4.0	7.2	8.0	11.3	6.5	5.8	7.6	60.5
Normal IRE	35.2	6.2	65.5	23.1	64.5	13.4	76.1	388.2
9t Metal	3.8	8.9	3.5	19.2	6.4	13.5	20.4	98.3
Average Discharge Concentration								
Normal Solid	763	711	730	784	739	730	757	763
Normal IRE	670	761	705	657	662	716	662	713
9t Metal	905	707	815	938	672	453	611	714

Extracted from Travis 1961d, page 7.

REACTOR OUTAGES - MAR 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
3/1	3/3	41.2	Leak testing and tube replacement.
3/13	3/15	38.6	Administrative.
3/20	3/24	79.3	Removal of an I&E regular metal rupture from tube 3764. Tube replacement and charge-discharge.
3/28	3/30	43.4	Removal of an I&E regular metal rupture from tube 3362.
<u>C Reactor</u>			
3/6	3/10	103.5	Scheduled overboring of 13 channels.
3/13	3/15	37.9	Administrative.
3/16	3/16	1.7	Panellit trip due to a faulty rear connector elbow on tube 1955.
3/17	3/17	0.2	Unexplained trip on No. 1 Beckman while setting trip on No. 4 Beckman.
3/23	3/23	0.5	Manual trip to repair a rear pigtail leak on tube 1935.
3/23	3/25	35.8	Manual trip due to flux imbalance caused by insufficient reactivity. Charge-discharge.
<u>D Reactor</u>			
3/12	3/16	84.9	Scheduled charge-discharge.
3/16	3/16	1.7	Front cap leak on tube 2969.
3/28	3/30	40.0	Electrical trip caused by a construction crane coming in contact with the 13.8 KV line.

Extracted from Plum 1962, March 1961, pages 3-6.

DR Reactor

3/5	3/8	69.3	Removal of an I&E E-metal rupture from tube 1467. Charge-discharge and leak testing.
3/13	3/15	38.9	Administrative.
3/28	3/30	38.3	Tripped when a construction crane at N Area came in contact with the 13.8 KV line.
3/31	Still down		Water leak.

F Reactor

2/28	3/4	103.8	Leak testing, tube replacement & charge-discharge.
3/11	3/13	37.3	Charge-discharge and maintenance following a Panellit trip.
3/13	3/14	26.5	Administrative.
3/18	3/20	36.5	Charge-discharge following a Panellit trip.
3/28	3/30	47.1	Charge-discharge and leak testing.

H Reactor

3/8	3/11	58.5	Removal of I&E E-metal ruptures from tubes 2892 and 0571 and charge-discharge.
3/13	3/15	32.3	Administrative.
3/15	3/15	0.2	Low pressure Panellit trip on gauge 1484
3/15	3/15	1.3	Rear pigtail adapter leak on tube 1484.
3/17	3/17	0.2	Unexplained Panellit trip on row 23.
3/28	3/30	40.4	Removal of an I&E E-metal rupture from tubes 2991 and 0572, and charge-discharge.

KE Reactor

3/8	3/11	72.3	Removal of an I&E regular metal rupture from tube 2776 and charge-discharge.
3/11	3/11	0.5	Panellit trip on tube 4666 due to a plugged crossheader screen. Pieces of O ring were found on the screen.
3/13	3/15	34.3	Administrative.
3/19	3/21	34.9	Removal of an I&E regular metal rupture from tube 5684 and charge-discharge.
3/21	3/21	0.5	Unexplained Panellit trip on row 56.
3/22	3/23	40.0	Tripped due to a leak on the heat exchanger outlet of loop. Replaced the shaft in No. 1 low-lift pump.
3/25	3/26	32.0	Panellit trip due to a faulty gauge on tube 5657.
3/26	3/26	1.5	Unexplained Panellit trip on Row 56.

KW Reactor

3/5	3/7	69.3	Removal of an I&E regular metal rupture from tube 4177 and charge-discharge.
3/8	3/8	0.5	Tightened loose orifice on tube 5655.
3/8	3/9	32.8	Insufficient reactivity. Concluded tightening of loose orifice assembly and miscellaneous maintenance.
3/10	3/11	33.9	Removal of an I&E E-metal rupture from tube 2178 and charge-discharge.
3/13	3/15	33.5	Administrative.
3/27	3/29	34.7	Removal of an I&E E-metal rupture from tube 3183. Charge-discharge.
3/29	3/29	1.0	Unexplained Panellit trip.

---

Extracted from Plum 1962, March 1961, pages 3-6.

COMPARATIVE FILE PERFORMANCE - APR 1961

	B	C	D	IR	P	H	KE	EW	TOTAL
Maximum Power Level To Date, MW	1,835	2,250	1,915	1,925	1,935	1,955	1,955	1,915	20,035
Maximum Power Level During Month, MW	1,870	2,120	1,915	1,920	1,925	1,925	1,925	1,900	19,453
Average Power Level While Operating, MW	1,787	2,005	1,797	1,628	1,850	1,752	2,073	3,967	18,492
Maximum Tube Power, KW	1,267	1,211	1,260	1,264	1,258	1,193	1,550	2,574	
Effective Central Tubes	1,478	1,700	1,510	1,507	1,490	1,525	2,500	2,594	
Time Operated Efficiency, %	84.3	82.8	78.7	65.4	67.6	83.5	80.7	65.6	81.0
Operational Limitation	1,259	1,250	93.5	1,240	1,200	1,195	1,560	1,560	
MWD Produced During Month, total									
Normal Solid	15,180	19,256	12,477	22,027	18,889	13,897	91,880	99,300	452,835
Normal KE	2,382	3,015	630	547	635	93	2,729	4,772	24,708
9L Metal	37,929	36,700	38,211	26,352	13,087	29,883	71,350	80,344	366,296
Plutonium Produced, grams	4,869	10,141	3,436	5,128	4,967	13,915	14,691	14,693	71,811
Uranium In Reactor At Month End, tons									
Normal Solid	229.6	227.4	240.3	220.7	233.0	198.9	43.4	43.4	2223.7
Normal KE	26.4	22.0	6.5	9.0	8.4	8.9	31.7	31.7	112.9
9L Metal	182.7	173.5	222.3	179.5	205.9	126.0	372.4	353.6	1813.5
Uranium Discharged During Month, tons									
Normal Solid	20.5	33.6	21.5	31.9	20.5	72.9	54.2	52.3	237.3
Normal KE	68.2	31.7	62.9	215.3	54.7	121.2	168.5	189.0	733.5
9L Metal	57.5	74.6	52.2	212.3	46.5	8.5	22.7	21.2	74.9
Average Discharge Concentration									
Normal Solid	770	735	766	719	788	478	638	717	667
Normal KE	682	783	702	75	654	470	673	690	700
9L Metal	866	774	823	630	823	631	736	736	763

Extracted from Travis 1961e, page 7.

REACTOR OUTAGES - APR 1961

B Reactor

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
4/6	4/8	37.5	Removal of an I&E regular metal rupture from tube 3272 and charge-discharge.
4/22	4/25	75.4	Removal of an I&E regular metal rupture from tube 1065 and charge-discharge.

C Reactor

4/9	4/11	40.8	Scheduled charge-discharge and overboring of channels.
4/17	4/19	36.6	Replacement of 24 cross-threaded front pigtails.
4/19	4/19	1.0	Panellit trip.
4/21	4/23	34.2	Removal of an I&E regular metal rupture from tube 2269.
4/23	4/23	1.3	Leaking rear pigtail on tube 2261.
4/30	Still down		Removal of an I&E regular metal rupture from tube 2270.

D Reactor

4/6	4/6	0.2	Panellit trip; #1 pump at 190 turned out a coil.
4/7	4/9	48.2	Removal of an I&E regular metal rupture from tube 0893 and charge-discharge.
4/9	4/9	0.5	Stuck ball valve on a poison tube.
4/12	4/14	46.4	Leak testing. Replaced tubes 3477 and 3261 due to internal leaks and seven additional process tubes. Miscellaneous maintenance.
4/20	4/30	57.8	Removal of an I&E regular metal rupture from tube 0160, changed 103 front nozzles, and charge-discharge.

Extracted from Plum 1962, April 1961 pages 3-5.

D Reactor

3/31	4/2	42.6	Leak testing.
4/4	4/6	52.2	Leak testing and tube replacement.
4/14	4/15	38.9	Panellit trip due to a leaking Bourdon tube, small charge-discharge and maintenance.
4/24	4/29	103.2	Water leak in tube 2682. Block charge-discharge
4/30	4/30	1.6	Manually tripped for thermocouple repair.

F Reactor

4/17	4/19	51.5	Water leak and charge-discharge. Number 4 pump motor burned out.
4/19	4/20	30	Leak testing. Tube 2875 was replaced.
4/30	Still down		Repair rear pigtails. Charge-discharge.

H Reactor

4/4	4/6	49.4	Removal of an I&E regular metal rupture from tube 2486 and charge-discharge.
4/6	4/7	18.1	Leak testing. Tube 2390 removed due to a leak, and channel blanked.
4/24	4/25	44.1	Removal of an I&E regular metal rupture from tube 1989. Charge-discharge and installation of 165 rear pigtails and 178 broached front nozzles.
4/26	4/26	6.7	Removal of an I&E regular metal rupture from tube 2857.

KE Reactor

4/8	4/10	46.8	Charge-discharge following removal of a NIN-1 rupture from KER loop 4.
4/10	4/11	22.4	Removal of an I&E E-metal rupture from tube 2461.
4/11	4/11	0.3	Panellit trip.
4/19	4/20	34.1	Removal of a solid regular metal rupture from tube 5653 and charge-discharge.
4/26	4/27	35.3	Charge-discharge and loop work following a Panellit trip.

KW Reactor

4/16	4/19	69.8	Scheduled charge-discharge and maintenance.
4/25	4/27	34.6	Removal of an I&E regular metal rupture from tube 5045.

URANIUM IN TONS  
1961

	REACTORS				SEPARATIONS			
	Charged		Inventory	In Reactor	Discharged		Inventory	In Cooling
	May	June	May	June	May	June	May	June
<u>Normal U</u>	558	326	1,794	1,783	690	336	2,322	2,143
							<u>Normal U</u>	
<u>94 Metal</u>	204.7	72.6	410.8	412.3	91.1	71.1	599.9	593.0
							<u>94 Metal</u>	
<u>94 Metal</u>	77.950	96.438	123.693	165.321	67.335	53.316	457.680	389.890
							<u>94 Metal</u>	

B.18

MWD AND SPECIAL MATERIALS  
1961

MWD	REACTORS				SEPARATIONS			
	Charged or Produced		Inventory In Reactor	Discharged	Inventory In Cooling	May	June	May
	May	June	May	June	May	June	May	June
<u>53.041</u>	<u>434,651</u>							
<u>Normal</u>	375,081	338,213	585,763	595,110	455,160	227,891	1,600,434	1,466,090
<u>94 Metal</u>	77.950	96.438	123,693	165,321	67,335	53,316	457,680	389,890

Extracted from Travis 1961q, pages 4 and 6.

COMPARATIVE PILE PERFORMANCE - MAY 1961

Maximum Power Level To Date, MW		Maximum Power Level During Month, MW		Average Power Level While Operating, MW		Maximum Tube Power, kW		Effective Central Tubes		Time Operated Efficiency, %		Operational Limitation	
1,985	2,116	C	1,955	D	1,925	E	1,925	F	1,925	G	1,925	H	I
1,360	2,130	1,885	1,895	1,895	1,875	1,875	1,875	1,875	1,875	1,875	1,875	1,875	1,875
1,735	1,971	1,871	1,863	1,863	1,759	1,759	1,759	1,759	1,759	1,759	1,759	1,759	1,759
1,208	1,250	1,247	1,240	1,240	1,220	1,220	1,220	1,220	1,220	1,220	1,220	1,220	1,220
1,522	1,685	1,685	1,590	1,590	1,475	1,475	1,475	1,475	1,475	1,475	1,475	1,475	1,475
72.3	80.0	83.6	79.8	79.8	70.4	70.4	70.4	70.4	70.4	70.4	70.4	70.4	70.4
92.50	1,250	93.50	1,250	1,250	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
39,236	36,708	47,517	36,533	36,533	38,371	37,847	37,847	37,847	37,847	37,775	37,775	37,775	37,775
33,295	2,059	13,455	36,661	36,661	33,892	12,775	12,775	12,775	12,775	65,251	65,251	65,251	65,251
1,773	10,068	3,085	92.4	92.4	625	0	0	0	0	653	3,464	3,464	3,464
4,238			7,588	7,588	4,064	25,072	25,072	25,072	25,072	16,871	16,523	16,523	16,523
32,766	40,290	38,469	38,355	38,355	32,092	27,104	27,104	27,104	27,104	89,925	89,925	89,925	89,925
228.7	226.4	228.0	220.5	220.5	228.2	221.1	221.1	221.1	221.1	1,35.0	1,37.1	1,37.1	1,37.1
21.0	18.4	5.3	6.6	6.6	5.7	0	0	0	0	6.2	26.8	26.8	26.8
180.3	173.2	21.3	38.5	38.5	22.1	22.1	22.1	22.1	22.1	37.6	360.0	360.0	360.0
20.1	26.3	26.3	30.3	30.3	21.2	21.2	21.2	21.2	21.2	52.2	52.2	52.2	52.2
61.5	85.0	33.9	30.9	30.9	26.4	26.0	26.0	26.0	26.0	199.8	142.2	142.2	142.2
3.0	3.6	1.2	1.2	1.2	3.7	0	0	0	0	2.8	6.9	6.9	6.9
55.2	68.5	30.5	29.5	29.5	27.1	26.0	26.0	26.0	26.0	165.5	215.3	215.3	215.3
3.3	31.5	2.2	9.5	9.5	6.4	5.6	5.6	5.6	5.6	31.5	20.0	20.0	20.0
764	824	765	692	692	770	735	735	735	735	0	554	782	782
			765	765	750	750	750	750	750	675	675	700	700
			765	765	765	765	765	765	765	695	695	695	695

B.19

Extracted from *Travis 1961f*, page 1.

REACTOR OUTAGES - MAY 1961

<u>Date Down</u>	<u>Date UP</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
5/1	5/2	40.3	Removal of an I&E regular metal rupture from tube 2370. Leaking tube 2257 and the rupture tube were replaced.
5/2	5/3	24.9	Removal of an I&E regular metal rupture from tube 1959.
5/16	5/19	58.9	Leak testing and removal of leaking tube 1881 (ribless). Replacement of 12 process tubes..
5/22	5/24	43.8	Leak testing. Replaced 12 ribless aluminum tubes due to thin walls.
5/24	5/26	31.1	Correction of a front pigtail leak on tube 1173. Replacement of 78 rear pigtails and 40 thermocouples.
<u>C REACTOR</u>			
4/30	5/1	40.8	Removal of I&E regular metal rupture from tube 2270. Charge-discharge.
5/4	5/4	0.5	Trip when a VSR dropped due to low voltage on instrument power.
5/14	5/19	22.5	Scheduled charge-discharge and maintenance.
5/19	5/19	4.8	Replacement of two rear face thermocouple wells.
<u>D REACTOR</u>			
5/20	5/25	118.2	Scheduled charge-discharge and maintenance.
5/25	5/25	2.7	Repair rear thermocouple.
5/31	Still down		Correction of a front face cap not fully rotated on the lug ring. Charge-discharge.

Extracted from Plum 1962, May 1961, pages 7-9.

DR REACTOR

5/4	5/6	54.8	Water leak. Replacement of 17 tubes, including three leakers.
5/17	5/19	39.8	Removal of I&E E metal rupture from tube 2657 and charge-discharge.
5/28	5/30	55.5	Leak testing. Removal and replacement of 12 tubes.

F REACTOR

4/30	5/3	62.6	Rear pigtail leaks. Charge-discharge and maintenance.
5/4	5/5	32.8	Panellit trip on gauge 3557. Miscellaneous maintenance.
5/8	5/11	63.5	Panellit trip. Replacement of 33 process tubes.
5/25	5/28	69.0	Trip due to a leaking rear pigtail. Charge-discharge and tube replacement.

H REACTOR

5/3	5/3	0.2	Tripped due to a power surge on the BPA system.
5/3	5/8	115.7	Failure of a rear pigtail on tube 1279. Charge-discharge and maintenance.
5/14	5/14	0.2	Trip due to the failure of a "Y" adapter fitting on tube 2791.
5/14	5/15	32.7	Leak testing.
5/16	5/16	0.2	Unexplained Panellit trip.
5/21	5/28	168.5	Scheduled charge-discharge and maintenance.
5/28	5/29	3.7	High pressure on two tubes.

KE REACTOR

5/10	5/12	40.8	KER Loop 3 trip. Charge-discharge.
5/12	5/13	2.6	Removal of a rupture from KER Loop 1.
5/26	5/29	56.5	Repair of nine front gunbarrel flanges, (tru-arc) rings and charge-discharge.
5/29	5/29	3.5	Suspected rupture in Loop 3 (PT-IP-377-1).

KW REACTOR

5/1	5/2	34.6	Tripped by oscillating Panellit gauge 0873. Charge-discharge.
5/3	5/3	0.3	Unexplained Panellit trip.
5/25	5/27	56.2	Scheduled charge-discharge and maintenance.
5/27	5/27	0.7	Panellit trip due to an oscillating guage.

COMPARATIVE PRICE PERFORMANCE - JUN 1961						
	A	B	C	D	E	F
Maximum Power Level To Date, Mw	1,895	2,180	1,915	1,925	1,935	1,935
Maximum Power Level During Month, Mw	1,660	2,275	1,625	1,850	1,860	1,875
Average Power Level While Generating, Mw	1,760	1,908	1,732	1,769	1,772	1,775
Maximum Tube Power, MW	1,179	1,225	1,000	1,180	1,206	1,207
Effective Central Tubes	1,520	1,695	1,500	1,520	1,540	1,550
Time Operated Efficiency, %	78.3	70.6	68.6	82.8	77.5	81.5
Operational Utilization	93.3	95.0	93.5	95.0	93.5	95.0
W.D. Produced During Month, total	11,321	10,398	25,612	13,923	40,571	38,727
Normal Solid	1,611	1,216	219	333	270	0
Normal T.E.	35,218	30,219	32,656	36,621	35,799	565
St. Metal	6,492	8,923	2,767	6,976	4,132	38,221
Plutonium Produced, grams	33,345	33,222	37,713	30,760	32,868	28,128
Uranium In Reactor at Month End, tons	226.7	225.3	234.4	220.8	227.6	189.7
Normal Solid	18.1	21.2	3.1	4.6	4.6	0
Normal T.E.	186.9	217.2	219.9	186.2	201.1	186.7
St. Metal	21.7	36.3	11.1	30.0	21.4	52.6
Uranium Discharged During Month, tons	75.7	79.4	66.2	26.5	25.2	15.2
Normal Solid	5.9	7.2	2.2	0.1	0.1	0.1
Normal T.E.	61.7	60.1	59.7	22.1	20.4	0.2
St. Metal	6.1	22.1	4.3	4.7	13.0	21.0
Average Market Concentration	733	627	794	777	6117	1,070
Normal Solid	671	727	822	1,063	724	265
Normal T.E.	1,957	832		817	159	
St. Metal						

REACTOR OUTAGES - JUN 1961

<u>Date</u> <u>Down</u>	<u>Date</u> <u>Up</u>	<u>Outage</u> <u>Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
6/17	6/22	116.7	Removal of an I&E regular metal rupture from tube 0967, charge-discharge and tube replacement.
6/22	6/22	2.4	Rear face cap leak.
6/26	6/28	37.2	High pressure Panellit trip on tube 2683. Miscellaneous maintenance and a small charge-discharge.
<u>C Reactor</u>			
6/5	6/8	61.1	Removal of an I&E regular metal rupture from tube 3766. Miscellaneous maintenance and charge-discharge.
6/8	6/8	2.1	Panellit trip due to the pigtail coming loose from rear nozzle 1557.
6/8	6/8	0.4	Manual trip for temperature control.
6/9	6/11	31.3	Removal of a solid regular metal rupture from tube 2352.
6/16	6/17	36.7	Leak testing. Leaking tube 4170 replaced.
6/20	6/22	37.7	Leak testing.
6/26	6/28	42.7	Leak testing. Tube 2566 replaced.
<u>D Reactor</u>			
5/31	6/3	68.9	Correction of a front face cap not fully rotated on the lug ring. Charge-discharge and tube replacement.
6/3	6/4	3.6	High pressure Panellit trip on tube 3882.
6/11	6/13	44.8	Leak testing, charge-discharge and tube replacement.
6/25	6/30	107.7	Scheduled charge-discharge and tube replacement.

Extracted from Plum 1962, June 1961, pages 2-5.

DR Reactor

6/6	6/8	62.4	Leak testing and tube replacement.
6/9	6/10	26.4	Removal of an I&E regular metal rupture from tube 2986.
6/12	6/14	35.3	Repair of broken lug ring on front nozzle 1563. Charge-discharge.

F Reactor

6/12	6/16	82.9	Removal of a stuck I&E metal rupture from tube 3457. Charge-discharge and miscellaneous maintenance.
6/19	6/21	38.0	Tripped due to a faulty circuit breaker at Midway. Leak testing and charge-discharge.
6/24	6/25	41.6	Removal of an I&E regular metal rupture from tube 2264.
6/28	6/28	0.2	Panellit trip due to a ruptured rear pigtail on tube 4370.

H Reactor

6/6	6/6	0.2	Panellit trip due to a rear pigtail failure on tube 3691.
6/6	6/6	0.1	Unexplained trip on Nos. 2, 3 and 4 Bechmanns.
6/7	6/8	32.4	Leak testing.
6/18	6/20	47.5	Removal of stuck I&E metal rupture from tube 2967. Leak testing.
6/21	6/21	0.1	Tripped when flow to PCCF tube 2072 was reduced prior to bypassing the Panellit gauge.
6/21	6/22	22.9	Tripped due to a rear connector leak on tube 0678. Leak testing.
6/27	6/29	53.4	Leak testing.
6/29	6/30	1.8	Correction of two leaking front face caps.

KE Reactor

6/7 6/9 35.7 Trip by KER loop 1. Charge-discharge.

6/20 6/23 61.1 Faulty tru-arc ring. Charge-discharge and miscellaneous maintenance.

KW Reactor

6/9 6/11 35.0 Unexplained Panellit trip. Charge-discharge.

6/27 Still down Scheduled charge-discharge and maintenance.

URANIUM IN TONS  
1961

<u>SEPARATIONS</u>					
<u>REACTORS</u>			<u>IN COOLERS</u>		
	<u>Charged</u>	<u>Inventory</u>	<u>Discharged</u>	<u>Inventory</u>	<u>Dissolved</u>
	<u>July Aug.</u>	<u>July Aug.</u>	<u>July Aug.</u>	<u>July Aug.</u>	<u>July Aug.</u>
<u>Normal U</u>	470	345	1,742	1,744	505
				350	2,136 1,821
					<u>Normal U</u>
					<u>Purex</u>
					509 589
					<u>24 Metal</u>
					24 Metal
<u>24 Metal</u>	93.6	104.7	434.9	434.3	70.9
				105.1	429.7
					409.5
					<u>Redox</u>
					143.9 126.0

MWD AND SPECIAL MATERIALS  
1961

<u>REACTORS</u>					
<u>Charged or Produced</u>			<u>Inventory In Reactor</u>		
	<u>July</u>	<u>August</u>	<u>July</u>	<u>August</u>	<u>Discharged</u>
	<u>July Aug.</u>	<u>July Aug.</u>	<u>July</u>	<u>August</u>	
<u>MWD</u>	227.202	296.618			
<u>Normal</u>	320,325	302,409	679,572	733,594	337,363 248,387
<u>94 Metal</u>	106,379	94,239	217,038	225,492	55,662 85,765 332,387 317,267
					<u>Inventory In Cooling</u>
					July August
					<u>Inventory In Cooling</u>
					July August
					<u>Dissolved</u>
					July August

Extracted from Travis 1961i, pages 4 and 6.

COMPARATIVE PILE PERFORMANCE - JULY 1961						TOTAL
B	C	D	DR	P	H	KW
Maximum Power Level To Date, MW	1,895	2,180	1,905	1,935	1,955	4,085
Maximum Power Level During Month, MW	1,755	2,080	1,755	1,910	1,725	3,930
Average Power Level While Operating, MW	1,769	1,990	1,656	1,129	1,657	3,647
Maximum Tube Power, KW	1,111	1,163	1,115	1,160	1,244	1,085
Effective Central Tubes	1,520	1,695	1,500	1,530	1,479	1,397
Time Operated Efficiency, %	79.9	94.9	71.9	42.2	51.6	2,590
Operational Limitation	93.5	95.0	93.5	All	93.5	25.0
MWD Produced During Month, total	42,293	58,506 <sup>1</sup>	36,895	14,766	26,495	47,758
Normal Solid	1,293	1,429	158	111	116	0
Normal I&E	36,048	44,002	33,752	12,223	23,362	742
94 Metal	4,952	13,075	2,985	2,432	2,987	47,016
Plutonium Produced, grams	34,160	46,175	29,691	11,705	21,521	33,049
Uranium In Reactor At Month End, tons	225.8	225.3	230.3	218.9	223.5	189.6
Normal Solid	144.1	11.2	2.8	4.6	3.0	0
Normal I&E	189.7	177.2	214.6	177.0	191.0	31.1
94 Metal	22.0	36.9	12.9	37.3	29.5	186.5
Uranium Discharged During Month, tons	64.7	64.0	39.8	37.0	87.4	5.1
Normal Solid	55.1	3.3	37.7	29.8	80.9	1.6
Normal I&E	5.7	0.7	1.8	7.2	4.9	5.1
Average Discharge Concentration	810	545	660	625	630	685
Normal Solid	682	527	757	630	569	711
Normal I&E	929	527	807	807	963	757
94 Metal						

<sup>1</sup> New record.  
Extracted from Travis 1961h, page 7.

REACTOR OUTAGES - JUL 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
7/24	7/30	150.2	Scheduled charge-discharge and tube replacement.
<u>C REACTOR</u>			
7/6	7/7	38.6	Leak testing.
<u>D REACTOR</u>			
7/4	7/6	40.3	Leak testing. Replacement of four leaking tubes.
7/11	7/13	47.1	Power failure trip. Tube replacement.
7/20	7/24	86.3	Water leak. Charge-discharge and miscellaneous maintenance.
7/24	7/26	40.1	Improperly positioned front face cap. Replacement of 20 tubes.
<u>DR REACTOR</u>			
7/1	7/2	47.2	Leak testing. Replaced five process tubes.
7/5	7/8	55.5	Leak testing. Replaced twenty seven process tubes.
7/11	7/21	237.8	Power failure when a relay at 151 substation was shorted out during testing. A 50 psi drop in water pressure following trip resulted in the 3X system balls dropping into the VSR channels. The 100 psi drop was caused by an improper pressure trip setting resulting from the wrong identification of mercoids. Ball recovery.
7/21	7/22	27.7	Lack of reactivity. Charged enrichment and completed leak testing.
7/27	7/30	61.5	Enrichment adjustment, removal of balls from channels with electromagnet and tube replacement.
7/30	7/30	0.4	Panellit trip.

Extracted from Plum 1962, July 1961, pages 3-5.

F REACTOR

7/1	7/3	52.9	Removal of an I&E regular metal runture from tube 2485 and charge-discharge.
7/10	7/14	95.9	Scheduled charge-discharge, tube replacement and maintenance.
7/17	7/20	73.2	Leak testing.
7/20	7/20	1.8	Repair leak on spline cap 1168.
7/21	7/23	52.5	Leak testing.
7/27	7/30	62.0	Low pressure Panellit trip on tube 3063 due to a leak - tube removed. Charge-discharge and probologging of 97 process tubes.
7/30	7/31	10.0	Charge enrichment in wet zone.
7/31	Still down		Charge additional enrichment.

II REACTOR

7/7	7/9	45.4	Leak testing.
7/10	7/10	1.3	Repair leaks on two front crossheader caps.
7/18	7/18	0.3	Tripped due to a rear pigtal failure on 0778.

III REACTOR

7/17	7/20	83.2	Scheduled charge-discharge and maintenance.
7/31	Still down		Panellit trip. Charge-discharge is in progress.

IV REACTOR

6/27	7/1	87.4	Scheduled charge-discharge and maintenance.
7/1	7/1	1.1	Replace orifices and pigtails on three tubes due to high pressure.
7/11	7/12	35.3	Panellit trip. Charge-discharge.
7/11	7/15	33.5	Unexplained Panellit trip.

Extracted from Plum 1962, July 1961, pages 3-5.

COMPARATIVE PILE PERFORMANCE - AUG 1961						
B	C	D	DR	F	H	KW
Maximum Power Level To Date, MW	1,895	2,180	1,945	1,925	1,955	4,115
Maximum Power Level During Month, MW	1,675	2,000	1,680	1,615	1,630	3,675
Maximum Power Level While Operating, MW	1,596	1,863	1,607	1,369	1,401	3,506
Average Power Level, MW	1,098	1,168	1,120	1,113	1,178	1,066
Maximum Tube Power, KW	1,540	1,680	1,480	1,400	1,450	1,433
Effective Central Tubes	75.8	60.8	70.8	81.4 <sub>2</sub>	89.4 <sub>1</sub>	79.3
Time Operated Efficiency, %	93.5 <sub>1</sub>	95.0 <sub>1</sub>	93.5 <sub>1</sub>	93.5 <sub>1</sub>	93.5 <sub>1</sub>	77.0
Operational Limitation					95.0 <sub>1</sub>	
MMT Produced During Month, total	37,492	35,105	35,276	34,548	35,482	93,751
Normal Solid	862	319	67	61	0	188
Normal I&E	3,210	26,597	32,250	26,656	31,402	613
9 <sub>4</sub> Metal	4,530	8,189	2,959	7,831	7,256	34,869
Plutonium Produced, grams	30,940	29,017	28,340	26,676	31,569	23,921
Uranium In Reactor At Month End, tons	224.2	223.8	229.0	217.8	223.3	190.5
Normal Solid	12.2	4.7			2.7	4.5
Normal I&E	189.6	180.4	217.1	174.7	193.6	3.5
9 <sub>4</sub> Metal	22.4	38.7	11.9	43.1	27.0	187.0
Uranium Discharged During Month, tons	27.9	115.0	33.9	22.5	28.4	24.4
Normal Solid	1.9	6.5	2.8	4.6	0.3	53.7
Normal I&E	23.7	83.5	28.1	14.5	21.0	0.1
9 <sub>4</sub> Metal	2.3	25.0	3.0	3.4	7.1	10.5
Average Discharge Concentration	755	768	776	789	757	0
Normal Solid	670	717	798	591	662	270
Normal I&E	836	827	750	1,157	979	399
9 <sub>4</sub> Metal					687	785

1 Bulk outlet temperature.  
 2 Administrative limit for lack of reactivity.

Extracted from Travis 1961i, page 7.

REACTOR OUTAGES - AUG 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
8/14	8/15	0.3	Tripped by a power surge on the BPA system due to lightning.
8/15	8/16	42.2	Tripped when a VSR dropped to the lower position. Charge-discharge and miscellaneous maintenance.
8/17	8/19	34.0	Leak testing and miscellaneous maintenance.
8/21	8/23	57.1	Leak testing and miscellaneous maintenance. Three leaking tubes replaced. Seven pumps in use due to the motor on No. 3 burning out.
8/28	8/30	37.9	Leak testing and miscellaneous maintenance.
<u>C Reactor</u>			
8/1	8/4	88.4	Scheduled charge-discharge and maintenance.
8/14	8/15	0.2	Tripped by a power surge on the BPA system due to lightning.
8/19	8/25	159.8	Scheduled overboring.
8/30	8/31	43.4	Abnormally high pressure on overbored tube 3165.
<u>D Reactor</u>			
8/6	8/10	99.1	Water leak. Charge-discharge and tube replacement.
8/18	8/20	51.8	Water leak. Charge-discharge.
8/24	8/24	0.4	Unexplained Panellit trip.
8/29	Still down		Removal of an I&E regular metal (bumper) rupture from tube 1163. Charge-discharge and tube replacement.

Extracted from Plum 1962, August 1961, pages 4-6.

DR Reactor

8/9	8/11	47.7	Panellit trip. Charge-discharge and miscellaneous maintenance.
8/14	8/16	38.1	Charging of additional enrichment and replacement of 7 process tubes.
8/23	8/25	40.5	Gas loop trip. Miscellaneous maintenance.
8/31	Still down		Removal of I&E regular metal ruptures from tubes 2470 and 2478.

F Reactor

7/31	8/1	17.4	Charging of additional enrichment.
8/23	8/26	73.4	Leak testing and charge-discharge.

H Reactor

8/3	8/6	93.4	Leak testing and tube replacement.
8/6	8/7	2.3	Repair of leaking front pigtails on tubes 2290 and 2655.
8/7	8/7	0.7	Low pressure Panellit trip on tube 2391.
8/7	8/7	3.0	High pressure Panellit trip on tube 2391. Discharged metal and replaced Venturi and front pigtail.
8/7	8/8	21.6	Removal of an I&E E-metal rupture from tube 2476.
8/15	8/16	38.2	Leak testing.
8/30	9/1	35.7	Removal of an I&E E-metal rupture (bumper) from tube 1379. Charge-discharge and miscellaneous maintenance.

---

Extracted from Plum 1962, August 1961, pages 4-6.

KE Reactor

7/31	8/2	40.9	Panellit trip. Charge-discharge and miscellaneous maintenance.
8/8	8/10	41.3	Panellit trip. Miscellaneous maintenance.
8/30	Still down		Scheduled charge-discharge.

KW Reactor

8/14	8/17	79.9	Scheduled charge-discharge and miscellaneous maintenance.
8/24	8/26	40.7	Removal of an I&E E-metal rupture from tube 1363 and leak testing.
8/26	8/27	39.5	Leak testing.

---

Extracted from Plum 1962, August 1961, pages 4-6.

URANIUM IN TONS  
1961

	REACTORS			SEPARATIONS			
	Charged	Inventory	Inventory	In Cooling	Sept. Oct.	Dissolved Sept. Oct.	
		In Reactor	Discharged				
Sept. Oct.	Sept. Oct.	Sept. Oct.	Sept. Oct.	Sept. Oct.	Sept. Oct.	Sept. Oct.	
<u>Normal U</u>	592	413	1,749	1,746	588	425	1,909 1,990
							<u>Normal U</u>
							Purex
							576 347
<u>24 Metal</u>	194.7	110.0	429.5	434.3	200.0	108.0	540.2 535.9
							<u>24 Metal</u>
							Reduc
							69.0 111.8

MWD AND SPECIAL MATERIALS  
1961

	REACTORS			LIQUID PROCESS		
	Charged or Produced	Inventory In Reactor	Discharged	Inventory In Cooling	Sept. Oct.	Sept. Oct.
		Sept.	Oct.	Sept.	Oct.	Sept. Oct.
MWD	382,596	427,418				
Normal	300,987	325,177	612,037	631,129	422,544	306,085
94 Metal	81,609	102,241	147,383	165,437	159,718	84,187

	REACTORS			LIQUID PROCESS		
	Charged or Produced	Inventory In Reactor	Discharged	Inventory In Cooling	Sept. Oct.	Sept. Oct.
		Sept.	Oct.	Sept.	Oct.	Sept. Oct.
MWD	382,596	427,418				
Normal	300,987	325,177	612,037	631,129	422,544	306,085
94 Metal	81,609	102,241	147,383	165,437	159,718	84,187

	REACTORS			LIQUID PROCESS		
	Charged or Produced	Inventory In Reactor	Discharged	Inventory In Cooling	Sept. Oct.	Sept. Oct.
		Sept.	Oct.	Sept.	Oct.	Sept. Oct.
MWD	382,596	427,418				
Normal	300,987	325,177	612,037	631,129	422,544	306,085
94 Metal	81,609	102,241	147,383	165,437	159,718	84,187

Extracted from Travis 1961k, pages 4 and 6.

**COMPARATIVE FILE PERFORMANCE - SEPT 1961**

	B	C	D	DR	F	H	KW	TOTAL
Maximum Power Level To Date, MW	1,895	2,180	1,945	1,925	1,935	1,955	4,085	20,035
Maximum Power Level During Month, MW	1,735	2,060	1,705	1,740	1,760	1,610	3,770	18,180
Average Power Level While Operating, MW	1,669	1,933	1,541	1,611	1,663	1,442	3,508	16,299
Maximum Tube Power, KW	1,110	1,232	1,150	1,140	1,179	1,061	1,182	1,182
Effective Central Tubes	1,520	1,650	1,445	1,500	1,440	1,510	2,570	2,520
Time Operated Efficiency, %	68.4	85.4	61.7	65.0	67.7	51.5	82.3	87.9
Operational Limitation	93.5	95.0	93.5	93.5	93.5	93.5	95.0	95.0
<b>WMD Produced During Month, total</b>	<b>34,252</b>	<b>49,491</b>	<b>28,533</b>	<b>31,168</b>	<b>33,757</b>	<b>22,287</b>	<b>87,106</b>	<b>382,596</b>
Normal Solid	678	339	0	0	115	0	554	1,683
Normal KE	29,365	37,443	26,283	22,786	29,195	401	73,932	299,299
9L Metal	4,269	11,709	2,250	8,682	4,117	21,986	13,172	81,609
<b>Plutonium Produced, grams</b>	<b>27,707</b>	<b>40,253</b>	<b>23,001</b>	<b>25,761</b>	<b>27,455</b>	<b>15,389</b>	<b>76,566</b>	<b>82,300</b>
<b>36 Uranium In Reactor At Month End, tons</b>	<b>223.9</b>	<b>224.0</b>	<b>229.4</b>	<b>216.6</b>	<b>224.0</b>	<b>191.7</b>	<b>435.3</b>	<b>433.9</b>
Normal Solid	9.5	2.0	0	0	2.2	0	0	3.3
Normal KE	192.0	182.6	217.9	170.0	198.5	3.6	390.1	377.5
9L Metal	22.4	39.4	11.5	46.6	23.3	188.1	45.2	53.1
<b>Uranium Discharged During Month, tons</b>	<b>62.7</b>	<b>77.7</b>	<b>42.5</b>	<b>112.3</b>	<b>55.6</b>	<b>120.3</b>	<b>165.5</b>	<b>150.0</b>
Normal Solid	2.7	2.7	0	0	0.6	0	2.4	3.3
Normal KE	54.5	67.0	37.1	105.7	46.7	2.9	132.5	128.5
9L Metal	5.5	8.0	5.4	6.6	8.3	117.4	30.6	18.2
<b>Average Discharge Concentration</b>	<b>795</b>	<b>742</b>	<b>730</b>	<b>723</b>	<b>757</b>	<b>-</b>	<b>755</b>	<b>790</b>
Normal Solid	704	766	742	778	721	709	710	719
Normal KE	849	864	742	778	673	629	823	799
9L Metal								

Extracted from Travis 1961j, page 6.

REACTOR OUTAGES - SEP 1961

<u>Date</u>	<u>Date</u>	<u>Outage</u>	<u>Remarks</u>
<u>Down</u>	<u>Up</u>	<u>Hours</u>	
<u>B Reactor</u>			
9/8	9/11	120.9	Water leak. Tube replacement.
9/11	9/14	1.6	Leak testing and tube replacement.
9/24	9/28	104.1	Repair faulty thermocouple on tube 02711.
<u>C Reactor</u>			
9/15	9/15	0.2	Panellit trip.
9/16	9/21	105.4	Scheduled charge-discharge.
<u>D Reactor</u>			
9/22	9/2	94.6	Charge-discharge and tube replacement following rupture removal.
9/3	9/4	39.4	Removal of an I&E regular metal rupture from tube 1465.
9/4	9/5	4.9	Removed pieces of broken spline from tube 3860.
9/8	9/10	39.5	Tripped due to an improper switching procedure at 151 building. Leak testing & miscellaneous maintenance.
9/11	9/11	0.4	Tripped due to the loss of #7 pump resulting from an improper procedure at 151 building.
9/15	9/18	36.9	Removal of an I&E E-metal rupture from tube 6072. Charge-discharge & tube replacement.
9/21	9/23	52.9	Panellit trip due to internal leak in tube 6180. Tube Replacement.
9/25	9/26	41.2	Water leak. Charge-discharge and tube replacement.
9/30	Still down		Leak testing.

Extracted from Plum 1962, September 1961, pages 3-6.

DR Reactor

8/31	9/2	40.5	Miscellaneous maintenance following rupture removal.
9/2	9/2	0.6	Panellit trip due to a stub being pulled from spline cap on tube 0779.
9/5	9/11	136.0	Scheduled charge-discharge, tube replacement on Ball 3X work.
9/18	9/20	41.5	Removal of I&E E-metal rupture from tube 2561. Miscellaneous maintenance and charge-discharge.
9/20	9/20	0.3	Panellit trip due to oscillating gauge.
9/26	9/28	46.8	Removal of an I&E E-metal rupture from tube 0766. Charge-discharge and miscellaneous maintenance.

F Reactor

9/5	9/6	38.5	Removal of an I&E E-metal rupture from tube 2178.
9/12	9/14	61.9	Leak testing. Charge-Discharge.
9/15	9/16	30.6	Removal of an I&E E-metal rupture from tube 2384.
9/19	9/21	54.8	Removal of an I&E E-metal rupture from tube 2795. Tube replacement.
9/21	9/21	0.6	Remove poison piece stuck in PCCF machine.
9/26	9/28	44.8	Leak testing and miscellaneous maintenance.

II Reactor

9/30	9/1	35.7	Removal of an I&E E-metal rupture (bump) from tube 1379. Charge-Discharge.
9/2	9/3	32.1	Removal of I&E E-metal rupture from tube 2667.
9/3	9/3	1.2	Replaced faulty ball valve on tube 0860.
9/6	9/7	28.5	Removal of an I&E E-metal rupture from tube 1581. Leak testing.
9/10	9/15	128.4	Scheduled charge-discharge, tube replacement and leak testing.
9/19	9/19	0.2	Panellit trip due to faulty bourdon tube.
9/19	9/19	0.1	Unexplained Panellit trip.
9/19	9/21	33.2	Panellit trip when spline cap failed while pulling spline. Charge-discharge and miscellaneous maintenance.
9/21	9/21	0.2	Unexplained low Panellit trip on gauge 1974.
9/24	9/29	114.4	Scheduled EN charge-discharge. Tube replacement and miscellaneous maintenance.
9/30	Still down		Leak testing and tube replacement.

---

Extracted from Plum 1962, September 1961, pages 3-6.

KE Reactor

8/30	9/1	58.6	Scheduled charge-discharge.
9/3	9/4	31.3	Panellit trip.
9/17	9/19	37.0	Unexplained Panellit trip. Miscellaneous maintenance & charge-discharge.
9/24	9/26	35.9	Tripped due to an unexplained instrument failure on KER loop 1 neutron monitor. Charge-discharge.

KW Reactor

9/19	9/23	85.8	Scheduled charge-discharge. Internal rupture of HCR #3 cooling water line.
9/23	9/23	1.4	Repair rear cap leak on tube 1447.

---

Extracted from Plum 1962, September 1961, pages 3-6.

COMPARATIVE FILE PERFORMANCE - OCT 1961									
B	C	D	DR	F	H	KW	TOTAL		
Maximum Power Level To Date, MW	1,895	2,180	1,945	1,925	1,955	4,085	4,115	20,035	
Maximum Power Level During Month, MW	1,800	2,130	1,775	1,770	1,835	3,895	3,920	19,865	
Average Power Level While Operating, MW	1,612	1,970	1,618	1,591	1,738	1,605	2,745	3,752	
Maximum Tube Power, KW	1,190	1,276	1,203	1,193	1,193	1,120	1,582	1,532	
Effective Central Tubes	1,185	1,660	1,160	1,170	1,470	1,515	2,160	2,470	
Time Operated Efficiency, %	70.1	80.1	76.9	59.3	68.5	81.9	81.2	89.2	
Operational Limitation	93.5	95.0	93.5	95.0	93.5	93.5	95.0	95.0	
WD Produced During Month, total	35,032	48,952	38,577	29,228	36,896	40,767	94,266	103,700	
Normal Solid	452	167	0	0	89	0	0	265	
Normal I&E	29,921	37,379	34,771	21,654	32,282	780	80,761	86,556	
9 <sub>4</sub> Metal	4,659	11,406	3,806	7,574	4,525	39,987	13,505	16,779	
Plutonium Produced, grams	28,895	39,688	31,412	23,905	30,171	30,140	80,989	89,415	
Uranium In Reactor At Month End, tons	221.6	225.7	226.9	219.0	224.6	191.8	434.7	434.6	
Normal Solid	7.2	1.8	1.8	1.8	1.6	1.6	1.6	273	
Normal I&E	189.3	187.1	212.9	176.4	200.1	3.6	387.0	378.6	
9 <sub>4</sub> Metal	25.1	36.8	14.0	42.6	22.9	188.2	48.7	56.0	
Uranium Discharged During Month, tons	28.5	34.7	59.5	21.8	62.5	17.1	170.3	138.2	
Normal Solid	2.3	0.3	56.5	6.1	0.5	0.1	150.8	109.5	
Normal I&E	21.8	18.6	3.0	15.7	51.8	17.0	19.5	25.4	
9 <sub>4</sub> Metal	1.4	15.8						108.0	
Average Discharge Concentration	758	620	643	776	688	886	540	772	
Normal Solid	628	643	747	920	652	915	875	756	
Normal I&E	647							720	
9 <sub>4</sub> Metal								780	

REACTOR OUTAGES - OCT 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
10/2	10/4	39.2	Leak testing.
10/4	10/6	33.7	Leak testing.
10/10	10/12	53.3	Leak testing. Replaced four tubes due to tube leaks and one tube due to a rear Van Stone leak.
10/17	10/19	55.1	Leak testing.
10/24	10/26	39.0	Leak testing.
10/26	10/26	0.2	Unexplained Beckman trip.
<u>C REACTOR</u>			
10/12	10/15	68.3	Removal of an I&E-E metal rupture from tube 2576 and charge-discharge.
10/23	10/25	54.1	Charge-discharge and maintenance following a trip when a rear pigtail and elbow came off.
10/25	10/25	0.6	Unexplained Panellit trip.
10/26	10/27	24.2	Removal of an I&E-E metal rupture from tube 2271.
10/27	10/27	0.6	Panellit trip due to an oscillating gauge.
<u>D REACTOR</u>			
9/30	10/3	76.9	Charge-discharge and tube replacement following leak testing.
10/5	10/5	0.2	Unexplained Panellit trip.
10/10	10/13	53.5	Removal of an I&E regular metal rupture from tube 2762. Charge-discharge and leak testing.
10/24	10/27	55.1	Charge-discharge and leak testing.
10/27	10/27	1.7	Removal of bumper metal from tube 1892 due to high Panellit pressure.

Extracted from Plum 1962, October 1961, pages 2-5.

DR REACTOR

10/2	10/4	43.2	Tripped due to failure of gas loop compressor. Miscellaneous maintenance.
10/6	10/8	44.7	Removal of ruptured production test capsule piece from tube 0574 (PR-IP-402A).
10/10	10/12	40.6	Removal of an I&E-E metal rupture from tube 3985 and tube replacement.
10/15	10/17	44.5	Removal of an I&E-E metal rupture from tube 1460 and miscellaneous maintenance.
10/17	10/17	1.2	Panellit trip due to fluctuation of gauge 1481.
10/20	10/22	14.3	Removal of a stuck I&E-E metal rupture from tube 2658. Charge-discharge.
10/22	10/22	0.4	Unexplained Panellit trip on gauge 0670.
10/23	10/25	42.0	Removal of an I&E-E metal rupture from tube 4173. Charge-discharge and maintenance.
10/25	10/25	0.3	Two Beckmans inadvertently reached trip points.
10/27	10/28	42.1	Removal of an I&E-E metal rupture from tube 2987.

F. REACTOR

10/3	10/8	123.0	Charge-discharge and scheduled tube replacement.
10/24	10/26	63.4	Charge-discharge and leak testing.
10/29	10/31	38.4	Removal of an I&E regular metal rupture from tube 2377. Miscellaneous maintenance.
10/31	still down	-	Removal of an I&E regular metal rupture from tube 2369.

II REACTOR

9/30	10/1	26.0	Leak testing and tube removal.
10/5	10/6	37.2	Removal of an I&E-E metal rupture from tube 1978. Miscellaneous maintenance.
10/14	10/15	25.5	Low pressure trip on tube 1383. Leak testing.
10/23	10/24	29.0	Leak testing.
10/28	10/29	28.3	Leak testing.

KE REACTOR

10/16	10/19	76.7	Scheduled charge-discharge and miscellaneous maintenance.
10/19	10/19	0.4	Panellit trip due to an oscillating gauge.
10/28	10/31	64.4	Miscellaneous maintenance following a Panellit trip. Installed N-type tube in channel 1074 as authorized by project CG-839.

KW REACTOR

10/22	10/26	79.5	Heat cycle 5 hours prior to scheduled charge-discharge.
10/26	10/26	1.2	Panellit trip due to an oscillating gauge.

URANIUM IN TONS  
1961

	REACTORS				SEPARATIONS			
	Charged		Inventory		Inventory		Dissolved	
	Nov.	Dec.	In Reactor	In Reactor	In Cooling	In Cooling	Nov.	Dec.
<u>Normal U</u>	436	445	1,732	1,725	450	452	2,284	1,953
<u>Purex</u>							256	669
<u>24 Metal</u>	83.1	85	443.9	449	73.6	80	472.4	487
<u>24 Metal</u>							136.7	66.3

MUD AND SPECIAL MATERIALS

	R E A C T O R S		I n v e n t o r y I n C o o l i n g		D i s s o l v e d
	Charged or Produced Nov. Dec.	I n v e n t o r y I n R e a c t o r Nov. Dec.	D i s c h a r g e d Nov. Dec.	I n v e n t o r y I n C o o l i n g Nov. Dec.	
M W D	432,763	431,495			
Normal	335,150	325,740	644,908	665,557	321,371
94 Metal	97,613	105,755	204,267	245,395	58,783
					64,627
					375,682
					386,766
					105,803
					105,744
					54,744
					516,985

Extracted from Travis 1962a, pages 7 and 9.

COMPARATIVE FILE PERFORMANCE - NOV 1961							
B	C	D	DR	F	H	KE	KW
Maximum Power Level To Date, MW	1,895	2,265	1,945	1,925	1,935	4,085	4,160
Maximum Power Level During Month, MW	1,880	2,265	1,850	1,835	1,905	4,035	4,150
Average Power Level While Operating, MW	1,717	2,081	1,687	1,756	1,799	1,770	19,700
Maximum Tube Power, KW	1,253	1,367	1,272	1,248	1,262	1,178	3,973
Effective Central Tubes	1,500	1,657	1,654	1,670	1,666	1,490	1,601
Time Operated Efficiency, %	117.2	84.7	63.5	63.1	71.6	65.3	2,615
Operational Limitation	NE	95.5°C	93.5°C	1320°F	93.5°C	89.4	90.6
					93.5°C	750°C	1650Kw
MtD Produced During Month, total	24,332	52,845	32,084	43,780	38,610	30,762	107,595
Normal Solid	292	42	0	0	62	0	0
Normal KE	20,575	40,951	28,939	33,185	33,897	591	89,693
94 Metal	3,465	11,852	3,315	10,595	4,651	30,171	18,306
Plutonium Produced, grams	19,719	43,018	25,525	30,445	31,605	21,671	88,779
Uranium In Reactor At Month End, tons	221.4	225.4	226.2	218.8	224.4	192.5	433.5
Normal Solid	6.7	0	0	0	0	0	0
Normal KE	189.9	187.8	212.4	175.9	200.6	3.6	370.3
94 Metal	24.8	37.6	13.8	42.9	23.8	186.9	55.2
Uranium Discharged During Month, tons	35.6	70.6	37.6	19.8	65.9	15.5	161.6
Normal Solid	0.5	1.8	0	0	1.6	0	0
Normal KE	30.7	56.7	34.9	11.0	60.6	0.3	116.5
94 Metal	4.4	12.1	2.7	8.8	3.7	15.2	11.6
Average Discharge Concentration	826	784	807	741	790	577	728
Normal Solid	631	728	1,061	922	678	723	829
Normal KE	868	722					
94 Metal							

REACTOR OUTAGES - Nov 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
11/1	11/6	105.0	Water leak. Charge-discharge and replacement of process tubes.
11/6	11/6	3.6	Loss of building ventilation due to excessive water in tunnel. *
11/12	11/16	87.1	Low pressure Panellit trip on 2882 due to a tube leak. Process tube replacement.
11/18	11/21	64.6	Water leak. Process tube replacement.
11/21	11/21	.3	Unexplained trip on No. 1 Safety Circuit caused by seismoscope.
11/26	Still down		Water leak. Tube replacement and miscellaneous maintenance.
<u>C Reactor</u>			
11/1	11/1	0.3	Panellit trip due to a flux imbalance.
11/7	11/12	100.4	Scheduled charge-discharge and maintenance.
11/12	11/12	3.5	Correct neutron leak on tube 11484.
11/30	Still down		Electrical ground in safety circuit. Charge-discharge.
<u>D Reactor</u>			
11/4	11/7	64.8	Water leak. Tube replacement.
11/12	11/14	50.6	Water leak. Charge-discharge and replacement of tubes.
11/20	11/23	55.9	Water leak. Leak testing and tube replacement.
11/24	11/26	41.4	Water leak. Leak testing and tube replacement.
11/27	11/29	50.5	Removal of an I&E-E metal rupture from tube 0774. Tube replacement.
11/29	11/29	.3	Panellit trip due to a faulty gauge.

Extracted from Plum 1962, November 1961, pages 4-6.

DR Reactor

11/14	11/17	86.0	Water leak. Charge-discharge and tube replacement.
11/29	Still down		Water leak. Charge-discharge and tube replacement.

F Reactor

10/31	11/1	31.6	Rupture removal concluded.
11/17	11/21	88.2	Water leak. Charge-discharge and tube replacement.
11/22	11/23	37.3	Water leak.
11/28	11/30	46.5	Water leak. Tube replacement.
11/30	11/30	.6	Panellit trip due to loose rear cap.
11/30	Still down		Water leak.

H Reactor

11/1	11/2	26.1	Water leak. Tube replacement.
11/6	11/8	35.4	Water leak. Tube replacement.
11/14	11/18	100.7	Scheduled tube replacement and miscellaneous maintenance.
11/18	11/18	.3	Tripped due to failure of rear pigtails at the nozzle connector.
11/18	11/19	2.7	Unexplained trip.
11/19	11/19	.8	Unexplained Panellit trip.
11/20	11/20	1.3	Unexplained Panellit trip.

11/23	11/24	28.9	Panellit trip on tube 2767. The Hoke valve was partially closed with a rusty substance. Charge-discharge.
11/26	11/27	27.9	Water leak. Rear gasket leaks corrected and tube replacement.
11/29	11/30	27.0	Low pressure Panellit trip on tube 0180. Charge-discharge and leak testing.
11/30	11/30	.2	Unexplained Panellit trip on Row 43.

KE Reactor

11/20	11/23	76.2	Scheduled charge-discharge and miscellaneous maintenance.
-------	-------	------	---

KW Reactor

11/14	11/17	67.6	Scheduled charge-discharge and maintenance.
-------	-------	------	---

(\*) Resulted from effluent water backing up in one C-reactor effluent line when the other was taken out of service for repair, together with concurrent failure to start a sump pump in the B pipe tunnel.

COMPARATIVE PILE PERFORMANCE - DEC 1961									
B	C	D	DR	F	H	KW	KW	TOTAL	
Maximum Power Level To Date, MW	1,895	2,275	1,945	1,325	1,235	1,255	4,215	4,160	
Maximum Power Level During Month, MW	1,840	2,275 <sup>1</sup>	1,935	1,895	1,920	1,850	4,215 <sup>1</sup>	4,160	
Average Power Level While Operating, MW	1,648	1,965	1,924	1,746	1,822	1,710	3,870	3,870	
Maximum Tube Power, KW	1,215	1,359	1,337	1,258	1,291	1,246	1,697	1,697	
Effective Central Tubes	1,483	1,674	1,447	1,472	1,464	1,437	2,484	2,480	
Time Operated Efficiency, %	65.1	47.6	63.4	80.0	75.3	75.7	78.0	91.9	
Operational Limitation	93.50 <sup>2</sup>	95.00 <sup>2</sup>	93.50 <sup>2</sup>	1320Kt <sup>3</sup>	1150 <sup>3</sup>	93.50 <sup>2</sup>	1709Kt <sup>3</sup>	1650Kt <sup>3</sup>	
MWD Produced During Month, total									
Normal Solid	33,253	29,014	35,287	43,298	42,518	40,106	93,599	111,390 <sup>1</sup>	
Normal I&E	28,359	22,127	31,946	32,935	36,868	879	78,195	94,127	
9u Metal	4,660	6,887	3,341	10,263	5,680	39,227	15,404	20,193	
Plutonium Produced, grams									
Uranium In Reactor At Month End, tons	27,379	23,794	28,100	32,855	35,170	27,366	81,557	98,703	
Normal Solid	220.4	225.4	227.3	218.4	223.3	191.9	434.0	433.4	
Normal I&E	3.8	0	0	0	0	0	0	3.8	
9u Metal	191.9	184.8	211.0	175.9	197.6	14.6	377.7	374.8	
Uranium Discharged During Month, tons	211.7	40.6	13.3	42.5	25.7	187.3	56.3	58.6	
Normal Solid	56.4	76.0	34.6	28.7	75.1	10.3	149.7	100.7	
Normal I&E	2.9	0	0	0	0	0	0	0	
9u Metal	47.9	65.0	29.7	18.4	71.9	0.2	129.3	86.7	
Average Discharge Concentration	5.6	11.0	4.9	10.3	3.2	10.1	20.4	14.0	
Normal Solid	754	0	0	0	0	0	0	0	
Normal I&E	689	661	782	765	628	715	661	679	
9u Metal	850	791	772	1,021	838	956	720	701	

<sup>1</sup> New record.  
<sup>2</sup> Bulk outlet water temperature limit.  
<sup>3</sup> True corrosion limit.

REACTOR OUTAGES - DEC 1961

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
11/26	12/2	150.4	Leak testing, tube replacement, and miscellaneous maintenance.
12/2	12/2	1.6	Failure of loop header back-up water supply.
12/5	12/7	42.0	Leak testing and tube replacement.
12/9	12/11	39.7	Leak testing and tube replacement.
12/14	12/18	101.2	Scheduled charge-discharge and tube replacement.
12/26	12/27	42.5	Leak testing.
<u>C Reactor</u>			
11/30	12/2	34.7	Charge-discharge. Corrected a ground in the DC circuit of the upper limit switch on #40 VSR.
12/8	12/21	313.2	Removal of an I&E-E metal rupture from tube 3762. Scheduled overboring, charge-discharge, replacement of front pigtails and miscellaneous maintenance.
12/21	12/21	0.8	Panellit trip.
12/21	12/21	10.9	Thermocouple repair on tube 2764.
12/23	12/23	0.4	Panellit trip.
12/26	12/28	35.9	Miscellaneous maintenance work after a manual trip due to a loose front pigtail connector.

---

Extracted from Plum 1962, December 1961, pages 4-6.

D Reactor

12/1	12/2	42.0	Low pressure Panellit trip on tube 1086. Miscellaneous maintenance.
12/12	12/14	41.5	Leak testing, tube replacement and charge-discharge.
12/14	12/14	0.2	Unexplained Panellit trip.
12/16	12/22	150.1	Scheduled charge-discharge. Tube replacement and miscellaneous maintenance.
12/25	12/27	41.5	Leak testing and tube replacement.

DR Reactor

11/29	12/2	65.8	Charge-discharge and tube replacement.
12/3	12/3	0.3	Manual trip due to a reactivity change while flushing a ball valve tube.
12/14	12/16	46.0	Removal of a stuck I&E regular metal rupture from tube 3264. Charge-discharge.
12/27	12/29	53.0	Removal of a stuck I&E regular metal rupture from tube 0867. Leak testing.
12/31	Still down		Scheduled charge-discharge and tube replacement.

F Reactor

11/30	12/1	26.8	Leak testing and tube replacement.
12/6	12/9	68.3	Leak testing, tube replacement and charge-discharge.
12/9	12/9	0.9	Panellit trip due to improperly installed rear cap on tube 1677.
12/23	12/27	92.7	Panellit trip due to a leak in tube 3971. Scheduled charge-discharge and leak testing.

H Reactor

12/4	12/5	29.8	Leak testing and tube replacement.
12/8	12/9	25.7	Leak testing.
12/13	12/14	32.1	Removal of an I&E-E metal rupture from tube 2864.
12/15	12/16	28.5	Panellit trip on tube 1469 due to a water leak. Leak testing and tube removal.
12/21	12/22	28.9	Leak testing and tube replacement.
12/23	12/23	1.8	Removal of an I&E-E metal rupture from tube 4177.
12/28	12/29	27.8	Removal of an I&E-E metal rupture from tube 2872. Helium leak testing.
12/31	Still down		Removal of an I&E-E metal rupture from tube 2667. Charge-discharge.

KE Reactor

12/3	12/5	42.3	Charge-discharge and miscellaneous maintenance following a Loop 2 trip.
12/14	12/16	59.7	Panellit trip due to a grounded gauge. Charge-discharge and miscellaneous maintenance.
12/27	12/30	61.3	Scheduled charge-discharge and miscellaneous maintenance.
12/31	12/31	0.4	Panellit trip due to the inadvertent opening of a toggle valve.

KW Reactor

12/4	12/7	61.1	Scheduled charge-discharge.
12/7	12/7	0.4	Panellit trip due to an oscillating gauge 0370.

APPENDIX C

OPERATING DATA FOR 1962

URANIUM IN TONS  
1962

	REACTORS			SEPARATIONS		
	Charged		Inventory	In Cooling		Dissolved
	Jan.	Feb.	In Reactor	Jan.	Feb.	Jan. Feb.
<u>Normal U</u>	582	56	1,732	1,830	575	47
				2,158	2,447	<u>Normal U</u>
						Purex
						385 144
<u>94 Metal</u>	133	69	446	357	136	158
					46	501
						<u>94 Metal</u>
						168 112

MWD AND SPECIAL MATERIALS

	REACTORS			REACTORS		
	Charged or Produced		Inventory In Reactor	Discharged		Inventory In Cooling
	Jan.	Feb.	Jan.	Feb.	Jan.	Feb.
<u>MWD</u>	404,374	394,752				
<u>Normal</u>	309,858	313,774	588,915	604,239	386,500	298,450
<u>94 Metal</u>	94,316	80,978	231,630	181,858	108,081	130,750
					359,203	403,528
						136,209
						<u>86,432</u>

Dissolved

Extracted from Travis 1962c, pages 5 and 7.

COMPARATIVE PILE PERFORMANCE - JAN 1962

	B	C	D	DR	F	H	RB	KW	TOTAL
Maximum Power Level To Date, MW	1,895	2,295 <sup>1</sup>	1,765	1,925	1,935	1,955	1,100 <sup>1</sup>	4,100 <sup>1</sup>	20,750
Maximum Power Level During Month, MW	1,840	2,225	1,730	1,875	1,890	1,825	1,100	4,100	20,445
Average Power Level While Operating, MW	1,631	2,082	1,610	1,734	1,736	1,613	1,248	3,977	18,651
Average Power Level While Power, KW	1,205	1,370	1,180	1,250	1,253	1,170	1,722	1,679	
Maximum Tube Power, KW	1,470	1,670	1,180	1,455	1,485	1,180	2,320	2,500	
Effective Central Tubes	35.2	76.1	65.7	50.6	86.9	54.7	86.2	73.4	65.8
Time Operated Efficiency, %	110.0 <sup>2</sup>	137.5 <sup>3</sup>	100.0 <sup>2</sup>	110.0 <sup>2</sup>	115.0 <sup>2</sup>	115.0 <sup>2</sup>	115.0 <sup>2</sup>	115.0 <sup>2</sup>	
Operational Limitation									
MHD Produced During Month, total	17,796	47,805	32,869	27,189	47,312	27,367	113,447 <sup>1</sup>	90,449	404,174
Normal Solid	101	0	0	0	0	0	0	0	101
Normal I&E	15,204	36,179	29,619	19,112	40,818	1,538	93,769	73,508	309,157
9 <sub>4</sub> Metal	2,491	11,626	3,190	8,047	6,491	25,829	19,598	16,941	94,316
Plutonium Produced, grams	1h,338	38,602	25,629	22,062	38,114	18,100	97,613	78,412	332,870
Uranium In Reactor At Month End, tons	22h.6	225.3	225.9	217.0	223.5	193.0	434.1	434.4	2177.8
Normal Solid	3.0	0	0	0	198.2	26.0	370.7	0	3.0
Normal I&E	197.3	185.0	211.2	167.8	167.8	26.5	63.4	372.4	1729.1
9 <sub>4</sub> Metal	2h.3	40.3	11.7	49.2	25.3	166.5	63.4	62.0	45.7
Uranium Discharged During Month, tons	90.8	56.2	1h.1	93.4	3.0	32.9	192.1	229.4	711.9
Normal Solid	0.8	0	0	0	0	0	0	0	0.8
Normal I&E	81.1	43.4	12.9	88.8	2.4	0.6	159.6	185.9	574.7
9 <sub>4</sub> Metal	8.9	12.8	1.2	4.6	0.6	32.3	32.5	13.5	136.4
Average Discharge Concentration									
Normal Solid	730	0	0	0	0	0	0	0	730
Normal I&E	563	666	812	738	553	841	681	671	671
9 <sub>4</sub> Metal	730	774	1,052	768	508	894	787	738	792

<sup>1</sup> New record.

<sup>2</sup> Tube temperature limit for control of tube corrosion.

<sup>3</sup> Tube power limit for rupture control.

<sup>4</sup> Administrative reactor power limit.

Extracted from Travis 1962b, page 25

REACTOR OUTAGES

JAN 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
1/2	1/6	111.5	Leak testing and tube replacement.
1/7	1/10	57.8	Removal of an I&E regular metal rupture from tube 2088. Tube replacement.
1/13	1/29	383.1	Scheduled charge-discharge and replacement of 340 tubes. Miscellaneous maintenance.
1/29	1/29	0.7	Panellit trip due to fluctuation in water pressure while adjusting gauges.
<u>C REACTOR</u>			
1/5	1/6	40.7	Removal of an I&E metal rupture from tube 3271.
1/16	1/19	72.9	Removal of an oversize I&E natural metal rupture from tube 4463. Probologging and miscellaneous maintenance.
1/23	1/25	42.8	Leak testing and tube replacement.
1/28	1/29	26.6	Leak testing and tube replacement.

---

Extracted from Plum 1963, January 1962, pages 3-6.

D REACTOR

1/1	1/4	68.3	Charge-discharge following leak testing.
1/7	1/9	46.2	Leak testing.
1/9	1/10	28.1	Removal of an I&E regular metal rupture from tube 2773.
1/14	1/16	42.6	Leak testing and tube replacement.
1/20	1/20	0.2	Power surge due to the grounding of a power line.
1/24	1/26	42.1	Leak testing and tube replacement..
1/27	1/27	3.4	Two Panellit trips due to oscillating gauges.
1/30	Still Down		Removal of an I&E regular metal rupture from tube 2371.

DR REACTOR

12/31	1/14	344.0	Scheduled charge-discharge and replacement of 180 tubes.
1/16	1/18	47.2	Leak testing and tube replacement.
1/19	1/19	0.5	Gas loop trip due to a voltage drop on the loop compressor when wind blew power lines together.

F REACTOR

1/10	1/12	55.8	Water leak and tube replacement.
1/18	1/20	11.6	Leak testing and tube replacement.

---

Extracted from Plum 1963, January 1962, pages 3-6.

II REACTOR

12/31	1/2	32.1	Removal of an I&E-E metal rupture from tube 2667. Charge-discharge.
1/4	1/5	30.5	Leak testing and tube replacement.
1/7	1/8	28.2	Removal of an I&E-E metal rupture from tube 2580. Tube replacement.
1/9	1/9	1.0	Successful quick discharge of an I&E-E metal rupture from tube 2576.
1/11	1/13	51.6	Leak testing and tube replacement.
1/13	1/13	1.8	Three unexplained Panellit trips.
1/16	1/18	32.5	Removal of an I&E-E metal rupture from tube 1968. Tube replacement.
1/21	1/22	32.0	Removal of an I&E-E metal rupture from tube 2669. Tube replacement.
1/25	1/26	29.3	Removal of an I&E-E metal rupture from tube 3174.
1/27	Still Down		Scheduled tube replacement.

III REACTOR

1/23	1/27	102.5	Removal of an I&E regular metal rupture from tube 4667. Scheduled charge-discharge and maintenance.
1/27	1/27	0.5	Tripped by loop 1 when the control valve packing failed.

Extracted from Plum 1963, January 1962, pages 3-6.

KW REACTOR

1/3	1/6	70.6	Scheduled charge-discharge and miscellaneous maintenance.
1/6	1/6	1.1	Manual trip due to insufficient control rod.
1/8	1/9	33.5	Miscellaneous maintenance work following a dual Beckman trip. (No. 2 Beckman circuit was caused to be bypassed by an electrical identification tab which dropped into a relay).
1/21	1/23	44.5	Removal of an I&E-E metal rupture from tube 2779. Charge-discharge and miscellaneous maintenance.
1/23	1/23	5.3	Unexplained Panellit trip.
1/23	1/23	0.7	Unexplained Panellit trip.
1/23	1/23	1.2	Unexplained Panellit trip.
1/23	1/24	4.3	Unexplained Panellit trip.
1/24	1/24	1.7	Removal of an I&E-E metal rupture from tube 2571.
1/27	1/28	33.0	Tripped by the crosstie system when the #3 high-lift discharge line check valve malfunctioned at (70).

---

Extracted from Plum 1963, January 1962, pages 3-6.

COMPARATIVE PILE PERFORMANCE - FEB 1962

	B	C	D	DR	F	H	ES	KW	TOTAL
Maximum Power Level to Date, MW	1,935 <sup>1</sup>	2,310 <sup>1</sup>	1,945	1,925	1,935	1,955	1,400	1,400	20,905
Maximum Power Level During Month, MW	1,935	2,310	1,750	1,850	1,700	1,810	1,400	1,400	20,155
Average Power Level While Operating, MW	1,169	2,113	1,631	1,825	1,611	1,723	1,326	1,326	18,975
Maximum Tube Power, KW	1,270	1,370	1,170	1,225	1,110	1,210	1,715	1,715	1,620
Effective Central Tubes	1,520	1,665	1,550	1,500	1,500	1,500	2,570	2,560	
Time Operated Efficiency, %	67.1	69.1	62.3	91.1	36.1	54.7	91.5	82.9	
Operational Limitation	105 <sup>2</sup>	231 <sup>3</sup>	100 <sup>2</sup>	110 <sup>2</sup>	105 <sup>2</sup>	105 <sup>2</sup>	100 <sup>4</sup>	100 <sup>4</sup>	69.1
MW Produced During Month, total	33,219	42,058	28,457	46,565	16,285	26,110	110,798	90,930	394,752
Normal	28,879	31,560	25,564	33,292	14,069	16,917	89,794	73,669	313,774
% Metal	4,370	10,498	2,893	13,273	2,216	9,463	21,004	17,251	80,978
Plutonium Produced, grams	27,983	34,078	21,979	36,785	12,758	22,150	97,112	79,169	332,314
Uranium In Reactor At Month End, tons	224.1	223.7	225.7	217.0	224.3	202.4	434.8	435.0	2187.0
Normal	200.8	180.3	211.0	169.3	199.0	124.1	374.6	370.8	1829.9
% Metal	23.3	43.4	11.7	47.7	25.3	78.3	60.2	60.2	357.1
Uranium Discharged During Month, tons	20.4	97.6	26.4	26.3	96.2	96.6	83.3	158.0	604.8
Normal	18.6	77.9	21.6	18.9	88.9	2.7	73.6	111.6	111.6
% Metal	1.8	19.7	1.8	7.1	7.3	93.9	9.7	16.4	158.0
Average Discharge Concentration									
Normal	649	646	875	782	649	686	652	651	668
% Metal	738	826	1,136	1,048	998	813	769	747	828

<sup>1</sup> New reactor level record.

<sup>2</sup> Tube temperature limit for control of tube corrosion.

<sup>3</sup> Tube temperature limit for rupture control.

<sup>4</sup> Administrative reactor power limit.

Extracted from Travis 1962c, page 25.

REACTOR OUTAGESB REACTOR FEB 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
2/11	2/12	29.7	Leak testing and tube replacement.
2/13	2/13	0.5	Adjust water flow on three gamma monitoring sample lines.
2/14	2/16	15.4	Leak testing and tube replacement.
2/22	2/25	67.4	Leak testing, tube replacement and charge-discharge.
2/25	2/25	6.0	Correct faulty thermocouples.
2/26	Still Down		Removal of an I&E E-metal rupture from tube 2463, leak testing and tube replacement.

C REACTOR

2/3	2/5	39.6	Removal of an I&E regular metal rupture from tube 2289, charge-discharge and maintenance.
2/5	2/5	1.5	Panellit trip due to loose spline cap on tube 0670.
2/15	2/22	142.4	Front pigtail leak at crossheader adaptor on tube 3456. Scheduled charge-discharge and maintenance.

---

Extracted from Plum 1963, February 1962, pages 2-4.

D REACTOR

1/30	2/2	51.0	Charge-discharge following rupture removal.
2/7	2/9	43.0	Leak testing and tube replacement.
2/9	2/9	0.3	Replacement of faulty front-face cap.
2/16	2/18	40.9	Leak testing and tube replacement following a Panellit trip.
2/18	2/19	14.0	Removal of a stuck I&E regular metal rupture from tube 3775 and tube replacement.
2/21	2/21	0.1	Unexplained Panellit trip.
2/23	Still Down		Scheduled charge-discharge, maintenance and replacement of approximately 400 tubes.

DR REACTOR

2/6	2/8	59.5	Scheduled charge-discharge following leak testing.
-----	-----	------	--

F REACTOR

2/7	2/9	35.6	Miscellaneous maintenance following a Panellit trip.
2/10	2/26	411.4	Scheduled tube replacement.
2/27	2/27	6.3	Adjust radiation shielding on "A" test hole.

H REACTOR

1/27	2/13	407.6	Replacement of 300 tubes, charge-discharge and miscellaneous maintenance.
2/13	2/13	2.7	Correction of abnormal water pressure on tube 3478.

---

Extracted from Plum 1963, February 1962, pages 2-4.

KE REACTOR

2/16 2/18 56.5 Charge-discharge following a Panellit trip.

2/19 2/19 0.7 Unexplained Panellit trip.

KW REACTOR

2/13 2/16 72.0 Scheduled charge-discharge and miscellaneous maintenance.

2/16 2/16 8.0 Adjustment of Panellit gauges for 5 pump operation.

2/24 2/25 34.8 Unexplained Panellit trip and miscellaneous maintenance.

URANIUM IN SEDIMENTS

---

REACTORS		SEPARATIONS			
Charged Year.	Inventory I <sub>2</sub> Reactor Mar. Apr.	Inventory In Cooling I <sub>2</sub> R. APR.	Discharged I <sub>2</sub> R. APR.	Dissolved I <sub>2</sub> R.	Dissolved I <sub>2</sub> R.
<u>Normal U</u>	463 617	1,828 1,830	465 615	2,640 2,901	<u>Normal U</u>
				Purex	259 346
					<u>24 Metal</u>
<u>24 Metal</u>	126 92	357 357	126 91	554 642	Redox
					76 4

WWD AND SPECIAL MATERIALS  
1962

	Charged or Produced		Inventory In Reactor		Discarded		Inventory In Cooling		Mar.	Apr.	Mar.	Apr.
	Mar.	Apr.	Mar.	Apr.	Mar.	Apr.	Mar.	Apr.				
WID	461,139	409,827										
Normal	371,561	325,528	671,450	623,943	304,350	373,035	1,774,676	1,903,696	217,878	233,861		
94 Metal	89,578	84,299	163,827	175,990	107,609	72,135	453,658	523,226	55,038 <sup>6</sup>	3,296		

Extracted from Travis 1962e, pages 3 and 5.

COMPARATIVE PILE PERFORMANCE							
		MAR 1962					
B		C		D		F	
Maximum Power Level To Date, MW	1,910 <sup>1</sup>	2,310	1,975 <sup>1</sup>	1,925	1,935	1,955	
Maximum Power Level During Month, MW	1,910	2,310	1,975	1,810	1,830	1,810	1,100
Average Power Level While Operating, MW	1,730	2,216	1,930	1,728	1,749	1,746	20,810
Maximum Tube Power, KW	1,257	1,395	1,325	1,223	1,225	1,183	1,100
Effective Central Tubes	1,180	1,650	1,485	1,490	1,470	1,530	2,535
Time Operated Efficiency, %	82.9	63.9	64.2	35.7	88.1 <sup>5</sup>	78.4 <sup>5</sup>	19,619
Operational Limitation	670 <sup>6</sup>	2310 <sup>3</sup>	93.5 <sup>6</sup>	110 <sup>5</sup>	105 <sup>5</sup>	105 <sup>5</sup>	2,560
MW Produced During Month, total	14,470	13,918	38,857	19,133	47,759	44,112	73.2
Normal	38,055	32,489	35,220	13,868	41,167	28,548	
9 <sub>6</sub> Metal	6,445	11,429	3,637	5,265	6,592	15,464	
Plutonium Produced, grams	36,135	36,351	31,829	11,621	39,713	34,991	
Uranium In Reactor At Month End, tons	224.1	223.8	228.5	215.7	223.0	199.8	
Normal	197.3	182.2	214.7	170.1	197.4	123.8	
9 <sub>6</sub> Metal	26.8	11.6	13.8	45.6	25.6	76.0	
Uranium Discharged During Month, tons	22.3	62.6	74.5	15.1	55.2	28.5	
Normal	20.5	16.8	69.0	3.5	49.3	10.5	
9 <sub>6</sub> Metal	1.8	15.8	5.5	11.6	5.9	18.0	
Average Discharge Concentration							
Normal	566	604	806	932	645	370	654
9 <sub>6</sub> Metal	788	762	918	1,150	1,084	1,051	687
							851

<sup>1</sup> New record.  
<sup>2</sup> Graphite temperature limit.  
<sup>3</sup> Administrative reactor power limit.  
<sup>4</sup> Bulk outlet water temperature limit.  
<sup>5</sup> Tube outlet water temperature limit for control of tube corrosion.  
<sup>6</sup> Tube power limit for rupture control.  
 Extracted from Travis 1962d, page 23.

REACTOR OUTAGES MAR 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
2/26	3/31	79.9	Leak testing following rupture removal.
3/9	3/11	39.7	Removal of an I&E regular metal rupture from tube 2378. Charge-discharge and leak testing.
3/12	3/13	19.2	Correction of a spline-cap leak.
3/19	3/20	26.9	Leak testing and tube replacement.
3/31	Still down		Water leak. Charge-discharge.
<u>C Reactor</u>			
3/10	3/18	192.1	Scheduled charge-discharge and tube replacement; miscellaneous maintenance.
3/18	3/18	0.3	Unexplained Panellit trip.
3/27	3/30	75.9	Leak testing.
<u>D Reactor</u>			
2/23	3/11	388.8	Scheduled replacement of tubes. Charge-discharge and miscellaneous maintenance. 2 + 31.6
<u>DR Reactor</u>			
3/2	3/3	44.1	Water leak. Charge-discharge & miscellaneous maintenance.
3/11	3/13	39.4	I&E regular metal rupture in tube 1078.
3/15	Still down		I&E regular metal rupture in tube 1584, and tube replacement.

Extracted from Plum 1963, March 1962, pages 2-4.

F Reactor

3/1	3/2	42.9	Leak testing.
3/26	3/27	43.1	Scheduled charge-discharge.
3/27	3/28	2.7	Low pressure Panellit trip due to rear cap leak on tube 3984.

H Reactor

3/12	3/14	53.6	I&E regular metal rupture in tube 1372. Charge-discharge.
3/15	3/15	0.7	Two unexplained Panellit trips.
3/15	3/16	16.4	Leak testing.
3/18	3/20	32.9	Leak testing.
3/29	3/30	32.3	Removal of an I&E-E metal rupture from tube 4169.
3/31	Still down		Tube replacement.

KE Reactor

3/5	3/8	77.4	Scheduled charge-discharge.
3/28	3/31	83.3	I&E-E metal rupture in tube 2091. Charge-discharge.

KW Reactor

3/12	3/14	34.6	Manual trip due to a production test (PT-397-A) rupture in tube 3446. Charge-discharge.
3/16	3/17	36.1	Tripped due to a heat cycle. Charge-discharge.

---

Extracted from Plum 1963, March 1962, pages 2-4.

	COMPARATIVE PILE PERFORMANCE				H	KW	TOTAL
	B	C	D	M			
Maximum Power Level To Date, MW	1,540	2,310	1,975	1,925	1,235	1,955	20,310
Maximum Power Level During Month, MW	1,530	2,310	1,760	1,920	1,525	1,970	20,320
Average Power Level While Operating, MW	1,684	2,140	1,762	1,648	1,790	1,698	18,262
Maximum Tube Power, KW	1,280	1,363	1,330	1,215	1,203	1,120	1,618
Effective Central Tubes	1,500	1,634	1,590	1,498	1,470	1,620	2,550
Time Operated Efficiency, %	33.3	77.2	70.9	69.2	81.3	68.9	82.5
Operational Limitation	670°C	95.0°C	93.5°C	110°C	93.5°C	81.0	95.0°C
M:D Produced During Month, total	16,832	49,585	37,503	34,196	43,623	24,933	102,051
Normal	11,269	36,889	33,183	24,421	37,629	16,429	80,942
9t Metal	2,563	12,596	14,020	9,775	5,994	8,504	20,585
Plutonium Produced, grams	13,400	40,318	31,354	28,768	35,284	19,599	89,098
Uranium In Reactor At Month End, tons	224.1	223.7	227.6	217.4	223.0	200.8	1,36.2
Normal	197.2	182.1	211.9	169.5	197.5	123.8	377.9
9t Metal	26.9	41.6	15.7	47.9	25.5	77.0	58.3
Uranium Discharged During Month, tons	22.2	18.5	90.9	149.3	11.8	29.9	122.3
Normal	20.0	13.7	85.7	138.8	10.8	20.4	26.7
9t Metal	2.2	4.8	5.2	10.5	1.0	9.5	26.1
Average Discharge Concentration							
Normal	638	567	669	532	576	355	657
9t Metal	1,010	398	1,034	750	1,117	1,122	713

1 Granite temperature is it.

2 Bulk outlet water temperature limit.

3 Tube outlet water temperature is. For control of tube corrosion.

Extracted from Travis 1962e, page 22.

REACTOR OUTAGES APR 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
3/31	4/1	38.2	Leak testing.
4/6	4/7	30.3	Power failure trip.
4/8	4/9	25.6	Leak testing.
4/13	Still down		Scheduled tube replacement. A total of 343 tubes was installed.
<u>C Reactor</u>			
4/5	4/5	0.3	Unexplained Panellit trip.
4/5	4/7	48.7	Removal of an overbore size I&E regular metal rupture from tube 2969; removal of two I&E metal ruptures from tube 2955.
4/12	4/14	56.6	Leak testing. Inspection of the overbore size fuel elements discharged from tube 2969 on 4/5 failed to confirm the presence of a rupture. Leaking tube 1468 was replaced.
4/16	4/16	0.6	Correct rear connector leak.
4/16	4/18	57.6	Removal of three overbore size ruptures from tube 3062.

---

Extracted from Plum 1963, April 1962, pages 2-5.

D Reactor

4/2	4/5	82.4	Scheduled charge-discharge.
4/6	4/8	34.2	Miscellaneous maintenance following a power failure trip.
4/14	4/16	42.2	Removal of an I&E natural metal rupture from tube 2281 and replacement of three leaking tubes.
4/16	4/16	2.0	Removal of an I&E natural metal rupture from tube 1684.
4/21	4/23	48.1	Removal of an I&E natural metal rupture from tube 1962. Charge-discharge and tube replacement.

DR Reactor

3/15	4/3	450.9	Completed the replacement of 218 process tubes.
4/4	4/4	0.4	Manual trip due to indications of high temperature, caused by faulty thermocouple.
4/6	4/8	36.2	Miscellaneous maintenance following a power failure trip.
4/8	4/8	0.3	Panellit trip when spline stub was removed from tube 0885.
4/15	4/18	76.4	Charge-discharge and leak testing following a Panellit trip.
4/20	4/21	37.5	Removal of an I&E natural metal rupture from tube 1064. Tube replacement.
4/22	4/22	0.2	Panellit trip due to a non-seated charge.
4/26	4/27	38.6	Panellit trip. Removal of an I&E natural metal rupture from tube 3879.

---

Extracted from PLUM 1963, April 1962, pages 2-5.

F Reactor

4/6 4/8 41.8 Charge-discharge following a power failure trip.

4/27 Still down Scheduled tube replacement.

H Reactor

3/31 4/14 354.0 Tube replacement - 192 removed, 189 installed.

4/14 4/14 2.5 Two scrams for thermocouple repairs.

4/15 4/15 0.2 Panellit trip caused by valving of PCFF before Panellit gauge was jumpered.

4/15 4/15 0.3 Panellit trip due to faulty Panellit jumper.

4/21 4/23 35.9 Leak testing and tube replacement.

4/24 4/24 0.2 Unexplained Panellit trip.

KE Reactor

4/1 4/1 1.2 Correction of two rear cap leaks unsuccessful when discharge platform failed to operate.

4/4 4/6 38.8 Charge-discharge and maintenance following PT rupture removal from Loop 1.

4/6 4/6 0.7 Tripped due to a power failure.

4/26 4/29 88.7 Charge-discharge and maintenance following a Panellit trip. Replaced No. 3 low lift pump set on Project CG-883.

4/30 4/30 0.9 Two unexplained Panellit trips.

KW Reactor

4/6 4/10 92.7 Scheduled charge-discharge following a power failure trip.

4/25 4/26 33.0 Charge-discharge following a Panellit trip.

---

Extracted from Plum 1963, April 1962, pages 2-5.

URANIUM IN TONS  
1962

	REACTORS						SEPARATIONS					
	Charged		Inventory In Reactor May June		Discharged May June		Inventory In Cooling May June		Discharged		Dissolved May June	
	May	June	May	June	May	June	May	June	May	June	May	June
Normal U	492	567	1,842	1,836	480	576	2,750	2,775	Normal U			
									Purex			
									Purex	626	559	
<u>94 Metal</u>	97	106	350	356	105	99	708	717	<u>94 Metal</u>			
									Reduc	40	89	

MWD AND SPECIAL MATERIALS

1962

MWD	REACTORS						COOLING					
	Charged or Produced		Inventory In Reactor		Discharged		Inventory In Cooling		Inventory In Cooling		Dissolved	
	May	June	May	June	May	June	May	June	May	June	May	June
	<u>435,311</u>	<u>407,287</u>										
Normal	352,579	330,943	687,996	646,111	283,526	372,828	1,781,780	1,794,056			413,541	360,383
94 Metal	83,232	76,344	167,349	160,201	91,373	83,992	582,195	593,346			32,399	72,777

Extracted from Travis 1962g, pages 2 and 4.

	COMPARATIVE PILE PERFORMANCE						TOTAL
	B	C	D	MAY 1962	F	H	
Maximum Power Level To Date, MW	1,310	2,310	1,975	1,925	1,935	1,255	6,400 20,310
Maximum Power Level During Month, MW	1,865	2,310	1,910	1,785	1,855	1,355	6,335 20,200
Average Power Level While Operating, MW	1,761	2,074	1,813	1,734	1,762	1,693	6,051 18,876
Maximum Tube Power, KW	1,196	1,100	1,215	1,184	1,253	1,196	1,664 1,640
Effective Central Tubes	1,505	1,575	1,510	1,485	1,471	1,540	2,572 2,560
Time Operated Efficiency, %	84.9	52.2	83.7	89.3	50.1	83.4	86.6 71.4
Operational Limitation	93.5°C	95.0°C	93.5°C	110°C	93.5°C	93.5°C	95.0°C 95.0°C
MW Produced During Month, total	46,377 <sup>3</sup>	33,570	47,038	48,019	27,375	21,568	103,160 143,311
Normal	39,057	25,087	42,289	34,853	23,582	14,232	85,114 135,279
9U Metal	7,320	8,483	4,749	13,166	3,793	7,336	17,716 83,232
Plutonium Produced, grams	39,062	26,516	37,336	38,900	22,395	16,750	90,307 94,080
Uranium In Reactor At Month End, tons	225.2	222.8	228.3	217.5	224.8	202.1	436.6 365,346
Normal	197.2	181.3	215.3	170.8	198.9	125.7	381.0 1841.8
9U Metal	28.0	41.5	13.0	46.7	25.9	76.4	55.6 350.0
Uranium Discharged During Month, tons	110.5	78.1	65.7	29.1	60.7	93.8	94.6 2191.8
Normal	98.1	62.7	36.7	17.4	49.8	75.2	88.6 72.7
9U Metal	12.4	15.4	9.0	11.7	10.9	18.6	6.0 62.9
Average Discharge Concentration							
Normal	578.3	618.8	638.4	214.2	597.1	560.5	666.2 600.8
9U Metal	817.7	800.1	825.6	1049.3	930.2	1017.4	677.0 670.2

1 Bulk outlet water temperature limit.  
 2 Tube outlet water temperature limit for control of tube corrosion.  
 3 New record.

Extracted from Travis 1962f, page 22.

REACTOR OUTAGES MAY 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
4/13	5/1	421.0	Tube replacement.
5/1	5/1	2.8	Unexplained Panellit trip.
5/2	5/2	0.9	Repair ball valve oil line leak in order to discharge poison.
5/2	5/2	0.1	VSR's 16 and 25 dropped out of upper limit switch.
5/12	5/14	44.0	Removal of an I&E natural metal rupture from tube 1068. Tube replacement.
5/15	5/17	52.0	PCCF malfunction, charge-discharge and maintenance.
<u>C Reactor</u>			
5/5	5/9	103.6	Removal of an I&E natural metal rupture from tube 1384. Charge-discharge and maintenance.
5/10	5/10	0.2	Repair faulty thermocouple.
5/10	5/10	1.7	Four unexplained Panellit trips.
5/11	5/12	41.8	Removal of an I&E natural metal rupture from tube 1159.
5/20	5/23	56.2	Charge-discharge and maintenance following a trip when leads to the No. 4 pump motor burned out.
5/25	Still down		Tube replacement.

Extracted from Plum 1963, May 1962, pages 2-5.

D Reactor

5/2	5/4	40.4	Leak testing and tube replacement.
5/4	5/4	0.5	Remove stuck perf from PCCF machine.
5/27	5/29	59.2	Removal of an I&E natural metal rupture; charge-discharge.
5/29	5/30	20.9	Leak testing and tube replacement.
5/30	5/30	0.4	Faulty ball valve on tube 3564.

DR Reactor

5/1	5/3	44.5	Removal of an I&E natural metal rupture from tube 1265.
5/8	5/9	35.1	Removal of an I&E natural metal rupture from tube 3072. Maintenance.

F Reactor

4/27	5/15	437.6	Replacement of 355 tubes.
5/31	Still down		Scheduled charge-discharge.

H Reactor

5/6	5/8	36.1	Removal of an I&E-E metal rupture from tube 0576, charge-discharge and maintenance.
5/8	5/9	14.7	Water leak. Tube replacement.
5/12	5/27	358.6	Replacement of 249 tubes.
5/27	5/27	0.4	Unexplained instrumentation trip.
5/28	5/28	0.3	Unexplained high pressure Pannelit trip.
5/28	5/30	28.1	Miscellaneous maintenance following the correction of a water leak.

---

Extracted from Plum 1963, May 1962, pages 2-5.

KE Reactor

5/14	5/16	49.2	Trip due to a leak in Panellit gauge 2483. Charge-discharge and miscellaneous maintenance.
5/16	5/16	1.0	Correction of two rear-face cap leaks.
5/18	5/19	36.3	Repair of valve in cross-tie system.
5/19	5/19	0.4	Unexplained Panellit trip.
5/19	5/19	0.4	Improper switching while by-passing KER Loop 4.
5/19	5/19	0.2	Manual trip due to insufficient control rods.
5/23	5/24	33.7	Trip due to the failure of a small transformer in loop instrumentation.

KW Reactor

5/4	5/5	38.0	Front-face pigtail leak. Charge-discharge.
5/17	5/20	55.3	V-73 cross-tie valve repair and charge-discharge.
5/20	5/20	6.6	Unexplained Panellit trip.

---

Extracted from Plum 1963, May 1962, pages 2-5.

COMPARATIVE PILE PERFORMANCE						
	B	C	D	DR	F	H
Maximum Power Level To Date, MW	1,240	2,210	1,375	1,325	1,235	1,255
Maximum Power Level During Month, MW	1,365	2,110	1,955	1,760	1,815	1,735
Average Power Level While Operating, MW	1,761	1,209	1,745	1,519	1,724	1,689
Maximum Tube Power, KW	1,183	1,350	1,191	1,168	1,222	1,130
Effective Central Tubes	1,534	1,665	1,524	1,450	1,477	1,535
Time Operated Efficiency, %	80.1	95.0	82.3	78.3	68.1	59.6
Operational Limitation <sup>1</sup>	93.5°C	95.0°C	93.5°C	93.5°C	93.5°C	95.0°C
KWD Produced During Month, total	12,305	25,590	13,090	18,509	35,205	30,211
Normal	35,604	19,349	39,330	13,553	30,415	20,111
94 Metal	6,701	6,211	3,760	5,066	4,790	10,100
Plutonium Produced, grams	34,276	21,447	34,156	14,624	29,346	24,910
Uranium In Reactor At Month End, tons	225.8	223.9	229.0	218.3	225.6	202.7
Normal	198.3	184.1	216.2	172.1	200.3	127.9
94 Metal	27.5	39.8	12.8	46.2	25.3	74.3
Uranium Discharged During Month, tons	56.0	59.8	36.0	49.7	115.0	17.0
Normal	50.7	54.9	34.7	35.9	105.4	15.4
94 Metal	53.0	53.0	1.3	13.8	9.6	1.6
Average Discharge Concentration						
Normal	652	567	713	480	640	623
94 Metal	892	753	841	828	862	884

<sup>1</sup> All reactors were limited by bulk outlet water temperatures.  
Extracted from Travis 1962g, page 21.

REACTOR OUTAGES JUN 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
6/13	6/17	106.8	Scheduled charge-discharge. Miscellaneous maintenance.
6/18	6/18	.6	Unexplained Panellit trip.
6/23	6/25	35.9	Miscellaneous maintenance following a Panellit trip due to a faulty spline cap seal on tube 3479.
<u>C Reactor</u>			
5/25	6/11	395.3	Replacement of 399 tubes.
6/11	6/12	37.0	Leak testing and tube replacement following a Panellit trip.
6/13	6/13	1.7	Thermocouple repair.
6/20	6/25	115.1	Leak testing, tube replacement and miscellaneous maintenance.
6/25	6/25	1.9	Investigation of excessive steam formation in the rear face revealed that one of the two exhaust fans normally used was not on.
<u>D Reactor</u>			
6/11	6/13	41.7	Leak testing and tube replacement.
6/13	6/13	.3	Panellit trip due to a faulty gauge on PCCF tube 1475.
6/14	6/16	47.7	Removal of an I&E natural metal rupture from tube 3065. Charge-discharge.
6/18	6/20	37.6	Removal of an I&E natural metal rupture from tube 3378 and replacement of the tube.

---

Extracted from Plum 1963, June 1962, pages 2-4.

DR Reactor

6/5	6/6	38.5	Charge-discharge, leak testing and the correction of two faulty lug rings.
6/9	6/25	403.0	Replacement of 296 tubes.
6/26	6/26	.4	Unexplained Panellit trip.
6/26	6/26	2.1	Removal of an I&E natural metal rupture from tube 1268.

F Reactor

5/31	6/2	63.3	Scheduled charge-discharge. Miscellaneous maintenance.
6/3	6/3	1.8	Replace leaking front connector on tube 1585.
6/12	6/15	68.3	High pressure on tube 4167 due to a broken thermocouple well. Leak testing and miscellaneous maintenance.
6/25	6/29	112.8	Removal of an I&E natural metal rupture from tube 2272. Charge-discharge and miscellaneous maintenance.
6/30	6/30	1.2	Trip due to a loose spline cap on tube 3172.

H Reactor

6/1	6/1	.2	Panellit trip due to faulty gauge circuitry.
6/1	6/2	34.8	Beckman trip during recovery due to ultra-sensitive trip setting. Tube replacement.
6/7	6/9	45.7	Leak testing and tube replacement.
6/10	6/12	42.6	Leak testing and tube removal.
6/19	6/19	.3	Trip due to a faulty rear connector on tube 0682.
6/24	Still down		Scheduled tube replacement.

---

Extracted from Plum 1963, June 1962, pages 2-4.

KE Reactor

6/18	6/21	92.4	Scheduled charge-discharge.
6/21	6/21	1.3	Three Fanellit trips apparently due to metal charges washing down stream.
6/22	6/22	.9	Manual trip to correct leaking rear face cap.
6/22	6/22	.2	Beckman trip during range change.

KW Reactor

6/11	6/14	82.3	Scheduled charge-discharge.
------	------	------	-----------------------------

---

Extracted from Plum 1963, June 1962, pages 2-4.

URANIUM IN TONS  
1962

REACTORS				SEPARATIONS										
	Inventory	In Reactor	Discharged		Inventory	In Cooling	Dissolved							
	Charged	July Aug.	July Aug.		July Aug.	July Aug.	July Aug.							
Normal U	498	336	1,335	1,849	499	323	2,401	2,507	Normal U					
									Purex					
									Purex	784	222			

MWD AND SPECIAL MATERIALS														
REACTORS				SEPARATIONS										
	Charged or Produced	Inventory In Reactor	Discharged		Inventory	In Cooling	Dissolved							
	July August	July August	July August		July August	July August	July August							
MWD	<u>34,228</u>	<u>426,847</u>												
Normal	303,024	345,124	621,356	759,534	332,379	206,946	1,633,737	1,633,750						
94 Metal	76,204	81,723	163,378	181,037	68,027	69,064	623,361	553,727						

REACTORS				SEPARATIONS										
	Charged or Produced	Inventory In Reactor	Discharged		Inventory	In Cooling	Dissolved							
	July August	July August	July August		July August	July August	July August							
MWD	<u>34,228</u>	<u>426,847</u>												
Normal	303,024	345,124	621,356	759,534	332,379	206,946	1,633,737	1,633,750						
94 Metal	76,204	81,723	163,378	181,037	68,027	69,064	623,361	553,727						

Extracted from Travis 1962i, pages 2 and 4

	COMPARATIVE PILE PERFORMANCE							TOTAL
	B	C	D	E	F	G	H	
Maximum Power Level To Date, MW	1,310	2,310	1,275	1,925	1,235	1,355	1,100	20,110
Maximum Power Level During Month, MW	1,785	2,100	1,795	1,740	1,715	1,715	1,500	15,550
Average Power Level While Operating, MW	1,672	1,868	1,714	1,633	1,547	1,552	1,520	17,342
Maximum Tube Power, KW	1,139	1,225	1,123	1,128	1,157	1,057	1,561	1,273
Effective Central Tubes	1,520	1,660	1,495	1,490	1,500	1,550	2,335	2,095
Time Operated Efficiency, %	76.0	69.7	80.0	73.3	65.1	57.2	73.3	73.3
Operational Limitation	93.50C	93.50C	93.50C	93.50C	93.50C	95.00C	95.00C	95.00C
WMD Produced During Month, total	39,413	40,229	41,606	37,031	40,279	43,186	41,324	41,228
Normal	33,187	30,905	40,703	27,340	36,946	39,520	30,107	30,024
% Metal	6,256	10,094	3,398	9,714	5,333	13,666	12,217	12,396
Plutonium Produced, grams	32,568	33,660	38,316	30,125	33,392	34,601	37,834	37,743
Uranium In Reactor At Month End, tons	225.2	221.4	228.8	218.6	226.4	204.1	432.1	2189.5
Normal	196.7	181.5	216.0	172.7	201.7	130.6	268.9	1354.9
% Metal	28.5	39.9	12.9	45.9	24.7	73.5	63.1	55.2
Uranium Discharged During Month, tons	73.4	47.9	61.3	87.1	1.2	32.6	120.4	504.9
Normal	69.0	38.3	57.8	74.4	0.5	15.3	108.7	138.7
% Metal	4.1	9.6	3.5	12.7	0.7	17.3	11.7	36.2
Average Discharge Concentration	570	673	917	622	500	657	637	661
Normal	836	791	960	896	567	704	745	789

1 All reactors were limited by bulk outlet water temperature.  
 Extracted from Travis 1962h, page 21.

REFACTOR OUTAGES JUL 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
7/8	7/13	126.7	Scheduled charge-discharge and maintenance.
7/13	7/13	.7	Unexplained high pressure Panellit trip on tube 2561.
7/14	7/15	23.3	Repair of front nozzle pigtal adapter leak on tube 1794.
7/23	7/24	27.4	Removal of an I&E-E metal rupture from tube 4078.
7/24	7/24	.5	Beckman trip due to operational error.
<u>C Reactor</u>			
7/2	7/4	48.7	Leak testing.
7/4	7/4	.7	Tightening of rear caps on overbore tubes.
7/8	7/10	62.0	Tripped when #1 HCR cooling water hose came loose from a connector. Charge-discharge and maintenance.
7/11	7/13	33.5	Manually tripped when No. 1 HCR cooling water hose came loose from connector. Miscellaneous maintenance.
7/19	7/20	44.0	Removal of an I&E-E metal rupture from tube 1692. Miscellaneous maintenance.
7/27	7/29	36.3	Removal of an I&E-E metal rupture from tube 3962.
7/29	7/29	.3	Panellit trip while removing a spline stub from tube 2776.

Extracted from Plum 1963, July 1962, pages 3-6.

D Reactor

7/10	7/13	74.1	Tripped by a heavy power surge on the BPA system when a transformer faulted on the Priest Rapids #1 Line at Midway. Charge-discharge, maintenance, and tube replacement.
7/13	7/15	37.7	Leak testing and tube replacement.
7/31	Still down		Water leak.

DR Reactor

7/5	7/6	35.1	Panellit trip due to the failure of a rear pigtail adaptor on tube 2086. Charge-discharge.
7/10	7/11	35.1	Tripped by a heavy power surge on the BPA system when a transformer faulted on the Priest Rapids #1 Line at Midway. Miscellaneous maintenance.
7/16	7/20	93.1	Partially engaged front cap on tube 1703. Charge-discharge and miscellaneous maintenance.
7/20	7/20	.2	Unexplained Panellit trip.
7/23	7/24	33.9	Panellit trip due to non-seated charge in tube 3982. Miscellaneous maintenance.
7/24	7/24	1.5	Repair a flange leak on tube 3293.

F Reactor

7/1	7/2	33.6	Removal of an I&E-E metal rupture from tube 3958.
7/5	7/6	39.2	Panellit trip due to a broken rear pigtail on tube 3684. Miscellaneous maintenance and leak testing.
7/7	7/7	11.8	Removal of an I&E-E metal rupture from tube 2059.
7/10	7/11	34.1	Tripped by a heavy power surge on the BPA system. Retubed five air channels; decontamination and leak testing.
7/23	7/24	37.2	High pressure Panellit trip on tube 3371. Miscellaneous maintenance.

Extracted from Plum 1963, July 1962, pages 3-6.

II Reactor

6/24	7/4	317.8	Scheduled tube replacement.
7/10	7/11	37.9	Trip by a heavy power surge on the BPA system. Miscellaneous maintenance.

KE Reactor

7/10	7/12	51.5	Tripped by a heavy power surge on the BPA system. Charge-discharge.
7/16	7/22	167.3	Scheduled project work CG-844 and miscellaneous maintenance.
7/23	7/23	1.1	Tripped when VSR #70 dropped due to a faulty holding coil on the solenoid seal.
7/23	7/24	23.5	Flushing of high-pressure cross tie system piping through V-71 and V-74 valves.
7/28	7/29	31.9	Unexplained Panellit trip.
7/29	7/29	.4	Panellit trip due to an oscillating gauge.
<u>KW Reactor</u>			
7/1	7/4	72.9	Scheduled charge-discharge.
7/6	7/8	34.7	Unexplained Panellit trip. Replaced two sections of VSR #43.
7/8	7/8	2.6	Install one additional section of VSR #43.
7/10	7/11	42.6	Tripped by heavy power surge on the BPA system. Rear-face decontamination and maintenance.
7/16	7/21	134.7	Scheduled project work CG-844
7/23	7/24	31.8	Panellit trip due to a faulty jumper on gauge 4462. Miscellaneous maintenance.

COMPARATIVE PALE PERFORMANCE											
		AUG 1962		DR		F		H		KE	
B		C		D		E		F		G	
Maximum Power Level To Date, MW	1,910	2,110	1,975	1,925	1,935	1,955	1,950	1,950	1,950	20,710	
Maximum Power Level During Month, MW	1,715	2,050	1,725	1,690	1,735	1,650	1,685	1,685	1,685	1,720	
Average Power Level While Operating, MW	1,573	1,765	1,616	1,654	1,656	1,573	1,607	1,607	1,607	17,207	
Maximum Tube Power, KW	1,317	1,230	1,182	1,127	1,133	1,101	1,119	1,119	1,119	1,520	
Effective Central Tubes	1,520	1,640	1,500	1,490	1,500	1,490	2,495	2,495	2,495	2,495	
Tube Operated Efficiency, %	80.3	75.5	91.6	65.7	75.9	65.1	93.5	93.5	93.5	73.9	
Operational Limitation, %	93.5	95.0	93.5	93.5	93.5	93.5	95.0	95.0	95.0	95.0	
WD Produced During Month, total	61,656	15,307	38,502	16,953	33,725	37,012	105,745	107,742	107,742	426,747	
Normal	34,913	11,519	34,867	34,659	29,368	25,872	87,025	86,301	86,301	345,124	
94 Metal	6,713	3,788	3,635	12,299	4,357	11,210	18,720	21,311	21,311	81,723	
Plutonium Produced, grams	34,300*	12,295*	30,655*	37,927*	27,163*	28,029	89,304	91,317*	91,317*	351,719*	
Uranium In Reactor At Month End, tons	224.2	223.9	227.1	217.9	226.4	202.0	432.5	431.4	431.4	2185.4	
Normal	196.3	183.9	213.3	174.6	201.9	131.8	374.6	371.5	371.5	1847.9	
94 Metal	27.9	40.0	13.8	43.3	24.5	70.2	57.9	59.9	59.9	337.5	
Uranium Discharged During Month, tons	54.6	64.7	55.2	25.5	52.7	11.6	10.5	129.7	129.7	104.5	
Normal	45.1	49.7	50.2	16.9	50.1	3.2	0.3	107.8	107.8	323.3	
94 Metal	9.5	15.0	5.0	8.6	2.6	8.4	10.2	21.9	21.9	81.2	
Average Discharge Concentration											
Normal	620	483	847	723	608	646	367	625	640	640	
94 Metal	1,051	708	936	930	927	928	636	872	872	872	

1 All reactors were limited by bulk outlet water temperature.

\* Corrected figure.

Extracted from Travis 1962i, page 21 (Rev.).

REACTOR OUTAGES AUG 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
8/7	8/10	80.4	Scheduled charge-discharge and maintenance.
8/13	8/15	29.7	Removal of an I&E natural metal rupture from tube 3868.
8/22	8/24	36.2	Removal of an I&E E-metal rupture from tube 0989.
<u>C Reactor</u>			
8/1	8/3	40.2	Trip caused by a burned out transformer for the instrument air compressor. Miscellaneous maintenance.
8/3	8/3	2.1	Change Venturis on two tubes.
8/9	8/28	454.4	Scheduled replacement of 302 tubes.
8/29	8/29	3.1	Manual trip due to loss of cooling water to HCR No. 14.
8/29	8/30	36.1	Removal of an overbore-size I&E natural metal rupture from tube 3162.

---

Extracted from Plum 1963, August 1962, pages 2-4.

D Reactor

7/31	8/2	54.3	Leak testing and charge-discharge. Corrected 68 rear-face gas leaks.
8/5	8/6	38.0	Repair of a weld leak at a crossheader nipple for the pigtail.
8/11	8/13	42.0	Tripped due to a short in the brake coil on No. 7 HCR. Miscellaneous maintenance.
8/13	8/13	0.4	Additional rod comparison tests authorized by PT-IP-447C.
8/27	8/28	43.4	Removal of an I&E natural metal rupture from tube 2583. Leak testing and tube replacement.

DR Reactor

8/17	8/18	26.5	Removal of an I&E E-metal rupture from tube 1285.
8/19	8/20	23.5	Unexplained Panellit trip.
8/20	8/20	0.5	Tripped due to a defective spline cap seal.

F Reactor

8/6	8/7	38.8	Scheduled charge-discharge.
8/7	8/7	3.6	Repair two broken sample lines in near riser room.
8/9	8/10	33.0	Leak testing. Removed and replaced ball valve tube 3665 due to rear Van Stone leak.
8/10	8/10	1.5	Manual trip when the PCCF machine came loose from the ball valve while charging poison.
8/24	Still down		Tube replacement.

---

Extracted from Plum 1963, August 1962, pages 2-4.

II Reactor

8/1	8/4	73.9	Leak testing and charge-discharge.
8/7	8/8	35.3	Leak testing.
8/15	8/17	33.8	Removal of an I&E E-metal rupture from tube 0359.
8/27	8/28	36.2	Leak testing.

KE Reactor

8/3	8/5	39.0	Tripped due to a high-pressure surge while testing the backup coolant system. Miscellaneous maintenance and charge-discharge.
8/29	Still down		Scheduled charge-discharge.

KW Reactor

8/24	8/27	85.5	Loss of #2 emergency generator when the main exciter failed. Charge-discharge and miscellaneous maintenance.
------	------	------	--

URANIUM IN TONS  
1962

	REACTORS				SEPARATIONS			
	Charged	Inventory In Reactor	Discharged	Inventory In Cooling	Sep. Cct.	Sep. Cct.	Dissolved	Sep. Cct.
	Sep. Cct.	Sep. Cct.	Sep. Cct.	Sep. Cct.				
Normal U	611 555	1,843 1,355	615 562	2,648 2,506	Normal U			
Scrap			Purex		Purex		552 707	
<u>94 Metal</u>	104 106	339 348	103 96	704 694	<u>94 Metal</u>			
					Redox		113 109	

MWD AND SPECIAL MATERIALS  
1962

MWD	Sep. Cct.	REACTORS				SEPARATIONS			
		Charged or Produced	Inventory In Reactor	Discharged	Sep. Cct.	Inventory In Cooling	Sep. Cct.	Dissolved	Sep. Cct.
		Sep. Cct.	Sep. Cct.	Sep. Cct.	Sep. Cct.	Sep. Cct.	Sep. Cct.	Sep. Cct.	Sep. Cct.
391,332	393,857								
Normal	320,048	319,991	675,000	620,071	404,582	374,920	1,621,464	391,553	452,259
94 Metal	71,884	73,866	166,053	153,602	86,363	86,317	592,708	593,455	87,719

Extracted from Travis 1962k, pages 2 and 4.

COMPARATIVE PILE PERFORMANCE						
		1962				
		B	C	D	SEP	TOTAL
Maximum Power Level To Date, MW	1,940	2,310	1,975	1,935	1,255	1,440
Maximum Power Level During Month, MW	1,740	2,045	1,695	1,755	1,610	1,825
Average Power Level While Operating, MW	1,612	1,928	1,569	1,587	1,715	1,562
Maximum Tube Power, KW	1,127	1,240	1,158	1,121	1,153	1,103
Effective Central Tubes	1,525	1,625	1,550	1,470	1,495	1,670
Time Operated Efficiency, %	81.1	71.7	23.8	75.2	47.7	63.7
Operational Limitation <sup>1</sup>	93.5	95.0	93.5	95.0	93.5	95.0
W.D. Produced During Month, total	39,952	41,482	11,206	35,819	47,701	22,266
Normal	33,524	31,395	9,981	27,213	41,757	15,782
9u Metal	6,428	10,087	1,225	8,606	5,944	6,464
Plutonium Produced, grams	32,341	36,002	9,322	27,861	39,314	16,085
Uranium In Reactor At Month End, tons	223.6	224.2	226.4	219.0	226.0	201.5
Normal	195.8	185.0	208.8	179.4	202.0	131.3
9u Metal	27.8	39.2	17.6	39.6	21.0	70.2
Uranium Discharged During Month, tons	43.0	79.2	50.1	31.9	64.4	0.5
Normal	37.4	69.1	44.5	20.6	57.4	0.5
9u Metal	5.6	10.1	5.6	11.3	7.0	0
Average Discharge Concentration						
Normal	54.5	61.8	58.5	74.6	561	699
9u Metal	94.1	78.3	65.1	87.0	860	812

<sup>1</sup> All reactors were limited by bulk outlet water temperature.  
Extracted from Travis 1962j, page 21.

REACTOR OUTAGES      SEP 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
9/5	9/7	47.6	Removal of an I&E natural metal rupture from tube 1175 and leak testing.
9/8	9/10	40.9	Removal of an I&E natural metal rupture from tube 2068.
9/11	9/11	.3	Unexplained Panellit trip.
9/17	9/17	.2	Tripped when a VSR switch was accidentally bumped.
9/29	Still down		Removal of an I&E E-metal rupture from tube 3768. Charge-discharge.
<u>C Reactor</u>			
9/3	9/5	60.3	Removal of an overbore size I&E natural metal rupture from tube 1191. Leak testing.
9/5	9/5	1.6	Installed shield bayonet in channel 0572.
9/6	9/7	32.7	Removal of an overbore size I&E natural metal rupture from tube 2969.
9/23	9/28	108.6	Removal of an I&E natural metal production test (IP-490A) rupture from tube 3680. Charge-discharge and miscellaneous maintenance.
9/28	9/28	.5	Unexplained Panellit trip.

---

Extracted from Plum 1963, September 1962, pages 2-4.

D Reactor

8/31	9/18	424.9	Water leak. Scheduled tube replacement: 317 tubes replaced.
9/23	9/24	31.3	Leak testing.
9/25	9/27	52.2	Leak testing.
9/29	Still down		Water leak.

DR Reactor

9/10	9/12	35.2	Tripped when an injection fitting came loose from a nozzle while injecting test material (IP-471-AE) for the control of a water leak. Leak testing and tube replacement.
9/16	9/17	34.6	Removal of an I&E E-metal rupture from tube 2989.
9/22	9/23	37.3	Water leak.
9/25	9/26	36.6	Water leak.
9/28	9/30	34.9	Removal of an I&E metal rupture from tube 3086 and miscellaneous maintenance.

F Reactor

8/24	9/3	230.8	Tube replacement (185 tubes).
------	-----	-------	-------------------------------

---

Extracted from Plum 1963, September 1962, pages 2-4.

KE Reactor

8/29	9/1	85.6	Scheduled charge-discharge.
9/6	9/8	33.9	Charge-discharge following a trip due to the failure of #3 transformer.
9/25	9/28	74.9	Scheduled charge-discharge.
9/28	9/28	.3	Unexplained low pressure Panellit trip.
9/28	9/28	.9	Unexplained low pressure Panellit trip.
9/28	9/28	.7	Tripped when VSR #22 dropped due to a defective latch.
9/28	9/29	.7	Tripped when VSR #22 dropped. Rod was tied out of service.

KW Reactor

9/3	9/4	35.8	Panellit trip when a spline cap insert flushed downstream.
9/17	9/20	79.9	Scheduled charge-discharge.
9/20	9/20	1.2	Unexplained Panellit trip while adjusting gauges for six pumps.
9/20	9/20	.4	Panellit trip due to bypassing the wrong gauge while making adjustments for six pumps.

H Reactor

9/6	9/7	30.6	Miscellaneous maintenance following a Panellit trip.
9/10	9/11	34.1	Leak testing.
9/11	9/11	1.4	Repair fitting leaks on five front-face pigtails.
9/13	9/14	33.4	Removal of an I&E natural metal rupture from tube 2890.
9/19	Still down		Tripped due to the failure of a spline cap seal while removing a spline. Tube replacement is in progress.

---

Extracted from Plum 1963, September 1962, pages 2-4.

COMPARATIVE PILE PERFORMANCE						
		OCT 1962				
B	C	D	DR	F	H	KW
Maximum Power Level To Date, MW	1,910	2,310	1,975	1,925	1,935	1,955
Maximum Power Level During Month, MW	1,820	2,125	1,770	1,720	1,805	1,685
Average Power Level While Operating, MW	1,686	1,878	1,626	1,472	1,713	1,612
Maximum Tube Power, KW	1,188	1,300	1,186	*	1,203	1,152
Effective Central Tubes	1,515	1,630	1,575	*	1,485	1,485
Time Operated Efficiency, %	67.4	68.2	67.8	41.1	74.8	51.9
Operational Limitation	93.50**	95.00**	93.50**	95.00**	93.50**	95.00**
MWD Produced During Month, total	35,242	39,691	34,158	18,745	39,728	25,923
Normal	29,814	30,063	30,224	14,532	34,691	16,967
9h Metal	5,428	9,628	3,924	4,213	5,037	8,926
Plutonium Produced, grams	28,805	32,068	27,754	15,112	32,904	22,269
Uranium In Reactor At Month End, tons	222.8	223.4	226.4	219.5	225.7	205.0
Normal	196.6	188.4	208.8	177.3	201.4	127.7
9h Metal	26.2	39.0	17.6	42.2	24.3	77.3
Uranium Discharged During Month, tons	67.5	15.8	42.2	110.8	82.8	164.3
Normal	58.7	11.2	41.3	98.2	73.8	131.1
9h Metal	8.8	4.6	0.9	16.6	9.0	33.2
Average Discharge Concentration						
Normal	614	659	810	604	661	707
9h Metal	930	766	688	801	982	930

\* Reactor not at equilibrium long enough to calculate meaning full data.  
 \*\* Bulk outlet water temperature limit.  
 \*\*\* Graphite temperature limit.  
 # New record.

Extracted from Travis 1962k, page 19.

REACTOR OUTAGES - OCT 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
9/29	10/1	60.2	Removal of an I&E E-metal rupture from tube 3768 (reported last month).
10/10	10/11	29.0	Removal of an I&E E-metal rupture from tube 3063.
10/12	10/12	0.6	Tripped while flushing a ball valve tube.
10/17	10/19	43.0	Leak testing and tube removal.
10/24	10/25	29.1	Panellit trip due to leak in tube 1686; tube removed.
10/26	Still down		Scheduled tube replacement.
<u>C Reactor</u>			
10/5	10/7	35.5	Removal of an I&E E-metal rupture from tube 2970.
10/8	10/10	39.1	Leak testing and tube removal.
10/13	10/14	40.3	Removal of an I&E E-metal rupture from tube 2879.
10/18	10/20	28.6	Removal of an I&E natural metal rupture from tube 3677. Charge-discharge.
10/20	10/20	1.4	Three unexplained Panellit trips.
10/20	10/21	10.5	Removal of an I&E E-metal rupture from tube 3857.
10/21	10/21	2.1	Removal of an I&E E-metal rupture from tube 3856. (Rupture not confirmed)
10/27	10/29	79.3	Removal of an I&E natural metal rupture from tube 3959.

---

Extracted from Plum 1963, October 1962, pages 2-5.

D Reactor

9/29	10/1	55.5	Leak testing and tube replacement.
10/2	10/2	0.5	Repair faulty ball valve.
10/4	10/6	57.0	Leak testing.
10/7	10/7	0.1	Tripped due to a faulty spline cap seal.
10/15	10/17	40.6	Removal of an I&E natural metal rupture from tube 2166. Leak testing and tube replacement.
10/19	10/21	38.5	Removal of an I&E natural metal rupture from tube 3284. Charge-discharge and leak testing.
10/22	10/23	34.5	Tripped when the No. 9 HCR brake solenoid failed. Charge-discharge and miscellaneous maintenance.
10/23	10/23	0.4	Unexplained Panellit trip.
10/27	10/29	70.2	Removal of an I&E natural metal rupture from tube 3180. Charge-discharge, leak testing and tube replacement.
10/29	10/29	0.8	Tripped by the power failure relay when No. 1 motor lost synchronization.
10/29	10/30	8.2	Tripped by the power failure relay.
10/30	10/30	0.6	Unexplained Panellit trip.

---

Extracted from Plum 1963, October 1962, pages 2-5.

DR Reactor

10/2	10/4	38.4	Removal of an I&E E-metal rupture from tube 3885.
10/4	10/4	2.3	Unexplained Panellit trip.
10/7	10/9	39.2	Removal of an I&E E-metal rupture from tube 3967.
10/12	10/24	293.7	Scheduled tube replacement and charge-discharge; 166 tubes replaced.
10/24	10/24	0.5	Unexplained Panellit trip.
10/26	10/26	0.2	Unexplained Panellit trip.
10/26	10/27	30.4	Manual trip due to temperature and pressure variation on tube 2663.
10/29	10/30	39.2	Leak testing and tube replacement.

F Reactor

10/1	10/4	88.5	Scheduled charge-discharge, tube replacement and miscellaneous maintenance.
10/8	10/9	34.4	Correction of a rear-face water leak.
10/24	10/25	38.0	Removal of an I&E natural metal rupture from tube 1677.
10/30	Still down		Water leak.

H Reactor

9/19	10/14	593.5	Replacement of 51 $\frac{1}{4}$ tubes.
10/26	10/27	38.6	Leak testing.

---

Extracted from Plum 1963, October 1962, pages 2-5.

1000 kWe Reactor

10/30 Still down      Tripped by a momentary loss of flow on a KER single pass tube while switching water supply. Charge-discharge and miscellaneous maintenance.

1000 kW Reactor

10/12 10/13 44.5      Removal of an I&E E-metal rupture from tube 2260.

10/14 10/14 1.7      Unexplained Panellit trip.

10/19 10/29 244.7      Replacement of 99 tubes.

10/29 10/29 0.6      Unexplained Panellit trip.

---

Extracted from Plum 1963, October 1962, pages 2-5.

URANIUM IN TONS  
1962

	<u>REACTORS</u>				<u>SEPARATIONS</u>			
	Charged		Inventory	Discharged	Inventory		Dissolved	
	Nov. Dec.	In Reactor	In Reactor	Nov. Dec.	Nov. Dec.	In Cooling	Nov. Dec.	In Cooling
Normal U	402	429	1,243	1,329	369	426	2,157 <sup>1</sup>	1,841
							Normal U	
							24 Metal	
							754	713
<u>94 Metal</u>	80	90	338	335	90	93	728	771
							94 Metal	
							56	47

MWD AND SPECIAL MATERIALS  
1962

	<u>REACTORS</u>				<u>REACTORS</u>			
	Charged or Produced		Inventory In Reactor	Discharged	Inventory In Cooling	Discharged	Inventory In Cooling	Dissolved
	Nov.	Dec.	Nov.	Dec.	Nov.	Dec.	Nov.	Dec.
<u>MWD</u>	<u>386.415</u>	<u>440.022</u>						
Normal	310,727	352,322	665,730	732,370	265,063	292,622	1,230,104	1,276,713
94 Metal	75,639	80,207	155,595	159,573	73,696	76,229	620,515	656,252

Extracted from Travis 1963a, pages 2 and 4.

	COMPARATIVE FILE PERFORMANCE						TOTAL
	NOV		1962		JAN		
B	C	D	DR	F	H	E	K
Maximum Power Level To Date, MW	1,210	2,310	1,375	1,925	1,935	1,100	20,710
Maximum Power Level During Month, MW	1,320	2,155	1,850	1,320	1,780	1,400	20,570
Average Power Level While Operating, MW	1,609	2,003	1,721	1,726	1,695	1,367	18,610
Maximum Tube Power, KW	1,263	1,100	1,205	1,151	1,599	1,151	1,759
Effective Central Tubes	1,140	1,620	1,470	1,520	1,500	1,535	2,000
Tube Operated Efficiency, %	12.1	73.2	72.1	81.7	76.2	71.5	67.4
Operational Limitation	93.5C	95.0C	93.5C	95.0C	93.5C	93.5C	94.0C
WID Produced During Month, total	20,330	44,438	37,238	43,881	38,750	37,911	48,189
Normal	17,175	34,062	33,127	33,119	33,266	25,100	40,707
9L Metal	3,155	10,376	4,111	10,432	4,781	12,811	7,482
Plutonium Produced, grams	17,126	36,110	30,722	36,326	31,885	30,311	41,512
Uranium In Reactor At Month End, tons	225.0	222.8	228.2	220.2	225.1	204.5	430.4
Normal	198.0	184.3	213.2	180.7	202.0	127.9	371.3
9L Metal	27.0	38.5	15.0	39.5	33.4	76.7	55.6
Uranium Discharged During Month, tons	78.0	24.9	37.6	27.2	90.7	10.6	199.4
Normal	71.3	10.8	32.8	16.7	84.2	0.1	171.6
9L Metal	6.7	14.1	4.9	10.5	5.8	10.5	27.8
Average Discharge Concentration	602	619	694	803	637	370	728
Normal	691	732	695	816	794	920	883
9L Metal							790

<sup>1</sup> All reactors were limited by bulk outlet water temperature except KE and KJ.

Extracted from Travis 19621, page 19.

REACTOR OUTAGES - NOV 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
10/26	11/14	447.3	Replacement of 417 tubes.
11/14	11/14	3.7	Thermocouple repair.
11/20	11/21	28.6	Water leak. Tube replacement.
11/21	11/21	4.4	Correct front pigtail leak.
11/26	11/28	47.4	Leak testing.
11/28	11/29	12.9	Panellit trip due to a faulty rear pigtail on tube 1272.
<u>C Reactor</u>			
11/4	11/5	39.2	Removal of an I&E E-metal rupture from tube 1888. Charge-discharge.
11/6	11/6	0.8	Panellit trip.
11/6	11/6	1.5	Replaced the rear nozzle adapter on tube 3966 which was causing a rear-face leak.
11/14	11/17	96.0	Removal of an I&E natural metal rupture from tube 1282.
11/26	11/27	34.2	Removal of an I&E E-metal rupture from tube 1458. Tube removed and channel blanked.
11/29	Still down		Scheduled tube replacement.

---

Extracted from Plum 1963, November 1962, pages 2-4.

D Reactor

11/2	11/3	35.0	Removal of an I&E natural metal rupture from tube 3266.
11/9	11/11	39.8	Leak testing and tube replacement.
11/11	11/11	0.6	Manual trip due to a short in "A" hole which gave a false period.
11/12	11/14	47.0	Water leak. Leak testing.
11/19	11/21	49.9	Water leak. Leak testing.
11/27	11/28	37.4	Removal of an I&E natural metal rupture from tube 2777. Leak testing and charge-discharge.

DR Reactor

11/13	11/15	36.0	Removal of an I&E E-metal rupture from tube 1675.
11/15	11/15	1.9	Correct front cap leak on tube 2565.
11/17	11/18	34.5	Panellit trip.
11/28	11/30	36.5	Panellit trip due to a faulty sensing line on 1164.
11/30	11/30	0.3	Tripped when wrong toggle valve was opened while checking gauge response time.

F Reactor

10/30	11/1	39.0	Leak testing.
11/3	11/5	49.7	Removal of an I&E E-metal rupture from tube 4167.
11/14	11/16	41.1	Removal of an I&E natural metal rupture from tube 1364.
11/22	11/25	66.3	Removal of an I&E natural metal rupture from tube 3867. Charge-discharge.
11/25	11/25	1.7	Repair broken sample line on crossheader 9½.

---

Extracted from Plum 1963, November 1962, pages 2-4.

II Reactor

11/17	11/19	38.7	Water leak. Leak testing.
11/21	11/21	0.3	Tripped due to a rear pigtail failure.
11/25	Still down		Scheduled tube replacement.

KE Reactor

10/30	11/2	70.1	Concluded charge-discharge and maintenance following a trip.
11/9	11/23	367.4	Scheduled tube replacement.
11/27	11/29	38.9	Investigate high temperature on tube 0570.
11/29	11/29	0.3	Replace a front leaking pigtail on tube 0958.
11/29	11/29	0.8	Low pressure trip on single pass tube 4456 while making a flow adjustment.
11/30	11/30	0.5	Tripped by loop 4 while making manual adjustments.
11/30	Still down		Manual trip for temperature control.

KW Reactor

11/11	11/13	37.1	Removal of an I&E natural metal rupture from tube 3648.
11/14	11/16	36.8	Investigation of partial flow restriction in bottom thermal shield coolant piping.

---

Extracted from Plum 1963, November 1962, pages 2-4.

COMPARATIVE PULF PERFORMANCE						TOTAL
B	C	D	E	F	G	
Maximum Power Level To Date, MW	2,310	1,975	1,925	1,935	1,935	20,910
Maximum Power Level During Month, MW	2,060	1,885	1,725	1,810	1,780	19,810
Average Power Level While Operating, MW	1,727	1,780	1,791	1,676	1,763	18,957
Maximum Tube Power, kW	1,185	1,270	1,244	1,139	1,183	1,731
Effective Central Tubes	1,155	1,615	1,510	1,500	1,450	2,502
Time Operated Efficiency, %	85.3	10.6	76.1	92.8	86.6	81.2
Operational Limitation	108°C	105°C	93.582	108°C	105°C	100.3
MWD Produced During Month, total	5,821	12,214	18,220	47,327	40,275	108,129
Normal	39,039	4,448	38,364	37,456	41,621	87,079
9t Metal	6,554	1,373	3,880	10,764	5,706	21,633
Plutonium Produced, grams	37,851	5,075	34,366	37,987	38,579	86,678
Uranium In Reactor At Month End, tons	223.4	223.3	227.8	219.7	221.9	226.5
Normal	198.9	181.8	215.0	180.2	201.5	199.0
9t Metal	24.5	36.5	12.8	39.5	23.4	45.5
Uranium Discharged During Month, tons	111.9	81.7	43.5	0	1.7	21.9
Normal	37.1	67.6	35.6	0	0	3.8
9t Metal	7.8	11.1	7.9	0	1.7	26.1
Average Discharge Concentration						
Normal	615	621	750	-	885	392
9t Metal	960	730	781	-	792	720

1 Tube corrosion.  
2 Bulk outlet.  
3 Administrative.

Extracted from Travis 1963a, page 28.

REACTOR OUTAGES      DEC 1962

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
12/13	12/16	74.5	Removal of an I&E natural metal rupture from tube 3465. Charge-discharge.
12/23	12/25	35.0	Leak testing. Tube 1077 was removed due to an internal leak. An I&E natural metal rupture was removed from tube 3162.
<u>C Reactor</u>			
11/29	12/28	680.6	Replacement of 251 tubes and maintenance work.
12/28	12/28	11.0	Thermocouple repairs.
<u>D Reactor</u>			
12/7	12/9	47.2	Removal of an I&E E-metal rupture from tube 1478. Charge-discharge.
12/14	12/15	39.2	Water leaks. Replacement of tubes 2169 and 0673.
12/15	12/15	0.5	Unexplained Panellit trip.
12/22	12/23	38.8	Removal of I&E natural metal ruptures from tubes 1064 and 3265.
12/27	12/29	28.2	Removal of an I&E natural metal rupture from tube 1077.
<u>DR Reactor</u>			
12/24	12/24	0.3	Panellit trip when a stub ejected from a spline cap.
12/29	Still down		Scheduled charge-discharge.

---

Extracted from Plum 1963, December 1962, pages 2-4.

F Reactor

12/7	12/10	72.6	Removal of an I&E E-metal rupture from tube 0674 and charge-discharge.
12/30	Still down		Removal of an I&E E-metal rupture from tube 0658 and charge-discharge.

H Reactor

11/25	12/2	171.2	Replacement of 156 tubes.
12/2	12/2	4.3	Correction of a loose rear-face cap.
12/6	12/6	0.3	Correction of a partially engaged front-face cap.
12/6	12/7	29.3	Tripped by low pressure on Loop 1 caused by the unexplained loss of power. Maintenance.
12/8	12/8	0.2	Manual trip due to malfunction of rate of rise instrumentation.
12/18	12/19	39.4	Unexplained Panellit trip.
12/22	12/23	30.9	Panellit trip due to a small piece of gasket-like material on the orifice cross wire. Charge-discharge and leak testing.
12/27	12/27	0.1	Panellit trip due to faulty rear pigtal fitting on tube 1864.
12/31	Still down		Water leak.

KE Reactor

11/30	12/1	31.5	Manual trip for temperature control.
12/2	12/2	3.7	Repair leaking flapper cap.
12/2	12/2	0.4	Tripped while making flow adjustment on single pass tube 4355.
12/2	12/2	2.9	Insufficient control rod for turn around.
12/12	12/14	50.5	Inspection of a damaged front-face connector. Charge-discharge.
12/15	12/15	2.2	Unexplained Panellit trip.
12/26	12/30	72.1	Scheduled charge-discharge.
12/30	12/30	1.1	Tripped by Loop 2 due to failure to bypass the No. 1 safety circuit during functional checks.

KW Reactor

12/3	12/6	89.7	Scheduled charge-discharge and maintenance.
12/10	12/12	50.5	Panellit trip caused by leaking Bourdon tube. Miscellaneous maintenance.

---

Extracted from Plum 1963, December 1962, pages 2-4.

APPENDIX D

OPERATING DATA FOR 1963

<u>REACTORS</u> <u>1963</u>										
<u>Charged</u>		<u>Produced</u>		<u>Inventory in Reactor</u>		<u>Discharged</u>		<u>Inventory in Basins</u>		
	Jan.	Feb.	Jan.	Feb.	Jan.	Feb.	Jan.	Feb.	Jan.	Feb.
<u>Normal U</u> (tons)	368	532			1,732	1,721	504	514	2,351	2,399
M&D			357,793	262,397	762,333	652,613	328,330	372,117	1,610,452	1,615,265
Pu (kg)			305	224	671	575	281	320	1,380	1,289
<u>Cl. Metal</u> (tons)	210	74			440	450	105	64	657	642
M&D			78,258	100,726	115,687	194,817	92,114	51,566	564,177	552,682
Pu (kg)			57	74	109	115	67	38	107	399
<u>SEPARATIONS</u> <u>1963</u>										
		<u>PUREX AND REDOX</u>		<u>Dissolved</u>						
<u>Normal U</u> (tons)				0	510					
M&D					0	375,959				
Pu (kg)				0	318.9					
<u>91 Metal</u> (tons)				219	78					
M&D				164,315	63,569					
Pu (kg)				133.4	17.1					

COMPARATIVE PILE PERFORMANCE						
B	C	D	E	F	G	TOTAL
JAN 1963						
Maximum Power Level To Date, MW	1,610	2,310	1,975	1,935	1,955	1,400
Maximum Power Level During Month, MW	1,350	2,205	1,845	1,725	1,755	1,100
Maximum Power Level While Operating, MW	1,341	2,021	1,780	1,566	1,726	1,180
Average Power Level, KW	1,239	1,279	1,172	1,137	1,260	1,082
Maximum Tube Power, KW	1,525	1,550	1,515	1,485	1,665	1,261
Effective Central Tubes	70.2	82.0	79.1	81.0	80.6	75.0
Time Operated Efficiency, %	103°C	105°C	93.5°C	108°C	109°C	82.7
Operational Limitation						62.7
						4,140 <sup>3</sup>
MWD Produced During Month, total	40,055	51,380	44,080	41,322	27,050	12,927
						110,911
Normal $^{94}\text{Pu}$ Metal	34,713	39,549	40,513	33,386	23,311	7,674
	5,312	11,831	3,567	7,936	3,739	5,253
Plutonium Produced, grams	32,494	41,901	35,028	32,425	22,613	9,699
Uranium In Reactor At Month End, tons	222.8	223.6	227.8	219.2	223.6	194.9
Normal $^{94}\text{Pu}$ Metal	198.9	185.6	215.2	181.6	197.2	13.5
	23.9	38.0	12.6	35.6	26.4	191.4
Uranium Discharged During Month, tons	26.9	24.4	31.4	85.1	97.8	143.1
Normal $^{94}\text{Pu}$ Metal	24.5	20.4	26.7	67.3	86.7	128.7
	2.4	4.0	4.7	17.8	11.1	11.4
Average Discharge Concentration						
Normal $^{94}\text{Pu}$ Metal	618	593	743	667	586	585
	733	765	864	892	839	833

\* This reactor did not reach equilibrium during the month.

1 Tube corrosion.

2 Bulk outlet water temperature limit.

3 Administrative limit.

Extracted from Travis 1963b, page 29.

REACTOR OUTAGES JAN 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
1/1	1/2	41.5	Scheduled charge-discharge.
1/24	Still down		Tube replacement.
<u>C Reactor</u>			
1/2	1/4	46.7	Leak testing and miscellaneous maintenance.
1/6	1/6	0.3	Unexplained Panellit trip.
1/14	1/16	49.9	Leak testing and thermocouple well cap repairs.
1/19	1/21	37.2	Unexplained Panellit trip.
<u>D Reactor</u>			
1/2	1/4	39.7	Removal of an I&E natural metal rupture from tube 3786 and replacement of 4 process tubes.
1/17	1/20	81.4	Removal of an I&E natural metal rupture from tube 4075 and an I&E natural metal rupture from tube 1167. Charge-discharge.
1/21	1/22	31.4	Leak testing and replacement of tube 3273 due to a rear Van Stone leak.
1/23	1/23	1.2	Tripped from unknown cause.

---

Extracted from Plum 1964, January 1963, pages 2-4.

DR Reactor

12/29	1/1	53.2	Scheduled charge-discharge.
1/14	1/17	47.6	High temperature on tube 0969. An I&E E-metal rupture was removed from tube 1987. Charge-discharge and maintenance.
1/17	1/18	3.8	Unexplained Panellit trip on tube 1386.
1/18	1/18	1.0	Low pressure trip on tube 0963 during spline removal.
1/28	1/30	40.5	Removal of an I&E natural metal rupture from tube 1468.
1/30	1/30	1.1	Panellit trip while pulling a spline from tube 2679. The spline seal failed.
1/30	1/31	21.1	Removal of an I&E natural metal rupture from tube 2473.
1/31	1/31	0.7	Panellit trip due to a faulty spline cap.

F Reactor

12/30	1/1	27.2	Concluded rupture removal.
1/3	1/16	312.4	Replacement of 191 tubes.
1/16	1/16	6.3	Tripped due to a spline cap leak.
1/16	1/16	0.8	Tripped when VSR No. 25 dropped out of the upper limit switch.
1/29	1/31	38.5	Removal of an I&E natural metal rupture from tube 1362.

H. Reactor

12/31	1/1	20.2	Leak testing.
1/6	1/7	36.6	Removal of an I&E E-metal rupture from tube 1180. Leak testing.
1/9	1/10	30.8	Removal of an I&E natural metal rupture from tube 1975.
1/11	1/30	456.5	Replacement of 346 tubes.

Extracted from Plum 1964, January 1963, pages 2-4.

KE Reactor

1/7	1/8	36.3	Correction of a front pigtail leak.
1/11	1/12	36.5	Panellit trip due to a broken spline in tube 4946.
1/12	1/13	9.3	Panellit trip due to a broken front nozzle on tube 1162.
1/13	1/13	1.1	Unexplained Panellit trip on tube 4946.
1/26	1/27	36.1	Panellit trip on gauge 1875 due to a broken Bourdon tube.

KW Reactor

1/9	1/13	113.4	Scheduled charge-discharge and maintenance.
1/31	Still down		Unexplained Panellit trip on tube 3770. Charge-discharge.

COMPARATIVE PILE PERFORMANCE						
B	C	D	DR	F	H	KW
Maximum Power Level To Date, MW	2,310	2,005 <sup>1</sup>	1,225	1,935	1,955	1,400
Maximum Power Level During Month, MW	2,220	2,005 <sup>1</sup>	1,809	1,800	1,710	1,100
Average Power Level While Operating, MW	2,069	1,893	1,721	1,943	1,905	1,250
Maximum Tube Power, KW	1,256	1,310	1,297	1,196	1,238	1,949
Effective Central Tubes	1,512	1,655	1,530	1,507	1,520	2,380
Time Operated Efficiency, %	52.5	71.2	76.7	74.0	89.9	62.2
Operational Limitation	108°C <sup>2</sup>	105°C <sup>2</sup>	107°C <sup>3</sup>	106°C <sup>2</sup>	106°C <sup>3</sup>	100°C <sup>4</sup>
MMB Produced During Month, total	41,662	41,231	40,617	21,195	16,417	18,591
Normal 94 Metal	20,403	31,725	37,275	17,061	39,220	662
Plutonium Produced, grams	4,259	9,506	3,372	4,134	6,497	4,792
Uranium In Reactor At Month End, tons	20,652	33,933	31,778	16,247	37,239	35,890
Normal 94 Metal	223.4	222.9	226.3	219.2	223.9	194.9
Uranium Discharged During Month, tons	193.8	184.8	212.7	183.6	198.5	191.4
Normal 94 Metal	29.6	38.1	13.6	35.6	25.4	37.5
Average Discharge Concentration	99.3	77.9	55.6	0.1	60.5	0.2
Normal 94 Metal	90.1	62.6	52.6	52.6	51.6	11.3
	9.2	15.3	3.0	0.1	5.9	0.1

<sup>1</sup> New record.  
<sup>2</sup> Tube corrosion.  
<sup>3</sup> Bulk outlet water temperature limit.  
<sup>4</sup> Administrative limit.  
 Extracted from Travis 1963c, page 29.

REACTOR OUTAGES FEB 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
1/24	2/12	450.6	Replacement of 408 tubes.
2/20	2/22	48.9	Leak testing. Tube replacement.
<u>C Reactor</u>			
2/4	2/8	86.0	Scheduled charge-discharge. Tube replacement.
2/10	2/10	0.3	Panellit trip.
2/10	2/12	34.2	Removal of an I&E natural metal rupture from tube 3584. Tube replacement.
2/24	2/25	35.8	Removal of an I&E E-metal rupture from tube 4272.
2/27	2/28	57.1	Leak testing.
2/28	2/28	4.4	Repair thermocouple well leak on tube 4167.
<u>D Reactor</u>			
2/3	2/6	69.6	Removal of an I&E natural metal rupture from tube 2466. Charge-discharge and leak testing.
2/19	2/21	45.2	Removal of an I&E natural metal rupture from tube 0682. Miscellaneous maintenance.
2/26	2/28	41.8	Removal of I&E natural metal ruptures from tubes 2759 and 1374 (latter one not confirmed). Miscellaneous maintenance.

Extracted from Plum 1964, February 1963, pages 3-5.

DR Reactor

2/2 2/4 38.7 Removal of an I&E natural metal rupture from tube 1475 and an I&E E-metal rupture from tube 1362. Miscellaneous maintenance.

2/14 Still down Removal of an I&E natural rupture from tube 2079. Charge-discharge, flushing and decontamination in preparation for tube replacement. Tube replacement.

F Reactor

2/19 2/22 77.7 Scheduled charge-discharge.

H Reactor

2/9 2/10 25.0 Removal of an I&E E-metal rupture from tube 3457.

2/10 2/10 0.7 Trip due to electrical power fluctuation.

KE Reactor

2/2	2/3	37.7	Panellit trip due to a faulty spline cap seal on tube 4993.
2/6	2/7	38.0	Removal of an I&E E-metal rupture from tube 4065.
2/7	2/8	5.5	Manual trip due to insufficient control rods for turn around.
2/8	2/9	29.8	Trip due to VSR's dropping when a holding latch failed.
2/9	2/9	0.5	Panellit trip due to a faulty spline cap seal.
2/13	2/16	93.3	Tripped by loop 4 due to an instrument power failure caused by a loose terminal connection in the main instrument power disconnect box. Scheduled charge-discharge.
2/16	2/17	2.0	RTD repair on tube 2947.
2/17	2/17	2.0	Investigate high pressure on tube 0752.
2/20	2/22	47.1	Panellit trip due to a broken spline washing downstream in tube 1188. Miscellaneous maintenance.

KW Reactor

1/31	2/1	61.0	Panellit trip. Charge-discharge.
2/8	2/19	310.5	Replacement of 56 tubes.
2/19	2/19	2.0	RTD repair.

REACTORS									
1963					Inventory in Basins				
Charged		Produced		Inventory in Reactor		Discharged		Mar. Apr.	
Mar.	Apr.	Mar.	Apr.	Mar.	Apr.	Mar.	Apr.	Mar.	Apr.
Normal U (tons)	312	567		1,723	1,729	310	561	1,248	2,382
M&D			365,368	378,369	787,611	751,305	230,370	411,675	1,349,479
Pu (kg)			311	323	690	663	196	349	1,157
Sl. Metal (tons)	70	112		452	447	69	117	660	594
M&D			128,998	124,168	262,721	286,832	61,121	160,057	563,240
Pu (kg)			91	86	191	206	44	72	411
SEPARATIONS									
1963					Dissolved				
PUREX AND REDOX		Dissolved		Mar. Apr.		Mar. Apr.		Mar. Apr.	
Normal U (tons)			764	119					
M&D			497,763	81,170					
Pu (kg)			429.0	68.6					
Sl. Metal (tons)			49	182					
M&D			44,843	149,586					
Pu (kg)			35.1	110.4					

COMPARATIVE PILE PERFORMANCE									
MARCH 1963									
B	C	D	DR	F	H	K	M	TTL	
Maximum Power Level To Date, MW	1,910	2,310	2,005	1,725	1,955	1,450	1,700	20,770	
Maximum Power Level During Month, MW	1,915	2,170	1,760	1,770	1,500	1,450	1,755	20,155	
Average Power Level While Operating, MW	1,954	2,146	1,979	1,939	1,935	1,961	1,215	15,311	
Maximum Tube Power, kW	1,221	1,220	1,275	1,153	1,23 <sup>a</sup>	1,220	1,770	1,752	
Effective Central Tubes	1,565	1,625	1,515	1,535	1,207	1,525	2,175	2,512	
Time Operated Efficiency, %	60.1	62.8	65.1	72.6	82.6	82.4	81.0	76.1	
Operational Limitation	105°C	105°C	107°C	106°C	23.5°C	32.4	11.0°C <sup>b</sup>	33	
MWD Produced During Month, total	52,017 <sup>c</sup>	41,772	26,257	37,348	47,526	53,619 <sup>d</sup>	107,714	129,033 <sup>d</sup>	
Normal	43,252	32,177	23,662	29,544	41,089	74	90,464	104,537	
9Li Metal	8,795	9,595	2,595	7,804	6,438	52,875	17,650	23,216	
Plutonium Produced, grams	41,989	32,841	21,448	31,098	37,464	36,691	92,092	107,933	
Uranium In Reactor At Month End, tons	223.4	222.9	227.5	220.5	224.0	195.4	430.0	430.5	
Normal	194.7	184.8	212.3	183.0	198.6	3.6	373.2	372.4	
9Li Metal	28.7	38.1	15.2	37.5	25.4	191.8	56.8	55.1	
Uranium Discharged During Month, tons	35.9	0	45.7	91.0	0.1	14.4	160.2	32.2	
Normal	32.2	0	44.3	77.7	0.1	0.1	138.7	17.2	
9Li Metal	3.7	0	1.4	13.3	0	14.3	21.5	15.0	
Average Discharge Concentration									
Normal	653	-	665	801	480	730	738	882	
9Li Metal	848	-	769	881	961	845	866	883	

<sup>1</sup> Tube corrosion.

<sup>2</sup> Bulk outlet water temperature limit.

<sup>3</sup> Administrative limit.

<sup>4</sup> New record.

Extracted from Travis 1963d, page 27.

REACTOR OUTAGES MAR 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
3/11	3/13	44.5	Removal of an I&E E-metal rupture from tube 2476.
3/23	3/24	18.0	Removal of an I&E E-metal rupture from tube 3660.
<u>C Reactor</u>			
3/20	Still down		Leak testing. Tube replacement. Charge-discharge and miscellaneous maintenance.
<u>D Reactor</u>			
3/2	3/19	408.7	Replacement of 350 tubes.
<u>DR Reactor</u>			
2/14	3/4	429.1	Replacement of 307 tubes.
3/6	3/6	0.2	Panellit trip due to a faulty spline cap seal.
3/7	3/8	35.4	Correction of partially engaged front-face cap on tube 2474.
3/12	3/12	0.2	Panellit trip when the wrong Panellit gauge was by-passed during a base check.
3/14	3/16	34.6	Water leak. Replaced tube 0579 due to a rear Van Stone leak.
3/26	3/28	41.5	Removal of an I&E natural metal rupture from tube 3976.

---

Extracted from Plum 1964, March 1963, pages 2-4.

F Reactor

3/4	3/6	38.9	Removal of an I&E natural metal rupture from tube 1275.
3/28	Still down		Scheduled charge-discharge.

H Reactor

3/11	3/12	34.6	Water leak. Tube 0473 was replaced due to an internal leak. Inspection of the metal discharged from this tube revealed an I&E enriched metal rupture.
3/31	Still down		Removal of an I&E E-metal rupture from tube 0678.

KE Reactor

3/4	3/6	37.3	Investigation of flow valve vibration on Loop 4. Valve plug was found separated from the stem.
3/6	3/6	1.5	Unexplained low pressure trip on single pass tube 3050.
3/14	3/16	37.0	Panellit trip due to a broken spline in tube 1967. Charge-discharge and miscellaneous maintenance.
3/26	3/28	55.0	Scheduled charge-discharge.
3/29	3/29	0.4	At the associated test facility instrument power was switched to BPA power because of indications of trouble.

KW Reactor

3/7	3/8	36.1	Removal of an I&E E-metal rupture from tube 3868.
3/9	3/9	1.1	Unexplained Panellit trip on tube 1186.
3/9	3/9	0.6	Unexplained Panellit trip on tube 3286.

COMPARATIVE PILE PERFORMANCE						
		APR 1963				
B	C	D	E	F	G	H
Maximum Power Level To Date, MW	2,310	2,005	1,925	1,935	1,255	4,400
Maximum Power Level During Month, MW	2,215	1,925	1,360	1,945	1,375	4,400
Average Power Level While Operating, MW	2,062	1,867	1,910	1,792	1,927	3,336
Maximum Tube Power, KW	1,215	1,330	1,241	1,195	1,182	1,210
Effective Central Tubes	1,555	1,630	1,551	1,556	1,537	1,520
Time Operated Efficiency, %	78.0	76.5	84.5	87.7	94.2	93.0
Operational Limitation	108°C	105°C	93.5°C	107°C	106°C	105°C
MWD Produced During Month, total	42,225	47,300	47,324	47,533	50,654	47,573
Normal 94 Metal	36,024	36,001	42,764	37,719	44,258	40,404
Plutonium Produced, grams	6,201	11,299	4,560	9,924	6,396	6,915
Uranium In Reactor At Month End, tons	34,325	39,738	37,582	37,721	41,212	31,035
Normal 94 Metal	224.0	223.3	226.9	220.0	224.8	196.0
Uranium Discharged During Month, tons	200.1	182.7	212.5	182.3	201.0	196.0
Normal 94 Metal	23.9	40.6	14.3	37.7	23.8	192.4
Average Discharge Concentration	74.4	117.5	56.8	93.1	85.2	5.3
Normal 94 Metal	94.7	27.3	5.9	10.2	11.5	5.2

1 Tube corrosion.  
 2 Bulk outlet water temperature limit.  
 3 Administrative limit.  
 4 Record monthly production figure.  
 Extracted from Travis 1963e, page 27.

REACTOR OUTAGES APR 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
4/1	4/3	58.5	Removal of an I&E E-metal rupture from tube 2774. Charge-discharge.
4/16	4/19	80.6	Removal of an I&E E-metal rupture from tube 2681. Charge-discharge and maintenance.
4/20	4/21	29.3	Removal of an I&E E-metal rupture from tube 2490. Tube was removed and channel left blank.
<u>C Reactor</u>			
3/20	4/3	331.7	Tube replacement.
4/5	4/7	38.3	Manual trip for temperature control. Leak testing.
4/18	4/18	0.3	Unexplained Panellit trip.
4/18	4/21	75.8	Manually tripped to control tube temperature. Charge-discharge and leak testing.
<u>D reactor</u>			
4/14	4/16	68.1	Removal of an I&E natural metal rupture from tube 0661. Charge-discharge.
4/24	4/25	43.0	Water leak. Replaced 7 tubes.
4/30	Still down		Panellit trip due to a faulty gauge on 2668.
<u>DR Reactor</u>			
4/21	4/25	64.0	Scheduled charge-discharge. Miscellaneous maintenance.
4/25	4/25	0.3	Panellit trip when gauge was accidentally rolled beyond the high trip point.

Extracted from Plum 1964, April 1963, pages 2-4.

F Reactor

3/28	4/1	84.5	Scheduled charge-discharge.
4/1	4/1	2.2	Unexplained Panellit trip.
4/16	4/18	38.4	Tripped due to a spline cap seal leak.

H Reactor

3/31	4/1	26.7	Removal of I&E E-metal rupture from tube 0578.
4/27	Still down		Scheduled charge-discharge and maintenance.

KE Reactor

4/10	4/12	77.8	Panellit trip on gauge 3568 caused by a short circuit. Charge-discharge.
4/12	4/12	0.6	Unexplained Panellit trip.
4/12	4/12	6.0	Unexplained Panellit trip.

KW Reactor

4/1	4/4	77.8	Scheduled charge-discharge and maintenance.
4/4	4/4	2.7	Unexplained Panellit trip.
4/7	4/9	38.2	Leak testing. Remove aluminum tube from test hole 3A, channel blanked off.
4/16	4/17	36.9	Replacement of No. 3 low lift pump motor.

REACTORS  
1963

	Charged		Produced		Inventory in Reactor		Discharged		Inventory in Basins	
	May	June	May	June	May	June	May	June	May	June
Normal U (tons)	303	549			1,728	1,730	304	547	2,027	1,999
M&D			290,523	335,526	837,731	758,985	204,097	414,272	1,461,870	1,380,702
Pu (kg)			241	287	728	668	176	348	1,246	1,171
9L Metal (tons)	198	106			458	464	186	100	762	733
M&D			94,473	127,388	216,788	257,427	164,517	86,749	667,583	646,066
Pu (kg)			68	91	159	188	115	62	478	461
<u>SEPARATIONS</u> <u>1963</u>										
<u>PUREX AND REDOX</u>										
Normal U (tons)					Dissolved		May June			
M&D										
Pu (kg)										
9L Metal (tons)										
M&D										
Pu (kg)										

COMPARATIVE PILE PERFORMANCE - MAY 1963

	B	C	D	DR	F	H	KE	KW	TOTAL
Maximum Power Level To Date, MW	1,910	2,310	2,005	1,925	1,955	1,400	1,400	20,370	
Maximum Power Level During Month, MW	1,925	2,290	1,900	1,775	1,830	1,780	1,400	20,190	
Average Power Level While Operating, MW	1,795	2,181	1,823	1,742	1,791	1,697	1,379	17,217	
Maximum Tube Power, KW	1,181	1,317	1,227	1,176	1,175	1,182	1,762	1,623	
Effective Central Tubes	1,510	1,680	1,532	1,513	1,534	1,476	2,500	2,511	
Time Operated Efficiency, %	87.3	95.1	91.7	90.3	87.2	70.7	35.7	30.4	73.9
Operational Limitation	10 <sup>10</sup> g <sub>0</sub> 1	95.0 <sup>0</sup> 2	23.5 <sup>0</sup> 2	107 <sup>0</sup> 1	106 <sup>0</sup> 1	93.5 <sup>0</sup> 2	14.000 <sup>0</sup> 3	14.000 <sup>0</sup> 3	
WTD Produced During Month, total	48,290	64,320 <sup>1</sup>	53,509 <sup>4</sup>	48,266	48,115	26,290	18,702	35,804	291,896
Normal	41,755	48,599	48,507	39,298	42,643	504	10,671	29,556	290,523
9 <sub>U</sub> Metal	6,535	15,731	5,002	9,668	5,772	36,186	8,031	7,213	94,173
Plutonium Produced, grams	39,523	50,976	41,112	39,279	39,743	27,401	38,960	31,919	208,243
Uranium In Reactor At Month End, tons	224.7	223.3	227.2	220.7	226.0	199.1	430.0	435.0	2186.0
Normal	199.5	182.7	212.9	181.9	203.0	195.6	375.7	365.6	1727.9
9 <sub>U</sub> Metal	25.2	40.6	14.3	35.3	23.0	195.5	54.3	69.1	458.1
Uranium Discharged During Month, tons	61.1	11.9	0.5	5.7	88.9	137.8	0	184.8	420.6
Normal	53.2	6.1	0.5	0.3	80.6	3.1	0	160.3	304.1
9 <sub>U</sub> Metal	7.9	5.8	0	5.4	8.2	134.7	0	24.5	186.5
Average Discharge Concentration									
Normal	623	720	354	467	749	623	-	648	671
9 <sub>U</sub> Metal	883	866	-	802	949	891	-	832	882

1 Tube corrosion  
 2 Bulk outlet water temperature limit.  
 3 Administrative limit.  
 4 New record.  
 Extracted from Travis 1963f, page 27.

REACTOR OUTAGES MAY 1963

<u>Date</u>	<u>Date</u>	<u>Outage</u>	
<u>Down</u>	<u>Up</u>	<u>Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
5/14	5/17	60.8	Scheduled charge-discharge. Removed tube 3390 due to a rear Van Stone leak.
5/22	5/23	16.8	Removal of an I&E natural metal rupture from tube 2080. Retubed 9 air channels.
<u>C Reactor</u>			
5/7	5/9	35.1	Removal of an I&E metal rupture from tube 2077.
<u>D Reactor</u>			
4/30	5/2	39.0	Panellit trip due to faulty gauge on tube 2668. Miscellaneous maintenance.
5/2	5/2	1.1	Removed an orifice from tube 1490 and installed a Venturi to correct high tube temperature.
<u>DR Reactor</u>			
5/1	5/3	36.0	Leak testing. Two rear Van Stone leaks were corrected; tube 0677 was replaced and a new Van Stone was formed on tube 0664.
5/10	5/12	36.0	Removal of an I&E E-metal rupture from tube 3960. Charge-discharge and leak testing.

Extracted from Plum 1964, May 1963, pages 2-4.

H Reactor

4/27	5/6	227.3	Scheduled charge-discharge and maintenance. Expansion joint work completed. Replacement of eleven process tubes.
5/7	5/7	0.9	Manually discharged poison from FCFF tube 3974 due to a stuck valve.
5/14	5/15	29.2	Leak testing.
5/16	5/16	0.3	Tripped when a VSR dropped out of the upper limit switch.
5/17	5/19	46.8	Leak testing. Replaced tube 2874 due to an internal leak.

KE Reactor

5/12	Still down		Removal of a production test rupture from front-to-rear test hole 3565. Scheduled tube replacement.
------	------------	--	---

KW Reactor

5/2	5/23	515.7	Scheduled tube replacement.
5/23	5/23	1.6	Unexplained low pressure Panellit trip on 1247.
5/23	5/23	1.0	Unexplained low pressure Panellit trip on 5278.

COMPARATIVE PILE PERFORMANCE - JUN 1963

	B	C	D	DR	F	H	KE	KW	TOTAL
Maximum Power Level To Date, MW	1,940	2,310	2,005	1,925	1,935	1,955	1,960	1,970	20,570
Maximum Power Level During Month, MW	1,835	2,150	1,805	1,775	1,815	1,755	1,755	1,755	15,295
Average Power Level While Operating, MW	1,710	2,039	1,737	1,737	1,751	1,719	1,719	1,721	15,261
Maximum Tube Power, KW	1,174	1,247	1,213	1,139	1,198	1,125	1,125	1,122	1,780
Effective Central Tubes	1,550	1,667	1,510	1,510	1,511	1,511	1,511	2,500	2,405
Time Operated Efficiency, %	54.4	80.5	66.8	86.0	73.2	100.0	100.0	100.0	77.2
Operational Limitation	95.0°C	95.0°C							
MWD Produced During Month, total	28,388	49,259	24,371	44,304	38,840	51,571	95,594	130,097	462,914
Normal	24,556	37,115	22,094	36,213	34,383	704	77,242	103,219	335,526
94 Metal	3,032	12,144	2,277	8,591	4,457	50,867	18,342	26,878	127,388
Plutonium Produced, grams	22,972	40,627	17,770	36,373	31,965	35,756	83,341	109,680	378,1484
Uranium In Reactor At Month End, tons	225.6	223.2	227.7	220.8	226.5	199.1	136.1	135.0	2194.0
Normal	201.5	182.6	214.1	185.7	203.9	3.6	372.9	365.6	1729.9
94 Metal	24.1	40.6	13.6	35.1	22.6	195.5	63.2	69.4	164.1
Uranium Discharged During Month, tons	22.5	132.0	103.7	87.6	90.0	211.9	647.7	647.7	847.3
Normal	14.8	106.3	93.8	71.1	82.7	178.3	33.6	33.6	100.4
94 Metal	7.7	25.7	9.9	16.2	7.3	98.3	758	757	864
Average Discharge Concentration									
Normal	657	679	963	707	683	791			
94 Metal	579	797	1,082	984	791				

REACTOR OUTAGES JUN 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
6/6	6/18	297.2	Removal of an I&E E-metal rupture from tube 0773. Scheduled charge-discharge and maintenance work - bellows foaming, thermocouple and Venturi work.
6/20	6/20	0.3	Panellit trip due to a blown thermocouple well on tube 1679.
6/20	6/21	39.9	Removal of an I&E E-metal rupture from tube 1762.
<u>C Reactor</u>			
6/1	6/4	72.8	Scheduled charge-discharge.
6/18	6/21	66.3	Removal of an I&E E-metal rupture from tube 2458. Charge-discharge.
6/21	6/21	1.5	Unexplained Panellit trip.
6/22	6/22	0.3	Unexplained Panellit trip.
<u>D Reactor</u>			
6/14	6/29	381.7	Scheduled charge-discharge and maintenance. Replacement of 241 tubes. Foaming of rear-face bellows.
6/30	6/30	1.5	Corrected a rear-face cap leak on tube 3765.
<u>DR Reactor</u>			
6/3	6/5	60.5	Scheduled charge-discharge. Proboglogged 205 tubes and installed 200 Van Stone inserts.
6/5	6/5	1.5	Repaired front-pigtail fitting leak on tube 3661.
6/24	6/25	39.1	Removal of an I&E natural water mixer rupture from tube 3689. Charge-discharge.

Extracted from Plum 1964, June 1963, pages 3 and 4.

F Reactor

6/5	6/8	73.3	Leak testing, charge-discharge and miscellaneous maintenance. Replaced 5 process tubes.
6/9	6/11	38.6	Leak testing. Rear Van Stone leaks were corrected on tubes 3794 and 3188.
6/11	6/11	0.7	Panellit trip due to a spline cap leak while inserting a spline.
6/19	6/22	75.0	Scheduled charge-discharge. Maintenance and tube replacement.

H Reactor

No outages.

KE Reactor

5/12	6/8	651.5	Scheduled replacement of 591 tubes, charge-discharge and miscellaneous maintenance.
6/8	6/8	0.7	Unexplained high pressure Panellit trip on tube 2044.

KW Reactor

No outages.

REACTORS									
1963									
Charged		Produced		Inventory in Reactor		Discharged		Inventory in Basins	
July	Aug.	July	Aug.	July	Aug.	July	Aug.	July	Aug.
Normal U (tons)	459	514		1,731	1,741	457	505	2,354	2,531
MWD			346,249	283,762	747,366	690,856	357,868	340,272	1,734,435
Pu (kg)			296	238	660	606	304	292	1,472
U Metal (tons)	119	75		161	159	122	77	703	681
MWD			117,125	99,038	260,679	296,297	113,873	63,420	628,862
Pu (kg)			82	67	189	210	80	45	445
SEPARATIONS									
1963									
PUREX AND REDOX		Dissolved							
July	Aug.	July	Aug.	Normal U (tons)	0	325			
MWD				0	201,687				
Pu (kg)				0	177.2				
U Metal (tons)				153	118				
MWD				133,793	108,708				
Pu (kg)				97.0	75.7				

~~SECRET~~

COMPARATIVE PILE PERFORMANCE - JULY 1963

	B	C	D	DR	P	R	RE	TOTAL
Max. Power Level to Date, MW	1,940	2,310	2,005	1,925	1,955	1,955	1,400	20,870
Max. Power Level During Month, MW	1,935	2,090	1,735	1,755	1,830	1,700	1,290	19,510
Avg Power Level While Operating, MW	1,713	1,978	1,672	1,661	1,776	1,652	3,291	18,437
Max. Net Power, KW	1,213	1,232	1,169	1,115	1,133	1,089	1,611	1,077
Effective Central Tubes	1,500	1,655	1,095	1,560	1,565	1,520	2,535	2,160
Time-Operated Efficiency, %	79.2	89.7	82.1	82.2	92.9	87.7	76.1	73.3
Operational Limitation <sup>1</sup>	95.0%	95.0%	93.5%	95.0%	93.5%	95.0%	95.0%	83.0
WMD Produced During Month, total	12,575	55,030	42,530	43,077	51,216	48,901	89,896	163,374
Normal	36,931	41,156	38,229	34,877	45,291	612	71,834	316,249
94 Metal	5,611	13,574	4,301	8,220	5,925	44,289	17,110	117,125
Plutonium Produced, gm	34,831	44,474	35,537	34,978	41,266	29,601	82,616	74,213
U in Reactor at Month End, tons	224.0	223.4	226.7	220.9	226.8	198.1	437.0	435.6
Normal	198.0	182.9	209.9	185.6	204.2	3.6	378.1	369.1
94 Metal	26.0	40.5	16.8	35.3	22.6	194.5	58.9	66.5
U Discharged During Month, tons	93.1	43.5	38.0	63.7	7.2	43.3	155.5	134.7
Normal	87.1	36.4	37.6	57.2	3.1	0.5	134.2	101.2
94 Metal	6.0	7.1	0.1	6.5	4.1	42.8	21.3	33.5
Avg Discharge Concentration	710	743	890	626	816	630	806	783
Normal	782	899	175	871	784	1,065	734	982
94 Metal								936

1 Bulk outlet water temperature limit.  
Extracted from Travis 1963h, page 31.

REACTOR OUTAGES JUL 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
----------------------	--------------------	-------------------------	----------------

B Reactor

7/3	7/5	39.7	Panellit trip caused by a blown thermocouple well.
7/15	7/18	86.6	Scheduled charge-discharge.
7/20	7/21	33.1	Unexplained Panellit trip.

C Reactor

7/1	7/1	0.2	Unexplained Panellit trip on Row 38.
7/1	7/3	42.2	Manual trip for temperature control. Charge-discharge and VSR work performed.
7/3	7/3	0.2	Low Beckman trip while bringing gas purity within standards.
7/27	7/28	33.7	Correction of cavitation in front pigtail on tube 3551.

D Reactor

7/1	7/3	34.5	Removal of an I&E E-metal rupture from tube 1958.
7/3	7/3	1.0	Unexplained Panellit trip on tube 1675.
7/3	7/3	5.1	Unexplained Panellit trip on tube 1686.
7/3	7/3	3.1	Panellit trip due to a portion of a spline cap assembly washing down stream.
7/12	7/14	52.0	Removal of an I&E natural metal rupture from tube 2468. Charge-discharge.
7/17	7/19	35.8	Tripped by an electrical power failure when lightning struck a line near Midway.
7/19	7/19	1.9	Panellit trip caused by a spline cap leak while inserting a spline.
7/19	7/19	0.7	Unexplained Panellit trip.

DR Reactor

7/10	7/14	97.8	Scheduled charge-discharge and repair of damaged front crossheader.
7/17	7/18	34.7	Correction of a front-face cap which was not fully rotated on the lug ring.

F Reactor

7/15	7/17	52.8	Leak testing. Replaced tube 1275 to correct an internal leak.
------	------	------	---

II Reactor

7/19	7/21	58.5	Charge-discharge and leak testing.. Replaced tube 1589 due to an internal leak.
7/21	7/21	0.5	Manually opened a ball valve which failed to operate automatically..
7/22	7/22	0.4	Panellit trip caused by a spline seal leak.
7/28	7/29	29.7	Leak testing. Tube 2590 replaced due to an internal leak. Three thin-wall tubes were replaced.
7/29	7/29	2.6	Panellit trip on tube 3983 due to a faulty gauge.

KE Reactor

7/1	7/3	69.9	Scheduled charge-discharge and maintenance.
7/3	7/4	0.6	Unexplained Panellit trip.
7/10	7/12	36.2	Tripped by Loop 2 when the diaphragms in the dump valve failed.
7/11	7/16	46.3	Tripped by Loop 4 when a diaphragm ruptured in a 3-way valve.
7/22	7/23	34.0	Removal of an I&E E-metal rupture from tube 4050.

IW Reactor

7/8	7/12	106.0	Scheduled charge-discharge.
7/13	7/13	1.4	Panellit trip due to a broken spline in tube 5370.
7/13	7/13	0.4	Unexplained Panellit trip on tube 3151.
7/13	7/13	14.7	Unexplained Panellit trip on tube 3151. The tube was recharged and the hard- ware and Panellit gauge replaced.
7/15	7/17	37.2	Panellit trip due to a broken spline in tube 1585.
7/17	7/17	1.2	Manual trip for temperature control.
7/30	Still down		Removal of an I&E E-metal rupture from tube 3868. Charge-discharge in preparation for tube replacement.

COMPARATIVE PILE PERFORMANCE - AUG 1963

	B	C	D	DR	F	H	KW	TOTAL
Max. Power Level to Date, MW	1,710	2,310	2,005	1,225	1,235	1,955	1,400	20,370
Max. Power Level During Month, MW	1,770	2,025	1,725	1,715	1,770	1,640	1,125	16,355
Avg. Power Level While Operating, MW	1,639	1,615	1,574	1,557	1,727	1,371	1,123	17,322
Max. Tube Power, KW	1,227	1,186	1,103	1,053	1,120	1,075	1,076	2,555
Effective Central Tubes	1,436	1,674	1,526	1,571	1,563	1,517	2,153	1,330
Time-Operated Efficiency, %	85.4	81.9	99.9	86.7	85.2	88.7	61.4	2,517
Operational Limitation <sup>1</sup>	95.00%	95.00%	95.00%	95.00%	92.50%	95.00%	95.00%	77.0
K:D Produced During Month, total	11,264	18,536	51,878	14,345	18,099	14,258	20,276	21,211
Normal	38,881	36,589	16,092	36,020	12,475	12,583	65,260	17,172
94 Metal	6,083	11,947	5,796	8,525	5,524	12,675	1h,316	97,033
Plutonium Produced, gm	36,958	39,164	10,615	35,265	39,069	27,392	66,131	15,211
U in Reactor at Month End, tons	22h.4	223.4	226.7	221.0	226.7	128.0	137.0	442.8
Normal	128.5	182.2	209.9	196.1	203.9	3.6	37.1	377.5
94 Metal	25.9	10.5	16.3	31.7	22.3	19h.1	55.9	159.1
U Discharged During Month, tons	72.3	98.5	77.1	70.7	73.5	80.0	0.2	1h.9
Normal	70.0	77.1	21.1	7.8	6.2	73.3	1h.0	230.3
94 Metal	9.3					0.2		32.0
Avg Discharge Concentration	636	662	680	720	780	569	681	591.7
Normal	853	928	930	951			697	50h.9
94 Metal								75.9

<sup>1</sup> Bulk outlet water temperature limit.  
Extracted from Travis 1963i, page 31.

REACTOR OUTAGES AUG 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
8/2	8/4	34.9	Panellit trip due to a blown thermo-couple well on tube 2087. Replaced five thin wall tubes.
8/19	8/22	71.9	Scheduled charge-discharge.
8/22	8/22	1.7	Unexplained Panellit trip.
<u>C Reactor</u>			
8/12	8/15	92.3	Scheduled charge-discharge and maintenance.
8/20	8/20	0.3	Tripped when cooling water hose came loose from No. 14 HCR.
8/24	8/24	0.3	Manually tripped when HCR cooling water annunciator tab dropped; probably caused when Midway-Grand Coulee line relayed out and immediately reset.
8/25	8/26	38.3	Removal of an I&E oversize rupture from tube 3062.
8/31	still down		Removal of tube 2374 due to an internal water leak.
<u>D Reactor</u>			
8/5	8/5	0.2	Panellit trip due to a procedure error while inserting a spline.
<u>DR Reactor</u>			
8/7	8/8	34.1	Panellit trip on 1494 because of a ground.
8/27	8/29	63.7	Scheduled charge-discharge.

---

Extracted from Plum 1964, August 1963, pages 2-4.

F Reactor

8/5 8/3 75.5 Scheduled charge-discharge.

H Reactor

8/5 8/6 27.9 Leak testing.

8/16 8/17 27.7 Tripped when a VSR slipped from the upper limit switch.

8/24 8/24 0.3 Low pressure Panellit trip during spline insertion.

8/24 8/26 26.5 Manual trip for temperature control and miscellaneous maintenance.

I/E Reactor

8/5 8/6 31.9 Removal of an I/E natural metal rupture from tube 3977.

8/22 still down Scheduled tube replacement and charge-discharge.

K/V Reactor

7/30 8/23 577.5 Replacement of 618 tubes (600 zirconium and 48 aluminum).

8/24 8/26 36.6 Investigation of excessive water collection. Some nozzles of recently replaced tubes were found loose.

8/26 8/26 0.5 Tripped due to a faulty spline cap seal.

8/26 8/27 22.6 Correction of a grounded circuit.

---

Extracted from Plum 1964, August 1963, pages 2-4.

<u>REACTORS</u>						<u>Inventory in Basins</u>	
				<u>1963</u>			
<u>Charged</u>		<u>Produced</u>		<u>Inventory in Reactor</u>		<u>Sept. Oct.</u>	
<u>Sept.</u>	<u>Oct.</u>	<u>Sept.</u>	<u>Oct.</u>	<u>Sept.</u>	<u>Oct.</u>	<u>Sept.</u>	<u>Oct.</u>
<u>Normal U (tons)</u>	397	2119		1,751	1,717	387	253
<u>M&amp;D</u>				725,835	828,552	279,814	201,821
<u>Pu (kg)</u>				640	729	237	167
<u>9L Metal (tons)</u>	207	61		457	459	210	60
<u>M&amp;D</u>		90,781	108,863	173,699	227,245	213,379	55,317
<u>Pu (kg)</u>		61	78	128	167	117	39

  

<u>SEPARATIONS</u>						<u>1963</u>	
				<u>PUREX AND REDOX</u>			
<u>Sept.</u>		<u>Dissolved</u>		<u>Sept.</u>			
<u>Sept.</u>	<u>Oct.</u>	<u>Sept.</u>	<u>Oct.</u>	<u>Sept.</u>	<u>Oct.</u>	<u>Sept.</u>	<u>Oct.</u>
<u>Normal U (tons)</u>		591		591		1,622	
<u>M&amp;D</u>				392,296		390,992	
<u>Pu (kg)</u>		340.3		326.7			
<u>9L Metal (tons)</u>				92		42	
<u>M&amp;D</u>		80,534		37,066			
<u>Pu (kg)</u>		55.7		27.8			

Extracted from Travis 1963k, pages 3 and 4.

**COMPARATIVE PILE PERFORMANCE - SEP 1963**

	B	C	D	DR	F	H	KW	TOTAL
Max. Power Level to Date, MW	1,240	2,310	2,035	1,925	1,935	1,955	4,400	20,970
Max. Power Level During Month, MW	1,760	2,030	1,700	1,650	1,755	1,635	1,125	18,260
Avg Power Level While Operating, MW	1,725	1,258	1,627	1,551	1,666	1,554	2,302	17,213
Max. Tube Power, kW	1,184	1,206	1,135	1,017	1,128	1,048	1,665	1,710
Effective Central Tubes	1,187	1,577	1,505	1,590	1,560	1,557	2,111	2,457
Time-Operated Efficiency, %	38.7	61.6	82.3	91.0	72.8	58.3	17.2	100.0
Operational Limitation <sup>1</sup>	95.00°C	95.00°C	95.00°C	95.00°C	95.00°C	95.00°C	25.00°C	75.2
MW Produced During Month, total	45,890	34,146	40,164	45,064	36,377	27,173	52,185	124,305
Normal	39,691	26,027	36,440	36,555	32,046	36.9	43,874	105,564
94 Metal	6,199	8,119	4,124	8,509	4,331	26,304	8,311	314,823
Plutonium Produced, gm	37,528	27,502	31,125	35,744	29,862	18,387	46,209	214,024
U in Reactor at Month End, tons	221.6	223.1	227.7	221.0	221.0	199.8	224.7	2207.6
Normal	190.5	181.4	211.1	186.1	197.3	3.6	350.5	1750.5
94 Metal	25.0	41.7	13.3	31.9	26.7	196.2	54.2	457.1
U Discharged During Month, tons	53.3	70.4	53.5	0.3	93.5	139.6	186.3	596.9
Normal	47.9	57.0	43.8	0.3	86.1	3.3	148.8	357.2
94 Metal	5.4	13.4	9.7	-	7.4	136.3	37.5	209.7
Avg Discharge Concentration								
Normal	607	728	1,031	443	690	707	687	-
94 Metal	936	882	1,022	922	-	1,083	857	1,018

<sup>1</sup> Bulk outlet water temperature limit.  
Extracted from Travis 1963j, page 31.

REACTOR OUTAGES SEP 1963

<u>Date</u> <u>Down</u>	<u>Date</u> <u>Up</u>	<u>Outage</u> <u>Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
9/20	9/23	81.7	Removal of an I&E natural metal rupture from tube 3562. Charge-discharge.
<u>C Reactor</u>			
8/31	9/2	37.1	Leak testing. Removal of tube 2374 due to an internal leak.
9/4	9/4	0.2	Manual trip due to a spline cap seal leak.
9/13	9/14	33.7	Removal of an I&E E-metal rupture from tube 3778.
9/21	9/30	207.9	Scheduled charge-discharge and maintenance, including mass foaming. Replaced 20 process tubes.
<u>D Reactor</u>			
9/5	9/9	55.1	Removal of an I&E natural metal rupture from tube 2761. Charge-discharge and maintenance.
9/21	9/23	45.4	Removal of an I&E natural metal rupture from tube 3366. Replaced tube 1566 due to a rear Van Stone leak. Also replaced three other tubes.
<u>DR Reactor</u>			
9/2	9/4	65.1	Leak testing following a Panellit trip. A piece of foreign material was found on the orifice screen of tube 0388 which probably caused the Panellit trip.

---

Extracted from Plum 1964, September 1963, pages 2-4.

F Reactor

9/9	9/12	99.2	Scheduled charge-discharge and maintenance.
9/13	9/13	2.3	Unexplained Panellit trip.
9/21	9/24	64.4	Penellit trip on tube 3082 caused by an internal leak. Leak testing and replacement of three tubes.
9/28	9/29	39.2	Tripped by an operating error while attempting to clear an annunciator signal for a 4500 h.p. motor.

H Reactor

9/3	9/5	29.7	Leak testing. Replaced tube 3562 due to an internal leak.
9/5	9/5	1.3	Panellit trip caused by a spline cap seal leak.
9/13	9/24	269.3	Scheduled tube replacement and block charge-discharge.

KE Reactor

8/22	9/11	483.7	Scheduled tube replacement - 597 zirconium and 22 aluminum tubes were replaced.
9/12	9/13	27.1	Miscellaneous maintenance and the adjustment of control.
9/15	9/16	30.1	Miscellaneous maintenance following an unexplained Panellit trip.
9/18	9/20	31.1	Removal of an I&E natural metal rupture from tube 3965.
9/28	9/29	39.6	Correction of a water leak. Several nozzles were tightened.

KW Reactor - No outages during September.

COMPARATIVE PILE PERFORMANCE - OCT 1963									
	B	C	D	DR	F	H	KW	TOTAL	
Max. Power Level to Date, MW	1,940	2,310	2,005	1,295	1,955	4,100	20,570		
Max. Power Level During Month, MW	1,870	2,085	1,820	1,905	1,870	4,150	19,725		
Avg. Power Level While Operating, MW	1,768	2,020	1,675	1,707	1,755	4,111	13,536		
Max. Tube Power, KW	1,254	1,236	1,154	1,160	1,232	1,124	1,673	2,143	
Effective Central Tubes	1,190	1,655	1,500	1,535	1,537	2,160	2,159		
Time-Operated Efficiency, %	86.3	93.0	75.8	83.1	87.7	23.6	80.7	78.0	
Operational Limitation <sup>1</sup>	95.00%	95.00%	95.00%	95.00%	95.00%	95.00%	95.00%		
MEP Produced During Month, total	46,796	58,275	39,339	43,987	48,201	30,106	99,000	413,401	
Normal	40,738	43,520	35,560	35,709	41,648	25,262	81,362	304,538	
9L Metal	6,058	14,765	3,675	8,278	6,049	4,7556	17,538	103,253	
Plutonium Produced, gm	37,832	46,676	31,637	36,377	38,421	34,895	25,666	82,307	
U in Reactor at Month End, tons	223.8	223.1	225.6	221.0	224.2	199.8	144.7	2205.5	
Normal	197.3	181.4	207.5	186.3	197.5	34.6	390.5	176.7	
9L Metal	26.5	41.7	18.1	34.7	26.7	196.2	54.2	153.9	
U Discharged During Month, tons	40.0	0	22.9	29.3	24.4	0	0	312.5	
Normal	30.0	0	86.7	80.9	10.1	0	0	253.0	
9L Metal	6.0	0	6.2	18.4	4.3	0	0	59.5	
Avg Discharge Concentration	720	-	826	714	805	-	-	798	
Normal	821	-	935	1,046	849	-	-	882	
9L Metal									

<sup>1</sup> Bulk outlet water temperature limit.  
Extracted from Travis 1963K, page 38.

REACTOR OUTAGES OCT 1963

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
10/8	10/10	39.7	Removal of an I&E E-metal rupture from tube 3359. Charge-discharge.
10/10	10/10	0.5	Panellit trip caused by a faulty spline cap seal on tube 3181.
10/11	10/11	0.4	Panellit trip due to a faulty spline cap seal on tube 2683.
10/23	10/25	50.1	Removal of an I&E E-metal rupture from tube 3784. Replaced three tubes because of rear Van Stone leaks.
10/25	10/26	10.8	Removal of an I&E natural metal rupture from tube 2178.
10/27	10/27	0.2	Tripped during the removal of a spline from tube 3564 due to the malfunction of the spline coiler.
<u>C Reactor</u>			
10/1	10/1	0.3	Unexplained Panellit trip.
10/22	10/22	0.3	Tripped when the No. 8 pump set dropped off the line because of a motor fault to ground.
10/29	still down		Removal of an oversized I&E natural metal rupture from tube 1464. Charge-discharge and miscellaneous maintenance.

DR Reactor

10/1	10/5	91.0	Removal of an I&E E-metal rupture from tube 1489. Block charge-discharge.
10/8	10/9	34.8	Panellit trip due to improper jumpering procedure.

F Reactor

10/8	10/10	57.8	Leak testing. Replaced tubes 0678 and 2179 due to a rear Van Stone leak and internal tube leak, respectively.
10/13	10/14	34.0	Removal of an I&E natural metal rupture from tube 2787.

H Reactor

10/7	10/8	26.5	Panellit trip when a rear connector adapter failed on tube 1569.
10/9	10/10	.4	Trip caused by VSR No. 24 dropping from the upper limit switch.
10/10	10/10	21.5	Same as above, both trips caused by an improperly adjusted clutch.
10/11	10/11	.2	Unexplained low pressure Panellit trip on tube 1395.

KE Reactor

10/8 still down Scheduled tube replacement.

KW Reactor

10/1 10/3 60.9 Scheduled charge-discharge.

10/16 10/17 32.8 Removal of an I&E E-metal rupture from tube 3670.

10/18 10/18 1.0 Panellit trip caused by a faulty spline cap seal on tube 1991.

10/29 still down Questionable integrity of a front-face pigtail when 18 wire strands were found broken. Tube replacement scheduled for 10/31/63 is being completed.

REACTORS									
1963									
	Charged		Produced		Inventory in Reactor		Discharged		Inventory in Basins
	Nov.	Dec.	Nov.	Dec.	Nov.	Dec.	Nov.	Dec.	Nov.
Normal U (tons)	627	620			1,757	1,782	616	594	1,366 1,889
MWD			325,089	376,616	732,170	658,569	421,471	450,247	1,420,412 1,376,154
Pu (kg)			281	317	646	584	364	379	1,202 1,167
9L Metal (tons)	84	207 <sup>1</sup>			462	556 <sup>1</sup>	81	113	857 913
MWD			115,222	115,480	274,424	296,524	68,043	93,380	782,794 826,276
Pu (kg)			81	79	198	210	49	68	556 589
SEPARATIONS									
1963									
	PUREX AND REDOX				Dissolved		Nov.	Dec.	
	Nov.	Dec.			Nov.	Dec.	Nov.	Dec.	
Normal U (tons)					777	660			
MWD					579,446	490,150			
Pu (kg)					490.1	415.6			
9L Metal (tons)					17	51			
MWD					1L,832	4L,496			
Pu (kg)					10.4	31.3			

COMPARATIVE PILE PERFORMANCE - NOV 1963

B	C	D	DR	F	H	KW	TOTAL
Max. Power Level to Date, MW	1,240	2,310	2,005	1,925	1,935	1,955	20,370
Max. Power Level During Month, MW	1,240	2,150	1,875	1,855	1,920	1,915	20,355
Avg. Power Level While Operating, MW	1,825	2,018	1,321	1,781	1,778	1,782	10,245
Max. Tube Power, MW	1,290	1,257	1,202	1,152	1,249	1,150	3,370
Effective Central Tubes	1,189	1,671	1,526	1,563	1,699	1,565	1,738
Time-Operated Efficiency, %	92.6	77.6	95.0	83.5	76.3	100.0	26.9
Operational Limitation	1940 ft. <sup>2</sup>	950 ft. <sup>2</sup>	14,000 ft. <sup>2</sup>				
WAD Produced During Month, total	52,651 <sup>3</sup>	46,930	51,930	46,618	50,678	53,457	118,817
Normal	46,085	36,130	45,936	36,220	35,612	38,718	98,630
9 <sub>4</sub> Metal	6,566	10,830	5,994	8,398	5,066	52,739	20,187
Plutonium Produced, gm	42,807	38,211	41,651	35,729	33,356	35,984	106,320
U in Reactor at Month End, tons	223.9	223.8	225.3	220.0	224.1	199.9	451.6
Normal	197.6	185.7	206.5	182.6	197.5	3.7	393.8
9 <sub>4</sub> Metal	26.3	38.1	18.8	37.4	26.6	196.2	57.8
U Discharged During Month, tons	63.1	95.8	114.4	85.7	88.1	0	176.3
Normal	59.9	76.6	114.4	77.3	79.4	0	155.7
9 <sub>4</sub> Metal	3.2	19.2	0	8.4	4.7	0	20.6
Avg Discharge Concentration	601	676	885	663	701	-	711
Normal	819	857	-	1,040	891	-	828
9 <sub>4</sub> Metal							839

1 Bulk outlet water temperature limit.

2 Administrative limit.

3 Poor record.

Extracted from Travis 19631, page 38.

REACTOR OUTAGES Nov 1963

<u>Date</u>	<u>Date</u>	<u>Outage</u>	
<u>Down</u>	<u>Up</u>	<u>Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
11/4	11/6	53.0	Correction of a spline cap leak, charge-discharge and miscellaneous maintenance.
<u>C Reactor</u>			
10/29	11/2	93.7	Rupture removal, charge-discharge, and miscellaneous maintenance.
11/10	11/12	53.2	Scheduled charge-discharge. Replaced tube 2574 because of a rear Van Stone leak and tube 2470 because of a thin wall.
11/18	11/18	0.3	Manual trip when a front-face cap was found partially engaged.
11/18	11/20	33.5	Manual trip for tube temperature control.
11/21	11/22	31.7	Removal of an I&E natural metal rupture from tube 1979.
<u>D Reactor</u>			
11/4	11/5	35.5	Removal of an I&E natural metal (bumper mixer) rupture from tube 3272.
11/27	11/27	0.1	Panellit trip caused by a rear pigtail failure on tube 3282.
<u>DR Reactor</u>			
11/16	11/19	80.6	Malfunction of ball valve on tube 2167 and scheduled charge-discharge.
11/26	11/28	37.9	Removal of an I&E-EB metal rupture from tube 1558. Miscellaneous maintenance. Replaced two process tubes.

---

Extracted from Plum 1964, November 1963, pages 2-4.

F Reactor

11/4	11/7	91.7	Scheduled charge-discharge, leak testing and tube replacement.
11/9	11/11	47.7	Water leak. Replaced two leaking tubes and corrected gasket leaks.
11/11	11/11	2.2	Trip due to a spline seal leak.
11/11	11/11	2.0	Trip due to a spline seal leak.
11/19	11/21	37.2	Removal of a stuck I&E-E metal rupture from tube 3890.

H Reactor - No outages

KE Reactor

10/8	11/3	624.9	Scheduled tube replacement.
11/3	11/3	0.5	Unexplained Panellit trip on tube 4477.

KW Reactor

10/29	11/21	527.1	Scheduled tube replacement.
11/21	11/22	1.9	Replacement of two faulty RTD's.
11/22	11/22	2.4	Unexplained Panellit trip.
11/22	11/22	1.0	Unexplained Panellit trip.
11/22	11/23	21.0	Trip caused by a VSR drop caused by a faulty latching mechanism.

**COMPARATIVE PILE PERFORMANCE - DEC 1963**

	<u>B</u>	<u>C</u>	<u>D</u>	<u>DR</u>	<u>F</u>	<u>H</u>	<u>KE</u>	<u>KW</u>	<u>TOTAL</u>
Max. Power Level to Date, MW	1,310	2,310	2,005	1,225	1,654 <sup>1</sup>	1,255	4,400	4,400	20,600
Max. Power Level During Month, MW	1,210	2,285	1,290	1,925	1,265 <sup>4</sup>	1,885	4,400	4,400	20,700
Avg Power Level While Operating, MW	1,894	2,134	1,914	1,913	1,805	1,771	4,148	4,148	19,673
Max. Tube Power, KW	1,297	1,366	1,258	1,261	1,224	1,752	1,393	1,393	
Effective Central Tubes	1,426	1,673	1,485	1,523	1,504	1,535	2,512	2,324	
Time-Operated Efficiency, %	80.7	75.1	90.1	77.8	77.0	85.4	76.6	92.5	
Operational Limitation	1540M <sup>2</sup>	95°C <sup>1</sup>	95°C <sup>1</sup>	1925M <sup>2</sup>	1935M <sup>2</sup>	95°C <sup>1</sup>	1400M <sup>2</sup>	1400M <sup>2</sup>	
MWD Produced During Month, total	49,712	49,696	53,813 <sup>3</sup>	43,714	43,105	46,893	97,767	107,126	
Normal	43,157	38,740	47,854	35,372	37,219	43,294	83,294	89,383	
94 Metal	6,255	10,956	5,959	8,342	5,886	46,266	13,773	18,443	
Plutonium Produced, gm	39,776	40,435	41,726	35,073	35,919	29,652	82,274	91,635	396,490
U in Reactor at North End, tons	223.7	223.3	224.0	219.2	221.0	192.0	454.5	452.1	2216.3
Normal	127.3	185.9	203.8	179.6	192.5	3.6	416.3	403.2	1782.2
94 Metal	26.4	37.4	20.2	39.6	28.5	195.4	38.2	48.9	134.6
U Discharged During Month, tons	104.8	20.7	59.8	11h.3	83.6	1.1	125.1	127.4	706.8
Normal	96.3	75.0	49.9	29.9	75.4	< 0.1	96.0	101.4	593.2
94 Metal	8.5	15.7	9.9	11.1	8.2	1.1	29.1	26.0	112.9
Avg Discharge Concentration									
Normal	773	765	922	657	628	708	903	758	
94 Metal	1,017	873	845	864	865	1,300	771	731	827

<sup>1</sup> Bulk outlet water temperature limit.

<sup>2</sup> Administrative limit.

<sup>3</sup> Key record.

<sup>4</sup> Operation momentarily exceeded established limit until revised by management.  
Extracted from Travis 1964a, page 6.

REACTOR OUTAGES DEC 1963

<u>Date</u>	<u>Date</u>	<u>Outage</u>	
<u>Down</u>	<u>Up</u>	<u>Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
12/9	12/11	64.8	Scheduled charge-discharge.
12/27	12/29	59.1	Removal of an I&E natural metal rupture from tube 2490.

C Reactor

12/4	12/6	57.9	Charge-discharge and leak testing following a Panellit trip.
12/17	12/19	53.0	Scheduled charge-discharge.
12/20	12/20	0.4	Unexplained Panellit trip.
12/23	12/23	0.3	Manual trip when hose came off the No. 7 HCR reel.
12/23	12/24	34.9	Insufficient reactivity. Replaced tube 2371 due to a rear Van Stone leak.
12/30	12/31	37.6	Removal of an I&E natural metal (overbore size) rupture from tube 2969.

D Reactor

12/11	12/14	69.2	Scheduled charge-discharge.
-------	-------	------	-----------------------------

DR Reactor

12/3	12/3	0.3	Unexplained Panellit trip.
12/4	12/5	30.6	Insufficient reactivity following a Panellit trip. Charge-discharge.
12/5	12/5	2.0	Panellit trip on tube 0592 caused by a partially plugged orifice screen.
12/13	12/15	36.3	Panellit trip when the Panellit panel was accidentally jarred. Charge-discharge and maintenance.
12/26	12/28	58.6	Removal of an I&E natural metal rupture from tube 2088. Charge-discharge.
12/30	12/31	30.0	Water leak in tube 0576. Charge-discharge and leak testing. Tube 0576 was replaced due to a rear Van Stone leak and tube 4681 was replaced because of an internal leak.

F Reactor

12/4	12/6	56.9	Scheduled charge-discharge
12/9	12/11	36.2	Leak testing. Corrected a rear Van Stone leak on tube 2073.
12/12	12/13	34.3	Water leak. Tube 2073 was replaced due to a rear Van Stone leak.
12/21	12/23	43.6	Removal of an I&E enriched metal rupture from tube 2676.

H Reactor

12/4	12/6	38.4	Removal of an I&E E-metal rupture from tube 2886.
12/15	12/17	31.2	Scheduled maintenance. Reworked nozzles installed on two horizontal rows.
12/24	12/25	29.8	Removal of suspected I&E E-metal ruptures from tubes 3381 and 3481. Inspection revealed one natural I&E (water mix) rupture in tube 3481.
12/31	Still down		Scheduled maintenance, charge-discharge and tube replacement.

Extracted from Plum 1964, December 1963, pages 2-5.

KE Reactor

12/6	12/8	33.8	Tripped by loop 2. Charge-discharge and RTD repair.
12/13	12/14	31.4	Tripped when loop 4 was inadvertently depressurized.
12/21	12/24	79.0	Scheduled charge-discharge.
12/28	12/29	33.9	Tripped because of a short in the connector of No. 2 flux monitor.

KW Reactor

12/2	12/3	33.8	Panellit trip on tube 4182 caused by a broken spline. Miscellaneous maintenance.
12/18	12/20	13.4	Panellit trip caused by a broken spline in tube 1155. Charge-discharge.
12/20	12/20	0.8	Unexplained Panellit trip on tube 0555 during spline work.
12/29	12/31	60.0	Scheduled charge-discharge and maintenance.

APPENDIX E

OPERATING DATA FOR 1964

<u>REACTORS</u>					
<u>1964</u>			<u>Inventory in Basins</u>		
	<u>Charged</u> Jan. Feb.	<u>Produced</u> Jan. Feb.	<u>Inventory in Reactor</u> Jan. Feb.	<u>Discharged</u> Jan. Feb.	<u>Jan.</u> <u>Feb.</u>
<u>Normal U (tons)</u>	367	484	1,764	385	485
M&D			736,473 737,944	263,047 340,762	1,535,224 1,829,041
<u>Pu (kg)</u>			696 655	218 292	1,297 1,549
<u>9L Metal (tons)</u>	300 <sup>3</sup>	276 <sup>5</sup>	607 <sup>4</sup> 825 <sup>6</sup>	248 57	971 856
M&D		97,191 109,506	147,897 210,596	235,818 47,207	501,460 805,796
<u>Pu (kg)</u>		65 79	109 155	166 32	634 567
<u>SEPARATIONS</u>					
<u>PUREX AND REDOX</u>					
	<u>Dissolved</u> Jan. Feb.	<u>Inventory in Process</u> Jan. Feb.	<u>Separated</u> Jan. Feb.	<u>Inventory of Product</u> Jan. Feb.	
<u>Normal U (tons)</u>	168	73	37 103	235 3	25 30
M&D	108,186	47,430			
<u>Pu (kg)</u>	93.3	39.6	14.9 44.6	178.9 0	77.4 20.0
<u>9L Metal (tons)</u>	184	178	40 38	185 180	167 187
M&D	159,879	149,880			
<u>Pu (kg)</u>	113.0	107.4	41.2 41.4	128.3 107.6	81.2 46.9

COMPARATIVE PILE PERFORMANCE

	B	C	JAN	D	1964	DR	P	H	KW	TOTAL
Max. Power Level to Date, MW	1,940	2,310	2,005	1,925	1,965	1,955	1,900	20,200	20,200	
Max. Power Level During Month, MW	1,940	2,310	2,005	1,925	1,935	1,955	1,900	20,370	20,370	
Avg Power Level While Operating, MW	1,353	2,201	1,919	1,873	1,906	1,890	1,851	20,365	20,365	
Max. Tube Power, KW	1,259	1,298	1,217	1,201	1,289	1,211	1,837	1,254	1,254	
Effective Central Tubes	1,128	1,652	1,522	1,508	1,496	1,504	2,395	2,509	2,509	
Time-Operated Efficiency, %	83.1	77.0	79.9	88.9	51.9	30.0	68.1	100.0	100.0	72.9
Operational Limitation	1940KW	2310KW	2005KW	1925KW	1935KW	1955KW	1900KW	1900KW	1900KW	
MW Produced During Month, total	52,108	52,108	51,698	51,605 <sup>1</sup>	30,633	19,395	91,217	116,180 <sup>1</sup>	116,180 <sup>1</sup>	
Normal	41,362	40,853	42,394	41,065	26,308	23.1	81,611	117,097	117,097	
94 Metal	6,344	11,555	5,904	10,510	4,325	19,164	10,276	19,083	19,083	
Plutonium Produced, gm	39,976	42,847	37,892	42,315	24,597	18,670	74,723	114,078	114,078	
U in Reactor at Month End, tons	222.6	222.6	222.8	219.4	221.0	201.5	152.1	2216.4	2216.4	
Normal	193.7	183.7	196.7	179.8	189.0	3.1	416.1	403.2	403.2	
94 Metal	28.9	38.9	26.1	39.6	33.0	198.1	38.3	1764.3	1764.3	
U Discharged During Month, tons	85.0	105.8	121.8	0.2	101.6	199.0	17.2	0	0	633.6
Normal	77.2	89.4	116.3	0.2	97.1	3.6	1.4	0	0	385.2
94 Metal	7.8	16.4	5.5	0	7.5	195.1	15.8	0	0	248.4
Avg Discharge Concentration										
Normal	587	623	879	555	582	611	673	683	683	
94 Metal	900	900	1,054	841	955	962	962	962	962	

<sup>1</sup> New record.  
Extracted from Travis 1964b, page 6.

REACTOR OUTAGES JAN 1964

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
1/7	1/10	88.0	Scheduled charge-discharge.
1/21	1/23	39.9	Removal of an I&E natural metal rupture from tube 2181. Replacement of tubes 2054 and 1169 due to rear Van Stone leaks.
<u>C Reactor</u>			
1/10	1/10	0.2	Unexplained Panellit trip.
1/10	1/12	42.8	Manual trip for temperature control; charge-discharge and maintenance.
1/18	1/22	93.2	Manual trip to remove an oversize I&E natural metal rupture from tube 3366; charge-discharge; problem tube 2473 was split and removed.
1/23	1/23	0.2	Unexplained Panellit trip.
1/24	1/25	34.5	Removal of a I&E-E metal rupture from tube 1888.
1/26	1/26	0.2	Unexplained Panellit trip.
<u>D Reactor</u>			
1/12	1/16	80.0	Scheduled charge-discharge and maintenance.
1/25	1/28	69.4	Charge-discharge and leak testing. Replaced tube 1279 due to an internal leak.

---

Extracted from Plum 1965, January 1964, pages 4-6.

DR Reactor

1/6	1/7	36.9	Removal of an I&E natural metal rupture from tube 1265.
1/10	1/12	37.0	Removal of an I&E natural metal rupture from tube 3663.
1/31	still down		Panellit trip due to a I&E natural metal rupture in tube 2263.

F Reactor

1/14	1/29	358.2	Removal of I&E E-metal rupture from tube 0678. Scheduled tube replacement, charge-discharge and maintenance.
------	------	-------	--

H Reactor

12/31	1/20	486.7	Scheduled maintenance, charge-discharge and tube replacement.
1/20	1/20	0.2	Tripped when one flux monitor stuck at a high trip and another flux monitor was adjusted to a low trip.
1/21	1/21	12.0	Manual trip for temperature control.
1/22	1/22	0.9	Repair of a faulty ball valve on tube 2788.

KE Reactor

1/17	1/19	36.9	Questionable integrity of a front-face pigtails. Eight pigtails were replaced due to broken wire strands.
1/23	still down		Scheduled tube replacement.

KW Reactor

No outages

**COMPARATIVE PILE PERFORMANCE**

	B	C	D	E	F	G	H	I	J	K	L	M
Max. Power Level to Date, MW	2,075 <sup>1</sup>	2,310	2,000 <sup>1</sup>	2,015 <sup>1</sup>	2,000 <sup>1</sup>	2,050 <sup>1</sup>						
Max. Power Level During Month, MW	2,075	2,310	2,010	2,015	2,000	2,050	2,050	2,050	2,050	2,050	2,050	2,050
Avg Power Level While Operating, MW	1,895	2,262	1,799	1,928	1,900	1,667	1,102	1,266	1,266	1,266	1,266	1,266
Max. Tube Power, kW	1,416	1,408	1,313	1,261	1,312	1,324	1,775	1,775	1,775	1,775	1,775	1,775
Effective Central Tubes	1,412	1,640	1,500	1,570	1,497	1,578	2,479	2,479	2,479	2,479	2,479	2,479
Time-Operated Efficiency, %	81.5	79.5	87.3	86.9	86.7	93.8	93.1	93.1	93.1	93.1	93.1	93.1
Operational Limitation	950c	950c	950c	950c	950c	20900MW	14000MW	14000MW	14000MW	14000MW	14000MW	14000MW
MWD Produced During Month, total	14,781	52,134	50,609	48,567	47,760	53,519	51,923	52,816	52,816	52,816	52,816	52,816
Normal	38,330	10,272	12,990	38,600	10,712	6,126	15,126	15,126	15,126	15,126	15,126	15,126
94 Metal	6,451	11,862	7,619	9,927	7,017	52,878	6,797	7,355	7,355	7,355	7,355	7,355
Plutonium Produced, gm	36,379	42,258	41,216	39,506	39,044	39,816	48,616	46,682	46,682	46,682	46,682	46,682
U in Reactor at Month End, tons	222.5	222.7	222.6	219.2	221.3	201.4	159.9	152.1	152.1	152.1	152.1	152.1
Normal	193.6	181.1	196.2	179.7	189.2	31.1	111.9	103.2	103.2	103.2	103.2	103.2
94 Metal	28.9	38.6	26.1	39.5	32.1	198.3	45.0	48.9	48.9	48.9	48.9	48.9
U Discharged During Month, tons	82.1	90.6	71.3	66.4	68.8	0.2	221.7	54.1	54.1	54.1	54.1	54.1
Normal	77.0	71.1	62.8	58.9	67.1	<0.1	208.2	184.7	184.7	184.7	184.7	184.7
94 Metal	5.4	19.5	8.5	7.5	2.1	0.2	13.5	56.7	56.7	56.7	56.7	56.7
Avg Discharge Concentration	636	624	745	584	685	664	375	776	776	776	776	776
Normal	886	788	905	1,002	664	769	703	833	833	833	833	833

E.5

<sup>1</sup> New record.  
Extracted from Travis 1964c, page 6.

REACTOR OUTAGES FEB 1964

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
2/16	2/20	93.7	Scheduled charge-discharge.
2/22	2/24	35.2	Correction of a front-face cap leak (faulty O-ring). Replaced tube 3693 due to an internal leak.
<u>C Reactor</u>			
2/9	2/11	44.9	Removal of an I&E E-metal rupture from tube 3465.
2/25	2/29	98.0	Scheduled charge-discharge.
<u>D Reactor</u>			
2/20	2/24	88.4	Removal of an I&E natural metal rupture from tube 3473. Replace- ment of tube 3473. Charge-discharge.
<u>DR Reactor</u>			
1/31	2/3	62.0	Charge-discharge and rupture removal.
2/4	2/6	36.3	Leak testing. Tube 1857 was replaced due to a leaking Van Stone flange.
2/6	2/6	1.8	Correction of a front nozzle adapter leak on tube 3590.

---

Extracted from Plum 1965, February 1964, pages 3-4.

F Reactor

2/7	2/8	36.5	Removal of an I&E E-metal rupture from tube 3781.
2/24	2/26	55.0	Removal of an I&E E-metal rupture from tube 2257. Leak testing; replaced 4 tubes due to rear Van Stone flange leaks.
2/26	2/26	0.2	Panellit trip due to a faulty relay on Row 27.

H Reactor

2/22	2/23	30.1	Removal of an I&E E-metal rupture from tube 1377.
2/23	2/24	12.7	Removal of an I&E E-metal rupture from tube 1987.

KE Reactor

1/23	2/15	559.8	Scheduled tube replacement; 575 zirconium and 53 aluminum tubes were installed.
2/16	2/16	0.5	Panellit trip caused by a broken spline in tube 2546.
2/24	2/26	35.4	Tripped when a power operator interrupted the electrical service to the KER loop pumps. Miscellaneous maintenance.

KW Reactor

2/12	Still down	Schedule tube replacement.
------	------------	----------------------------

REACTORS						Inventory in Basins			
			1964				Mar. Apr.		
		Charged	Produced	Inventory in Reactor	Discharged				
		Mar.	Apr.	Mar.	Apr.	Mar.	Apr.	Mar.	Apr.
Normal U (tons)	458	857		1,765	1,762	456	860	2,154	2,703
MD		389,423	334,435	790,419	503,784	336,948	621,070	1,604,894	1,964,695
Pu (kg)		335	293	702	457	288	537	1,357	1,677
9L Metal (tons)	91	291		829 <sup>2</sup>	831 <sup>2</sup>	87	288	942	1,108
MD		129,500	84,983	257,791	132,644	82,350	210,130	885,806	989,142
Pu (kg)		91	62	188	99	58	152	624	700
<u>SEPARATIONS</u>						1964			
PUREX AND REDOX						Inventory of Product			
			1964		1964		Mar.	Apr.	
		Dissolved	Inventory in Process		Separated		Inventory of Product		
Normal U (tons)		817	305	113	119	805	298	234	124
MD		558,322	257,052						
Pu (kg)		479.4	204.5	96.8	61.6	425.5	240.5	156.8	18.7
9L Metal (tons)		0	120	5	36	29	89	59	68
MD		106,090							
Pu (kg)		2.01	75.2	5.7 <sup>2</sup>	32.0	27.0	52.8 <sup>3</sup>	45.4	92.2

1 Includes 2 pieces unenriched at KER loops.  
 2 Includes 368 tons from N reactor.

1 PRTR.  
 2 3.7 kg Regular and 2.0 kg PRTR.  
 3 Includes 6.3 kg from PRTR.

COMPARATIVE PILE PERFORMANCE					
B	C	MAR D	1964	DR	
Max. Power Level to Date, MW	2,075	2,310	2,040	2,015	2,090
Max. Power Level During Month, MW	2,090 <sup>1</sup>	2,365 <sup>1</sup>	2,055 <sup>1</sup>	2,015 <sup>1</sup>	2,110 <sup>1</sup>
Avg. Power Level While Operating, MW	2,030	2,237	1,996	1,963	2,02
Max. Tube Power, KW	1,392	1,453	1,348	1,263	1,343
Effective Central Tubes	1,487	1,608	1,506	1,576	1,644
Time-Operated Efficiency, %	51.7	85.7	91.5	66.9	54.5
Operational Limitation	95.0	95.0	95.0	95.0	95.0
RMD Produced During Month, total	32,532	59,446	56,596 <sup>1</sup>	40,304	58,907 <sup>1</sup>
Normal	27,818	45,668	48,286	32,100	32,096
94 Metal	4,714	13,778	8,310	8,204	8,067
Plutonium Produced, gm	26,344	48,666	45,314	32,248	33,324
U in Reactor at Month End, tons	222.6	222.2	222.9	219.2	217.5
Normal	193.5	181.5	197.6	179.7	174.7
94 Metal	29.1	40.7	25.3	39.5	42.8
U Discharged During Month, tons	9.4	78.8	15.3	85.3	89.9
Normal	4.6	61.6	11.2	68.3	81.2
94 Metal	4.8	11.2	11.0	17.0	8.7
Avg Discharge Concentration	580	625	594	635	570
Normal	927	874	618	985	805
94 Metal					525

REACTOR OUTAGES MAR 1964

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
<u>B Reactor</u>			
3/11	3/13	54.6	Removal of an I&E natural metal rupture from tube 2181. Tubes 0984 and 3251 were replaced due to internal leaks.
3/19	still down		Scheduled charge-discharge and tube replacement.
<u>C Reactor</u>			
3/2	3/2	0.2	Trip due to the malfunction of the temperature control system on No. 1 loop.
3/5	3/5	0.2	Manual trip due to high pressure surge on HCR cooling water.
3/5	3/6	35.1	Removal of an I&E-E metal rupture from tube 2876.
3/7	3/7	0.3	Manual trip due to indicated high tube temperature. Instrumentation was found in error.
3/25	3/27	70.4	Scheduled charge-discharge.
<u>D Reactor</u>			
3/7	3/9	57.3	Repair of a leak in the fire and sanitary water line; charge-discharge and leak testing. New flanges were formed on tubes 3164 and 3184.
3/31	still down		Panellit trip due to the failure of a rear Parker fitting on tube 3261. Will remain down for scheduled tube replacement.

---

Extracted from Plum 1965, March 1964, pages 2-4.

DR Reactor

3/9	3/11	35.8	High pressure Panellit trip; removal of an I&E natural metal rupture from tube 3975.
3/11	3/20	210.3	Removal of an I&E-E metal (bumpered) rupture from tube 2464. Charge-discharge and replacement of 149 tubes.

F Reactor

3/4	3/15	247.6	Removal of an I&E-E metal rupture from tube 2167. Charge-discharge and replacement of 152 process tubes.
3/31	still down		Scheduled charge-discharge.

H Reactor

3/1	3/2	24.8	Removal of an I&E-E metal rupture from tube 2888.
3/14	3/15	26.7	Removal of an I&E-E metal rupture from tube 3773.

KE Reactor

No outages

KW Reactor

2/13	3/10	520.0	Replacement of 672 tubes.
3/10	3/10	1.7	RTD repair.

COMPARATIVE PILE PERFORMANCE				APR 1964				TOTAL			
B	C	D	DR	P	H	KW		B	C	D	DR
Max. Power Level to Date, MW	2,075	2,310	2,040	2,015	2,000	2,090	1,400	1,400	1,400	1,400	21,330
Max. Power Level During Month, MW	1,295	2,260	1,250	1,265	1,250	2,080	1,400	1,400	1,400	1,400	21,000
Avg. Power Level While Operating, MW	1,853	2,178	1,823	1,880	1,769	1,769	1,185	1,185	1,185	1,185	17,713
Max. Tube Power, KW	1,347	1,297	1,337	1,245	1,295	1,322	1,778	1,778	1,778	1,778	1,812
Effective Central Tubes	1,177	1,705	1,459	1,564	1,428	1,500	2,475	2,475	2,475	2,475	2,435
Time-Operated Efficiency, %	77.1	83.6	38.5	68.4	71.5	68.4	89.1	89.1	89.1	89.1	67.5
Operational Limitation	95.00%	95.00%	95.00%	95.00%	95.00%	95.00%	100.00%	100.00%	100.00%	100.00%	
MOB Produced During Month, total	42,874	54,616	21,039	38,590	37,527	22,237	85,959	116,516	116,516	116,516	116,516
Normal	36,125	41,344	18,065	30,674	30,000	277	75,181	102,469	102,469	102,469	102,469
94 Metal	6,649	13,302	2,974	7,916	7,527	21,960	10,778	14,077	14,077	14,077	14,077
Plutonium Produced, gm	36,058	44,228	18,061	31,020	30,731	16,945	75,288	102,462	102,462	102,462	102,462
U in Reactor at Month End, tons	222.8	221.8	223.1	219.2	218.5	200.4	459.3	460.0	460.0	460.0	460.0
Normal	192.3	181.1	197.7	180.6	180.3	180.3	409.7	417.2	417.2	417.2	417.2
94 Metal	30.5	40.7	25.4	38.6	38.2	197.3	49.6	42.8	42.8	42.8	42.8
U Discharged During Month, tons	115.8	99.8	104.3	90.5	85.4	184.5	371.0	187.1	187.1	187.1	187.1
Normal	99.8	99.8	92.3	82.0	70.8	3.6	331.9	178.6	178.6	178.6	178.6
94 Metal	16.0	8.6	12.0	8.5	14.6	180.9	39.1	8.5	8.5	8.5	8.5
Avg Discharge Concentration	550	593	634	635	578	455	778	861	861	861	722
Normal	739	791	802	945	591	676	882	986	986	986	729

Extracted from Travis 1964e, page 6.

REACTOR OUTAGES APR 1964

B REACTOR

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
3/19	4/4	395.3	Replacement of 454 tubes. Charge-discharge and miscellaneous maintenance.
4/8	4/9	36.6	Tripped when a front face cap O-ring failed on tube 3189.
4/23	4/25	37.6	Removal of an I&E natural metal rupture from tube 2772. Miscellaneous maintenance.

C REACTOR

4/13	4/15	51.1	Removal of an I&E enriched metal rupture from tube 1681. Charge-discharge.
4/15	4/15	8.7	Removal of an I&E enriched metal rupture in tube 3960.
4/28	still down		Removal of an I&E enriched metal rupture in tube 3181. Charge-discharge and maintenance.

D REACTOR

3/31	4/16	379.5	Panellit trip due to the failure of a rear Parker fitting on tube 3261. Replacement of 263 tubes, charge-discharge and maintenance.
4/16	4/17	22.5	Removal of an I&E enriched metal rupture in tube 1958.
4/22	4/24	42.8	I&E natural metal rupture was removed by pushing tube (2361) and metal. Miscellaneous maintenance.

---

Extracted from Plum 1965, April 1964, pages 4-6.

DR REACTOR

4/15	4/22	154.5	Removal of an I&E enriched metal rupture from tube 3257. Charge-discharge and replacement of 61 process tubes.
4/22	4/22	1.6	Removal of an I&E enriched metal rupture from tube 2058.
4/23	4/25	34.8	Removal of an I&E enriched metal rupture from tube 3357.
4/25	4/25	2.1	Manually tripped due to 3 front pigtail leaks.
4/29	still down		Removal of an I&E enriched metal rupture from tube 3788.

F REACTOR

3/31	4/2	46.4	Scheduled charge-discharge. Replaced 3 tubes due to rear Van Stone leaks.
4/6	4/7	38.3	Removal of an I&E enriched metal rupture from tube 0678.
4/15	4/19	86.5	Removal of an I&E natural metal rupture from tube 1189. Charge-discharge.
4/19	4/19	0.2	Low pressure Panellit trip on tube 4388.
4/19	4/19	0.2	Thermocouple repair.
4/23	4/24	34.7	High pressure Panellit trip on tube 3464 when a spline was being withdrawn.

H REACTOR

4/3	4/4	29.0	Removal of an I&E enriched metal rupture from tube 3486.
4/4	4/5	9.6	Removal of an I&E enriched metal rupture from tubes 3059, 2962 and 2057.
4/5	4/18	343.0	Removal of I&E enriched metal ruptures from tubes 2056 and 1785, and I&E natural (mixer) from tube 2058. Charge-discharge of E-N block and replacement of 146 tubes.
4/19	4/19	7.8	Poison discharge.
4/23	4/24	41.6	Investigation of abnormal flux distribution. 172 tubes in the E-N load were recharged.

KE REACTOR

4/1	4/5	45.5	Scheduled charge-discharge.
4/5	4/5	2.2	RTD repair.
4/6	4/6	0.3	Tripped when a broken spline in tube 0967 washed down stream.
4/7	4/8	26.7	Tripped when a broken spline in tube 4458 washed down stream.
4/26	4/30	81.4	Tripped by KER 3 due to faulty instrumentation on the heat ex- changer exit temperature. Charge- discharge.
4/30	4/30	0.4	Panellit trip caused by a faulty gauge.
4/30	4/30	0.6	Unexplained Panellit trip on 4861.

KW REACTOR

4/13	4/16	78.6	Scheduled charge-discharge.
------	------	------	-----------------------------

---

Extracted from Plum 1965, April 1964, pages 4-6.

REACTORS					
1964					
Charged		Produced		Inventory in Basins	
May	June	May	June	May	June
<u>Normal U</u> (tons)	462	713		1,777	1,784
<u>Md</u>		409,813	379,924	631,307	579,026
<u>Pu</u> (kg)		363	332	574	525
<u>9L Metal</u> (tons)	80	70		819 <sup>2</sup>	811 <sup>2</sup>
<u>Md</u>		132,288	128,372 <sup>4</sup>	201,791	269,196 <sup>4</sup>
<u>Pu</u> (kg)		97	93 <sup>4</sup>	151	200 <sup>4</sup>

1 Includes 2 pieces unenriched at KER loops.

2 Includes 368 tons from N reactor.

3 Includes 2 pieces at 8 units unenriched KER loop and 3 cold pieces received and returned to cold storage.  
4 Includes NMR.

SEPARATIONS  
/964

PUREX AND REDOX					
Inventory of Product					
In Process		Separated		May June	
May	June	May	June	May	June
<u>Normal U</u> (tons)	478	707	117	95	471 727
<u>Md</u>	299,325	588,507			64 203
<u>Pu</u> (kg)	253.9	502.6	59.9	89.1	252.2 472.0
<u>9L Metal</u> (tons)	181	79	42	37	175 86
<u>Md</u>	153,587	68,759			103 91
<u>Pu</u> (kg)	111.3	49.2	35.5	25.2	107.4 59.3

**COMPARATIVE PILE PERFORMANCE**

	B	C	D	DR	P	H	KJ	TOTAL
Max. Power Level to Date, MW	2,075	2,310	2,015		2,000	2,000	4,400	21,330
Max. Power Level During Month, MW	1,775	2,210	1,955	1,910	1,985	1,910	4,400	20,775
Avg. Power Level While Operating, MW	1,808	2,101	1,892	1,835	1,813	1,813	4,330	20,127
Max. Tube Power, KW	1,283	1,396	1,294	1,212	1,277	1,241	1,759	1,935
Effective Central Tubes	1,512	1,886	1,680	1,508	1,696	1,500	2,500	2,398
Time-Operated Efficiency, %	75.6	80.8	89.0	85.2	80.8	96.5	91.3	85.9
Operational Limitation	95.0°C	95.0°C	95.0°C	95.0°C	95.0°C	1310KW	1400KW	
MtD Produced During Month, total	42,362	52,624	52,162	48,160	46,158	46,294	111,792	512,101
Normal	36,228	40,195	44,387	39,030	38,951	38,738	101,233	409,813
94% Metal	6,134	12,429	7,775	9,430	7,305	57,556	18,011	13,648
Plutonium Produced, gm	34,990	42,943	43,251	39,516	37,935	43,458	111,578	459,973
U in Reactor at Month End, tons	223.4	220.9	222.8	219.5	220.2	200.3	159.8	460.9
Normal	194.9	181.6	195.7	181.2	187.1	171	112.2	420.9
94% Metal	28.5	39.3	27.1	38.3	35.1	197.2	47.6	451.1
U Discharged During Month, tons	79.0	96.8	55.3	20.9	85.1	0.2	21.0	180.7
Normal	68.4	74.4	49.6	6.2	69.2	<0.1	15.4	16.6
94% Metal	10.6	22.4	5.7	14.7	15.9	0.2	5.6	92.2
Avg Discharge Concentration	612	618	611	607	608	-	999	637
Normal	630	693	817	661	679	445	913	790
94% Metal								685

Extracted from Travis 1964f, page 6.

REACTOR OUTAGES MAY 1964

B REACTOR

<u>Date Down</u>	<u>Date Up</u>	<u>Outages Hours</u>	<u>Remarks</u>
5/4	5/6	38.1	Power failure trip caused by a faulty voltage regulator at 190-B Annex, and other miscellaneous maintenance.
5/13	5/16	50.9	Scheduled charge-discharge.
5/19	5/20	34.5	Removal of an I&E enriched metal rupture from tube 3688.
5/27	5/29	56.4	Removal of an I&E enriched metal rupture from tube 4071.

C REACTOR

4/28	5/2	98.2	Removal of an I&E enriched metal rupture from tube 3181.
5/4	5/5	33.7	Removal of an I&E enriched metal rupture from tube 3173. Miscellaneous maintenance.
5/10	5/12	35.7	Removal of an I&E enriched metal rupture from tube 3960.
5/13	5/13	0.3	Scrammed when instrument air to C-1 loop was inadvertently shut off.
5/20	5/21	35.1	Removal of an I&E natural metal rupture from tube 3361.

D REACTOR

5/2	5/4	35.8	Removal of an I&E natural metal rupture from tube 1281.
5/17	5/18	46.3	Scheduled charge-discharge.

---

Extracted from Plum 1965, May 1964, page 3-4.

DR REACTOR

4/29	5/1	39.3	Removal of an I&E enriched metal rupture from tube 3788.
5/2	5/3	33.0	Removal of an I&E enriched metal rupture from tube 2958.
5/5	5/7	28.3	Removal of an I&E natural metal rupture from tube 1179.
5/15	5/17	35.6	Removal of an I&E natural metal rupture from tube 1184.

F REACTOR

5/2	5/4	51.4	Removal of an I&E enriched metal rupture from tube 1290.
5/5	5/6	28.3	Removal of an I&E enriched metal rupture from tube 0662.
5/23	5/26	63.2	Scheduled charge-discharge.

H REACTOR

5/28	5/29	26.2	Removal of an I&E enriched metal rupture from tube 2676.
------	------	------	---

KE REACTOR

5/1	5/1	0.2	Panellit trip caused by a broken spline in tube 5182.
5/17	5/19	38.9	Panellit trip and miscellaneous maintenance.

KW REACTOR

5/11	5/15	113.4	Scheduled charge-discharge and maintenance.
------	------	-------	--

COMPARATIVE PILE PERFORMANCE						
B	C	D	E	F	G	KW
Max. Power Level to Date, MW	2,090	2,365	2,055	2,015	2,110	4,400
Max. Power Level During Month, MW	1,885	2,130	1,885	1,850	1,880	4,400
Avg Power Level While Operating, MW	1,855	2,035	1,860	1,807	1,811	4,305
Max. Tube Power, KW	1,225	1,324	1,240	1,190	1,195	4,229
Effective Central Tubes	1,522	1,603	1,504	1,529	1,536	1,770
Time-Operated Efficiency, %	91.9	80.9	83.6	88.1	86.6	1,712
Operational Limitation	95°C	95°C	95°C	95°C	95°C	2,495
MWD Produced During Month, total	51,148	49,431	46,646	47,774	53,755	106,195
Normal	44,060	37,719	35,225	38,209	40,598	500,780
94 Metal	7,088	11,712	7,421	9,465	7,214	92,679
Plutonium Produced, gm	42,151	41,761	36,909	38,817	38,733	11,364
U in Reactor at Month End, tons	223.1	220.1	222.0	219.2	220.2	11,364
Normal	194.6	180.1	194.7	181.0	187.5	13,516
94 Metal	28.5	40.0	27.3	38.2	32.7	120,856
U Discharged During Month, tons	63.6	77.6	152.1	69.5	3.8	1,783
Normal	59.8	70.5	132.4	64.9	0.1	94,750
94 Metal	3.8	7.1	19.7	4.6	3.7	85.6
Avg Discharge Concentration	624	639	586	565	320	81.8
Normal	620	788	801	1,029	-	1,000
94 Metal	780	-	-	-	-	799

Extracted from Travis 1964g, page 6.

REACTOR OUTAGES  
B REACTOR

JUN 1964

<u>Date Down</u>	<u>Date Up</u>	<u>Outage Hours</u>	<u>Remarks</u>
6/16	6/19	58.3	Scheduled charge-discharge.

C-REACTOR

6/3	6/6	75.9	Scheduled charge-discharge and miscellaneous maintenance.
6/6	6/6	0.3	Unexplained Panellit trip.
6/6	6/7	19.8	Shut down for the correction of a water leak. Replaced tube 2469 due to a rear Van Stone flange leak.
6/13	6/13	0.1	Unexplained Panellit trip.
6/13	6/15	23.2	Manual trip to control high tube temperature.
6/15	6/15	5.9	Removal of an overbore I&E natural metal rupture from tube 3363.
6/15	6/15	0.2	Beckman trip due to a faulty range change switch.
6/15	6/15	0.2	Manual trip due to a false indication of a fast rate of rise.

D REACTOR

6/22	6/27	115.3	Scheduled charge-discharge.
6/27	6/27	2.9	Scrammed by an unexplained Panellit trip on tube 0282.

---

Extracted from Plum 1965, June 1964, pages 2-4.

DR REACTOR

6/1	6/2	41.6	Scheduled charge-discharge.
6/3	6/5	54.1	Removal of an I&E natural metal rupture from tube 3679.
6/30	still down		Scheduled charge-discharge.

F REACTOR

6/4	6/6	36.7	Shut down for the correction of a front face cap leak. The cap was not fully engaged. Miscellaneous maintenance.
6/6	6/6	0.3	Manually tripped due to insufficient control when spline insertion equipment failed.
6/28	still down		Scheduled charge-discharge.

H REACTOR

6/8	6/9	27.7	Shut down for the correction of leaking front pigtail on tube 2353.
-----	-----	------	--

KE REACTOR

6/7	6/11	110.3	Tripped when a broken spline washed downstream in tube 1967. Scheduled charge-discharge.
6/14	6/15	33.2	Shut down for the correction of a front pigtail leak on tube 0392.
6/17	6/18	35.0	Tripped by a broken spline in tube 3370.

KW REACTOR

6/14	6/18	79.2	Tripped by a broken Panellit sensing line fitting on tube 3351. Scheduled charge-discharge.
6/19	6/19	1.5	Panellit trip caused by a broken spline in tube 5149.
6/19	6/20	49.6	Shut down to investigate the broken spline problem.

---

Extracted from Plum 1965, June 1964, pages 2-4.

<u>REACTORS</u>									
<u>1964</u>									
<u>Charged</u>		<u>Produced</u>		<u>Inventory in Reactor</u>		<u>Discharged</u>		<u>Inventory in Basins</u>	
		July	Aug.	July	Aug.	July	Aug.	July	Aug.
<u>Normal U (tons)</u>	5931	326		1,722	1,729 <sup>3</sup>	616	331	3,00 <sup>2</sup>	2,195
<u>Mu</u>		370,083	344,279 <sup>3</sup>	515,018	639,082 <sup>3</sup>	403,991	200,315	2,001,876	1,634,619 <sup>3</sup>
<u>Pu (kg)</u>		325	296 <sup>3</sup>	496	616 <sup>3</sup>	354	176	1,741	1,467 <sup>3</sup>
<u>2L Metal (tons)<sup>8</sup></u>	308	71 <sup>5</sup>		859 <sup>2</sup>	864 <sup>2</sup>	260	66 <sup>6</sup>	1,153	1,155 <sup>7</sup>
<u>Mu</u>		128,741 <sup>4</sup>	143,759 <sup>4</sup>	191,873 <sup>4</sup>	296,312 <sup>4</sup>	205,403	39,370 <sup>4</sup>	985,822	932,172 <sup>4</sup>
<u>Pu (kg)</u>	994	105 <sup>4</sup>		150 <sup>4</sup>	226 <sup>4</sup>	148	28 <sup>4</sup>	697	662 <sup>4</sup>

1 Includes 8.9 tons special depleted.  
 2 Includes 360 tons from N reactor.  
 3 Includes special depleted production.  
 4 Includes MPR.  
 5 Includes 25 tons in N reactor.  
 6 Includes 25 tons from N reactor.  
 7 Includes 1.9 tons from N reactor.  
 8 Includes 1.25 metal in N reactor.

SEPARATIONS

1964

<u>PUREX AND REDOX</u>									
<u>1964</u>									
<u>Dissolved</u>		<u>Inventory in Process</u>		<u>Separated</u>		<u>Inventory of Product</u>			
		July	Aug.	July	Aug.	July	Aug.	July	Aug.
<u>Normal U (tons)</u>	317	838	124	95	289	856	191	380	
<u>HWD</u>	200,688	524,843							
<u>Pu (kg)</u>	169.8	149.3	69.0	34.8	177.7	1493.4	40.7	87.1	
<u>2L Metal (tons)</u>	129	85	18	49	147	55	212	114	
<u>R&amp;D</u>	115,131	90,426							
<u>Pu (kg)</u>	83.5	62.3	19.6	53.9	88.6	28.1	26.9	46.9	

COMPARATIVE PILE PERFORMANCE						N REACTOR PILE PERFORMANCE													
B		C		D		E		F		G		H		I		Kw		TOTAL	
Max. Power Level to Date, MW	2,090	2,365	2,055	2,015	2,015	2,110	4,400	21,450											
Max. Power Level During Month, MW	1,855	2,125	1,815	1,825	1,825	1,905	4,400	20,180											
Avg Power Level While Operating, MW	1,776	2,011	1,600	1,762	1,762	1,711	4,277	19,503											
Max. Tube Power, KW	1,197	1,313	1,241	1,162	1,162	1,210	1,233	1,707	1,753										
Effective Central Tubes	1,550	1,613	1,487	1,536	1,536	1,483	1,533	2,504	2,644										
Time-Operated Efficiency, %	65.3	39.1	94.3	88.6	88.6	75.6	86.8	82.2	78.0										
Operational Limitation	95.0	95.0	95.0	95.0	95.0	95.0	95.0	95.0	95.0										
MWD Produced During Month, total	36,151	24,721	52,894	48,393	47,923	43,383	119,044	108,226	1480,725										
Normal	30,532	18,812	43,823	39,321	40,456	50,3	101,375	95,218	370,983										
94 Metal	5,619	5,909	9,061	9,069	7,467	42,810	17,669	13,008	110,642										
Plutonium Produced, gm	28,995	19,783	44,300	39,690	39,618	32,871	104,393	95,931	1406,131										
U in Reactor at Month End, tons	213.7	221.7	221.9	219.7	220.0	200.7	455.9	461.0	2213.7										
Normal	160.5	181.3	194.0	183.0	185.8	3.1	392.3	420.8	1722.4										
94 Metal	53.1	40.4	27.9	36.7	33.2	197.6	62.2	40.2	491.3										
U Discharged During Month, tons	111.5	96.6	0.9	88.8	105.2	182.8	154.5	165.5	905.9										
Normal	100.6	74.2	0.8	72.8	95.1	3.1	116.7	152.9	615.2										
94 Metal	10.9	22.1	0.1	16.0	10.1	179.7	7.9	12.6	259.7										
Avg Discharge Concentration	560	651	72	600	622	559	643	657	625										
Normal	810	833	8	802	801	774	885	852	790										
Fuel Balance (Ton)																			
Input Production Pu (KgID)	18.1																		
Input Production T (KgID)	0																		
Max-Rum Power Level Attained (MW)	1600																		
Average Power Level While Operating (MW)	1110																		
Time-Operated Efficiency (%)	56.9																		
Plant Utilization (%)																			

Extracted from Travis 1964h, pages 6 and 6a.

REACTOR OUTAGES JUL 1964

<u>Date</u>	<u>Date</u>	<u>Outage</u>	<u>Remarks</u>
<u>Down</u>	<u>Up</u>	<u>Hours</u>	
<u>B Reactor</u>			
7/18	7/29	257.6	Scheduled outage for charge-discharge. Miscellaneous maintenance.
7/29	7/29	0.7	Panellit trip due to a leaking toggle valve.
<u>C Reactor</u>			
7/9	7/28	442.4	Scheduled charge-discharge, tube replacement and foaming of rear-face bellows.
7/31	Still down		Removal of an overbore rupture from tube 1459.
<u>D Reactor</u>			
7/5	7/6	25.7	Unexplained Panellit trip on gauge 0969. Replaced tube 1257 due to a rear Van Stone leak.
<u>DR Reactor</u>			
6/30	7/2	69.5	Scheduled charge-discharge.
7/2	7/2	1.2	Corrected a faulty thermocouple on tube 2472.
7/13	7/15	36.4	Stuck I&E natural metal rupture in tube 3160.
7/31	Still down		Removal of a stuck I&E enriched rupture from tube 1858.

---

Extracted from Plum 1965, July 1964, pages 2-3.

F Reactor

6/28	7/1	69.5	Scheduled charge-discharge.
7/1	7/1	2.5	Correction of a rear cap leak on tube 2164.
7/4	7/5	34.1	Unexplained Panellit trip on gauge 4073.
7/18	7/19	37.3	Removal of a stuck I&E enriched metal rupture from tube 4174.

H Reactor

7/5	7/12	171.6	Scheduled (block) charge-discharge.
7/13	7/13	9.9	Poison discharge.

KE Reactor

7/12	7/15	76.1	Scheduled charge-discharge.
------	------	------	-----------------------------

KW Reactor

7/2	7/4	41.5	Removal of an I&E enriched metal rupture from tube 4755.
-----	-----	------	---

COMPARATIVE PILE PERFORMANCE						REF.	
B	C	AUG 1964	D	DR	F	H	K
Max. Power Level to Date, MW	2,020	2,355	2,055	2,015	2,015	2,110	4,160
Max. Power Level During Month, MW	1,755	2,050	1,785	1,750	1,765	1,815	4,150
Avg. Power Level While Operating, MW	1,651	1,776	1,713	1,705	1,732	1,735	4,255
Max. Tube Power, KW	1,210	1,310	1,173	1,173	1,169	1,169	1,127
Effective Central Tubes	1,139	1,553	1,498	1,498	1,481	1,453	1,620
Time-Operated Efficiency, %	83.1	86.0	81.0	81.0	78.1	71.5	73.2
Operational Limitation	95°C	95°C	95°C	95°C	95°C	95°C	95°C
MD Produced During Month, total	12,518	52,685	49,290	41,305	49,154	56,797	104,747
Normal	20,226	39,265	41,209	33,774	42,045	712	174,753
94 Metal	12,282	12,720	8,081	7,531	7,109	56,085	21,257
Plutonium Produced, gm	35,704 <sup>2</sup>	40,439	38,711	34,178	40,403	41,363	65,698
U in Reactor at Month End, tons	210.2	221.7	223.3	219.9	221.1	200.5	155.0
Normal	117.8	181.3	197.0	184.3	189.4	131	161.0
94 Metal	62.4	40.4	26.3	35.6	31.7	197.4	39.9
U Discharged During Month, tons	26.9	13.3	30.3	78.2	68.3	0	155.4
Normal	21.5	13.3	25.3	66.2	61.6	-	139.7
94 Metal	2.4	-	5.0	11.3	6.7	-	15.7
Avg Discharge Concentration	454	585	-	731	549	602	-
Normal	863	-	1,028	950	756	-	-
N REACTOR PILE PERFORMANCE						REF.	
AUG 1964	AUG 1964	AUG 1964	AUG 1964	AUG 1964	AUG 1964	AUG 1964	AUG 1964
Input Production Plutonium (KWD)	13.2	Fuel Balance (Ton)	0.34	1.25	Total		
Output Production T (KWD)	0	Fuel Charged	6.23	18.77	35.0		
Maximum Power Level Attained (MW)	2300	Fuel Discharged	25.10	0	25.10		
Average Power Level While Operating (MW)	1560	Net Change	-19.37	+18.77	-0.10		
Time-Operated Efficiency (%)	27.1	Total in Reactor					
Plant Utilization (%)	-28.7	at Month End	331.39	36.43	367.82		

1 Includes 1,025 KWD from special depleted material.

2 Includes 1,954 grams from special depleted material.

Extracted from Travis 1964i, pages 6 and 6a.

REACTOR OUTAGES AUG 1964

DATE DOWN	DATE UP	OUTAGES HOURS	REMARKS
<b>B REACTOR</b>			
8/16	8/18	37.2	Removal of an I&E natural metal rupture from tube 0863.
8/23	8/25	53.5	Removal of an I&E natural metal rupture from tube 3976. charge-discharge and tube replacement.
8/26	8/28	35.2	Down for temperature control on two process tubes. Charge-discharge and miscellaneous maintenance.
<b>C REACTOR</b>			
7/31	8/2	36.4	Removal of an overbore rupture from tube 1459.
8/4	8/5	33.7	Unexplained Panellit trip on tube 1271.
8/5	8/5	2.7	Faulty thermocouple on tube 3162.
8/7	8/9	42.3	Panellit trip on overbore tube 4472. Charge-discharge and miscellaneous maintenance.
<b>D REACTOR</b>			
8/9	8/12	67.3	Charge-discharge and installation of 0.244 venturis.
<b>DR REACTOR</b>			
7/31	8/6	136.0	Removal of an I&E enriched metal rupture from tube 1858. Charge-discharge and miscellaneous maintenance.
8/11	8/13	35.6	Removal of an I&E natural metal rupture from tube 1583.

Extracted from Plum 1965, August 1964, pages 6-8.

**F REACTOR**

8/5	8/7	58.0	Charge-discharge.
8/31	Still down		Removal of an I&E enriched metal rupture from tube 0788.

**H REACTOR**

No outages

**KE REACTOR**

8/19	Still down		Charge-discharge and maintenance. Gamma Monitoring Systems Improvement CGI-998, and Front and rear face hardware standardization.
------	------------	--	---

**KW REACTOR**

8/14	8/15	37.8	Unexplained Panellit trip on tube 0750.
8/26	8/28	64.7	Charge-discharge.
8/30	8/31	32.4	Broken spline in tube 5358.

---

Extracted from Plum 1965, August 1964, pages 6-8.

REACTORS 1964						Inventory in Basins Sep. Oct.
	Charged Sep.	Produced Oct.	Inventory in Reactor Sep.	Discharged Oct.	Sep.	Inventory in Basins Sep. Oct.
Normal U (tons)	738	582	1,845	1,772	621	2,599 2,421
MD		341,109	299,818	638,995	535,193	391,156 103,320 1,581,176 1,173,291
Pu (kg)		302	267	578	499	339 357 1,397 1,310
94 Metal (tons) <sup>2</sup>	126	172	759	801	231	130 1,153 1,236
MD		150,854	104,094	265,614	268,448	181,352 101,260 889,168 948,121
Pu (kg)		114	78	211	215	130 73 632 679

1 Includes special delayed production.

2 Includes 7 reactor.

### SEPARATIONS 1964

PUREX AND REDOX						Inventory of Product Sep. Oct.
	Dissolved Sep.	Dissolved Oct.	Inventory in Process Sep.	Separated Oct.	Sep.	Inventory of Product Sep. Oct.
Normal U (tons)	535	833	121	105	508	243 228 355
MD	165,082	515,467				
Pu (kg)	403.7	453.2	55.6	53.2	381.2 456.3	117.7 231.8
94 Metal (tons)	223	60	38	1	231	97 196 125
MD	223,833	45,597				
Pu (kg)	154.3	33.1	39.2	15.2	169.0 56.8	48.0 47.3

Extracted from Travis 1964k, pages 3 and 4.

COMPARATIVE PILE PERFORMANCE						
	SEP 1964			TOTAL		
B	C	D	DR	P	R	KW
Max. Power Level to Date, MW	2,090	2,365	2,055	2,015	2,110	21,450
Max. Power Level During Month, MW	1,710	2,060	1,790	1,750	1,845	4,400
Avg Power Level While Operating, MW	1,636	1,985	1,713	1,696	1,681	4,335
Max. Tube Power, KW	1,231	1,315	1,163	1,206	1,239	1,756
Effective Central Tubes	1,318	1,532	1,534	1,430	1,416	1,102
Time-Operated Efficiency, %	79.3	80.0	87.1	84.8	86.4	1,198
Operational Limitation	71.1	95.0%	95.0%	95.0%	76.1	1,507
MWD Produced During Month, total	37,716	47,620	45,550	43,170	43,593	40,068
Normal	24,288	35,823	37,711	35,379	38,200	33,569
%U Metal	13,488	11,797	7,839	7,791	5,393	36,119
Plutonium Produced, g	32,502	37,793	37,698	35,170	36,311	28,024
U in Reactor at Month End, tons	222.0	222.5	221.5	220.1	223.7	218.2
Normal	116.6	181.8	193.1	185.3	197.0	131.7
%U Metal	63.2	60.7	28.4	24.8	26.7	71.5
% Discharged During Month, tons	55.8	61.2	119.7	97.2	91.8	130.5
Normal	46.6	63.8	103.3	83.7	98.0	3.1
%U Metal	9.2	17.4	16.4	13.5	13.8	127.4
Avg Discharge Concentration	569.4	604.1	629.7	607.3	607.1	288.6
Normal	618.5	680.1	865.8	812.0	825.3	255.3
%U Metal						-
N REACTOR PILE PERFORMANCE						
	SEP 1964			TOTAL		
Input Production Plutonium (END)	34.09	Fuel Balance (Ton)	0.94	1.25	0	0
Input Production T (END)	0	Fuel Charged	0	0	0	0
Maximum Power Level Attained (MW)	2,800	Fuel Discharged	0	0	0	0
Average Power Level While Operating (MW)	2,660	Net Change	0	0	0	0
Time-Operated Efficiency (%)	16.8	Total in Reactor	0	0	0	0
Plant Utilization (%)	49.5	at Month End	331.39	36.43	0	0

1 Trip after instability.  
Extracted from Travis 1964j, pages 6 and 6a.

REACTOR OUTAGES SEP 1964

<u>DATE DOWN</u>	<u>DATE UP</u>	<u>OUTAGES HOURS</u>	<u>REMARKS</u>
<u>B REACTOR</u>			
9/2	9/5	76.8	Removal of an I&E natural metal rupture from tube 3880. Charge-discharge
9/18	9/21	72.1	Removal of an I&E natural metal rupture from tube 3566. Charge-discharge and miscellaneous maintenance.
<u>C REACTOR</u>			
9/1	9/5	96.2	Down for charge-discharge and maintenance.
9/5	9/5	2.2	Down due to faulty thermocouple on tube 0175.
9/21	9/23	48.1	Scrammed due to an unexplained Panellit trip on tube 3265. Miscellaneous maintenance.
<u>D REACTOR</u>			
9/7	9/10	91.7	Down for scheduled charge-discharge.
9/10	9/10	1.1	Down to correct a rear face cap leak.
<u>DR REACTOR</u>			
9/10	9/13	71.3	Removal of an I&E natural metal rupture from tube 2362. Charge-discharge. Replaced tube 4374 due to a sheared rear Van Stone flange.
9/13	9/13	0.4	Down due to a Panellit trip caused by faulty row relay.
9/26	9/27	36.2	Removal of an I&E enriched metal rupture from tube 0868.

---

Extracted from Plum 1965, September 1964, pages 2-4.

F REACTOR

8/31	9/2	35.5	Removal of an I&E enriched metal rupture from tube 0788.
9/2	9/2	3.5	Down due to an unexplained Panellit trip.
9/9	9/11	46.3	Down for scheduled charge-discharge.
9/11	9/12	3.2	Scrammed for temperature control.
9/12	9/12	13.1	Down to correct a front face cap leak on tube 3170.

H REACTOR

9/20	9/21	26.1	Reactor scrammed by a high pressure Panellit trip caused by an I&E enriched metal rupture in tube 3261.
9/21	9/21	1.4	Scram due to a Panellit trip.
9/21	9/21	2.2	Scram due to insufficient control for turnaround.
9/22	9/27	164.7	Discharge of E-N load. Removal of an I&E enriched metal rupture in tube 2378. Charge-discharge.
9/28	9/28	1.3	Down due to no flow from No. 37 cross-header to near sample room.
9/30	still down		Down due to insufficient reactivity.

KE REACTOR

8/19	9/9	505.8	Charge and maintenance, and hardware standardization work.
9/9	9/9	0.4	Down due to an unexplained Panellit trip on tube 4568.
9/11	9/12	29.3	Scram due to the rupture of the cooper sensing line to the flow orifice on a 1706 KE single pass tube.
9/15	9/17	35.2	Scram due to a ruptured Panellit sensing line on 1706 KE single pass tube no. 3050.

KW REACTOR

9/29	still down		Down due to a Panellit trip caused by a broken spline in tube 3561. Charge-discharge and maintenance.
------	------------	--	---

Extracted from Plum 1965, September 1964, pages 2-4.

COMPARATIVE PILE PERFORMANCE

B	C OCT 1964		DR		F	H	KE	MW	TOTAL
	C	D							
Max. Power Level to Date, MW	2,020	2,365	2,055	2,015	2,110	1,100	1,100	1,100	21,150
Max. Power Level During Outage, MW	1,315	2,100	1,920	1,755	1,915	1,320	1,320	1,320	20,355
Avg. Power Level While Operating, MW	1,537	1,760	1,550	1,527	1,732	1,322	1,322	1,322	1,322
Max. Tube Power, KW	1,216	1,251	1,212	1,173	1,220	1,221	1,221	1,221	1,221
Effective Central Tubes	1,145	1,145	1,148	1,148	1,145	1,145	1,145	1,145	1,145
Time-Operated Efficiency, %	62.3	68.7	75.6	71.2	87.0	83.2	85.3	85.3	85.3
Operational Limitation	TMI*	95°C	95°C	95°C	95°C	95°C	95°C	95°C	95°C
WD Produced During Month, total	26,230	42,119	23,483	36,285	47,657	19,263	112,731	10,170	399,268
Normal and Depleted	24,004	31,783	19,353	29,895	41,608	33,399	87,538	32,568	266,318
% Metal	12,226	10,366	4,130	6,390	6,019	16,191	25,193	7,902	93,150
Plutonium Produced, gm	29,277	33,112	18,990	29,230	32,379	11,368	102,022	37,180	331,258
U-235 Reactor at Month End, tons	210.0	223.8	221.5	219.2	223.5	205.2	215.5	431.6	2121.0
Normal	150.6	160.9	133.1	134.3	156.6	127.1	374.1	336.5	1747.2
% Metal	52.1	38.2	28.4	35.6	26.2	78.1	71.4	95.1	132.9
U Discharged During Month, tons	31.2	35.5	37.8	71.9	91.9	36.1	110.1	282.7	720.3
Normal	37.5	62.7	16.3	41.2	75.2	7.5	126.0	245.2	222.2
% Metal	16.6	22.8	0.9	7.5	5.9	28.9	23.1	18.5	121.1
Avg Discharge Concentration	554	659	599	558	572	675	651	653	615
Normal	712	763	983	788	805	827	705	1,042	807

H REACTOR PILE PERFORMANCE		Oct 1964	
		Oct	1964
Input production plutonium (kgMD)	15.64	Fuel balance (Ton)	0.94
		Fuel charged	1.25
		Fuel discharged	2.23
Maximum power level attained (MW)	2800	Net change	5.87
Average power level while operating (MW)	2056	Total in reactor	-3.64 +3.31
Time-operated efficiency (%)	23.3	at month end	0
Plant utilization (%)			0

\* Trip after instability.

\*\* Graphite temperature.

Extracted from Travis 1964k, pages 6 and 6a.

REACTOR OUTAGES OCT 1964

<u>Date Down</u>	<u>Date Up</u>	<u>Outages Hours</u>	<u>Remarks</u>
<u>B REACTOR</u>			
10/11	10/16	118.0	Removal of an I&E natural metal rupture from tube 1374. Charge-discharge and miscellaneous maintenance.
10/16	10/16	7.9	Manual scram due to flow restriction to No. 8 HCR caused by corrosion material.
10/24	10/25	38.8	Removal of an I&E natural metal rupture from tube 0964.
10/26	10/28	37.6	Scrammed by a Panellit trip when a spline was being pulled from tube 3281. Miscellaneous maintenance was performed.
10/30	still down		Manually scrammed because of HCR water loss annunciations caused by a circuit short. Miscellaneous maintenance.
<u>C REACTOR</u>			
10/10	10/14	99.7	Down for scheduled charge-discharge.
10/21	10/22	36.3	Removal of an I&E enriched metal rupture from tube 2763.
10/24	10/26	40.2	Removal of a stuck I&E enriched rupture from tube 2774. The front venturi assembly on tube 2764 parted from the head adapter when water pressure was raised to 400 lbs. A complete new assembly was installed.
10/26	10/28	57.3	Down to check the integrity of the front CG-558 hardware.

---

Extracted from Plum 1965, October 1964, pages 2-5.

D REACTOR

10/8	10/9	42.2	Scrammed due to an I&E natural metal rupture in tube 3259. Completed a small charge-discharge.
10/13	10/15	33.3	Scrammed due to a stuck I&E enriched metal rupture in tube 0886.
10/16	10/17	26.2	Down to manually close a ball valve on tube 1182. Startup failed when No. 25 VSR cable tangled.
10/17	10/17	0.5	Down due to a trip caused by a faulty Beckman.
10/19	still down		Down for scheduled charge-discharge.

DR REACTOR

10/2	10/4	40.0	Manually scrammed due to an I&E natural metal rupture in tube 2561. Replaced tube 2561.
10/7	10/8	34.8	Scrammed due to an I&E enriched metal rupture in tube 1360.
10/10	10/12	34.7	Manually scrammed due to rupture indications. Removal of an I&E enriched metal rupture from tube 1161. Charge-discharge.
10/19	10/22	54.5	Manually scrammed due to a stuck I&E natural metal rupture in tube 1364. Charge-discharge.
10/26	10/28	45.0	Scrammed by a low pressure Panellit trip when a rear pigtail adapter failed on tube 3979. Miscellaneous maintenance.

F REACTOR

10/2	10/4	40.9	Scrammed by an unexplained Panellit trip on tube 0980. Charge-discharge.
10/16	10/18	55.1	Down for scheduled charge-discharge.
10/18	10/18	1.2	Correct two rear cap leaks.

---

Extracted from Plum 1965, October 1964, pages 2-5.

H REACTOR

9/30	10/2	32.4	Down due to insufficient reactivity. Charge-discharge and installation of three process tubes.
10/3	10/4	27.6	Scrammed when the wrong ball valve was bypassed.
10/14	10/15	33.2	Removal of an I&E enriched metal rupture from tube 0576.
10/15	10/15	1.0	Discharge of a stuck poison charge from ball valve tube 0874.

KE REACTOR

10/7	10/10	69.2	Scheduled charge-discharge.
10/10	10/10	0.4	Down due to an unexplained Panellit trip.
10/10	10/10	3.0	Down due to an unexplained Panellit trip.
10/17	10/19	37.1	Scrammed by an unexplained Panellit trip on tube 4365. Charge-discharge and miscellaneous maintenance.

KW REACTOR

9/29	10/20	492.1	Down due to a Panellit trip caused by a broken spline in tube 3561. Maintenance.
10/24	10/25	37.4	Down due to a water leak. Tube 3155 was confirmed as a leaker and was replaced.
10/25	10/25	1.6	Manually scrammed due to high pressure on tube 3069.
10/31	still down		Down due to a Panellit trip caused by partial plugging of the Panellit opening at the orifice cage.

REACTORS											
					1964						
		Charged		Produced		Inventory in Reactor		Discharged		Inventory in Basins	
		Nov.	Dec.	Nov.	Dec.	Nov.	Dec.	Nov.	Dec.	Nov.	Dec.
<u>Normal U (tons)</u> <sup>1</sup>	384	615		1,696		1,340		461		971	
MWD		377,747	366,374	635,783		417,291	277,457	584,866	1406,369	2,304	3,218
Pu (kg)		327	319	581		391	235	509	1,231	1,711	1,956,340
<u>94u Metal (tons)</u> <sup>2</sup>	161	267		842		931		119		173	
MWD		165,277	235,863	334,928		424,061	98,797	146,730	848,703	755,142	
Pu (kg)		127	183	272		350	69	105	606	541	

1 Includes special depleted production.

2 Includes N reactor 94u and 1.25 material.

### SEPARATIONS

PUREX AND REDOX									
		Dissolved		Inventory in Process		Separated		Inventory of Product	
		Nov.	Dec.	Nov.	Dec.	Nov.	Dec.	Nov.	Dec.
<u>Normal U (tons)</u>	585	43		82	11	606	118	394	36
MWD	365,915	25,829							
Pu (kg)	319.2	228		50.3	0.2	326.0	65.7	258.9	123.4
<u>94u Metal (tons)</u>	217	303		43	24	172	322	127	226
MWD	189,561	238,474							
Pu (kg)	137.2	168.6		33.0	11.3	109.9	189.9	66.1	67.8

COMPARATIVE PILE PERFORMANCE						
	NOV 1964				DEC	
	B	C	D	DR	F	H
Max. power level to date, MW	2,090	2,365	2,055	2,015	2,110	4,400
Max. power level during month, MW	1,850	2,205	1,920	1,500	1,930	4,400
Avg power level while operating, MW	1,576	2,092	1,713	1,807	1,812	4,247
Maximun tube power, KW	1,306	1,393	1,274	1,267	1,223	1,255
Effective central tubes	1,380	1,581	1,495	1,460	1,523	1,515
Time-operated efficiency, %	76.0	70.6	70.2	95.0	82.0	85.0
Operational limitation	TAI	95°C	95°C	95°C	1250RM	1400RM
MWD produced during month, total	38,224	50,602	36,088	51,503	46,357	110,873
Normal and depleted (125 for N)	24,884	39,015	26,689	41,951	30,618	88,154
94 Metal	13,340	11,587	9,399	9,552	5,618	15,739
Plutonium produced, g	31,088	40,545	28,806	42,039	36,902	35,845
U in reactor at month end, tons	195.8	223.9	205.2	219.6	223.1	201.5
Normal and depleted (125 for N)	111.0	187.0	118.1	182.6	195.7	126.9
94 Metal	81.8	36.9	57.1	37.0	27.4	74.6
Avg in reactor concentration at month end, %W/T						
Normal and depleted (125 for N)	319	298	405	341	262	521
94 Metal	316	421	274	520	431	267
U discharged during month, tons	92.2	76.7	80.3	57.1	90.6	39.5
Normal and depleted (125 for N)	72.1	65.2	70.0	49.6	80.2	0.3
94 Metal	20.1	11.5	10.3	7.5	10.4	39.2
Avg discharge concentration, MW/T	545	660	625	542	582	503
Normal and depleted (125 for N)	774	806	698	702	810	1,035
94 Metal						

1 Does not include 125 metal.  
 2 Not available for N reactor.  
 3 No 125 metal.

Extracted from Travis 19641, pages 6 and 6a.

REACTOR OUTAGES Nov 1964

<u>DATE DOWN</u>	<u>DATE UP</u>	<u>OUTAGES HOURS</u>	<u>REMARKS</u>
<u>B REACTOR</u>			
11/30	11/1	35.8	Manually scrammed because of HCR water loss caused by a circuit short. Rod water flow was normal. Miscellaneous maintenance.
11/4	11/6	47.0	Removal of a rupture from tube 1560.
11/14	11/19	124.6	Removal of an I&E natural metal rupture from tube 0986. Charge-discharge.
<u>C REACTOR</u>			
11/9	11/11	36.9	Removal of an overbore rupture from tube 2868. Twelve overbore tubes were charge-discharged.
11/12	11/14	45.4	Scrammed by an unexplained Panellit trip. Charge-discharge of special material and miscellaneous maintenance work followed.
11/24	11/26	50.9	Down for scheduled charge-discharge.
11/26	11/26	6.4	Down to correct six front face cap leaks.

---

Extracted from Plum 1965, November 1964, pages 2-4.

D REACTOR

10/19	11/3	369.3	Down for charge-discharge, thermocouple work and replacement of the top seal on the rear face.
11/3	11/3	4.6	Scrammed by a high pressure Panellit trip caused by two pieces of gasket material on the Venturi cross wire.
11/3	11/3	0.6	Down to correct a partially engaged front face cap on tube 3396.
11/13	11/14	33.5	Scrammed due to an I&E natural metal rupture in tube 0969.
11/14	11/15	13.3	Down for removal of an I&E natural metal rupture from tube 3161.
11/18	11/20	34.5	Down due to a broken pigtail adapter on the rear of tube 3776. Charge-discharge and miscellaneous maintenance.
11/23	11/25	33.4	Down for removal of a I&E natural metal rupture from tube 3485.
11/29	11/30	38.1	Down for removal of an I&E natural metal rupture from tube 3674.

DR REACTOR

11/20	11/21	35.8	Down for scheduled charge-discharge
11/21	11/21	0.8	Scrammed from an unexplained low Panellit trip.

F REACTOR

11/6	11/8	42.2	Down for removal of I&E enriched metal rupture from tube 2078. Charge-discharge.
11/19	11/21	56.2	Down due to effluent water leak in the downcomer. Charge-discharge.
11/22	11/23	31.2	Scrammed from a Panellit trip while attempting to insert a plastic stub in spline cap 3662.

H REACTOR

11/4	11/6	62.4	Scrammed by a high pressure Panellit trip on tube 2585.
11/25	11/26	37.5	Down for removal of an I&E natural metal rupture from tube 1085.

KE REACTOR

11/14	11/19	107.8	Down for scheduled charge-discharge and maintenance.
-------	-------	-------	--

KW REACTOR

10/31	11/3	67.1	Scrammed due to a Panellit trip caused by partial plugging of the Panellit opening at the orifice cage.
11/3	11/4	0.7	Scrammed by an unexplained Panellit trip on tube 5762.
11/4	11/4	13.1	Scrammed by an unexplained Panellit trip on tube 5762.
11/29	Still down		Down for charge-discharge.

COMPARATIVE FILE PERFORMANCE						
B	C	DEC D	1964 DR	F	H	KW
Max. power level to date, MW	2,090	2,310	2,055	2,015	2,125 <sup>1</sup>	4,400
Max. power level during month, MW	1,885	2,300	2,030	1,950	2,125	4,000
Max. power level while operating, MW	1,754	2,204	1,701	1,827	1,955	3,755
Avg power level during month, MW	1,265	1,467	1,352	1,222	1,307	2,150
Maximum tube power, KW	1,374	1,552	1,505	1,510	1,511	2,125
Effective central tubes	83.1	73.6	95.5	91.7	82.2	2,057
Time-operated efficiency, %	95°C	95°C	95°C	95°C	85.7	222
Operational limitation	TAI				87.0	83.1
MWD produced during month, total	45,193	50,273	50,373	50,504	51,282	108,535
Normal and depleted (125 for N)	27,516	37,543	37,166	40,709	42,005	82,720
94 Metal	17,577	12,730	13,207	9,795	6,277	53,527
Plutonium produced, g	36,285	41,005	41,721	39,139	39,378	42,276
U in reactor at month end, tons	195.4	204.7	206.1	222.1	204.6	115,105
Normal and depleted (125 for N)	113.7	134.4	146.3	193.6	125.1	93,871
94 Metal	81.7	70.3	59.8	28.5	79.5	21,244
Avg in reactor concentration at month end, MWD/T	288	213	245	199	215	53.4
Normal and depleted (125 for N)	340	163	336	293	406	36.6
94 Metal						6.10
U discharged during month, tons	72.8	130.2	114.3	219.6	134.7	331
Normal and depleted (125 for N)	54.1	109.4	103.2	182.6	88.6	335
94 Metal	18.7	20.8	11.1	37.0	11.7	365
Avg discharge concentration, MWD/T	504	591	593	561	572	638
Normal and depleted (125 for N)	837	807	792	785	834	664
94 Metal						1,003

<sup>1</sup> New record.  
Extracted from Travis 1965a, pages 6 and 6a.

## REACTOR OUTAGES DEC 1964

DATE DOWN	DATE UP	OUTAGES HOURS	REMARKS
<u>B REACTOR</u>			
12-13	12-16	73.6	High pressure Panellit trip caused by an I&E natural metal rupture in Tube 3581, and charge-discharge.
12-16	12-16	8.0	Replacement of a ruptured rear expansion joint and discharge of an I&E normal uranium rupture from Tube 3686.
12-25	12-27	43.9	Removal of a stuck I&E normal uranium rupture from Tube 1961.
<u>C REACTOR</u>			
12-18	12-25	174.8	Scheduled charge-discharge and miscellaneous maintenance.
12-25	12-26	.5	Low Panellit trip on Tube 3387.
12-26	12-27	19.4	Correction of a faulty thermocouple connection on Tube 3676.
12-31	Still down		Removal of an I&E 94 metal rupture from Tube 3369.
<u>D REACTOR</u>			
12-9	12-14	102.8	Scheduled charge-discharge.
12-14	12-14	5.3	High pressure Panellit trip on Tube 4080.
<u>DR REACTOR</u>			
12-21	12-23	53.6	High pressure trip on Tube 2561. Removal of an I&E normal uranium rupture from Tube 2561.
12-23	12-24	6.5	Removal of an I&E normal uranium rupture from Tube 1961.
12-30	Will remain down.		Manually scrammed as first step in deactivation. Deactivation schedule being followed.

Extracted from Plum 1965, December 1964, pages 2-4.

F REACTOR

12-8	12-10	48.1	Removal of an I&E normal uranium rupture from Tube 2676. Replacement of Tubes 0781 and 0561 due to rear Van Stone leaks.
12-10	12-10	.8	Restoration of flow on Gamma monitor sample line from header No. 42.
12-27	12-30	83.5	Scheduled charge-discharge. Replacement of Tube 4468 due to cracked rear Van Stone.

H REACTOR

12-6	12-10	79.9	Scheduled block discharge.
12-12	12-13	28.8	Flexowriter failed during a period of flux change.

KE REACTOR

12-4	12-5	34.0	Removal of I&E 94-metal rupture in Tube 4189 and scheduled charge-discharge.
12-5	12-5	.5	Panellit trip apparently caused by an unseated charge in Tube 5151.
12-16	12-18	61.2	Excessive icing on incoming 230 KVA line. Charge-discharge.
12-31	Still down.		Low crossheader pressure trip on 1706 single pass Tubes 4355 and 4456.

KW REACTOR

11-29	12-5	150.2	Scheduled charge-discharge.
12-5	12-5	.7	Panellit trip caused by an oscillating gage on Tube 4271.
12-6	12-6	1.6	Panellit trips on gages 5280 and 3283, caused by oscillating gages on thoria tubes.

DISTRIBUTION

<u>No. of Copies</u>	<u>No. of Copies</u>
<u>OFFSITE</u>	
<u>Technical Steering Panel</u>	
D. S. Barth University of Nevada 4505 Maryland Parkway Las Vegas, NV 89154	P. D. McGavran Dept. of Health and Welfare 450 W. State St., 4th Floor Boise, ID 83720-5450
W. A. Bishop 2503 Wedgewood Court SE Olympia, WA 98501	R. L. Morrill Dept. of Geography, DP-10 University of Washington Seattle, WA 98195
M. L. Blazek Oregon Department of Energy 625 Marion Street N.E. Salem, OR 97310	A. H. Murphy Department of Atmospheric Sciences Oregon State University Corvallis, OR 97331-2209
G. G. Caldwell, Director Tulsa City-County Health Dept. 4616 East 15th Street Tulsa, OK 74112	D. W. Price Agricultural Economics Hulbert Hall Room 211 Washington State University Pullman, WA 99164-6210
S. N. Davis Dept. of Hydrology & Water Resources Bldg. 11 University of Arizona Tucson, AZ 85721	M. A. Robkin Radiological Sciences SB-75 University of Washington Seattle, WA 98195
N. J. Germond 224 Iron Mountain Blvd. Lake Oswego, OR 97034	G. S. Roessler 202 Nuclear Sciences Center University of Florida Gainesville, FL 32611
P. C. Klingeman Civil Engineering Dept. Oregon State University Appejin Hall 202 Corvallis, OR 97331-2302	B. Shleien 2421 Homestead Drive Silver Springs, MD 20902
K. J. Kopecky Fred Hutchinson Cancer Research Center 1124 Columbia Street Seattle, WA 98104	A. P. Slickpoo, Sr. P.O. Box 331 809 Nez Perce Lane Kamiah, ID 83536
	J. E. Till Rt. 2 Box 122 Neeses, SC 29107

<u>No. of Copies</u>	<u>No. of Copies</u>
D. E. Walker, Jr. P.O. Box 4147 Boulder, CO 80306	<u>ONSITE</u>
<u>Other</u>	
2 DOE Office of Scientific and Technical Information Technical Information Center P.O. Box 62 Oak Ridge, TN 37830	7 <u>DOE Richland Field Office</u>
B. G. Brooks, EH-421 Department of Energy Room J-112 Germantown, MD 20545	R. F. Brich, TSD A5-55 M. W. Tiernan, TSD A5-55 Public Reading Room (5) A1-65
18 K. CharLee Office of Nuclear Waste Mgmt. Department of Ecology 719 Sleater Kinney Road S.E. Suite 200 Olympia, WA 98504	<u>Boeing Computer Services</u>
M. R. Donnelly Public Health Service Centers for Disease Control 2201 6th Ave. Mail Stop RX-22 Seattle, WA 98121	F. J. Ungefug B1-02
H. A. Haerer Golder Associates, Inc. 4104 148th N.E. Redmond, WA 98052	35 <u>Battelle Pacific Northwest Laboratories</u>
L. E. Sewell Centers for Disease Control 1600 Clifton Road Atlanta, GA 30333	S. D. Cannon K1-25 J. M. Daer (5) K6-89 D. H. Denham K6-15 W. T. Farris K3-54 M. D. Freshley K6-77 R. O. Gilbert K7-34 W. A. Glass K4-13 R. H. Gray K1-33 S. P. Gydesen (5) P8-55 G. L. Harvey K1-77 C. M. Heeb (2) K6-42 T. A. Ikenberry K3-54 D. C. Martin K3-70 A. H. McMakin K1-25 B. A. Napier K3-54 J. V. Ramsdell K6-03 D. B. Shipley K6-89 J. C. Simpson K7-34 D. L. Stewart K6-91 W. L. Templeton K1-30 W. H. Walters K6-77 G. L. Wilfert K6-54 Publishing Coordination K1-06 Records Center K3-70 Technical Library (2) P8-55
J. Thomas HEAL 1720 N. Ash Spokane, WA 99204	

**END**

**DATE  
FILMED**

**11 / 24 / 92**

