

**TECHNICAL AND ECONOMIC ASSESSMENT
OF PHASE CHANGE AND THERMOCHEMICAL
ADVANCED THERMAL ENERGY STORAGE (TES) SYSTEMS**

**EPRI EM-256
(Research Project 788-1)**

Final Report

**Volume II:
Phase Change TES Sizing
Computer Program**

December 1976

Prepared by

**Boeing Engineering and Construction
A Division of The Boeing Company
Seattle, Washington 98124**

**Program Manager
John R. Gintz**

Prepared For

**Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, California 94304**

**Project Manager
Dr. Joe Pepper**

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

EP

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

LEGAL NOTICE

This report was prepared by Boeing Engineering and Construction (BEC), a division of The Boeing Company, as an account of work sponsored by the Electric Power Research Institute, Inc. (EPRI). Neither EPRI, members of EPRI, BEC, nor any person acting on behalf of either: (a) makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or (b) assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method or process disclosed in this report.

ABSTRACT

This document describes the computer program used in conceptual studies of phase change thermal energy storage systems. The model assumes the phase change media is contained in a tube-in-bath configuration. The program has been used in conjunction with, but is not necessarily limited to, a high temperature, gas-cooled solar power plant. The program represents a computer implementation of the engineering equations used to estimate the size and cost of a given phase change storage system design concept. Herein is a description of the model including a description of the inputs and outputs of the program.

ACKNOWLEDGEMENTS

The constructive program guidance afforded by Dr. Joe Pepper, Electric Power Research Institute Project Manager, is gratefully acknowledged.

The efforts of the Boeing people who made major contributions to this study are also acknowledged. These include: Mr. Fred Baisch, Mr. Don Bartlett, Mr. William Beverly, Mr. William Engle, Mr. Ferg Mahony, Mr. Mark Rubeck, Mr. Roger Shannon, Mr. Ernest Valley, Mr. Gary Vieth, and Mr. Ronald Zentner. Mr. John E. Lowe, Solar Energy Systems Manager, and Mr. John Gintz, Program Manager, provided the necessary program direction and resources.

Special acknowledgement is also given to the Rocket Research people who made major contributions to the study. These include Dr. Eckart Schmidt, Mr. Don Emmons, Mr. Russ Anderson, Mr. Scoll Neish, and Mr. Doug Huxtable.

Sincere appreciation is expressed to Mr. Paul Kogita and Mr. Mark Martin, who, with the Aerospace Graphics Staff, produced the tables, figures, report design and layout, and coordinated report production; and to Ms. Lorraine Healy for typing and secretarial assistance.

TABLE OF CONTENTS

| | <u>PAGE</u> |
|--|-------------|
| VOLUME II - PHASE CHANGE TES SIZING COMPUTER PROGRAM | |
| 1.0 Introduction and Summary | 1 |
| 2.0 Technical Description | 5 |
| 2.1 Mathematical Methods | 6 |
| 2.2 Recomendations | 23 |
| 2.3 References for Section 2.0 | 25 |
| 3.0 Input Description | 27 |
| 3.1 NAMELIST | 27 |
| 3.2 Input Variables | 27 |
| 4.0 Operating Instructions | 31 |
| 4.1 Control Cards | 31 |
| 4.2 Time and Output Estimate | 32 |
| 5.0 Output Description | 33 |
| 6.0 Program Listings | 39 |
| APPENDIX I - Kirchhoff Correction to Eutectic Heat of Fusion | 77 |
| APPENDIX II - Unit Thermal Conductance Analysis | 81 |



FIGURES

| VOLUME II - PHASE CHANGE TES SIZING COMPUTER PROGRAM | | <u>PAGE</u> |
|--|--|-------------|
| 1-1 | Designation Molten Salt Heater Sizing Math Model Structure | 3 |
| 1-2 | Phase Change Thermal Energy Storage Concept | 4 |
| 2-1 | Thermophysical Properties of Helium | 6 |
| 2-2 | Inputs to Phase Change Math Model Analysis | 8 |
| 2-3 | Geometrical Options | 10 |
| 2-4 | Unit Thermal Conductance Nodal Model | 13 |
| 2-5 | Tube Number Calculation Schematic | 16 |
| 2-6 | Logic Diagram for Exact Tube Number Calculation | 18 |
| 2-7 | Simplified Schematic of Storage Charging Cycle | 21 |
| 2-8 | Cost Account Structure | 23 |
| 3-1 | Case Input | 28 |
| II-1 | Exact Unit Thermal Conductance Eigenvalues | 85 |
| II-2 | Single Node Unit Thermal Conductance Accuracy | 85 |

Section 1.

INTRODUCTION AND SUMMARY

Analytical models and computer programs which mechanize these models have been developed to support the sizing and performance analysis of the phase change and chemical energy storage systems. Each of the three major models presented in this volume and volumes III and IV has been programmed in Fortran for the IBM 370.

The math model for sizing the phase change storage system (Volume II) performs the basic function of initial thermal sizing, conceptual configuration sizing, and preliminary cost estimating. The math model for the sizing of the CES system (Volume III) includes the chemical analysis, initial thermal sizing for the reactor and fractionating column, preliminary cost estimating, and overall configuration synthesis. The plant operation math model described in Volume IV is the result of a major modification to a similar program developed during the EPRI Solar Receiver Program RP377-1.

The analytical basis and overall program structure for each of these three computer programs is presented in Section 2.0 of each volume respectively. The input, output, operating instructions, and Fortran listings for each of the three Fortran programs are also included.

This report contains a description of the phase change thermal energy storage sizing model developed in conjunction with storage concepts evaluated in Volume I of this report.

The purpose of this document is to describe the program from a user's point-of-view as an aid to the engineer wishing to size and cost phase change storage systems. The program has been coded in standard IBM FORTRAN IV language using EBCDIC card format. The program encompasses about 2,000 cards and is totally self-contained in batch execution.

Figure 1-1 shows the program logic flow at the main program level. The separate logic blocks represent subroutines that execute the functions described in the figure.

The program assumes a storage system configuration as shown schematically in Figure 1-2. The phase change storage media is contained in an underground insulated vessel. The helium working fluid is dispersed and collected by manifolds. The storage media is contained as a bath immersing the helium tubes. A vertical flow arrangement is used with hot helium entering the top manifold during charging and the cold helium entering the bottom manifold during discharging.




Figure 1-1. Designation Molten Salt Heater Sizing Math Model Structure




Figure 1-2. Phase Change Thermal Energy Storage Concept

Section 2.

TECHNICAL DESCRIPTION

This section reports on the details of the Phase Change Sizing math model. The purpose of this model is to physically size a phase change thermal energy storage device given a set of consistent performance requirements and operating conditions. Cost estimates of system components are made on the basis of the sizing results. This section includes a presentation of the analytical basis of the math model.

The inputs to the analysis include TES system performance requirements and operating conditions, storage media and working fluid material properties, and storage vessel wall and heat exchanger tubing mechanical restrictions. The performance requirements and operating conditions are obtained from the plant operations math model and include the storage time, discharge rate, heat exchanger NTU value, TES system temperatures, temperature swing of the media, mass flow rates, turbine efficiencies, system pressure and pressure drop criterion. Helium is used as the working fluid, and its thermophysical properties of interest for this analysis include thermal conductivity, density, viscosity, heat capacity and specific heat ratio. The values assumed for helium and the data sources are shown in Figure 2-1. The required material properties of the salt eutectic used as the storage media include thermal conductivity, density, solid and liquid heat capacity, heat of fusion, and melt temperature. The value of heat of fusion for the salt is a very important concern. Some of the heat of fusion values are experimentally determined values; others are calculated values. The calculated values have the Kirchhoff correction included.⁽¹⁾ The details of this correction are presented in Appendix I. The key physical parameter input into the analysis is a characteristic vessel dimension. For a vessel with a square cross-section the dimension is the inside width; for a circular cross-section, the dimension is the inside diameter.




Figure 2-1. Thermophysical Properties of Helium

The outputs of the analysis include geometrical data (tubing diameter, tubing thickness, intertube spacing, vessel height, vessel wall thicknesses, etc.), required quantities of TES media, tubing, and container vessel materials, required size of helium pump circulation system, and cost estimates of the components.

2.1 MATHEMATICAL METHODS

The structure of the math model analysis is represented by Figure 1-1. This diagram shows the flow diagram for the computer model; however, it allows a presentation of the details of the analysis. The steps of the analysis are represented by the subroutine blocks shown in the Figure. The details of each block are presented below.

INITIAL

The purpose of this block is to set up the input data and make any initializations or preliminary calculations required by the remainder of the

analysis. An example of a preliminary calculation is the selection of the proper value of helium thermal conductivity and viscosity given an average helium temperature (see Figure 2-1). A detailed list of the required inputs for the analysis is shown in Figure 2-2. The source of the values is also indicated.

VOLM

The calculation of the required volume of salt eutectic is carried out in this block. The required thermal energy E is found from:

$$E = \frac{P_D \tau}{\eta_T} \quad (1)$$

where P_D = discharge power, τ = storage time and η_T = turbine efficiency at the average helium temperature T_f_{avg} .

The mass of media m required to store this thermal energy is given by

$$m = \frac{E}{xh + C_p(l) \Delta T - (T_m - T_o) \Delta C_p} \quad (2)$$

where h = heat of fusion, $C_p(l)$ = liquid heat capacity, $\Delta C_p = C_p(l) - \overline{C_p(s)}$, the difference between liquid and solid heat capacity, T_m = melt temperature, T_o = initial temperature of storage system, ΔT = effective temperature swing of the media, x = effective portion of salt that undergoes a change of phase. ΔT and x are determined from the plant operation model. $\overline{C_p(s)}$ is an average value over the temperature range T_o to T_m . The solid heat capacity of the salt can be expressed as follows

$$C_p(s) = a + bT + cT^{-2} \quad (3)$$

The final term is negligible in most cases, accounting for about 1/2% of the total value. Using the first two terms, the average $C_p(s)$ can be found from

$$\begin{aligned} \overline{C_p(s)} &= \frac{1}{T_m - T_o} \int_{T_o}^{T_m} C_p(s) dT \\ &= a + \frac{b}{2} (T_m - T_o) \end{aligned} \quad (4)$$

| Parameter | Description | Units | Source |
|-------------------|--|-------------------------------|-----------------------|
| \dot{m} | Mass flow rate | kg/sec | POP* |
| \dot{m}_c | Charge condition mass flowrate | kg/sec | POP |
| ΔT | Temperature drop across TES media | °C | POP |
| $(\Delta T)_{pp}$ | Pinch point temperature drop | °C | POP |
| η_T | Turbine efficiency | — | POP |
| X | Fraction of heat of fusion utilized | — | POP |
| NTU | Number of transfer units | — | POP |
| P_D | Discharge rate | Watts | POP |
| t | Storage time | Sec | POP |
| $T_{f,avg}$ | Average working fluid temperature | °C | POP |
| T_0 | Initial storage temperature | °C | POP |
| a | Fractional pressure drop criterion | — | OCS** |
| a_1 | Fractional pressure drop heater + receiver | — | OCS |
| p | System pressure | N/m ² | OCS |
| T_i | Heater inlet temperature | °C | OCS |
| C_p (l) | Salt heat capacity (liquid) | Watt-sec/kg-°C | Material properties |
| a_1 | Salt heat capacity coefficient (solid) | Watt-sec/kg-°C | |
| b_1 | Salt heat capacity coefficient (solid) | Watt-sec/kg-(°C) ² | |
| ρ | Salt density | kg/m ³ | |
| h | Salt heat of fusion | Watt-sec/kg | |
| k | Salt thermal conductivity | Watt/m-°K | |
| T_m | Salt melt temperature | °K | |
| C_{Pf} | Working fluid heat capacity | Watt-sec/kg-°K | |
| ρ_f | Working fluid density | kg/m ³ | |
| μ_f | Working fluid viscosity | N-sec/m ² | |
| k_f | Working fluid thermal conductivity | Watt/m-°C | |
| γ_f | Working fluid specific heat ratio | — | |
| η_C | Helium pump efficiency | — | Design specifications |
| H_t | Maximum tubing length manufactured | m | |
| S | Maximum allowable stress in tubing material | N/m ² | |
| D | Vessel characteristic dimension | m | |
| j | { = 1 triangular tube spacing = 0 square tube spacing | | |
| k | { = 1 circular vessel cross section = 0 square vessel cross section | | |
| a | Ratio of wall clearance to intertube spacing | | |
| CM | Manifold cost allowance | % | Cost data |
| C_{mt1} | Cost per m ³ of tubing metal volume | \$/m ³ | |
| C_{mt2} | Cost per m of tubing length | \$/m | |
| C_{TES} | Cost per m ³ of TES media | \$/m ³ | |
| C_{VW} | Cost per m ² of vessel wall | \$/m ² | |
| C_w | Cost per weld | \$/weld | |

*Plant operation program

**Operating condition specification

Figure 2-2. Inputs to Phase Change Math Model Analysis

The required salt volume V is found from

$$V = \frac{m}{\rho} \quad (5)$$

where ρ = salt density

GEOM

This block does a major portion of the geometric calculations. The most important calculation is the estimate of the tube number n_T . This estimate is calculated by considering the packing density of a given tubing spacing pattern. Figure 2-3 shows the two spacing patterns considered. Defining the packing density $\bar{\rho}$ as the ratio of the salt volume to total available volume, we have

$$\bar{\rho} = 1 - a_c \frac{d^2}{(d + 2\delta)^2} \quad (6)$$

and

$$a_c = \begin{cases} \frac{\pi/4}{\sqrt{3}} & \text{square tube spacing} \\ \frac{\pi}{9} & \text{triangular tube spacing} \end{cases} \quad (7)$$

The tube number is proportional to the ratio of the vessel cross-sectional area A_V , the tube cross-sectional area $\pi d^2/4$, and the packing density $\bar{\rho}$

$$n_T \propto (1 - \bar{\rho}) \frac{A_V}{\frac{\pi d^2}{4}}$$

Since

$$A_V = b_c D^2 \quad (8)$$

where

$$b_c = \begin{cases} 1, & \text{square vessel cross section} \\ \frac{\pi}{4}, & \text{circular vessel cross section} \end{cases} \quad (9)$$




Figure 2-3. Geometrical Options

then

$$n_T = C_1 \frac{4 b_c a_c}{\pi} \frac{D^2}{(d + 2\delta)^2} \quad (10)$$

The constant C_1 is used to correct the n_T value to the actual vessel design. Because a certain minimum spacing must be chosen between the outer tubes and the vessel inner wall (see Figure 2-3), not all the area of the vessel cross-section is available for the heat exchanger.

Another important geometric calculation is the determination of the vessel height H . Assuming the salt volume is contained entirely in the heat exchanger portion of the vessel; i.e., no salt in the manifold heat regions, the height of vessel to contain the desired amounts of salt volume and tubing is given by

$$H_1 = \frac{4}{\pi} \frac{V}{\left(\frac{4}{\pi} b_c D^2 - n_T d^2 \right)} \quad (11)$$

There is also a requirement for enough tubing surface area to provide adequate heat transfer from/to the helium flow and the salt TES media. This required surface area A is expressed as a desired UA - value, U being the effective unit thermal conductance. The UA - value is usually expressed as

$$UA = \dot{m} C_p \text{ NTU} \quad (12)$$

where \dot{m} - mass flowrate at critical charge or discharge condition, C_p = heat capacity of helium, NTU = number of transfer units. The NTU - value is a measure of the heat exchanger effectiveness ϵ

$$\epsilon = 1 - e^{-\text{NTU}} = \frac{T_E - T_I}{T_m - T_I} \quad (13)$$

where T_E = system exit temperature, T_I = system inlet temperature, and T_m = melt temperature. The NTU - value is an input given from the plant performance math model. The heat exchange surface area is given by

$$A = n_T \pi d H$$

Therefore, the required vessel height for the desired heat exchange is

$$H_2 = \frac{\dot{m} C_p \text{ NTU}}{\pi d n_T} \frac{1}{U} \quad (14)$$

A consistent design is obtained when $H_1 = H_2$. The parameter that is varied to cause this consistency to occur is the tube half spacing δ . Since Eqn (14) requires a unit thermal conductance value, which is also dependent upon d and δ , the initial pass through GEOM picks up default values of C_1 , d , and δ . The calculations of (13) and (14) are skipped until the U is calculated later in the analysis. As shown in Figure 1-1, an iterative process is required to simultaneously satisfy $H_1 = H_2$ and calculate the unit thermal conductance U .

FILMCO

This block has the important function of accurately predicting the convective heat transfer coefficient h . The tubing wall thickness t is calculated from

$$t = 0.75 \frac{pd}{S} \quad (15)$$

where p = helium pressure, S = allowable stress in tubing metal = 3.9×10^7 N/m² (5600 psi) for Inconel 617 at 816°C (1500°F). This thickness value contains a 50% safety factor over the minimum allowable thickness. The flow velocity U_f through each tube is given by

$$U_f = \frac{m}{n_T} \frac{4}{\rho_f \pi (d - 2t)^2} \quad (16)$$

where ρ_f = helium density. The Reynolds number Re and Prandtl number Pr are given below

$$Re = \frac{U_f (d - 2t)}{\mu_f / \rho_f} \quad (17)$$

$$Pr = \frac{C_{pf} \mu_f}{k_f} \quad (18)$$

where μ_f = helium viscosity, k_f = helium thermal conductivity.

The Nusselt number Nu is related to the convective film coefficient by

$$h = Nu \frac{k_f}{(d - 2t)} \quad (19)$$

Nu has been experimentally correlated ⁽⁴⁾ with Re and Pr at expected temperatures by

$$Nu = 0.0215 Re^{0.8} Pr^{0.6} \quad (20)$$

This correlation has been shown to give Nu values accurate to 5%.

TUBSPC

This block calculates the tube half spacing δ and the unit thermal conductance U . A new value of tube half spacing is calculated from equating Eqns (11) and (14) to yield

$$\delta^* = 1/2 \left\{ \left[C_1 a_c d^2 + \frac{4d C_1 a_c V}{m C_p NTU} \right]^{1/2} - d \right\} \quad (21)$$


If the new and old half spacing values are not sufficiently close, control passes back to GEOM. This process continues until a consistent δ is found.

The unit thermal conductance is used to calculate the heat transfer between the helium flow and the storage media

$$Q = U (T_{He} - T_{SALT})$$

where $U = (R_{\text{total}} A_i)^{-1}$, R_{total} = total thermal resistance, A_i = tube inside surface area. The unit thermal conductance is calculated by lumping the masses of the helium, tube wall and storage media into nodes (see Figure 2-4). Halfway between the tubes is an adiabatic surface, so that U can be found from

$$U = \frac{1}{R_{\text{total}} A_2} = \frac{1}{A_2 [R_{12} + R_{23} + R_{34} + R_{45}]} \quad (22)$$



$$U = \frac{1}{R_{\text{total}} A_2} = \left\{ A_2 [R_{12} + R_{23} + R_{34} + R_{45}] \right\}^{-1}$$

$$R_{ij} = \frac{r_j - r_i}{k_{ij} A_{ij}}, \text{ (CONDUCTION)}$$

$$= \frac{1}{h_{ij} A_{ij}}, \text{ (CONVECTION)}$$

Figure 2-4. Unit Thermal Conductance Nodal Model

The thermal resistances are found from

$$R_{ij} = \frac{r_j - r_i}{k_{ij} A_{ij}} \quad \text{for conduction} \quad (23)$$

$$= \frac{1}{h_{ij} A_{ij}} \quad \text{for convection}$$

substitution and simplification gives

$$U = \left\{ \frac{1}{h} + \frac{(d - 2t)}{2 k_w} \left[\ln \left(\frac{\sqrt{2} \sqrt{d^2 + (d - 2t)^2}}{(d - 2t)} \right) + \ln \left(\frac{\sqrt{2} d}{\sqrt{d^2 + (d - 2t)^2}} \right) \right] + \frac{(d - 2t)}{2 k} \ln \left(\frac{\sqrt{2} \sqrt{d^2 + (d + 2\delta)^2}}{d} \right) \right\}^{-1} \quad (24)$$

A check on the adequacy of using a lumped node approach over the exact solution was made for a planar geometry. The details of those calculations are shown in Appendix II. The results from those calculations indicate that the lumped node approach can provide accurate values for the unit thermal conductance for a wide range of conditions.

One concern that remains with this lumped node approach used to obtain the unit thermal conductance is the value of the salt thermal conductivity. Presently an average value is assumed to handle variations caused by differences between solid and molten salt properties. If there is a substantial difference between solid and molten salt thermal conductivity values, the average thermal conductivity approach may produce misleading data. During the ERDA portion of this study, the effects of the salt melt face propagation on the charge/discharge characteristics of the phase change device will be considered in detail.

PLOSS

This block calculates the pressure drop through the heat exchanger. The ratio of the pressure drop to the system pressure is given by ⁽²⁾

$$\frac{\Delta p}{p} = \frac{1}{2} f U_f^2 \frac{H}{(d - 2t)} \quad (25)$$

The friction factor f for flow through smooth tubes is given by the Blasius formula

$$f = \frac{0.3164}{Re^{1/4}} \quad (26)$$

The pressure ratio of Eqn. (25) is compared to a desired criterion, e.g., 4%. If the ratio is significantly different, the tubing diameter d is changed and control passes back to the GEOM routine as shown in Figure 2-1. A new tube half spacing is found and a new pressure drop ratio calculated. This process continues until both the consistent tube spacing requirement and pressure drop criterion are satisfied.

The pressure drop calculated herein so far accounts only for the heat exchanger portion. Plans are to later include the manifold pressure drop contribution. Initial estimates indicate that the contribution is an additional 0.5%.

EXTUN

This block calculates the exact tube number n_T' which will fit in a given vessel cross-section. This involves actually counting the number of tubes that will fit in a vessel with a given spacing pattern. This n_T' is used to update the numerical constant C_1 used in the GEOM routine. As will be shown, this additional correction is necessary to accurately give the tube number for a given configuration.

As was indicated in the discussion of the GEOM routine, the exact tube number that can be placed in a vessel with a specified tubing spacing pattern depends on the specification of the minimum distance allowed between the outer tubes and the vessel wall. As shown in Figure 2-5 this minimum distance can be specified by giving the value for the parameter a , which is defined as the ratio of this minimum distance to the intertube spacing distance 2δ . Most calculations so far have proceeded with $a = 1$. The maximum number of tubes that can be placed along the centerline of the vessel with a dimension D is given by

$$m_1 = \text{INTEGER} \left(\frac{D - 2a\delta}{\ell_1} \right) \quad (27)$$

where ℓ_1 = centerline to centerline tube spacing = $d + 2\delta$

Defining

$$D^* = 2 (m_1 + a) \delta + m_1 d$$

and

$$\bar{\alpha} = \frac{D - D^*}{2} \quad (28)$$




Figure 2-5. Tube Number Calculation Schematic

the distance between the vessel wall and the centerline of the closest tube is given by

$$x_1 = 2\delta a + \bar{\alpha} + \frac{d}{2} \quad (29)$$

With these initial setups, the tube number is calculated by determining the distance Y from the centerline to the minimum distance line at points regularly spaced along the vessel centerline. The Y - values are divided by the distance between tubes, the integer value of the quotient taken, and the integer values summed. By the use of symmetry, twice the integer value sum plus m_1 yields the tube number n_T' . This procedure obviously allows the calculation of n_T' for any symmetrical vessel where Y can be specified as a function of the distance along its centerline.

In order to accomplish this summation for either a square or cylindrical vessel and either a square or triangular tube spacing pattern, a logic pattern was set up (see Figure 2-6). For a square tube spacing, the following parameters were defined

$$\begin{aligned} \bar{m} &= m_1 \\ \bar{b} &= 1 \\ \bar{B} &= \ell_1 \\ A_i &= 0, \text{ for all } i \end{aligned} \quad (30)$$

For a triangular spacing

$$\begin{aligned} \bar{m} &= 2m_1 - 1 \\ \bar{b} &= 1/2 \\ \bar{B} &= \frac{\sqrt{3}}{2} \ell_1 \end{aligned} \quad (31)$$

$$A_i = \begin{cases} 0, & \text{for odd } i \\ 1, & \text{for even } i \end{cases}$$

The points along the centerline are given by

$$x_i = x_1 + (i-1) \bar{b} \ell_1 \quad (32)$$




Figure 2-6. Logic Diagram for Exact Tube Number Calculation

The distance Y_i is given by

$$Y_i = \begin{cases} \sqrt{\bar{R}^2 - (x_i - \bar{R} - x_1)^2}, & \text{circular cross section} \\ \bar{R}, & \text{square cross section} \end{cases} \quad (33)$$

where

$$\bar{R} = 1/2D - 2\delta a - \bar{a}$$

The Y_i value is divided by the distance between tubes \bar{B} to give

$$\Delta_i = \frac{Y_i}{\bar{B}} \quad (34)$$

The integer sum is then given by

$$\Phi = \sum_{i=1}^{\bar{m}} \left\{ \text{INTEGER} [\bar{b} (\Delta_i - A_i)] + A_i \right\} \quad (35)$$

Then, the tube number n_T' is given by

$$n_T' = m_1 + 2\Phi \quad (36)$$

The numerical constant C_1 is updated by

$$C_1 = \frac{n_T'}{\bar{n}_T} \quad (37)$$

where $\bar{n}_T = \frac{4}{\pi} b_c a_c \frac{D^2}{(d + 2\delta)^2}$

The importance of calculating the exact tube number n_T' and updating C_1 is shown in Table 2-1. As can be seen, basing the tube number solely on the packing fraction approach produces significant variations with the actual number of tubes that can be physically placed in a vessel.

Table 2-1
COMPARISON OF TUBE NUMBER CALCULATIONS

$d = 0.01 \text{ m}$, $\delta = 0.03 \text{ m}$, $a = 1.0$

| | D (meters) | Square vessel square spacing | Square vessel triangular spacing | Circular vessel square spacing | Circular vessel triangular spacing |
|--------|---------------|---------------------------------|--|-----------------------------------|--|
| C_1 | 5 | .988 | 1.526 | .994 | 1.513 |
| n_T' | 5041 | 5993 | 3981 | 4665 | |
| C_1 | 10 | 1.002 | 1.152 | 1.004 | 1.518 |
| n_T' | 20449 | 23513 | 16099 | 18731 | |

ANAL

This block analyzes the solution to provide data needed to calculate cost estimates. The total length of heat exchanger tubing required is

$$l = n_T H \quad (38)$$

The volume of tubing metal V_m is given by

$$V_m = \pi l (dt - t^2) \quad (39)$$

The number of welds n_w required to produce the length of tubes required is

$$n_w = n_T \text{ INTEGER } \left(\frac{H}{H_t} \right) \quad (40)$$

where H_t = maximum manufactured tube length. At present, the vessel container wall cost estimate is based on the surface area A_s of the vessel

$$A_s = \pi D H$$

It is planned to include the detailed design calculations for the vessel container wall at a later date.

HEPUMP

This block sizes the helium circulation system pump. During charging of the TES system, the helium pump will circulate the helium through the receiver and the storage system. The compressor is sized to recoup the pressure

losses in both the receiver and storage system. A schematic of its location is given in Figure 2-7. Defining the compressor efficiency by

$$\eta_C = \frac{\left(\frac{p_{03}}{p_{02}}\right)^{\frac{\gamma-1}{\gamma}} - 1}{\frac{T_{03}}{T_{02}} - 1} \quad (41)$$




Figure 2-7. Simplified Schematic of Storage Charging Cycle

the required work rate W_C from the compressor is given by

$$W_C = \dot{m}_C C_p (T_{03} - T_{02}) \\ = \frac{\dot{m}_C C_p T_{02}}{\eta_C} \left[\left(\frac{p_{03}}{p_{02}} \right)^{\frac{\gamma-1}{\gamma}} - 1 \right] \quad (42)$$

where \dot{m}_C = critical charging mass flowrate, γ = specific heat ratio, and $(\)_0$ indicates stagnation flow conditions.

The stagnation pressure p_0 is given by

$$p_0 = p + 1/2 \rho_f u_f^2$$

Since the static pressure p is \gg the dynamic pressure $1/2 \rho_f u_f^2$, $p_0 \approx p$ or stagnation conditions \approx static conditions. Using $p_1 = p_2 + (\Delta p)_T$ where $(\Delta p)_T$ is pressure drop through receiver and TES system.

$$W_C = \frac{\dot{m} C_p T_2}{\eta_C} \left[\left(\frac{1}{1-\alpha_1} \right)^{\frac{\gamma-1}{\gamma}} - 1 \right]$$

where

$$\alpha_1 = \frac{(\Delta p)_T}{p}$$

The temperature T_2 can be found from

$$\frac{T_3}{T_2} = 1 + \frac{1}{\eta_C} \left[\left(\frac{p_3}{p_2} \right)^{\frac{\gamma-1}{\gamma}} - 1 \right] \quad (43)$$

and

$$T_3 = T_1 - (\Delta T)_{PP}$$

where $T_1 \equiv$ TES inlet temperature = 816°C (1500°F), $(\Delta T)_{PP}$ = pinch point temperature delta = 111°C (200°F).

Substitution and simplification yields

$$w_C = \frac{\dot{m}_C C_p [T_1 - (\Delta T)_{PP}] \left[\left(\frac{1}{1 - \alpha_1} \right)^{\frac{\gamma-1}{\gamma}} - 1 \right]}{\left\{ \eta_C + \left(\frac{1}{1 - \alpha_1} \right)^{\frac{\gamma-1}{\gamma}} - 1 \right\}} \quad (44)$$

To cost a compressor of this rating, a number of existing compressors were surveyed. Table 2-2 shows the findings. It was decided to scale the 0.8 MW compressor using the following relation ⁽³⁾

$$C_{HP} = \frac{210 \times 10^{-3}}{\left(\frac{w_C}{8 \times 10^5} \right)^{0.4}} \quad (45)$$

where C_{HP} is the \$/watt for the pump.

COST

This block assembles the various design data to form cost estimates of the various components. The cost account structure is shown in Figure 2-8.

Table 2-2
EXAMPLES OF AVAILABLE COMPRESSORS

| Manufacturer | Inlet temp (°C) | Pressure ratio | Rating (MW) | Cost (\$/kW) |
|---------------|-----------------|----------------|-------------|--------------|
| Ingersol-Rand | 45 | 8 | 15 | 250 |
| Ingersol-Rand | 39 | 150 | 10 | 250 |
| Turbonetics | 294 | 1.27 | 0.3 | 223 |
| Elliot | 316 | 1.18 | 0.8 | 210 |

| Account | Quantity (units) | Unit cost (units) | Cost (M\$) |
|-------------------------|--------------------|------------------------|-----------------------|
| TES media | V (m^3) | C_{TES} ($$/m^3$) | $C_{TES} \cdot V$ |
| Storage container | | | |
| *Vessel outer wall | V_{ow} (m^3) | C_{ow} ($$/m^3$) | $C_{ow} \cdot V_{ow}$ |
| *Insulating Brick | V_e (m^3) | C_l ($$/m^3$) | $C_l \cdot V_l$ |
| *Liner | V_R (m^3) | C_e ($$/m^3$) | $C_e \cdot V_e$ |
| *Roof | | C_R ($$/m^3$) | $C_R \cdot V_R$ |
| Heat exchanger | | | |
| Metal volume | V_m (m^3) | C_{mt_1} ($$/m^3$) | $C_{mt_1} \cdot V_m$ |
| Tubing length | ℓ (m) | C_{mt_2} ($$/m$) | $C_{mt_2} \cdot \ell$ |
| Number of welds | n_w | C_W ($$/weld$) | $C_W \cdot n_w$ |
| Manifold allowance | | | C_M |
| Helium circulation pump | W_C (MW) | C_{HP} ($$/MW$) | $C_{HP} \cdot W_C$ |
| Total | | | $C_T = \Sigma$ |

*Presently expressed as lumped value for vessel wall

Figure 2-8 Cost Account Structure

The unit costs for the various components and their data sources are listed in Table 2-3.

2.2 RECOMMENDATIONS

Although the phase change sizing math model is working well, additional calculational steps will be added under the ERDA portion of the study. An

Table 2-3
TYPICAL UNIT COST VALUES

| Material | Unit cost value | Data source |
|--------------------------------|--------------------------------------|-------------|
| TES media NaF/ZnF ₂ | 2,170\$/m ³ (0.42 \$/lbm) | 1 |
| Storage container | 4,100 \$/m ² | 2 |
| Heat exchanger | | |
| Metal volume | 99,000. \$/m ³ | 3 |
| Tubing length | 4.92 \$/m | 3 |
| Number of welds | 12.00 \$/weld | 4 |
| Helium circulation system | From Hepump | 5 |

1. Pennwalt Data, April 1976, FOB Inyokern, California
2. Based on an estimate of container cost for a square vessel cross section, metal wall and liner, insulating brick, and truss roof
3. Based on estimates from Huntington Alloys, Huntington, W.Va.
4. Manufacturing estimate
5. Data produced in Hepump subroutine

important addition will be the incorporation of vessel wall sizing calculations into the ANAL subroutine.

This will allow a point design calculation to be made for the vessel wall, increasing the accuracy of the storage container cost account.

Another very important addition will be the addition of the manifold sizing and costing calculations. This addition will require the selection of a particular manifolding concept and the quantifying of the sizing calculations. It is expected that this sizing will significantly affect the choice of heat exchanger tube number, diameter, wall thickness, etc.

Other additions include the capacity to handle finned heat exchanger tubing and radiation enhanced salt thermal conductivity. Both of these additions will allow the quantifying of their influence on the phase change system sizing and cost estimates.

Finally, it is expected that the phase change sizing model can be modified slightly to allow consideration of the sizing of a sensible heat TES system. The requirements of such a modification will be explored.

2.3 REFERENCES FOR SECTION 2.0

1. Bramlette, T. T., et al, "Survey of High Temperature Thermal Energy Storage" Sandia Labs, Albuquerque, N. M., March 1976.
2. Schlichting, H., Boundary Layer Theory, McGraw-Hill, N. Y., 1968, p. 12.
3. Boeing Coordination Sheet, "Turbomachinery Costs," K-6161-GLV-079.
4. Kays, W. M. Convective Heat and Mass Transfer, McGraw-Hill, N. Y., 1966, p. 173.



Section 3.

INPUT DESCRIPTION

The following is a description of the input variables and how to prepare them to initialize the Molten Salt TES Math Model. All inputs are defined and listed at the beginning of each case. The variables given are FORTRAN names.

3.1 NAMELIST

The inputs to the Molten Salt Thermal Energy Math model are completely on cards. All variables have default values built in which may be overriden by standard IBM/NAMELIST statements. The inputs are free field separated by commas (,). Card column one (1) may not be used, however.

Input for a given case is initiated by the symbol &INPUT, and computation is started when the symbol &END is encountered. For example, input changes are started with a card as follows:

```
&INPUT DT = 300.0, CW = 10.0, . . . . .
```

Input is terminated and case execution begins with the following:

```
. . . . , XK = 5.0, T0 = 700.00 &END
```

Where $\sqrt{ }$ represents a blank space. Any variable defined in Section 2.2 may be changed for a given case. Once an input has been modified, it will remain the same for all following cases or until changed again. Figure 3-1 is an example from a recent study.

3.2 INPUT VARIABLES

The inputs are listed here primarily for identification purposes. For a detailed explanation of their significance, refer to Section 2.

```
&INPUT NTU=4.0,DT=200.0,EFFT=0.326,HC=516000.0,TI=1089.0,TAVG=786.0
DMT=196.0,DMTC=150.0,EFFC=0.9,EFFT1=0.442,CPL=937.0,CPS=937.0
TMELT=913.0,DT1=111.0,
NTU=5.7,DT=267.0,EFFT=0.332,HC=539000.0,T0=778.0
VCD=12.3,ISHAPE=0,1J=0 &END
&INPUT XK=2. &END
&INPUT XK=7. &END
&INPUT XK=10. &END
```

*Case Input
Figure 3-1.*

| Variable | Default Value | Definition |
|----------|----------------------|---|
| CDR | 0.9 | Charge to discharge power ratio |
| CM | 20.0 | Manifold allowance in heat exchanger cost - % |
| CMT1 | 99000.0 | Cost per cubic meter of tubing metal volume - \$/meters ³ |
| CMT2 | 4.92 | Cost per meter of turbine metal length - \$/meter |
| CPL | 1204.0 | Salt heat capacity (liquid) Watt-sec/kg-°K |
| CPSA | 814.1 | Salt heat capacity coefficient (solid) - Watt-sec/kg-°K |
| CPSB | 0.2825 | Salt heat capacity coefficient (solid) - Watt-sec/kg-°K ² |
| CSR | 1.0 | Ratio of wall clearance to inter-tube spacing |
| CTES | 2170.0 | Cost per cubic meter of TES media - \$/meter ³ |
| CVW | 4100.0 | Cost per square meter of wall materials - \$/meter ² |
| CW | 12.0 | Cost per weld - \$/weld |
| DEN | 2339.0 | Salt density - kg/meter ³ |
| DMT | 195.0 | Total mass flow rate - kg/sec |
| DMTC | 195.0 | Charge condition mass flow rate-kg/sec |
| DPØ | 0.04 | Pressure drop criteria |
| DPØ1 | 0.07 | Pressure drop in heater plus receiver |
| DT | 246.0 | Temperature change across the system - °K |
| DT1 | 111.0 | Pinch point temperature change - °K |
| EFFC | 0.4 | Helium circulation system compressor efficiency |
| EFFT | 0.4 | Turbine efficiency |
| HC | 5.98X10 ⁵ | Salt latent heat of fusion - Watt-sec/kg |
| HT | 6.1 | Longest tube length manufactured - meters |
| IJ | 0 | = 1 for hexagonal tube spacing = 0 for rectangular tube spacing |
| IPRINT | 1 | Print indicator = 1 Print interim calculations = 0 Print only final results |
| ISHAPE | 0 | = 1 for cylindrical vessel crossection = 0 for square vessel crossection |
| NTU | 3.0 | Number of thermal units |

| Variable | Default Value | Definition |
|----------|--------------------|--|
| PD | 5.0×10^7 | Discharge rate - Watts |
| PRESS | 3.45×10^6 | System pressure - Newtons/meter ² |
| STRESS | 3.86×10^7 | Allowable stress in tubing material - Newtons/meter ² |
| TAU | 21600.0 | Storage time - seconds |
| TAVG | 786.0 | Average heater temperature - °K |
| TI | 1111.0 | Heater inlet temperature - °K |
| TMELT | 908.0 | Salt melt temperature - °K |
| TØ | 833.0 | Initial storage temperature - °K |
| VCD | 11.28 | Vessel diameter - meters |
| VIS | 0.0017 | Salt viscosity - Newton-sec/meter ² |
| XK | 4.3 | Salt thermal conductivity - Watts/meter - °K |

The program contains several variables which are computed internally, but initial values are needed as a beginning for their iterative solution. If the user wishes to change the starting value and perhaps speed problem solution these are available as inputs.

| Variable | Default Value | Definition |
|----------|---------------|--|
| C1I | 0.98 | Ratio of actual to calculated tube numbers |
| TDI | 0.1 | Tube diameter - meters |
| TSI | 0.028 | Tube spacing - meters |

Section 4.

OPERATING INSTRUCTIONS

The computer program exists in the form of card decks and is executed in the batch mode. The source cards are coded in FORTRAN IV language and are compatible with IBM 360/370 computer systems.

Conversion to other computer systems should not be difficult if required. The program uses only standard FORTRAN instructions and there is no machine dependent software used and no known numerical significance concerns. The program should readily adapt to Remote Job Entry (RJE) or time sharing terminals.

4.1 CONTROL CARDS

The program is executed by standard FORTRAN compile, LINKEDIT, and GØ steps run in sequence with IBM Job Control Language (JCL).

In order to resolve installation dependent system difference, JCL procedures (PROCS) exist at all IBM facilities for accomplishing the execution sequence. The example shown below illustrates one of the PROCS used at Boeing System 370 computers and will be similar if not identical elsewhere.

COLUMN 1

Card 1 //EXEC//FORTHCLG
Card 2 //FORT.SYSIN//DD/*

{ FORTRAN
{ SOURCE } }

Card n /*
Card n+1 // G0.SYSIN//DD/*

{ NAMELIST
{ STATEMENTS } }

Card last /*

4.2 TIME AND OUTPUT ESTIMATES

The run time for a given case will vary somewhat depending on the number of program iterations required. Experience has shown a typical average to be about 0.2 seconds of central processor time per case. This estimate was obtained using Boeing IBM/370 computers. The FORTRAN compilation required 3.7 seconds and the LINKEDIT step about 0.5 seconds. Obviously, optimum use is achieved when as many cases as possible are grouped together in one program execution. The program generates 3 to 4 pages of output per case, excluding the subroutine compilations.

Section 5.

OUTPUT DESCRIPTION

Output from the Molten Salt Heater Sizing Model consists of (1) the inputs for the case with working fluid properties, (2) the vessel geometry, and (3) the cost data. An output option (IPRINT=1) will cause the program to generate internal output from subroutine EXTUN. The following example is the first case shown in Figure 3-1.

***** INPUTS *****

CDR = 0.900 CHARGE/DISCHARGE RATIO
 CM = 20.000 MANIFOLD ALLOWANCE IN HEAT EXCHANGER COST - %
 CMT1 = 99004.000 COST PER M**3 OF TUBING METAL VOLUME - \$/M**3
 CMT2 = 4.920 COST PER M OF TUBING METAL LENGTH - \$/M
 CPL = 937.000 SALT HEAT CAPACITY (LIQUID) - WATT-SEC/KGM-DEGK
 CPSA = 814.100 SALT HEAT CAP COEFF (SOLID) - WATT-SEC/KGM-DEGK
 CPSB = 0.282 SALT HEAT CAP COEFF (SOLID) - WATT-SEC/KGM-DEGK**2
 CSR = 1.000 RATIO OF WALL CLEARANCE TO INTERTUBE SPACING
 CTES = 2170.000 COST PER M**3 OF TES MEDIA - \$/M**3
 CVW = 4100.000 COST PER M**2 OF WALL MATERIALS - \$/M**2
 CW = 12.000 COST PER WELD - \$/WELD
 DEN = 2339.000 SALT DENSITY - KGM/M**3
 DMT = 196.000 TOTAL MASS FLOW RATE - KGM/SEC
 DMTC = 150.000 CHARGE CONDITION MASS FLOW RATE - KGM-SEC
 DPO = 0.040 PRESSURE DROP CRITERIA
 DPO1 = 0.070 PRESSURE DROP IN HEATER + RECIEVER
 DT = 267.000 TEMPERATURE CHANGE ACROSS SYSTEM - DEG K
 DT1 = 111.000 PINCH POINT TEMPERATURE CHANGE - DEG K
 EFFC = 0.900 HELIUM CIRCULATION SYSTEM COMPRESSOR EFFICIENCY
 EFFT = 0.332 TURBINE EFFICIENCY
 HC = 539000.000 SALT LATENT HEAT OF FUSION - WATT-SEC/KGM
 HT = 6.100 LONGEST TUBE LENGTH MANUFACTURED - M
 IJ = 0 = 1 HEXAGONAL SPACING OF TUBES
 = 0 RECTANGULAR SPACING OF TUBES
 IPRINT = 1 PRINTING INDICATOR = 1 PRINT INTERIM CALCULATIONS
 = 0 PRINT ONLY FINAL RESULTS
 ISHAPE = 0 = 1 CYLINDRICAL VESSEL CROSSECTION
 = 0 SQUARE VESSEL CROSSECTION
 NTU = 5.700 NO. OF THERMAL UNITS
 PD = 50000000.000 DISCHARGE RATE - WATTS
 PRESS = 3450000.000 SYSTEM PRESSURE - N/M**2
 STRESS = 3860000.000 ALLOWABLE STRESS IN TUBING MATERIAL - N/M**2
 TAU = 21600.000 STORAGE TIME - SEC
 TAVG = 786.000 AVERAGE HEATER TEMPERATURE - DEG K
 TI = 1089.000 HEATER INLET TEMPERATURE - DEG K
 TMELT = 913.000 SALT MELT TEMPERATURE - DEG K
 TO = 778.000 INITIAL STORAGE TEMPERATURE - DEGK
 VCD = 12.300 VESSEL DIAMETER - METERS
 VIS = 0.001700 SALT VISCOSITY - N-SEC/M**2
 XK = 4.300 SALT THERMAL CONDUCTIVITY - WATTS/M-DEGK

***** INITIAL DEFAULT VALUES *****

C1 = 0.980 RATIO OF ACTUAL TO CALC. TUBE NUMBERS
 TD = 0.100 TUBE DIAMETER - METERS
 TS = 0.028 TUBE SPACING - METERS

***** HELIUM PROPERTIES AT T = 786.00 *****

XKF = 0.305 THERMAL CONDUCTIVITY - WATTS/M-DEGK
 DENF = 1.524 DENSITY - KGM/M**3
 VISF = 0.000036 VISCOSITY - N-SEC/KGM-DEGK
 CPF = 5230.000 HEAT CAPACITY - WATT-SEC/KGM-DEGK
 GAMMA = 1.670 RATIO OF SPECIFIC HEATS

| M1 | ALP | X1 | MB | SBB | XBB | IPC | NTP |
|-----|-------|-------|-----|-------|-------|-------|-------|
| 184 | 0.008 | 0.070 | 184 | 1.000 | 0.066 | 16744 | 33672 |

VESSEL CROSSECTONAL SHAPE IS SQUARE
TUBE SPACING PATTERN IS SQUARE

| | |
|----------------------------------|---------------------|
| VESSEL CHARACTERISTIC DIMENSION | 12.30 METERS |
| TUBE OUTER DIAMETER | 0.00964 METERS |
| TUBE HALF SPACING | 0.02840 METERS |
| TUBE WALL THICKNESS | 0.00065 METERS |
| TUBE NUMBER | 33579 |
| VESSEL HEIGHT | 12.09 METERS |
| HEIGHT/DIAMETER RATIO | 0.98 |
| ACTUAL CALCULATED TUBE NO. RATIO | 0.98 |
| PRESSURE DROP | 3.99 PERCENT |
| FLUID FLOW VELOCITY | 69.95 M/SEC |
| REYNOLDS NUMBER | 23604.98 |
| PRANDTL NUMBER | 0.65 |
| NUSSELT NUMBER | 52.13 |
| FILM COEFFICIENT | 1905.65 WATT/M**2-K |
| UNIT CONDUCTANCE | 476.60 WATT/M**2-K |
| REQUIRED THERMAL ENERGY | 903.61 MEGAWATT-HRS |
| REQUIRED TES MEDIA MASS | 4196558.00 KGM |
| REQUIRED TES MEDIA VOLUME | 1794.17 M**3 |
| TUBING METAL VOLUME | 7.41 M**3 |
| NUMBER OF WELDS IN TUBING | 33579 |
| TUBING VOLUME | 29.61 M**3 |
| DISTANCE FROM WALL TO TUBE CAL | 0.07003 METERS |
| CONSISTANCY RELATION | 1.00267 |
| CONVERGENCE CONDITION | 1.00278 |
| UA-VALUE | 5.84 MEGAWATTS/K |
| REQUIRED HELIUM PUMP SIZE | 24.38 MEGAWATTS |

8

**** COST SUMMARY ****

| ACCOUNT | QUANTITY | UNIT COST (\$/Q) | COST (M\$) |
|--------------------------------|-----------|------------------|--------------|
| TES MEDIA (M**3) | 1794.17 | 2170.00 | 3.89 |
| STORAGE CONTAINER (M**2) | 594.66 | 4100.00 | 2.44 |
| HEAT EXCHANGER | | | |
| METAL VOLUME (M**3) | 7.41 | 99000.00 | 0.73 |
| TUBING LENGTH (M) | 204831.88 | 4.92 | 1.01 |
| NUMBER OF WELDS (NO.) | 33579 | 12.00 | 0.40 |
| MANIFOLD ALLOWANCE (+20%) | | | 0.43 |
| HELIUM CIRCULATION SYSTEM (MW) | 24.38 | 53531.47 | 1.31 |
| TOTAL | | | 10.21 |



Section 6.

PROGRAM LISTINGS

BLOCK DATA

C COMMON/SALT/C(500)
C DATA C / 500*0.0/
C EQUIVALENCE (PI ,C(56))
C DATA PI /3.14159 /
C EQUIVALENCE (NTU ,C(1)),(PD ,C(2))
C EQUIVALENCE (TAU ,C(3)),(CDR ,C(4))
C EQUIVALENCE (TI ,C(5)),(DT ,C(6))
C EQUIVALENCE (DMT ,C(7)),(EFFT ,C(8))
C EQUIVALENCE (PRESS ,C(9)),(DPO ,C(10))
C EQUIVALENCE (XKF ,C(11)),(DENF ,C(12))
C EQUIVALENCE (VISF ,C(13)),(CPF ,C(14))
C EQUIVALENCE (XK ,C(15)),(DEN ,C(16))
C EQUIVALENCE (VIS ,C(17)),(CPL ,C(18))
C EQUIVALENCE (CPS ,C(19)),(HC ,C(20))
C EQUIVALENCE (TMELT ,C(21)),(XKW ,C(22))
C EQUIVALENCE (STRESS ,C(24))
C EQUIVALENCE (HT ,C(25)),(CTES ,C(26))
C EQUIVALENCE (CMT1 ,C(27)),(CMT2 ,C(28))
C EQUIVALENCE (CMW ,C(29)),(CW ,C(30))
C EQUIVALENCE (IPRINT ,C(31)),(IJ ,C(32))
C EQUIVALENCE (CSR ,C(33))
C EQUIVALENCE (TDI ,C(85)),(TSI ,C(86))
C EQUIVALENCE (CII ,C(87))
C EQUIVALENCE (DMTC ,C(70)),(EFFC ,C(65))
C EQUIVALENCE (CVW ,C(68))
C EQUIVALENCE (TAVG ,C(88)),(EFFT1 ,C(89))
C EQUIVALENCE (DT1 ,C(90)),(DPO1 ,C(91))
C EQUIVALENCE (CM ,C(92))
C EQUIVALENCE (TO ,C(94)),(CPSA ,C(95))
C EQUIVALENCE (CPSB ,C(96))
C EQUIVALENCE (VTES ,C(34)),(TD ,C(35))
C EQUIVALENCE (TS ,C(36)),(VCD ,C(37))
C EQUIVALENCE (C1 ,C(38)),(ISHAPE ,C(39))

C
REAL NTU
C

DATA NTU,PD,TAU,CDR / 3.0 ,50000000.,21600.0 ,0.9 /
DATA TI,DT,DMT,EFFT / 1111.0 ,246.00 ,195.0 ,0.4 /
DATA PRESS,DPO,XKF,DENF/ 3450000.0,0.04 ,0.3839 ,1.472 /
DATA VISF,CPF,XK,DEN / 4.794E-5,5230.0 ,4.3 ,2339.0 /
DATA VIS,CPL,CPS,HC / 0.0017 ,1204.0 ,1204.0 ,598000.0 /
DATA TMELT,XKW / 908.0 ,23.3 /
DATA STRESS,HT,CTES,CM / 3.86E+7,6.1 ,2170.0 , 20.0 /
DATA CMT1,CMT2,CMW,CW / 99000.0 ,4.92 ,9500.0 ,12.0 /
DATA IPRINT,IJ,CSR,CVW / 1, 0,1.0 ,4100.0 /
DATA TAVG,EFFT1,DT1,DPO1/786.0 ,0.442 ,111.0 ,0.07 /

C
DATA VTES,TD,TS,VCD / 1150.0 ,0.0427 ,0.02975 ,11.28 /
DATA C1,ISHAPE / 0.98 , 0/ /
DATA TO,CPSA,CPSB / 833.0 ,814.1 ,0.2825 /

C
DATA DMTC,EFFC / 195.0 ,0.4 /

C
DATA TDI,TSI,CII / 0.1 ,0.028 ,0.98 /

C
END

```
COMMON/SALT/C(500)
C
C EQUIVALENCE (IPASS      ,C( 55))
C EQUIVALENCE (IPASS1     ,C( 58))
C EQUIVALENCE (IPASS2     ,C( 59))
C EQUIVALENCE (IPASS3     ,C( 60))
C
C CALL ERRSET(208,1000,-1,1)
C CALL ERRSET(209,1000,-1,1)
C CALL ERRSET(217,1      ,-1,1)
C
C WRITE(6,1000)
C
C DIMENSION AC      (20)
C
100 READ(5,1010,END=200)AC
      WRITE(6,1020)AC
C
C GO TO 100
C
200 REWIND 5
C
C**** OPERATING CONDITIONS INITIALIZATION
C
300 CALL INITIAL(&800)
C
C**** CALCULATE REQUIRED TES MEDIA VOLUME
C
C      CALL VOLM
C
C**** SELECT SYSTEM GEOMETRY
C
C      IPASS=0
C
C      IPASS1=0
C      IPASS2=0
C      IPASS3=0
C
500 CALL GEOM
C
```

```
    IPASS=IPASS+1
C
C**** CALCULATE CONVECTIVE FILM COEFFICIENT
C
C      CALL FILMCO
C
C**** CALCULATE TUBE SPACING
C
C      IPASS1=IPASS1+1
C
C      IF(IPASS1.GT.20)CALL UABEND(1)
C
C      CALL TUBSPC(8500)
C
C**** PRESSURE LOSS CALCULATION
C
C      IPASS1=0
C
C      IPASS2=IPASS2+1
C
C      IF(IPASS2.GT.100)CALL UABEND(2)
C
C      CALL PLOSS(8500)
C
C      IPASS2=0
C
C      IPASS3=IPASS3+1
C
C      IF(IPASS3.GT.10)CALL UABEND(3)
C
C      CALL EXTUN(8500)
C
C**** ANALYZE SOLUTION
C
C      CALL ANAL
C
C**** SIZE HELIUM CIRCULATION PUMPING
C
C      CALL HEPUMP
C
```

```
C**** COST ESTIMATE CALCULATIONS
C
C      CALL COST
C
C**** PRINT CASE OUTPUT
C
C      CALL OUTPUT
C
C      GO TO 300
C
C      800 STOP
C
1000 FORMAT('1')
1010 FORMAT(20A4)
1020 FORMAT(1X,20A4)
END
```

SUBROUTINE ANAL

C COMMON/SALT/C(500)

C EQUIVALENCE (NT ,C(41)),(TD ,C(35))
EQUIVALENCE (HF ,C(42)),(TWT ,C(47))
EQUIVALENCE (PI ,C(56))
EQUIVALENCE (VL ,C(40)),(VT ,C(57))
EQUIVALENCE (HT ,C(25))
EQUIVALENCE (VW ,C(63)),(TL ,C(66))
EQUIVALENCE (VM ,C(61)),(NW ,C(62))
EQUIVALENCE (VCD ,C(37)),(ISHAPE ,C(39))

C VM=PI*FLOAT(NT)*VL*(TD*TWT-TWT**2)

C NW=NT*INT(VL/HT)

C IF(ISHAPE.EQ.0)VW=4.0*VCD*VL
IF(ISHAPE.EQ.1)VW= PI*VCD*VL

C**** VOLUME OCCUPIED BY TUBES

C VT=FLOAT(NT)*VL*PI*TD**2/4.0

C TL=FLOAT(NT)*HT

C RETURN
END

```
FUNCTION CBRT(X)
C
C      IF(X.LT.0.0) GO TO 10
C
C      CBRT=X**0.3333333
C      RETURN
C
C      10 XL=-X
C
C      CBRT=-XL**0.3333333
C      RETURN
C
C      END
```

SUBROUTINE COST

C

COMMON/SALT/C(500)

C

| | | |
|---------------------|-----------------|----------|
| EQUIVALENCE (CTES | ,C(26)),(CMT1 | ,C(27)) |
| EQUIVALENCE (CMT2 | ,C(28)),(CMW | ,C(29)) |
| EQUIVALENCE (CW | ,C(30)),(VTES | ,C(34)) |
| EQUIVALENCE (VM | ,C(61)),(NT | ,C(41)) |
| EQUIVALENCE (NW | ,C(62)),(VW | ,C(63)) |
| EQUIVALENCE (TL | ,C(66)),(CHP | ,C(67)) |
| EQUIVALENCE (PCP | ,C(69)),(CVW | ,C(68)) |
| EQUIVALENCE (CCTES | ,C(78)),(CCVW | ,C(79)) |
| EQUIVALENCE (CPHX1 | ,C(80)),(CPHX2 | ,C(81)) |
| EQUIVALENCE (CPHX3 | ,C(82)),(CCHP | ,C(83)) |
| EQUIVALENCE (CTOTAL | ,C(84)) | |
| EQUIVALENCE (CM | ,C(92)),(CCM | ,C(93)) |

C

CCTES=CTES*VTES/1000000.0

C

CPHX1=CMT1*VM/1000000.0

CPHX2=CMT2*TL/1000000.0

CPHX3=CW *FLOAT(NW)/1000000.0

C

CCHP=CHP*PCP/1000000.0

C

CCVW=CVW*VW/1000000.0

C

CCM =CM*(CPHX1+CPHX2+CPHX3)/100.0

C

CTOTAL=CCTES+CPHX1+CPHX2+CPHX3+CCHP+CCVW+CCM

C

RETURN

END

```
SUBROUTINE CUBIC(A,B,C,D,ANS)
P=B/A
Q=C/A
R=D/A
P3=P/3.
AA=(3.*Q-P**2)/3.
BB=(2.*P**3-9.*P*Q+27.*R)/27.
TER=AA**3/27.
TERM=BB**2/4.+TER
IF(ABS(TERM).GT.0.0) GO TO 10
C
C**** THREE REAL ROOTS, TWO EQUAL
C
AB=2.*CBRT(-BB/2.)
ABB=-AB/2.

C
C**** SELECT POSITIVE ROOT
C
ANS=AMAX1(AB-P3,ABB-P3)
RETURN
10 IF(TERM.LT.0.)GO TO 20
C
C**** ONE REAL ROOT, TWO CONJUGATE IMAGINARY ROOTS
C
STERM=SQRT(TERM)
AAA=CBRT(-BB/2.+STERM)
BBB=CBRT(-BB/2.-STERM)
C
C**** SELECT REAL ROOT
C
ANS=AAA+BBB-P3
RETURN
C
C**** THREE REAL, UNEQUAL ROOTS
C
20 STER=SQRT(-TER)
THETA=ACOS(-BB/2./STER)
TE=2.*SQRT(-AA/3.)
THETA3=THETA/3.
X1=TE*COS(THETA3)-P3
```

```
X2=TE*COS(THETA3+2.09439)-P3
X3=TE*COS(THETA3+4.18879)-P3
```

```
C
```

```
C**** SELECT SMALLEST POSITIVE ROOT
```

```
C
```

```
ANS=AMAX1(X1,X2,X3)
IF(X1.GT.0.)ANS=AMIN1(ANS,X1)
IF(X2.GT.0.)ANS=AMIN1(ANS,X2)
IF(X3.GT.0.)ANS=AMIN1(ANS,X3)
RETURN
END
```

SUBROUTINE EXTUN(*)
C
C COMMON/SALT/C(500)
C
C EQUIVALENCE (VCD ,C(37)),(TD ,C(35))
C EQUIVALENCE (CSR ,C(33)),(IJ ,C(32))
C EQUIVALENCE (IPRINT ,C(31)),(TS ,C(36))
C EQUIVALENCE (ISHAPE ,C(39)),(BC ,C(51))
C EQUIVALENCE (NT ,C(41)),(C1 ,C(38))
C EQUIVALENCE (AC ,C(52)),(IPASS3 ,C(60))
C EQUIVALENCE (PI ,C(56))
C EQUIVALENCE (X1 ,C(74)),(C1C1P ,C(76))
C
C**** THIS ROUTINE COMPUTES THE EXACT TUBE NUMBER
C
C IF(IPASS3.EQ.1)C1P=C1
C
C**** INITIALIZATION
C
C M1 =INT((VCD-2.0*CSR*TS)/(TD+2.0*TS))
50 XL1=TD+2.0*TS
DST=2.0*(FLOAT(M1)+CSR)*TS+FLOAT(M1)*TD
ALP=(VCD-DST)/2.0
X1 =2.0*TS*CSR+ALP +TD/2.0
C
C IF(IJ.NE.1)GO TO 100
C
C MB =2*M1-1
SBB=1.0/2.0
XBB=SQRT(3.0)/2.0*XL1
C
C GO TO 200
C
100 MB =M1
SBB=1.0
XBB=XL1
C
200 IPC=0
C
DO 500 I=1,MB

```
C      A=IJ*MOD(I+1,2)
C
C      XI=X1+FLOAT(I-1)*SBB*XL1
C
C      RB=0.5*VCD-2.0*TS*CSR-ALP
C
C      YXI=RB
C
C      IF(ISSHAP.EQ.1)YXI=SQRT(RB**2-(XI-RB-X1)**2)
C
C      DELTA=YXI/XBB
C
C      IP=INT(SBB*(DELTA-A))+INT(A)
C
500  IPC=IPC+IP
C
C      NTP=2*IPC+M1
C
C      IF(IPRINT.EQ.0)GO TO 600
C
C      IF(IPASS3.EQ.1)WRITE(6,1000)
C
C      WRITE(6,1010)M1,ALP,X1,MB,SBB,XBB,IPC,NTP
C
600  NTB=4.0*BC/PI*AC*VCD**2/(TD+2.0*TS)**2
C
C      C1 =FLOAT(NTP)/FLOAT(NTB)
C
C      C1C1P=C1/C1P
C
C      IF(ABS((C1-C1P)/C1).LT.0.05)RETURN
C
C      C1P=C1
C
C      RETURN 1
C
1000 FORMAT(1      M1      ALP      X1      MB      SBB      '
C      X      ,      XBB      IPC      NTP      '/')
C1010 FORMAT( 1X,I6,4X,2F10.3,I6,4X,2F10.3,I6,4X,I6)
```

C

END

SUBROUTINE FILMCO

C COMMON/SALT/C(500)

C EQUIVALENCE (NT ,C(41)),(HF ,C(42))
EQUIVALENCE (VISF ,C(13)),(STRESS ,C(24))
EQUIVALENCE (PRESS ,C(9)),(TD ,C(35))
EQUIVALENCE (VF ,C(43)),(RE ,C(44))
EQUIVALENCE (PR ,C(45)),(XNU ,C(46))
EQUIVALENCE (TWT ,C(47))
EQUIVALENCE (DENF ,C(12)),(CPF ,C(14))
EQUIVALENCE (XKF ,C(11)),(DMT ,C(7))
EQUIVALENCE (PI ,C(56))

C **** THIS ROUTINE COMPUTES THE FLUID FILM COEFFICIENT

C

C

C **** TUBE WALL THICKNESS

C

TWT=PRESS/STRESS*TD/2.0*1.5

C

C **** FLOW VELOCITY

C

VF=DMT/FLOAT(NT)*4.0/DENF/PI/(TD-2.0*TWT)**2

C

C **** REYNOLDS NUMBER

C

RE=VF*(TD-2.0*TWT)/VISF*DENF

C

C **** PRANDTL NUMBER

C

PR=CPF*VISF/XKF

C

C **** NUSSELT NUMBER

C

XNU=0.0215*RE**0.8*PR**0.6

C

C **** FILM COEFFICIENT

C

HF=XNU*XKF/(TD-2.0*TWT)

C

RETURN
END

SUBROUTINE GEOM

C

COMMON/SALT/C(500)

C

EQUIVALENCE (NTU ,C(1)),(DMT ,C(7))
EQUIVALENCE (CPF ,C(14)),(TD ,C(35))
EQUIVALENCE (ISHAPE ,C(39))
EQUIVALENCE (C1 ,C(38)),(VL ,C(40))
EQUIVALENCE (TD ,C(35)),(TS ,C(36))
EQUIVALENCE (VCD ,C(37)),(UC ,C(48))
EQUIVALENCE (B ,C(50)),(IJ ,C(32))
EQUIVALENCE (AC ,C(52)),(BC ,C(51))
EQUIVALENCE (VTES ,C(34))
EQUIVALENCE (NT ,C(41))
EQUIVALENCE (PI ,C(56))
EQUIVALENCE (IPASS ,C(55))
EQUIVALENCE (HDR ,C(72)),(VLVLC ,C(75))

C

REAL NTU

C

BC=1.0

C

IF(ISHAPE.EQ.1)BC=PI/4.0

C

AC=PI/4.0

C

IF(IJ.EQ.1)AC=PI*SQRT(3.0)/9.0

C

NT =C1*4.0*BC/PI*AC*VCD**2/(TD+2.0*TS)**2

C

IF(IPASS.EQ.1)RETURN

C

***** SELECT VESSEL LENGTH

C

B=NTU*DMT*CPF

C

VL=B/PI/TD/FLOAT(NT)/UC

C

VLC=4.0/PI*VTES/(4.0/PI*BC*VCD**2-FLOAT(NT)*TD**2)

C

HDR=VL/VCD
VLVLC=VL/VLC

C

RETURN
END

SUBROUTINE HEPUMP

C
COMMON/SALT/C(500)

C
EQUIVALENCE (TI ,C(5)),(CPF ,C(14))
EQUIVALENCE (DPO ,C(10)),(PCP ,C(69))
EQUIVALENCE (GAMMA ,C(64)),(CHP ,C(67))
EQUIVALENCE (EFFC ,C(65)),(DMTC ,C(70))
EQUIVALENCE (TAVG ,C(88)),(EFFT1 ,C(89))
EQUIVALENCE (DT1 ,C(90)),(DPO1 ,C(91))

C
C**** COMPUTE REQUIRED HE PUMPING COMPRESSOR POWER & COST

C
T1=TI-DT1

C
PCP1=DMTC*CPF*T1 *((1.0/(1.0-DPO1))**((GAMMA-1.0)/GAMMA)-1.0)
PCP=PCP1/(EFFC+(1.0/(1.0-DPO1))**((GAMMA-1.0)/GAMMA)-1.0)

C
CHP =210.0/(PCP/800000.0)**0.4*1.0/1000.0

C
RETURN
END

SUBROUTINE INITIAL(*)

C

COMMON/SALT/C(500)

C

| | | |
|---------------------|------------------|----------|
| EQUIVALENCE (NTU | ,C(1)),(PD | ,C(2)) |
| EQUIVALENCE (TAU | ,C(3)),(CDR | ,C(4)) |
| EQUIVALENCE (TI | ,C(5)),(DT | ,C(6)) |
| EQUIVALENCE (DMT | ,C(7)),(EFFT | ,C(8)) |
| EQUIVALENCE (PRESS | ,C(9)),(DPO | ,C(10)) |
| EQUIVALENCE (XKF | ,C(11)),(DENF | ,C(12)) |
| EQUIVALENCE (VISF | ,C(13)),(CPF | ,C(14)) |
| EQUIVALENCE (XK | ,C(15)),(DEN | ,C(16)) |
| EQUIVALENCE (VIS | ,C(17)),(CPL | ,C(18)) |
| EQUIVALENCE (CPS | ,C(19)),(HC | ,C(20)) |
| EQUIVALENCE (TMELT | ,C(21)),(XKW | ,C(22)) |
| EQUIVALENCE (ISPACE | ,C(23)),(STRESS | ,C(24)) |
| EQUIVALENCE (HT | ,C(25)),(CTES | ,C(26)) |
| EQUIVALENCE (CMT1 | ,C(27)),(CMT2 | ,C(28)) |
| EQUIVALENCE (CMW | ,C(29)),(CW | ,C(30)) |
| EQUIVALENCE (IPRINT | ,C(31)),(IJ | ,C(32)) |
| EQUIVALENCE (CSR | ,C(33)) | |
| EQUIVALENCE (VCD | ,C(37)) | |
| EQUIVALENCE (ISHAPE | ,C(39)) | |
| EQUIVALENCE (CVW | ,C(68)),(EFFC | ,C(65)) |
| EQUIVALENCE (DMTC | ,C(70)) | |
| EQUIVALENCE (VTES | ,C(34)),(TD | ,C(35)) |
| EQUIVALENCE (TS | ,C(36)),(C1 | ,C(38)) |
| EQUIVALENCE (TDI | ,C(85)),(TSI | ,C(86)) |
| EQUIVALENCE (C1I | ,C(87)) | |
| EQUIVALENCE (TAVG | ,C(88)),(EFFT1 | ,C(89)) |
| EQUIVALENCE (DT1 | ,C(90)),(DPO1 | ,C(91)) |
| EQUIVALENCE (CM | ,C(92)) | |
| EQUIVALENCE (TO | ,C(94)),(CPSA | ,C(95)) |
| EQUIVALENCE (CPSB | ,C(96)) | |

C

REAL NTU

C

CDR CHARGE/DISCHARGE RATIO

C

CM MANIFOLD ALLOWANCE IN HEAT EXCHANGER COST - %

C

CMT1 COST PER M**3 OF TUBING METAL VOLUME - \$/M**3

C CMT2 COST PER M OF TUBING METAL LENGTH - \$/M
C CPL SALT HEAT CAPACITY (LIQUID) - WATT-SEC/KGM-DEGK
C CPSA SALT HEAT CAP COEFF (SOLID) - WATT-SEC/KGM-DEGK
C CPSB SALT HEAT CAP COEFF (SOLID) - WATT-SEC/KGM-DEGK**2
C CSR RATIO OF WALL CLEARANCE TO INTERTUBE SPACING
C CTES COST PER M**3 OF TES MEDIA - \$/M**3
C CVW COST PER M**2 OF WALL MATERIALS - \$/M**2
C CW COST PER WELD - \$/WELD
C DEN SALT DENSITY - KGM/M**3
C DMT TOTAL MASS FLOW RATE - KGM/SEC
C DMTC CHARGE CONDITION MASS FLOW RATE - KGM-SEC
C DPO PRESSURE DROP CRITERIA
C DPO1 PRESSURE DROP IN HEATER + RECIEVER
C DT TEMPERATURE CHANGE ACROSS SYSTEM - DEG K
C DT1 PINCH POINT TEMPERATURE CHANGE - DEG K
C EFFC HELIUM CIRCULATION SYSTEM COMPRESSOR EFFICIENCY
C EFFT TURBINE EFFICIENCY
C HC SALT LATENT HEAT OF FUSION - WATT-SEC/KGM
C HT LONGEST TUBE LENGTH MANUFACTURED - M
C IJ = 1 HEXAGONAL SPACING OF TUBES
= 0 RECTANGULAR SPACING OF TUBES
C IPRINT PRINTING INDICATOR = 1 PRINT INTERIM CALCULATIONS
= 0 PRINT ONLY FINAL RESULTS
C ISHAPE = 1 CYLINDRICAL VESSEL CROSSECTION
= 0 SQUARE VESSEL CROSSECTION
C NTU NO. OF THERMAL UNITS
C PD DISCHARGE RATE - WATTS
C PRESS SYSTEM PRESSURE - N/M**2
C STRESS ALLOWABLE STRESS IN TUBING MATERIAL - N/M**2
C TAU STORAGE TIME - SEC
C TAVG AVERAGE HEATER TEMPERATURE - DEG K
C TI HEATER INLET TEMPERATURE - DEC K
C TMELT SALT MELT TEMPERATURE - DEG K
C TO INITIAL STORAGE TEMPERATURE - DEGK
C VCD VESSEL DIAMETER - METERS
C VIS SALT VISCOSITY - N-SEC/M**2
C XK SALT THERMAL CONDUCTIVITY - WATTS/M-DEGK
C ***** DEFAULT VALUES *****
C

```

C   C1      DEFAULT VALUE OF RATIO OF ACTUAL/CALC TUBE NO
C   TD      DEFAULT VALUE OF TUBE DIAMETER - M
C   TS      DEFAULT VALUE OF TUBE SPACING - M
C
DIMENSION ID1  (13),ID2  (13),ID3  (13),ID4  (13),ID5  (13)
DIMENSION ID6  (13),ID7  (13),ID8  (13),ID9  (13),ID10 (13)
DIMENSION ID11 (13),ID12 (13),ID13 (13),ID14 (13),ID15 (13)
DIMENSION ID16 (13),ID17 (13),ID18 (13),ID19 (13),ID20 (13)
DIMENSION ID21 (13),ID22 (13),ID23 (13),ID24 (13),ID25 (13)
DIMENSION ID26 (13),ID27 (13),ID28 (13),ID29 (13),ID30 (13)
DIMENSION ID31 (13),ID32 (13),ID33 (13),ID34 (13),ID35 (13)
DIMENSION ID36 (13),ID37 (13),ID38 (13),ID39 (13),ID40 (13)
C
C   DIMENSION ID291(13),ID301(13),ID311(13)
C
DATA ID1  '//  NO. OF THERMAL UNITS          '/'
DATA ID2  '//  DISCHARGE RATE - WATTS          '/'
DATA ID3  '//  STORAGE TIME - SEC              '/'
DATA ID4  '//  CHARGE/DISCHARGE RATIO          '/'
DATA ID5  '//  HEATER INLET TEMPERATURE - DEG K  '/'
DATA ID6  '//  TEMPERATURE CHANGE ACROSS SYSTEM - DEG K  '/'
DATA ID7  '//  TOTAL MASS FLOW RATE - KGM/SEC          '/'
DATA ID8  '//  CHARGE CONDITION MASS FLOW RATE - KGM-SEC          '/'
DATA ID9  '//  HELIUM CIRCULATION SYSTEM COMPRESSOR EFFICIENCY  '/'
DATA ID10 //  TURBINE EFFICIENCY          '/'
DATA ID11 //  SYSTEM PRESSURE - N/M**2          '/'
DATA ID12 //  PRESSURE DROP CRITERIA          '/'
DATA ID13 //  MANIFOLD ALLOWANCE IN HEAT EXCHANGER COST - %  '/'
DATA ID14 //  SALT THERMAL CONDUCTIVITY - WATTS/M-DEGK          '/'
DATA ID15 //  SALT DENSITY - KGM/M**3          '/'
DATA ID16 //  SALT VISCOSITY - N-SEC/M**2          '/'
DATA ID17 //  SALT HEAT CAPACITY (LIQUID) - WATT-SEC/KGM-DEGK          '/'
DATA ID18 //  SALT HEAT CAP COEFF (SOLID) - WATT-SEC/KGM-DEGK          '/'
DATA ID19 //  SALT LATENT HEAT OF FUSION - WATT-SEC/KGM          '/'
DATA ID20 //  SALT MELT TEMPERATURE - DEG K          '/'
DATA ID21 //  ALLOWABLE STRESS IN TUBING MATERIAL - N/M**2          '/'
DATA ID22 //  LONGEST TUBE LENGTH MANUFACTURED - M          '/'
DATA ID23 //  COST PER M**3 OF TES MEDIA - $/M**3          '/'
DATA ID24 //  COST PER M**3 OF TUBING METAL VOLUME - $/M**3          '/'
DATA ID25 //  COST PER M OF TUBING METAL LENGTH - $/M          '/'

```

DATA ID26 /* INITIAL STORAGE TEMPERATURE - DEGK */
DATA ID27 /* COST PER WELD - \$/WELD */
DATA ID28 /* COST PER M**2 OF WALL MATERIALS - \$/M**2 */
DATA ID29 /* PRINTING INDICATOR = 1 PRINT INTERIM CALCULATIONS */
DATA ID291/* = 0 PRINT ONLY FINAL RESULTS */
DATA ID30 /* = 1 HEXAGONAL SPACING OF TUBES */
DATA ID301/* = 0 RECTANGULAR SPACING OF TUBES */
DATA ID31 /* = 1 CYLINDRICAL VESSEL CROSSECTION */
DATA ID311/* = 0 SQUARE VESSEL CROSSECTION */
DATA ID32 /* RATIO OF WALL CLEARANCE TO INTERTUBE SPACING */
DATA ID33 /* VESSEL DIAMETER - METERS */
DATA ID34 /* TUBE DIAMETER - METERS */
DATA ID35 /* TUBE SPACING - METERS */
DATA ID36 /* RATIO OF ACTUAL TO CALC. TUBE NUMBERS */
DATA ID37 /* AVERAGE HEATER TEMPERATURE - DEG K */
DATA ID38 /* SALT HEAT CAP COEFF (SOLID) - WATT-SEC/KGM-DEGK**2 */
DATA ID39 /* PINCH POINT TEMPERATURE CHANGE - DEG K */
DATA ID40 /* PRESSURE DROP IN HEATER + RECIEVER */

C

NAMELIST/INPUT/NTU ,PD ,TAU ,CDR ,TI ,DT ,DMT
X ,EFFT ,PRESS ,DPO ,XKF ,DENF ,VISF ,CPF
X ,XK ,DEN ,VIS ,CPL ,CPS ,HC ,TMELT
X ,XXW ,ISHAPE ,STRESS ,HT ,CTES ,CMT1 ,CMT2
X ,CMW ,CW ,IPRINT ,IJ ,CSR ,VCD ,DMTC
X ,EFFC ,CVW ,TAVG ,EFFT1 ,DT1 ,DPO1 ,CM
X ,TO ,CPSA ,CPSB ,C1I ,TDI ,TSI

61

C

READ(5,INPUT,END=800)

C

WRITE(6,1005)

C

WRITE(6,1040)CDR ,ID4
WRITE(6,1130)CM ,ID13
WRITE(6,1240)CMT1 ,ID24
WRITE(6,1250)CMT2 ,ID25
WRITE(6,1170)CPL ,ID17
WRITE(6,1180)CPSA ,ID18
WRITE(6,1380)CPSB ,ID38
WRITE(6,1320)CSR ,ID32
WRITE(6,1230)CTES ,ID23

```
      WRITE(6,1280)CVW  ,ID28
      WRITE(6,1270)CW   ,ID27
      WRITE(6,1150)DEN  ,ID15
      WRITE(6,1070)DMT  ,ID7
      WRITE(6,1080)DMTC ,ID8
      WRITE(6,1120)DPO  ,ID12
      WRITE(6,1370)DPO1 ,ID40
      WRITE(6,1060)DT   ,ID6
      WRITE(6,1360)DT1  ,ID39
      WRITE(6,1090)EFFC ,ID9
      WRITE(6,1100)EFFT ,ID10
      WRITE(6,1190)HC   ,ID19
      WRITE(6,1220)HT   ,ID22
      WRITE(6,1300)IJ   ,ID30, ID301
      WRITE(6,1290)IPRINT, ID29, ID291
      WRITE(6,1310)ISHAPE, ID31, ID311
      WRITE(6,1010)NTU  ,ID1
      WRITE(6,1020)PD   ,ID2
      WRITE(6,1110)PRESS ,ID11
      WRITE(6,1210)STRESS, ID21
      WRITE(6,1030)TAU  ,ID3
      WRITE(6,1340)TAVG ,ID37
      WRITE(6,1050)TI   ,ID5
      WRITE(6,1200)TMELT ,ID20
      WRITE(6,1260)TD   ,ID26
      WRITE(6,1330)VCD  ,ID33
      WRITE(6,1160)VIS  ,ID16
      WRITE(6,1140)XK   ,ID14
```

C

```
      TD=TDI
      TS=TSI
      C1=C1I
```

C

```
      WRITE(6,1500)
      WRITE(6,1530)C1   ,ID36
      WRITE(6,1510)TD   ,ID34
      WRITE(6,1520)TS   ,ID35
```

C

```
      **** COMPUTE WORKING FLUID PROPERTIES
```

C

CALL PROPFL

C

RETURN

C

800 RETURN 1

C

1005 FORMAT('1 **** INPUTS ****',/)
1010 FORMAT(' NTU = ',F13.3,3X,13A4)
1020 FORMAT(' PD = ',F13.3,3X,13A4)
1030 FORMAT(' TAU = ',F13.3,3X,13A4)
1040 FORMAT(' CDR = ',F13.3,3X,13A4)
1050 FORMAT(' TI = ',F13.3,3X,13A4)
1060 FORMAT(' DT = ',F13.3,3X,13A4)
1070 FORMAT(' DMT = ',F13.3,3X,13A4)
1080 FORMAT(' DMTC = ',F13.3,3X,13A4)
1090 FORMAT(' EFFC = ',F13.3,3X,13A4)
1100 FORMAT(' EFFT = ',F13.3,3X,13A4)
1110 FORMAT(' PRESS = ',F13.3,3X,13A4)
1120 FORMAT(' DPO = ',F13.3,3X,13A4)
1130 FORMAT(' CM = ',F13.3,3X,13A4)
1140 FORMAT(' XK = ',F13.3,3X,13A4)
1150 FORMAT(' DEN = ',F13.3,3X,13A4)
1160 FORMAT(' VIS = ',F13.6,3X,13A4)
1170 FORMAT(' CPL = ',F13.3,3X,13A4)
1180 FORMAT(' CPSA = ',F13.3,3X,13A4)
1190 FORMAT(' HC = ',F13.3,3X,13A4)
1200 FORMAT(' TMELT = ',F13.3,3X,13A4)
1210 FORMAT(' STRESS = ',F13.3,3X,13A4)
1220 FORMAT(' HT = ',F13.3,3X,13A4)
1230 FORMAT(' CTES = ',F13.3,3X,13A4)
1240 FORMAT(' CMT1 = ',F13.3,3X,13A4)
1250 FORMAT(' CMT2 = ',F13.3,3X,13A4)
1260 FORMAT(' TO = ',F13.3,3X,13A4)
1270 FORMAT(' CW = ',F13.3,3X,13A4)
1280 FORMAT(' CVW = ',F13.3,3X,13A4)
1290 FORMAT(' IPRT = ',I9,4X,3X,13A4,/26X,13A4)
1300 FORMAT(' IJ = ',I9,4X,3X,13A4,/26X,13A4)
1310 FORMAT(' ISHAPE = ',I9,4X,3X,13A4,/26X,13A4)
1320 FORMAT(' CSR = ',F13.3,3X,13A4)
1330 FORMAT(' VCD = ',F13.3,3X,13A4)

```
1340 FORMAT(' TAVG    = ',F13.3,3X,13A4)
1360 FORMAT(' DT1     = ',F13.3,3X,13A4)
1370 FORMAT(' DPQ1    = ',F13.3,3X,13A4)
1380 FORMAT(' CPSB    = ',F13.3,3X,13A4)
1500 FORMAT(/ '      *** INITIAL DEFAULT VALUES ****',/)
1510 FORMAT(' TD     = ',F13.3,3X,13A4)
1520 FORMAT(' TS     = ',F13.3,3X,13A4)
1530 FORMAT(' C1     = ',F13.3,3X,13A4)
C
END
```

SUBROUTINE OUTPUT

C

COMMON/SALT/C(500)

C

| | | |
|---------------------|-----------------|----------|
| EQUIVALENCE (ISHAPE | ,C(39)),(IJ | ,C(32)) |
| EQUIVALENCE (VCD | ,C(37)),(TD | ,C(35)) |
| EQUIVALENCE (TS | ,C(36)),(TWT | ,C(47)) |
| EQUIVALENCE (NT | ,C(41)),(C1 | ,C(38)) |
| EQUIVALENCE (VF | ,C(43)),(RE | ,C(44)) |
| EQUIVALENCE (PR | ,C(45)),(XNU | ,C(46)) |
| EQUIVALENCE (HF | ,C(42)),(UC | ,C(48)) |
| EQUIVALENCE (VM | ,C(61)),(VT | ,C(57)) |
| EQUIVALENCE (VTES | ,C(34)),(NW | ,C(62)) |
| EQUIVALENCE (B | ,C(50)) | |
| EQUIVALENCE (HDR | ,C(72)),(VLVLC | ,C(75)) |
| EQUIVALENCE (X1 | ,C(74)),(C1C1P | ,C(76)) |
| EQUIVALENCE (RTE | ,C(71)) | |
| EQUIVALENCE (DP | ,C(73)) | |
| EQUIVALENCE (XM | ,C(77)) | |
| EQUIVALENCE (CCTES | ,C(78)),(CCVW | ,C(79)) |
| EQUIVALENCE (CPHX1 | ,C(80)),(CPHX2 | ,C(81)) |
| EQUIVALENCE (CPHX3 | ,C(82)),(CCHP | ,C(83)) |
| EQUIVALENCE (CTOTAL | ,C(84)) | |
| EQUIVALENCE (VW | ,C(63)),(CTES | ,C(26)) |
| EQUIVALENCE (CVW | ,C(68)),(CMT1 | ,C(27)) |
| EQUIVALENCE (CMT2 | ,C(28)),(CW | ,C(30)) |
| EQUIVALENCE (CHP | ,C(67)),(PCP | ,C(69)) |
| EQUIVALENCE (TL | ,C(66)) | |
| EQUIVALENCE (VL | ,C(40)) | |
| EQUIVALENCE (CM | ,C(92)),(CCM | ,C(93)) |

69

C

DIMENSION ISO (6),IJO (6)

C

DATA ISO /'SQUA','RE ',' ',' ','CYLI','NDRI','CAL '/
DATA IJO /'SQUA','RE ',' ',' ','HEXA','GONA','L '/

C

WRITE(6,1000)

C

IF(ISHAPE.EQ.0)IS1=1
IF(ISHAPE.EQ.1)IS1=4

```
      IF(IJ      .EQ.0)IS2=1
      IF(IJ      .EQ.1)IS2=4
C
      WRITE(6,1010)ISO(IS1),ISO(IS1+1),ISO(IS1+2)
      WRITE(6,1020)IJO(IS2),IJO(IS2+1),IJO(IS2+2)
C
      WRITE(6,1030)VCD
      WRITE(6,1040)TD
      WRITE(6,1050)TS
      WRITE(6,1060)TWT
      WRITE(6,1070)NT
      WRITE(6,1080)VL
      WRITE(6,1090)HDR
      WRITE(6,1110)C1
C
      DPO=DP*100.0
C
      WRITE(6,1100)DPO
C
      WRITE(6,1120)VF
      WRITE(6,1130)RE
      WRITE(6,1140)PR
      WRITE(6,1150)XNU
      WRITE(6,1160)HF
      WRITE(6,1170)UC
C
      RTO=RTE/1000000.0/3600.0
C
      WRITE(6,1180)RTO
      WRITE(6,1190)XM
      WRITE(6,1200)VTES
      WRITE(6,1210)VM
C
      WRITE(6,1220)NW
      WRITE(6,1230)VT
      WRITE(6,1240)X1
      WRITE(6,1250)VLVLC
      WRITE(6,1260)C1C1P
C
      BO=B/1000000.0
```

```
C      WRITE(6,1270)BO
C
C      PCPO=PCP/1000000.0
C      CHPC=CHP*1000000.0
C
C      WRITE(6,1280)PCPO
C
C      WRITE(6,1500)
C      WRITE(6,1510)
C
C      ICCM= CM+0.0001
C
C      WRITE(6,1520)VTES,CTES,CCTES
C      WRITE(6,1530)VW,CVW,CCVW
C      WRITE(6,1540)
C      WRITE(6,1550)VM,CMT1,CPHX1
C      WRITE(6,1560)TL,CMT2,CPHX2
C      WRITE(6,1570)NW,CW,CPHX3
C      WRITE(6,1575)ICCM,CCM
C      WRITE(6,1580)PCPO,CHPO,CCHP
C      WRITE(6,1590)CTOTAL
C
C      RETURN
C
1000 FORMAT('1')
1010 FORMAT('OVESSEL CROSSECTIONAL SHAPE IS ',3A4)
1020 FORMAT(' TUBE SPACING PATTERN IS ',3A4)
1030 FORMAT('OVESSEL CHARACTERISTIC DIMENSION      ',F13.2,' METERS')
1040 FORMAT(' TUBE OUTER DIAMETER                 ',F13.5,' METERS')
1050 FORMAT(' TUBE HALF SPACING                  ',F13.5,' METERS')
1060 FORMAT(' TUBE WALL THICKNESS                 ',F13.5,' METERS')
1070 FORMAT(' TUBE NUMBER                         ',I13)
1080 FORMAT(' VESSEL HEIGHT                      ',F13.2,' METERS')
1090 FORMAT(' HEIGHT/DIAMETER RATIO                ',F13.2)
1100 FORMAT(' PRESSURE DROP                      ',F13.2,' PERCENT')
1110 FORMAT(' ACTUAL CALCULATED TUBE NO. RATIO   ',F13.2)
1120 FORMAT('OFLUID FLOW VELOCITY                 ',F13.2,' M/SEC')
1130 FORMAT(' REYNOLDS NUMBER                     ',F13.2)
1140 FORMAT(' PRANDTL NUMBER                      ',F13.2)
```

1150 FORMAT(' NUSSELT NUMBER ',F13.2)
1160 FORMAT(' FILM COEFFICIENT ',F13.2,' WATT',
X ' /M**2-K')
1170 FORMAT(' UNIT CONDUCTANCE ',F13.2,' WATT',
X ' /M**2-K')
1180 FORMAT(' REQUIRED THERMAL ENERGY ',F13.2,' MEGAWATT',
X ' -HRS')
1190 FORMAT(' REQUIRED TES MEDIA MASS ',F13.2,' KGM')
1200 FORMAT(' REQUIRED TES MEDIA VOLUME ',F13.2,' M**3')
1210 FORMAT(' TUBING METAL VOLUME ',F13.2,' M**3')
1220 FORMAT(' NUMBER OF WELDS IN TUBING ',I13)
1230 FORMAT(' TUBING VOLUME ',F13.2,' M**3')
1240 FORMAT(' DISTANCE FROM WALL TO TUBE C/L ',F13.5,' METERS')
1250 FORMAT(' CONSISTANCY RELATION ',F13.5)
1260 FORMAT(' CONVERGENCE CONDITION ',F13.5)
1270 FORMAT(' UA VALUE ',F13.2,' MEGAWATTS',
X ' /K ')
1280 FORMAT(' REQUIRED HELIUM PUMP SIZE ',F13.2,' MEGAWATTS')

C

1500 FORMAT('1 **** COST SUMMARY ****')
1510 FORMAT('OACCOUNT',30X,'QUANTITY UNIT COST (\$/Q) COST (M\$)')
1520 FORMAT('OTES MEDIA (M**3) ',3F15.2)
1530 FORMAT('OSTORAGE CONTAINER (M**2) ',3F15.2)
1540 FORMAT('OHEAT EXCHANGER ')
1550 FORMAT(' METAL VOLUME (M**3) ',3F15.2)
1560 FORMAT(' TUBING LENGTH (M) ',3F15.2)
1570 FORMAT(' NUMBER OF WELDS (NO.) ',I15,2F15.2)
1575 FORMAT(' MANIFOLD ALLOWANCE (',I2,'%) ',30X,F15.2)
1580 FORMAT('OHELIUM CIRCULATION SYSTEM (MW) ',3F15.2)
1590 FORMAT('OTOTAL ',30X,F15.2)

C

END

```
SUBROUTINE PLOSS(*)
C
C      COMMON/SALT/C(500)
C
C      EQUIVALENCE (DPO      ,C( 10)),(VL      ,C( 40))
C      EQUIVALENCE (VF       ,C( 43)),(RE      ,C( 44))
C      EQUIVALENCE (DENF     ,C( 12)),(PRESS   ,C(  9))
C      EQUIVALENCE (TD       ,C( 35)),(TWT     ,C( 47))
C      EQUIVALENCE (HT       ,C( 25)),(UC      ,C( 48))
C      EQUIVALENCE (IPASS2   ,C( 59))
C      EQUIVALENCE (DP       ,C( 73))

C      F=0.3164/RE**0.25
C
C      **** PRESSURE LOSS
C
C      DP =0.5*DENF/PRESS*VF**2*F*VL/(TD-2.0*TWT)
C
C      IF(IPASS2.GT.1)GO TO 50
C
C      IF(DP.LT.DPO)ISTEP=1
C      IF(DP.LT.DPO)STEP=0.9
C      IF(DP.GT.DPO)ISTEP=2
C      IF(DP.GT.DPO)STEP=1.1
C
C      50 GO TO (100,200,300),ISTEP
C
C      100 IF(DP.GT.DPO)GO TO 300
C
C      TDP=TD
C      TDP=TD
C      DPP=DP
C      TD =TD*STEP
C
C      RETURN 1
C
C      200 IF(DP.LT.DPO)GO TO 300
C
C      TDP=TD
C      TDP=TD
```

```
DPP=DP
TD =TD*STEP
C
RETURN 1
C
300 TDPR=TD+(TDP-TD)*(DP-DPO)/(DP-DPP)
C
DPP=DP
TDP=TD
TD=TDPR
C
IF(ABS((TDP-TDPR)/TDPR).LT.0.001)GO TO 400
C
ISTEP=3
C
RETURN 1
C
400 RETURN
C
END
```

SUBROUTINE PROPFL

C

COMMON/SALT/C(500)

C

EQUIVALENCE (TI ,C(5)),(PRESS ,C(9))
EQUIVALENCE (DENF ,C(12)),(VISF ,C(13))
EQUIVALENCE (CPF ,C(14)),(GAMMA ,C(64))
EQUIVALENCE (XKF ,C(11))
EQUIVALENCE (TAVG ,C(88))

C

DIMENSION TA (6)
DIMENSION XKFA (6)
DIMENSION VISFA (6)

C

DATA TA /555.56 ,694.56 ,833.33 ,972.22 ,1111.11 ,1255.55 /
DATA XKFA /0.2386 ,0.2801 ,0.3182 ,0.3545 ,0.3839 ,0.4150 /
DATA VISFA/2.976E-5,3.472E-5,3.926E-5,4.381E-5,4.794E-5,5.208E-5/

C

DATA NPTS / 6/

C

GAMMA=1.67
CPF =5230.0

C

R=8314.0
AW=4.0

C

DENF=PRESS/R/TI*AW

C

XKF =TABLE1(TA,XKFA ,NPTS,TAVG)
VISF=TABLE1(TA,VISFA,NPTS,TAVG)

C

DIMENSION ID1 (13),ID2 (13),ID3 (13),ID4 (13),ID5 (13)

C

DATA ID1 /* THERMAL CONDUCTIVITY - WATTS/M-DEGK /*
DATA ID2 /* DENSITY - KGM/M**3 /*
DATA ID3 /* VISCOSITY - N-SEC/KGM-DEGK /*
DATA ID4 /* HEAT CAPACITY - WATT-SEC/KGM-DEGK /*
DATA ID5 /* RATIO OF SPECIFIC HEATS /*

C

WRITE(6,1000)TAVG

```
      WRITE(6,1010)XKF  ,ID1
      WRITE(6,1020)DENF  ,ID2
      WRITE(6,1030)VISF  ,ID3
      WRITE(6,1040)CPF   ,ID4
      WRITE(6,1050)GAMMA ,ID5
C
1000 FORMAT('0          *** HELIUM PROPERTIES AT T =',F10.2,' ***')/
1010 FORMAT(' XKF      = ',F13.3,3X,13A4)
1020 FORMAT(' DENF     = ',F13.3,3X,13A4)
1030 FORMAT(' VISF     = ',F13.6,3X,13A4)
1040 FORMAT(' CPF      = ',F13.3,3X,13A4)
1050 FORMAT(' GAMMA   = ',F13.3,3X,13A4)
C
      RETURN
      END
```

```
FUNCTION TABLE1(X,Y,N,AX)
DIMENSION X(1),Y(1)
C
  I=1
  IF(AX-X(I))40,40,80
40 I=2
  GO TO 110
80 IF(I-N)100,90,90
90 SL=(Y(N)-Y(N-1))/(X(N)-X(N-1))
  TABLE1=SL*(AX-X(N))+Y(N)
  RETURN
100 I=I+1
  IF(AX-X(I))110,110,80
110 SL=(Y(I)-Y(I-1))/(X(I)-X(I-1))
  TABLE1=SL*(AX-X(I-1))+Y(I-1)
  RETURN
  END
```

SUBROUTINE TUBSPC(*)
C
C COMMON/SALT/C(500)
C
EQUIVALENCE (HF ,C(42)),(TWT ,C(47))
EQUIVALENCE (UC ,C(48)),(TD ,C(35))
EQUIVALENCE (XK ,C(15)),(TST ,C(49))
EQUIVALENCE (B ,C(50)),(BC ,C(51))
EQUIVALENCE (AC ,C(52)),(VTES ,C(34))
EQUIVALENCE (TS ,C(36)),(IPASS ,C(55))
EQUIVALENCE (HF ,C(42)),(C1 ,C(38))
EQUIVALENCE (IPASS ,C(55))
EQUIVALENCE (PI ,C(56))
EQUIVALENCE (XKW ,C(22))
C
DATA TSP / 0.0/
C
C***** THIS ROUTINE COMPUTES TUBE SPACING - TS
C
C
IF(IPASS.GT.1)GO TO 100
C
C***** MAKE INITIAL ESTIMATE OF TS
C
A1=2.0/XK
A2=2.0*TD/XK+4.0*(1.0/HF-TST/XKW)
A3=TD**2/2.0/TD+4.0*TD*(1.0/HF-TST/XKW)-PI*AC*TD**2/4.0/BC/2.0/XK
A4=TD**2*(1.0/HF+TWT/XKW)-PI*AC*TD**2/4.0/BC-PI*TD*AC*VTES/B/BC
C
CALL CUBIC(A1,A2,A3,A4,TS)
C
C
100 T1=TD-2.0*TWT
T2=SQRT(TD**2+T1**2)
C
XL1=ALOG(T2/T1/2.0**0.5)
XL2=ALOG(2.0**0.5*TD/T2)
C
T3=SQRT(TD**2+(TD+2.0*TS)**2)
C

```
XL3=ALOG(T3/TD/2.0**0.5)
C
C**** COMPUTE UNIT CONDUCTANCE
C
UC=1.0/(1.0/HF+T1/2.0/XKW*(XL1+XL2)+T1/2.0/XK*XL3)
C
TD2S2=C1*AC*TD**2+(4.0*TD*C1*AC*VTES)/B*UC
C
TS =(SQRT(TD2S2)-TD)/2.0
C
IF(ABS((TS-TSP)/TS).LT.0.00005)RETURN
C
TSP=TS
C
RETURN 1
C
END
```

SUBROUTINE VOLM
C
COMMON/SALT/C(500)
C
EQUIVALENCE (PD ,C(2)),(TAU ,C(3))
EQUIVALENCE (EFFT ,C(8)),(HC ,C(20))
EQUIVALENCE (VTES ,C(34)),(DEN ,C(16))
EQUIVALENCE (CPL ,C(18)),(CPS ,C(19))
EQUIVALENCE (DT ,C(6))
EQUIVALENCE (RTE ,C(71))
EQUIVALENCE (XM ,C(77))
EQUIVALENCE (TO ,C(94)),(CPSA ,C(95))
EQUIVALENCE (CPSB ,C(96))
EQUIVALENCE (TMELT ,C(21))
C
C**** COMPUTE REQUIRED TES MEDIA VOLUME
C
C**** REQUIRED THERMAL ENERGY (RTE)
C
RTE=PD*TAU/EFFT
C
C**** TES MEDIA MASS
C
DCP=CPL-CPSA-CPSB/2.0*(TMELT-TO)
C
XM=RTE/(HC+CPL*DT-(TMELT-TO)*DCP)
C
C**** TES MEDIA VOLUME
C
VTES=XM/DEN
C
RETURN
END

1117 CARDS

APPENDIX I

KIRCHKOFF CORRECTION TO EUTECTIC HEAT OF FUSION

The heat of fusion for molten salt eutectics are often calculated on the basis of a mole average of the heat of fusion of the constituent salts. Significant errors can be encountered for eutectic melt temperatures significantly removed from the constituent salt melt temperatures. Kirchhoff's Law can be applied to correct the eutectic salt heat of fusion. Kirchhoff's Law can be stated as:

If a reaction originally takes place at a temperature T_1 and has a heat of reaction of ΔH_{T_1} at that temperature, then the heat of reaction at some other temperature T_2 is given by

$$\Delta H_{T_2} = \Delta H_{T_1} + \int_{T_1}^{T_2} \Delta C_p dT \quad (I-1)$$

Applying this law to a two-component eutectic salt yields (I-2)

$$h_e = x_A h_A + x_B h_B + x_A \int_{T_e}^{T_A} (C_{pA}(s) - C_{pA}(l)) dT + x_B \int_{T_e}^{T_B} (C_{pB}(s) - C_{pB}(l)) dT$$

where h_A , h_B \equiv component salt heats of fusion, T_A , T_B \equiv component salt melt temperatures, $C_{pA}(s)$, $C_{pB}(s)$ solid heat capacity of components, $C_{pA}(l)$, $C_{pB}(l)$ \equiv liquid heat capacity of components, T_e \equiv eutectic melt temperature, x_A , x_B \equiv mole fraction of component salts in eutectic mixture.

The heat capacity can be expressed as

$$C_p = a + bT + cT^{-2} \quad (I-3)$$

Defining I by

$$\begin{aligned} I &= x_A \int_{T_e}^{T_A} C_p dT = x_A \int_{T_e}^{T_A} (a + bT + cT^{-2}) dT \\ &= x_A \left[a(T - T_e) + \frac{b}{2} (T^2 - T_e^2) + c (T_e^{-1} - T^{-1}) \right] \end{aligned}$$

Then eqn. (I-2) yields

$$h_e = x_A h_A + x_B h_B + I_A^S - I_A^\ell + I_B^S - I_B^\ell \quad (I-4)$$

Values for h , a , b , c for various salts are available in the literature.* Characteristically, b , c are zero for liquid component salts.

This same methodology should be extendable to three component eutectic mixtures:

$$h_e = x_A h_A + x_B h_B + x_C h_C + I_A^S - I_A^\ell + I_B^S - I_B^\ell + I_C^S - I_C^\ell \quad (I-5)$$

Sample results for calculation on a two-component salt are shown below:

Table I-1
SAMPLE RESULTS

| Salt | Melt temperature (°C) | Molecular weight (g/mole) | a_s (cal/mole °C) | $b_s \times 10^3$ (cal/mole (°C) ²) | $c_s \times 10^{-5}$ (cal (°C) ² /mole) | $C_p (\ell)$ (cal/mole °C) | h (cal/mole) | x (%) |
|----------------------|--------------------------|------------------------------|------------------------|--|---|-------------------------------|-------------------|------------|
| NaF | 1268 | 41.99 | 10.4 | 3.88 | -0.33 | 16.4 | 8030 | 40.5 |
| KF | 1131 | 58.1 | 11.88 | 2.22 | -0.72 | 16.0 | 6750 | 59.5 |
| 40.5 NaF/ 59.5 KF | 983 | 51.58 | | | | | 6860 | |

The heat of fusion of the 40.5 NaF/59.5KF eutectic expressed on a per-unit mass basis is 133 cal/g. This value is 7 cal/g or 5% less than the mole average heat of fusion. In general, this method of correction has produced satisfactory results for eutectic heats of fusion.** For candidate fluoride salts where experimental data were not available on the eutectic heat of fusion, the Kirchhoff correction was applied to data on the component salts.

A check on the correction accuracy for the type of salts considered in this study was made by applying Eqn. (I-4) to a salt with experimental heat of fusion data. For the eutectic 67 LiF/33MgF₂, Dr. Schroder, from the Philips

*"Molten Salt Chemistry," Interscience, N.Y., 1964, p. 141.

**Bramlette, et al, "Survey of High Temperature Thermal Energy Storage," Sandia Labs, Albuquerque, N.M., March 1976.

Labs in Aachen, Germany, has measured at 746°C melt temperature the heat of fusion value to be 217 cal/g. The mole average heat of fusion is 235 cal/g and the Kirchhoff correction is 13 cal/g, yielding a calculated heat of fusion of 222 cal/g. Comparison shows for this salt, the Kirchhoff correction is too small. This implies that, although the Kirchhoff correction can be used to provide approximate heat of fusion data, a detailed TES design with a specific salt will require experimental verification of the salt thermophysical properties.




APPENDIX II

UNIT THERMAL CONDUCTANCE ANALYSIS

The heat transfer from/to the helium flow to/from the storage media for the sensible heat and phase change TES systems has been modeled as a one-dimensional problem. For the purpose of the initial presentation, a planar heat flow model has been adopted. This approach greatly simplifies the presentation and leads to a conclusion that applies equally well to the radial heat flow problem.

At a given axial position in the storage device, the heat flow from the working fluid into the storage media is substantially a one-dimensional problem. The working fluid temperature varies with time at a given axial location and the media simply responds to that temperature change. Symmetrical adiabatic surfaces develop between the uniformly heated tubes which further reduces the problem to the classical case of the semi-infinite plate uniformly heated on one side and insulated on the other. Any basic heat transfer text treats this transient problem. There is an exact solution to this problem, but it is complex in the general case. Over a wide range of parameters of practical interest in our problem, these solutions can be avoided by the adoption of a single node approximation. The accuracy of this approach is demonstrated in the following paragraphs by comparison to the step change response characteristic of the partial differential equation.

Under the above conditions, the one-dimensional temperature distribution within the media shown below must satisfy the following partial differential equations.



$$\frac{\partial^2 t}{\partial x^2} = 1/\alpha \frac{\partial t}{\partial \tau}$$

where:

α = storage media thermal diffusivity

In addition, the following initial and boundary conditions apply:

$$t - t_f = t_i - t_f \text{ at } \tau = 0 \quad (\text{II-1})$$

$$\frac{\partial (t-t_f)}{\partial x} = 0 \text{ at } x = 0 \text{ for all } \tau \quad (\text{II-2})$$

$$-k \frac{\partial^2 (t-t_f)}{\partial x^2} = h (t-t_f) \text{ at } x = l \quad (\text{II-3})$$

The solution to the partial differential equation with these boundary and initial conditions is obtained by the separation of variables technique and is as follows:

$$\frac{t-t_f}{t_i-t_f} = 2 \sum_{n=1}^{\infty} \left(\frac{\sin \lambda_n l}{\lambda_n l + \sin \lambda_n l \cos \lambda_n l} \right) e^{-\lambda_n^2 \alpha \tau} \cos \lambda_n x \quad (\text{II-4})$$

The λ_n satisfy the transcendental equation

$$\cot \lambda_n l = \frac{k}{n} \lambda_n \quad (\text{II-5})$$

and are referred to as the eigenvalues.

The condition of concern in our problem is the heat flux rate at the surface which is given by

$$q = -k \left(\frac{\partial (t-t_f)}{\partial x} \right)_{x=\ell} \quad (II-6)$$

Then by defining the unit thermal conductance as,

$$U = \frac{q}{(t_0 - t_f)} \quad (II-7)$$

U can be written in terms similar to equation (4) as follows:

$$U = \frac{k}{\ell} \frac{\sum_{n=1}^{\infty} \left(\frac{N_n \sin^2 N_n}{N_n + \sin N_n \cos N_n} \right) e^{-N_n^2 N_{Fo}}}{\sum_{n=1}^{\infty} \left(\frac{\sin N_n}{N_n + \sin N_n \cos N_n} \right) e^{-N_n^2 N_{Fo}}} \quad (II-8)$$

and the eigenvalues (N_n) now satisfy the expression,

$$N_n \tan N_n - N_{Bi} = 0 \quad (II-9)$$

The non-dimensional quantities that have been introduced in equations (II-8) and (II-9) are the Fourier Number (N_{Fo}) and the Biot number (N_{Bi}) which are defined as follows:

$$N_{Fo} = \frac{\alpha \tau}{\ell^2}$$

$$N_{Bi} = \frac{h \ell}{k}$$

The Fourier number is a measure of the degree heating or cooling effects have penetrated the plate and the Biot number is indicative of the resistance to heat transfer at the surface of the plate compared to its internal resistance.

For our particular problem, $\frac{N_{Fo}}{\tau}$ runs about 3.0 and N_{Bi} runs about 4-5. The data presented below include variations in N_{Bi} from 1.0 to 10.0 and variations in N_{Fo} from .3 to 5.0. Since the time response in the axial heat transfer problem is about .5 hour, considerations of longer times here are of little significance.

The solution for the unit thermal conductance in equation (II-9) is a complex series solution. Fortunately, the series converges rather rapidly and satisfactory accuracy is obtained by considering only five terms. A chart of the eigenvalues for the first five terms is shown as a function of the Biot number in Figure II-1. Final results for the exact unit thermal conductance given in equation (II-8) are presented in Figure II-2. The single node approximation to the unit thermal conductance is shown for comparison with the exact data. The accuracy of the single node approximation is obviously very good.

The final conclusion applies equally well to the lateral heat flow problem in cylindrical coordinates. Specifically, the lateral heat flow problem can be adequately represented by a single thermal node approximation if that node is taken as the centroid of the thermal mass of the storage media enclosed by the adiabatic surface of symmetry between the heat exchanger tubes. The derivation and presentation of the resultant unit thermal conductance in cylindrical coordinates are given in Section 2.0 of this volume.




Figure II-1. Exact Unit Thermal Conductance Eigenvalues




Figure II-2. Single Node Unit Thermal Conductance Accuracy