

Sta 5

SEP 16 1999

12

## ENGINEERING DATA TRANSMITTAL

Page 1 of 13

1. EDT 626649

MB 9/16/99

2. To: (Receiving Organization) Information Resource Management	3. From: (Originating Organization) PFP Facility Systems Engineering	4. Related EDT No.: N/A
5. Proj./Prog./Dept./Div.: 101400/B000	6. Design Authority/ Design Agent/Cog. Engr.: R.D. Keck	7. Purchase Order No.: N/A
8. Originator Remarks: Initial release of supporting document.		9. Equip./Component No.: N/A
		10. System/Bldg./Facility: 12B/2721-Z
11. Receiver Remarks: 11A. Design Baseline Document? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		12. Major Assm. Dwg. No.: N/A
		13. Permit/Permit Application No.: N/A
		14. Required Response Date: N/A

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	HNF-5043	1-5	0	Standby Power System Commercial Grade Item Critical Characteristics	SQ	2	1	

16. KEY		Approval Designator (F)		Reason for Transmittal (G)		Disposition (H) & (I)		
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval 2. Release 3. Information	4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)			1. Approved 2. Approved w/comment 3. Disapproved w/comment	4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged	

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
2	1	Design Authority	RD Keck	8/16/99	T4-20						
		Design Agent									
		Cog. Eng.									
2	1	Cog. Mgr. GA Glover		8/16/99							
2	1	QA D.R. Groth		8/12/99	T4-20						
2	1	Safety D.A. Conners		8/16/99	T4-20						
		Env.									

18.		19.		20.		21. DOE APPROVAL (if required)		
MS Busch <i>Edmund Busch</i> Signature of EDT Originator	Date 8/31/99	Authorized Representative for Receiving Organization		RD Keck <i>RD Keck</i> Design Authority/ Cognizant Manager	Date 8/31/99	Ctrl. No.		
						<input type="checkbox"/> Approved	<input type="checkbox"/> Approved w/comments	<input type="checkbox"/> Disapproved w/comments

**UNREVIEWED SAFETY QUESTION (USQ)  
SCREENING AND EVALUATION**

Z of 3

Page 1 of 2 9/16/99

1. IDENTIFICATION NUMBER: EDT 626649

**USQ SCREENING**

Page 1 of 2 9/16/99

2. TITLE: HNF-5043, "Standby Power System Commercial Grade Item Critical Characteristics," Rev. 0

**INSTRUCTIONS:** Respond to each question and provide justification for each response. A re-statement of the question does not constitute a satisfactory justification or basis. An adequate justification provides sufficient explanation such that an independent reviewer could reach the same conclusion based on the information provided (DOE 5480.21, 10.e.1).

**DESCRIPTION:**

EDT 626649 releases HNF-5043, "Standby Power System Commercial Grade Item Critical Characteristics" Rev. 0. This document identifies the critical characteristics for Commercial Grade Item (CGI) procurements for the Standby Power System.

**INTRODUCTION:**

PFP's Standby Power System consists of the diesel generators, the generator control system, Rm 308 UPS, switchgear batteries, and the electrical equipment used to distribute this power. Due to the nature of the equipment and its use throughout general industry, the majority of the system falls within the CGI definition. HNF-PRO-268, "Control of Purchased Items and Services" and HNF-PRO-1819, "PHMC Engineering Requirements" require that the critical characteristics of CGI-procured equipment be established in an engineering document prior to placing the order. HNF-5043 establishes these critical characteristics for the Standby Power System. Equipment will be added to the list as required to support future CGI procurements.

**AFFECTED SSC:**

HNF-5043 establishes the critical characteristics for CGI procured for use in the Standby Power System. No other SSCs are affected.

**AUTHORIZATION BASIS:**

PFP's Standby Power System is covered by the PFP Final Safety Analysis Report (FSAR), HNF-SD-CP-SAR-021, Rev.1, ECN 649956, "Thermal Stabilization Project, Pre-ORR Support," and ECN 649958, "Thermal Stabilization Project, Pre-ORR Support." There are no OSRs, LCOs, or Surveillance Requirements associated with this system. The remaining documents of FSP-PFP-5-8, Section 2.23, Appendix A, Rev. 18 do not apply.

**CONCLUSION:**

The release of HNF-5043 is within the bounds of the Authorization Basis. All screening questions have been answered "No" or "N/A" so a USQ Evaluation is not required. No changes to the Authorization Basis are required.

**REFERENCES:**

HNF-PRO-1819, "PHMC Engineering Requirements," Rev. 3.

HNF-PRO-268, "Control of Purchased Items and Services," Rev. 3.

HNF-SD-CP-SDD-024, "Definition and Means of Maintaining the 2721-Z Standby Power System Portion of the PFP Safety Envelope," Rev. 1.

FSP-PFP-5-8, Section 2.23, IDENTIFICATION AND RESOLUTION OF UNRESOLVED SAFETY QUESTIONS, Appendix A, Rev. 18.

**QUESTIONS:**

1. Does the proposed change or occurrence represent a change to the facility or procedures as described in the Authorization Basis?

N/A    No    Yes/Maybe

**BASIS:** The Standby Power System is described in general in HNF-SD-CP-SAR-021, Plutonium Finishing Plant Final Safety Analysis Report, sections 1.2.2.1.7, Table 4-7, 5.1.2.4.1, 5.2.8.6.2, and 5.4.2. These descriptions do not specify the type, manufacturer, or specifications of any individual system equipment. Documenting the minimum critical characteristics for specific system equipment does not change any of these descriptions.

**UNREVIEWED SAFETY QUESTION (USQ)  
SCREENING AND EVALUATION**

3 of 3 MS  
Page 2 of 2 9/16/95

1. IDENTIFICATION NUMBER: EDT 626649

**USQ SCREENING**

2. TITLE: HNF-5043, "Standby Power System Commercial Grade Item Critical Characteristics," Rev. 0

2. Does the proposed change or occurrence represent conditions that have not been analyzed in the Authorization Basis?  
 N/A    No    Yes/Maybe

BASIS: The Standby Power System is not part of any accident scenarios in Chapter 9 of the FSAR. Additionally, Engineering and QA requirements dictate that CGI procured equipment is functionally tested prior to returning the system to service. This ensures that the equipment will perform its required safety function as intended.

3. Does the proposed change represent a test or experiment NOT described in the Authorization Basis that may affect the safe operation of the facility?  
 N/A    No    Yes/Maybe

BASIS: No new tests or experiments will be introduced by this change.

4. Does the proposed change or occurrence represent a change to the Technical Safety Requirements or a reduction in the margin of safety defined in the Technical Safety Requirements?  
 N/A    No    Yes/Maybe

BASIS: The OSRs, in their capacity as TSRs do not contain any requirements concerning this system. There are no LCOs, Administrative Controls, or Surveillance Requirements associated with this system. There are no margins of safety defined in the OSR.

USQE No. 1: M. S. BUSCH  
Print Name

USQE No. 1: Matt Busch 18/31/99  
Signature Date

USQE No. 2: R.D. Klock  
Print Name

USQE No. 2: R.D. Klock 18/31/99  
Signature Date

If there is a Yes/Maybe response to Questions 1, 2, 3, or 4, then a USQ Evaluation must be completed.

The following guidance should be considered when completing this screening. This guidance should not be considered all-inclusive. Additional factors may need to be considered depending on the nature of the proposed change.

Does the proposed change:

- 1) Modify, add, or delete a safety class function of a structure, system or component stated in the Authorization Basis?
- 2) Alter the design of a structure, system or component as described in the Authorization Basis?
- 3) Modify, add, or delete the description of operation, operating environment, or analyses of any system or component described in the Authorization Basis?
- 4) Modify, add, delete, or conflict with any of the design bases stated in the Authorization Basis?
- 5) Conflict with the principle or general design criteria stated in the Authorization Basis?
- 6) Modify, add, or delete any plant design features described in the Authorization Basis?
- 7) Modify, add, or delete a flow diagram or facility drawing provided in the Authorization Basis?
- 8) Create the potential for new system or component interactions (e.g., seismic, electrical breaker coordination)?

# PFP STANDBY POWER SYSTEM COMMERCIAL GRADE ITEM CRITICAL CHARACTERISTICS

**M. S. Busch**

B&W Hanford Company, Richland, WA 99352  
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 626649

UC: 506

Org Code: 15510

Charge Code: 101400

B&R Code: EW7002000

Total Pages: 6

Key Words: PFP, Standby Power, CGI, Critical Characteristics

Abstract: This document defines the critical characteristics of Commercial Grade Items procured for use in PFP's Standby Power System.


---

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

  
Release Approval

9/16/99  
Date



Approved for Public Release

## 1.0 PURPOSE

This document specifies the critical characteristics for Commercial Grade Items (CGI) procured for PFP's diesel generator system, as required by HNF-PRO-268 and HNF-PRO-1819. These are the minimum specifications that the equipment must meet in order to properly perform its safety function. There may be several manufacturers or models that meet the critical characteristics for any one item.

## 2.0 BACKGROUND

PFP's Standby Power System includes the 2721-Z diesel generators, the Room 308 UPS, the 125 VDC Switchgear batteries, and the electrical distribution equipment to deliver standby power to the required loads. Specific system boundaries and justifications are contained in HNF-SD-CP-SDD-024, "Definition and Means of Maintaining the 2721-Z Backup Power System Portion of the PFP Safety Envelope." A large percentage of this system is made up of standard industry components, such as diesel engine accessory equipment, generator control modules, and standard circuit breakers. The Standby Power System was designated a Safety Significant system on November 1, 1998. This new safety designation changed the procurement requirements associated with the system, and necessitates procurement of most system equipment as Commercial Grade Items in accordance with HNF-PRO-268, "Control of Purchased Items and Services."

## 3.0 SCOPE

Since the safety function of the Standby Power System does not impose any requirements unique to PFP, and due to the common use of various standby power systems throughout commercial industry, standard industry equipment is acceptable for most of PFP's Standby Power System. The following list of critical characteristics details the minimum specifications for this standard industry equipment. The critical characteristics are verified through a combination of receipt inspections and installation testing.

Due to the interactive nature of the individual standby power systems and their controls, the following characteristics assume the new part is either the same manufacturer and part number or a replacement part specified by the vendor. Further information for the listed equipment is available from the appropriate Vendor Information (VI) files.

## 4.0 CRITICAL CHARACTERISTIC LISTING

### 1. Magnetic Pickup Unit

#### Critical Characteristics:

- 0.5-30 V<sub>RMS</sub> supplied to governor when properly adjusted.
- Adjusted 5/8 to 7/8 of a turn back from contact with flywheel.

## **2. Governor Module**

### **Critical Characteristics:**

- Controls steady-state generator frequency at  $60 \pm 0.1$  Hz.
- Returns generator to base frequency after manual override of actuator (see figure 6 on page 247 of VI 21221 for example).
- Engine idle is stable without surging. Controls engine speed using input from synchronizer to allow synchronization with energized bus within 30 seconds.
- Controls engine actuator during load test with input from load share module to obtain generator output near set point (normally 250 kva) without oscillation.

## **3. Synchronizer Module**

### **Critical Characteristics:**

- Provides phase error signal to the governor and breaker closure signal within 30 seconds when line and generator's phases are matched as observed on the synch scope.

## **4. Actuator Assembly**

### **Critical Characteristics:**

- Controls engine speed with governor input to provide steady-state generator frequency at  $60 \pm 0.1$  Hz
- Controls engine power during load test with input from load share module to obtain generator output near set point (normally 250 kva) without oscillation.

## **5. Load Share Module**

### **Critical Characteristics:**

- Provides stable control output to governor during load test as evidenced by generator output being maintained near set point (normally 250 kVa) without oscillation.
- Under load sharing for two generator providing 2736-ZB backup power, load split between two generators is no worse than 60%-40%.

## **6. Engine Block Heater**

### **Critical Characteristics:**

- Maintains engine coolant temperature 90-200°F

## **7. Resistors (generic item)**

### **Critical Characteristics:**

- Specified resistance
- Power rating
- Tolerance

### **8. Transistors/Diodes (generic items)**

Critical Characteristics:

- Transistor or diode designation

### **9. Relays (generic item)**

Critical Characteristics:

- Base or socket configuration as specified.
- Contact rating as specified.
- Coil voltage as specified.
- 80% Pickup voltage.

### **10. Filters (Fuel, Oil, Cooling Water, Air)**

Critical Characteristics:

- Proper type (fuel, oil, water, or air).
- Physically fits filter receptacle with no noted leakage.

### **11. Galvanized Steel Reducers, nipples, adapters, etc for cooling system**

Critical Characteristics:

- Conform to ASTM A53, Type S, Grade B.
- Size as specified.

### **12. Block Heater Coolant Hose**

Critical Characteristics:

- Rated for at least 200°F.
- Size as specified.

### **13. Fuel Hoses**

Critical Characteristics:

- Rated for diesel fuel use.
- Size as specified.

### **14. Cord Caps (male and female)**

Critical Characteristics:

- UL listed.
- Amp rating as specified.

## **15. Engine Oil**

Critical Characteristics:

- Meets API CF-4 or CG-4 performance categories.
- Viscosity grade of SAE 15W-40.

## **16. Diesel Fuel**

Critical Characteristics:

- No. 2 or better diesel fuel.

## **17. Antifreeze**

Critical Characteristics:

- Conforms to ASTM D-3306/D-4985.

## **18. Water**

Critical Characteristics:

- Distilled, demineralized, or de-ionized water.

## **19. Grease**

Critical Characteristics:

- Lithium based.
- Operating range 0-275°F

## **20. Circuit Breakers**

Critical Characteristics:

- Time-current curve as specified.

### **3.0 REFERENCES**

- A. HNF-PRO-268, "Control of Purchased Items and Services," Rev. 3.**
- B. HNF-PRO-1819, "PHMC Engineering Requirements," Rev. 3.**
- C. Vendor Information file 21221.**
- D. HNF-SD-CP-SDD-024, "Definition and Means of Maintaining the 2721-Z Backup Power System Portion of the PFP Safety Envelope," Rev. 1.**
- E. Cummins Bulletin 3810340-02, "Cummins Engine Oil Recommendations."**
- F. Cummins Bulletin 3666132, "Cummins Coolant Requirements and Maintenance."**