

8

ENGINEERING CHANGE NOTICE

1. ECN

656334

Page 1 of 2

Proj.
ECN

| | | | |
|--|---|---|--|
| 2. ECN Category (mark one) <input type="checkbox"/> Supplemental <input checked="" type="checkbox"/> Direct Revision <input type="checkbox"/> Change ECN <input type="checkbox"/> Temporary <input type="checkbox"/> Standby <input type="checkbox"/> Supersedure <input type="checkbox"/> Cancel/Void | 3. Originator's Name, Organization, MSIN, and Telephone No. R. H. Webb, Nuclear Safety, R3-26, 373-2251 | 4. USQ Required? K-99-1511 <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 5. Date 12/17/99 |
| | 6. Project Title/No./Work Order No. SNF Project K Basins | 7. Bldg./Sys./Fac. No. K Basins | 8. Approval Designator S^N |
| | 9. Document Numbers Changed by this ECN (includes sheet no. and rev.) HNF-3960 Rev. 0 | 10. Related ECN No(s). N/A | 11. Related PO No. N/A |
| | | | |
| | | | |
| | | | |

| | | | |
|---|-------------------------------------|---|--|
| 12a. Modification Work <input type="checkbox"/> Yes (fill out Blk. 12b) <input checked="" type="checkbox"/> No (NA Blks. 12b, 12c, 12d) | 12b. Work Package No. N/A | 12c. Modification Work Complete <u>N/A</u> Design Authority/Cog. Engineer Signature & Date | 12d. Restored to Original Condition (Temp. or Standby ECN only) <u>N/A</u> Design Authority/Cog. Engineer Signature & Date |
|---|-------------------------------------|---|--|

13a. Description of Change 13b. Design Baseline Document? Yes No

Changes include:

1. Incorporation of fire hazards identified in the K Basins Fire Hazards Analysis (HNF-SD-SNF-FHA-001, Rev. 1):
 - + packing materials + rags
 - + oil + diesel fuel/gasoline
 - + building contents
2. Hazard analysis identified and documents liquid fuel (from transport vehicles) and crane oil to be included as a fire covered in a design basis accident (DBA) in the safety analysis report (SAR).
3. Packing materials, rags, and building contents fire hazards identified and documented as worker safety hazard.
4. "Criticality" added as a potential consequence in evaluation of cask drop in the hazard analysis worksheet (F.1A) to be consistent with evaluation in the K Basins criticality safety evaluation report (HNF-SD-SNF-CSER-005).
5. Minor cleanup editorial changes made to include correcting referenced DBA numbers in the hazard analysis worksheet, and updating references as necessary.

14a. Justification (mark one)

| | | | |
|---|---|--|--|
| Criteria Change <input checked="" type="checkbox"/> | Design Improvement <input type="checkbox"/> | Environmental <input type="checkbox"/> | Facility Deactivation <input type="checkbox"/> |
| As-Found <input type="checkbox"/> | Facilitate Const <input type="checkbox"/> | Const. Error/Omission <input type="checkbox"/> | Design Error/Omission <input type="checkbox"/> |

14b. Justification Details


The K Basins Fire Hazards Analysis (FHA) has been issued and the changes made in this document are provided for consistency with the FHA. Changes associated with the addition of fire hazards provide the basis for development of the fire DBA in the SAR.

Editorial changes were not technical in content.

15. Distribution (include name, MSIN, and no. of copies)

| | | | |
|-------------------|-------|------------------------|-------|
| M. J. Langevin | X3-76 | K Basins Project Files | X3-90 |
| R. H. Webb | R3-26 | | |
| R. L. Garrett | R3-26 | | |
| C. T. Miller | X3-79 | | |
| J. H. Wicks | X3-71 | | |
| J. R. Ellis | R3-26 | | |
| SNF Project Files | R3-11 | | |

RELEASE STAMP



ENGINEERING CHANGE NOTICE

Page 2 of 2

I. ECN (use no. from pg. 1)

656334

| | | | | | | |
|---|-----------------|----------------------------------|--------------|-------------------------------|----------------------------|---------|
| 16. Design Verification Required [] Yes [X] No | 17. Cost Impact | | | | 18. Schedule Impact (days) | |
| | ENGINEERING | | CONSTRUCTION | | Improvement | [] N/A |
| Additional Savings | [] N/A | Additional Savings | [] N/A | Delay | [] | |
| 19. Change Impact Review: Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 13. Enter the affected document number in Block 20. | | | | | | |
| SDD/DD | [] | Seismic/Stress Analysis | [] | Tank Calibration Manual | | |
| Functional Design Criteria | [] | Stress/Design Report | [] | Health Physics Procedure | | |
| Operating Specification | [] | Interface Control Drawing | [] | Spares Multiple Unit Listing | | |
| Criticality Specification | [] | Calibration Procedure | [] | Test Procedures/Specification | | |
| Conceptual Design Report | [] | Installation Procedure | [] | Component Index | | |
| Equipment Spec. | [] | Maintenance Procedure | [] | ASME Coded Item | | |
| Const. Spec. | [] | Engineering Procedure | [] | Human Factor Consideration | | |
| Procurement Spec. | [] | Operating Instruction | [] | Computer Software | | |
| Vendor Information | [] | Operating Procedure | [] | Electric Circuit Schedule | | |
| OM Manual | [] | Operational Safety Requirement | [] | ICRS Procedure | | |
| PSAR/SAR | [X] | IEPD Drawing | [] | Process Control Manual/Plan | | |
| Safety Equipment List | [] | Cell Arrangement Drawing | [] | Process Flow Chart | | |
| Radiation Work Permit | [] | Essential Material Specification | [] | Purchase Requisition | | |
| Environmental Impact Statement | [] | Fac. Proc. Samp. Schedule | [] | Tickler File | | |
| Environmental Report | [] | Inspection Plan | [] | | | |
| Environmental Permit | [] | Inventory Adjustment Request | [] | | | |

20. Other Affected Documents: (NOTE: Documents listed below will not be revised by this ECN.) Signatures below indicate that the signing organization has been notified of other affected documents listed below.







Document Number/Revision

Document Number/Revision

Document Number Revision

WHC-SD-WM-SAR-062 Rev. 3L

21. Approvals

| | | | |
|--|---|---|-----------------|
| Design Authority | M. J. Langevin | Signature | Date |
| |  |  | <u>12/28/99</u> |
| Cog. Eng. | R. H. Webb | Signature | Date |
| |  |  | <u>12/17/99</u> |
| Cog. Mgr. | R. L. Garrett | Signature | Date |
| |  |  | <u>12/28/99</u> |
| QA | N/A | Signature | Date |
| | |  | <u>12/28/99</u> |
| Safety | C. T. Miller | Signature | Date |
| |  |  | <u>12/28/99</u> |
| Environ. | N/A | Signature | Date |
| | |  | <u>12/28/99</u> |
| Operations | J. H. Wicks | Signature | Date |
| |  |  | <u>12/28/99</u> |
| DEPARTMENT OF ENERGY | | | |
| Signature or a Control Number that tracks the Approval Signature | | | |
| <u>ADDITIONAL</u> | | | |

K Basins Hazard Analysis

Roger Webb

Fluor Daniel Hanford, Inc., Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 656334
Org Code: 2F200
B&R Code: EW313540

UC: 620
Charge Code: 105414
Total Pages: 55


Key Words: Hazard, Frequency, Consequence, Source, Radiation, Prevention, Mitigation, Worker, Safety, Abnormal Event

Abstract: This report describes the methodology used in conducting the K Basins Hazard Analysis, which provides the foundation for the K Basins Safety Analysis Report (HNF-SD-WM-SAR-062, Rev.4). This hazard analysis was performed in accordance with guidance provided by DOE-STD-3009-94, Preparation Guide for U. S. Department of Energy Nonreactor Nuclear Facility Safety Analysis Reports and implements the requirements of DOE Order 5480.23, Nuclear Safety Analysis Report.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420 Fax (509) 376-4989.

[Signature] 12/29/99
Release Approval Date



Approved for Public Release

| | | | |
|---------------------------------------|--|---|--------|
| RECORD OF REVISION | | (1) Document Number HNF-3960, Rev. 1 | Page 1 |
| (2) Title K Basins Hazard Analysis | | | |

| CHANGE CONTROL RECORD | | | | | | | | | |
|-----------------------|---|------------------------|--------------------------|-------|------------------------|---------------------|--|--|--|
| (3) Revision | (4) Description of Change - Replace, Add, and Delete Pages | Authorized for Release | | | | | | | |
| | | (5) Cog. Engr. | Date | | | | | | |
| 0 | EDT: 626877 Original Document | R. H. Webb 9/20/99 | R. L. Garrett 9/20/99 | | | | | | |
| 1 <i>RS</i> | <p>EDT: 656334; Changes include:</p> <ol style="list-style-type: none"> 1. Incorporation of fire hazards identified in the K Basins Fire Hazards Analysis (HNF-SD-SNF-FHA-001, Rev. 1): <table> <tr><td>+ packing materials</td><td>+ rags</td></tr> <tr><td>+ oil</td><td>+ diesel fuel/gasoline</td></tr> <tr><td>+ building contents</td><td></td></tr> </table> 2. Hazard analysis identified and documents liquid fuel (from transport vehicles) and crane oil to be included as a fire covered in a design basis accident (DBA) in the safety analysis report (SAR). 3. Packing materials, rags, and building contents fire hazards identified and documented as worker safety hazard. 4. "Criticality" added as a potential consequence in evaluation of cask drop in the hazard analysis worksheet (F.1A) to be consistent with evaluation in the K Basins criticality safety evaluation report (HNF-SD-SNF-CSER-005). 5. Minor cleanup editorial changes made to include correcting referenced DBA numbers in the hazard analysis worksheet, and updating references as necessary. | + packing materials | + rags | + oil | + diesel fuel/gasoline | + building contents | | R. H. Webb <i>Roger H. Webb</i> 12/17/99 | R. L. Garrett <i>mark A. madd</i> for R.L. Garrett 12/28/99 |
| + packing materials | + rags | | | | | | | | |
| + oil | + diesel fuel/gasoline | | | | | | | | |
| + building contents | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

K BASIN HAZARD ANALYSIS

HNF-3960, Rev. 1

December 1999

This page intentionally left blank.

CONTENTS

| | |
|--|-----|
| 1.0 INTRODUCTION | 1 |
| 2.0 SCOPE | 1 |
| 3.0 METHODOLOGY | 2 |
| 4.0 RESULTS SUMMARY | 4 |
| 5.0 REFERENCES | 12 |
| Attachment A: Hazardous Material List | A-1 |
| Attachment B: Hazard Baseline - Energy Checklist | B-1 |
| Attachment C: Hazard Analysis Tables | C-1 |

LIST OF TABLES

| | |
|---|---|
| 3-1. Qualitative Accident Severity Levels | 3 |
| 3-2. Frequency Ranges | 3 |
| 4-1. Summary of S2 and S3 Hazard Items | 5 |
| 4-2. Summary of S1 (Worker Safety) Hazards | 7 |
| 4-3. Hazard Initiators for Potential Abnormal Event for K Basins (3 Sheets) | 9 |

LIST OF TERMS

| | |
|-------|--|
| AC | alternating current |
| BPA | Bonneville Power Administration |
| CCTV | closed-circuit television |
| CSER | criticality safety evaluation report |
| CVDF | Cold Vacuum Drying Facility |
| DBE | design basis earthquake |
| DBF | design basis flood |
| DC | direct current |
| DOE | U.S. Department of Energy |
| FRS | Fuel Retrieval System |
| GFI | ground fault interrupters |
| HA | hazard analysis |
| HAZOP | hazard and operability study |
| HEPA | high-efficiency particulate air (filter) |
| HPT | health physics technician |
| IPSS | immersion pail support structure |
| IWTS | Integrated Water Treatment System |
| IXC | ion-exchange column |
| IXM | ion-exchange module |
| KE | K East |
| KW | K West |
| MCO | Multi-Canister Overpack |
| MLS | Multi-Canister Overpack Loading System |
| NLOP | north loadout pit |
| PCB | polychlorinated biphenyl |
| PCM | primary clean machine |
| PHMC | Project Hanford Management Contract |
| PV | pressure--volume |
| SAA | satellite accumulation area |
| SAR | safety analysis report |
| SCBA | self-contained breathing apparatus |
| SLOP | south loadout pit |
| SNF | spent nuclear fuel |
| TSD | treatment, storage, and disposal |
| WAC | Washington Administrative Code |

1.0 INTRODUCTION

The K East (KE)/K West (KW) Basins in the 100 K Area of the Hanford Site have been used for storage of irradiated N Reactor and single-pass reactor fuel. The spent fuel is currently being stored underwater in racks and canisters in the basins. The Spent Nuclear Fuel (SNF) Project is adding equipment to the facility in preparation for removing the fuel from the basins to an interim storage location in the 200 Area.

In preparing this hazard analysis, a variety of hazard analysis techniques were used by the K Basins hazard analysis team, including hazard and operability studies (HAZOPs), preliminary hazard analyses, and "what if" analyses (WHC-SD-SNF-PHA-001, HNF-2032, HNF-2456, and HNF-SD-SNF-SAD-002). This document combines the hazard analyses generated from the fuel retrieval sub-project, the KW integrated water treatment sub-project, and the cask loadout system with the one previously generated for K Basins to form one integrated hazard analysis. This hazard analysis reflects design changes and current analysis. This hazard analysis also identifies the preliminary set of design features and controls that the facility could rely on to prevent or reduce the frequency or mitigate consequences of identified accident conditions based on their importance and significance to safety. The operational controls and institutional programs relied on for prevention or mitigation of an uncontrolled release are identified as potential technical safety requirements.

All operational activities and energy sources at the K Basins are evaluated in this hazard analysis. Using a systematic approach, this document identifies hazards created by abnormal operating conditions and external events (e.g., earthquakes) that have the potential for causing undesirable consequences to the facility worker, the onsite individual, or the public.

2.0 SCOPE

The systems and operational activities associated with the KE and KW Basins and support buildings were evaluated for potential hazards that could endanger facility workers or result in unacceptable releases of radioactive or hazardous chemical materials, which could affect the environment or the public. The scope of operations includes continued storage, retrieval, repackaging, and loadout of the SNF.

The related support buildings evaluated include the following:

- 165 KE – Power Control Building
- 1717 K Building – Maintenance Shop
- 183.1 KW Chlorine Vault (Spent Ion-Exchange Column [IXC] Storage)
- Spent Ion-Exchange Module (IXM) Storage Pads
- 1706 KE and KEL – Water Studies Semiworks Facility, Development Laboratory

- 190 KE – Main Pump House
- 183 KE – Clearwells, Filters, Sedimentation Basins, Headhouse, Chlorine Vault
- 165 KW – Switchgear
- 1724 K – Maintenance Shop Addition
- 185 K – Package Water Treatment Plant.

3.0 METHODOLOGY

The hazard identification process systematically and comprehensively identifies hazards that can endanger facility workers or cause unacceptable releases of radioactive or hazardous chemical materials, which can affect the environment or the public. The hazard analysis process (1) identifies hazardous conditions, (2) determines causes, and preventive and mitigative features, and (3) qualitatively estimates the consequences and frequencies of occurrence. Results of the hazard analysis are used to select candidate accidents for quantitative analysis in the K Basin Safety Analysis Report (SAR).

As part of the hazard identification process, a hazardous materials identification table (Attachment A, Table A-1) was developed from the Containment Vessel Collection Forms (HNF-3262). An energy source checklist, adapted from DOE-76-45-19, *Job and Task Analysis*, and HNF-PRO-704, *Hazard and Accident Analysis Process*, was also used to identify energy sources. The completed energy source checklist can be found in Attachment B, Table B-1.

The energy source checklist was evaluated to identify hazards not controlled by standard industrial safety programs or other institutional programs (e.g., Radiation Protection Program). These hazards were then entered into the hazard analysis table for additional analysis. Each hazardous condition was evaluated to identify the following:

- Potential accidents arising from the presence of the hazard
- Potential causes and consequences of the accident
- Design features or administrative controls credited to prevent the condition or mitigate the accident consequences
- Estimates of the likelihood and consequences of the accident.

Additional defense-in-depth features that can prevent or mitigate the accident consequences or frequency, or provide worker protection, are also included. The completed hazard analysis is included as Table C-1 in Attachment C.

The impacts of the potential unmitigated accidents developed in the hazard analysis worksheet were qualitatively ranked with respect to the frequency and severity of the consequences. Consequences were ranked in order of increasing severity, as shown in Table 3-1. Descriptions of the frequency rankings are included in Table 3-2.

Table 3-1. Qualitative Accident Severity Levels.

| Consequence Assessment Code | Description |
|-----------------------------|---|
| S3 | There is sufficient material and energy available to cause a high or moderate impact to the maximum off-site individual. |
| S2 | There is sufficient material and energy available to cause a high or moderate impact to the maximum on-site individual. |
| S1 | There is sufficient material and energy available to cause an industrial injury, radiological dose, or chemical exposure to one or more facility workers. |
| S0 | There is insufficient material and energy to adversely impact facility workers. |

Table 3-2. Frequency Ranges.

| Frequency Assessment | Description | Estimated Frequency |
|----------------------|---|---|
| F3 | Has occurred or is likely to occur during the lifetime of the facility. | Anticipated: $1.0 \text{ E-02/yr} \leq F3 < 1.0 \text{E-01/yr}$ |
| F2 | Is foreseeable, but unlikely to occur during the lifetime of the facility. | Unlikely: $1.0 \text{ E-04/yr} \leq F2 < 1.0 \text{ E-02/yr}$ |
| F1 | Is perhaps possible, but extremely unlikely to occur during the lifetime of the facility. | Extremely Unlikely: $1.0 \text{ E-06/yr} \leq F1 < 1.0 \text{E-04/yr}$ |
| F0 | Is considered too improbable to warrant further consideration. | Beyond extremely unlikely: $F0 < 1.0 \text{ E-06/yr}$ |

4.0 RESULTS SUMMARY

As stated in DOE-STD-3009-94, *Preparation Guide for U.S. Department of Energy Nonreactor Nuclear Facility Safety Analysis Reports*, “the final purpose of the hazard analysis is to identify a limited subset of accidents to be carried forward to accident analysis.” The initial selection of hazard items requiring further quantitative considerations was based on consequence only. Only items ranked as S3 or S2 were considered for evaluation as design basis accidents. Results of this screening are shown in Table 4-1. Events that were categorized as S2/F1 were not further considered, unless they were identified to have fatality impacts to the facility worker. Frequency categories for each event were estimated to assist in subsequent safety analysis.

Table 4-2 identifies hazards associated with the facility workers. These hazards do not necessarily warrant detailed accident analysis in the SAR as they are controlled by worker safety or other institutional control programs.

All four detailed hazards analyses that were precursors to this hazard analysis (WHC-SD-SNF-PHA-001, HNF-2032, HNF-2456, and HNF-SD-SNF-SAD-002) and this hazard analysis were reviewed for hazards that could be initiators for “off-normal or abnormal operations” and warrant brief coverage in the SAR. Abnormal events are defined as operating conditions resulting from situations outside of normal operations, where normal operations are defined by process flow diagrams, system design descriptions, and operation and maintenance procedures. Consequences from abnormal events are typically standard industrial hazards that may include worker exposure to ionizing radiation. Events having radiological consequences greater than allowed by the facility radiological protection and ALARA (as low as reasonably achievable) programs do not fit the abnormal event profile and are required to be analyzed as accidents by the DOE safety analysis process. Abnormal events, their means of detection, consequences, and potential corrective actions are identified in Table 4-3.

Table 4-1. Summary of S2 and S3 Hazard Items (2 Sheets).

| Initial Consequence Estimate | ID | Energy Source | Hazard Condition/Potential Accident |
|-------------------------------------|-----------|-----------------------|--|
| S2/F2 | B.1 | Nuclear Criticality | Load drops, seismic events, misloading, etc. |
| S3/F2 | C.1 | Kinetic/Linear | Truck and trailer movement of the cask-MCO, or moving forklift or highlifter |
| S2/F2 | C.2A | Kinetic/Linear | Transfer bay crane moving cask/IXM; cask/IXM or hook catches gantry structure |
| S2/F2 | C.2B | Kinetic/Linear | Transfer bay crane moving cask/IXM; cask/IXM strikes NLOP/SLOP causing basin damage |
| S3/F1 | E.1 | Pressure/Volume | Mis-installed MCO shield plug (vent port closed); exceeds 24-hour shipping window |
| S2/F2 | E.2 | Pressure/Volume | Pressure in vessel, pumps, or piping; IXMs, Annular Filter Vessel, above-water piping causes spray release |
| S1/F2 | E.3 | Pressure/Volume | Pipe/valve failure of backup service water supply to basin causes overflow of basin, spilling water (although S1, this event included because it is a carry-over event that is included in the K Basins SAR as a DBA). |
| S2/F2 | E.4 | Pressure/Volume | Piping failure or mis-operation results in pumping water out of the basin |
| S2/F2 | F.1 | Mass, Gravity, Height | Heavy load drop damages basin boundary (excluding drain valves) |
| S2/F2 | F.1A | Mass, Gravity, Height | Cask-MCO dropped: into IPSS, onto IPSS, onto IPSS bottom plate, onto SLOP curb, onto operations deck and then tip-and-hit the SLOP curb |
| S2/F2 | F.2 | Mass, Gravity, Height | Load drop/seismic forces damage the basin drain valves resulting in loss of water |
| S3/F2 | F.3 | Mass, Gravity, Height | Fuel containers or rack lifted out of water causing high radiation or fuel fire |
| S3/F1 | F.4 | Mass, Gravity, Height | DBE causes failure of gantry while loading the MCO scrap basket at the highest point; basin drains down causing high radiation and fuel ignition |
| S2/F1 | G.1 | Flammable Materials | Hydrogen buildup results in hydrogen burn or explosion (Included because of potential for worker fatality). |
| S2/F2 | G.2 | Flammable Materials | Liquid fuel (from either forklift, high-lifter, or MCO transport tractor) spills and burns impacting transfer bay critical column. Failure of a critical column could result in the transfer bay bridge crane and supporting structural members dropping onto the annular filter vessel. |

Table 4-1. Summary of S2 and S3 Hazard Items (2 Sheets).

| Initial Consequence Estimate | ID | Energy Source | Hazard Condition/Potential Accident |
|-------------------------------------|-----------|----------------------|---|
| S3/F1 | G.3 | Flammable Materials | Crane hydraulic oil leaks while performing operations above the south loadout pit and oil pools around gantry column and burns. Gantry fails and drops MCO basket, which perforates floor and results in loss of basin water. |
| S3/F2 | K.1 | Thermal | Loss of cooling results in basin water heatup to beyond limit, followed by MCO shipment and release |
| S3/F1 | L.1 | Explosive Pyrophoric | Uranium hydrides accumulated in fuel canister causes rapid burn of the fuel |
| S3/F1 | L.2 | Explosive Pyrophoric | Buildup of metal uranium metal particles causes fuel fire in settler or knockout pot; or air sparge of an annular filter vessel |
| S3/F1 | L.3 | Explosive Pyrophoric | Uranium metal/uranium hydrides burn due to dryout of basin |
| S3/F2 | N.1 | Natural Phenomena | Earthquake (DBE) |
| S3/F1 | P.3 | Loss of Power | General or partial power failure, reduced voltage; surge causes cask-MCO to hang up on crane, exceeding shipping window and causing release |

DBA = design basis accident
 DBE = design basis earthquake
 IPSS = immersion pail support structure
 IXM = ion-exchange module
 MCO = multi-canister overpack
 NLOP = north loadout pit
 SAR = safety analysis report
 SLOP = south loadout pit

Table 4-2. Summary of S1 (Worker Safety) Hazards (2 sheets).

| Initial frequency estimate | ID ¹ | Energy source | Description |
|----------------------------|--------------------|-----------------------|--|
| F2 | W.E.1 | Pressure-Volume | Fuel Retrieval System flow in addition to recirculation pump bypass to IXMs caused by misvalving air monitoring equipment or incorrect cartridge filter start up after replacement, causing a decrease in the basin water quality resulting in increased worker exposure |
| F2 | W.E.2 | Pressure-Volume | Pipe break, clogged filter, or improper valving causes low or no flow resulting in contamination or increased worker exposure |
| F2 | W.E.3 | Pressure-Volume | Misloading of MCO (too many scrap baskets, excess fuel fines) causes cask to be pressurized during loadout, resulting in potential of contamination release through cask seals |
| F2 | W.E.4 | Pressure-Volume | Inadequate helium purge of loaded MCO during preshipping processing causes cask to be pressurized during loadout, resulting in potential of contamination release through cask seals |
| F3 | W.F.1 ² | Mass, gravity, height | Equipment drops in pool creating a splash resulting in an aerosol release and ALARA problems during recovery |
| F2 | W.F.2 | Mass, gravity, height | Knockout pot too heavy when lifted resulting in equipment damage, potential worker injury, and possible contamination of the basin work area from splash |
| F3 | W.F.3 ² | Mass, gravity, height | Process dip tube not seated correctly prevents shield plug from seating and results in a high radiation stream |
| F3 | W.G.1 | Flammable material | Combustible material (e.g., shipping crates, pallets, windbreak material, impact-limiting foam, plastic containment tents, anticontamination clothing) ignites and impacts critical structural columns by direct flame impingement and hot gas layer |
| F1 | W.J.1 | Radiation | Transfer of contaminated water to air lines, receiver, and compressor results in additional exposure to worker |
| F2 | W.J.2 | Radiation | Waste pad and shipping dock store spent IXMs and packaged cartridge filters (awaiting disposal or stored improperly) resulting in increased worker exposure |
| F2 | W.J.3 | Radiation | Cs-137 trapped in piping and valves generates hot spots which results in increased worker exposure |
| F2 | W.J.4 | Radiation | Loss of basin water level decreases shielding over the basin source terms resulting in increased worker exposure |
| F1 | W.M.1 | Hazardous material | Loading wrong resin into IXM results in potential to increase worker exposure |

Table 4-2. Summary of S1 (Worker Safety) Hazards (2 sheets).

| Initial frequency estimate | ID ¹ | Energy source | Description |
|----------------------------|-----------------|---------------|--|
| F1 | W.P.1 | Loss of power | Loss of radiation monitors result in the potential for workers to receive increased exposure |

¹ Event identifier is provided for cross-reference to Table C-2² Hazards that are considered initiators of "abnormal events"

ALARA = as low as reasonably achievable

IXM = ion-exchange module

MCO = multi-canister overpack

NLOP = north loadout pit

Table 4-3. Hazard Initiators for Potential Abnormal Event for K Basins (3 Sheets).

| Event | Means of detection | Consequences | Corrective Actions ¹ |
|---|--|---|---|
| Immersion pail seal fails during cask loadout operations, outside of cask, and the MCO is contaminated | HPT Surveillance | <ul style="list-style-type: none"> Increased occupational radiation exposure Operational delay | <ul style="list-style-type: none"> Evaluate situation (e.g., at what level, amount, location, etc. if contamination found and determine path forward) Decontaminate, as necessary Perform shipping window TSR actions as necessary |
| FRS equipment failure, leakage, or mis-operation causes some sludge and/or canister liquid to be discharged directly to the basin instead of to the IWTS. | <ul style="list-style-type: none"> Operator observation HPT surveillance | <ul style="list-style-type: none"> Increased basin water turbidity and reduced sight capabilities Small increase in occupational radiation exposure to personnel due to increased basin contamination | <ul style="list-style-type: none"> Run IWTS as necessary to clear up turbidity and reduce basin water dose levels |
| FRS manipulator arm drops a fuel element on the floor | Operator observation | Increased occupational radiation exposure | <ul style="list-style-type: none"> Initiate manual retrieval of the element following approved procedures |
| MCO basket loading interrupted | Operator surveillance | Possible increased dose during recovery | <ul style="list-style-type: none"> Place MCO basket in a safe position and suspend MCO loading operations Evaluate the situation for safe recovery (which may include manual operation of the MCO loading system grapple to lower basket) Generate and perform recovery plan, as necessary Evaluate situation to ensure that MCO shipping window will not be exceeded |
| MCO basket gets stuck in go-no-go gauge | Operator observation | Operational delay | <ul style="list-style-type: none"> Try to unstuck MCO basket (if successful, then evaluate the basket for damage and proceed per management direction) If MCO basket cannot be unstuck, or if the MCO basket is unstuck, but visual observation of the MCO basket shows damage, suspend FRS operations Evaluate the situation Generate and perform a recovery plan |

Table 4-3. Hazard Initiators for Potential Abnormal Event for K Basins (3 Sheets).

| Event | Means of detection | Consequences | Corrective Actions ¹ |
|---|---|--|--|
| Small equipment or tools are dropped into the basin | Operator observation | <ul style="list-style-type: none"> • Splash or aerosol release • Increased occupational radiation exposure | <ul style="list-style-type: none"> • Contact health physics if water is splashed outside of the basin or onto personnel • Evaluate the situation • Generate and perform recovery plan, as necessary |
| The stuck fuel equipment cutter encounters a sludge pocket and stirs the sludge, adding contamination to the basin water | <ul style="list-style-type: none"> • Operator observation • HPT surveillance | Increased occupational exposure as a result of increased basin dose rate | <ul style="list-style-type: none"> • Suspend stuck fuel equipment operations • HPT surveillance • Run IWTS as necessary to clear turbidity and reduce basin water dose levels |
| Hydraulic leak in FRS manipulator | <ul style="list-style-type: none"> • Operator observation • Operator surveillance • Water conductivity monitored downstream of IXM | <ul style="list-style-type: none"> • Changes the chemistry of the basin water, affecting water treatment and exposing personnel to chemicals, and causes potential injury from pressurized spray • Problems with the IXM – potential reduction in decontamination factor for cesium causing ALARA problems | <ul style="list-style-type: none"> • Suspend manipulator operations by placing equipment in a safe position • Notify management and contact first aid as required • Perform maintenance to get manipulator back in service • Evaluate the IXMs for potential problems and change out IXMs as necessary |
| Loss of flow through IWTS recirculation loop because of recirculation pump failure, clogged line, or instrument malfunction | <ul style="list-style-type: none"> • Operator observation • Operator surveillance • Control terminal instrumentation • HPT surveillance | <ul style="list-style-type: none"> • Higher dose rate and higher resuspension rate from the basin water • Equipment repair will increase occupational radiation exposure to personnel • Operational delay | <ul style="list-style-type: none"> • Suspend FRS and sludge/debris removal operations • HPT surveillance • Evaluate situation • Generate and perform a recovery plan to restart operation of the IWTS (e.g., unclog line, perform maintenance on the recirculation pump or instrument, replace the recirculation pump) |

Table 4-3. Hazard Initiators for Potential Abnormal Event for K Basins (3 Sheets).

| Event | Means of detection | Consequences | Corrective Actions ¹ |
|--|--|--|---|
| Small leak in above-water piping | <ul style="list-style-type: none"> Continuous air monitor Area radiation monitors HPT observation Operator observation | <ul style="list-style-type: none"> Higher dose rate from loss of water shielding Aerosol release | <ul style="list-style-type: none"> Suspend FRS and sludge/debris removal operations HPT surveillance Evaluate situation Generate and perform a recovery plan that stops the leak |
| Process dip tube inadvertently contacts top MCO basket during MCO shield plug installation | Operator surveillance | <ul style="list-style-type: none"> Potential equipment damage Unloading damaged baskets (may not have room to replace them in the queue) Operational delay Increased occupational radiation exposure | <ul style="list-style-type: none"> Remove shield plug and place in a safe condition Evaluate the situation (including visual verification that the basket was not damaged) Generate and perform recovery plan, as necessary |
| FRS manipulator collides with other equipment or manual tools | Operator observation | <ul style="list-style-type: none"> Force of impact injures operator and equipment Equipment repair may increase occupational radiation exposure to personnel Operational delay | <ul style="list-style-type: none"> Suspend manipulator operations by placing equipment in a safe position Notify management and contact first aid as required Evaluate situation Generate and perform recovery plan |

¹ Actions to be evaluated during recovery.

ALARA = as low as reasonably achievable
 FRS = Fuel Retrieval System
 HPT = health physics technician
 IXM = ion-exchange module
 IWTS = Integrated Water Treatment System
 MCO = multi-canister overpack
 TSR = technical safety requirement

5.0 REFERENCES

DOE-76-45-19, 1979, *Job and Task Analysis*, U.S. Department of Energy, Washington, D.C.

DOE-STD-3009-94, 1994, *Preparation Guide for U.S. Department of Energy Nonreactor Nuclear Facility Safety Analysis Reports*, U.S. Department of Energy, Richland Operations Office, Richland, Washington.

HNF-2032, 1998, *SNF Fuel Retrieval Sub-Project Safety Analysis Document*, Rev. 0, DE&S Hanford, Richland, Washington. (Peck, S. H., 1998)

HNF-2456, 1998, *SNF Cask Loadout System Sub-Project Safety Analysis Document*, DE&S Hanford, Richland, Washington.

HNF-3262, 1998, *Facility Vulnerability Assessment Phase 3 Final Report*, Rev. 0, January 20, DE&S Hanford, Inc., Richland, Washington.

HNF-PRO-455, *Solid Waste Management*, Fluor Daniel Hanford, Incorporated, Richland, Washington.

HNF-PRO-704, *Hazard and Accident Analysis Process*, Project Hanford Policy and Procedure System, Fluor Daniel Hanford, Incorporated, Richland, Washington.

HNF-SD-SNF-RD-001, 1999, *Spent Nuclear Fuel Project Standards/Requirements Identification Document*, Rev. 2, DE&S Hanford, Inc., Richland, Washington.

HNF-SD-SNF-FHA-001, 1999, *Fire Hazards Analysis for the K Basins Facilities at 100 K Area*, Rev. 1, Fluor Daniel Hanford, Inc., Richland, Washington.

HNF-SD-SNF-SAD-002, 1998, *Integrated Water Treatment System Subproject Safety Assessment Document*, Rev. 2, DE&S Hanford, Richland, Washington.

HNF-SD-SNF-SEL-001, *Safety Equipment List for K Basins*, Rev. 2, DE&S Hanford, Richland, Washington.

HNF-SD-SNF-TI-015, 1998, *Spent Nuclear Fuel Project Technical Databook*, Rev. 6, DE&S Hanford, Richland, Washington.

HNF-SD-TP-SARP-017, 1998, *Safety Analysis Report for Packaging (Onsite) Multicanister Overpack Cask*, Rev. 1, Waste Management Federal Services, Inc., Richland, Washington.

WAC 173-303, "Dangerous Waste Regulations," *Washington Administrative Code*, as amended.

WHC-SD-SNF-PHA-001, 1994, *Preliminary Hazards Analysis of K-Basin Fuel Encapsulation and Storage*, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
(Strickland, G. C., 1994)

Williams, N. H., 1998, *Closure of Special Condition of Approval from the Fuel Retrieval Subproject Safety Evaluation Report*, (Letter FDH 9858841 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office), October 19, Fluor Daniel Hanford, Inc., Richland, Washington.

Attachment A

HAZARDOUS MATERIAL LIST

This page intentionally left blank

Table A-1. Hazardous Material List (2 Sheets).

| | Hazardous Material | Location | Quantity |
|--|--|--|---|
| 105 KE/KW Basin systems | Radiologically contaminated water Radionuclides: ¹ Pu-236 Pu-238 Pu-239 Pu-240 Pu-241 Pu-242 Am-241 Cm-244 Eu-154 Cs-134 Cs-137 Ce-144 Pr-144 Pr-144 Pm-147 Sb-125 Te-125 Ru-106 Sr-90 Y-90 Chemicals: Purolite NRW-37 Ion Exchange Resin Isopropyl Alcohol Plasti Dip Heavy Duty Flexible Rubber Coating | 105 KE 105 KW | ~1.2 E+06 gal ~1.2 E+06 gal |
| Other supporting structures, systems, and components | Radionuclides: 39 Spent IXCs Chemicals: Hydraulic Fluid (for FRS) Liquid Propane Dow Frost Heat Transfer Fluid Sodium Bicarbonate Liquid Alum (aluminum sulfate) Lubricating Oil Turbine Oil Buffer Reagent for PC Hardness Analyzer Purolite NRW-37 Ion Exchange Resin Magnafloc 990-N Sulfuric Acid Valvoline Oil SAE30 Amercoat 90 HS Resin Delo 400 SAE 40 HD Motor Oil Sodium Hydroxide Turbine Oil Indicator Solution for Pump Calorimeter Total Alka Turbine Oil Ethyl Alcohol, 200 proof Coffing Transmission Oil Dectol R&O Oil 68, Conoco Regal Oil R&O 220 Sili Kroil Jet-Lube TFW | 183.1 KW 190 KE 183 KE 183 KE 183 KE 190 KE 190 KE 183 KE 183.1 KW 183 KE 190 KE 190 KE 190 KE 183 KE 183 KE 183 KE 1717 K 1717 K 1717 K 1717 K 1717 K 1717 K | (2) 55 gal/drums 500 gal 807 gal 90 gal empty 12 gal 25 gal 3.5 gal 39 IXCs 1205 gal 5 gal 26 gal 30 gal 40 gal 4 gal 33 gal 14 gal 23 gal 1 gal 20 gal 22 gal 199 gal 3 gal 1 gal |

Table A-1. Hazardous Material List (2 Sheets).

| | Hazardous Material | Location | Quantity |
|--|--|----------------------|------------------------------|
| Other supporting structures, systems, and components cont. | Chemicals cont.: | | |
| | WD-40 | 1717 K | 1 gal |
| | PPG Interior Enamel Semi-Gloss Acrylic Latex | 1717 K | 620 gal |
| | Amberlite IR-120 Cation Exchange Resin | 1706 KE | 748 gal |
| | Krylon Spray Paint | 165 KE | 10 gal |
| | Lectra Clean II | 165 KE | 1.4 gal |
| | Sodium Sulfite | 1706 KEL | less than 1 gal ⁵ |
| | Lead | Recycle ⁴ | 20 ft ³ maximum |
| | P-Bis (O-Methylstyryl)Benzene | SAA ² | 1.5 gal |
| | Toluene | SAA ² | 20 gal |
| | Toluene | 90d SP ³ | 55 gal |
| | Sulfuric Acid | Recycle ⁴ | 20 ft ³ maximum |
| | Nitric Acid | 1706 KE | 17 gal |
| | Liquid Nitrogen | Lab | 80 gal |
| | Isopropyl Alcohol | 1705 KE | 23 gal |
| | Sodium Hydroxide | 1706 KE | 2 gal |
| | Unleaded fuel, Conoco (in carbon steel tank) | 1717 KE | 154 gal |

¹ HNF-SD-SNF-TI-015, *Spent Nuclear Fuel Project Technical Databook*, Rev. 6, DE&S Hanford, Richland, Washington.

² This is an established satellite accumulation area (SAA) and is under the control of the operator. The requirements for establishing this SAA are based on WAC-173-303, "Dangerous Waste Regulations," and PHMC procedure HNF-PRO-455, *Solid Waste Management*. Weekly inspections are performed and documented per HNF-PRO-455.

³ This is an established <90-day storage area and is under the control of the operator. The requirements for establishing, maintaining, and inspecting this <90-day storage area are based on WAC-173-303 and HNF-PRO-455. The volume and percentage of primary chemicals fluctuate based on plant operations and quantities shipped to a TSD.

⁴ This recycle staging area is for staging of lead acid batteries, non-PCB ballasts, aerosol cans, non-regulated oil, and fluorescent light bulbs. These materials are considered recycled and are shipped to the recycle consolidation center.

⁵ Quantity represents heel left in the bottom of a 50-gal tank.

| | | |
|------|---|---|
| FRS | = | Fuel Retrieval System |
| KE | = | K East |
| KW | = | K West |
| IXC | = | ion-exchange column |
| PCB | = | polychlorinated biphenyl |
| PHMC | = | Project Hanford Management Contract |
| SAA | = | satellite accumulation area |
| TSD | = | treatment, storage, and disposal facility |

Attachment B

HAZARD BASELINE - ENERGY CHECKLIST

This page intentionally left blank.

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|---|---------------------------------|---|---|---------------------------------------|
| A. Electrical Note: All electrical hazards are standard industrial hazards with the exception of loss of power, which is covered by external events (see hazard P.4) | 1. Battery banks | N/A | Two battery rooms in basement of 165 KE (used for switchgear, rectifiers and distribution panels - part of the DC system) | None ¹ |
| | 2. Diesel units | N/A | N/A | N/A |
| | 3. High voltage lines | N/A | 230kV power poles | None ¹ |
| | 4. Transformers | Power transformers | Power transformers | None ¹ |
| | 5. Wiring | AC/DC system | AC/DC system | None ¹ |
| | 6. Switchgear | 480V switchgear at 105 KE/KW | <ul style="list-style-type: none"> • 230 kV switchgear at the 151 K substation • 13.8 kV switchgear in the 165 K Building • 480V switchgear <p>The system ends at the load side of the motor control center or at the secondary side of the transformers for voltages below 480V</p> | None ¹ |
| | 7. Underground wiring | N/A | Underground tunnel | None ¹ |
| | 8. Cable runs | Various cable raceways | Various cable raceways | None ¹ |
| | 9. Service outlets and fittings | 110/120V outlets are located throughout the 105 KE/KW Basin temporary welding receptacle GFI's are located throughout the basin | 110/120V outlets Temp welding receptacle | None ¹ |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis | |
|---------------------|---------------------------------|--|---|---------------------------------------|--|
| A. Electrical cont. | 10. Electric motor driven pumps | Recirculation pump (3) | River pumps: raw water pumps (1500 HP motor) | None ¹ | |
| | | Booster pump (part of the IWTS system) (KW only) | Potable water pumps (3) (300 HP motor) | | |
| | | Skimmer pump | Service water pumps (300 HP) | | |
| | | B-Sump pumps | Backwash pumps (300 HP motor) | | |
| | | C-Sump pumps | Water treatment facility pumps | | |
| | | D-Sump pumps | Sample pumps | | |
| | | Submersed pumps for the PCM, decapper, and process table | Outfall samplers | | |
| | | High-pressure pump for the PCM | Outfall sample pumps/piping | | |
| | | Hydraulic pump for the manipulator | Outfall temperature and flow monitoring | | |
| | | Pump for the chiller | Low lift pumps | | |
| | | Sludge pumping equipment (electrical submersible pump) | Septic system pumps | | |
| | | Boiler circulation pumps | Air compressor | | |
| | | Air conditioning pumps | | | |
| | | Air compressor | | | |
| | | | | | |
| | 11. Other motors | PCM lid motor | Control/valve room (165E) contains most motor-operated valves for raw/service water systems | None ¹ | |
| | | Building exhaust fans | | | |
| | | Decapper exhaust | | | |
| | | Air exhauster/sampler motors | | | |
| | | Motor 3-way valves | | | |
| | | MLS gantry drive | | | |
| | | Exhaust blowers (each basin has four roof mounted) | | | |
| | | Each basin has two evaporative coolers used for summer conditions | | | |
| 12. Heaters | Hot water boilers | Unit heaters | None ¹ | | |
| | (8) Unit heaters | Heat pumps | | | |
| | Heat pumps | Water treatment structure unit heaters | | | |
| | 13. Power tools | Used during construction, maintenance, and operations | Used during construction, maintenance, and operations | None ¹ | |
| | 14. Hoists | Various electric hoists are mounted on manually and motor-operated trolleys rated up to 32 ton | 15-ton bridge crane | None ¹ | |
| | | Tractor motors for hoist and flexible transfer crane | 25-ton bridge crane | | |
| | | | | | |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|------------------------|--------------------------------|---|---|---------------------------------------|
| A. Electrical cont. | 16. Other | Electrical roll-up doors Instrumentation and cameras | Traveling water intake screen (motorized) Raw water, bypass valve cross tie (electric motorized) Electrical roll-up doors | None ¹ |
| B. Nuclear Criticality | 1. Vaults | N/A | N/A | N/A |
| | 2. Temporary storage areas | Accumulated sludge storage: KE weasel pit KW dummy elevator pit KE/KW sand filter backwash pit (NLOP) KE/KW floor sludge KW technical view pit Water treatment: Knockout pots (KW) Particulate settler tanks (KW weasel pit) Annular filter vessel IXMs, sand filters Fuel storage: Main basins MCO basket queue | 39 spent IXC (183.1 KW) | Yes |
| | 3. Receiving areas | N/A | N/A | N/A |
| | 4. Casks | MCO, Chem-Nuclear Cask, PAS-1 sampling cask | | Yes |
| | 5. Burial grounds | N/A | N/A | N/A |
| | 6. Storage tanks | N/A | N/A | N/A |
| | 7. Storage racks | Fuel storage racks on floor of each basin (KE/KW)/MCO basket queue | N/A | Yes |
| | 8. Canals and basins | N/A | N/A | N/A |
| | 9. Decon solution | N/A | N/A | N/A |
| | 10. Trucks, forklifts, dollies | IXM, IXC transport, cask transporters | IXM, IXC transport, cask transporters | Yes |
| | 11. Hand carry | N/A | N/A | N/A |
| | 12. Cranes/lifts | Monorail and chain hoists; transfer bay crane; gantry | N/A | Yes |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|------------------------------|----------------------------------|---|--|---------------------------------------|
| B. Nuclear Criticality cont. | 13. Hot cells, assembly | N/A | N/A | N/A |
| | 14. Inspection areas | Process table | N/A | Yes |
| | 15. Other | N/A | N/A | N/A |
| C. Kinetic/Linear | 1. Cars/trucks/buses | Trailer and truck | Trailer and truck | Yes |
| | 2. Forklifts/dollies/carts | Forklift/dollies/carts/highlifters | Forklift/dollies/carts used to move storage containers in holding area (low level waste) | Yes |
| | 3. Railroad | Rail system deactivated | Rail system deactivated | None |
| | 4. Obstructions (collision with) | Building structures, basin structures, and process equipment | Building structures and process equipment | Yes |
| | 5. Crane loads in motion | Canisters, IXMs, casks, cask-MCO and related equipment, MCO baskets, debris Maintenance and construction loads | Maintenance, construction and warehousing loads; IXMs, IXCs | Yes |
| | 6. PV blowdown | Compressed gas cylinders | Compressed gas cylinders | None ¹ |
| | 7. Other | N/A | N/A | N/A |
| D. Kinetic/Rotational | 1. Centrifuges | N/A | N/A | N/A |
| | 2. Motors | Tipper station; PCM drive | N/A | None ¹ |
| | 3. Pumps | All pumps with exposed shafts | All pumps with exposed shafts | None ¹ |
| | 4. Cooling tower fans | N/A | N/A | N/A |
| | 5. Shop equipment | Power tools | Machine tools and power tools | None ¹ |
| | 6. Other | Air operated trailer landing gear Gantry shaft | N/A | None ¹ |
| E. Pressure - Volume | 1. Boilers | Package boilers - KE/KW | N/A | None ¹ |
| | 2. Heated surge tanks | Boiler expansion tank/air separator | N/A | None ¹ |
| | 3. Autoclaves | N/A | N/A | N/A |
| | 4. Test loops and facilities | N/A | N/A | N/A |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|----------------------------|-------------------------------|--|---|---------------------------------------|
| 7. Pressure - Volume cont. | 5. Gas bottles | Inert gas system Compressed gas cylinders SCBA Various gas cylinders | Bottle gas system | None ¹ |
| | 6. Pressure vessels | Housing of cartridge filters vessel Sand filter IXMs Air chilled evaporator Knockout pots Particulate settler vessel Annular filter vessels Compressed air vessel MCO (once shield plug is installed) Cask-MCO Chem-Nuclear casks PAS-1 casks Piping | N/A | Yes |
| | 7. Stressed members | N/A | N/A | N/A |
| | 8. Gas receivers | Shop air receiver | Shop air receivers | None ¹ |
| | 9. Negative pressure collapse | N/A | N/A | N/A |
| | 10. Other | Pressurized water wands; Immersion pail lid seal Trailer brakes | N/A | None ¹ |
| | 1. Human effort | Long-handled manual tools: Manual tongs/air-operated tong Hand-operated trolley system Moving carts Manually operated locking pin on top of the IPSS Maintenance, construction, and operations | Maintenance, construction and operations Moving carts Manual hoists | None ¹ |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|--------------------------------|---------------------------|--|---|---------------------------------------|
| F. Mass, Gravity, Height cont. | 2. Stairs | Various building stairs Operations platform Cask loadout trailer stairs | Various stairs Water Treatment Facility | None ¹ |
| | 3. Lifts and cranes | Canisters, knockout pots IXMs, casks Cask-MCO and related equipment MCO baskets, debris Maintenance and construction loads | Maintenance, construction and warehousing loads IXMs, IXC _s Low level waste containers | Yes |
| | 4. Bucket and ladder | Maintenance activities | Maintenance activities | None ¹ |
| | 5. Trucks | Truck deliveries in and out of the transfer area | Truck deliveries in other areas | Yes |
| | 6. Slings | Construction, maintenance, and operations | Construction, maintenance, and operations | None ¹ |
| | 7. Hoists | Construction, maintenance, and operations | Construction, maintenance, and operations | Yes |
| | 8. Elevators | N/A | N/A | N/A |
| | 9. Jacks | Truck jacks, pallet jacks | Truck jacks, pallet jacks | None ¹ |
| | 10. Scaffolds and ladders | Construction, maintenance, and operations | Construction, maintenance, and operations | None ¹ |
| | 11. Pits and excavations | Basin and pits | Construction activities | None ¹ |
| | 12. Elevated doors | N/A | N/A | N/A |
| | 13. Vessels | N/A | N/A | N/A |
| | 14. Other | Building structure and grating Roll-up door Deteriorating roof FRS Manipulator drops | Roll-up door Deteriorating roof | Yes |
| G. Flammable Materials | 1. Packing materials | 4 x 4 x 8 shipping crates, pallets | 4 x 4 x 8 shipping crates, pallets | Yes |
| | 2. Rags | Cleaning rags and anti-c | Cleaning rags | Yes |
| | 3. Gasoline | Forklift, truck, and cranes | Gasoline fuel storage: Vehicles in parking lot | Yes |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|------------------------------|--|---|---|---------------------------------------|
| G. Flammable Materials cont. | 4. Oil | Chiller, crane, hoist Manipulator hydraulic fluid | Motor oil Bearing lubrication Oil storage | Yes |
| | 5. Coolant oil | N/A | N/A | N/A |
| | 6. Paint solvent | Solvents and cleaners | Paints | None ² |
| | 7. Diesel fuel | Forklift used in waste accumulation area - 30 gal diesel fuel tank Trucks in transfer area (100 gal) Mobile crane for construction purposes | Truck, forklift, mobile cranes | Yes |
| | 8. Buildings and contents | Building roofs, windbreak, electrical installation material | Building roofs, wood structures, electrical installation material | Yes |
| | 9. Trailers and contents | Personnel trailers (mobile offices), vehicle tires | Personnel trailers (mobile office), vehicle tires | None ² |
| | 10. Grease | Small amount in bearings/gearboxes | Small amount in bearings/gearboxes | None ² |
| | 11. Hydrogen (including battery banks) | Knockout pots Canisters, basin sludge Particulate settler IXMs/IXCs; cask-MCO Annular filter vessels | IXCs (183 KW)/battery rooms each provided with dedicated fans to ensure H ₂ gas is released. | Yes |
| | 12. Nitric acid | N/A | N/A | None ¹ |
| | 13. Organics | Decon solution | Decon solution | None ² |
| | 14. Gases - other | Freon/chiller Glycol/failure of basin heaters or piping P-10 gas used for portal monitors Oxygen/acetylene | Oxygen/acetylene | None |
| | 15. Spray paint | Maintenance use | Maintenance use and storage | None ² |
| | 16. Other | Adjoining facility material storage | N/A | None ² |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|----------------|---|---|--|---------------------------------------|
| H. Corrosive | 1. Acids | Vehicle batteries | Vehicle batteries DC battery system | None ¹ |
| | 2. Caustics | N/A | Caustic cleaners | None ¹ |
| | 3. "Natural" chemicals (soil, air, water) | N/A | N/A | N/A |
| | 4. Decon solutions | Maintenance use | N/A | None ¹ |
| | 5. High temperature waste | N/A | N/A | N/A |
| | 6. Other | Nitric acid | N/A | None ¹ |
| J. Radiation | 1. Canals | N/A | N/A | N/A |
| | 2. Plug storage | N/A | N/A | N/A |
| | 3. Storage areas | Accumulated sludge storage: KE weasel pit KW dummy elevator pit KE/KW sand filter backwash pit (NLOP) KE/KW floor sludge KW technical view pit IXCs Water treatment: Knockout pots (KW) Particulate settler tanks (KW weasel pit) Annular filter vessel IXMs, sand filters, pumps and piping Fuel storage: Canisters; MCO basket queue; cask-MCO | Storage pad (IXMs) | Yes |
| | 4. Storage buildings | N/A | 183.1 KW (IXC storage) | Yes |
| | 5. Radioactive sources | Check sources | N/A | None ¹ |
| | 6. Waste and scrap | Waste accumulation areas in transfer bay of each basin | Waste pad shipping dock | None |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|--------------------|--|--|--|---------------------------------------|
| J. Radiation cont. | 7. Contamination | Contaminated water and contaminated areas in both K Basins | N/A | None ¹ |
| | 8. Irradiated experimental and reactor equipment | N/A | N/A | N/A |
| | 9. Electric furnace | N/A | N/A | N/A |
| | 10. Blacklight (e.g., magniflux) | N/A | N/A | N/A |
| | 11. Laser | N/A | N/A | N/A |
| | 12. Medical x-ray | N/A | N/A | N/A |
| | 13. Radiography equipment and sources | N/A | N/A | N/A |
| | 14. Welding | Construction and maintenance | Construction and maintenance | None ¹ |
| | 15. Electric arc, other (high current circuits) | N/A | N/A | N/A |
| | 16. Electron beam | N/A | N/A | N/A |
| K. Thermal | 17. Equipment noise | Pumps, motors, power tools, etc. Noise from venting of raw water pumps (tunnel) | Pumps, motors, power tools, etc. Noise from venting of raw water pumps (tunnel) | None ¹ |
| | 18. Ultrasonic cleaners | N/A | N/A | N/A |
| | 1. Bunsen burner/ hot plates | N/A | N/A | N/A |
| | 2. Electrical equipment | Unit heaters and space heaters Electrical motors and pumps | Space heaters Electrical furnaces heaters Switchgear room Electrical motors and pumps | None ¹ |
| | 3. Furnaces/ boilers/heater | Boiler package in KE/KW | Unit heaters | None ¹ |
| | 4. Steam lines | N/A | N/A | N/A |
| | 5. Welding torch/arc | Construction and maintenance | Construction and maintenance | None ¹ |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|-------------------------|---|---|---|---------------------------------------|
| K. Thermal cont. | 6. Diesel units/fire box/ exhaust line | Truck exhaust | Truck exhaust | None ¹ |
| | 7. Radioactive decay heat | Decay heat from fuel Cask-MCO | N/A | Yes |
| | 8. Exposed components | N/A | N/A | N/A |
| | 9. Power tools | High speed grinders | High speed grinders | None ¹ |
| | 10. Convective | Motors, lighting, instrumentation, control panels | Motors, lighting, instrumentation, control panels | None ¹ |
| | 11. Solar | N/A | N/A | N/A |
| | 12. Cryogenic | N/A | N/A | N/A |
| | 13. Other | N/A | N/A | N/A |
| L. Explosive Pyrophoric | 1. Caps | N/A | N/A | N/A |
| | 2. Primer cord | N/A | N/A | N/A |
| | 3. Dynamite | N/A | N/A | N/A |
| | 4. Scrub chemicals | N/A | N/A | N/A |
| | 5. Dusts | N/A | N/A | N/A |
| | 6. Hydrogen (including battery banks and water decomposition) | Knockout pots Canisters/decapping Basin sludge Particulate settler Cask-MCO Annular filter vessels | Battery rooms each provided with dedicated fans to ensure H gas is released. IXCs (183.1 KW) | Yes |
| | 7. Gases, other | N/A | N/A | N/A |
| | 8. Nitrates | N/A | N/A | N/A |
| | 9. Peroxides | Hydrogen peroxide used to control algae in basins | N/A | None ¹ |
| | 10. Pu and U metals | Fuel assemblies, fuel scrap, uranium hydrides, knockout pots, settlers, annular filter vessel | N/A | Yes |
| | 11. Sodium | N/A | N/A | N/A |
| | 12. Other | N/A | N/A | N/A |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|-----------------------|----------------------------|--|---|---------------------------------------|
| M. Hazardous Material | 1. Alkali metals | N/A | N/A | N/A |
| | 2. Asphyxiants | Basin water (drowning) Vehicle exhaust Inert gases for welding/maintenance | Clearwells (underground water storage reservoirs with depth ~20 ft water) (drowning) | None ¹ |
| | 3. Biologicals | Spiders/insects/snakes/mice | Spiders/insects/snakes/mice | None ¹ |
| | 4. Carcinogens | PCBs (in sludge) | PCBs (possible residual from transformers) | None ³ |
| | 5. Corrosives | Battery acid | Vehicle battery acid Battery room | None ¹ |
| | 6. Asbestos | Building/piping | Building/piping | None |
| | 7. Oxidizers | Decon agents | Decon agents | None ¹ |
| | 8. Dusts and particulates | Sand and dust Volcanic ash Construction and demolition | Sand and dust Volcanic ash Construction and demolition | None ¹ |
| | 9. Beryllium and compounds | In-fuel braze rings (underwater) | Potentially 1706-KE | None ³ |
| | 10. Chlorine and compounds | N/A | N/A | N/A |
| | 11. Heavy metal | Pu, U, lead, lead paint | Lead, lead paint | None |
| | 12. Other | N/A | Sodium hydrochloride, aluminum sulfate | None |
| N. Natural Phenomena | 1. Earthquake | Design basis earthquake | Design basis earthquake | Yes |
| | 2. Flood | N/A | Yes | Yes |
| | 3. Lightning | Yes | Yes | Yes |
| | 4. Rain | Yes | Yes | Yes |
| | 5. Snow, freezing weather | Yes | Yes | Yes |
| | 6. Straight wind | Yes | Yes | Yes |
| | 7. Dust devil | (Covered by straight wind) | (Covered by straight wind) | N/A |
| | 8. Tornado | (Covered by straight wind) | (Covered by straight wind) | N/A |
| | 9. Ashfall | Yes | N/A | Yes |

Table B-1. Hazard Baseline - Energy Checklist (12 Sheets).

| Type of Hazard | Form of Hazard | 105 KE/KW Basin | Other Supporting Structures, Systems, and Components | Hazards Requiring Additional Analysis |
|--|--------------------------|--|--|---------------------------------------|
| P. External Events | 1. Explosion | N/A | N/A | N/A |
| | 2. Fire | Yes | Yes | Yes |
| | 3. Events at other sites | Yes | Yes | Yes |
| | 4. Loss of power | Yes | Yes | Yes |
| R. Vehicles in Motion (external to facility) | 1. Airplane | Commercial, general, and military | N/A | Yes |
| | 2. Helicopter | Commercial, general, and military | N/A | Yes |
| | 3. Train | N/A | N/A | N/A |
| | 4. Truck/bus/car | Only authorized vehicle travel permitted within K Basin. Only two public roads that cross the Hanford Site. Remaining roads are restricted access roads. | N/A | None ¹ |
| | 5. Other | River barge and boat traffic | N/A | None ¹ |

¹ Considered to be a standard industrial hazard.

² Considered to be a standard fire hazard covered by the K Basins Fire Hazards Analysis (HNF-SD-SNF-FHA-001) and not considered for further evaluation.

³ Considered to be a toxicological hazard, but when radiological consequences are controlled to meet radiological limits and guidelines, toxicological consequences will also be below toxicological guidelines.

| | | |
|------|---|------------------------------------|
| AC | = | alternating current |
| DC | = | direct current |
| GFI | = | ground fault interruptor |
| IPSS | = | immersion pail support structure |
| IWTS | = | Integrated Water Treatment System |
| IXC | = | ion-exchange column |
| IXM | = | ion-exchange module |
| KE | = | K East |
| KW | = | K West |
| MCO | = | multi-canister overpack |
| MLS | = | MCO loading system |
| N/A | = | not applicable |
| NLOP | = | north loadout pit |
| PCB | = | polychlorinated biphenyl |
| PCM | = | primary clean machine |
| PV | = | pressure--volume |
| SCBA | = | self-contained breathing apparatus |

Attachment C

HAZARD ANALYSIS WORKSHEET

This page intentionally left blank

HAZARD ANALYSIS WORKSHEET

The following is a description of the Hazard Analysis Worksheet columns:

| Column Number | Description of Content |
|----------------------|---|
| 1 | Assigns a numeric identifier to a specific accident. |
| 2 | Identifies the energy source "hazard" from the energy source checklist in Appendix B. |
| 3 | Briefly describes the hazardous condition. |
| 4 | Identifies the cause of the hazardous condition (typically Human Error, Equipment Failure, or Natural Phenomena, or all three). |
| 5 | Describes the potential accident associated with the hazard energy and hazardous condition. |
| 6 | Contains a qualitative assessment of the result of the potential accident. |
| 7 | Identifies equipment or administrative controls credited to prevent consequences of the accident. |
| 8 | Contains a qualitative estimate of the frequency of the event, divided into two sections, without and with credited prevention measures. |
| 9 | Identifies equipment or administrative controls credited to mitigate consequences of the accident. |
| 10 | Contains a qualitative estimate of the consequence of the event divided into two sections, without and with credited mitigation measures. |
| 11 | Identifies other equipment or controls that provide additional measures for prevention or mitigation of the accident, which are not credited in the accident analysis but do provide defense-in-depth protection. |
| 12 | Provides risk ranking (from Figure 3-3 in DOE-STD-3009-94) and accident identification for cross-reference. |

This page intentionally left blank

Table C-1. Hazard Analysis Worksheet (7 Sheets).

| ID | Hazardous Condition | Cause | Potential Accident | Available Credited Protection and Defense-in-Depth Features | Quantitative Frequency | Available Credited Mitigation and Defense-in-Depth Mitigation | | Qualitative Consequences | Defense-in-Depth W/O With | Defense-in-Depth W/O With | Risk Ranking (Accident ID) | |
|------|--|---|--|--|-------------------------------------|---|---|--|---------------------------|---|--|--|
| | | | | | | W/O | With | | | | | |
| B.1 | Nuclear Criticality ¹ (B2, B4, B7, B10, B12, B14, B3) | Human error Equipment failure Seismic event | Failure to control fuel arrangement (mass, enrichment, geometry, form) (Specific accident conditions covered in detail in the related CSERs) (See K Basin CSER for extensive analysis of criticality hazards.) | Administrative Controls: Nuclear Criticality Safety Program Controls on fuel arrangement Design Features: Knockout pot; knockout pot screen; particulate filter tubes; similar filter vessel; knockout pot lifting tool; monostatic stops (IWTS only); PCMV support structure; process table support structure; MCO basket; queue; MCO; MCO basket; basket; curtains; racks; beams | F2 | F0 | Administrative Controls: Basin water level controls Controls for water addition and leak mitigation | S2 | S1 | Administrative Controls: Personnel qualification Operational surveillance Mass controls Fuel form and enrichment controls Dimensional quality control verifications Accountability/campaign letters Design Features: Geometric design of components; spacing controls; basin water cover; inspection methods (OCTV) | NA (see Chapter 6 and CSERs) | |
| C.1 | Kinetic Liner ¹ (C1, C2, C4, F5, F3) | Human error Equipment failure | Transport truck or forklift/highlifter exceeds speed limit, strikes building structure or gantry structure causing damage, potentially falling into basin, damaging basin or rearranging fuel | Administrative Controls: Vehicle movements Nuclear Criticality Safety Program Design Features: Bumpers; sand filter; iron; building columns; loadout pit curbs | Release Criticality ¹ | F2 | F0 | Administrative Controls: Basin water level controls Controls for water addition and leak mitigation | S3 | S0 | Administrative Controls: Load limitations/engineering calculations Personnel qualification Vehicle configuration Operational surveillance Annual maintenance Weight verifications | § (3.4.2.1 Uncontrolled Vehicle) |
| C.2A | Kinetic Liner ¹ (C4, C5, F3) | Transfer bay bridge crane moving caulk/TKM | Human error Equipment failure | Crash or hook strikes gantry, knocks gantry into pool causing leak; spills an MCO basket on floor | Release Criticality ¹ | F2 | F1 | Administrative Controls: Heavy load controls Nuclear Criticality Safety Program Engineering Evaluations: Drop calculations | S2 | S0 | Administrative Controls: Hauling and rigging controls Load limitations/engineering calculations Personnel qualification Accident response (leak mitigation) Operational surveillance Annual maintenance Weight verifications Design Features: Impact limiting structures (drain valve covers); reinforced concrete beam structure | 5 (3.4.2.1 Heavy Load Drop) |

Table C-1. Hazard Analysis Worksheet (7 Sheets).

| ID | Energy Source | Hazardous Condition | Cause | Potential Accident | Potential Consequence | Available Credited Prevention and Defense-in-Depth Features | Qualitative Consequence | Defense-in-Depth | Risk Rating (Accident ID) |
|------|------------------------------|---|---|---|---|--|-------------------------|---|--|
| | | | | | | | | | |
| C.2B | Kinetic/ Linear (C4, C5, B3) | Transfer bay bridge crane moving cask/DXM | Human error Equipment failure | Cask or DXM impacts NLOPSLOP curb, damages NLOPSLOP causing basin leak, [bounded by tip-and-hit curb accident (drain down to -6'-6" level)] | Release Worker Does | Administrative Control Heavy load controls | F2 F1 | Administrative Controls: Basin water level controls Controls for water addition and leak mitigation | 5 (3.4.2.2 Cask-MCO Drops) |
| E.1 | Pressure-Volume (E6, P4) | | Human error | Pressurize cask causing cask failure; cask leak | Release Worker fatality | Administrative Controls: MCO assembly controls Shipping window control Basin water temperature controls | F1 F0 | Administrative Control: Cooling and depressurization of MCO | 3 (3.4.2.5 MCO Shipping) |
| E.2 | Pressure-Volume (E6, B3, M4) | | Human error | Component failure/leak causes spray release | Release High radiation | Administrative Controls: Disk closed; exceeds 24-hour shipping window; overpressure during inert gas purge | F2 F2 | Administrative Control: Operator response Design Features: Continuous air monitoring and radiation monitoring IWTs radiation monitoring | 5 (3.4.2.7 Spray Release) |
| E.3 | Pressure-Volume (E6) | | Human error Equipment failure Seismic event | Pipe/valve failure of backup service water supply to basin | Release (environmental) Overflow basin, spill water | Administrative Control: Basin water level controls | F1 F1 | Administrative Control: Basin water level controls | 1 (3.4.2.8 Overflow of Radioactive Water from Basin) |

Table C-1. Hazard Analysis Worksheet (7 Sheets).

| ID | Energy Source | Hazardous Condition | Cause | Potential Accident | Potential Consequence | Qualitative Frequency | | Available Credited Protection and Defense-in-Depth Mitigation | | Qualitative Consequences | | Risk Rating (Accident ID) |
|------|------------------------------------|---|---|--|-------------------------------------|---|---|---|----|--|-------------|--|
| | | | | | | W/O | With | F2 | F1 | S2 | S1 | |
| E.4 | Pressure-Volume (E6) | Piping failure or mis-operation | Human error Equipment failure Seismic event | Failure of piping or component or equipment mis-operation results in pumping water out of basin | Release Criticality ¹ | Administrative Control Basin water level controls | Administrative Controls: Water addition and leak mitigation Facility manning requirements Design Feature: Piping and suction control | S2 | S1 | Administrative Controls: Operational surveillances Authorized inspections Radiation Protection Program Design Features: IWTS equipment enclosures (vessels, booster pump, etc.); guard pipe; IWTS radiation monitor; Continuous air monitors; area radiation monitors | W/O With | 6 (3.4.2.9 Pump-out/Siphoning of Radioactive Water from Basin) |
| F.1 | Mass, Gravity, Height (F3, F7, F3) | Heavy load drop (e.g., canisters, knockout pots, DMAX, MCO baskets, debris, maintenance and construction loads) | Human error Equipment failure Seismic event | Dropped load damages basin boundary (excluding drain valves) resulting in loss of basin water Rearrange or spill fuel | Release Criticality ¹ | Administrative Controls: Heavy load controls Nuclear Criticality Safety Program Engineering Evaluation: Drop calculations Design Feature: IPSS/T; MCO basket shutoff, PCM support structure, process table support structure, MCO queue, knockout pots; lifting devices (limit drop height) | Administrative Controls: Basin water level controls Controls for water addition and leak mitigation Annual maintenance Weight verifications Independent check Design Features: Monorail stops and inter-locks; asphalt barrier and sump system | S2 | S1 | Administrative Controls: Hoisting and rigging controls Personnel qualifications Operational surveillances Annual maintenance Weight verifications Independent check Design Features: Monorail stops and inter-locks; asphalt barrier and sump system | W/O With | 7 (3.4.2.1 Heavy Load Drops) |
| F.1A | Mass, Gravity, Height (F4, F3) | Heavy load drop | Human error Equipment failure Seismic event | Crash-MCO dropped: • Into IPSS • Onto IPSS • Onto IPSS bottom plate • Onto SLOP curb • Onto floor, tip-and-hit south loadout pit curb | Release Criticality ¹ | Administrative Control: Heavy loads controls Engineering Evaluation: Drop calculations Design Feature IPSS/T | Administrative Controls: Basin water level controls Controls for water addition and leak mitigation | S2 | S1 | Administrative Controls: Basin water level controls Controls for water addition and leak mitigation | W/O With | 5 (3.4.2.2 Crash-MCO Drops) |
| F.2 | Mass, Gravity, Height (F3, F7, F3) | Load drop (e.g., canisters, debris, seller, maintenance and construction loads) | Human error Equipment failure Seismic event | Dropped load/seismic forces potentially damages basin drain valve resulting in loss of basin water | Release Criticality ¹ | Administrative Control: Nuclear Criticality Safety Program Engineering Evaluation: Drop calculations Design Features: IPSS/T; horizontal beam on south loadout pit west wall; operations interface platform; drain valve cover; drain line plugs | Administrative Controls: Basin water level controls Controls for water addition and leak mitigation | S2 | S1 | Administrative Controls: Hoisting and rigging controls Personnel qualifications Operational surveillances Annual maintenance Weight verifications Independent check Design Features: Asphalt barrier and sump system | W/O With | 7 (3.4.2.3 Damage to Drain Valve from an Operational Drop) |

Table C-1. Hazard Analysis Worksheet (7 Sheets).

| ID | Energy Source | Hazardous Condition | Cause | Potential Accident | Potential Consequence | Qualitative Frequency | | Available Credited Protection and Defense-in-Depth Mitigation | | Qualitative Consequence | | Risk Ranking (Accident ID) |
|-----|------------------------------|--------------------------|---|---|-----------------------|-----------------------|--|---|--|---|---|--------------------------------------|
| | | | | | | W/O | W/I | F3 | F1 | S3 | S1 | |
| F.3 | Mass, Gravity, Height (F7) | Overlift fuel containers | Human error | Fuel containers and/or racks lifted out of water causing high heat and/or fuel fire or aerodynamic entrainment | Release | High Radiation | Administrative Control: Independent check | Administrative Control: Radiation Protection Program | Administrative Controls: Hoisting and rigging controls | Load limitations/engineering calculations | Personnel qualification | 9 (3.4.2.4 SNF Overlifts) |
| F.4 | Mass, Gravity, Height (F7) | | Equipment failure | | | | Design Features: Lifting devices, gantry and support structure | | Design Features: Continuous air monitors; area radiation monitors; hoses controls; fuel handling hooks | | | |
| G.1 | Flammable Materials (G11,L6) | | Seismic event | DBE occurs while gantry is jacking an MCO scrap basket. Gantry fails with MCO basket in highest position while basin water drains. | Release | High Radiation | Engineering Evaluation | F1 | Administrative Controls: Basin water level controls | Controls for water addition and leak mitigation | Design Features: Lifting devices; gantry and support structure | 6 (bounded by 3.4.2.4 SNF Overlifts) |
| G.2 | Flammable Materials (G7) | | Human error | Hydrogen burn/ explosion | Release | Worker Fatality | Administrative Controls: Shipping window control | F1 | Administrative Control: Cooling and depressurization of MCO | Design Features: Cask Venting Tool | Design Features: Structural design of components (cask-MCO, knockout pots, annular filter vessels, particulate settlers, IXMs/TXCs) | 3 (3.4.2.5 MCO Shipping) |
| G.2 | Flammable Materials (G7) | | Equipment failure | | | | Administrative Controls: Basin water temperature controls | | Cask access lift device (to access cask when hung on transfer bay bridge crane) | | | 3 (3.4.2.6 Explosions) |
| G.2 | Flammable Materials (G7) | | Diesel fuel (from either forklift, high-lifter, or MCO transport truck) | Diesel fuel spills and burns (either pooling around critical columns resulting in structural failure or excessive heat builds up in ceiling resulting in structural failure). If a column critical to the transfer bay bridge crane is impacted, the transfer bay bridge crane and supporting structural members could drop onto the annular filter vessels and release some of its contents. | Release | Worker Fatality | Administrative Controls: Vehicle controls (fuel quantity limitations) | F2 | Administrative Controls: Emergency Response Program | Transfer bay door open during cask delivery/pick-up (allows heat to escape) | Design Features: Shielding enclosure protects TWTS annular filter vessels | 5 (3.4.2.13 Fires) |
| | | | | | | | Fire Protection Program | F0 | Emergency Site fire fighters | Roof vents allow hot gas to vent | Design Features: Floor drains | |
| | | | | | | | Vehicle maintenance and inspections | | Transfer bay open during cask delivery/pick-up (allows heat to escape) | Roof vents allow hot gas to vent | Roof vents | |
| | | | | | | | Design Features: Critical columns on concrete stanchions prevent pooling | | | | | |
| | | | | | | | Transfer Bay floor sloped away from moist columns | | | | | |

Table C-1. Hazard Analysis Worksheet (7 Sheets).

| ID | Hazardous Source | Hazardous Condition | Cause | Potential Accident | Potential Consequence | Quantitative Frequency | | Available Credited Protection and Defense-in-Depth Mitigation | | Qualitative Consequence | | Rate Resulting (Accident ID) |
|-----|--------------------------------|---|-------------------|--|-----------------------|---|----|---|-----|-------------------------|---|-----------------------------------|
| | | | | | | F1 | F0 | Administrative Controls: Fire Protection Program | W/O | Wth | Administrative Controls: Transfer bay bridge crane preventive maintenance | |
| G.3 | Flammable Materials (G4) | Crane hydraulic oil leaks and is ignited | Equipment failure | Create hydraulic oil leaks while performing operations above the south loadout pit and oil pools around gantry column and burns. Gantry fails and drops MCO basket, which perforates floor and results in loss of basin water. | Release | Engineering Features: Transfer bay bridge crane | F1 | Administrative Controls: Fire Protection Program | S3 | S1 | Administrative Controls: Transfer bay bridge crane preventive maintenance | 6 (3.4.2.13 Fires) |
| K.1 | Thermal (K7) | Radioactive decay heat from stored fuel, pump heating and lighting in basin | Human error | Loss of cooling system results in heating of basin water to greater than allowed limit for shipping a cask-MCO resulting in overpressurization | Release | Administrative Controls: MCO shipping controls | F2 | Administrative Control: Cooling and depressurization of MCO | S3 | S1 | Administrative Controls: Personnel qualifications | 8 (3.4.2.5 MCO Shipping) |
| L.1 | Explosive pyrophoric (L10) | Pyrophoric uranium hydrides accumulated in fuel canister due to plugged canister vent | Chemical reaction | Rapid burn of fuel or fuel element underwater in deceiver or PCM | Release | Administrative Controls: Basin water temperature controls | F1 | Administrative Control: Basin water | S3 | S1 | Administrative Control: Independent check | 6 (3.4.3.1 Underwater Fuel Burns) |
| L.2 | Explosive pyrophoric (L10, N1) | Buildup of uranium metal particles | Equipment failure | Fuel fire in particulate settler or knockout pots caused by heating; loss of basin water; or overfill; or air spring in annular filter vessel | Release | Design Feature: Cask-MCO | F2 | Administrative Control: Controls for water addition and leak mitigation | S3 | S1 | Administrative Control: Slow accumulation rate | 6 (3.4.2.4 SNF Overfill) |
| L.3 | Explosive pyrophoric (L10, N1) | Uranium metal/uranium hydrides dryout | Human error | Loss of basin pool water causes uranium metal/uranium hydrides dryout creating rapid oxidation of uranium fuel | Release | Engineering Evaluation | F1 | Administrative Controls: Basin water level controls | S3 | S1 | Design Feature: Building provides limited confinement | 6 (3.4.2.4 SNF Overfill) |
| | | | Equipment failure | | | | F0 | Administrative controls: Vehicle movements | | | | |
| | | | Seismic event | | | | | Heavy loads | | | | |
| | | | | | | | | Basin water level controls | | | | |
| | | | | | | | | Water addition and leak mitigation | | | | |
| | | | | | | | | Design Features: Bumper; sand filter; UXMs; building columns; loadout pit curbs | | | | |

Table C-1. Hazard Analysis Worksheet (7 Sheets).

| ID | Hazardous Condition | Cause | Potential Accident | Potential Consequence | Available Credited Prevention and Defense-in-Depth Features | Qualitative Frequency | Available Credited Mitigation and Defense-in-Depth Mitigation | Qualitative Consequence | | Risk Rating (Accident ID) | | |
|-----|--|--|--|---|---|---|---|-------------------------|---|---------------------------|-----|---|
| | | | | | | | | W/O | With | | | |
| N.1 | Natural Phenomena (N1, F14) | Earthquake (DBE) | Seismic event | DBE causes basin leakage or fuel rearrangement | Release Criticality ¹ | None | F2 | F2 | Administrative Controls: Controls for water addition and leak mitigation; Nuclear Criticality Safety Program. Design Features: Basin, Basin water level, Building superstructure, Transfer bay bridge crane, Canisters, PCM support structure, Process table support structure, MCO basket queue, MLS shuttle, Gandy, IPSS/TP, Drain valve covers | S3 | S1 | Design Features: Asphalt barrier and sump system (3.4.2.10 Design Basis Earthquake) |
| N.2 | Natural Phenomena (N2) | Flood (DBF) | Columbia River floods | Loss of river pumps | None | | F1 | N/A | | S0 | N/A | None |
| N.3 | Natural Phenomena (N3, N4, N5, N6, N9) | Lightning, Rain, Snow, Freezing Weather, Straight Wind, Ashfall (All facility design basis events) | Weather conditions | Structural damage | | | F2 | N/A | Building designed for these design basis events | S0 | N/A | None |
| P.1 | External Events (P2) | Fire (range fire) | Lightning strike, human error, etc. | Loss of electrical (fire can't get near basin) | See K Basin (SAR) Section 11.4 | | | | | N/A | N/A | |
| P.2 | External Events (P3) | Events at other facilities | CVD accidents | See CVD/SAR | All accidents are prevented or mitigated by CVD | N/A | | | | N/A | N/A | |
| P.3 | Loss of Power (P4) | General or partial power failure Reduced voltage Surge | BPA problem Human error Equipment failure Seismic event | Loaded tank-MCO hung up on crane, exposed shipping window, access problem to vent system, loss of cooling water | Release | Administrative Controls: MCO assembly controls Shipping window control Basin water temperature controls Design Features: Cask-MCO; MCO HEPA filter, spray water source | F2 | F0 | Administrative controls for cooling and depressurization of MCO | S3 | S0 | Design Features: Portable monitoring equipment Emergency lighting (3.4.2.5 MCO Shipping) |
| R.1 | Vehicles in Motion (R1) | Airplane | Human error Equipment failure | Crash of commercial, general, or military airplane | Beyond Extremely Unlikely | F0 | | | | S3 | | 0 (Chapter 1.0) |

Table C-1. Hazard Analysis Worksheet (7 Sheets).

| ID | Energy Source | Hazardous Condition | Cause | Potential Accident | Potential Consequence | Available Credited Prevention and Defense-in-Depth Features | Qualitative Frequency | Available Credited Mitigation and Defense-in-Depth Mitigation | | Qualitative Consequence | W/O | With | Defense in Depth | Risk Resulting (Accident ID) |
|-----|-------------------------|---------------------|----------------------------------|--|---------------------------|---|-----------------------|---|------|-------------------------|-----|------|------------------|------------------------------|
| | | | | | | | | W/O | With | | | | | |
| R-2 | Vehicles in Motion (R2) | Helicopter | Human error Equipment failure | Crash of commercial, general, or military helicopter | Beyond Extremely Unlikely | | F0 | | | S3 | | | 0 | (Chapter 1.0) |

¹ An extensive hazards analysis focused on criticality is provided in the K Basins CSERs and is documented in Chapter 6.0.

BPA = Bonneville Power Administration
 CCTV = closed-circuit television
 CSER = criticality safety evaluation report
 CVDF = Cold Vacuum Drying Facility
 DBE = design basis earthquake
 DBF = design basis flood
 HEPA = high-efficiency particulate air (filters)
 IPSS = immersion pail support structure
 IWTS = Integrated Water Treatment System
 IXC = ion-exchange column
 IXM = ion-exchange module
 MCO = multi-canister overpack
 MLS = multi-canister overpack loading system
 NLOP = north leadout pit
 PCM = primary clean machine
 SAR = safety analysis report
 SLOP = south leadout pit

Table C-2. Workers Safety Hazard Analysis Worksheet (3 Sheets).

| ID | Hazard energy | Hazardous condition | Cause | Potential accident | Potential Consequence | Potential Credited protection | Frequency | Potential Credited mitigation | Consequence | Defense-in-depth or worker safety features |
|-------|-------------------------|--|----------------------------------|---|-----------------------|---|-----------|-------------------------------|-------------|---|
| W.E.1 | Pressure - Volume | Decreased filtration or DFM efficiency | Human error Equipment failure | FRS flow in addition to recirculation pump bypass to DFM caused by misvalving air monitoring equipment or incorrect cartridge filter start up after replacement, causing a decrease in the basin water quality | Worker exposure | Air monitoring equipment Procedures for change out of filters and DFM | F2 | | S1 | Radiation Protection Program |
| W.E.2 | Pressure - Volume | Inadequate filtration from the C-Sump return | Human error Equipment failure | Pipe break, clogged filter, or improper valving causes low or no flow from sump return, resulting in contamination of the transfer bay area | Worker exposure | Procedures (Change out filters) Reduced Filter System | F2 | | S1 | Radiation Protection Program Hazardous Waste Program |
| W.E.3 | Pressure-Volume (W.E.4) | Presurized MCO | Human error | MCO mis-loaded (too many scrap basket, excess fuel fines) | Worker exposure | Administrative Control: Shipping window control | F2 | | S1 | Radiation Protection Program Training Program |
| W.E.4 | Pressure-Volume (W.E.3) | Presurized MCO | Human error | Inadequate helium purge of loaded MCO during pre-ship processing | Worker exposure | Administrative Control: Shipping window control | F2 | | S1 | Radiation Protection Program Training Program |
| W.F.1 | Mass, Gravity, Height | Equipment drop | Human error Equipment failure | During disassembly, sorting or inspection, equipment is dropped into the pool creating a splash resulting in an aerosol release and ALARA problems during recovery of damaged equipment (e.g., a deformed basket) | Worker exposure | Engineered lifting points Material handling equipment will have a limited swing radius and limited position change rate Procedures Inspection | F3 | | S1 | Radiation Protection Program Training Program Personnel Personnel Qualification Requirements |
| W.F.2 | Mass, Gravity, Height | Knockout pot too heavy | Equipment failure | During lifting of knockout pot, the pot is dropped causing damage to lifting equipment and contamination of basin | Worker exposure | Design Features: Knockout Pot Safety Class: physical strength to withstand drop loads without failure; screens limit particle size in downstream equipment Hoist Controls | F2 | | S1 | Hoisting and Raising Controls Personnel Qualifications Load Limitations Engineering Calculations |
| W.F.3 | Mass, Gravity, Height | Process dip tube not seated correctly | Human error Equipment failure | During installation of MCO shield plug, the process dip tube does not seat correctly causing the MCO shield plug to not seat, which results in a high radiation stream | Worker exposure | Cameras Basket geometry Procedures Qualified operators | F3 | | S1 | Radiation Protection Program Continuous Air Monitoring Area Radiation Monitoring |
| W.F.5 | Mass, Gravity, Height | Immediate high radiation dose | Human error Equipment failure | FRS manipulator brings fuel element too close to surface of basin water or throws fuel element of out water | Worker exposure | Engineering evaluation determines that this is not a credible event (Williams 1996) Manipulator design | F0 | | S1 | Radiation Protection Program Area Radiation Monitoring |

Table C-2. Workers Safety Hazard Analysis Worksheet (3 Sheets).

| ID | Hazard energy | Hazardous conditions | Cause | Potential accident | Potential Consequence | Potential Credited prevention | Frequency | Potential Credited mitigation | Consequence | Defense-in-Depth or worker safety features |
|-------|----------------------------------|---|---|--|--|---|-----------|---|-------------|--|
| W.G.1 | Flammable Materials (G1, G2, G8) | Combustible materials (e.g. shipping crates, pallets, windbreak material, impact-limiting foam, plastic containment tents, anti-contamination clothing) | Human error Equipment failure | Combustible material ignites and impacts critical structural columns by direct flame impingement and hot gas layer | Worker exposure Minor release | Administrative Controls: Fire Protection Program (including combustible quantities and spacing limits, and controls on hot work) Impact-limiting foam encased in sheet metal or below water surface | F3 | | S1 | Hanford Site fire response |
| W.I.1 | Radiation | Transfer of contaminated water to air lines, receiver, and compressor | Equipment failure | Equipment contamination | Worker exposure | Check valve Procedure Operational surveillance | F1 | | S1 | Radiation Protection Program |
| W.I.2 | Radiation | Waste pad shipping dock stores spent IXMs and packaged cartridge filters awaiting disposal | Human error | Equipment stored improperly | Worker exposure | Fenced area Concrete pad etched with muriatic acid and coated with epoxy | F1 | | S1 | Radiation Protection Program Hazardous Waste Control Program |
| W.I.3 | Radiation | 137Cs trapped in piping and valves | Human error Equipment failure | Generates hot spots in piping | Worker exposure | Procedures Samples are collected routinely Radiation fields monitored IXMs | F2 | | S1 | Radiation Protection Program |
| W.I.4 | Radiation (I3, I4) | Accumulated sludge storage: KE Waste Pit; KW Dummy Elevator Pit; KE/KW Sand Filter Backwash Pit (NLOP); KE/KW floor sludge; KW Technical View Pit; IXCs | Human error Equipment failure Seismic event | Loss of shielding | High radiation | Administrative Controls: Basin water level controls Radiation Protection Program Design Features: Basin/Basin water Equipment enclosures | F2 | | S1 | Administrative Controls: Operational Surveillances Personnel Qualifications Authorized Inspections Design Feature: Continuous Air Monitoring Area Radiation Monitoring |
| W.M.1 | Hazardous Material | Knockout Pots (KW); Particulate Settler; Tanks (KW waste pit); Annular Filter Vessel; IXMs; Sand Filters; Pumps and Piping Fuel Storage: Cansiders; Decapper; Stuck Fuel Station; PCM; Process Table; MCCO Bulkhead; Cask-MCCO; Stiffneck Grapples | Loading wrong resin into IXM | Human error | Vender ships wrong resin Plant personnel load wrong resin | Possible selective removal of plutonium from basin water leading to criticality module | F1 | Procedures Training Cognizant Engineer oversight at loading | S1 | Beyond Extremely Unlikely |

Table C-2. Workers Safety Hazard Analysis Worksheet (3 Sheets).

| ID | Hazard energy | Hazardous conditions | Cause | Potential accident | Potential Consequence | Potential Credited prevention | Frequency | Potential Credited mitigation | Consequence | Defense-in-depth or worker safety features |
|-------|--------------------|---|---|--|---|-------------------------------|-----------|-------------------------------|-------------|---|
| W.P.1 | Loss of Power (P4) | Partial power failure Reduced voltage Surge | Human error Equipment failure Natural phenomena | Loss of safety-significant radiation monitoring for similar filter vessels | Unmonitored buildup of sludge causing increased dose to workers | | F1 | Surveillance Program | S1 | Radiation Protection Program Loss of Radiation Monitor Alarm |

ALARA = as low as reasonably achievable
 FRS = Fuel Retrieval System
 KB = K East
 KW = K West
 IXC = ion-exchange column

IXM = ion-exchange module
 MCO = multi-canister overpack
 NLOP = north lookout pit
 PCM = primary clean machine
 PHMC = Project Hanford Management Contract

Attachment D

K BASIN HAZARD ANALYSIS TEAM MEMBERS

This page intentionally left blank

Attachment D

K BASIN HAZARD ANALYSIS TEAM MEMBERS

This K Basins hazard analysis was prepared by combining the hazards analysis from previous subproject and K Basins analyses. This integrated K Basins Hazard analysis was developed by the following personnel, who were also participants in the previous hazard analysis work, and are as follows:

Gail Chaffee (100 K Basins Nuclear Safety)
Bob Meichle (K Basins Nuclear Safety Subject Matter Expert)
Steve Peck (FRS Nuclear Safety Subject Matter Expert)
Lynn Semmens (IWTS Nuclear Safety Subject Matter Expert)
Roger Webb (CLS Nuclear Safety Subject Matter Expert).

This page intentionally left blank