

**S****ENGINEERING CHANGE NOTICE**Page 1 of 2

1. ECN

660518

Proj.  
ECN

2. ECN Category (mark one)	3. Originator's Name, Organization, MSIN, and Telephone No.	4. USQ Required?	5. Date
Supplemental Direct Revision Change ECN Temporary Standby Supersedure Cancel/Void  <input checked="" type="checkbox"/>	T. Nuxall, CVDF, R3-86, 372-3739	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6/1/00
	6. Project Title/No./Work Order No.  SNF/W-441  Spent Nuclear Fuel Cold Vacuum Drying	7. Bldg./Sys./Fac. No.  CVDF 142-K	8. Approval Designator  S <sup>N</sup> Q
	9. Document Numbers Changed by this ECN (includes sheet no. and rev.)  SNF-3934, Rev. 1, SNF-3890, Rev. 1, SNF-3876, Rev. 1, SNF-3877, Rev. 1	10. Related ECN No(s).  N/A	11. Related PO No.  N/A
12a. Modification Work  <input type="checkbox"/> Yes (fill out Blk. 12b)  <input checked="" type="checkbox"/> No (NA Blks. 12b, 12c, 12d)	12b. Work Package No.  N/A	12c. Modification Work Complete  N/A  Design Authority/Cog. Engineer Signature & Date	12d. Restored to Original Condi- tion (Temp. or Standby ECN only)  N/A  Design Authority/Cog. Engineer Signature & Date
13a. Description of Change	13b. Design Baseline Document? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		

SC

**Process Hood GOVs**

Revised internal pressure acceptance criteria to "Withstands nominal 150 psig and 29" Hg Vacuum". Add GOV Seat Leakage acceptance criteria. Revised all GOV fail safe position, stroke time to "Less than 2 seconds", deleted critical characteristic insulation resistance, solenoid inrush current, solenoid holding current, and current carrying capability of contracts.

USQ Approval: *CVDF-00-1036 lk 4/2/00*

14a. Justification (mark one)	Criteria Change <input type="checkbox"/>	Design Improvement <input checked="" type="checkbox"/>	Environmental <input type="checkbox"/>	Facility Deactivation <input type="checkbox"/>
As-Found <input type="checkbox"/>	Facilitate Const <input type="checkbox"/>	Const. Error/Omission <input type="checkbox"/>	Design Error/Omission <input type="checkbox"/>	


## 14b. Justification Details

Revision required to make these CGI dedication packages consistent with there safety function.

The design verification method for SS/SC components is by independent review in accordance with EN-6-027-01. Documentation of this review is accomplished by the independent review approval signature provided on page 2 of this ECN.

## 15. Distribution (include name, MSIN, and no. of copies)

See distribution sheet.



## ENGINEERING CHANGE NOTICE

1. ECN (use no. from pg. 1)

Page 2 of 2

660518

16. Design Verification Required

17. Cost Impact NA

18. Schedule Impact (days)

Yes  
 No

ENGINEERING		CONSTRUCTION		NA	
Additional	\$	Additional	\$	Improvement	\$
Savings	\$	Savings	\$	Delay	\$

19. Change Impact Review: Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 13. Enter the affected document number in Block 20.

SDD/DD	<input type="checkbox"/>	Seismic/Stress Analysis	<input type="checkbox"/>	Tank Calibration Manual	<input type="checkbox"/>
Functional Design Criteria	<input type="checkbox"/>	Stress/Design Report	<input type="checkbox"/>	Health Physics Procedure	<input type="checkbox"/>
Operating Specification	<input type="checkbox"/>	Interface Control Drawing	<input type="checkbox"/>	Spares Multiple Unit Listing	<input type="checkbox"/>
Criticality Specification	<input type="checkbox"/>	Calibration Procedure	<input type="checkbox"/>	Test Procedures/Specification	<input type="checkbox"/>
Conceptual Design Report	<input type="checkbox"/>	Installation Procedure	<input type="checkbox"/>	Component Index	<input type="checkbox"/>
Equipment Spec.	<input type="checkbox"/>	Maintenance Procedure	<input type="checkbox"/>	ASME Coded Item	<input type="checkbox"/>
Const. Spec.	<input type="checkbox"/>	Engineering Procedure	<input type="checkbox"/>	Human Factor Consideration	<input type="checkbox"/>
Procurement Spec.	<input type="checkbox"/>	Operating Instruction	<input type="checkbox"/>	Computer Software	<input type="checkbox"/>
Vendor Information	<input type="checkbox"/>	Operating Procedure	<input type="checkbox"/>	Electric Circuit Schedule	<input type="checkbox"/>
OM Manual	<input type="checkbox"/>	Operational Safety Requirement	<input type="checkbox"/>	ICRS Procedure	<input type="checkbox"/>
FSAR/SAR	<input type="checkbox"/>	IEPD Drawing	<input type="checkbox"/>	Process Control Manual/Plan	<input type="checkbox"/>
Safety Equipment List	<input type="checkbox"/>	Cell Arrangement Drawing	<input type="checkbox"/>	Process Flow Chart	<input type="checkbox"/>
Radiation Work Permit	<input type="checkbox"/>	Essential Material Specification	<input type="checkbox"/>	Purchase Requisition	<input type="checkbox"/>
Environmental Impact Statement	<input type="checkbox"/>	Fac. Proc. Samp. Schedule	<input type="checkbox"/>	Tickler File	<input type="checkbox"/>
Environmental Report	<input type="checkbox"/>	Inspection Plan	<input type="checkbox"/>		<input type="checkbox"/>
Environmental Permit	<input type="checkbox"/>	Inventory Adjustment Request	<input type="checkbox"/>		<input type="checkbox"/>

20. Other Affected Documents: (NOTE: Documents listed below will not be revised by this ECN.) Signatures below

indicate that the signing organization has been notified of other affected documents listed below.




Document Number/Revision

Document Number/Revision

Document Number Revision

NA

21. Approvals

	Signature	Date	Signature	Date
Design Authority C. Miska		6/1/00	Design Agent	<input type="text"/>
Cog. Eng. C. VanKatwijk		6/2/00	PE	<input type="text"/>
Cog. Mgr. T. Choho		6/2/00	QA	<input type="text"/>
QA H. Chafin P. RAMSEY		6/2/00	Safety	<input type="text"/>
Safety J. Brehm		6/2/00	Design	<input type="text"/>
Independent Reviewer G. C. Lee		6/2/00	Environ.	<input type="text"/>
Other: * C. Haller		6/2/00	Other	<input type="text"/>

\* Approval authorized parallel preparation of USQ screen  
 with implementation of ECN per NSDI-02.

## DEPARTMENT OF ENERGY

Signature or a Control Number that tracks the  
 Approval Signature

## ADDITIONAL

## DISTRIBUTION SHEET

# **Worcester 1" Solenoid- Actuated Gas-Operated SCHE System Valves**

Prepared for the U.S. Department of Energy  
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the  
U.S. Department of Energy under Contract DE-AC06-96RL13200

**Fluor Hanford**  
P.O. Box 1000  
Richland, Washington

**Copyright License**

By acceptance of this article, the publisher and/or recipient acknowledges the U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper.

# Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

C. Van Katwijk  
Fluor Hanford, Inc.

Date Published  
June 2000

Prepared for the U.S. Department of Energy  
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the  
U.S. Department of Energy under Contract DE-AC06-96RL13200


**Fluor Hanford**  
P.O. Box 1000  
Richland, Washington

**Copyright License**

By acceptance of this article, the publisher and/or recipient acknowledges the U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper.

  
Barbara Polson  
Release Approval

6/6/00  
Date



Release Stamp

**TRADEMARK DISCLAIMER**

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy and microfiche.

Available electronically at <http://www.doe.gov/bridge>. Available for a processing fee to the U.S. Department of Energy and its contractors, in paper, from:  
U.S. Department of Energy  
Office of Scientific and Technical Information  
P.O. Box 62  
Oak Ridge, TN 37831-0062  
phone: 865-576-8401  
fax: 865-576-5728  
email: [reports@adonis.osti.gov](mailto:reports@adonis.osti.gov)(423) 576-8401

Available for sale to the public, in paper, from:  
U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161  
phone: 800-553-6847  
fax: 703-605-6900  
email: [orders@ntis.fedworld.gov](mailto:orders@ntis.fedworld.gov)  
online ordering: <http://www.ntis.gov/ordering.htm>

Printed in the United States of America

Total Pages:

14



# Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002  
Title: **Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves**

Page 1 of 10

<b>Section 1 Part Information</b>													
Item No.: <b>N/A</b>	Manufacturer: <b>N/A</b>	Supplier: <b>N/A</b>											
Mfg. Part/Model No.: <b>N/A</b>		Supplier's P/N: <b>N/A</b>											
Part Description: <b>N/A</b>													
End Use Description: <b>N/A</b>													
<b>Section 2a Component Information</b>													
Equipment No.: <b>He-GOV/SOV-1*02, 1*06 SCHe-GOV/SOV-5*12, 5*31, 5*51, 5*71</b>	Specification No.: <b>SNF-5303, Rev. 0 (W-441-P4, Rev. 3)</b>	Manufacturer: <b>Worcester Controls</b>	Past P.O. No.: <b>N/A</b>										
Procurement and/or Model Number: <b>1" E 5966RTBW4 with 15I939SWM2120PBC</b>	Equipment Supplier (if different from manufacturer): <b>Olympic Tool &amp; Engineering</b>		Equip. Supplier's Part No.: <b>N/A</b>										
Component Description: <b>1" Gas-operated full-port ball valves incorporate a solenoid and limit switches as integral parts of the actuator. These valves are normally open and fail safe to the open position (GOV-1*02 and 1*06 fail closed) to provide a flow path of helium gas to the MCO under helium purge and off-normal conditions when the MCO is isolated.</b>													
<b>Section 2b Commercial Availability of the Item</b>													
<p>1. Is the item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)? <input type="checkbox"/> YES (go to #2 below) <input checked="" type="checkbox"/> NO (go to procedure step 6.3.2, proceed to dedicate item)</p> <p>If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Interface Engineer or BTR):</p> <p><input type="checkbox"/> YES (go to #2 below, procedure step 6.3.2, dedicate item) <input checked="" type="checkbox"/> NO (procedure step 6.3.2, dedicate item)</p>													
2. List of Candidate qualified suppliers or ISO 9000 suppliers: <b>N/A</b>													
3. Recommended Procurement Strategy(coordinate with project CGI interface Engineer or BTR): <b>N/A</b>													
<b>Section 2c CGI Determination</b>													
<p>CGI Determination Questions:</p> <p>#1: Is the item subject to design or specification requirements that are unique to nuclear facilities or activities?</p> <p><input type="checkbox"/> YES (the item is not commercial grade) <input checked="" type="checkbox"/> NO (continue)</p> <p>#2: Is the item used in applications other than nuclear facilities or activities?</p> <p><input type="checkbox"/> NO (the item is not commercial grade) <input checked="" type="checkbox"/> YES (continue)</p> <p>#3: Is the item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?</p> <p><input type="checkbox"/> NO (the item is not commercial grade) <input checked="" type="checkbox"/> YES (continue)</p>													
<p><input checked="" type="checkbox"/> All three criteria have been satisfied. The item meets the definition of commercial grade.</p>													
<b>Section 2d Reason for Dedication</b>													
<p>The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"><input checked="" type="checkbox"/></td> <td>Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.</td> </tr> <tr> <td><input type="checkbox"/></td> <td>Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.</td> </tr> <tr> <td><input type="checkbox"/></td> <td>Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.</td> </tr> <tr> <td><input type="checkbox"/></td> <td>Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.</td> </tr> <tr> <td><input type="checkbox"/></td> <td>Other ('like-for-like', similar, substitution, replacement evaluation)</td> </tr> </table>				<input checked="" type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.	<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.	<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.	<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.	<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)
<input checked="" type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.												
<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.												
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.												
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.												
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)												

# Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/A

CGI No. CGI-SNF-D-13-P4-002

Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 2 of 10

Section 3: Failure Effects Evaluation			
<p>A. Part/Component Safety Function:</p> <ol style="list-style-type: none"> <li>1. Prevent H<sub>2</sub> Explosion.</li> <li>2. Remain intact and functional during any event that might threaten the valve integrity. Maintain intact pressure boundary/confinement.</li> <li>3. Maintain critical function before and after seismic event.</li> </ol>			
<p>B. Part/Component Functional Mode:</p> <p>Safety Function #1: <input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive</p> <p>Safety Function #2: <input type="checkbox"/> Active <input checked="" type="checkbox"/> Passive</p> <p>Safety Function #3: <input type="checkbox"/> Active <input checked="" type="checkbox"/> Passive</p>		<p>Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function</p> <p>Passive - Change of state is not required for the component to perform its safety function</p>	
<p>C. Host Component Safety Function (if applicable): N/A</p> <ol style="list-style-type: none"> <li>1.</li> </ol>			
<p>D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):</p> <ol style="list-style-type: none"> <li>1. Electrical fault in the solenoid. Valve fails open (fail-safe), fails closed for GOV-1*02 &amp; 1*06.</li> <li>2. Loss of air pressure to the pneumatic actuator. Valve fails open (fail safe), fails closed for GOV-1*02 &amp; 1*06.</li> <li>3. Loss of control signal to solenoid. Valve fails open (fail safe), fails closed for GOV-1*02 &amp; 1*06.</li> </ol>			
Section 4: Environmental & Natural Phenomena Hazard Design			
<p>Environmental Qualification Required:</p> <p>Yes <input type="checkbox"/></p> <p>No <input checked="" type="checkbox"/> Environmental Condition B</p>		<p>If yes: Environmental Qualification Requirements</p> <p>Limiting Environmental Conditions:</p> <p>Required Safety Functions:</p> <p>Qualification Period:</p>	
<p>Natural Phenomena Hazard (NPH) Design Required:</p> <p>Yes <input checked="" type="checkbox"/></p> <p>No <input type="checkbox"/></p> <p><b>HNF-PRO-97 Rev. 0</b> <b>W-441-P4, Rev. 3</b></p>		<p>If yes: NPH Design Requirements</p> <p>Performance Category: <b>PC-3</b></p> <p>NPH Design Req'ts.: <b>Seismic Condition A</b></p> <p>Required Safety Functions: <b>Boundary/Confinement, Isolation, Prevent H<sub>2</sub> Explosion</b></p>	
Section 5: Component Functional Classification			
<input checked="" type="checkbox"/>	Safety Class (SC)	General Service (GS)	Safety Significant (SS)
<p>If part/component classification is different from host component/system, document basis. <b>N/A</b></p>			
Sections 6 and 7 (Reserved)			
Section 8: References (for Functional Classification)			
<p>National Codes/Standards: <b>ASME B31.3</b></p> <p>Safety Analysis Report (SAR): <b>HNF- 3553, Rev. 0a, Annex B</b></p> <p>Drawings: <b>H-1-82161, Rev. 4, HNF-SD-SNF-SEL-002, Rev. 7</b></p> <p>Vendor Manual/Manufacturer/Supplier Information: <b>Worcester PB451-22</b></p>			

## Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/ACGI No. CGI-SNF-D-13-P4-002Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 3 of 10

Section 9 - Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the item delivered is the item specified)				
<b>Nameplate - Manufacturer</b>	<b>Worcester Controls</b>	1, IN	X	
<b>Valve-Component Number-Procurement and/or Model Number</b>	<b>1" E 5966RTBW4 (Per Procurement Package W-441-P4, Rev. 3, Section H, Design Data Sheet)</b>	1, IN	X	
<b>Actuator-Component Number-Procurement and/or Model Number (Includes SOV)</b>	<b>15I939SWM2120PBC (Per Procurement Package W-441-P4, Rev. 3, Section H, Design Data Sheet)</b>	1, IN	X	
<b>Nameplate Data of Actuator (Includes SOV)</b>	<b>Per Vendor Manual. To Include "R6" (Upper Right Corner)</b>	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the item delivered is the item specified)				
<b>Valve Body Material</b>	<b>Stainless Steel (Note 4)</b>	1, IN; 1, T	X	
<b>Configuration/Mounting</b>	<b>Integral Actuator/Valve Assembly. Black recessed override button</b>	1, IN	X	
<b>Process Connection</b>	<b>1" Butt Weld</b>	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the item will perform its intended safety function(s))				
<b>GOV Pressure Boundary</b>	<b>Pressure Test At nominal 165 psig (Zero Leakage) Note 3</b>	1, T		X
<b>Internal Pressure</b>	<b>Withstands nominal 150 psig and 29" Hg Vacuum (Zero Leakage)</b>	1, T		X
<b>GOV Seat Leakage</b>	<b>Pressurize the upstream side of the valve seat to 165 psig (110%) and reduce to 150 psig (110%), 100% soaking for 10 min. at 150 psig, then check for obvious leaks. Apply bubble leak solution on the valve seat to find leaks. Proceed to lower the pressure to 15 psig for the Sensitive Leak Test. Apply solution to valve seat area after minimum 15 minutes soak time at nominal 15 psig.</b> <b>Acc. Criteria: No Leakage-No Bubbles. Note 5</b>	1, T		X
<b>GOV Fail Safe Position GOV-5*12, 5*31, 5*51, 5*71</b>	<b>Valve fails OPEN on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.</b>	1, T		X
<b>GOV Fail Safe Position GOV-1*02 &amp; 1*06*</b>	<b>Valve fails CLOSED on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.</b>	1, T		X
<b>Environmental</b>	<b>Note 1</b>			
<b>Seismic Condition A</b>	<b>Note 2</b>	1, T		X

## Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002  
 Title: **Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves**

Page 4 of 10

<p>4. Notes and Legend:</p> <ol style="list-style-type: none"> <li>These valves have coro-lube (nickel-acetate), acetal resin, and NEMA Enclosed Solenoids, these materials are not subject to degradation at 40°F and 60% RH or 115°F and 22% RH and are suitable for condition B Application.</li> <li>Maintain critical function before and after seismic event. W-441-P4, Rev. 3, Appendix L, pages L-2 &amp; L-4, provide a seismic testing plan for these components at a (TBD) seismic spectra. Equipment that has been shaker-table tested should not be installed in a plant (Ref. IEEE Standard 344-1984, Section 7). Consequently, the seismic test constitutes a destructive test. The industry sampling practice for destructive test is to test only one item.</li> <li>Pressure test at 110% of design accident condition pressure of 150 psig.</li> <li>Material verification acceptance method may be by either inspection or test.</li> <li>15 psig = 15 psig or 25% of 150 psig=37.5 whichever is less (ASME V, Article 10, T-1044 and B31.1-1993, 345.8(a))</li> </ol> <p>Rev. 2: Rev'd all pages - new forms; rev'd Internal Pressure Acc. Criteria to "Withstands nominal 150 psig and 29" Hg Vacuum", GOV Seat Leakage Acc. Criteria - rev'd all, GOV Fail Safe Position rev'd Stroke Time to "Less Than 2 Seconds", Deleted CC: Insulation Resistance, Solenoid Inrush Current, Solenoid Holding Current, and Current Carrying Capability Of Contacts</p>	<p>Acceptance Method:</p> <ol style="list-style-type: none"> <li>Special Test and Inspection           <ul style="list-style-type: none"> <li>1, IN for Inspection</li> <li>1, T for Test</li> </ul> </li> <li>Commercial Grade Survey</li> <li>Source Verification</li> <li>Vendor/Item History</li> </ol>
---	---

## Section 10 Initial Review and Approval

Approvals:

Designated Engineer: Elvan K. Karpuz 5/31/00Design Authority: John 5/30/00QA Engineer: MM Rompt 6/1/00

# Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002  
Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 5 of 10

## WORKSHEET 1 DETERMINATION OF FAILURE MECHANISMS

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation X? Indicate Failure Mode	
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.		
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	<b>Structural Failure or Seizure of Valve/Disc</b>
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
<b>1. Loss of Air Pressure</b>			

# Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002  
Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 6 of 10

## Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

### SECTION 1

Item Description: 1" SCHe Solenoid Valves System #: 13	Equip #: He-GOV/SOV-1*02, 1*06, SCHe-GOV/SOV-5*12, 5*31, 5*51, 5*71 Procurement and/ or Model #: 1" E 5966RTBW4 with 15I939SWM2120PBC
Manufacturer (Address/Phone): <b>Worcester Controls</b> P.O. Box 538 33 Lock Dr. Marlborough, MA 01752 (508) 481-4800	Supplier (Address/Phone): <b>Olympic Tool &amp; Engineering</b> W. 21 Sanderson Way Shelton, WA 98584 (360)426-5231

### SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1

Insp	Test	Post-Test	
X			1. Nameplate - Manufacturer
X			2. Component Number-Procurement and/or Model Number
X			3. Actuator-Component Number-Procurement and/or Model Number (Includes SOV)
X			4. Nameplate Data of Actuator (Includes SOV)
X	X		5. Body Material (Verification may be by either inspection or test)
X			6. Configuration/Mounting
X			7. Process Connection
	X		8. GOV Pressure Boundary
	X		9. Internal Pressure
	X		10. GOV Seat Leakage
	X		11. GOV Fail Safe Position
	X		12. Seismic Condition A

### SECTION 3 BY INSPECTION \* See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)

Characteristic: Nameplate – Manufacturer	Sample Size*: 100%
Acceptance Criteria: Worcester Controls	Receipt Inspection Plan / Report #:
Characteristic: Valve Component Number-Procurement and/or Model Number	Sample Size*: 100%
Acceptance Criteria: 1" E 5966RTBW4 (Per Procurement Package W-441-P4, Rev. 3, Section H, Design Data Sheet)	
Receipt Inspection Plan / Report #:	
Characteristic: Actuator-Component Number-Procurement and/or Model No. (Includes SOV)	Sample Size*: 100%
Acceptance Criteria: 15I939SWM2120PBC (Per Procurement Package W-441-P4, Rev. 3, Section H, Design Data Sheet)	
Receipt Inspection Plan / Report #:	

# Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002  
Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 7 of 10

Characteristic Nameplate Data of Actuator (Includes SOV)		Sample Size*: <b>100%</b>
Acceptance Criteria: Per Vendor Manual. To Include "R6" (Upper Right Corner).		
Receipt Inspection Plan / Report #:		
Characteristic: <b>Process Connection</b>		Sample Size*: <b>100%</b>
Acceptance Criteria: <b>1" Butt weld</b>		Receipt Inspection Plan / Report #:
Characteristic: <b>Configuration/Mounting</b>		Sample Size*: <b>100%</b>
Acceptance Criteria: <b>Integral Actuator/Valve Assembly. Black recessed override button.</b>		
Receipt Inspection Plan / Report #:		
Characteristic: <b>Valve Body Material</b>		Sample Size*: <b>100%</b>
Acceptance Criteria: <b>Stainless Steel</b>		Receipt Inspection Plan / Report #:
Section 4 By Special Test * See Attachment H, Table H-1 of Deck Instruction for Sampling Size, References (See Section 7)		
Characteristic for Test: <b>GOV Pressure Boundary</b>		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: <b>Pressure Test at nominal 165 psig for &gt;10 minutes; Reduce pressure to 100%, perform snoop test (No Leakage-No Bubbles)</b>		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: <b>Internal Pressure</b>		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: <b>Withstands nominal 150 psig and 29" Hg Vacuum (Zero Leakage)</b>		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: <b>GOV Seat Leakage</b>		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: <b>Pressurize the upstream side of the valve seat to 165 psig (110%) and reduce to 150 psig (110%), soaking for 10 min. at 150 psig, then check for obvious leaks. Apply bubble leak solution on the valve seat to find leaks. Proceed to lower the pressure to 15 psig for the Sensitive Leak Test. Apply solution to valve seat area after minimum 15 minutes soak time at nominal 15 psig. Acc. Criteria: No Leakage-No Bubbles</b>		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: <b>GOV Fail Safe Position GOV-5*12, 5*31, 5*51, 5*71</b>		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: <b>Valve fails OPEN on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.</b>		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: <b>GOV Fail Safe Position GOV-1*02 &amp; 1*06</b>		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: <b>Valve fails CLOSED on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.</b>		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: <b>Seismic Condition A</b>		Samp Size*: <b>Destructively Test Only One Item</b>
Acceptance Criteria: <b>Maintain Critical Function Before and After Seismic Event</b>		
Actual Test Value:		Test Plan and Report #:

\*\*If Supplier/Manufacturer or Other, Refer to CGI Checklist-2 for Support Information

## Commercial Grade Item Upgrade Dedication Form

ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P4-002</u>
Title <u>Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves</u>	

SNF-3877, Rev. 2

Page 8 of 10

## Section 5 Test / Inspection Summary (Acceptance Method 1)

## 1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS , THEIR VERIFICATION METHODS, AND RESULTS

## ITEM DESCRIPTION: Gas Operated Full Port Ball Valves

Critical Characteristics		Verification Results									
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-1st ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Worcester Controls	X	1, IN								
Valve Component No.- Proc. and/or Model No.	1" E 5966RTBW4 (Per Procurement Package W-441-P4, Rev. 3, Section H, Design Data Sheet)	X	1, IN								
Actuator P/N-Comp. No.-Proc. and/or Model No. (Includes SOV)	151939SWM2120PBC (Per Procurement Package W-441-P4, Rev. 3, Section H, Design Data Sheets)	X	1, IN								
Nameplate Data of Actuator (Includes SOV)	Per Vendor Manual, to include "R6" (Upper Right Corner).	X	1, IN								
Body Material	Stainless Steel	X	1, IN								
Configuration/ Mounting	Integral Actuator/Valve Assembly. Black recessed override button.	X	1, IN								
Process Connection	1" Butt-weld	X	1, IN								

## Commercial Grade Item Upgrade Dedication Form

ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-13-P4-002</u>	Page 9 of 10
Title: <u>Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves</u>		

SNF-3877, Rev. 2

## ITEM DESCRIPTION: Gas Operated Full Port Ball Valves - Continued

Critical Characteristics		Verification Results																			
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Checklist ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date										
GOV Pressure Boundary	Pressure Test At nominal 165 psig (Zero Leakage)	X	1, T																		
Internal Pressure	Withstands nominal 150 psig and 28" Hg Vacuum (Zero Leakage)	X	1, T																		
GOV Seat Leakage	Pressurize the upstream side of the valve seat to 165 psig (110%) and reduce to 150 psig (110%), soaking for 10 min. at 150 psig, then check for obvious leaks. Apply bubble leak solution on the valve seat to find leaks. Proceed to lower the pressure to 15 psig for the Sensitive Leak Test. Apply solution to valve seat area after minimum 15 minutes soak time at nominal 15 psig. Acc. Criteria: No Leakage-No Bubbles	X	1, T																		
GOV Fail Safe Position GOV-5*12, 5*31, 5*51, 5*71	Valve fails OPEN on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.	X	1, T																		
GOV Fail Safe Position GOV-1*02 & 1*06*	Valve fails CLOSED on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.	X	1, T																		
Seismic Condition A	Maintain Critical Function Before and After Seismic Event.	X	1, T																		
2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS																					
Critical Characteristic		Disposition																			
3. Signature Indicates All Critical Characteristics Verified Satisfactory or Acceptably Dispositioned And Commercial Grade Dedication Is Satisfactory and Complete.																					
Testing Agency Approval:		Date		Design Authority:		Date															
Testing Agency QA Engineer:		Date		QA Engineer:		Date															

## Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 2

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002  
Title: **Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves**

Page 10 of 10

Section 6 Contacts / Phone Numbers		
Title	Name	Phone
Design Authority		
QA		
QC		
Cog - Engineer		
CGI Engineer	<b>Larry Price</b>	<b>372-8770</b>
Procurement Engineer		
Other		
Section 7 Supporting Documentation for This Checklist		
Initial Procurement Documents		For Critical Characteristics
<input type="checkbox"/>	Drawings:	
<input type="checkbox"/>	Manuals (specify type & number):	
<input type="checkbox"/>	Design Calculations	
<input type="checkbox"/>	Installation Instructions	
<input type="checkbox"/>	Operation Instructions	
<input type="checkbox"/>	Calibration Instructions	
<input type="checkbox"/>	Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/>	<b>Other: Vendor Specifications: Worcester PB451-22</b>	<b>All</b>
Procurement Documents		
<input type="checkbox"/>	Certificate of Conformance/Compliance	
<input type="checkbox"/>	Seismic Qualification Certificate	
<input type="checkbox"/>	Environmental Qualification Certificate	
<input type="checkbox"/>	Test Report (s):	
<input type="checkbox"/>	Inspection Report (s):	
<input type="checkbox"/>	CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/>	Valve Seat Leakage Report	
<input type="checkbox"/>	Weld Records	
<input type="checkbox"/>	Material Traceability Record	
<input type="checkbox"/>	Other:	