

S

ENGINEERING CHANGE NOTICE

1. ECN

663979

Page 1 of 2Proj.
ECN

2. ECN Category (mark one)	3. Originator's Name, Organization, MSIN, and Telephone No. A. Artzer, CVDF, X3-78, 372-2785	4. USQ Required? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5. Date 11/10/00
Supplemental Direct Revision Change ECN Temporary Standby Supersedure Cancel/Void	6. Project Title/No./Work Order No. SNF/W-441, Spent Nuclear Fuel Cold Vacuum Drying	7. Bldg./Sys./Fac. No. CVDF 142K	8. Approval Designator S ^N Q
	9. Document Numbers Changed by this ECN (includes sheet no. and rev.) SNF-3876, Rev. 3, SNF-3877, Rev. 4, SNF-3890, Rev. 2 & SNF-3934, Rev. 2	10. Related ECN No(s). N/A	11. Related PO No. N/A
12a. Modification Work [] Yes (fill out Blk. 12b) [X] No (NA Blks. 12b, 12c, 12d)	12b. Work Package No. N/A	12c. Modification Work Complete N/A Design Authority/Cog. Engineer Signature & Date	12d. Restored to Original Condition (Temp. or Standby ECN only) N/A Design Authority/Cog. Engineer Signature & Date

13a. Description of Change

13b. Design Baseline Document? Yes No

HOOD

SC

Added note that either actuator Model Number is acceptable; revised valve failure position sampling size to 100%; Revised stroke time to be a separate item in Section 4, By Special Test and Section 5.

USQ Approval: CVD-00-2311




14a. Justification (mark one)	14b. Justification Details
Criteria Change <input type="checkbox"/> Design Improvement <input type="checkbox"/> Environmental <input type="checkbox"/> Facility Deactivation <input type="checkbox"/> As-Found <input checked="" type="checkbox"/> Facilitate Const <input type="checkbox"/> Const. Error/Omission <input type="checkbox"/> Design Error/Omission <input type="checkbox"/>	<p>The CGI dedication document is being revised to rely on physical verification of valve failure position instead of relying on inspection of part number to verify valve failure position.</p> <p>The design verification method for SC/SS components is by independent review in accordance with EN-6-027-01. Documentation of this review is accomplished by the independent review approval signature provided on page 2 of this ECN.</p>

15. Distribution (include name, MSIN, and no. of copies)

See distribution sheet.

RELEASE STAMP



ENGINEERING CHANGE NOTICE						Page 2 of 2		1. ECN (use no. from pg. 1) 663979	
16. Design Verification Required [X] Yes [] No		17. Cost Impact ENGINEERING Additional [N/A] \$ Savings [N/A] \$				CONSTRUCTION Additional [N/A] \$ Savings [N/A] \$		18. Schedule Impact (days) Improvement [N/A] Delay [N/A]	
19. Change Impact Review: Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 13. Enter the affected document number in Block 20.									
SDD/DD		[]		Seismic/Stress Analysis		[]		Tank Calibration Manual []	
Functional Design Criteria		[]		Stress/Design Report		[]		Health Physics Procedure []	
Operating Specification		[]		Interface Control Drawing		[]		Spares Multiple Unit Listing []	
Criticality Specification		[]		Calibration Procedure		[]		Test Procedures/Specification []	
Conceptual Design Report		[]		Installation Procedure		[]		Component Index []	
Equipment Spec.		[]		Maintenance Procedure		[]		ASME Coded Item []	
Const. Spec.		[]		Engineering Procedure		[]		Human Factor Consideration []	
Procurement Spec.		[]		Operating Instruction		[]		Computer Software []	
Vendor Information		[]		Operating Procedure		[]		Electric Circuit Schedule []	
OM Manual		[]		Operational Safety Requirement		[]		ICRS Procedure []	
FSAR/SAR		[]		IEFD Drawing		[]		Process Control Manual/Plan []	
Safety Equipment List		[]		Cell Arrangement Drawing		[]		Process Flow Chart []	
Radiation Work Permit		[]		Essential Material Specification		[]		Purchase Requisition []	
Environmental Impact Statement		[]		Fac. Proc. Samp. Schedule		[]		Tickler File []	
Environmental Report		[]		Inspection Plan		[]		N/A [X]	
Environmental Permit		[]		Inventory Adjustment Request		[]		[]	
20. Other Affected Documents: (NOTE: Documents listed below will not be revised by this ECN.) Signatures below indicate that the signing organization has been notified of other affected documents listed below.									
Document Number/Revision N/A			Document Number/Revision			Document Number Revision			
21. Approvals									
Design Authority	C. Miska	Signature	Date	Design Agent	Signature	Date			
Cog. Eng.	N/A		<u>11/10/00</u>	PE					
Cog. Mgr.	C. Haller		<u>11/10/00</u>	QA					
QA	R. K. Ramsgate		<u>11/10/00</u>	Safety					
Safety	J. R. Brehm		<u>11/13/00</u>	Design					
Environ.	N/A		<u>11/10/00</u>	Environ.					
Other	N/A		<u>11/10/00</u>	Other					
Independent Review	MARK VANDERZANDEN		<u>11/10/00</u>	DEPARTMENT OF ENERGY					
CVDF OPS			<u>11/13/00</u>	Signature or a Control Number that tracks the Approval Signature					
ADDITIONAL									

DISTRIBUTION SHEET

Worcester 1" Solenoid- Actuated Gas-Operated SCHe System Valves

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford
P.O. Box 1000
Richland, Washington

SNF-3877
Revision 5

ECN 663979

Worcester 1" Solenoid-Actuated Gas-Operated SCHe System Valves

Project No: W-441

Division: SNF

C. R. Miska
Fluor Hanford, Inc.

Date Published
November 2000


Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford
P.O. Box 1000
Richland, Washington

Release Approval

11/13/00
Date



Release Stamp

TRADEMARK DISCLAIMER

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy.

Printed in the United States of America

Total Pages: 13

SNF- 3877, rev 5

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002
 Title: **Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves**

Page 1 of 10

Section 1 Part Information			
Item No.: N/A	Manufacturer: N/A	Supplier: N/A	
Mfg. Part/Model No.: N/A		Supplier's P/N: N/A	
Part Description: N/A			
End Use Description: N/A			
Section 2a Component Information			
Equipment No.: He-GOV/SOV-1*02, 1*06 SCHe-GOV/SOV-5*12, 5*31, 5*51, 5*71	Specification No.: SNF-5303 (W-441-P4)	Manufacturer: Worcester Controls	Past P.O. No.: N/A
Procurement and/or Model Number: 1" E 5966RTBW4 with 15I939SWM2120PBC	Equipment Supplier (if different from manufacturer): Olympic Tool & Engineering		Equip. Supplier's Part No.: N/A
Component Description: 1" Gas-operated full-port ball valves incorporate a solenoid and limit switches as integral parts of the actuator. These valves are normally open and fail safe to the open position (GOV-1*02 and 1*06 fail closed) to provide a flow path of helium gas to the MCO under helium purge and off-normal conditions when the MCO is isolated.			
Section 2b Commercial Availability of the Item			
1. Is the item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?			
<input type="checkbox"/> YES (go to #2 below) <input checked="" type="checkbox"/> NO (go to procedure step 6.3.2, proceed to dedicate Item)			
If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Interface Engineer or BTR):			
<input type="checkbox"/> YES (go to #2 below, procedure step 6.3.2, dedicate Item) <input checked="" type="checkbox"/> NO (procedure step 6.3.2, dedicate Item)			
2. List of Candidate qualified suppliers or ISO 9000 suppliers: N/A			
3. Recommended Procurement Strategy(coordinate with project CGI interface Engineer or BTR): N/A			
Section 2c CGI Determination			
CGI Determination Questions:			
#1: Is the item subject to design or specification requirements that are unique to nuclear facilities or activities?			
<input type="checkbox"/> YES (the item is not commercial grade)		<input checked="" type="checkbox"/> NO (continue)	
#2: Is the item used in applications other than nuclear facilities or activities?			
<input type="checkbox"/> NO (the item is not commercial grade)		<input checked="" type="checkbox"/> YES (continue)	
#3: Is the item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?			
<input type="checkbox"/> NO (the item is not commercial grade)		<input checked="" type="checkbox"/> YES (continue)	
<input checked="" type="checkbox"/> All three criteria have been satisfied. The item meets the definition of commercial grade.			
Section 2d Reason for Dedication			
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):			
<input checked="" type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.		
<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.		
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.		
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.		
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)		

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002
 Title: **Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves**

Page 2 of 10

Section 3 Failure Effects Evaluation												
<p>A. Part/Component Safety Function:</p> <ol style="list-style-type: none"> MCO overpressurization, Thermal Runaway, and H₂ Explosion Prevention. Remain intact and functional during any event that might threaten the valve integrity. Maintain intact pressure boundary/confinement. Maintain critical function before and after seismic event. 												
<p>B. Part/Component Functional Mode:</p> <table> <tr> <td>Safety Function #1: [<input checked="" type="checkbox"/>] Active</td> <td>[<input type="checkbox"/>] Passive</td> <td>Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function</td> </tr> <tr> <td>Safety Function #2: [<input type="checkbox"/>] Active</td> <td>[<input checked="" type="checkbox"/>] Passive</td> <td>Passive – Change of state is not required for the component to perform its safety function</td> </tr> <tr> <td>Safety Function #3: [<input type="checkbox"/>] Active</td> <td>[<input checked="" type="checkbox"/>] Passive</td> <td></td> </tr> </table>				Safety Function #1: [<input checked="" type="checkbox"/>] Active	[<input type="checkbox"/>] Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function	Safety Function #2: [<input type="checkbox"/>] Active	[<input checked="" type="checkbox"/>] Passive	Passive – Change of state is not required for the component to perform its safety function	Safety Function #3: [<input type="checkbox"/>] Active	[<input checked="" type="checkbox"/>] Passive	
Safety Function #1: [<input checked="" type="checkbox"/>] Active	[<input type="checkbox"/>] Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function										
Safety Function #2: [<input type="checkbox"/>] Active	[<input checked="" type="checkbox"/>] Passive	Passive – Change of state is not required for the component to perform its safety function										
Safety Function #3: [<input type="checkbox"/>] Active	[<input checked="" type="checkbox"/>] Passive											
<p>C. Host Component Safety Function (if applicable): N/A</p> <ol style="list-style-type: none"> 												
<p>D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):</p> <ol style="list-style-type: none"> Electrical fault in the solenoid. Valve fails open (fail-safe), fails closed for GOV-1*02 & 1*06. Loss of air pressure to the pneumatic actuator. Valve fails open (fail safe), fails closed for GOV-1*02 & 1*06. Loss of control signal to solenoid. Valve fails open (fail safe), fails closed for GOV-1*02 & 1*06. 												
Section 4 Environmental & Natural Phenomena Hazard Design												
<p>Environmental Qualification Required:</p> <p>Yes [<input type="checkbox"/>]</p> <p>No [<input checked="" type="checkbox"/>] Environmental Condition B</p> <p>HNF-PRO-97 SNF-5303</p>		<p>If yes: Environmental Qualification Requirements</p> <p>Limiting Environmental Conditions:</p> <p>Required Safety Functions:</p> <p>Qualification Period:</p> <p>If yes: NPH Design Requirements</p> <p>Performance Category: PC-3</p> <p>NPH Design Req'ts.: Seismic Condition A</p> <p>Required Safety Functions: MCO overpressurization, Thermal Runaway and H₂ Explosion Prevention. Maintain Critical Function before and after seismic event.</p>										
Section 5 Component Functional Classification												
X	Safety Class (SC)	General Service (GS)	Safety Significant (SS)									
<p>If part/component classification is different from host component/system, document basis. N/A</p>												
Sections 6 and 7 (Reserved)												
Section 8 References (for Functional Classification)												
<p>National Codes/Standards: ASME B31.3</p> <p>Safety Analysis Report (SAR): HNF- 3553, Annex B</p> <p>Drawings: H-1-82161, HNF-SD-SNF-SEL-002</p> <p>Vendor Manual/Manufacturer/Supplier Information: Worcester PB451-22</p>												

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002
 Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 3 of 10

Section 9: Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the item delivered is the item specified)				
Nameplate - Manufacturer	Worcester Controls	1, IN	X	
Valve-Component Number-Procurement and/or Model Number	1" E 5966RTBW4 (Per SNF-5303, Section H, Design Data Sheet)	1, IN	X	
Actuator-Component Number-Procurement and/or Model Number (Includes SOV)	15I939SWM2120PBC (Per SNF-5303, Section H, Design Data Sheet) (Either Model Number 15I939SWM2120PBC or 15I39SWM2120PBC is acceptable because valve failure position will be verified for 100% of items as a Critical Characteristic.)	1, IN	X	
Nameplate Data of Actuator (Includes SOV)	Per Vendor Manual. To Include "R6" (Upper Right Corner)	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the item delivered is the item specified)				
Valve Body Material	Stainless Steel (Note 4)	1, IN; 1, T	X	
Configuration/Mounting	Integral Actuator/Valve Assembly. Black recessed override button	1, IN	X	
Process Connection	1" Butt Weld	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the item will perform its intended safety function(s))				
GOV Pressure Boundary	Pressure Test At nominal 165 psig (Zero Leakage) Note 3	1, T		X
Internal Pressure	Withstands nominal 150 psig and 29" Hg Vacuum (Zero Leakage)	1, T		X
GOV Seat Leakage	Pressurize the upstream side of the valve seat to 165 psig and reduce to 150 psig, soaking for 10 min. at 150 psig, then check for obvious leaks. Apply bubble leak solution on the valve seat to find leaks. Proceed to lower the pressure to 15 psig for the Sensitive Leak Test. Apply solution to valve seat area after minimum 15 minutes soak time at nominal 15 psig. Acc. Criteria: No Leakage-No Bubbles. Note 5	1, T		X
GOV Fail Safe Position GOV-5*12, 5*31, 5*51, 5*71	Valve fails OPEN on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.	1, T		X
GOV Fail Safe Position GOV-1*02 & 1*06*	Valve fails CLOSED on loss of air pressure, control signal, or electrical power to the solenoid. Stroke time less than 2 seconds.	1, T		X
Environmental	Note 1			
Seismic Condition A	Note 2	1, T		X

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/ACGI No. CGI-SNF-D-13-P4-002Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 4 of 10

4. Notes and Legend:

1. These valves have coro-lube (nickel-acetate), acetal resin, and NEMA Enclosed Solenoids, these materials are not subject to degradation at 40°F and 60% RH or 115°F and 22% RH and are suitable for condition B Application.
2. Maintain critical function before and after seismic event. SNF-5303, Appendix L, pages L-2 & L-4, provide a seismic testing plan for these components at a SNF-4896 seismic spectra. Equipment that has been shaker-table tested should not be installed in a plant (Ref. IEEE Standard 344-1984, Section 7). Consequently, the seismic test constitutes a destructive test. The industry sampling practice for destructive test is to test only one item.
3. Pressure test at 110% of design accident condition pressure of 150 psig.
4. Material verification acceptance method may be by either inspection or test.
5. 15 psig = 15 psig or 25% of 150 psig=37.5 whichever is less (ASME V, Article 10, T-1044 and B31.1-1993, 345.8(a))

Rev. 2: Rev'd all pages - new forms; rev'd Internal Pressure Acc. Criteria to "Withstands nominal 150 psig and 29" Hg Vacuum", GOV Seat Leakage Acc. Criteria - rev'd all, GOV Fail Safe Position rev'd Stroke Time to "Less Than 2 Seconds", Deleted CC: Insulation Resistance, Solenoid Inrush Current, Solenoid Holding Current, and Current Carrying Capability Of Contacts

Rev. 3: Updated reference documentation.

Rev. 4: Rev'd GOV Seat Leakage CC from "Pressurize the upstream side of the valve seat to 165 psig (110%) and reduce to 150 psig (110%)...." to "Pressurize the upstream side of the valve seat to 165 psig and reduce to 150 psig....."

Rev. 5: Added note that either actuator Model Number is acceptable; revised valve failure position sampling size to 100%; Revised stroke time to be a separate item in Section 4, By Special Test, and Section 5, Test/Inspection Summary.

Acceptance Method:

1. Special Test and Inspection
 - 1, IN for Inspection
 - 1,T for Test
2. Commercial Grade Survey
3. Source Verification
4. Vendor/Item History

Section 10 Initial Review and Approval

Approvals:

Ana per telecom fd

Designated Engineer:

Carl Van Katwijk 11/10/00

Design Authority:

Janet Mohr 11/10/00

QA Engineer:

Jeff Pennington 11/10/00

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/A

CGI No. CGI-SNF-D-13-P4-002

Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 5 of 10

WORKSHEET 1 DETERMINATION OF FAILURE MECHANISMS

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation X? Indicate Failure Mode	
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.		
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Structural Failure or Seizure of Valve/Disc
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1. Loss of Air Pressure			

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002
 Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 6 of 10

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1			
Item Description: 1" SCHe Solenoid Valves System #: 13		Equip #: He-GOV/SOV-1*02, 1*06, SCHe-GOV/SOV-5*12, 5*31, 5*51, 5*71 Procurement and/ or Model #: 1" E 5966RTBW4 with 15I939SWM2120PBC	
Manufacturer (Address/Phone): Worcester Controls P.O. Box 538 33 Lock Dr. Marlborough, MA 01752 (508) 481-4800		Supplier (Address/Phone): Olympic Tool & Engineering W. 21 Sanderson Way Shelton, WA 98584 (360)426-5231	
SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	
X			1. Nameplate - Manufacturer
X			2. Component Number-Procurement and/or Model Number
X			3. Actuator-Component Number-Procurement and/or Model Number (Includes SOV)
X			4. Nameplate Data of Actuator (Includes SOV)
X	X		5. Body Material (Verification may be by either inspection or test)
X			6. Configuration/Mounting
X			7. Process Connection
	X		8. GOV Pressure Boundary
	X		9. Internal Pressure
	X		10. GOV Seat Leakage
	X		11. GOV Fail Safe Position
	X		12. GOV Stroke Time to Fail Safe Position
	X		13. Seismic Condition A
SECTION 3 BY INSPECTION - See Appendix D, Table D-1, of EN-6-035-01 for Sampling Size References (See Section 7)			
Characteristic: Nameplate – Manufacturer			Sample Size*: 100%
Acceptance Criteria: Worcester Controls			Receipt Inspection Plan / Report #:
Characteristic: Valve Component Number-Procurement and/or Model Number			Sample Size*: 100%
Acceptance Criteria: 1" E 5966RTBW4 (Per SNF-5303, Section H, Design Data Sheet)			
Receipt Inspection Plan / Report #:			
Characteristic: Actuator-Component Number-Procurement and/or Model No. (Includes SOV)			Sample Size*: 100%
Acceptance Criteria: 15I939SWM2120PBC (Per SNF-5303, Section H, Design Data Sheet). (Either Model Number 15I939SWM2120PBC or 15I39SWM2120PBC is acceptable because valve failure position will be verified for 100% of items as a Critical Characteristic.)			
Receipt Inspection Plan / Report #:			

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002
 Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 7 of 10

Characteristic Nameplate Data of Actuator (Includes SOV)		Sample Size*: 100%
Acceptance Criteria: Per Vendor Manual. To Include "R6" (Upper Right Corner).		
Receipt Inspection Plan / Report #:		
Characteristic: Process Connection		Sample Size*: 100%
Acceptance Criteria: 1" Butt weld		Receipt Inspection Plan / Report #:
Characteristic: Configuration/Mounting		Sample Size*: 100%
Acceptance Criteria: Integral Actuator/Valve Assembly. Black recessed override button.		
Receipt Inspection Plan / Report #:		
Characteristic: Valve Body Material		Sample Size*: 100%
Acceptance Criteria: Stainless Steel		Receipt Inspection Plan / Report #:
Section 4 By Special Test* See Appendix D, Table D-1, of EN-6-035-01 for Sampling Size, References (See Section 7)		
Characteristic for Test: GOV Pressure Boundary		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: Pressure Test at nominal 165 psig for >10 minutes; Reduce pressure to 100%, perform snoop test (No Leakage-No Bubbles)		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: Internal Pressure		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: Withstands nominal 150 psig and 29" Hg Vacuum (Zero Leakage)		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: GOV Seat Leakage		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: Pressurize the upstream side of the valve seat to 165 psig and reduce to 150 psig, soaking for 10 min. at 150 psig, then check for obvious leaks. Apply bubble leak solution on the valve seat to find leaks. Proceed to lower the pressure to 15 psig for the Sensitive Leak Test. Apply solution to valve seat area after minimum 15 minutes soak time at nominal 15 psig. Acc. Criteria: No Leakage-No Bubbles		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: GOV Fail Safe Position GOV-5*12, 5*31, 5*51, 5*71		Samp Size*: 100%
Acceptance Criteria: Valve fails OPEN on loss of air pressure, control signal, or electrical power to the solenoid.		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: GOV Fail Safe Position GOV-1*02 & 1*06		Samp Size*: 100%
Acceptance Criteria: Valve fails CLOSED on loss of air pressure, control signal, or electrical power to the solenoid. .		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: GOV Stroke Time to Fail Safe Position All GOVs		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: Stroke time less than 2 seconds.		
Actual Test Value:		Test Plan and Report #:
Characteristic for Test: Seismic Condition A		Samp Size*: Destructively Test Only One Item
Acceptance Criteria: Maintain Critical Function Before and After Seismic Event		
Actual Test Value:		Test Plan and Report #:

**If Supplier/Manufacturer or Other, Refer to CGI Checklist-2 for Support Information

Commercial Grade Item Upgrade Dedication Form

ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P4-002</u>
Title: <u>Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves</u>	

SNF-3877, Rev. 5

Page 8 of 10

Section 5: Test/ Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Gas Operated Full Port Ball Valves

Critical Characteristics		Verification Results									
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or R#	Check-Off ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Worcester Controls	X		1, IN							
Valve Component No. Proc. and/or Model No.	1" E 5966RTBW4 (Per SNF-5303, Section H, Design Data Sheet)	X		1, IN							
Actuator P/N-Comp. No.-Proc. and/or Model No. (Includes SOV)	151939SWM2120PBC (Per SNF-5303, Section H, Design Data Sheets) (Either Model Number 151939SWM2120PBC or 15139SWM2120PBC is acceptable because valve failure position will be verified for 100% of items as a Critical Characteristic.)	X		1, IN							
Nameplate Data of Actuator (Includes SOV)	Per Vendor Manual to Include "R6" (Upper Right Corner).	X		1, IN							
Body Material	Stainless Steel	X		1, IN							
Configuration/ Mounting	Integral Actuator/Valve Assembly. Black recessed override button.	X		1, IN							
Process Connection	1" Butt Weld	X		1, IN							
GOV Pressure Boundary	Pressure Test At nominal 165 psig (Zero Leakage)	X		1, T							
Internal Pressure	Withstands nominal 150 psig and 29" Hg Vacuum (Zero Leakage)	X		1, T							

Commercial Grade Item Upgrade Dedication Form

Commercial Grade Item Upgrade Dedication Form	
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-13-P4-002</u>
Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves	
SNF-3877, Rev. 5	
Page 9 of 10	

SNF-3877, Rev. 5

Page 9 of 10

CGI-SNE-D-13-P4-002

Actuated Gas-Operated SCHE System Valves

CON NO. 101

ITEM DESCRIPTION: Gas Operated Full Port Ball Valves - Continued

Critical Characteristics

3. Signature Indicates All Critical Characteristics Verified Satisfactory or Acceptably Dispositioned And Commercial Grade Dedication Is Satisfactory and Complete.

Testing Agency Approval:

5

300

Date:

Commercial Grade Item Upgrade Dedication Form

SNF-3877, Rev. 5

ECN No. N/A CGI No. CGI-SNF-D-13-P4-002
 Title: Worcester 1" Solenoid-Actuated Gas-Operated SCHE System Valves

Page 10 of 10

Section 6 Contacts / Phone Numbers

Title	Name	Phone
Design Authority		
QA		
QC		
Cog - Engineer		
CGI Engineer	Larry Price	372-8770
Procurement Engineer		
Other		

Section 7 Supporting Documentation for This Checklist

Initial Procurement Documents		For Critical Characteristics
	Drawings:	
	Manuals (specify type & number):	
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/>	Other: Vendor Specifications: Worcester PB451-22	All
Procurement Documents		
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
	Test Report (s):	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Records	
	Material Traceability Record	
	Other:	