

CARBONIZER TESTS WITH LAKELAND FEEDSTOCKS

Phase 2 Task 4 Topical Report By:

**C. Lu
Z. Fan
R. Froehlich
A. Robertson**

Issued September 2003

**U.S. Department of Energy
Contract No: DE-AC21-86MC21023**

**SECOND GENERATION
PRESSURIZED FLUIDIZED BED RESEARCH AND DEVELOPMENT**

**Foster Wheeler Development Corporation
12 Peach Tree Hill Road
Livingston, New Jersey 07039**

DISCLAIMER

"This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe upon privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

ABSTRACT

Research has been conducted under United States Department of Energy Contract (USDOE) DE-AC21-86MC21023 to develop a new type of coal-fired plant for electric power generation. This new type of plant, called a Second Generation Pressurized Fluidized Bed Combustion Plant (2nd Gen PFB), offers the promise of efficiencies greater than 48%, with both emissions and a cost of electricity that are significantly lower than those of conventional pulverized coal-fired (PC) plants with wet flue gas desulfurization/scrubbers.

The 2nd Gen PFB plant incorporates the partial gasification of coal in a carbonizer, the combustion of carbonizer char in a pressurized circulating fluidized (PCFB) bed boiler, and the combustion of carbonizer syngas in a topping combustor to achieve gas turbine inlet temperatures of 2700°F and higher.

Under the USDOE Clean Coal V Demonstration Plant Program, a nominal 260 MWe plant demonstrating 2nd Gen PFB technology has been proposed for construction at the McIntosh Power Plant of the City of Lakeland, Florida. In the September-December 1997 time period, four test runs were conducted in Foster Wheeler's 12-inch diameter carbonizer pilot plant in Livingston New Jersey to ascertain carbonizer performance characteristics with the Kentucky No 9 coal and Florida limestone proposed for use in the Lakeland plant. The tests were of a short-term nature exploring carbonizer carbon conversions, sulfur capture efficiencies and syngas alkali levels. The tests were successful; observed carbonizer performance was in agreement with predictions and no operating problems, attributed to the planned feedstocks, were encountered. The results of the four test runs are reported herein.

Table of Contents

Executive Summary	1
1. Introduction.....	3
2. Experimental/Pilot Plant Description	4
3. Results and Discussion	7
3.1 Feed Stocks	7
3.2 Sorbent Feed Size and Bed Agglomeration.....	17
3.3 Overall Performance	20
3.4 Syngas Ammonia and H ₂ S Levels	23
3.5 Bed Composition	29
3.6 Zinc Oxide Sulfur Polishing	32
3.7 Syngas Alkali Vapor Measurements.....	34
4. Candle Filter.....	51
5. Conclusions/Summary	58
6. References	60
7. Bibliography.....	60
8. Acronyms and Abbreviations	60

Lists of Graphical Materials

Figures

2.1	12-in. Carbonizer for Lakeland Tests	5
2.2	HIPPS Pilot Plant Schematic	6
3.1.1	Size Distribution of Limestone Feed Samples from Test Run TR7	15
3.1.2	Size Distribution of Coal Feed Samples from Test Run TR7	16
3.2.1	Agglomeration Experienced in Carbonizer Test Run TR4	18
3.2.2	TR6 Bed Temperatures and Cooler Flows.....	19
3.4.1	NH ₃ Formation Data from Otaniemi Test Facility.....	25
3.4.2	Test Run TR4 H ₂ S Drager Tube Readings.....	26
3.4.3	Test Run TR5 H ₂ S Drager Tube Readings.....	27
3.5.1	TR7.2 Bed Char Content via Post Run Inspection	30
3.5.2	TR7.2 Char Carbon Content via Post Run Inspection	31
3.6.1	Zinc Oxide Slurry Injection Nozzle	33
3.7.1	Syngas Equilibrium Total Alkali Vapor Estimate	35
3.7.2	Location of Carbonizer Syngas Alkali Measurements	36
3.7.3	WSTC Typical Probe Flow Arrangement	37
3.7.4	WSTC Alkali Probe Sampling Arrangement.....	37
3.7.5	WSTC Probe with Alkali Sampling Tip	38
3.7.6	Syngas Alkali Vapor Level Versus Temperature	43
3.7.7	Syngas Alkali Vapor Level Versus Temperature (Expanded Scale)	44
3.7.8	Alkali Results Extracted from [3-1].....	47
3.7.9	Predicted and Observed Alkali Data in Oxidizing PFB Flue Gas from [3-3]	50
4.1	Candle Filter Layout	52
4.2	Candle Arrangement-Plan View	53
4.3	Typical Filter Performance During Test Run TR5 (22 Candles).....	55
4.4	Typical filter Performance During Test Run TR7 (10 Candles).....	56

Tables

3.1.1	Typical Coal Analysis for Test Runs TR4 through TR7	8
3.1.2	Typical Coal Ash Analysis for Test Runs TR4 through TR7	9
3.1.3	Typical Coke Analysis for Test Point TR7.1	10
3.1.4	Typical Coke Ash Analysis for Test Point TR7.1	11
3.1.5	Typical Limestone Analysis for Test Runs TR4 and TR5	12
3.1.6	Typical Limestone Analysis for Test Runs TR6 and TR7	13
3.1.7	Typical Limestone Size Distribution for Test Runs TR4 and TR5	14
3.3.1	Lakeland Carbonizer Test Results	21
3.3.2	Carbonizer Syngas Composition.....	22
3.3.3	Carbon Content of Carbonizer Streams	22
3.4.1	Syngas Ammonia Analyses of GC Data	23
3.4.2	Typical NH ₃ and HCN Contents of the Product Gas w/Different Feedstocks	24
3.4.3	Carbonizer Sulfur Capture Efficiency.....	28
3.7.1	Alkali Sampling Summary for Lakeland Test TR4 through TR7 (Sept. – Dec. 1997) ..	41
3.7.2	Alkali Sample Chemical Analysis Summary for Lakeland Test TR4 through TR7 (Sept. – Dec. 1997).....	42
3.7.3	Gasifier and Feedstock Data Extracted from [3-1]	46
3.7.4	Wakamatsu Fuel and Test Conditions from [3-3].....	48
3.7.5	Wakamatsu Oxidizing PFB Flue Gas and Alkali Results from [3-3].....	49
4.1	Candle Filter Performance	54

Executive Summary

The Kentucky No 9 coal and Florida limestone proposed for use in the Lakeland Clean Coal V Second Generation Pressurized Fluidized Bed (2nd Gen PFB) Demonstration Plant were tested in Foster Wheeler's carbonizer pilot plant in the September-December 1997 time period. Four relatively short-term test runs were conducted and the feedstocks caused no operating problems in the carbonizer or its ceramic candle filter. In the first two runs a fine limestone feed size (d₅₀ ≈ 150 micron) was used, whereas in the second two runs a coarser minus 1/8 in. feed was employed. Since the carbonizer was operated on a once-through basis (no recycle of elutriated fines back to the bed), most of the fine sorbent elutriated and left behind a predominantly char bed. With less sorbent in the bed, the fine feed sulfur capture efficiency was less than that of the coarse feed (about 93½ versus 95%); and the coarse feed size 1/8" x 300 micron is recommended for the Lakeland demonstration plant carbonizer.

Agglomeration was experienced in the carbonizer during the tests and an examination of operating data traced the cause to inadequate fluidization around the feed pipe. By raising the velocity to 2 ft/sec in the drain annulus that surrounds the feed pipe, agglomeration was eliminated.

The carbon conversions and gas yields observed in the tests were in accordance with the performance predicted by Foster Wheeler's proprietary carbonizer computer model. A portion of the coal nitrogen that is released in the carbonizer is converted to ammonia. Previous testing has shown this conversion to be a function of the feedstocks and operating conditions. Ammonia conversion with the Lakeland coal and limestone ranged from 6.7 to 22.5% of the coal nitrogen released in the carbonizer.

Tests were also conducted to determine what increases in sulfur capture efficiency could be achieved by injecting zinc oxide (ZnO), a sulfur capturing/polishing agent, into the carbonizer syngas upstream of the candle filter. The ZnO was injected as a 5 to 15% by weight water slurry into the gas stream at the top of the carbonizer while the unit operated with the Lakeland 1.4% sulfur coal and Florida limestone. The tests showed that large amounts of water injection can cause sulfur, already captured as calcium sulfide, to be released to the syngas from entrained particulate matter and the candle filter ash cake. By using the 15% by weight slurry it was possible to increase the carbonizer sulfur capture efficiency from 93.7% to over 98%. Although this was achieved at a Zn to syngas sulfur molar feed ratio of 6.5, lower feed ratios would be required if the injection were done with more dense slurries or by using a dry injection system.

Gas turbine limits on vapor phase alkali levels are in the parts per billion range; because their levels are low and gas temperatures and pressures are high, measurement of alkali vapor levels is difficult to make. Using an extractive probe that was designed and supplied by the Westinghouse Science and Technology Center (WSTC) together with their laboratory handling/analyses procedures, alkali measurements were conducted by Foster Wheeler in the Livingston carbonizer pilot plant. The measurements were made downstream of the ceramic candle filter with the carbonizer operating at proposed Lakeland conditions. The vapor phase alkali levels measured with the WSTC probe decreased, as expected, with decreasing gas

temperature. Even though the alkali levels were very low, the temperature trend exhibited minimal scatter and the data indicates carbonizer syngas alkali levels should be less than 20 ppbw at 1200°F, a value that should be acceptable to a gas turbine. The ceramic candle filter operated at about 1300E F. During the first two runs, the filter operated without a pre-cleaning cyclone and, to accommodate the higher solids loading, a 1.9 ft/min candle face velocity was used (22 candles were installed in the filter). In the second run, a pre-cleaning cyclone was installed, and the face velocity was increased to about 4 ft/min by reducing the number of candles to 10. In all four runs the filter performed successfully showing no signs of blinding, bridging, or ash hopper agglomeration.

Although the carbonizer tests were of a relatively short duration, the feedstocks planned for the Lakeland plant caused no operating problems and their carbon conversions, syngas yields and heating values, and sulfur capture efficiencies agreed with the performance predicted by Foster Wheeler's proprietary carbonizer computer model.

1.0 Introduction

Under the U.S. Department of Energy Clean Coal V Demonstration Plant Program, a nominal 260 MWe plant demonstrating 2nd Gen PFB technology has been proposed for construction at the McIntosh Power Plant of the City of Lakeland, Florida. In this new type of plant coal is partially gasified in a jetting/bubbling fluidized bed reactor called the carbonizer. The carbonizer produces a syngas that fuels a gas turbine and a char residue that fuels a pressurized circulating fluidized bed (PCFB) boiler which in turn powers a steam turbine. The PCFB boiler operates with relatively high excess air and the unused oxygen in its flue gas supports the combustion of the carbonizer syngas in a gas turbine topping combustor. Before these gases reach the topping combustor they are stripped of entrained particulate by barrier type candle filters.

The carbonizer, PCFB boiler, and candle filters are the new technologies of the 2nd Gen PFB plant and, although each has been successfully tested at the pilot plant scale, operations to date have been limited to a few specific fuels. The coal and limestone sorbent proposed for use in the Lakeland plant are new untested feedstocks. In the September-December 1997 time period, four test runs were conducted in Foster Wheeler's 12-inch diameter carbonizer pilot plant carbonizer in Livingston, New Jersey, with the Kentucky No 9 coal and Florida limestone proposed for the Lakeland plant. The tests were of a short-term nature and were conducted to:

1. determine if the feedstocks caused any operating problems in the carbonizer or candle filter;
2. confirm that the feedstocks performed (carbon conversion, syngas yields and heating values, sulfur capture efficiency, etc.) as predicted by Foster Wheeler's proprietary carbonizer computer models.
3. determine if the carbonizer would operate successfully with the fine limestone feed ($d_{50} \approx 150$ micron) proposed for the Lakeland PCFB boiler (essentially all previous carbonizer testing had been conducted with a 1/8" x 0 feed with $d_{50} \approx 600$ micron).
4. investigate the feasibility of injecting zinc oxide (ZnO) into the carbonizer syngas upstream of the candle filter to increase the carbonizer sulfur capture efficiency over and above that provided by in-bed limestone injection.
5. measure syngas alkali vapor levels exiting the candle filter

2.0 Experimental/Pilot Plant Description

The Lakeland tests were conducted in the refractory lined, 12-inch diameter carbonizer/pyrolyzer and pilot plant shown in Figures 2.1 and 2.2. Coal, limestone, and air entered as a vertical central jet at the base of the unit. The unit typically operated with about a 26-foot deep bed with syngas exiting from a 4-inch ID top radial nozzle. The char-sorbent residue generated in the process drained from the bottom through a 1-7/8 inch wide annulus that surrounded the feed pipe. A packed bed cooling section below the annulus cooled the residue with counter-flowing nitrogen. Thereafter the residue was withdrawn in batches through a 4-inch pipeline to a lock hopper that was used to depressure the material. A bed overflow nozzle provided at the top of the bed was not used during these tests.

The syngas exited from the top of the carbonizer, passed through a WSTC ceramic candle filter that essentially removed all gas entrained particulate, an orifice plate that depressured the gas to ambient, a dry quench water spray tower that cooled the syngas to approximately 350EF, a demister that removed any gas entrained water droplets, a baghouse filter, and a natural gas fired incinerator that burned the syngas and exhausted to the atmosphere. During the first two runs there was no precleaning cyclone between the carbonizer and the ceramic candle filter, and the latter operated with 22 candles yielding a syngas candle face velocity of about 1.9 feet per minute (fpm). In the last two runs a precleaning cyclone was added, and the particulate collected by the cyclone drained through a nitrogen aerated loop seal to the surge hopper beneath the filter. With the particulate loading to the filter reduced, the number of candles was reduced to 10, which raised the candle face velocity to about 4 feet per minute. Within the filter the entrained particulate collected on the outside of the ceramic candles and the accumulation, called the filter cake, was removed/blown off the candles by intermittent pulses of nitrogen back flowing through the unit.

Blown free of the candles, the filter cake fell to the bottom and drained to a surge hopper provided directly below the filter vessel. Steam cooled tube coils provided in the surge hopper cooled the draining material. A lock hopper under the surge hopper was used to depressure the material and facilitate their pneumatic transport by nitrogen to a second baghouse; the drains from both baghouses were collected in drums and weighed before removal to storage.

Coal and limestone were pneumatically transported to and injected into the carbonizer as a blend via a lock hopper feed system. The air-to-coal feed ratio is the primary determinant of the carbonizer operating temperature and, since the pilot plant utilizes an orifice plate to depressure the syngas, their total flow rate/throughput determines the carbonizer operating pressure.




Figure 2.1 12-in. Carbonizer for Lakeland Tests




Figure 2.2 HIPPS Pilot Plant Schematic

3.0 Results and Discussion

3.1 Feedstocks

A total of four carbonizer test runs (TR4 through TR7) were performed during the September-December 1997 time period. Tables 3.1.1 through 3.1.7 and Figures 3.1.1 and 3.1.2 present typical analyses and particle size distributions of the feedstocks used in the tests. The limestone used during the runs came from two different shipments from the same supplier, Florida Crushed Stone Co. Noting that the second shipment had a significantly higher silica content than the first, a typical analysis has been presented for each shipment. With regard to the Kentucky No 9 coal, it had a 1.4% sulfur content and, depending upon the sample analyzed, the Free Swelling Index varied from a low of 2.0 to a high of 4.5.

Table 3.1.1 Typical Coal Analysis for Test Runs TR4 through TR7

**FOSTER WHEELER DEVELOPMENT CORPORATION
FUEL ANALYSIS**

Sample Description: Coal,HIPPS/LAKELAND, TR04, CF07					
Charge No. : 941190406		Date: 10/28/97		Lab. Ref. No.: 971516	
Air Dry Loss (%) 0.00			Equilibrium Moisture (%)		
	As Received	Dry			
Proximate Analysis, wt%			Reactivity Index (°C)		
Fixed Carbon	55.41	56.08	Activation Energy (cal/g-mol)		
Volatile Matter	31.38	31.76	Hardgrove Index		
Ash	12.02	12.16	Free Swelling Index		2.5
Moisture	1.19	---	Specific Gravity		
Total	100.00	100.00	Viscosity		
Ultimate Analysis, wt%			Ash Fusion Temperature, °F		
Carbon	74.68	75.58		Red.	Oxid.
Hydrogen	4.65	4.70	Initial Deform.	2602	2610
Oxygen	4.58	4.64	Soft. Temp. Sph.	2672	2747
Nitrogen	1.45	1.47	Soft. Temp. Hem.	2721	2781
Sulfur	1.43	1.45	Fluid Temp.	2792	2810+
Ash	12.02	12.16			
Moisture	1.19	---			
Total	100.00	100.00			
			Bulk Density (gr/ml)		0.88
HHV, Btu/lb	0.	0.	Carbonate Carbon		
Sulfate S	0.00	0.00	Organic Carbon		
Pyritic S	.56	.57	Total Carbon		
Organic S	.87	.88	Chloride		0.19
Dulong's =		13607	Btu/lb		
Remarks:					

Analyst: _____

Approved: BREEL P LANTO

Table 3.1.2 Typical Coal Ash Analysis for Test Runs TR4 through TR7

**FOSTER WHEELER DEVELOPMENT CORPORATION
ASH/DEPOSIT ANALYSIS**

Sample Description: Coal,HIPPS/LAKELAND, TR04, CF07

Charge No. : 941190406

Date: 12-19-1997 Lab. Ref. No. : 971516

Analyte	As Element	Factor		As Oxide	Analyt. Method
Silicon	Si	2.140	Silicon Dioxide	50.8	X-RAY
Aluminum	Al	1.890	Aluminum Oxide	29.8	X-RAY
Titanium	Ti	1.668	Titanium Dioxide	1.6	X-RAY
Iron	Fe	1.430	Ferric Oxide	10.1	X-RAY
Calcium	Ca	1.399	Calcium Oxide	1.9	X-RAY
Magnesium	Mg	1.658	Magnesium Oxide	1.0	X-RAY
Sodium	Na	1.348	Sodium Oxide	< 0.1	X-RAY
Potassium	K	1.205	Potassium Oxide	2.6	X-RAY
Sulfur	S	2.500	Sulfur Trioxide	1.1	X-RAY
Phosphorus	P	2.291	Phos. Pentoxide	0.2	X-RAY
Nickel	Ni	1.273	Nickel(ic) oxide		
Vanadium	V	1.785	Vand. Pentoxide		
Manganese	Mn	1.583	Mangan. Dioxide		
Chromium	Cr	1.461	Chromic Oxide		
Molybdenum	Mo	1.500	Moly. Trioxide		
Zinc	Zn	1.245	Zinc Oxide		
Lead	Pb	1.077	Lead Oxide		
Tin	Sn	1.270	Stannic Oxide		
Copper	Cu	1.252	Cupric Oxide		
Silver	Ag	1.074	Silver Oxide		
Antimony	Sb	1.197	Antimony Trioxide		
Chlorine	Cl	1.000	Chloride		

Remarks: Total Percentage 99.1

Analyst: _____

Approved: BRIEL P. LANTIC

Table 3.1.3 Typical Coke Analysis for Test Point TR7.1

**FOSTER WHEELER DEVELOPMENT CORPORATION
FUEL ANALYSIS**

Sample Description: HIPPS/LAKELAND, COKE, TR04, CS01, Sack#3					
Charge No. : 940353903		Date: 12/12/98		Lab. Ref. No.: 981173	
Air Dry Loss (%)		0.00	Equilibrium Moisture (%)		
	As				
	Received	Dry			
Proximate Analysis, wt%			Reactivity Index (°C)		
Fixed Carbon	86.18	86.38	Activation Energy (cal/g-mol)		
Volatile Matter	10.82	10.84	Hardgrove Index		
Ash	2.77	2.78	Free Swelling Index		
Moisture	.23	---	Specific Gravity		
Total	100.00	100.00	Viscosity		
Ultimate Analysis, wt%			Ash Fusion Temperature, °F		
Carbon	88.14	88.34		Red.	Oxid.
Hydrogen	4.02	4.03	Initial Deform.		
Oxygen	-.60	-.60	Soft. Temp. Sph.		
Nitrogen	1.51	1.51	Soft. Temp. Hem.		
Sulfur	3.93	3.94	Fluid Temp.		
Ash	2.77	2.78			
Moisture	.23	---			
Total	100.00	100.00			
			Bulk Density (gr/ml)		
HHV, Btu/lb	0.	0.	Carbonate Carbon		
Sulfate S	0.00	0.00	Organic Carbon		
Sulfide S	.02	.02	Total Carbon		
Organic S	3.91	3.92	Chloride		
Dulong's =	15554	Btu/lb			
Remarks:					

Analyst: _____

Approved: BOB P. LANTIC

Table 3.1.4 Typical Coke Ash Analysis for Test Point TR7.1

**FOSTER WHEELER DEVELOPMENT CORPORATION
ASH/DEPOSIT ANALYSIS**

Sample Description: HIPPS/LAKELAND, COKE, TR07, CS01, Sack#3

Charge No. : 940353903

Date: 11-24-1998 Lab. Ref. No. : 981173

Analyte	As Element	Factor		As Oxide	Analyt. Method
Silicon	Si	2.140	Silicon Dioxide	37.5	X-RAY
Aluminum	Al	1.890	Aluminum Oxide	13.5	X-RAY
Titanium	Ti	1.668	Titanium Dioxide	0.9	X-RAY
Iron	Fe	1.430	Ferric Oxide	12.3	X-RAY
Calcium	Ca	1.399	Calcium Oxide	10.5	X-RAY
Magnesium	Mg	1.658	Magnesium Oxide	1.5	X-RAY
Sodium	Na	1.348	Sodium Oxide	1.0	X-RAY
Potassium	K	1.205	Potassium Oxide	2.2	X-RAY
Sulfur	S	2.500	Sulfur Trioxide	12.7	X-RAY
Phosphorus	P	2.291	Phos. Pentoxide	0.2	X-RAY
Nickel	Ni	1.273	Nickel(ic) oxide	1.7	SEMIQUANT
Vanadium	V	1.785	Vand. Pentoxide	4.7	SEMIQUANT
Manganese	Mn	1.583	Mangan. Dioxide		
Chromium	Cr	1.461	Chromic Oxide		
Molybdenum	Mo	1.500	Moly. Trioxide		
Zinc	Zn	1.245	Zinc Oxide	0.1	SEMIQUANT
Lead	Pb	1.077	Lead Oxide		
Tin	Sn	1.270	Stannic Oxide		
Copper	Cu	1.252	Cupric Oxide		
Silver	Ag	1.074	Silver Oxide		
Antimony	Sb	1.197	Antimony Trioxide		
Chlorine	Cl	1.000	Chloride		

Remarks:

Total Percentage

98.8

Analyst: _____

Approved: _____

BRE P LANTC

Table 3.1.5 Typical Limestone Analysis for Test Runs TR4 and TR5

**FOSTER WHEELER DEVELOPMENT CORPORATION
ASH/DEPOSIT ANALYSIS**

Sample Description: Limestone, HIPPS/LAKELAND, TR04, OF-06

Charge No. : 941190406

Date: 12-19-1997 Lab. Ref. No. : 971520

Analyte	As Element	Factor		As Oxide	Analyt. Method
Silicon	Si	2.140	Silicon Dioxide	9.3	X-RAY
Aluminum	Al	1.890	Aluminum Oxide	0.8	X-RAY
Titanium	Ti	1.668	Titanium Dioxide	NIL	X-RAY
Iron	Fe	1.430	Ferric Oxide	0.4	X-RAY
Calcium	Ca	1.399	Calcium Oxide	88.0	X-RAY
Magnesium	Mg	1.658	Magnesium Oxide	0.5	X-RAY
Sodium	Na	1.348	Sodium Oxide	< 0.1	X-RAY
Potassium	K	1.205	Potassium Oxide	0.1	X-RAY
Sulfur	S	2.500	Sulfur Trioxide	0.4	X-RAY
Phosphorus	P	2.291	Phos. Pentoxide	0.1	X-RAY
Nickel	Ni	1.273	Nickel(ic) oxide		
Vanadium	V	1.785	Vand. Pentoxide		
Manganese	Mn	1.583	Mangan. Dioxide		
Chromium	Cr	1.461	Chromic Oxide		
Molybdenum	Mo	1.500	Moly. Trioxide		
Zinc	Zn	1.245	Zinc Oxide		
Lead	Pb	1.077	Lead Oxide		
Tin	Sn	1.270	Stannic Oxide		
Copper	Cu	1.252	Cupric Oxide		
Silver	Ag	1.074	Silver Oxide		
Antimony	Sb	1.197	Antimony Trioxide		
Chlorine	Cl	1.000	Chloride		

Remarks:

Total Percentage

99.6

LOI=43.16%

Analyst: _____

Approved: _____

BREEL P. LANTO

Table 3.1.6 Typical Limestone Analysis for Test Runs TR6 and TR7

**FOSTER WHEELER DEVELOPMENT CORPORATION
ASH/DEPOSIT ANALYSIS**

Sample Description: HIPPS/LLAKELAND, Limestone, TRO7-SF01

Charge No. : 940353905

Date: 01-23-1998 Lab. Ref. No. : 971861

Analyte	As Element	Factor	As Oxide	As Oxide	Analyt. Method
Silicon	Si	2.140	Silicon Dioxide	19.5	X-RAY
Aluminum	Al	1.890	Aluminum Oxide	4.8	X-RAY
Titanium	Ti	1.668	Titanium Dioxide	0.2	X-RAY
Iron	Fe	1.430	Ferric Oxide	1.9	X-RAY
Calcium	Ca	1.399	Calcium Oxide	69.4	X-RAY
Magnesium	Mg	1.658	Magnesium Oxide	0.9	X-RAY
Sodium	Na	1.348	Sodium Oxide	< 0.1	X-RAY
Potassium	K	1.205	Potassium Oxide	1.0	X-RAY
Sulfur	S	2.500	Sulfur Trioxide	0.3	X-RAY
Phosphorus	P	2.291	Phos. Pentoxide	0.1	X-RAY
Nickel	Ni	1.273	Nickel(ic) oxide		
Vanadium	V	1.785	Vand. Pentoxide		
Manganese	Mn	1.583	Mangan. Dioxide		
Chromium	Cr	1.461	Chromic Oxide		
Molybdenum	Mo	1.500	Moly. Trioxide		
Zinc	Zn	1.245	Zinc Oxide		
Lead	Pb	1.077	Lead Oxide		
Tin	Sn	1.270	Stannic Oxide		
Copper	Cu	1.252	Cupric Oxide		
Silver	Ag	1.074	Silver Oxide		
Antimony	Sb	1.197	Antimony Trioxide		
Chlorine	Cl	1.000	Chloride		

Remarks: Total Percentage 98.1

LOI=36.52%


Analyst: _____

Approved: 

Table 3.1.7 Typical Limestone Size Distribution for Test Runs TR4 and TR5

Sieve Analysis

Laboratory No.: 971520		Run/Sample No: <i>CF</i>	
Sample Description: Limestone, HIPPS/LAKELAND, TR04, <i>CF-06</i>			
Screen	Microns	% On	% Thru
3"	76200		
2-1/2"	63500		
2"	50800		
1-1/2"	38100		
1-1/4"	31750		
1"	25400		
3/4"	19050		
1/2"	12700		
3/8"	9525		
5/16"	8000		
1/4"	6300		
NO. 4	4750		
NO. 6	3350		100.00
NO. 8	2360	.02	99.98
NO. 12	1700	.03	99.95
NO. 14	1400	.02	99.93
NO. 16	1180	.04	99.89
NO. 18	1000	.04	99.85
NO. 20	850	.09	99.76
NO. 25	710	.1	99.66
NO. 30	600	.13	99.53
NO. 50	300	21.58	77.95
NO. 100	150	33.34	44.61
NO. 140	106	17.04	27.57
NO. 200	75		
NO. 325	45		
PAN	00	27.57	0






Figure 3.1.1 Size Distribution of Limestone Feed Samples from Test Run TR7




Figure 3.1.2 Size Distribution of Coal Feed Samples from Test Run TR7

3.2 Sorbent Feed Size and Bed Agglomeration

In the first two test runs (TR4 and 5) the Florida limestone was crushed to the fine size distribution ($d_{50} \approx 150\mu$) planned for the Lakeland PCFB boiler, the attempt being made to use the same feed size in both the carbonizer and PCFB to minimize feedstock preparation costs. With the carbonizer being a bubbling bed unit, essentially all previous testing had been conducted with a 1/8" x 0 limestone feed size ($d_{50} \approx 600\mu$). In addition, the carbonizer had been operated on a simple, once through basis (particulate elutriated from the bed and captured by a downstream cyclone were not recycled back to the bed). As expected, when the fine feed size was used, most of the sorbent elutriated from the bed and left behind a predominantly char bed. With the bed limestone content reduced, a sulfur capture efficiency of only 93.5% was achieved with the 1.4% sulfur Kentucky No 9 coal. Analysis of the minus 300 micron limestone that had been elutriated from the bed revealed little sulfur content. With this size fraction contributing little to the carbonizer sulfur capture efficiency (SCE), a 1/8" x 300 micron feed was tested next by screening out the minus 300 μ material (in the Lakeland plant the minus 300 micron limestone would be saved for use in the PCFB SO₂ trim system). In the two test runs conducted with the fine sorbent (TR4 and 5) and the first run with the coarse sorbent (TR6), agglomeration was experienced at the bottom of the bed (see Figure 3.2.1). Initially it was thought the low sorbent content of the bed caused by fine sorbent feed was allowing agglomerates to form. Then when agglomeration was experienced with coarse sorbent feed which yielded a sorbent bed, operating conditions were reviewed to seek a cause for the agglomeration.

TI-3021A, located 15-1/2 inches above the top of the carbonizer feed pipe, is the lowest thermocouple in the bed and TI-3016, 12.5 feet above the feed pipe, is the reference bed temperature. Figure 3.2.1 plots these temperatures versus time along with the nitrogen flow (FI-3028) to the drain cooler and the velocity (V) of this nitrogen as it passes through the drain annulus for Test Run TR 6. It is observed that about one hour after the packed bed nitrogen flow is reduced, TI-3021A begins to depart from TI-3016 and about one hour later a temperature excursion/upset occurs. A review of Test Runs TR 4 and 5 revealed a similar relationship, e.g., a reduction in nitrogen flow/velocity is soon followed by excursions in TI-3021A and a bed upset.

Suspecting a lack of fluidization to be the cause of the agglomeration, it was decided to keep the fluidizing velocity in the drain annulus surrounding the feed pipe at a value of 2 ft/sec regardless of whether or not cooling flow was needed. Using this higher velocity, TR7 was conducted without experiencing any agglomeration problems and the unit operated successfully until a high baghouse back pressure forced the termination of the run. The first setpoint completed (TR7.1) was performed with 4.1% sulfur coke at a sorbent-to-coal mass feed ratio of 0.22 lbs per lb of coal; this yielded a calcium-to-sulfur molar feed ratio of 1.4. When the fuel was switched to 1.4% sulfur Kentucky No 9 coal, the 0.20 lbs of limestone per lb of coal feed rate yielded a 3.4 molar feed ratio. Although we had intended to systematically reduce the sorbent-to-coal mass feed ratio to see what minimum level, if any, would cause agglomeration with the 2 ft/sec annulus velocity and Kentucky No 9 coal, the forced shutdown of the plant prevented us from doing so. In Test Run TR5 the carbonizer operated for 30 hours with fine sorbent and Kentucky No 9 coal before the packed bed nitrogen flow was reduced and agglomeration problems developed. Based on this, it is surmised that the coarse sorbent would yield agglomeration-free operation at a sorbent-to-coal mass feed ratio as low as 0.07, the value used in TR5.




Figure 3.2.1 Agglomeration Experienced in Carbonizer Test Run TR4




Figure 3.2.2 TR6 Bed Temperatures and Cooler Flows

3.3 Overall Performance

Table 3.3.1 summarizes the pilot plant operating conditions and test results. Carbonizer test pressures, temperatures, and bed heights ranged from 90 to 165 psig, 1718 to 1808EF, and 23.5 to 27.7 feet respectively. The syngas produced by the carbonizer was sampled at the outlet of the demister after the gas had been depressured and water spray quenched to approximately 350EF. With the syngas being slightly pressurized at this point, two 3 liter Kevlar bags were easily filled with the gas for analysis in a gas chromatograph (GC) usually within 24 hours of collection. After collection hydrochloric acid (HCl) was injected into one bag to convert the ammonia (NH_3) in the fuel gas to ammonium chloride (NH_4Cl) while awaiting analysis. Similarly, sodium hydroxide was injected into the other bag to convert hydrogen sulfide (H_2S) to sodium sulfide or sodium hydrosulfide ($\text{Na}_2\text{S}/\text{NaHS}$). During each set point the syngas was sampled at least 5 times yielding 10 bags for analysis. In addition, multiple hydrogen sulfide (H_2S) and ammonia (NH_3) Drager tube measurements (DT) were made during each set point at the sampling location as a check that equilibrium/steady state conditions had been achieved before the start of and throughout the set point plus allowing a check of the GC measurement; both the GC and Drager tubes were found to be in close agreement. Table 3.3.2 presents the GC analysis on a moisture free basis and includes all nitrogen purges, i.e., bed drain cooler, pressure taps, water spray atomization, etc.

Because of all the nitrogen flows, calculated gas heating values are low and coal syngas values rise to 104 to 118 Btu/SCF on a purge nitrogen free basis (only air nitrogen included); correcting for the pilot plant high heat loss, they rise to typical, predicted commercial plant values of 126 to 138 Btu/SCF. Corresponding petroleum coke values are less because of the coke's lower volatile content (10.8 vs. 31.4%). The carbonizer syngas and the char sorbent residue were separately analyzed to determine the amount of fuel carbon that had been consumed (carbon conversion) in each of the runs, an effort that requires subtraction of sorbent carbon from the total carbon content. The residue streams are identified in Table 3.3.3 as drains from the bottom of the bed (bot) and combined drains, where applicable, from the cyclone and filter as overheads (ovhd).

Since the elutriated fine material/overheads are not reinjected back into the bed, their shorter in-bed residence time results in carbon conversion levels (fc) that are much lower than that of the bed bottom drains (note that overheads carbon-to-ash ratios are also higher and closer to that of the fuel fed - C/Ash (fed)). The carbon conversion of the combined overhead and bottom streams are reported as fc (solid). Despite numerous analyses, we have always observed that the carbon conversion calculated from an analysis of the solids residue is higher than that calculated from a syngas analysis. The disparity decreases with increasing temperature, and we suspect that higher hydrocarbons are being missed in the gas bomb gas chromatograph process. Consistent with this previous experience, Table 3.3.3 syngas analyses yield lower carbon conversion levels than solid residue analyses and for conservatism we continue to report and base our predictive correlations on the lower/former as varying from 32.5 to 41.4%.

Table 3.3.1 Lakeland Carbonizer Test Results

Test Run	4		5	6	7	
Set Point	4.1	4.2	5.1	6.1	7.1	7.2
Sorbent Size	fine	fine	fine	coarse	coarse	coarse
Bed Temperature, °F*	1761	1808	1756	1695	1752	1718
Freeboard Pressure, psig	90	105	122	146	160	165
Bed Height, ft	27.3	27.4	27.7	27.5	23.5	26.0
Ky No 9 Coal Flow Rate, lb/h	289	289	380	373	281 ⁺	304
Air Flow Rate, lb/h	582	672	733	713	791	754
Limestone Flow Rate, lb/h	20	23	29	64	63	60
Ca/S Molar Feed Ratio	1.50	1.70	1.58	3.57	1.38	3.36
Set Point Duration, hrs.	10	19	39	6	3	6
Syngas Flow Rate**, lb/h	965	1082	1213	1460	1641	1597
Syngas HHV ^A , Btu/SCF	138	126	133	133	111	132
Carbon Conversion ^G , %	36.2	40.8	32.9	32.5	35.6	41.4
Fuel Sulfur Released, %	58.4	74.0	65.0	58.5	79.5	79.0
Sulfur Capture Eff., %	93.7	93.6	93.6	94.5	98.7	95.1
Fuel Nitrogen Released, %	53.6	51.2	55.1	54.6	33.3	57.0
Rel'd Nitrogen to NH ₃ , %	8.0	7.2	6.7	16.7	17.7	22.5
Nitrogen flow, lb/h	303	310	392	371	528	519
Bed Drain, lb/h	15	15	21	36	211	103
Overhead Drain, lb/h	149	149	182	183	77	101

*at 12.5 ft height

⁺pet coke

^AN₂ and heat loss free

^Ggas analysis

**includes all N₂ flows and water spray

Table 3.3.2 Carbonizer Syngas Composition*

Test Run	TR4		TR5	TR6	TR7	
Set Point	TR4.1	TR4.2	TR5.1	TR6.1	TR7.1	TR7.2
H ₂ , %v	7.49	7.34	7.18	5.43	4.69	5.50
CO, %v	9.06	10.89	8.81	7.77	6.43	7.39
CH ₄ , %v	1.82	1.05	2.05	1.78	0.27	1.29
C [*] 2, %v	0.02	0.00	0.01	0.01	0.00	0.00
CO ₂ , %v	5.78	5.35	6.09	5.67	5.50	4.99
N ₂ , %v	76.28	75.81	76.22	79.48	83.14	79.42
Ar, %v	0.48	0.51	0.51	0.46	0.42	0.42
gasC/Ar	34.79	33.90	33.27	33.13	29.05	32.55
HHV, Btu/SCF	76	73	76	64	41	57
HHV (N ₂ free), Btu/SCF	118	109	114	108	78	104
HHV (commercial), Btu/SCF	138	126	133	133	111	132

* moisture free basis but including all cooling, purge, and atomizing nitrogen flows.

Table 3.3.3 Carbon Content of Carbonizer Streams

Test Run	TR4		TR5	TR6	TR7	
Set Point	TR4.1	TR4.2	TR5.1	TR6.1	TR7.1	TR7.2
C Fuel, %	74.87	74.87	75.58	75.49	88.90	75.49
C/Ash (fed), %	6.47	6.47	7.08	7.21	80.09	7.21
C/Ash (ovhd), %	4.23	3.28	4.71	4.44	56.97	4.86
C/Ash (bot), %	2.17	NA	2.13	1.64	12.29	2.40
gas C/Ar, %	34.79	33.90	33.27	33.13	29.05	32.55
fuel C/Ar, %	96.00	83.14	101.06	101.85	81.54	78.57
fc, % (gas)*	36.24	40.77	32.92	32.53	35.63	41.43
fc, % (ovhd)	34.51	49.28	33.57	38.42	28.87	32.56
fc, % (bot)	66.46	NA	69.94	77.25	84.65	66.69
fc, % (solid)	37.43	NA	37.39	42.49	69.88	50.33
*Carbonate C included						

3.4 Syngas Ammonia and H₂S Levels

Syngas NH₃ and H₂S Drager tube measurements were, for the most part, in close agreement with the GC results. Analysis of the syngas GC data and residue compositions (see Table 3.4.1) indicate that the Lakeland coal nitrogen (N) release rates ranged from 51.2 to 57.0% and that 6.7 to 22.5% of the released nitrogen was converted to ammonia. The conversion of released nitrogen to ammonia varies with the feedstock and decreases with increasing temperature. Despite this, we (as well as other investigators) have been unable to develop a correlation for predicting this conversion. In previous tests, our conversions have in some instances approached 100% with an overall average of about 60%; this range in conversion is similar to data collected in the Otaniemi Finland 6-inch ID bubbling bed gasifier with operating conditions and results shown in Table 3.4.2 and Figure 3.4.1 [3-1]*. When reviewing Figure 3.4.1 note that the Otaniemi conversions are based on the fuel nitrogen fed rather than fuel nitrogen actually released; if the former was used, conversions will be higher. We note that TR6 and TR7 nitrogen to ammonia conversion levels and limestone feed rates are much higher than TR4 and TR5.

Table 3.4.1 Syngas Ammonia Analyses of GC Data

Test Run	TR4		TR5	TR6	TR7	
	TR4.1	TR4.2	TR5.1	TR6.1	TR7.1	TR7.2
Set Point						
N Fuel, %	1.52	1.52	1.53	1.57	1.46	1.57
N/C (fed), %	0.0203	0.0203	0.0202	0.0208	0.0164	0.0208
N/C (ovhd), %	0.0167	0.0155	0.0167	0.0174	0.0160	0.0194
N/C (bot), %	0.0132	0.0132	0.0136	0.0119	0.0127	0.0150
Average NH ₃ , ppm	350	267	314	650	283	713
NH ₃ /N fuel, %	4.3	3.7	3.7	9.1	5.9	12.8
NO _x Stack, lb/h	0.19	0.34	0.85	0.97	0.52	1.02
NO _x /N Fuel, %	2.0	3.7	5.8	9.6	5.6	10.1
N Released, %	53.6	51.2	55.1	54.6	33.3	57.0
NH ₃ /N Released, %	8.0	7.2	6.7	16.7	17.7	22.5


* Numbers in brackets designate references given in Section 6

In TR4 the unit was started with a sand bed and H₂S Drager tube values start high as shown in Figure 3.4.2 and decrease with time to a steady state value that reflects the establishment of a char-sorbent bed. In all other test runs the unit was started with a limestone bed and H₂S levels start low and increase with time to a steady state value again reflecting establishment of a char-sorbent bed (see Figure 3.4.3). In TR4 and 5 a pulverized zinc oxide (ZnO) water slurry was sprayed horizontally into the top of the carbonizer directly opposite the syngas outlet pipe. These spray injections were conducted to demonstrate that ZnO could be used as a second sulfur

capturing/polishing step to increase the carbonizer overall sulfur capture efficiency. The Figure 3.4.2 and 3.4.3 Drager tube data confirms this and results are discussed in Section 3.6.

Table 3.4.2 Typical NH₃ and HCN Contents of the Product Gas w/Different Feedstocks

	Pine Sawdust	Peat A	Peat B	Brown Coal	Iowa Coal	Polish Coal	Illinois No.6 Coal
Nitrogen content in the fuel, wt%	0.1-0.15	0.7-0.8	1.7-2.0	0.8	0.6-0.8	1.2-1.4	1.2-1.3
Pressure, MPa	0.4	0.4-0.8	0.4-1.0	0.5-0.7	0.5-0.8	0.5	0.5
Freeboard temp., EC	900-1000	855-920	800-940	860-940	920	940-1000	950-970
NH ₃ , ppm-v	300-950	4200-4900	5800-9200	2000-2600	2400-2500	1600-2600	950-1300
HCN, ppm-v	10-30	60-120	40-300	50-90	12-14	20-160	10-30



The conversion of fuel nitrogen to NH₃ in test runs with different feedstocks

Figure 3.4.1 NH₃ Formation Data from Otaniemi Test Facility

Lakeland Test Run TR04 H2S Sampling Results (fine limestone)

(Total 73 H2S Drager tube samples were taken. Total avg. H2S: 102 ppm)




Figure 3.4.2 Test Run TR4 H2S Drager Tube Readings

Lakeland Test Run TR05 H2S Sampling Results (fine limestone)
 (Total 77 H2S Drager tube samples were taken, total avg. H2S: 107 ppm)




Figure 3.4.3 Test Run TR5 H2S Drager Tube Readings

By analysis of the syngas and measurement of the syngas flow rate via the choked orifice the amount of hydrogen sulfide/sulfur escaping to the stack was determined. By forming the ratio of escaping sulfur to released sulfur and subtracting it from one, the carbonizer sulfur capture efficiencies (SCE) were determined in Table 3.4.3. Set points 4.1, 4.2, and 5.1, which were conducted with fine limestones, evidenced an SCE of approximately 93.6%. Set point 6.1 was conducted with coarse (1/8" x 0) limestone at a higher calcium to sulfur molar feed ratio (3.6) and evidenced an SCE of 94.5%. In Set Points 7.1 and 7.2 a 1/8" x 300 micron limestone feed was used to further increase the sorbent content of the bed and the SCE increased to 95.1% with the 1.4% sulfur coal. When 3.9% sulfur coke was used in Set Point 7.1, the SCE increased to 98.7%.

Table 3.4.3 Carbonizer Sulfur Capture Efficiency

Test Run	TR4		TR5	TR6	TR7	
Set Point	TR4.1	TR4.2	TR5.1	TR6.1	TR7.1	TR7.2
S Fuel, %	1.43	1.43	1.43	1.43	4.05	1.44
S/C (fed)	0.019	0.019	0.019	0.019	0.046	0.019
S/C (ovhd)	0.013	0.011	0.014	0.014	0.022	0.011
S/C (bot)	0.012	0.012	0.008	0.031	0.018	0.013
H2S, ppm (DT)	130	111	118	98	60	86
H2S, ppm (GC)	115	100	113	114	36	87
H2S/S fuel, %	3.67	3.51	3.18	3.24	1.04	3.79
SO2 Stack, lb/h	0.42	0.37	0.59	0.38	0.26	0.34
SO2/S Fuel, %	5.16	4.54	5.51	3.62	1.16	3.94
S Released, %	58.40	74.00	65.00	58.50	79.50	79.00
Captured/Released, %	93.72	93.58	93.58	94.46	98.69	95.06

3.5 Bed Composition

Except during startup, the carbonizer bed is a mixture of char and limestone. Since the char is much lighter than the limestone, the char tends to rise to the upper part of the bed and represents more than half of the material elutriated from the unit. Conversely, the limestone being heavier tends to sink to the lower part of the bed and represents most of the material drained from the bottom of the bed. At the end of Set Point 7.2, which was conducted with coarse (1/8" x 300 micron) limestone, the bed was emptied in equal volume batches via the bottom drain. The char content of each batch was measured and Figure 3.5.1 shows that the char content varied linearly with height ranging from about 35% at the bottom to almost 100% at the top of the bed. The carbon content of the char was also measured and Figure 3.5.2 shows a linear variation in carbon conversion ranging from 80% at the bottom, where material is exposed to the air jet, to about 40% at the top of the bed.

From Figure 3.5.1 it is seen that the carbonizer bed was predominantly char with the latter tending to the top of the bed. This high char content, and conversely low limestone content, bed was the result of operating with the bed overflow drain nozzle blanked off. The latter had been disconnected as a requirement of another test program that utilized pulverized coal (the four Lakeland runs were squeezed in between these other tests). If the overflow drain had been operational, the bed would have had a markedly higher sorbent content and probably would also have exhibited a higher level of sulfur capture.




Figure 3.5.1 TR7.2 Bed Char Content via Post Run Inspection




Figure 3.5.2 TR7.2 Char Carbon Content via Post Run Inspection

3.6 Zinc Oxide Sulfur Polishing

Zinc oxide has a higher affinity for capturing sulfur from gases containing hydrogen sulfide than either calcium oxide or calcium carbonate. To increase the carbonizer sulfur capture efficiency to greater than 95% when partially gasifying low sulfur coals with a limestone bed and/or increase the sulfur capture efficiency of an under performing unit, pulverized zinc oxide can be injected into the carbonizer syngas upstream of the ceramic candle filter. A series of tests involving zinc oxide injection were conducted in the 12-inch diameter Livingston pilot plant carbonizer to determine what improvement in sulfur capture efficiency might be achieved.

The pulverized zinc oxide was injected as 5 to 15% by weight water slurry into the top of the carbonizer via a horizontal, nitrogen atomized nozzle inserted through a cleanout plug provided opposite the syngas outlet (see Figure 3.6.1). The injection nozzle was a Delavan Spray Technologies Swirl-Air Atomizing Nozzle P/N 32740-13 with a 32742 adapter. Although the nominal rating of the nozzle is 1.0 gpm and the flow rate requirements of the testing were only in the range of 1 to 4 gph, the vendor indicated performance would be satisfactory. Since the major source of energy for liquid atomization in this gas-assisted nozzle is the pneumatic energy of the gas, the liquid flow rate has only a minor effect on the nozzle overall pressure drop. Bench testing of the nozzle at atmospheric pressure and test run flow rates of liquid confirmed this.

At the nominal nozzle capacity of 1.0 gpm the nozzle effects a spray angle of 50E which rapidly collapses into a straight columnar type pattern within the first couple feet from the nozzle discharge. The maximum pattern diameter at an 80 psig atomizing gas pressure drop is predicted by the vendor to be 18 inches in ambient air conditions. At the low flow rate at which this nozzle operated in the test run, the vendor predicted a maximum pattern diameter of under 12 inches in ambient air conditions. The vendor also predicted that in the 1700EF environment of the carbonizer the liquid should evaporate almost immediately at the nozzle discharge. The vendor's predicted Sauter mean droplet diameter for the carbonizer conditions was 27 microns.

The piping run length from the carbonizer syngas outlet nozzle to the candle filter was about 30 feet long (there was no cyclone) and the syngas pipe velocity was about 60 ft/sec. The residence of the zinc oxide in the overhead system is of the order of one second or less. Therefore, the major dwell time of the zinc oxide occurred on the filter.

The zinc oxide slurries tests were performed during Test Runs TR04 and TR05 (see Figures 3.4.2 and 3.4.3). In Test Run TR04, the carbonizer was started with a sand bed and sorbent feed commenced simultaneously with coal feed at about 6:00 p.m. on September 16, 1997. After about 8 hours of operation, H₂S levels were at about 225 ppm and over the next 20 hours decreased to steady state value of about 125 ppm, the latter corresponding to 93.7% sulfur capture efficiency. Injecting ZnO at a Zn/S molar feed ratio of 2.0 reduced H₂S levels to about 100 ppm and raised the overall sulfur capture efficiency to about 94.9% ($1 - .063 \times 100/125$). Increasing the feed ratio to 6.5 further reduced H₂S to about 25 ppm, for a carbonizer overall sulfur capture efficiency of about 98.7% ($1 - .063 \times 25/125$). Reducing the feed ratio to 4.3 allowed the H₂S to increase to about 60 ppm for an overall sulfur capture efficiency of 97% ($1 - .063 \times 60/125$).

In Test Run TR05 the carbonizer was started at 12:13 hours on September 23, 1997, with a bed of limestone rather than sand. Because the bed was totally filled with sorbent H₂S levels were minimal in the beginning and, as expected, increased with time as a portion of the limestone bed was displaced by char and a steady state char-used limestone composition was reached. H₂S levels are observed to line out at about 125 ppm as in TR04. Although ZnO was injected at Zn/S molar feed ratios of 2.2, 4.0, and 4.4, the slurry concentrations used this time were much more dilute and gains were marginal if at all. Returning to TR04, the injection of water without zinc oxide into the syngas was observed to about double the H₂S level, increasing it from about 125 ppm to 210 ppm. The water vapor raises the equilibrium partial pressure of H₂S over calcium oxide/ calcium carbonate and causes H₂S to be released from the calcium sulfide (CaS) entrained in the the gas stream and collected in the ash cake in the candle filter. The large quantity of water sprayed into the syngas in TR05 thus appears to have negated the gains provided by the zinc oxide; hence, commercial plant injections should be done with slurries containing high solids contents (15 weight per cent and higher) or use dry injection systems to maximize sulfur capture efficiency.

3.7 Syngas Alkali Vapor Measurements

In 1987 Westinghouse Science and Technology Center (WSTC) conducted equilibrium calculations to determine the amount of alkali vapor that could be released to the carbonizer syngas from Pittsburgh No. 8 coal and dolomite [3-2]. WSTC's calculations indicated the reducing conditions of the carbonizer enhance the release of alkali which appear as chlorides at levels well in excess of suggested gas turbine limits. Reducing the syngas temperature, however, will reduce the alkali level as shown in WSTC's Figure 3.7.1. To protect the Lakeland gas turbine from alkali induced corrosion, the carbonizer syngas will be cooled to 1200EF by a tubular heat exchanger located between the syngas cyclone and ceramic candle filter. This cooling will cause alkali vapor to condense on the fine particulate entrained in the syngas; the particulate will be captured/removed from the syngas by the candle filter thereby protecting the gas turbine. Although Figure 3.7.1 is insightful, equilibrium calculations are dependent on the assumptions and compounds taken into consideration and generally over predict gas phase alkali levels. In addition, these calculations do not account for alkali absorption by the coal fly ash and sorbent, which tend to reduce gas phase alkali levels, or the distribution of the alkali within the feedstocks which, together with operating conditions, affect the actual alkali release. As a result,

alkali measurements were made in the Livingston carbonizer pilot plant to determine the range of syngas alkali levels expected at Lakeland with Kentucky No. 9 and Florida limestone.

The vapor phase measurements were made at a point approximately 6 feet downstream of the candle filter outlet nozzle (see Figure 3.7.2) via a probe supplied by Westinghouse and used by Foster Wheeler in a previous test program. Since alkali levels in the parts per billion range are to be measured and since the vapor has been shown by other investigators to be absorbed by the stainless steel tubing used to extract gas samples, WSTC has developed a probe that minimizes gas sample heat loss and extraction run length; in addition the probe can be used, depending upon tip configuration, for either isokinetic particle or alkali gas sampling. The Westinghouse probe flow and sampling arrangements are shown in Figures 3.7.3 and 3.7.4.




Figure 3.7.1 Syngas Equilibrium Total Alkali Vapor Estimate




Figure 3.7.2 Location of Carbonizer Syngas Alkali Measurements




Figure 3.7.3 WSTC Typical Probe Flow Arrangement




Figure 3.7.4 WSTC Alkali Probe Sampling Arrangement

The alkali configured probe draws a non-isokinetic sample (typically about 1 ACFM) through a high-temperature, 5 micron, porous metal (Hastelloy X) thimble-shaped filter provided in the tip of the probe to remove particulate. The gas then passes into the cooling section of the probe to condense and collect alkali. Cooling is achieved by a continuous counter flow of high-pressure nitrogen in the inner concentric tube assembly. The sample gas passes through the outer annulus and cools to approximately 200EF with the alkali vapor condensing on the walls. The cooled gas exits the probe, passes through a bubbler, moisture separator/ knockout pot, rotameter, flow control valve, and proceeds to the pilot plant stack gas incinerator. The control valve sets the gas sampling/extraction rate, as measured by the rotameter, and the bubbler solution is analyzed after each test point to collect any alkali that escaped the probe; the knockout pot liquid content was negligible and hence none was available for analysis. Any particulate collecting on the thimble filter will gradually reduce the sampling rate and to minimize dust pick up during alkali measurements, the probe is oriented to face away from the flowing gas (Figure 3.7 5). In addition, the rotameter sampling rate is checked every five minutes and the control valve is adjusted accordingly to maintain the 1 ACFM sampling rate.




Figure 3.7.5 WSTC Probe with Alkali Sampling Tip

After a sufficient sampling time period (typically about one hour), the probe is withdrawn from the syngas stream through a double block-and-bleed-valve arrangement (see Figure 3.7.4.). The probe is disassembled and appropriate sections brought in sealed plastic bags to the laboratory for analysis. Care must be taken at all times when handling the sections (a white glove operation) to prevent contamination of the specimens by dust or even perspiration as these can distort test results. Specimen handling and analyses are performed using WSTC developed/recommended procedures. The particulate collected by and brushed off the porous metal thimble filter was weighted and where possible characterized to identify water-soluble and insoluble components. Alkali compounds were recovered from the thimble filter and cold finger using a rinse and recovery approach and these amounts, together with that obtained from the bubbler solution, were separately measured. On-site analyses were completed by selective-ion electrodes, atomic absorption, or inductively coupled plasma spectroscopy.

The gas temperature at the exact point of sampling was not measured during the Lakeland tests but can be inferred from nearby thermocouples. A thermocouple (TI 3001) located approximately 34 feet downstream of the filter outlet nozzle typically ran 110EF cooler than the filter outlet plenum. Based on this observation, the sampling point gas temperature, which is located approximately 6 ft. downstream of the filter, was about 20EF lower ($110 \times 6/34$) than the filter outlet plenum temperature.

A total of 17 gas alkali measurements were made during 3 carbonizer test runs (TR4, 6, and 7) at carbonizer bed temperatures of 1725EF, 1750EF and 1810EF as determined by a thermocouple located 12.5 feet above the top of the central feed pipe. Being a pilot plant, the carbonizer, cyclone, candle filter, and piping have a high surface to volume rate. As a result, heat loss through the walls of these components yielded a candle filter outlet temperature that was about 400 to 500EF lower than the bed temperature and closely approximated the proposed Lakeland filter temperature. Hence, a syngas cooler was not installed in the Livingston pilot plant.

Tables 3.7.1 and 3.7.2 present the alkali data. During the alkali measurements, no dust leaks were experienced with the upstream candle filter and the particulate captured by the probe filter was so minimal it generally couldn't be checked for alkali content. As seen from Table 3.7.1 each thimble exhibited a weight gain during its one-hour sampling period and that experienced by thimble AK07 is close to the average gain. To understand the cause of the gain a transverse cut was made through thimble AK07 and examination of the exposed surfaces revealed:

1. by an Optical Microscope and a Scanning Electron Microscope (SEM) respectively, that entrapped dust particles were on the outside surface of the thimble filter.
2. Closer examination revealed no dust particles inside the porous thimble filter.
3. Energy dispersive x-ray (EDS) analysis disclosed that the dust particles consisted of carbon, aluminum, silicon, sodium, sulfur, calcium, potassium, and titanium all of which are present in the test coal and limestone.
4. Recognizing that the thimble was exposed to the carbonizer syngas for only about an hour, no oxide or sulfide films were found on the thimble base metal.

Based on the above it was concluded that the thimble weight gains were caused by particulate trapped in the outer pores of the thimble, rather than by corrosion of the thimble. The water

soluble alkali washed from the thimble filter and finger and that captured by the bubbler were added together and reported as the vapor phase alkali contained in the gas stream exiting the filter. The water soluble alkali that was extracted from the dust fines was not included in the vapor phase alkali summation as it is assumed it had condensed on the particulate upstream of and within the candle filter. Since the thimble filter contained particulate trapped in its outer pores, its washings tend to overestimate the vapor phase alkali content and since it yields conservative results no attempt was made to correct for this. Figure 3.7.6 plots the alkali vapor levels versus the candle filter outlet temperature for the 17 measurements and Figure 3.7.7 expands the vertical, condensed alkali scale.

Table 3.7.1

Table 4 Alkali Sampling Summary for Lakeland Test TR04 to TR07 (Sep. to Dec. 1997)

Set Point	Sample No.	Date (m/d)	Time			Carbonizer+			Candle Filter+	Total Sampled/Collected				Tip position	Flow meter				
			Start (h:m)	End (h:m)	Dura. (min)	T3016 (F)	T3003 (F)	P3007 (psig)	T3627 (F)	Gas lb/h	MW	Dust* (g ppmw)	Vapor Alkali (mg (ppmw))		PG2 (psig)	TG2 (F)	Fread (liter)		
TR07.	AK02	12/10/97	15:35	16:35	60	1727	1660	174	1230	4738	26.8	0.125	26.3	0.195	0.041	down	145	104	3730
TR05.	AK01 _z	09/24/97	09:02	10:02	60	1745	1709	124	1320	6246	26.1	0.001	0.1	0.287	0.046	down	83	108	4860
TR05.	AK02 _z	09/24/97	13:29	14:29	60	1757	1718	126	1316	5832	26.1	0.021	3.5	0.168	0.029	down	80	104	4538
TR05.	AK04	09/25/97	02:20	03:20	60	1756	1734	137	1368	4602	26.1	0.036	7.8	4.107	0.892	down	128	84	3581
TR05.	AK05	09/25/97	04:10	05:40	90	1764	1745	139	1371	4584	26.1	0.042	9.1	0.422	0.092	down	126	80	3567
TR04.	AK01	09/17/97	12:45	13:40	55	1759	1702	84	1264	5029	26.3	0.099	19.6	0.595	0.118	down	60	97	3921
TR04.	AK02	09/17/97	17:11	18:06	55	1760	1706	86	1259	5369	26.3	0.085	15.9	0.589	0.110	down	75	95	4186
TR04.	AK03	09/17/97	19:39	20:39	60	1758	1707	87	1262	5414	26.3	0.061	11.3	9.738	1.799	down	79	97	4222
TR04.	AK04	09/17/97	22:20	23:20	60	1763	1703	94	1282	6590	26.3	0.067	10.2	0.096	0.015	down	82	116	5139
TR04.	AK05	09/18/97	01:40	02:40	60	1753	1705	94	1283	6326	26.3	0.071	11.2	0.080	0.013	down	91	125	4933
TR04.	AK06 _z	09/18/97	09:19	10:14	55	1759	1697	93	1280	5954	26.3	0.068	11.4	45.71	7.678	down	79	110	4642
TR04.	AK07 _z	09/18/97	11:59	12:54	55	1761	1679	95	1264	6064	26.3	0.063	10.3	0.045	0.007	down	83	132	4729
TR04.	AK08	09/18/97	23:20	00:20	60	1814	1745	99	1296	6803	26.3	0.079	11.6	0.212	0.031	down	84	101	5306
TR04.	AK09	09/19/97	02:25	03:25	60	1823	1752	102	1299	6860	26.3	0.073	10.7	0.249	0.036	down	86	100	5351
TR04.	AK10	09/19/97	04:35	05:30	55	1803	1741	106	1304	5311	26.3	0.061	11.5	0.222	0.042	down	82	91	4143
TR04.	AK11 _z	09/19/97	08:53	09:48	55	1817	1732	110	1287	6779	26.3	0.059	8.7	0.155	0.023	down	102	104	5288
TR04.	AK12	09/19/97	13:30	14:25	55	1796	1747	110	1311	6550	26.3	0.017	2.5	0.910	0.139	down	93	100	5109

Note:

Vapor Alkali means alkali from thimble, cold finger, and bubbler.

* - sum of the dust fine collected and weight gain by thimble; ppmw is only for reference since isokinetic sampling was not used.

+ - both temperature and pressure are the average value in the alkali sampling period.

Z - ZnO injection during measurement.

T3016 is the temperature at 12' 6 1/8" above the top of feed pipe, T3003 & P3007 are freeboard temperature & pressure are at 32' 6 1/8" & 31' 1/8" above feed pipe respecti

Probe filters are metallic (Hastelloy X) with pore size of 5 micron.

All tests used Kentucky coal with Florida limestone.

PG2 and TG2 represent the averaged pressure and temperature of sample gas at the rotameter inlet.

Gas flow lb/h is corrected for fuel gas molecular weight by $(MW_{air}/MW_g)^{0.5}$.Flow meter reading (liter) is accumulated air flow averaged for each 5 minutes & corrected for pressure and temperature by $[(14.7+PG2)/14.7]^{0.5} * (530/(460+TG2))^{1.5}$.MW_{air} = 28.96 MW_{gas} is each set point averaged test data corrected for N₂ leakage.

Table 3.7.2

Table 5 Alkali Sample Chemical Analysis Summary for Lakeland Test TR04 to TR07 (Sep. to Dec. 1997)

Set Point	Sample No.	Dust fine							Thimble					Finger*			Bubbler*			Vapor				
		Na		K		Sum	wt of	Ratio	Na		K		Sum	wt	Ratio	Na	K	Sum	Na	K	Sum	Na	K	Sum
		Sol (mg)	Ins (mg)	Sol (mg)	Ins (mg)	(mg)	(mg)	(%)	Sol (mg)	Ins (mg)	Sol (mg)	Ins (mg)	(mg)	(mg)	(%)	Sol (mg)	Sol (mg)	(mg)	Sol (mg)	Sol (mg)	(mg)	Sol (mg)	Sol (mg)	(mg)
TR07.	AK02	0.026	0.088	0.002	0.227	0.343	110	0.31	0.0160	-	0.0050	-	0.021	14.1	0.15	0.1140	0.0200	0.134	0.0200	0.0200	0.040	0.150	0.045	0.195
TR05.	AK01 z	-	-	-	-	0.000	0.0	ERR	0.0400	-	0.0005	-	0.041	0.7	5.79	0.0240	0.0005	0.025	0.1470	0.0745	0.222	0.211	0.076	0.287
TR05.	AK02 z	-	-	-	-	0.000	2.3	0.00	0.0170	-	0.0005	-	0.018	18.2	0.10	0.0650	0.0520	0.117	0.0210	0.0120	0.033	0.103	0.065	0.168
TR05.	AK04	-	-	-	-	0.000	10.5	0.00	0.0003	-	0.0005	-	0.001	25.4	0.00	0.0560	0.0200	0.076	4.0200	0.0100	4.030	4.076	0.031	4.107
TR05.	AK05	-	-	-	-	0.000	5.4	0.00	0.0030	-	0.0005	-	0.004	36.1	0.01	0.0760	0.0520	0.128	0.2800	0.0100	0.290	0.359	0.063	0.422
TR04.	AK01	4.840	0.130	0.030	0.220	5.220	28.8	18.1	0.0270	-	0.0005	-	0.028	69.7	0.04	0.0010	0.0005	0.002	0.0160	0.5500	0.566	0.044	0.551	0.595
TR04.	AK02	-	-	-	-	0.000	10.6	0.00	0.0320	-	0.0060	-	0.038	74.9	0.05	0.0060	0.0010	0.007	0.0140	0.5300	0.544	0.052	0.537	0.589
TR04.	AK03	-	-	-	-	0.000	3.9	0.00	0.0310	-	0.0140	-	0.045	57.3	0.08	0.0040	0.0030	0.007	9.6600	0.0260	9.686	9.695	0.043	9.738
TR04.	AK04	-	-	-	-	0.000	1.3	0.00	0.0260	-	0.0240	-	0.050	65.6	0.08	0.0110	0.0350	0.046	-	-	0.000	0.037	0.059	0.096
TR04.	AK05	-	-	-	-	0.000	0.0	ERR	0.0200	-	0.0210	-	0.041	71.0	0.06	0.0190	0.0200	0.039	-	-	0.000	0.039	0.041	0.080
TR04.	AK06 z	-	-	-	-	0.000	6.3	0.00	0.0520	-	0.0240	-	0.076	61.8	0.12	0.0100	0.0170	0.027	45.500	0.1110	45.61	45.56	0.152	45.71
TR04.	AK07 z	-	-	-	-	0.000	0.7	0.00	0.0010	-	0.0110	-	0.012	61.9	0.02	0.0010	0.0130	0.014	0.0010	0.0180	0.019	0.003	0.042	0.045
TR04.	AK08	-	-	-	-	0.000	4.2	0.00	0.0005	-	0.0062	-	0.007	74.3	0.01	0.0280	0.0270	0.055	0.0100	0.1400	0.150	0.039	0.173	0.212
TR04.	AK09	-	-	-	-	0.000	4.9	0.00	0.0005	-	0.0068	-	0.007	68.5	0.01	0.0560	0.0360	0.102	0.0100	0.1300	0.140	0.077	0.173	0.249
TR04.	AK10	-	-	-	-	0.000	1.5	0.00	0.0005	-	0.0005	-	0.001	59.6	0.00	0.0210	0.0300	0.051	0.0100	0.1600	0.170	0.032	0.191	0.222
TR04.	AK11 z	-	-	-	-	0.000	1.9	0.00	0.0005	-	0.0005	-	0.001	57.0	0.00	0.0190	0.0160	0.035	0.0090	0.1100	0.119	0.029	0.127	0.155
TR04.	AK12	-	-	-	-	0.000	0.0	ERR	0.7380	-	0.0280	-	0.766	16.7	4.59	0.0100	0.0140	0.024	0.0100	0.1100	0.120	0.758	0.152	0.910

Note:

"wt of dust fine" is the dust fine collected by brushing thimble; it doesn't include the weight gain of thimble.

"Sol" means soluble while "Ins" means insoluble.

"Vapor" = total of thimble, finger, and bubbler alkali sums.

"*" means no insoluble alkali present.

"-" means not applicable.

"Z" means ZnO injection during measurement.

Other refer to the notes in Table 4.




Figure 3.7.6 Syngas Alkali Vapor Level Versus Temperature




Figure 3.7.7 Syngas Alkali Vapor Level Versus Temperature (Expanded Scale)

The alkali levels shown in Figure 3.7.7 are very low and accurate measurements at these levels are known to be difficult. Seven of the 17 points shown in this figure do not agree with the predicted theoretical trend and are one to two orders of magnitude greater than the other points. It is suspected those seven points were “bad” possibly reflecting specimen contamination. A check of published literature revealed that similar measurements had been made in a fluidized bed gasifier pilot plant in Finland [3-1]. The gasifier was a 6 inch diameter bubbling bed unit running at 1750EF at 4 to 6 atmospheres pressure. The syngas generated by the gasifier passed through two stages of cyclones, a tubular heat exchanger/gas cooler, and a candle filter. Downstream of the candle filter syngas samples were extracted through an electrically heated line, cooled by water spray, depressured via a valve, passed through bubblers to condense the alkali, and vented to a flow meter. Although most of the testing was done using peat and wood as the fuels, some data was collected with the Illinois No. 6 coal shown in Table 3.7.3. Vapor phase alkali levels were found to be a function of the gasifier temperature, feed stock, and gas sampling temperature. The experimenter’s results shown in Figure 3.7.8 exhibit the Figure 3.7.1 and 3.7.7 temperature relationship, and the peat and Illinois No. 6 alkali levels scatter for the most part from 50 to 100 ppbw over the 932 to 1202EF temperature interval. The WSTC probe data shown in Figure 3.7.7 does not exhibit this scatter and, as a result, we suspect it to be the more accurate of the two techniques at these low levels. The Figure 3.7.7 WSTC probe data indicates vapor phase alkali levels should be less than 20 ppbw at 1200EF, the planned operating temperature of the Lakeland syngas candle filter.

Table 3.7.3 Gasifier and Feedstock Data Extracted from [3-1]

Technical Data of the VTT-PFG Test Facility			
Bed – I.D.	15 cm	Feedstocks gasified:	
Freeboard – I.D.	25 cm	- Saw dust and wood wastes	
Reactor height	4.2 m	- Different peat product	
Operating pressure	3-10 bar	- Rhenish brown coal	
Bed temperature	700-1000EC	- Hard coals: Iowa Rawhide, Polish Coal, Illinois No. 6	
Freeboard t (max)	1100EC	Total pressurized test time	1600 h
Fluidizing velocity	0.5-1.5 m/s	Number of measured set points	100
Gasification agents	Air, steam	Amount of gasified fuels	80 tons
		Fuel feed rate (max)	80 kg/h

Feedstock Analyses

	Pine saw dust	Peat A	Peat B	Rhenish brown coal	Iowa Rawhide coal	Polish coal	Illinois No.6 coal
Moisture content, wt%	5-11	9-16	15-19	11-13	17-19	5-7	2-5
Proximate analysis (d.b)							
Volatile matter, wt%	83.0	72.7	68.4	53.0	43.2	31.8	33.9
Fixed carbon, wt%	16.8	24.3	27.4	42.7	49.5	59.9	53.2
Ash, wt%	0.2	3.0	4.3	4.3	7.4	8.3	13.2
Ultimate analysis (d.b)							
C, wt%	50.2	50.1	54.5	63.8	70.8	75.5	64.6
H, wt%	6.1	5.4	5.6	4.6	4.7	4.7	4.2
N, wt%	0.1	0.8	1.8	0.8	0.7	1.3	1.3
S, wt%	0.0	0.1	0.2	0.3	0.5	0.7	2.9
Ash, wt%	0.2	3.0	4.3	4.3	7.4	8.3	13.2
O (diff.), wt%	43.4	40.6	33.6	26.2	16.2	9.5	13.8
Na content, ppm-wt (d.b)	40	380	330	300	1140	450	1420
K content, ppm-wt (d.b)	500	690	440	140	570	1420	3610
Cl content, ppm-wt (d.b)	<15	180	270	250	<25	760	1210




Figure 3.7.8 Alkali Results Extracted from [3-1]

Alkali measurements have also been made at several PFB test facilities utilizing other techniques. Although the PFB flue gas is oxidizing rather than reducing, similar temperature trends and minimal alkali levels are predicted by theory at 1200EF. The alkali measurements that were made at the outlet of the Asahi ceramic candle filter in the 71 MWe Wakamatsu non-topped PFB plant compared two different measuring techniques. The first used Argonne National Laboratory's bed of activated bauxite to capture the alkali vapor (AASB Method) and after a specified exposure period the bed was analyzed to determine its alkali content. In the second method a sample of gas was continuously passed through a flame that was monitored by a calibrated atomic emissions spectrometer (FAES Method). Tables 3.7.4 and 3.7.5 and Figure 3.7.9 present the published Wakamatsu data [3-3]. For the PFB vitiated air (oxidizing) conditions they too predict a decrease in alkali vapor with decreasing gas temperatures. Figure 3.7.9 depicts this temperature trend and presents alkali measurement data from other facilities. The gas sampling point temperatures during the second and third Wakamatsu test periods ranged from 642 to 650EC (1188 to 1202EF) and the alkali vapor ranged from 0 to 5 ppbw depending upon the measuring method used. Some experimenters have observed a time dependency on gas alkali vapor levels indicating an increase with time attributed to a gradual decrease in vapor absorption by upstream equipment surfaces. Eventually a pseudo-equilibrium is expected to be reached, but the time required to achieve it is uncertain and will depend on test rig size. The Wakamatsu data is believed to have been taken after about 4500 hours of operation (1800 hours with the ceramic filter) and hopefully has reached this equilibrium condition. The WSTC probe data shown in Figure 3.7.7 indicates, depending upon the bed temperature, vapor phase alkali levels ranging from about 30 to 50 ppbw; with a higher bed temperature (1750 to 1810EF vs.

1560EF) and reducing gas conditions involved, the syngas data could be expected to be and does appear to be slightly higher than the oxidizing 1560EF PCFB data. The fact that the difference is in the right direction is encouraging.

Table 3.7.4 Wakamatsu Fuel and Test Conditions from [3-3]

Test Conditions and Sampling Results

	First Run	Second Run	Third Run	Fourth Run
Operating Load	100% Load	54% Load	54% Load	100% Load
Burning Coal (by slurry with water and limestone)	Taiheiyo 50% Blairthol 50%	Blairthol 100%	Taiheiyo 100%	Blairthol 100%
Bed Temperature	830 - 860 °C	850 - 860 °C	847 - 851 °C	834 - 845 °C
Bed Pressure	1.013 MPa	0.728 MPa	0.728 MPa	1.033 MPa
Gas Temperature at Sampling Point	780 - 800 °C	650 - 660 °C	640 - 642 °C	793 - 804 °C
Gas Pressure at Sampling Point	0.974 MPa	0.689 MPa	0.689 MPa	0.974MPa
Sampling Period for AASB sampling	44.5 h	46.5 h	50.0 h	19.8h
Total Sampling gas quantity	109 Nm3	109 Nm3	120 Nm3	22Nm3
Condensed water quantity in the sampling unit	Approx. 14 ℓ	Approx. 11 ℓ	Approx. 9.5 ℓ	Approx. 2.2 ℓ

Chemical Analysis of the Coal Slurry Burnt During Measurement

		First Run	Second Run	Third Run	Fourth Run
Ultimate analysis (Moisture free)	C (%)	59.6	67.1	64.6	68.5
	H (%)	4.46	3.85	5.37	4.05
	O (%)	18.43	12.69	13.48	14.19
	N (%)	1.10	1.48	0.95	1.62
	S (%)	0.23	0.21	0.19	0.28
	Ash (%)	16.3	14.67	15.54	11.39
	P (%)	0.019	0.011	0.029	0.014
	Cl (mg/kg)	260	250	380	230
	F (mg/kg)	30	10	20	20
Ash analysis	Na ₂ O (%)	0.51	0.38	1.38	0.40
	K ₂ O (%)	0.44	0.16	0.98	0.27

Table 3.7.5 Wakamatsu Oxidizing PFB Flue Gas and Alkali Results from [3-3]

Exhaust Gas Analysis Result (at Gas Turbine Outlet)


	First Run	Second Run	Third Run	Fourth Run
Moisture (Vol. %)	11.8	8.9	10.0	11.8
Specific weight (kg/Nm ³)	1.29	1.29	1.29	1.29
Dust concentration (g/Nm ³)	0.0135	0.0014	0.0017	0.0036
SO ₂ concentration (ppm)	9.7	3.8	11.2	13.4
SO ₃ concentration (ppm)	0.45	1.0	2.8	2.4
Hcl concentration (ppm)	1.7	3.5	12.7	5.7

Measurement Result of Alkali Vapor in Wakamatsu PFBC


[UNIT : ppb wt]

	First Run	Second Run	Third Run	Fourth Run	
AASB method	Sodium vapor concentration	17.5 - 28.0	0 - 6.5	3.4	8.9
	Potassium vapor concentration	0.5 - 5.0	0 - 1.5	0.0	1.5
	Sodium concentration in fly ash	0 - 0.5	0.0	0.0	0.0
	Potassium concentration in fly ash	0.0	0.0	0.0	0.0
	Total sodium concentration	17.5 - 28.5	0 - 6.5	3.4	8.9
	Total potassium concentration	0.5 - 5.0	0 - 1.5	0.0	1.5
	Total alkali vapor concentration	18.0 - 33.0	0 - 8.0	3.4	10.4
FAES method	Sodium vapor concentration	-	1.9 - 3.7	1.0 - 3.2	0.9 - 7.8
	Potassium vapor concentration	-	0.7 - 1.3	0.3 - 0.7	0.5 - 1.4
	Sodium concentration in fly ash	-	(*) 13.2	(*) 16.8	(*) 14.3
	Potassium concentration in fly ash	-	(*) 4.6	(*) 0.7	(*) 0.7
	Total alkali vapor concentration	-	2.6 - 5.0	1.3 - 3.9	1.4 - 9.2
Theoretical value	Sodium vapor concentration	6.0	0.12	0.26	6.58
	Potassium vapor concentration	31.0	0.48	1.07	32.2
	Total alkali vapor concentration	37.0	0.6	1.33	38.8

(*) Peak value while pulse cleaning of ceramic filter



Alkali Vapor Measurement Results reported by various reserch Organizations



Theoretical Alkali Vapor Concentrations

Figure 3.7.9 Predicted and Observed Alkali Data in Oxidizing PFB flue Gas from [3-3]

4.0 Candle Filter

The Westinghouse Ceramic Candle Filter used during the test is shown in Figure 4.1; it consisted of a 50 inch OD by 17 ft. – 2 in. tall refractory lined vessel containing up to 22 candles split into two equal groupings. The candles were 2.36 in. in OD by 59 in. long and were hung from a metallic tube sheet in the cluster arrangement shown in Figure 4.2. Carbonizer syngas entered the vessel tangentially and flowed primarily over the top of a cylindrical shroud that protected the elements from direct gas impingement and promoted general downflow over the elements. The syngas passed through the porous wall of the candles, flowed up each candle, discharged into a plenum at the top of the unit, and exited through a 5 in. ID radial outlet nozzle. Particulate entrained in the syngas deposited on the outside of the candles and was blown off by intermittent pulses of high pressure nitrogen emanating from the inside of each candle. The dislodged dust cake fell to the bottom of the unit and drained by gravity through a 6 in. Sch 40 outlet to surge and lock hoppers provided beneath the unit.

During the fine sorbent test runs TR4 and 5, the filter was operated without a pre-cleaning cyclone and all material elutriated from the carbonizer bed entered the filter. Anticipating a high solids loading, these runs were conducted with all 22 candles installed and candles manufactured by Coors were used. For the coarse sorbent test runs TR6 and 7, a pre-cleaning cyclone was installed immediately upstream of the filter and, anticipating a lighter solids loading, only 10 candles were installed (5 Schumacher candles in the first cluster and 5 Pall Refraction candles in the second). The particulate captured by the cyclone drained through a “J” valve/loop seal to the surge hopper provided under the filter.




Figure 4.2 Candle Arrangement – Plan View

Table 4.1 tabulates the filter operating conditions and it is seen the 22 candle system operated with a face velocity of approximately 1.9 fpm with a solids loading ranging from $1.3(10)^5$ to $1.5(10)^5$ ppmw. With the 10 candle arrangement, the face velocity rose to approximately 4 fpm. Because the cyclone and filter shared the same surge and lock hoppers unlike TR4 and 5, the particulate loading to the filter in TR6 and 7 could not be calculated.

In all four test runs the filter operated successfully showing no signs of ash bridging or agglomeration.

Table 4.1 Candle Filter Performance

Test Run	4		5	6	7	
Set Point	4.1	4.2	5.1	6.1	7.1	7.2
Pre-cleaning cyclone	No	No	No	Yes	Yes	Yes
Solids drain rate, lb/h	149	149	182	NA ^V	77*	101*
Syngas flow rate	965	1082	1213	1460	1641	1597
Inlet pressure, psia	104.7	119.5	136.3	NA ^V	174.9	179.9
Inlet temperature, E F	1390	1429	1441	1451	1407	1446
Syngas Mol Wt	26.23	26.23	25.87	NA ^V	27.50	26.76
Syngas Vol Flow, ACFM	116.4	116.7	117.08	NA ^V	114.05	113.20
Number of candles	22	22	22	10	10	10
Candle filtration area ⁺ ft ²	62.7	62.7	62.7	28.5	28.5	28.5
Candle face velocity, fpm	1.86	1.86	1.88	NA ^L	4.0	3.97
Solids loading, ppmw	$1.54(10)^5$	$1.34(10)^5$	$1.50(10)^5$	---	---	---

NA^L = data not available

* Total collected by cyclone and filter

⁺ 2.85 ft² of face/filtration area per candle

Typical filter performance data is presented for TR5 in Figures 4.3 and TR7 in Figure 4.4 where:

PI 3007	carbonizer freeboard pressure
PI 3603	N ₂ pulse tank pressure
PDI 3638	Tube sheet pressure differential
TI 3049	Syngas inlet temperature
TI 3109	Solids drain temperature

TI 3109 is a thermocouple located in the 6 in. solids drain nozzle at the bottom of the filter vessel, and its spikes reflect falling filter cake from the pulse cleaned candles. The 22 and 10 candle runs exhibit on the whole similar performance characteristics. In TR5 the pulse tank cleaning pressure was about 350 psi above process, the cleaning pulse was triggered when the candle pressure drop reached about 50 in. of H₂O, and after cleaning the candle pressure drop was about 20 in. of H₂O.

Typical Candle Filter Operation Performance During TR05




Figure 4.3 Typical Filter Performance During Test Run TR5 (22 Candles)

Typical Candle Filter Operation Performance During TR07




Figure 4.4 Typical Filter Performance During Test Run TR7 (10 Candles)

In the 10 candle run the pulse pressure was about 525 psi over process, the cleaning pulse was triggered at about 40 in. of H₂O, and the candle pressure drop after cleaning was about 25 in. of H₂O. In both runs TI 3109, which is a thermocouple located in the 6 in. solids drain nozzle at the bottom of the unit, registers the expected temperature spike with each cleaning pulse as the dislodged cake drains from the unit. The most significant difference between the runs is the frequency of cleaning. With 10 candles the filter was pulse cleaned about 9 times per hour versus 2 times per hour with 22 candles. Although the former frequencies are high from the standpoint of long-term operation, they could have been reduced by raising the trigger pulse cleaning pressure differential to a more reasonable level of about 90 in. H₂O. Recognizing that test runs TR4 through 7 were of relatively short duration, no filter blinding was experienced and there appeared to be no significant increase in the candle after pulse cleaning pressure drop even after withholding cleaning for one hour.

5.0 Conclusions/Summary

The Kentucky No 9 coal and Florida limestone proposed for use in the Lakeland 2nd Gen PFB Demonstration Plant were tested in the Livingston carbonizer pilot plant. Four relatively short-term test runs were conducted, and they showed the feedstocks posed no obvious operating problems to the carbonizer or its ceramic candle filter. In the first two runs a fine limestone feed size ($d_{50} \approx 150\mu$) recommended for the PCFB boiler was used, whereas in the second two runs a coarser minus 1/8 in. feed was employed. Since the carbonizer was operated on a once-through basis (no recycle of elutriated fines back to the bed) most of the fine sorbent elutriated and left behind a predominantly char bed. With less sorbent in the bed, the fine feed sulfur capture efficiency was less than that of the coarse feed (about 93½ versus 95 per cent); and the coarse feed size 1/8" x 300 micron is recommended for the Lakeland demonstration plant carbonizer.

Agglomeration was experienced in the carbonizer during the tests, and it was initially thought to be caused by the lack of sorbent in the bed with the fine feed. When agglomeration was also experienced in the first coarse limestone run, an examination of operating data traced the cause to inadequate fluidization around the feed pipe. By raising the velocity to 2 ft/sec in the drain annulus that surrounds the feed pipe, agglomeration was eliminated.

The carbon conversions and gas yields observed in the tests agreed with values predicted by Foster Wheeler's proprietary carbonize computer model; this model is also being used to predict Lakeland plant performance. A portion of the coal nitrogen that is released in the carbonizer is converted to ammonia. Previous testing has shown this conversion to be a function of the feedstocks and operating conditions. Ammonia conversion with the Lakeland coal and limestone ranged from 6.7 to 22.5% of the coal nitrogen released in the carbonizer.

Pilot plant tests were also conducted to determine what increases in sulfur capture efficiency could be achieved by the injection of zinc oxide into the carbonizer syngas upstream of the candle filter. The tests were conducted with the Lakeland 1.4% sulfur Kentucky No 9 coal and limestone; the pulverized zinc oxide was injected as a 5 to 15% by weight water slurry into the gas stream at the top of the carbonizer. The tests showed that large water injections can cause sulfur, already captured as calcium sulfide, to be re-released to the syngas from entrained particulate matter and the ash cake in the candle filter. Despite this effect, with 15 weight per cent zinc oxide slurries it was possible to increase the carbonizer sulfur capture efficiency from 93.7% to over 98%. Although this was achieved at a Zn to syngas sulfur molar feed ratio of 6.5, lower feed ratios would be required if higher slurry densities or dry feeding zinc oxide feeding systems were to be used.

Gas turbine limits on vapor phase alkali levels are in the parts per billion range and, because low alkali levels, high temperatures, and high pressures are involved, these measurements are difficult to make. Using an extractive probe that was designed and supplied by WSTC together with their laboratory handling/analyses procedures, alkali measurements were conducted by Foster Wheeler in the Livingston carbonizer pilot plant. The measurements were made downstream of the ceramic candle filter with the carbonizer operating with the temperature and feedstocks (Kentucky No. 9 coal and Florida limestone) planned for the Lakeland plant. The vapor phase alkali levels measured with the WSTC probe decreased, as expected, with

decreasing gas temperature. Even though the alkali levels were very low, the temperature trend exhibited minimal scatter and the data indicates carbonizer syngas alkali levels should be less than 20 ppbw at 1200°F, a value that should be acceptable to a gas turbine.

The ceramic candle filter operated at about 1300E F. During the first two runs, the filter operated without a pre-cleaning cyclone, and to accommodate the higher solids loading a 1.9 ft/min candle face velocity was used (22 candles were installed in the filter). In the second run, a pre-cleaning cyclone was installed, and the face velocity was increased to about 4 ft/min by reducing the number of candles to 10. In all four runs the filter performed successfully showing no signs of blinding, bridging, or ash hopper agglomeration.

6.0 References

- 3-1 E. Kurkela et al, “Pressurized Fluidized Bed Gasification of Wood, Peat, and Coal – Reseach at Otaniemi PFBC/G Test Facility”, publication source unknown
- 3-2 A. Robertson, et al., “Conceptual Design and Optimization of a Second Generation PFB Combustion Plant,” Report DOE/MC/21023-2825, Vol. 1, Phase 1 Task 1 Topical Report, Prepared by Foster Wheeler Development Corporation under DOE Contract DE-AC21-86MC21023, September 1989.
- 3-3 Y. Daijou et al, “Alkali-Vapor Measurements in the Wakamatsu PFBC Plant”, Proceedings of the 14th International Conference on Fluidized Bed Combustion, Vancouver, 1997

7.0 Bibliography

None Required

8.0 Acronyms and Abbreviations

ACFM	Actual Cubic Feet Per Minute
ID	Inside Diameter
H ₂ S	Hydrogen Sulfide
NH ₃	Ammonia
PCFB	Pressurized Circulating Fluidized Bed
PFB	Pressurized Fluidized Bed
SCE	Sulfur Capture Efficiency
WSTC	Westinghouse Science and Technology Center
ZnO	Zinc Oxide