

Box 13
276

CONDENSED
FINAL REPORT

PG and E GEYSERS RETROFIT PROJECT
UNITS 1 - 12

S-79007

August 24, 1979

Donated By:
Herbert Rogers Jr.
Rogers Engineering Co.

 **ROGERS**
Engineering • San Francisco

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.



ROGERS ENGINEERING CO., INC.
ENGINEERS & ARCHITECTS
111 PINE STREET
SAN FRANCISCO, CALIF. 94111, TEL. (415) 986-6546

In reply refer to:
S-79007

24 August 1979

Mr. J. P. Finney
Pacific Gas and Electric Company
77 Beale Street, Room 1901
San Francisco, CA 94106

Subject: Final Reports
PGandE Geysers Retrofit Project, Units 1-12

Dear Mr. Finney:

We are transmitting to you ten copies of the reports. They are titled:

Executive Summary
Condensed Final Report
Final Report Technical Data Volume 1
Final Report Technical Data Volume 2

These reports represent many weeks of conferences with you and your staff, and discussion of materials presented in previous reports. We do feel that this group of reports can serve your many needs.

It has been a pleasure to work with you on this phase of the project, and we look forward to serving Pacific Gas and Electric Company on additional assignments.

Yours very truly,

H. I. Rogers

H. I. Rogers
Acting Project Manager
Vice President

HIR:ee

Encls. 10 sets

cc: R. P. Wischow w/encls.



Rogers

EXECUTIVE SUMMARY

Pacific Gas and Electric Company Geysers Power Plant Units 1-12 Retrofit Concept Study

CONTENTS

- 1.0 Project
- 2.0 Study Scope
- 3.0 Cost Analysis
- 4.0 Existing Abatement
- 5.0 Alternative Abatement
- 6.0 Cost Benefit Analysis
- 7.0 Summary

Prepared by

Rogers Engineering Co., Inc.
111 Pine Street
San Francisco, California 94111

Job No. S-79007

August 24, 1979



Rogers

EXECUTIVE SUMMARY

1.0 PROJECT

Geysers Power Plant Units 1-12 conceptual study of two H₂S abatement systems.

2.0 STUDY SCOPE

The study is to provide a cost benefit and technical analysis of the existing (iron/caustic/peroxide) abatement system compared to retrofitting Units 1-12 with surface condensers and vent gases processing with the Stretford process.

The study is based on the understanding that both H₂S abatement system compared meet the Air Pollution Board's requirements for H₂S emissions.

3.0 COST ANALYSIS

GM cost estimates were prepared after field investigations and manufacturers' telephone quotations for major pieces of equipment. The GM cost is prepared in June 1979 dollars and also escalated to appropriate times for construction.

The comparative analysis is presented by three methods: Level annual revenue requirements, present worth, and constant dollars. Various parameter sensitivity analyses were performed on the more significant factors.

4.0 EXISTING ABATEMENT

The existing H₂S abatement is an iron/caustic/peroxide system. At this time this system is not fully installed and operating on all units 1-12. The additional capital required to install the total system is 14.9 million dollars.

This system requires various chemicals in its operation. The chemical costs become part of the operating expenses and amount to 10.9 million dollars a year in 1979 dollars at 70 percent capacity factor.

The capacity factor for the Geysers power plant Units 1-12 has been decreasing since the peak 81 percent in 1976. For economic evaluation purposes, 70 and 60 percent capacity factors have been used for the existing abatement study.



Rogers

5.0

ALTERNATIVE ABATEMENT

The alternative H_2S abatement considered in this study is a system using surface condensers and the Stretford process to process the vent gas stack gases. The Units 1-12 would be retrofitted with surface condensers and the vent gases collected and piped to economically located Stretford process plants. This study indicates four Stretford units at different locations would be installed to take vent gases from Units 1-12.

Capital costs estimates have been developed for work to implement the alternative abatement system. They are in the GM form and include all factors. The capital cost for the alternative abatement system in 1979 dollars is estimated to be 119.1 million dollars. The operating costs are estimated to be 2.1 million dollars per year 1979.

The capacity factor for the alternatively abated units is estimated to be equal to or better than the 1976 peak. For economic evaluation purposes, 80 and 85 percent capacity factors have been used for the alternative abatement study capacity factors.

6.0

COST BENEFIT ANALYSIS

The benefit in the analysis is the cost difference between the existing abatement and the alternative abatement. Sensitivity analysis was performed on the three biggest cost items contributing to the difference. In descending order they are: capacity factor (iron system), chemical costs (iron system), and capital costs (surface condenser/Stretford).

The following table presents least benefit in cost between the existing and the alternative abatement system. All values are in millions of 1979. The benefit is substantially in favor of implementing the alternative abatement system.

COST AND BENEFIT COMPARISON
(millions of 1979 dollars)

<u>Item</u>	<u>Case</u>		<u>Benefit</u>
	<u>Existing</u>	<u>Alternative</u>	
Level Annual Revenue			
Requirement	52.2	36.6	15.6
Present Worth	454.3	318.6	135.7
Constant Dollars	36.1	25.5	10.6



Rogers

Project timing was studied and showed an economic benefit to the specified timing of subprojects to implement the surface condenser/Stretford abatement.

<u>Subproject</u>	<u>Back On Line</u>
Unit 9 and 10, and Stretford	January 1982
Unit 7, 8 and 11, and Stretford	January 1983
Unit 1, 2, 3, 4, 5 and 6, and Stretford	January 1984
Unit 12 and Stretford	January 1984

7.0

SUMMARY

It is economical to convert from the existing abatement (iron/caustic/ peroxide) to the alternative (surface condenser/Stretford) by a substantial amount.

There is also a most economical timing sequence to accomplish the conversion to the surface condenser/Stretford abatement. The project if started immediately would be finished and operating by 1984.

It is felt that the surface condenser/Stretford abatement system will ultimately meet the Air Pollution Board's requirements and improve the capacity factor of the Geysers power plant Units 1-12.



ROGERS ENGINEERING CO., INC.
ENGINEERS & ARCHITECTS
111 PINE STREET
SAN FRANCISCO, CALIF. 94111, TEL. (415) 986-6546

In reply refer to:
S-79007

24 August 1979

Mr. J. P. Finney
Pacific Gas and Electric Company
77 Beale Street, Room 1901
San Francisco, CA 94106

Subject: Final Reports
PGandE Geysers Retrofit Project, Units 1-12

Dear Mr. Finney:

We are transmitting to you ten copies of the reports. They are titled:

Executive Summary
Condensed Final Report
Final Report Technical Data Volume 1
Final Report Technical Data Volume 2

These reports represent many weeks of conferences with you and your staff, and discussion of materials presented in previous reports. We do feel that this group of reports can serve your many needs.

It has been a pleasure to work with you on this phase of the project, and we look forward to serving Pacific Gas and Electric Company on additional assignments.

Yours very truly,

H. I. Rogers

H. I. Rogers
Acting Project Manager
Vice President

HIR:ee

Encls. 10 sets

cc: R. P. Wischow w/encls.

CONDENSED
FINAL REPORT


PGandE GEYSERS RETROFIT PROJECT
UNITS 1 - 12

S-79007

August 24, 1979



ROGERS ENGINEERING CO., INC.
ENGINEERS & ARCHITECTS
111 PINE STREET
SAN FRANCISCO, CALIF. 94111



Rogers

TABLE OF CONTENTS - CONDENSED REPORT

		<u>Page</u>
1.0	<u>INTRODUCTION</u>	
	1.1 Purpose	1- 1
	1.2 Scope of Study	1- 1
2.0	<u>SUMMARY AND RECOMMENDATIONS</u>	
	2.1 General Economic View Point	2- 1
	2.2 Existing Abatement (Iron Catalyst/Caustic/Hydrogen Peroxide)	2- 1
	2.3 Alternative Abatement (Surface Condensers/Stretford)	2- 2
	2.4 Cost Benefit Analysis	2- 4
	2.5 Overall Recommendation	2- 5
	2.6 Engineering Services	2- 5
3.0	<u>EXISTING ABATEMENT SYSTEM</u>	
	3.1 Existing Conditions	3- 1
	3.2 Overall Process	3- 7
	3.3 Operations	3- 9
	3.4 Capital Cost	3- 9
	3.5 Remaining Life	3-11
4.0	<u>ALTERNATIVE ABATEMENT</u>	
	4.1 Design Conditions	4- 1
	4.2 Power Plant Capacity Factor	4- 3
	4.3 Cost Estimates	4- 3
5.0	<u>GENERAL ECONOMICS AND COST BENEFIT ANALYSIS</u>	
	5.1 Economic Evaluation	5- 1
	5.2 Cost Estimate Accounts	5- 2
	5.3 Cost Estimates	5- 3
	5.4 Design Selection Evaluation	5- 6
	5.5 Installation Labor Sensitivity	5-10
	5.6 Capacity Factor	5-10
	5.7 Unit Energy	5-11
	5.8 Operation & Maintenance	5-13
	5.9 Capital Cost	5-14
	5.10 Replacement Energy During Construction	5-15
	5.11 Economic Evaluation	5-15
6.0	<u>RECOMMENDATIONS</u>	
	6.1 Timing Analysis Method	6- 1
	6.2 Timing Study Results	6- 3
	6.3 Geysers Power Plant Available Capacity	6- 4
7.0	<u>PROFESSIONAL SERVICES</u>	
	<u>APPENDIX "A"</u>	



Rogers

CONDENSED REPORT

PGandE GEYSERS RETROFIT PROJECT

1.0 INTRODUCTION

The firm of Rogers Engineering Co., Inc. is submitting herewith a cost benefit analysis for Pacific Gas and Electric Company on the hydrogen sulfide abatement systems required at Units 1-12 of the Geysers.

1.1 Purpose

The purpose of this work is to demonstrate whether there is a cost benefit to Pacific Gas and Electric Company in replacing the present iron catalyst/caustic/peroxide system used in the direct contact condenser units with an alternative approach using surface condensers and the Stretford System for hydrogen sulfide abatement.

1.2 Scope of Study

This work is limited to consideration of Units 1 thru 12, and shall use as much as possible data already prepared by PGandE, and with concurrence and cooperation of the various departments of PGandE with respect to the design, construction, and operations of the Geysers Project.

To evaluate the cost and time involved in installing the alternative abatement system (surface condenser/Stretford Process), it was necessary to prepare new process flow sheets, physical arrangements of equipment, cost estimates and construction schedules. It is important to note that for this report the design is a concept. If this project proceeds to final design and purchase of equipment, it will be necessary to pursue the engineering details to a much greater extent than allowed in the scope of work for this report.



Rogers

2.0 SUMMARY AND RECOMMENDATIONS

This section is prepared as an executive summary of the whole report. It also has the recommendations in brief form. Details of all data follow in the body of the report. This conceptual report is to justify the method and approach to assist in making a decision concerning H₂S abatement on Units 1 through 12.

2.1 General Economic Viewpoint

The overview of economic techniques, cost estimate method and economic design selection alternatives are presented. Generally the regular Pacific Gas and Electric GM estimate format has been followed. The accounts are the normal plant accounts used by plant accounting. The economic analysis must be done with equivalent alternatives and is performed using the level annual revenue requirement technique. The GM estimates are prepared in June 1979 dollars and also with estimated escalation to June 1982 the center of gravity of expenditures. General Construction, Engineering, Electric Operations, and Planning and Research all contributed to various aspects of the costs and economics. All figures in the summary are in June 1979 dollars unless otherwise noted. Also all economic analysis is performed in 1979 dollars as requested.

2.2 Existing Abatement

The existing units with the iron catalyst/caustic/peroxide H₂S abatement are presented so that a common base could be established for later comparison. Additional capital costs, operating and maintenance costs and capacity factors are addressed. It is understood that a fully implemented iron catalyst/caustic/peroxide system presently meets the air pollution board requirements. This existing abatement system is Alternative 1, the defender, and the retrofit with surface condensers and Stretford system vent gas treatment is Alternative 2, the challenger.

Analysis of the overall Geysers Power Plant capacity factor shows it to be decreasing. The highest calculated annual capacity factor was 81 percent and the lowest 65 percent to date. It is not possible to attribute all changes in capacity factor to abatement. Full time, complete abatement has only been on a relatively short time on a few units. The capacity factor can be stated for past plant operations and projections made from trends established. Recognizing the limitations of analyzing the total plant capacity factors versus those for analyzing individual units or groups of units, the calculated annual capacity factor range for the abated group and the unabated group is 62-76 percent and 68-84 percent respectively. The



Rogers

existing abatement system will be evaluated at both 60 and 70 percent capacity factors in the cost analysis. The long term mature unabated existing plants have demonstrated an ability to achieve 80 percent and even 85 percent. Capacity factor data is developed in Section 3.1.3.

The capital cost to implement the iron catalyst/caustic/peroxide abatement system fully on all units is estimated to be 14.9 million dollars over and above the 18.9 million already invested in the abatement facilities. See Table 3-9.

The costs for chemicals will amount to an estimated 10 million dollars per year and is included as part of the operating cost. Maintenance costs are estimated to be about double the unabated units.

Although this abatement method is very severe on the plant equipment it is estimated that continued high maintenance will keep the plants going. Replacement in kind is not envisioned.

2.3 Alternative Abatement

The alternative, considered in this report, to the iron catalyst/caustic/peroxide abatement is the retrofit of units 1 through 12 with surface condensers and the installation of various Stretford process plants to treat the vent gases and remove the sulfur. Various combinations of Stretford process plants are studied.

Recent tests at Unit 15 are not conclusive with respect to the Surface Condenser/Stretford abatement system meeting the air pollution requirements. However, it is believed this approach will prove satisfactory with further experience.

Each typical unit has been studied with regard to performance, equipment arrangement, and capital cost estimates. The typical units are:

<u>Typical</u>	<u>Typical For</u>
1	1 and 2
3	3 and 4
5	5, 6, 7, 8, 9 and 10
11	11 and 12

In a few cases individual units were addressed since there were arrangement or performance differences which affected costs.



Rogers

The capacity factor for the retrofit is dependent on the natural long term capacity factor of the power plant unit in combination with the Stretford units capacity factor. In Sections 3.1.3 and 4.2 the respective capacity factors are presented. Two overall capacity factors are used in the economic evaluation: 80 and 85 percent.

The total capital cost estimate is in the standard GM Form. This whole report is conceptual in nature as the final designs and drawings are not made. Telephone quotations of major equipment were obtained and field investigations by qualified persons developed the other costs. In the following tabulation, the GM 1979 is without escalation and GM with escalation is to June 1982.



Rogers

COST TO RETROFIT WITH SURFACE CONDENSERS AND STRETFORD PROCESS

Surface Condenser Retrofit

<u>Unit</u>	<u>GM 1979</u>	<u>GM With Escalation</u>
1	\$ 2,042,712	\$ 2,631,912
2	2,042,712	2,631,912
3	3,899,308	5,012,558
4	3,899,308	5,012,558
5	6,066,641	7,798,667
6	6,066,641	7,798,667
7	6,066,641	7,798,667
8	6,066,641	7,798,667
9	6,066,641	7,798,667
10	6,066,641	7,798,667
11	12,116,789	15,576,132
12	<u>12,116,789</u>	<u>15,576,132</u>
Subtotal	\$ 72,517,464	\$ 93,233,206

Stretford Systems

1-6	\$ 17,572,146	\$ 22,588,993
7, 8, 11	17,464,697	22,450,867
9, 10	5,634,310	7,242,906
12	<u>5,916,141</u>	<u>7,605,199</u>
Subtotal	\$ 46,587,294	\$ 59,887,965
Total	\$119,104,758	\$153,121,171
	=====	=====

Engineering, Procurement and Construction critical path schedules have been developed to determine the length of time required to implement the retrofit on each typical unit. Also, of critical importance to the economic evaluation is the required unit outage time to implement the retrofit. Generally, each total project takes 30 months from the start of engineering to end of restart of the unit. Outage times range from 8 - 11 months for specific units.

2.4 Cost Benefit Analysis

This is a comparison of the existing iron catalyst/caustic/peroxide system with the retrofit of units with surface condenser/Stretford Process in terms of 1979 dollars. The retrofit units with the



Rogers

Stretford Process is considerably more economic. The closest the iron method comes is 1.43 times the retrofit evaluated cost. The level annual revenue requirement is about 36,644,000 dollars for the surface condenser/Stretford Process retrofit and 52,240,000 dollars for the iron catalyst/caustic/peroxide method. The estimated minimum benefit is 15,596,000 dollars per year.

The largest cost factor in the evaluation is the cost of energy due to the iron catalyst/caustic/peroxide system's anticipated capacity factor. The second largest cost is cost of chemicals to keep the iron system operating and the third largest cost in the analysis is the capital to retrofit the units with surface condensers and install the Stretford units.

2.5 Overall Recommendation

The overall recommendation is to proceed with a series of projects to retrofit all existing Units 1-12 with surface condensers and various combinations of Stretford processes based upon the information in this study.

There is an economic sequence of the subprojects as described in Section 6 of this report. The timing economics are based upon a 10 percent difference in capacity factor between existing and retrofit abatement. The capacity factor is the largest single factor in determining the timing. The economic sequence shows Units 9 & 10 operational in 1981, Units 7, 8 and 11 operational in 1983, and Units 1, 2, 3, 4, 5, 6 and 12 operational in 1984.

2.6 Professional Services

The estimated professional services costs are included in each individual unit's cost estimate under Account 365, Other Engineering. The engineering services total based upon the 1979 total construction cost of 119.1 million is 7.1 million dollars.

If the economic timing sequence is followed Units 9 & 10 and the associated Stretford engineering, procurement and construction support services needs to start immediately. The retrofitting of Units 9 & 10 and the subsequent restarting the units must be delayed one year past the economic time because of delivery time of condenser and the required installation time. All other units can follow the economic timing.



Rogers

3.0

EXISTING ABATEMENT SYSTEM

Methods to control the hydrogen sulfide emissions from the Geysers Power Plant were initiated in 1971. The addition of a metal catalyst (ferric iron) to the circulating cooling water was selected for large scale tests at Units No. 1 and 2. Currently, in addition to the iron sulfate catalyst, caustic soda and hydrogen peroxide are being introduced on a full-time basis to maximize the abatement on Units 3, 4, 5, 6, 11 and 12. Additionally interim abatement on Units 2, 8, 9, 10 is being used at specified times.

3.1

Existing Conditions

It is our understanding, that Units 1, 2, 7, 8, 9 and 10 operate under a variance to the air pollution standards, and the iron catalyst/caustic/hydrogen peroxide system will accomplish the level of abatement required by the Air Pollution Board.

3.1.1

Historic Abatement

The historic data of time and type of abatement is important when evaluating the existing units. The abatement methods have affected the power plant unit operations and the equipment in each unit so treated. Table 3-1 summarizes by unit the abatement facilities installed to date. Each unit has a varying amount of abatement, and it was put on at differing times in the useful life of the equipment. The units which are not being abated 100% of the time are only abated when the air pollution officer requests. Up to this point in the concept study, we could not determine how many hours per year Units 2, 8, 9 and 10 abatement have actually been operating.



Rogers

TABLE 3-1

H₂S HISTORIC ABATEMENT

<u>Unit</u>	<u>Commercial Operation</u>	<u>H₂S Abatement</u>	<u>Remarks</u>
1	9/25/60	-	None
2	3/19/63	6/78	June-Oct. Interim Time Iron Catalyst
3	4/28/67	12/76 1/79	100% Time Iron Catalyst 100% Time Iron Catalyst with Caustic and Hydrogen Peroxide
4	11/ 2/68	9/76 1/79	100% Time Iron Catalyst 100% Time Iron Catalyst with Caustic and Hydrogen Peroxide
5	12/15/71	1/78 1/79	100% Time Iron Catalyst 100% Time Iron Catalyst with Caustic and Hydrogen Peroxide
6	12/15/71	1/78 1/79	100% Time Iron Catalyst 100% Time Iron Catalyst with Caustic and Hydrogen Peroxide
7	8/18/72	-	None
8	11/23/72	6/78	June-Oct Interim Time Iron Catalyst
9	10/15/73	6/78	June-Oct Interim Time Iron Catalyst Plus Caustic
10	11/30/73	6/78	June-Oct Interim Time Iron Catalyst Plus Caustic
11	5/31/75	1/77 1/79	100% Time Iron Catalyst 100% Time Iron Catalyst Caustic and Hydrogen Peroxide
12	3/1/79	3/79	100% Time Abatement Iron Catalyst and Caustic, Hydrogen Peroxide



Rogers

3.1.2 Existing Abatement

The existing units have the following abatement facilities installed as of June 1979:

- Unit 1 - No permanent abatement equipment - only abatement testing program
- Unit 2 - Operating intermittently using only ferric iron
- Unit 3 - Using ferric iron, caustic and hydrogen peroxide-continuous abatement
- Unit 4, 5 & 6 - Same as Unit 3
- Unit 7 - Up stream EIC and Coury Process - tests continuing
- Unit 8 - Intermittent abatement only ferric iron
- Unit 9 - Intermittent abatement only ferric iron with caustic
- Unit 10 - Same as Unit 9
- Unit 11 - Continuous abatement using ferric iron, caustic and hydrogen peroxide
- Unit 12 - Same as Unit 11

3.1.3 Capacity Factor

Geysers power plant units are operated as a base load plant, that is they are on line and fully loaded all the time regardless of system load. Therefore, the capacity factor is indicative of how well a unit is performing. Many factors affect the capacity factor, and it is difficult to indicate the exact causes of a low capacity factor even though outage and curtailment records are kept.

Two questions are of greatest importance. What has been the highest capacity factor at which existing units have operated unabated? What has been the capacity factor of H_2S abated units since abatement has started? These are difficult questions, and it is not possible to attribute all changes in capacity factor to abatement. Full time complete abatement has been only on a relatively small number of units and for a short period of time. The capacity factor can only be "stated" for the past plant operations and what they are operating at today.

Available capacity factor data has been analyzed by statistical methods: least square, mean, and median. It is essential to build confidence in a tool before it is used for predictions. The following Table 3-2 illustrates the accuracy of the methods to approximate the annual capacity factor. The mean is the average value of capacity factor taking into account all the capacity factor values. The median is the statistically calculated capacity factor value at which an equal number of capacity factor values occur below and above the calculated value.



Rogers

Many calculations and combinations of calculations have been made to study capacity factors of individual units and of the overall Geysers plant. Tables 3-2, 3-3 and 3-4 are summaries of part of the analysis. Trends have been statistically developed (least squares) from Table 3-3 using 1975 through 1978 data and 1975 through April 1979 data. Table 3-5 (graph of least squares trend) indicates the capacity factor trend of the overall Geysers total plant and the subset of units with abatement.

The capacity factor difference between existing units abated and unabated has been addressed by others and was not a part of this conceptual work. However based on the results in this report, the economic evaluations have been made at 60 and 70 percent capacity factor for abated units with the iron/caustic/peroxide abatement and 80 and 85 percent capacity factors for units with surface condenser/Stretford abatement.



Rogers

TABLE 3-2
COMPARISON OF METHODS
ANNUAL CAPACITY FACTOR ANALYSIS
(1977)

<u>Unit</u>	<u>Actual¹ Annual Capacity Factor</u>	-----Calculated-----		
		<u>Least Square</u>	<u>Mean</u>	<u>Median</u>
1	67.7	67.7	67	65
2	86.3	86.3	85	85
3	57.2	57.4	57	60
4	76.1	76.1	75	78.3
5	87.5	87.5	87	95.7
6	78.0	77.7	77	85
7	83.8	83.8	83	90
8	82.4	82.5	82	88
9	92.0	92.0	92	92.9
10	95.2	95.2	94	95
11	74.0	74.0	74	77.5
A	-	-	84	80.0
B	-	-	84	89.6
C	-	80.0	79	85.8

¹Annual capacity factor from Operating Dept.

A Combination of Units 3, 4, 5, 6, 11 (Existing Abatement)
B Combination of Units 1, 2, 7, 8, 9, 10 (Not Abated)
C All units combined



Rogers


TABLE 3-3
ANNUAL CAPACITY FACTORS
(Least Square)

<u>Units</u>	<u>1975</u>	<u>1976</u>	<u>1977</u>	<u>1978</u>	<u>1979*</u>
1	76	78	67	50	68.3
2	53	76	85	67	58.3
3	74	70	57	38	44.5
4	53	65	75	52	48.3
5	84	86	87	82	62.0
6	82	90	77	84	59.5
7	79	88	83	78	62.0
8	77	90	82	59	82.0
9	90	87	92	78	90.8
10	95	86	94	77	97.8
11	47	71	74	54	68.3
<hr/>					
A	68	76	74	62	56.5
B	78	84	84	68	76.4
C	74	81	79	65	67.3

TABLE 3-4
ANNUAL CAPACITY FACTORS
(Median)

<u>Units</u>	<u>1975</u>	<u>1976</u>	<u>1977</u>	<u>1978</u>	<u>1979*</u>
1	80.0	86.0	65.0	57.0	68.3
2	52.8	85.0	85.0	75.0	55.0
3	80.0	75.0	60.0	35.0	30.0
4	55.0	68.8	78.3	50.0	45.0
5	91.7	92.1	95.7	83.3	50.0
6	95.0	93.3	85.0	86.3	55.0
7	87.5	89.0	90.0	76.7	75.0
8	86.5	91.7	88.0	72.5	85.0
9	91.7	93.8	92.9	87.5	90.0
10	96.3	92.9	95.0	85.0	97.5
11	45.0	80.0	77.5	70.0	60.0
<hr/>					
A	79.0	82.5	80.0	71.7	60.0
B	86.3	90.0	89.6	75.7	80.0
C	83.5	88.2	85.8	74.5	69.0


*Developed from partial year data



DATA 1975-1978

LEGEND

C - TOTAL PLANT
A - ABATED UNITS



DATA 1975-4/79



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111

JOB NO. S-79007

DG-023

CAPACITY FACTOR
STATISTICAL TRENDS

DRAWING NO.

REV.

TABLE 3-5

SHEET

OF




Rogers

3.2 Overall Process

In order to compare the existing abatement system as applied to the direct contact condensers, the chemical feed (budget data) was examined for Units 3, 4, 5, 6, 11 and 12. The molar ratio of ferric iron, caustic soda and hydrogen peroxide were compared with the mols of hydrogen sulfide in the incoming steam and an average chemical input ratio was developed. For the purposes of this report, these chemical values can then be prorated for all Units 1 thru 12, so as to cost out the placement of a continuous abatement program onto each unit, which theoretically could provide the abatement necessary to meet the air quality standards.

The overall process for each of the first twelve units in block diagram is as follows:



The chemical requirements for each unit are summarized in Table 3-6 and 3-7. The chemical quantities required are dependent on the units' capacity factor. Two capacity factor levels are presented: the 60 percent which plants are now operating, and the 70 percent which is anticipated to be the long range best capacity factor obtainable with this abatement system.



Rogers

TABLE 3-6

IRON CATALYST ABATEMENT CHEMICALS
(60 Percent Capacity Factor)

<u>Unit</u>	<u>Iron #/hr.</u>	<u>NaOH 100% #/hr.</u>	<u>H₂O₂ Gal./hr.</u>	<u>Sludge yd.³/yr.</u>
1	12.8	14.2	22.8	180
2	12.8	14.2	22.8	180
3	58.4	67.9	109.5	1,367
4	58.4	67.9	109.5	756
5	116.8	135.8	219	1,451
6	146.0	135.8	219	2,073
7	90.6	100.9	162.5	1,267
8	41.6	56.1	90.4	670
9	22.4	25.0	40.2	313
10	27.3	30.4	49.0	382
11	219.0	271.6	438	3,622
12	<u>110.7</u>	<u>123.3</u>	<u>198.7</u>	<u>1,549</u>
Total	916.8	1,043.1	1,681.4	13,810

TABLE 3-7

IRON CATALYST ABATEMENT CHEMICALS
(70 Percent Capacity Factor)

<u>Unit</u>	<u>Iron #/hr.</u>	<u>NaOH 100% #/hr.</u>	<u>H₂O₂ Gal/hr.</u>	<u>Sludge yd.³/hr.</u>
1	14.9	16.6	26.6	210
2	14.9	16.6	26.6	210
3	68.1	79.2	127.8	1,595
4	68.1	79.2	127.8	882
5	136.3	158.4	255.5	1,693
6	170.3	158.4	255.5	2,418
7	105.7	117.7	189.6	1,478
8	48.5	65.4	105.5	782
9	26.1	29.2	46.9	365
10	31.8	35.5	57.2	446
11	255.5	316.9	511.0	4,226
12	<u>129.2</u>	<u>143.8</u>	<u>231.8</u>	<u>1,807</u>
Total	1,067.4	1,216.9	1,961.8	16,112



Rogers

3.3 Operations

As described in 3.2, Overall Process, above the chemical feed ratios between unit hydrogen sulfide feed input and chemicals, sludge production, etc. can be applied to the capacity factor (each unit separately) and thence calculate the related cost for operating chemicals, sludge disposal.

TABLE 3-8

IRON CATALYST/CAUSTIC/PEROXIDE
CHEMICAL COSTS
(1979 Dollars Per Year)

<u>Units</u>	<u>60% Capacity Factor</u>	<u>70% Capacity Factor</u>
1	\$ 131,500	\$ 153,400
2	131,500	153,400
3	632,200	737,600
4	627,000	731,500
5	1,214,400	1,416,800
6	1,256,400	1,465,800
7	882,500	1,029,600
8	490,900	572,700
9	216,100	252,100
10	272,100	317,400
11	2,432,400	2,837,800
12	<u>1,076,800</u>	<u>1,256,300</u>
Total	\$9,363,800	\$10,924,400
	=====	=====

3.4 Capital Cost

For the purpose of this report, the actual field installation costs were examined for the existing abatement facilities. (Units 3, 4, 5, 6, 11 and 12). These costs were then prorated and projected for facility costs for each unit (1, 2, 7, 8, 9 and 10) which do not have complete abatement installations. The existing column was derived from GM Estimate 186422R2, and the Research and Development allocation for caustic and peroxide facilities, all except for Unit 12, which is based on Unit 11. The "additional capital" is the estimated amount required to bring all existing units up to a common level of abatement using the iron catalyst/caustic/ peroxide systems. These costs are estimated in June 1979 dollars.

Table 3-9 is a summary of the past and additionally required capital costs for the iron/caustic/peroxide abatement system.



Rogers

TABLE 3-9

EXISTING H₂S ABATEMENT CAPITAL COST
(Dollars x 1,000)

<u>Unit</u>	<u>Existing</u>	<u>Additional GM 1979</u>	<u>Total</u>
1 & 2	-	2,302	2,302
3 & 4	\$ 4,950	-	4,950
5 & 6	2,415	-	2,415
7 & 8	-	6,327	6,327
9 & 10	-	6,327	6,327
11	5,794	-	5,794
12	<u>5,794</u>	<u> </u>	<u>5,794</u>
Totals	\$18,953	\$14,956	\$33,909
	<u>=====</u>	<u>=====</u>	<u>=====</u>

The GM Estimate total for the additional is calculated as follows:

<u>Item</u>	<u>Dollars x 1000</u>
Direct Costs	\$12,391
GM Factor @ 20.7%	<u>2,565</u>
Sub Total (GM 1979)	\$14,956
Escalation @ 28.55%	<u>4,270</u>
Total GM Estimate	\$19,226
	<u>=====</u>



Rogers

3.5

Remaining Life

Effect of Existing Abatement on Equipment Life

One problem developed by the existing abatement is that oxidation of the sulfur cannot be selectively stopped when free sulfur is produced. The reaction also produces some sulfites and sulfates. The existing equipment was constructed using 304 SS, and the expected equipment life was probably over 50 years. With the addition of the existing abatement system however, the sulfites, sulfates and oxygen corrode 304 SS in a manner described as "pit" corrosion.

Corrosion testing was initiated in about 1973, and the initial findings were reported by Dodd and Ham on 22 January 1975.

Tubular Type Heat Exchangers and Piping

The corrosion data without iron catalyst in the cooling water indicate very little loss of metal from 304 SS; measured value less than 0.0001 inch/year. With iron, the general corrosion increased to 0.0007 inch/year and the pitting action was at a rate of 0.005 inch/year on an unsensitized specimen. Assuming that 22 gauge heat exchanger tubing is the thinnest construction material and that a 30% thickness loss is allowable prior to replacement, the following can be calculated:

Normal life expectancy:

22 Ga. is 0.028 inch thick

$0.028 \times 0.30 = 0.0084$ allowable loss

$0.0084 \div 0.0001$ inch/year = 84 years

With iron $0.0084 \div 0.0007 = 12$ years

With iron and pitting $0.0084 \div 0.005 = < 2$ years

Based on the above values, it might be necessary to replace some tubular type heat exchanger tubes on every unit turnaround (2 year interval), and some piping may require patching. Testing has also been conducted on Carpenter alloy 20 cb 3, and the test data indicate this material is not corroded by the sulfur acids. Thus, equipment replacement should be based on the use of this alloy, which will give an additional useful life of over fifty years in this type of H₂S abatement service. This replacement has been accounted for in this study by doubling the regular replacement cost.



Rogers

Cooling Tower

The effect of the sulfur acids and excess iron and sulfur sludge on the cooling tower is such that a complete reconditioning will be required every unit turnaround (2 year interval). During this 2 year run, it is estimated that the cold water temperature will increase 1°F. The result will be an increase in turbine exhaust hood pressure of 0.075 psi (0.15 in. Hg Abs.). The resulting loss in turbine heat drop will be 2.175 Btu/lb. steam flow. Assuming 77% overall turbo-generator efficiency, the power loss will be about 0.0005 kW/lb. steam flow. This figure will be used to calculate the generation capacity loss during the run. It is included in Table 5-3 and associated tables.

Pumps

It is assumed that all pumping requirements for cooling water and auxiliary water will not be affected during the operation between turnaround.

3.6 Existing Abatement System Summary

This section presents the parameters involved with retrofitting the existing Units 1-12 with the iron oxide/caustic/peroxide. As this is the condensed report only the results are presented of the most significant elements. See Table 3-10.



Rogers

TABLE 3-10
ALTERNATIVE 1: EXISTING ABATEMENT

Unit	Design Gross kW	Net kW	Annual MWH @ 60%	Annual MWH @ 70%	GM Estimated Cost 1979	O & M Cost 1979 \$/yr. @ 60%	O & M Cost 1979 \$/yr. @ 70%	Schedule (Months)
1	12,500	12,098	63,587	74,185	2,302,000	155,300	172,700	-
2	12,500	12,115	63,676	74,289		155,300	172,700	-
3	27,500	26,500	139,284	162,498		747,800	831,400	-
4	27,500	26,500	139,284	162,498		740,900	823,800	-
5	55,000	53,020	278,673	325,119		1,435,400	1,595,900	-
6	55,000	53,020	278,673	325,119		1,484,200	1,650,200	
7	55,000	53,020	278,673	325,119	6,327,000	1,042,300	1,158,900	-
8	55,000	53,020	278,673	325,119		579,300	644,100	-
9	55,000	53,020	278,673	325,119	6,327,000	255,200	283,700	-
10	55,000	53,020	278,673	325,119		321,400	357,300	-
11	110,000	106,000	557,136	649,992		2,874,400	3,195,900	-
12	110,000	106,000	557,136	649,992		1,272,300	1,414,600	-
CT. DED.			(13,878)	(16,191)	-	-	-	
Total	630,000	607,333	3,178,263	3,707,977	14,956,000	11,063,800	12,301,200	



Rogers

4.0

ALTERNATIVE ABATEMENT

This section presents the parameters involved with retrofitting the existing Units 1-12 with surface condensers and installing various combinations of Stretford units to process the vent gases from the power plant units. As this is the condensed report only the results are presented of the most significant elements.

4.1

Design Conditions

Table 4-1 is the summary of the conceptual designs. All values are after retrofit is completed. It indicates the new design gross kilowatt output, the net kilowatt output and the annual net outputs at two capacity factors. The capital cost estimate total is presented in 1979 dollars. Operations and Maintenance cost differences from the existing design is tabulated. A schedule was created for each typical unit type in this study and the results are tabulated. The Total Project is the time in months to provide the engineering, procurement and construction. The total construction time and the unit outage time are indicated. The outage time was used in the calculation of construction outage energy.

The lower half of the Table 4-1 presents the summary information about Stretford Processes. It was determined there was an economic benefit for each of the combinations of Stretford units and their locations. The shorthand notation Stretford 1-6 means a single Stretford unit serving all Units 1-6 located near Unit 3 but not at the Unit 3 & 4 site. The shorthand notation Stretford 7, 8, 11 means a single Stretford unit serving units 7, 8 and 11 with it located at Unit 11. A single Stretford unit was economic for Unit 9 & 10 as was a single Stretford unit for Unit 12. All the Stretford costs are summarized in the table as well as the construction times.



Rogers

TABLE 4-1

ALTERNATIVE 2 - RETROFIT UNITS

Design Unit	Gross kW	Net kW	Annual MWH @ 80%	Annual MWH @ 85%	GM Estimate Cost 1979 \$	Operation & Maintenance Cost LA \$/yr.	Schedule (Months)		
							Total Project (Months)	Construction (Months)	Unit Outage (Months)
Surface Condenser Retrofit									
1	11,845	11,339	79,464	84,430	2,042,712	0	28.0	9.0	8.0
2	11,974	11,495	80,557	85,592	2,042,712	0			
3	26,817	25,661	179,832	191,072	3,899,308	0	28.0	9.0	8.0
4	26,817	25,661	179,832	191,072	3,899,308	0			
5	54,101	52,005	364,451	387,229	6,066,641	0	30.0	10.5	9.3
6	54,101	52,005	364,451	387,229	6,066,641	0			
7	54,101	51,988	364,332	387,103	6,066,641	0	30.0	10.5	9.3
8	54,101	51,988	364,332	387,103	6,066,641	0			
9	54,101	52,078	364,963	387,773	6,066,641	0	30.0	10.5	9.3
10	54,101	52,078	364,963	387,773	6,066,641	0			
11	108,147	103,729	726,933	772,366	12,116,789	0	32.0	12.0	11.3
12	108,147	102,801	720,429	765,456	12,116,789	0	32.0	12.0	11.3
Totals	618,353	592,828	4,154,539	4,414,198	72,517,464				

Stretford

			(Minus)	(Minus)					
1-6	x	x	(9,329)	(9,329)	17,572,146	1,911,874	30.0	9.3	8.7
7, 8, 11	x	x	(9,592)	(9,592)	17,464,697	1,953,136	30.0	9.3	8.7
9, 10	x	x	(1,050)	(1,050)	5,634,310	325,046	28.0	8.3	7.7
12	x	x	(1,050)	(1,050)	5,916,141	342,698	28.0	8.3	7.7
Totals	618,353	592,828	(21,021)	(21,021)	46,587,294	4,532,754			
Grand Total	618,353	592,828	4,133,518	4,393,177	119,104,758	4,532,754			



Rogers

4.2 Power Plant Capacity Factor

The capacity factor of the retrofit power plant units with surface condensers is estimated to be the same as the long term mature unabated capacity factor of existing units. This factor has been demonstrated to be 80 percent overall and it is anticipated could reach 85 percent in the long term. Both of these values are used in the economic evaluations of Section 5. In Section 3.1.3 is a discussion of the existing plant capacity factors.

4.3 Cost Estimates

Cost estimates have been made for each typical power plant unit and each Stretford installation separately. The summaries are presented by account number. The cost estimates are typical for the units as follows:

<u>Estimate Unit</u>	<u>Typical for Each Unit</u>
1	1 and 2
3	3 and 4
5	5, 6, 7, 8, 9, 10
11	11 and 12



Rogers

4.3.1 Unit 1 Estimate Summary

TABLE 4-2

SUMMARY COST ESTIMATE - UNIT 1

<u>Account</u>	<u>Description</u>	<u>Equip. & Mat'l</u>	<u>Labor</u>	<u>Total</u>
54-20	Condensate System	\$ 690,124	\$282,354	\$ 972,478
54-30	Circ. Water System	264,576	80,932	345,508
54-70	Instrumentation	16,790	18,171	34,961
55-30	Control & Power Conn.	3,943	17,472	21,415
55-60	Station Power System	19,716	16,214	35,930
365	Engineering & Other	<u>281,120</u>	<u>0</u>	<u>282,120</u>
	Subtotals	<u>\$1,277,269</u>	<u>\$415,143</u>	<u>\$1,692,412</u>
	GM Factor (20.7%)			<u>350,300</u>
	Subtotal (GM 1979)			<u>2,042,712</u>
	Escalation (28.55%)			<u>589,200</u>
	Total GM Estimate			<u>\$2,631,912</u>



Rogers

4.3.2 Unit 3 Estimate Summary

TABLE 4-3

SUMMARY COST ESTIMATE - UNIT 3

<u>Account</u>	<u>Description</u>	<u>Equip. & Mat'l</u>	<u>Labor</u>	<u>Total</u>
54-20	Condensate System	\$1,392,331	\$514,200	\$1,906,532
54-30	Circ. Water System	521,138	167,253	688,392
54-70	Instrumentation	19,080	19,352	38,432
55-60	Station Power System	39,432	19,352	58,784
365	Engineering & Other	<u>538,440</u>	<u>0</u>	<u>538,440</u>
	Subtotals	\$2,510,422	\$720,157	\$3,230,579
	GM Factor (20.7%)			<u>668,730</u>
	Subtotal (GM 1979)			3,899,308
	Escalation (28.55%)			<u>1,113,250</u>
	Total GM Estimate			<u>\$5,012,558</u>



Rogers

4.3.3 Unit 5 Estimate Summary

TABLE 4-4

SUMMARY COST ESTIMATE UNITS 5 THROUGH 10
(Each Unit)

<u>Account</u>	<u>Description</u>	<u>Equip. & Mat'l</u>	<u>Labor</u>	<u>Total</u>
51-20	Building	\$ 0	\$ 14,910	14,910
54-20	Condensate System	2,241,646	969,926	3,211,572
54-30	Circ. Water System	224,508	318,696	543,204
54-70	Instrumentation	25,440	20,501	45,941
55-60	Station Power System	34,344	86,430	120,774
365	Engineering & Other	<u>960,000</u>	<u>0</u>	<u>960,000</u>
	Subtotals	\$3,485,938	\$1,410,463	\$4,896,401
	GM Factor (23.9%)			<u>1,170,240</u>
	Subtotal (GM 1979)			6,066,641
	Escalation (28.55%)			<u>1,732,026</u>
	Total GM Estimate			\$7,798,667
				=====



Rogers

4.3.4 Unit 11 Estimate Summary

There are two estimates for Unit 11 typical retrofit. The first is to install the condensers perpendicular to the centerline of the turbine. The second is to install the condenser parallel with the centerline of the turbine. The least costly will be used in the carry on work. Telephone quotes indicated the two pass parallel condenser to cost the same as the four pass perpendicular condenser.

TABLE 4-5

SUMMARY COST ESTIMATE - UNIT 11
(Tube Bundle Perpendicular to Turbine Shaft)

<u>Account</u>	<u>Description</u>	<u>Equip. & Mat'l</u>	<u>Labor</u>	<u>Total</u>
51-20	Building	\$ 11,448	\$ 33,547	44,995
54-20	Condensate System	4,437,245	1,557,138	5,994,383
54-30	Circ. Water System	1,107,912	850,322	1,958,234
54-70	Instrumentation	34,471	41,937	76,405
55-60	Station Power System	67,416	37,274	104,690
56-10	Compressed Air System	2,544	27,956	30,500
365	Engineering & Other	<u>1,641,841</u>	<u>0</u>	<u>1,641,841</u>
	Subtotals	\$7,302,877	\$2,548,171	\$9,851,048
	GM Factor (23.0%)			<u>2,265,741</u>
	Subtotal (GM 1979)			12,116,789
	Escalation (28.55%)			3,459,343
	Total GM Estimate			<u>\$15,576,132</u>



Rogers

TABLE 4-6
SUMMARY COST ESTIMATE - UNIT 11
(Tube Bundle Parallel to Turbine Shaft)

<u>Account</u>	<u>Description</u>	<u>Equip. & Mat'l</u>	<u>Labor</u>	<u>Total</u>
51-20	Building	\$ 19,080	\$ 147,700	\$ 166,780
54-20	Condensate System	4,437,245	1,557,138	5,994,383
54-30	Circ. Water System	1,102,570	838,208	1,940,778
54-40	Lube Oil System	22,642	80,140	102,782
54-70	Instrumentation	35,107	46,593	81,700
55-60	Station Power System	70,087	47,059	117,146
56-10	Compressed Air System	10,812	67,560	78,372
365	Engineering & Other	<u>1,696,320</u>	<u>0</u>	<u>1,696,320</u>
	Subtotals	\$7,393,862	\$2,784,398	\$10,178,260
	GM Factor (23.0%)			<u>2,340,999</u>
	Subtotal (GM 1979)			12,519,259
	Escalation (28.55%)			<u>3,574,248</u>
	Total GM Estimate			\$16,093,507
				=====



Rogers

4.3.5 Stretford Unit 1-6 Estimate Summary

TABLE 4-7

SUMMARY COST ESTIMATE

STRETFORD UNIT FOR POWER PLANT UNITS 1-6

<u>Account</u>	<u>Description</u>	<u>Mat'l & Equip.</u>	<u>Labor</u>	<u>Total Dollars</u>
54-29	H ₂ S Abatement 1-6	\$11,872,723	\$1,164,545	\$13,037,269
365	Engineering & Other	<u>1,394,520</u>	<u>0</u>	<u>1,394,520</u>
	Subtotals	\$13,267,243	\$1,164,545	\$14,431,789
	GM Factor (21.76%)			<u>3,140,357</u>
	Subtotal (GM 1979)			17,572,146
	Escalation (28.55%)			<u>5,016,847</u>
	Total GM Estimate			\$22,588,993
				<u>=====</u>



Rogers

4.3.6 Stretford Unit 7, 8, 11 Estimate Summary

TABLE 4-8

SUMMARY COST ESTIMATE

STRETFORD UNIT FOR POWER PLANT UNITS 7, 8 &11

<u>Account</u>	<u>Description</u>	<u>Mat'l & Equip.</u>	<u>Labor</u>	<u>Total Dollars</u>
54-29	H ₂ S Abatement	\$11,789,716	\$1,323,707	\$13,113,423
365	Engineering & Other	<u>1,230,120</u>	<u>0</u>	<u>1,230,120</u>
	Subtotal	\$13,019,836	\$1,323,707	\$14,343,543
	GM Factor (21.76%)			<u>3,121,154</u>
	Subtotal (GM 1979)			17,464,697
	Escalation (28.55%)			<u>4,986,170</u>
	Total GM Estimate			\$22,450,867
				<u>=====</u>



Rogers

4.3.7 Stretford Units 9, 10 and 12 Estimate Summary

TABLE 4-9

SUMMARY COST ESTIMATE

STRETFORD UNIT FOR POWER PLANT UNITS 9 & 10

<u>Account</u>	<u>Description</u>	<u>Mat'l & Equip.</u>	<u>Labor</u>	<u>Total Dollars</u>
54-29	H ₂ S Abatement	\$ 3,584,280	\$620,703	\$ 4,204,983
365	Engineering & Other	<u>422,407</u>	-	<u>422,407</u>
	Subtotal	\$ 4,006,687	\$620,703	\$ 4,627,390
	GM Factor (21.76%)			<u>1,006,920</u>
	Subtotal (GM 1979)			<u>5,634,310</u>
	Escalation (28.55%)			<u>1,608,596</u>
	Total GM Estimate			\$ 7,242,906
				=====

TABLE 4-10

SUMMARY COST ESTIMATE

STRETFORD UNIT FOR POWER PLANT UNIT 12

<u>Account</u>	<u>Description</u>	<u>Mat'l & Equip.</u>	<u>Labor</u>	<u>Total Dollars</u>
54-29	H ₂ S Abatement	\$ 3,763,567	\$651,751	\$ 4,415,318
365	Engineering & Other	<u>443,536</u>	-	<u>443,536</u>
	Subtotal	\$ 4,207,103	\$651,751	\$ 4,858,854
	GM Factor (21.76%)			<u>1,057,287</u>
	Subtotal (GM 1979)			<u>5,916,141</u>
	Escalation (28.55%)			<u>1,689,058</u>
	Total GM Estimate			\$ 7,605,199
				=====



Rogers

5.0

GENERAL ECONOMICS AND COST BENEFIT ANALYSIS

The economic techniques, cost estimate methods and design selection parameters which apply in general to work performed in this report. Each area of costs or economics has assumptions and ground rules in order for the results to be consistent. These will be explained as applicable to this report. The cost benefit analysis follows the general economic conditions. The results of each system to be compared are analyzed on the Level Annual Revenue Requirement (LARR) basis. This method and factors are discussed in Appendix A.

The cost benefit analysis is where the alternatives are compared. At this point it is necessary to put the alternatives on a common basis in order for comparisons to be made. The benefits are defined as the difference in cost between the alternatives. The existing direct contact condenser system with the iron catalyst, caustic and peroxide is Alternative 1 and defender. The retrofit of units with surface condensers and the addition of Stretford units to process the vent gases is Alternative 2 or the challenger. The study is to show the economics of continuing with the existing defender or to convert and implement the challenger system in terms of 1979 dollars.

5.1

Economic Evaluation

There are two periods of time in which economic evaluations take place in this report. The first evaluation is early in the process and affects the basic design parameters and conditions. These could be called design trade-offs or design selection analyses. These tend to be very rough approximations to eliminate unnecessary alternatives to be addressed in detail. The second economic evaluation is the final comparison (cost benefit analysis) which includes all the details of each alternative.

The Engineering Planning Department, Generation Planning Section was consulted in the preparation and the determination of techniques and factors used in economic evaluations of different generation plans. The overall method is a level annual revenue requirement (LARR) technique. All economic quantities must be converted to LARR before comparison. LARR takes into account escalation, cost of capital, and other items. In generation planning, single life values for LARR are utilized rather than perpetual values.



Rogers

The following areas each have leveling factors which were provided by Generation Planning.

- Account 314 Capital, Single Life, 30 Years
- Operation & Maintenance, 30 Years
- Power Values, 30 Years and Single
- Geysers Steam, 30 Years

Appendix "A" explains these factors in more detail.

5.2

Cost Estimate Accounts

The cost estimates have been prepared by categories, and are the same accounts used by Pacific Gas and Electric for GM estimates. Only the following accounts are included by the nature of this project work.

<u>Account</u>	<u>Description</u>
51-20	Structures and Improvements
52-50	Main Steam Piping
54-20	Condensate System
54-29	H ₂ S Abatement Facilities
54-30	Circulating Water System
54-40	Lube Oil System
54-70	Instrumentation
55-30	Control and Power Connection
55-60	Auxiliary Electrical Equipment - Station Power
56-10	Compressed Air System
365	Engineering and Other Cost Allocations

The detailed cost figures are in June 1979 dollars. These are modified, due to escalation and project timing as a result of the



Rogers

schedule prepared. Separate subtotals are established for the total of direct costs, the total with GM overheads and indirects, and the total with escalation.

5.3 Cost Estimates

The cost estimates include equipment and material; installation labor with overheads, profit and indirects; Account 365-Engineering and other allocatable costs; escalation; and the GM factor. Each will be briefly discussed as they apply to the detailed estimates which follow.

5.3.1 Major Equipment

Suppliers of the major equipment, condensers, pumps, and Stretford licensors were contacted by telephone and followed up by transmittal of pertinent equipment data sheets. In the majority of cases, vendors were contacted who have had some experience in the special problems associated with geothermal plants.

The following items in the detailed cost estimate are adjusted quoted figures:

Condensers and Ejectors
Condensate Pumps
Circulating Water Pump
Stretford Equipment

The Material and Equipment column is a combination of adjusted quoted costs, estimated bulk materials, six percent use tax, and twenty percent for unestimated items since this is a conceptual cost estimate. The estimate assumes that Pacific Gas and Electric will purchase all major equipment and supply it to the contractor for installation, as has been the practice at the Geysers Plant. The costs in the estimate for each piece of major equipment reflect our best judgment as to the eventual bid on the "selected" equipment data sheets.

5.3.2 Installation Cost

The estimated installation cost is the cost anticipated to be charged by an outside contractor to perform the removal of the old and installation of the new equipment. Most of the larger project construction work at the Geysers has been done by outside contractors and this guide has been used in preparation of this estimate. This decision affects the labor overheads and labor efficiency as well as the general overheads of a GM factor.



Rogers

The estimated materials and labor shown on the detailed estimates are based upon the conceptual layout drawings and field investigations at the site for each installation. There is judgment used whenever making such an estimate, and this estimate has been prepared by people who have been a part of other geothermal plant construction. The General Construction Department has assisted with suggestions on various factors included in the estimates.

In consultation with General Construction about contractor performance and costs at the Geysers certain figures were developed for use in this conceptual report. The current labor direct rates show a \$15 per hour to be an overall good concept estimate direct labor cost. The labor efficiency has been estimated to be 60 percent and has been used in the estimate. The contractor overhead includes his profit, overheads and all indirect expenses. It has been estimated that 55 percent is a good value from past Geysers' experience in contractor bidding.

In addition to the above basic parameter discussions a twenty percent contingency has been included in the direct man-hours for this conceptual estimate. The labor man-hours shown in detailed estimates are derived as follows:

$$\begin{array}{l} \text{Man-hours} = \text{Basic Estimate} \times \text{One Divided By Efficiency} \times \text{Contingency} \\ 2.0 \qquad \qquad \qquad = 1.0 \qquad \qquad \qquad \qquad \qquad \qquad \times 1.67 \qquad \qquad \qquad \qquad \qquad \qquad \times 1.2 \end{array}$$

5.3.3 Account 365

The costs shown in Account 365 are the direct allocatable costs to a given project such as field construction activities, general office engineering and other engineering. All the costs have been lumped into the three above subdivisions. Also, previous Geyser GM's were studied both as estimates and as final plant accounting to determine the appropriate numbers. The past range is from 14 to 18 percent of the total direct charges. Since these cost estimates developed in this report are for fairly complex project modifications, a twenty percent figure is considered appropriate for this estimate.

5.3.4 GM Factor

The GM Estimate preparation is the last step in the cost estimate process. The GM estimate is used to get funds approved for the project. Engineering Services in consultation with Engineering and General Construction puts the final GM numbers together. Engineering Services has been consulted in the methods and factors used in preparation of GM estimates.



Rogers

The GM factor is a function of whomever does the construction. The estimates prepared here are based upon an outside contractor doing the construction. The following factor is applied to the direct costs.

Factor Development

<u>Item</u>	<u>Percent of Direct Cost</u>
Indirects:	
Indirects	0.0
General Overheads:	
General Engineering & Administration	16.0
Allowance for Funds During Construction	3.7 - 5.0
Ad Valorem Taxes	<u>1.0 - 2.0</u>
Total GM Factor	20.7 - 23.0%

The allowance for funds during construction is a function of the construction period; the general engineering and administration; and the direct costs. The Ad Valorem tax is a function of the direct dollar cost of the project. Pacific Gas and Electric S. P. 112.6-1, Appendix A, effective 10/16/78 has been used in determining the factor. Each estimate summary indicates the percentage used for the GM factor.

5.3.5 Escalation

The GM estimate total includes escalation, and it is separated out as a definable item. The rate of escalation was derived from Economics and Statistics Department escalation report for Autumn 1978. All the detailed cost estimates are June 1979 dollars. The escalation time assumes one year or June 1980 to start engineering and procurement, and two additional years to the center of gravity of dollar disbursements for a project (3 years of escalation). The escalation was calculated at the stated compound percent applied to the sum of the direct costs plus the GM factor costs.

5.3.6 Project Differential Cost

It is often helpful to have a magnitude feeling for the GM estimated cost total in terms of level annual revenue requirement. This figure in mills per kilowatthour is presented with each cost estimate summary.



Rogers

5.4 Design Selection Evaluation

Certain economic evaluations which were made at the very beginning of the design apply in general and are presented here.

5.4.1 Cooling Tower and Circulating Water Flow

It is assumed that no additional major investment is required to return the cooling tower capability to design condition beyond regular maintenance. Thus, the only design trade-off to maximize power is to increase circulating water flow until pumping costs or size of the circulating water piping limit the retrofit space considerations. This required an examination of field cooling tower test data, along with pumping and piping considerations to set the estimated capability for operating vacuum after retrofit.

5.4.2 Condensing and Gas Cooling Limitations

Once the cooling tower return water and off tower temperature have been assigned preliminary values as shown by para. 5.4.1, the specification of the surface type heat exchangers must then consider two factors:

- (a) The terminal temperature difference (TTD) which is the steam inlet temperature minus the condenser outlet water temperature and
- (b) the cold gas outlet temperature minus the condenser inlet water temperature.

As the specified TTD is lowered, the turbine operating back pressure is also lowered, the turbine output is increased, and the condenser size and cost rises. For surface type exchangers, the Standards of the Heat Exchanger Institute recommends a lower TTD limit of 5°F. Table 5.1 (study for Unit 1) shows that the increased power output will more than offset the condenser cost. However, the specification for TTD was increased to 7.8°F (Unit 1) in order to reduce the condenser to a size suited to the available installation space. A similar methodology was used for all units in the retrofit study.

As the gas cooling temperature is lowered (assuming turbine back pressure is held constant), two conditions influence vacuum system specification.

- (a) A colder temperature will decrease the inlet pressure available to the vacuum system steam jet ejectors, and



Rogers

(b) at the same time the steam vapor entrainment carried by the noncondensable gas flow is reduced.

The combination of these two factors results in an overall increase in motive steam requirement as the cold gas temperature is allowed to rise. Table 5.2 (Study for Unit 1) shows that when a cost of steam is assigned to the motive steam it is desirable to specify lower cold gas temperatures. Throughout the study, cold gas temperatures were adjusted to avoid oversizing the condensers.



Rogers

TABLE 5.1

TYPICAL ECONOMIC ANALYSIS

MAIN CONDENSER - UNIT 1

STEAM END APPROACH (TTD)

<u>Study Case Item</u>	<u>A</u>	<u>B</u>
TTD °F	7.8	5
Condenser Cost (1)	0	\$376,800
Calc. Power Output Increase	0	190 kW

ECONOMIC EVALUATION

Difference in Capital (2) (Cost)	0	(54,700) \$/yr.
Difference in Energy (3) (Revenue)	0	<u>86,500 \$/yr.</u>
Advantage (Capital over Energy)		\$31,800 \$/yr.
<hr/>		

(1) Capital Installed

(2) Annualized Capital Installed per Year Value

(3) System Level Annualized Power per Year Value

This table indicates that it is economic to buy a condenser for a lower TTD °F to increase electrical energy generated from the plant. The advantage is 31,800 level annual dollars per year. However, 7.8°F was used for conceptual design because of condenser space limitations.



Rogers

TABLE 5.2
TYPICAL ECONOMIC ANALYSIS
MAIN CONDENSER - UNIT 1
NONCONDENSABLE GAS END APPROACH

<u>Study Case Item</u>	<u>A</u>	<u>B</u>	<u>C</u>	<u>D</u>
Noncondensable Gas Outlet °F	95	105	115	119
Difference in Heat Exch. Cost (1)	\$17,700	\$ 9,300	\$ 2,700	0
Steam to Jet Difference (2)	0	\$14,400	\$47,200	\$67,500
TOTAL DIFFERENCES (3)	\$17,700	\$23.700	\$49,900	\$67,500

(1) Annualize Capital Installed
(2) Steam Fuel Level Annualized Value
(3) Annualized Basis

This table indicates that cooling of the noncondensable gases is "economic", if a cost is assigned to motive steam. However, in real life, the jet steam is not a cost factor. The capital cost is less in case D and the designs reflect this relationship.



Rogers

5.5

Installation Labor Cost Sensitivity

As all recognize in the construction industry, the labor productivity, the labor pay rate and the contractor overhead and profit vary depending on time of bid, overall conditions and the specific project requirements. Since this is a conceptual design report, some knowledge of what difference these variations of parameters can make in total project cost is worth studying. Cost sensitivity analysis was performed on the Unit 1 estimate to demonstrate the total cost vulnerability to parameter variation. This vulnerability is also a function of the labor to equipment and material ratio. The labor material ratio, excluding Account 365, vary from 0.365 to 0.558. Using a value of about 0.42, the following sensitivities to total project cost are observed:

<u>Labor Efficiency %</u>	<u>Total Project Cost (per unit)</u>
50	1.058
60	1.000
70	0.957

<u>Labor Rate \$/hr.</u>	<u>Total Project Cost (per unit)</u>
13.50	0.971
15.00	1.000
16.50	1.030

<u>Labor Overhead %</u>	<u>Total Project Cost (Per Unit)</u>
45	0.981
55	1.000
65	1.019

As observed these changes in total cost are small as compared with:

Escalation 1.285
Contingency 1.20

5.6

Capacity Factor (Cost Benefit Analysis)

Capacity factors of the units are being used to analyze the annual electrical output from a unit. The first discussions of capacity factor were presented in Section 3.1.3.

5.6.1

Alternative 1 (Iron/Caustic/Peroxide System)

This system has indicated a decrease in capacity factor. There are also many other reasons for capacity factor changes; however, at this time it appears that the iron catalyst/caustic/peroxide system



Rogers

and direct contact condensers could operate at a 60 percent capacity factor or lower. With continued operating experience and improvements to the system it appears a 70 percent capacity factor could eventually be achieved for the mature system. Both 60 and 70 percent will be used in comparisons.


5.6.2 Alternative 2 (Surface Condensed/Stretford System

This system should have the power plants capable of operating at their intrinsic or natural capacity factor. This was indicated by experience to be 80 percent and with a mature system to be 85 percent. Both figures are used in the economic analysis.

The capacity factors of the vent gas processing equipment (Stretford) affects the Units capacity factor. As discussed in Section 5.4 of the technical data, Volume 1, the Stretford unit cost has been increased from the normal to provide a design that has zero forced outages in the case of combined units and for individual units such that they are available all the time a separate power plant unit is available. Therefore, the Stretford units (the vent gas processing) are not anticipated to impact plant capacity factors.

5.7 Unit Energy (Cost Benefit Analysis)

The net kilowatt hours available for the bulk power system is of paramount importance when making comparisons. The design base reference point net kWh for each unit is used for this calculation. Alternative 1 energy is the base net kW times the hours indicated by the capacity factors. Alternative 2 energy is reduced from the base kW due to the retrofit. This new output times the hours indicated by capacity factor is the energy from the retrofit units. The Stretford energy is indicated at the bottom separately. Alternative 1 has a cooling tower deduct based upon Section 3.5, Table 5.3. The alternative which generates the least energy has to make up the difference for economic evaluation purposes. The bulk power system supplies this energy and at its 100 percent capacity factor energy cost. This reduction in capacity factor and output is considered to be increased forced outages and unpredictable, therefore the system energy cost includes capacity and energy in the energy cost number.



Rogers

TABLE 5-3
ANNUAL ENERGY OUTPUT

Capacity Factor Unit MWh/yr.	<u>Alternative 1</u>		<u>Alternative 2</u>	
	<u>60%</u>	<u>70%</u>	<u>80%</u>	<u>85%</u>
1	63,587	74,185	79,464	84,430
2	63,676	74,289	80,557	85,592
3	139,284	162,498	179,832	191,072
4	139,284	162,498	179,832	191,072
5	278,673	325,119	364,451	387,229
6	278,673	325,119	364,451	387,229
7	278,673	325,119	364,332	387,103
8	278,673	325,119	364,332	387,103
9	278,673	325,119	364,963	387,773
10	278,673	325,119	364,963	387,773
11	557,136	649,992	726,933	772,366
12	557,136	649,992	720,429	765,456
Cooling Tower	-13,878	-16,191	0	0
Stretford	0	0	-21,021	-21,021
Total MWh/hr.	3,178,263	3,707,977	4,133,518	4,393,177

Alternative 1 has the lowest energy output when compared to Alternative 2. Therefore, Alternative 1 for economic comparisons must have a replacement energy cost element. This replacement energy need continues for the life of the facility and is represented by a level annual cost. Since the replacement energy is a function of the capacity factor of the alternative, four cases are developed. Table 5-4, Alternative 1 - Replacement Energy and Cost, summarizes the replacement energy costs by case.



Rogers

TABLE 5-4

ALTERNATIVE 1 - REPLACEMENT ENERGY AND COSTS

<u>Case</u>	<u>Alt. #1 Capacity Factor</u>	<u>Alt. #2 Capacity Factor</u>	<u>MWh/yr.</u>	<u>Level Annual \$/yr.</u>
1	60%	80%	955,255	50,290,144
2	60%	85%	1,214,914	63,960,094
3	70%	80%	425,541	22,402,937
4	70%	85%	685,200	36,072,888

5.8 Operations and Maintenance

The operations and maintenance cost must be estimated for each alternative to form a basis for comparison. The difference between alternatives is presented.

5.8.1 Alternative 1 (Defender)

The maintenance is estimated to be twice that of the base unabated plant, Section 3.5. The maintenance is assumed for this study to be constant for both capacity factors. From historic data projected (FPC Form 1 year ending 1978 escalated one year), the unabated plant maintenance difference for Alternative 1 is estimated to be:

Level Annual Maintenance \$/yr. 3,723,000



Rogers

This alternative also has a direct operating expense for the chemicals required for the system. The level annual dollars per year are estimated for the capacity factors:

<u>Capacity Factor</u>	<u>Level Annual \$/yr.</u>
60%	20,506,700
70%	23,924,400

5.8.2 Alternative 2 (Challenger)

The power plant itself is estimated to require the same operations and maintenance as the unabated base plant; however, this alternative has the vent gas processing facilities (Stretford Units). These operations and maintenance costs are estimated to be:

TABLE 5-5

STRETFORD OPERATIONS AND MAINTENANCE
(Level Annual \$/yr.)

Maintenance	\$1,217,160
Chemicals	1,564,004
Steam	105,569
Electricity	<u>1,646,021</u>
 Total	\$4,532,754 \$/yr.

5.9 Capital Cost

The capital costs have been estimated in Sections 3.4 and 4.3 for the respective alternatives 1 and 2. For economic evaluations in 1979 dollars, the level annual dollars per year are segregated by alternative.

5.9.1 Alternative 1 (Defender)

Not all the existing units have the full abatement. For comparison they are all brought up to full abatement. The estimated capital cost was presented in Section 3.4 and in terms of 1979 dollars the level annual \$/year are estimated to be:

Capital 2,191,000 \$/year

5.9.2 Alternative 2 (Challenger)

The required capital expenditures are in two areas for this alternative. The first is retrofitting the power plants with surface



Rogers

condensers, and the second is the Stretford process. These capital costs are summarized in Section 4.3. The following is the 1979 level annual dollars per year required:

Retrofit	10,623,808 \$/yr.
Stretford	<u>6,825,038</u>
Total Capital	17,448,846 \$/yr.

5.10 Replacement Energy During Construction

Schedules for the work of Alternative 2 have been presented in Section 4.1. This summary table is from that data. The Unit down time is required in the economic evaluation to account for all cost. If a plant has two units, both are out at the same time and the total time is the out of service time.

TABLE 5-6

ALTERNATIVE 2 - SUMMARY
REPLACEMENT ENERGY DURING CONSTRUCTION

<u>Units</u>	<u>Construction Outage Months</u>	<u>Level Annual Replacement Cost \$/yr.</u>
1- 2	8.0	\$ 475,607
3- 4	8.0	1,041,062
5- 6	9.3	2,421,382
7- 8	9.3	2,421,383
9-10	9.3	2,421,383
11	11.3	2,941,000
12	11.3	<u>2,941,000</u>
Total		\$14,662,815
		=====

5.11 Economic Evaluation

This subsection is the main purpose of the whole report; to compare on a cost basis the alternatives for H₂S abatement. The Alternative 1 is the iron/caustic/peroxide abatement with existing direct contact condensers. The Alternative 2 is to retrofit all units with surface condensers and provide Stretford processes for the vent gases. The benefit is defined as the difference in costs between alternatives.

Three types of economic evaluations have been requested. They are: level annual revenue requirements, present worth, and constant



Rogers

dollars. All three give the same resultant choice; however, the numbers are in different units or kinds of units. In this report, the major analysis is by the level annual approach and the other methods are touched only slightly.

The capacity factors over the long term are the most significant factor as they affect the two biggest cost items: replacement energy and treatment chemicals. Evaluation "A" compares Alternative 2 (surface condenser/ Stretford) at 80 percent capacity factor with Alternative 1 (iron/caustic/ peroxide) at both 60 and 70 percent capacity factors. Evaluation "B" compares Alternative 2 at 85 percent capacity factor with Alternative 1 at both 60 and 70 percent capacity factors.

5.11.1 Level Annual Analysis

This evaluation is the summary of all the costs developed in this report. It is done by the level annual revenue requirement method. The dollar amounts in the table are thousands of dollars per year on a level annual basis, and are from the report sections indicated by the numbers in parenthesis. This evaluation is in 1979 dollars.



Rogers

TABLE 5-7

LEVEL ANNUAL ECONOMIC EVALUATION "A"
(thousands of \$/yr. 1979)

Alternative:	1	1	2
(5.6) Capacity Factor	60%	70%	80%
(5.7) Energy (Replacement)	\$50,290	\$22,402	-
(5.10) Energy (Replacement During Construction)	-	-	\$14,663
(5.8) Operation & Main- tenance	24,230	27,647	4,533
(5.9) Capital	<u>2,191</u>	<u>2,191</u>	<u>17,448</u>
Total \$1,000/yr.	\$ 76,711	\$52,240	\$36,644
Comparison "Per Unit"	2.09	1.43	1.00

TABLE 5-8

LEVEL ANNUAL ECONOMIC EVALUATION "B"
(thousands of \$/yr. 1979)

Alternative:	1	1	2
(5.6) Capacity Factor	60%	70%	85%
(5.7) Energy (Replacement)	\$ 63,960	\$36,073	-
(5.10) Energy (Replacement During Construction)	-	-	\$14,663
(5.8) Operation & Main- tenance	24,230	27,647	4,533
(5.9) Capital	<u>2,191</u>	<u>2,191</u>	<u>17,448</u>
Total \$1,000/yr.	\$ 90,381	\$65,911	\$36,644
Comparison "Per Unit"	2.47	1.80	1.00



Rogers

Alternative 2 is observed to be the lowest level annual cost in all four cases. The conditions and the per unit multiple cases are summarized below. The "per unit" multiple is defined as the base value divided into the compared value, where the base value is the lowest cost alternative. The per unit multiple is the number of times the most economical alternative is better than Alternative 1 for those conditions.

TABLE 5-9
SUMMARY COMPARISON

<u>Case</u>	<u>Alt. 1 Cap. Fac.</u>	<u>Alt. 2 Cap. Fac.</u>	<u>Per Unit Multiple</u>
1	60	80	2.09
2	60	85	2.47
3	70	80	1.43
4	70	85	1.80

TABLE 5-10
CASE DIFFERENCE SUMMARY (L.A.)

<u>Case</u>	<u>Alt. 1 Cap. Fac.</u>	<u>Alt. 2 Cap. Fac.</u>	<u>Difference in \$/yr. L.A.</u>
1	60	80	40,067,000
2	60	85	53,737,000
3	70	80	15,596,000
4	70	85	29,267,000

There is a very large difference between Alternative 2 and Alternative 1 in level annual dollars per year. The smallest of the differences occurs in Case 3, 15,596,000 \$/yr. level annual. It is worthwhile to study the sensitivity of the difference to various assumptions. The largest component in the evaluation is replacement energy. Decreasing the energy cost twice by 10 percent per kWh gives the following information.

<u>Per Unit</u> <u>Replacement Energy Cost</u>	<u>Level Annual</u>	<u>Difference</u>
1.0	22,402,000	0
0.90	20,145,100	-2,256,900
0.80	17,906,800	-4,495,200



Rogers

Decreases in replacement energy by significant amounts only change the difference slightly. 15.6 million is needed to make the alternatives equal in cost.

The second largest cost is chemical requirements of the iron/caustic/peroxide system. Both a 20 percent increase and decrease are presented. A negative number decreases the difference. Again the difference for the chemical sensitivity is small compared to the case difference of 15.6 million.

<u>Per Unit Chemical Cost</u>	<u>Level Annual</u>	<u>Difference</u>
1.0	27,647,000	0
0.8	22,117,000	-5,530,000
1.2	33,177,000	+5,530,000

The third largest cost is the capital to install the surface condenser and the Stretford units. A 20 percent change in the capital cost only created a difference of 3.4 million dollars for evaluation purposes.

<u>Per Unit Capital Cost</u>	<u>Level Annual \$/yr.</u>	<u>Difference</u>
1.0	17,448,000	0
0.8	13,958,400	-3,489,600
1.2	20,937,600	+3,489,600

Within the limits of the current analysis, it appears that a capacity factor difference between existing abatement and the alternative abatement (surface condenser/Stretford) of 3.6 or greater justifies the expenditures to change the abatement method.

If one were to take all the three major cost elements and add the differences stated above in the greatest way against Alternative 2 the total would amount to 13,514,000 million dollars per year. The difference between Alternative 2 and 1 is 15,596,000 million dollars per year. Therefore, Alternative 2 is solidly the most economic.

5.11.2 Present Value Comparison

To make comparisons with some previous work done by others it has been requested to present the "present values" of the cases and the elements. The results are the same; however, the units of the quantities are different. The present values are the 1979 dollars



Rogers

with all future expenditures converted to 1979 dollars. Table 5-13 summarizes the benefits (difference in cost) of each Alternative 2 case (surface condenser/Stretford) over Alternative 1 (iron/caustic/peroxide) cases as stated.



Rogers

TABLE 5-11

PRESENT VALUE ECONOMIC EVALUATION "A"
(1979 thousands of dollars)

Alternative:	<u>1</u>	<u>1</u>	<u>2</u>
Capacity Factor %	60	70	80
Energy Replacement \$	437,303	194,800	-
Energy Replacement During Construction \$	-	-	127,504
Operation & Maintenance \$	210,695	240,408	39,426
Capital \$	<u>19,052</u>	<u>19,052</u>	<u>151,721</u>
Total \$	667,050	454,261	318,651
	=====	=====	=====

TABLE 5-12

PRESENT VALUE ECONOMIC EVALUATION "B"
(1979 thousands of dollars)

Alternative	<u>1</u>	<u>1</u>	<u>2</u>
Capacity Factor %	60	70	85
Energy Replacement \$	556,174	313,678	-
Energy Replacement During Construction \$	-	-	127,504
Operation & Maintenance \$	210,695	240,408	39,426
Capital \$	<u>19,052</u>	<u>19,052</u>	<u>151,721</u>
Total \$	785,921	573,138	318,651
	=====	=====	=====

TABLE 5-13

CASE DIFFERENCE SUMMARY (PV)

<u>Case</u>	<u>Alt. 1 Cap. Fac.</u>	<u>Alt. 2 Cap. Fac.</u>	<u>Difference in PV</u>
1	60	80	\$348,399,000
2	60	85	467,270,000
3	70	80	135,609,000
4	70	85	254,487,000



Rogers

5.11.3 Constant Dollar Analysis

The constant dollar analysis is a useful and equivalent version of the level annual revenue requirement method; however, in periods of sustained general inflation the value of current dollars declines with time in real terms and the current dollar analysis eliminates the effects of general inflation which gives results more easily compared to present day costs. This method does not eliminate the effect of real price changes.

The constant dollar factor applied to the escalated costs was obtained from Generation-Planning and was from their latest Power Values Memo to management dated September 12, 1978.

The constant dollar approach works from escalated dollar values. All the previous economic comparisons did not work from escalated costs. 1982 was used as the year to escalate all values to before applying the constant dollar factor for a 30 year life operation to get 1979 constant dollars. The following tables are 1979 constant dollars. As predicted the results are the same as the previous two analyses.



Rogers

TABLE 5-14

CONSTANT DOLLAR EVALUATION "A"
(Thousands of \$/yr. 1979)

Alternative:	1	1	2
Capacity Factor %	60%	70%	80%
Energy (Replacement) \$/yr.	36,383	16,207	-
Energy (Replacement During Construction) \$/yr.	-	-	10,608
Operation & Maintenance \$/yr.	16,131	18,406	3,017
Capital \$/yr.	<u>1,490</u>	<u>1,490</u>	<u>11,867</u>
Total \$/yr.	54,004	36,103	25,492
	=====	=====	=====

TABLE 5-15

CONSTANT DOLLAR EVALUATION "B"
(thousands of \$/yr. 1979)

Alternative:	1	1	2
Capacity Factor %	60%	70%	85%
Energy (Replacement) \$/yr.	46,273	26,098	-
Energy (Replacement During Construction) \$/yr.	-	-	10,608
Operation & Maintenance \$/yr.	16,131	18,406	3,017
Capital \$/yr.	<u>1,490</u>	<u>1,490</u>	<u>11,867</u>
Total \$/yr.	63,894	45,994	25,492
	=====	=====	=====

TABLE 5-16

CONSTANT DOLLAR CASE DIFFERENCE SUMMARY

Case	Alt. 1 C. F.	Alt. 2 C. F.	Difference Construction Dollars
1	60	80	28,512,000
2	60	85	38,402,000
3	70	80	10,611,000
4	70	85	20,502,000



Rogers

6.0

RECOMMENDATIONS

It has been shown that there is an economic benefit to converting from the existing abatement to an abatement system which utilizes surface condensers and the Stretford Process for vent gas treatment. The economic analysis was done on an overall Geysers Power Plant basis. Since the overall project of retrofitting Units 1-12 with surface condensers and installing selected Stretford units was economic is there an economic benefit to doing the individual sub-projects in a prescribed sequence? The recommendations of this section relate to the timing of unit retrofitting.

Retrofitting the existing Units 1-12 with surface condensers is only part of the project. Various Stretford facilities are built as part of the program. The economics of power plant groupings and Stretford unit size and groupings was presented in the Technical Data Volume 1, Section 5.4 through 5.7. As it turns out groupings of about 200 MW of power plant units had about the same vent gas processing requirements and proved economic except for power plant Units 9-10 and 12 where 9-10 would have its own Stretford as would Unit 12. A power plant unit retrofitted must feed the vent gas into a Stretford unit before the power plant can operate. Therefore for timing economic studies each power plant unit or combination and its associated Stretford unit was considered as a subproject to evaluate construction timing.

6.1

Timing Analysis Method

The method has many variables that inter-relate to provide a relationship which gives a cost for construction timing. Most all the variables are functions of time themselves, each varying in a different manner. The following factors have been combined in a specific way to address the question of how long should the existing abatement continue operations before the retrofit surface condensers/Stretford be operational? The factors are:

- a) the chemical costs associated with the iron/caustic/peroxide's operation;
- b) the energy cost of operating the existing units at a lower capacity factor than is anticipated by the retrofit;
- c) the capital cost of retrofitting with surface condensers and installing Stretford units;



Rogers

- d) the replacement energy during construction of the retrofit and Stretford units when the power plant unit is out of service;
- e) the energy output increase after retrofit due to higher anticipated capacity factor operation;
- f) the operation and maintenance costs associated with new retrofit units and Stretford processes.

Table 5-17 shows all the factors described above and is the summary of the timing analysis calculations for the alternative abatement being constructed in period 3, 1982. Period 0 is June 1979. The present worth is the difference in cost, in 1979 dollars, between continuing with the existing abatement and installing and operating the surface condensers and the Stretford units. Previous analysis in Section 5.11 was on a levelized basis. Table 5-17 is not levelized but treats each individual cost element in the year it occurs. Table 5-17 is a more precise look at the details for timing purposes.

The method places the construction first in period 0, then period 1, etc. The present worth starts out positive which means the alternative abatement is more expensive and decreases continually and eventually goes negative which means the existing abatement has become more expensive. This crossover period from positive to negative is then the economic period to have the retrofit condenser units and the Stretford start operation. Table 5-18 shows the construction in the 4th period and the present worth negative. These two tables specify the period most economic for the specified construction, between period 3 and 4.

The input information and all the variables are presented in Appendix A since the information on power values (energy costs), escalation rates are considered in-house management figures.



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111
JOB NO. S-79007

-EXISTING ABATEMENT-

Period	Capital	Energy	Oper. & Maint.
0	0.	.481E+07	.450E+07
1	0.	.486E+07	.439E+07
2	0.	.461E+07	.428E+07
3	0.	0.	0.
4	0.	0.	0.
5	0.	0.	0.
6	0.	0.	0.
7	0.	0.	0.
8	0.	0.	0.
9	0.	0.	0.
10	0.	0.	0.
11	0.	0.	0.
12	0.	0.	0.
13	0.	0.	0.
14	0.	0.	0.
15	0.	0.	0.
16	0.	0.	0.
17	0.	0.	0.
18	0.	0.	0.
19	0.	0.	0.
20	0.	0.	0.
21	0.	0.	0.
22	0.	0.	0.
23	0.	0.	0.
24	0.	0.	0.
25	0.	0.	0.
26	0.	0.	0.
27	0.	0.	0.
	0.	.143E+08	.132E+08

-ALTERNATIVE ABATEMENT-

Capital	Energy	Oper. & Maint.	Period
0.	0.	0.	0
0.	0.	0.	1
0.	0.	0.	2
.579E+07	.448E+08	0.	3
.373E+07	-.528E+07	.157E+07	4
.327E+07	-.493E+07	.152E+07	5
.286E+07	-.483E+07	.147E+07	6
.250E+07	-.449E+07	.142E+07	7
.219E+07	-.430E+07	.137E+07	8
.202E+07	-.393E+07	.132E+07	9
.179E+07	-.375E+07	.128E+07	10
.156E+07	-.365E+07	.124E+07	11
.136E+07	-.333E+07	.119E+07	12
.119E+07	-.315E+07	.115E+07	13
.103E+07	-.301E+07	.111E+07	14
.899E+06	-.286E+07	.107E+07	15
.780E+06	-.269E+07	.104E+07	16
.101E+07	-.257E+07	.999E+06	17
.896E+06	-.243E+07	.964E+06	18
.770E+06	-.231E+07	.930E+06	19
.664E+06	-.219E+07	.897E+06	20
.568E+06	-.208E+07	.866E+06	21
.488E+06	-.197E+07	.835E+06	22
.418E+06	-.188E+07	.806E+06	23
.358E+06	-.177E+07	.778E+06	24
.305E+06	-.168E+07	.750E+06	25
.262E+06	-.160E+07	.724E+06	26
.222E+06	-.152E+07	.698E+06	27
	.369E+08	-.275E+08	.260E+08

Present Worth 8020770.

TIMING ECONOMICS

DRAWING NO.	REV.
Table 5-17	0



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111

DS-023

-EXISTING ABATEMENT-				-ALTERNATIVE ABATEMENT-			
Period	Capital	Energy	Oper. & Maint.	Capital	Energy	Oper. & Maint.	Period
0	0.	.481E+07	.450E+07	0.	0.	0.	0
1	0.	.486E+07	.439E+07	0.	0.	0.	1
2	0.	.451E+07	.428E+07	0.	0.	0.	2
3	0.	.533E+07	.414E+07	0.	0.	0.	3
4	0.	0.	0.	.562E+07	.444E+08	0.	4
5	0.	0.	0.	.327E+07	-.493E+07	.152E+07	5
6	0.	0.	0.	.286E+07	-.483E+07	.147E+07	6
7	0.	0.	0.	.250E+07	-.449E+07	.142E+07	7
8	0.	0.	0.	.219E+07	-.430E+07	.137E+07	8
9	0.	0.	0.	.191E+07	-.393E+07	.132E+07	9
10	0.	0.	0.	.176E+07	-.375E+07	.128E+07	10
11	0.	0.	0.	.157E+07	-.365E+07	.124E+07	11
12	0.	0.	0.	.137E+07	-.333E+07	.119E+07	12
13	0.	0.	0.	.119E+07	-.315E+07	.115E+07	13
14	0.	0.	0.	.104E+07	-.301E+07	.111E+07	14
15	0.	0.	0.	.904E+06	-.286E+07	.107E+07	15
16	0.	0.	0.	.786E+06	-.269E+07	.104E+07	16
17	0.	0.	0.	.683E+06	-.257E+07	.999E+06	17
18	0.	0.	0.	.888E+06	-.243E+07	.964E+06	18
19	0.	0.	0.	.784E+06	-.231E+07	.930E+06	19
20	0.	0.	0.	.673E+06	-.219E+07	.897E+06	20
21	0.	0.	0.	.581E+06	-.208E+07	.866E+06	21
22	0.	0.	0.	.497E+06	-.197E+07	.835E+06	22
23	0.	0.	0.	.427E+06	-.188E+07	.806E+06	23
24	0.	0.	0.	.366E+06	-.177E+07	.778E+06	24
25	0.	0.	0.	.313E+06	-.168E+07	.750E+06	25
26	0.	0.	0.	.267E+06	-.160E+07	.724E+06	26
27	0.	0.	0.	.229E+06	-.152E+07	.698E+06	27
	0.	.196E+08	.173E+08	.327E+08	-.226E+08	.244E+08	

Present Worth -2394969.

TYPICAL
TIMING ECONOMICS

DRAWING NO.	REV.
Table 5-18	0
SHEET	OF



Rogers

6.2 Timing Study Results

The timing studies were performed using a 10 percent difference in capacity factor between the existing abatement and the surface condenser/Stretford alternative abatement. There are four subprojects studied:

- a) Power Plant Units 7, 8 and 11 with Stretford at Unit 11.
- b) Power Plant Units 1, 2, 3, 4, 5 and 6 with a Stretford unit near Unit 3.
- c) Power Plant Unit 9 and 10 with a Stretford at 9 or 10.
- d) Power Plant Unit 12 with a Stretford at Unit 12.

The studies showed with a 10 percent capacity factor difference the subprojects should be implemented in the following order, the first at the top of the list. The third and fourth have the same timing.

- 1) Power Plant Units 9 and 10 and Stretford
- 2) Power Plant Units 7, 8 and 11 and Stretford
- 3) Power Plant Units 1, 2, 3, 4, 5 and 6 and Stretford
- 4) Power Plant Unit 12 and Stretford

A bar graph is presented in Table 5-19 which indicates the economic period to have the alternative abatement facilities come on the line.

A sensitivity analysis on the timing as it relates to capacity factor difference between the existing and the alternative showed very interesting results. If the capacity factor difference is as great as 15 percent then economically the projects should be put in as fast as possible (instantaneously). If the capacity factor difference is 5 percent the timing moves out about 4 years. Capacity factor differences are again very significant and are probably the most significant single element in the timing economics.



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111
JOB NO. S 79007
ba-023

PROJECTS	JUNE 1979	PERIODS					
		1980	1981	1982	1983	1984	1985
STUDY REPORT		■					
UNITS 9 & 10 & STETFORD AT 9			■				
UNITS 7, 8 & 11 & STRET福德 AT 11				■			
UNIT 12 & STRET福德 AT 12					■		
UNITS 1 - 6 & STRET福德 NEAR 3						■	
MOST ECONOMIC PLANT START-UP PERIODS							
DRAWING NO. TABLE 5 - 19 SHEET OF	REV. 0						



Rogers

6.3

Geysers Power Plant Available Capacity

Economics are not the sole governing element in making a decision nor are they in developing schedules. However, if the economics were followed here is a table which would approximate the available capacity from the total Geysers' plant. Only Units 1-12 are considered.

TABLE 5-20

AVAILABLE CAPACITY DURING CONSTRUCTION
(Units 1-12 only)

<u>Year</u>	<u>Net MW Before</u>	<u>Under Construction MW</u>	<u>Net MW After</u>	<u>Available MW</u>
1979	607	0	0	607
1980	501	106	0	501
1981	501	0	104	605
1982	289	212	104	393
1983	0	289	312	312
1984	0	0	593	593



Rogers

7.0

PROFESSIONAL SERVICES

A format for proceeding with the retrofitting of the existing power plant Units 1-12 with surface condensers and Stretford vent gas processing units is described here. In previous sections details of the overall objective have been discussed. This section brings the schedules for engineering, procurement and construction together with the economic timing of each sub-project, Table 7-1. The timing in Table 7-1 for the sub-project Units 9 & 10 and Stretford is deferred one year past the first economic year because engineering, equipment delivery and construction times are too great starting in June 1979 to get it accomplished for January 1981 start up.


This bar graph schedule Table 7-1, shows a coordinated effort and logical progression of accomplishing the projects. It also shows procurement as a very significant element in the overall plan. We feel this schedule can be maintained as the preliminary details indicated in Section 5.8 and Appendices A, B, C and D of the Final Report Technical volumes.

As part of the plan for organizing and arranging the accomplishment of the overall project, it is important to realize that in preparing the cost estimate for the project the estimates were so done to include the full GM costs. That is Account 365 "Engineering and Other Allocatable Costs" (field construction costs - general construction, general engineering, general office, and engineering other-professional services by consultant) are included in the direct costs and then the GM factor for general and administration has been added. The plan, governed by timing and costs, shows that the project should get underway very soon.

To culminate this section Table 7-2 represents the time and economic scheduled restart up of the retrofit units. It shows all units completed by June 1984.



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111
JOB NO. S 79007
DG-023



DRAWING NO. **TABLE 7-1**
REV. **O**
SHEET **OF**

RETROFIT PROJECTS - ENGINEERING, PROCUREMENT, & CONSTRUCTION SCHEDULE



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111
JOB NO. S 79007
DG-023

PROJECTS	JUNE 1979	PERIODS					
		1980	1981	1982	1983	1984	1985
UNITS 9 & 10 & STRETFORD				█			
UNITS 7, 8, & STRETFORD				█			
UNIT 12 & STRETFORD				█			
UNITS 1 - 6 & STRETFORD				█			

RETROFIT UNITS - PROPOSED START-UP PERIODS

▲ UNIT START-UP

RETROFIT UNITS
PROPOSED START-UP PERIODS

DRAWING NO. **TABLE 7-2**
REV. **0**
SHEET **0** OF **0**

COST OF CAPITAL: 11 Percent

CAPITAL: The single life 30 year level annual revenue requirement (LARR) factor for generation planning is 0.1465.

OPERATION AND MAINTENANCE: The 30 year level annual factor for generation planning is 2.19.

STEAM AT GEYSERS: The 30 year level annual steam cost in mills per kWh is 24.4.

POWER VALUES: (for base loaded units in mills per kilowatt hour)

<u>Year</u>	<u>30 Year Level</u>	<u>Single Value</u>
1979	61	33
1980	65	37
1981	68	39
*1982	72	50
1983	75	55

*Data used in Report

CONSTANT DOLLAR FACTOR: To convert 1982 figures to 1979 constant dollars 0.529.

CONSTRUCTION COST:

Direct Labor Rate: 15.00 dollars per hour

Efficiency: 60 percent of hours

Indirects and Profit: 55 percent of direct labor cost

Contingency: 20 percent on direct labor hours

Major Equipment: Evaluated manufacturer cost

Materials and Rentals: Estimated

Contingency: 20 percent on equipment and materials

Engineering and Other Allocatable Costs: 20 percent on labor and equipment

GM FACTOR:

<u>Item</u>	<u>Percent of Direct Cost</u>
Indirects:	
Indirects	0.0
General Overheads:	
General Engineering & Administration	16.0
Allowance for Funds During Construction	3.7 - 5.0
Ad Valorem Taxes	1.0 - 2.0
Total GM Factor	20.7 - 23.0%

4	8/24/79	Revised for Final "Condensed Report"			
3	8/3/79	Revised for Final Draft "Condensed Report"			
1	6/29/79	Revised for Milestone Report #2			
No.	Date	Description	Ck	R.App	C.App

ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111
JOB NO. S-79007-70

ECONOMIC FACTORS AND METHODS
DATA SHEET
APPENDIX "A"

SPECIFICATION

4

S-00-001

Client PGandE Date 6/28/79

SHEET 1 OF 3

METHODS:

1. For alternative comparison, the alternatives must be equal. All costs and their differences are compared to make a selection.
2. The costs of an installation is only the capital cost which must be authorized in a GM.

CALCULATIONS:

1.0 LEVEL ANNUAL STEAM

Level Annual Steam Factor (LASF) = 0.0244 \$/kWh
Steam #/hr. x 0.049 kW/# x Capacity Factor x hrs./yr. x LASF = Level Annual \$/yr.

2.0 LEVEL ANNUAL OPERATIONS AND MAINTENANCE

Note exclude electrical energy use factor of Section 3.0.
Level Annual Operations and Maintenance Factor (LAOMF) = 2.19
Operation and Maintenance Cost/yr. x LAOMF = Level Annual \$/yr.

3.0 LEVEL ANNUAL ELECTRICAL ENERGY (Continuous)

Level Annual Power Value Factor (LAPVF) = 0.065 \$/kWh
kWh/yr. x LAPVF = Level Annual \$/yr.

4.0 LEVEL ANNUAL ELECTRICAL ENERGY (Construction)

Single Power Value (SPV) = 0.037 \$/kWh
CRF (30, 11) Capital Recovery Factor Uniform Series 30 Years at
11 Percent
kWh/yr. x SPV x CRF (30, 11) = Level Annual \$/yr.

5.0 LEVEL ANNUAL CAPITAL COST

Level Annual Capital Factor (LACF) = 0.1465
(Account 314 Only)
Capital Cost \$ x LACF = Level Annual \$/yr.

6.0 CAPITAL COST

Construction Cost x GM Factor = Capital Cost

7.0 CONVERT LEVEL ANNUAL \$ PER YEAR TO PRESENT VALUE

Present Value = Level Annual \$/yr.
Uniform Series Capital Recovery Factor

~~CONFIDENTIAL~~



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111
JOB NO. S-79007-70

ECONOMIC FACTORS AND METHODS
DATA SHEET
APPENDIX "A"
PGandE

6/28/79

SPECIFICATION	REV.
S-00-001	4
SHEET 2 OF 3	

