

Box 13
279

PGandE GEYSERS RETROFIT PROJECT
MILESTONE REPORT NO. 3
(STRETFORD PROCESSES UNITS 1-12)

RECO Job No. S-79007

June 29, 1979

Donated By:
Herbert Rogers Jr.
Rogers Engineering Co.

 ROGERS
Engineering • San Francisco

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

HR



Rogers

MILESTONE REPORT NO. 3

INDEX

- 1.0 INTRODUCTION
- 2.0 SUMMARY
- 3.0 STRETFORD FOR UNITS 1 THRU 6 ✓
- 4.0 STRETFORD FOR UNITS 7, 8 AND 11
- 5.0 STRETFORD FOR UNITS 9, 10 and 12
- 6.0 ALTERNATE STRETFORD SCRUBBER APPROACH
- 7.0 SYSTEM BLOWER SIZE AND COST
- 8.0 STRETFORD SYSTEM COSTS



Rogers

MILESTONE NO. 3

OUTLINE

- 1.0 INTRODUCTION
- 2.0 SUMMARY
- 3.0 STRETFORD FOR UNITS 1 THRU 6
 - 3.1 Proposed Site at Units 3 and 4
SK-006 (Alternative No. 1)
 - 3.2 Alternative Site (UOC)
SK-005A & B (Alternative No. 2)
 - 3.3 Combining Units 1 thru 6 with Units 7 and 8, or with Unit 15
 - 3.4 Conclusions - Units 1 thru 6
 - 3.5 Noncondensable Gas Piping Network
Table 3.5.1
- 4.0 STRETFORD FOR UNITS 7, 8 AND 11
 - 4.1 Proposed Site at Units 7 and 8
SK-0027 (Alternative No. 2)
 - 4.2 Proposed Site at Unit 11
SK-0028 (Alternative No. 1)
 - 4.3 Combining Units 7, 8, 11 with Unit 17
 - 4.4 Conclusions - Units 7, 8 and 11
 - 4.5 Noncondensable Gas Piping Network
- 5.0 STRETFORD FOR UNITS 9, 10 AND 12
 - 5.1 Proposed Site at Units 9 and 10
SK-0029 (Alternative No. 1)
 - 5.2 Proposed Site at Unit 12
SK-0030 (Alternative No. 2)
 - 5.3 Combining Units 9, 10, 12 with Unit 14
 - 5.4 Conclusions - Units 9, 10, 12
 - 5.5 Noncondensable Gas Piping Network
- 6.0 ALTERNATE STRETFORD SCRUBBER APPROACH
- 7.0 STRETFORD SYSTEM BLOWER SIZE AND COST
 - 7.1 Blowers
 - 7.2 Data Sheets



Rogers

MILESTONE REPORT NO. 3

OUTLINE (Cont'd)

- 8.0 STRETFORD SYSTEM COSTS
 - 8.1 Equipment Quotations
 - 8.1.1 Chemicals (Inventory)
 - 8.1.2 Power Service
 - 8.2 Installation Costs
 - 8.3 Operation and Maintenance Costs



Rogers

1.0

INTRODUCTION

Milestone Report No. 3 is a progress report. Rogers Engineering Co., Inc. has investigated what sites are best suited for consolidation of power generating units 1 through 12 for processing the noncondensable gases through the Stretford Process for H₂S abatement below 10% of the mass flow.

The consolidation arrangement for the power generating units are Units 1 through 6 which produces 187 MWe power. Units 7-8 and 11 producing 212 MWe and Units 9-10 and 12 which also produces 212 MWe power. Site survey and selection for the Stretford units provided for a primary and alternative site for each consolidation. Each of these three groups of plants is associated with its Stretford Process Plant.

The gas blowers located at each power plant to push the noncondensable gases through the stainless steel pipe network to the Stretford Process have been sized. When combining the new auxiliary load requirements of these blowers and the Stretford units it was determined that additional auxiliary transformer capacity is necessary.

We are investigating additional alternatives with respect to the Stretford Process application. This data will be submitted in the Final Report, See Section 6.



Rogers

2.0

SUMMARY

A field survey was conducted to locate convenient Stretford sites for consolidation of power generation Units 1 through 6, 7-8 and 11, 9-10 and 12. The primary site location, verified with field measurements were at Units 3-4 illustrated by Drawing SK-006, Unit 11 illustrated by Drawing SK-0028 and Unit 12 illustrated by Drawing SK-0029.

The noncondensable gas blowers required to push the gas from the power unit sites to the Stretford site range in horsepower. Schedule 10 stainless steel pipe will convey the gas over the Geyser terrain following the routing of existing steam lines wherever possible.

Because of the cost of the noncondensable gas blowers and associated stainless steel pipe individual Stretford units are being costed out and will be reported on in the Final Report in July. At this time a recommendation will be made as to the best arrangement for the retrofit.

Alternative sites have been verified for the power unit consolidation and are addressed in the Table of Contents as Alternative No. 2.

The total GM estimate cost for the Stretford located at Unit 3-4 for consolidation of Units 1-6 = \$9,970,500.

For consolidation of Units 7-8 and 11, \$10,073,900.

For consolidation of Units 9-10 and 12, \$7,563,400.

Other power unit combinations were examined. Such as combining Units 1-6 with 7 and 8. This was rejected because the consolidated power block was nearing 300 MWe which was concluded to be too large to lose in the event we lost the Stretford. Other reasons; such as using an individual Stretford for Unit 11 would then become necessary thus producing an unbalanced power block in our consolidation arrangement.

Another combination being studied but not ready for this report is the routing of noncondensable gas from Units 9-10 and 12, to Unit 14 now under construction. This will require the Stretford supplier to expand the process facilities at the Unit 14 site. Field verification of the expanded Stretford Process on the Unit 14 site has yet to be accomplished.



Rogers

3.1 Proposed Site at Units 3 and 4
Drawing SK-006 (Alternative No. 1)

The two sites examined for Stretford location were both capable of accepting a 95' x 162' Process unit. Locating the process unit inside the existing fence line is desirable from the standpoint of no clearances required from other organizations for land rights as would be the case for Alternative No. 2. (SK-005A & B)

The auxiliary transformer required to accommodate the 1,065 kW of additional power for the Stretford can be located in the existing switchyard. Room to pull Unit 4 condenser tube bundle without interference has also been considered in placement of the Stretford.

The water purification equipment now existing and servicing Units 3-4, 5-6 must all be removed from the site. However its removal has an impact on operation of units 5 and 6, which will be taken into account when planning the retrofit construction schedule for each unit.

A

A

B

B


C

C

D

D

GE 212



PG and E RETROFIT STUDY UNITS 1 THRU 6 SITE PLAN - STRETFORD ALTERNATIVE No. 1 CONSOLIDATION OF UNITS 1 THRU 6									
REFERENCE DRAWINGS					APPROVALS				
REV. ZONE DATE					DATE				
REVISION					APPR.				
1	2	3	4	5	6	7			
GE 212									





Rogers

3.2 Alternative Site (UOC)
SK-005A & B (Alternative No. 2)

The land rights to clear the Union Oil Corp. junkyard of the procedural requirements necessary to make it available for the Stretford Process which consolidates Units 1 through 6 make it the second choice.

Another disadvantage the site has is the additional stainless steel piping required from Units 3-4. Not only do the piping costs increase, but so does the vulnerability of the noncondensable gas piping network, because of the additional pipe length.



REFERENCE DRAWINGS	ISSUED FOR MILESTONE REPORT #3	6-18-79
REV. ZONE	DATE	REVISION
GE 212	1/27/79	DR. LFW CHK. LFW APPR. APPR.

ROGERS ENGINEERING CO., INC.
ENGINEERS - ARCHITECTS
31 PINE STREET, SAN FRANCISCO, CALIFORNIA 94111

SCALE

1" = 200'

DATE

6-18-79

APPROVALS


DATE

6-18-79

PG and E RETROFIT STUDY
UNITS 1 THRU 6
SITE PLAN - STRETFORD PLANT LOCATIONS ALTERNATIVE No.1 & 2
CONSOLIDATION OF UNITS 1 THRU 6

JOB NO.
S 79007

SK-005A 0



REFERENCE DRAWINGS	REV. ZONE	DATE	ISSUED FOR MILESTONE REPORT #3	SCALE 1" = 20'	DATE 6-27-79	APPROVALS	PG and E RETROFIT STUDY
			3	25 LFH	DR. C.O. CHK. LFW ENG. JES APPROVED JES		UNITS 1 THRU 6
			4				SITE PLAN STRETFORD ALTERNATIVE No. 2
			5				CONSOLIDATION OF UNITS 1 THRU 6
GE 212			6				JOB NO. S79007 SK-005B
			7				0



Rogers

3.3 Combining Units 1 thru 6 with Units 7 and 8, or with Unit 15

In consideration of a possible site location for Units 1 thru 6, it was deemed necessary to investigate, in concept only, of course, the possibility of combining more than Units 1 thru 6 for a single Stretford Process Unit for the H₂S abatement requirement of PGandE on this Retrofit Conceptual Study.

The available sites for the placement of a Stretford System in near proximity to Units 1 thru 8 have limiting dimensions. For instance Alternative No. 1 (SK-006) has only available area of slightly in excess of the 95' x 162' dimensions for a Stretford System to service Units 1 thru 6. If Units 7 and 8 are added, then the Stretford System dimensions become much greater than the allowable site area; hence, this particular alternative could not be considered. Alternative No. 2 (SK-005A & B) has sufficient area for a larger Stretford System to include Units 7 and 8; however, it is quite remote from Units 7 and 8. Extra piping costs would make Alternative 2 an unlikely selection.

A second reason for not including Units 7 and 8 is that a failure in the operation of the Stretford System with Units 1 thru 8 combined would cause a loss of 290 MWe of power to PGandE. With only Units 1 thru 6 combined, a failure in the operation of the Stretford System would only cause a loss of 184 MWe of power to PGandE.

A third reason for not including Units 7 and 8 is that these Units can be more proximately combined with Unit 11 for a single Stretford System. The off-gas totals from 7, 8 and 11 is 29,931 lbm/hr. and the off-gas totals for Units 1 thru 6 is 30,245 lbm/hr. These totals are approximately equal; hence, from an off-gas total balance point of view, Units 7 and 8 should be combined with 11.

With respect to Unit 15, this Unit was not included with Units 1 thru 6 primarily because of its remoteness from Units 1 thru 6 and because Unit 15, just started-up, already has an installed Stretford System for only Unit 15 and it is separate and independent.



Rogers

3.4 Conclusions - Units 1 thru 6

The primary conclusion for recommendation of the Stretford site at power generation Units 3-4 have been adequately covered in the preceding paragraphs 3.1, 3.2 and 3.3.

Recapping these reasons:

- a) No land rights clearances required from other organizations.
- b) Less stainless steel noncondensable gas piping requiring than that of Alternative Site No. 2 (UOC junkyard).
- c) Consolidation of Units 1-6 only, without 7 and 8 will allow no increase in the 95' x 162' outline dimensions for the Stretford unit. Our recommended site will not accommodate an increase in the outline dimensions.
- d) In the event a consolidated power block is lost because of the Stretford operation, the power loss is 184 MWe not 290 MWe, as would be the case if Unit 7 and 8 noncondensable gas reported to the Stretford at Unit 3-4 site.
- e) Breakup of Units 7-8 and 11 consolidation will unbalance the noncondensable gas flow balance in the piping network. Presently the noncondensable gas flow from Units 1-6 and that from Units 7-8 and 11 are for all practical purposes, equal.



Rogers

3.5

Noncondensable Gas Piping Network

The piping arrangement for transporting the noncondensable gases from the power plant aftercondenser to the Stretford unit requires a blower situated at every power plant location. The blower discharges into stainless steel pipe running to the Stretford unit. The blowers are discussed in Section 7.1 of this report. Section 7.2 includes data sheets that were issued to obtain price quotations for all the blowers considered in this study.

The piping system can be fabricated from 304L Schedule 10 stainless steel. This alloy will withstand the highly corrosive vent gases. The pipe routes parallel existing steam supply lines where possible. In many instances it should be feasible to modify existing steam line supports to also hold the noncondensable gas pipeline. The stainless steel pipe need not be insulated, with the exception of a short section of pipe at the discharge of the blower as deemed necessary to protect personnel from the hot pipe. The pipe has been sized to carry the gas at an upset temperature of 120°F, though the gas will approach ambient temperature for the greater portion of the route. An economic tradeoff study weighing the installed cost of the pipe versus the energy cost associated with the blowers was utilized to specify the pipe diameters.

The sizes of the pipe carrying the gases from Units 1 and 2, Units 3 and 4, and Units 5 and 6 are 6" ϕ , 10" ϕ and 14" ϕ , respectively. The pipe from Units 1 and 2 is joined with the pipe from Units 5 and 6 just north of Unit 5 and 6. A 16" ϕ line runs from this junction to connect with the pipe from Unit 3 and 4 and the combined gas flows to the proposed Stretford location due east of Unit 4, through an 18" ϕ line.



Rogers

TABLE 3.5.1

ESTIMATE NONCONDENSABLE GAS BLOWER POWER REQUIREMENTS AND LINE SIZES

	Flow Rate*	Blower** BHP	Blower Discharge Line Diameter	Blower Discharge Line Velocity (ft./sec.)
Units 1 and 2	2,839	27.6	6	39
Units 3 and 4	9,726	20.4	10	57
Units 5 and 6	17,680	92.7	14	61
Units 7 and 8	11,282	95.2	12	43
Units 9 and 10	11,282	76.3	12	45
Unit 11	18,649	41.8	14	58
Unit 12	11,124	23.4	12	48

*Note: These flow rates are for an aftercondenser gas discharge temperature of 120°F

**Assumes Stretford facility located at Units 3 and 4, Unit 11, and Unit 12



Rogers

4.1 Proposed Site at Units 7 and 8

SK-0027 (Alternative No. 2)

The proposed site at Units 7-8, east of the Unit 8 cooling tower and cyclone fence is the most attractive site for consolidation of Units 7-8 and 11. A minimum of site preparation and/or clearance effort in the form of a partial re-route of an existing steam line and grading for the Stretford system concrete base constitutes total site preparation and minimum man-hour effort.

The economic disadvantage associated with location of the Stretford at Units 7-8 is a noncondensable gas mass transport problem. The mass units in pounds per hour for the noncondensable gas transported from Unit 11 is 1.65 times the mass flow coming from combining Units 7 and 8.

Resulting in a 14" stainless steel, Schedule 10 pipe cost of \$64.72 per foot mill price compared to a 12" pipe whose per foot cost is \$39.53 for gas flow from Units 7-8 to the Stretford located at the Unit 11 site. The installed piping differential capital cost penalty is \$300,000 and noncondensable gas blower capital cost penalty differential is approximately \$60,000, or a total penalty of \$360,000 if we were to use the available site at Units 7-8.

The advantage of the Unit 7-8 site is installation of the Stretford Process without a concurrent outage of Units 7-8 and 11, its non-critical impact on the man power and/or construction schedule, and the added cost of clearing Unit 11 site of the existing water purification equipment and the break out of the existing cyclone fence on the south side to accommodate a Stretford Process. When these points are assessed for the Final Report (Milestone No. 4) the Stretford site at Units 7-8 can well become the recommended site for consolidation of Units 7-8 and 11.

4.2 Proposed Site at Unit 11

SK-0028 (Alternative No. 1)

Using the Unit 11 site for consolidation of Units 7-8 and 11 requires removal of the existing water purification equipment. Relocation of the fence line on the south side along with re-route of the 42" main steam line which supplies steam to Unit 11 turbine. The cost for site preparation will be addressed in the Final Report (Milestone No. 4).

Aside from the preceding disadvantages the highlights which make this site appealing are the lower capital cost for piping when transporting the total noncondensable gas from Units 7-8 versus that



Rogers

from Unit 11. This was explained in Paragraph 4.1. The kW differential of 35 kW between the horsepower supplied to Units 7-8 and 11 noncondensable gas blowers gives the site at Unit 11 a capital plus operating cost advantage when evaluating noncondensable gas blowers.

4.3 Combining Units 7, 8, 11 with Unit 17

The possibility of combining Units 7, 8, and 11 with Unit 17 for purposes of placing a Stretford Process Unit was considered. A proposed site exists at Units 7 and 8 (Alternative No. 2, SK-0027), as well as at Unit 11 (Alternative No. 1, SK-0028). Unit 17 has not been built yet, but could be a possible location for the Stretford Process. Much the same thought was given here to this combination of Units as was given in Section 3.C above to Units 1 thru 6, 7 and 8, and Unit 15. Basically the reasons for not including Units 17 are as follows:

- (1) Unit 17 is planned by PGandE to have its own self-contained Stretford Process Unit. To add capacity would involve Process redesign.
- (2) Failure of operation of the Stretford System on Units 7, 8, 11 along with 17 would cause a loss of 330 MW of energy to PGandE whereas, without including Unit 17, there would be a loss of only 220 MW.

4.4 Conclusions - Units 7, 8, and 11

The primary conclusions for evaluation of the Unit 7-8 sites versus the Unit 11 site are enumerated below.

Unit 7-8 Site

- a) Minimum man-hour effort for site preparation
- b) Noncritical impact on construction schedule
- c) Completion of noncondensable gas piping network for Units 7-8 and 11, to an interface near the condensers
- d) Higher cost of noncondensable gas piping from Unit 11 versus noncondensable gas piping from Units 7-8
- e) 142 kW for blowers at Unit 11 pumping noncondensable gas to Units 7-8

Unit 11 Site


- a) Removal of existing water purification equipment
- b) Re-route existing main steam line along fence on the south side of water purification system



Rogers

- c) 107 kW for blowers at Unit 7-8 pumping noncondensable gas to Unit 11
- d) Lower cost of noncondensable gas piping from Units 7-8 versus that from Unit 11
- e) Permits Units 7 and 8 to stay on line.

The advantages under Unit 7-8 of items a, b and c may outweigh the capital cost disadvantages of items d and e and make the Stretford site east of Unit 8 the recommended location in the final analysis.



NOTES

1. STRETFORD UNIT TO BE PLACED IN
INDICATED AREA AFTER RE-LOCATION
OF EXISTING FENCE AND MAIN STEAM PIPING.

2. AREA 15,330 SQ.FT. RESULTS FROM DIMENSIONS
195' * 152' AS PER REPORTED BY PARSONS
FOR STRETSTFORD EQUIPMENT.

ROGERS ENGINEERING CO., INC.
ENGINEERS - ARCHITECTS
111 PINE STREET, SAN FRANCISCO, CALIFORNIA 94111


SCALE 1" = 20' DATE 6-18-79
F11 100
PPR. APPR. DR. CO. O. CHK LFW APPROVED 900

APPROVALS

PG and E RETROFIT STUDY
UNIT No. II SITE
SITE PLAN-STRETSTFORD ALTERNATIVE No. I
CONSOLIDATION OF UNITS 7, 8 & II

NO. 007	SK - 028	0
------------	----------	---

GB





Rogers

4.5 Noncondensable Gas Piping Network

The general description of the noncondensable gas piping network in Section 3.5 also applies for Units 7, 8 and 11. Two alternative piping schemes have been investigated corresponding to a Stretford system located either at Units 7 and 8, or at Unit 11.

A 12" ϕ pipe is required to transport the noncondensable gases from Units 7 and 8 down the mountain to a Stretford facility adjacent to Unit 11. The short section of pipe from Unit 11 to the Stretford system is 14" ϕ .

For a Stretford facility located at Units 7 and 8 a 14" ϕ SS pipe is needed to carry the gas from Unit 11 up to the abatement system. The noncondensable gases from Units 7 and 8 flow through a 12" ϕ pipe to the Stretford unit.



Rogers

5.1 Proposed Site At Units 9 and 10
SK-0029 (Alternative No. 1)

At a Project Managers' conference on June 19 it was established that a Stretford Process could not be located within 50 feet of a well. This criteria is documented in PCN 30.

Based on the criteria the plot east of Unit 9-10 gate entrance and illustrated on Drawing SK-0049 cannot be used. However just west of the gate entrance to the PGandE site and adjacent to the existing steam line sparger pit an open area exists which may be an attractive Stretford site for consolidation of Units 9-10 and 12.

A field trip will be made prior to writing up the final report to obtain verification dimensions on the sites ability to accommodate a 77' x 128' Stretford unit.

In evaluation of the conclusions shown in 5.4 and that of 5.3 two choices become available.

The first choice is to utilize the existing site within the PGandE fence line on the Unit 9-10 site. The ability to install the Stretford with modifications to existing steam piping which can be done during a scheduled unit outage prior to the Stretford installation is economically attractive and offers a noncritical impact on the overall Geyser construction schedule.

The alternative choice is to expand the Stretford process at Unit 14 to accommodate all the noncondensable gas flow from units 9-10 and 12.




Rogers

5.2 Proposed Site At Unit 12
SK-0030 (Alternative No. 2)

After removal of existing water purification equipment a Stretford process with outline dimensions of 77' x 128' can be installed according to the layout illustrated on Drawing SK-0030.

The disadvantage of this site is the man-hours required to remove the purification equipment and prepare for Stretford installation. This can have an undesirable impact on the construction schedule and unit outage since it forces maximum amount of man power concentration at Unit 12 site.



REFERENCE DRAWINGS	REV. ZONE DATE	ISSUED FOR MILESTONE REPORT #3	20. JF LFW 10/81
	REVISION	DR. C.O. CHK. JF	ENG. LFW APPROVED. 10/81

ROGERS ENGINEERING CO., INC.
ENGINEERS - ARCHITECTS
311 PINE STREET, SAN FRANCISCO, CALIFORNIA 94111


SCALE 1" = 20'

DATE 6-18-79

APPROVALS

PG and E RETROFIT STUDY	
UNIT No. 12 SITE	
SITE PLAN - STRETFRD ALTERNATIVE NO. 1	
CONSOLIDATION OF UNITS 9, 10 & 12	
JOB NO.	SK-029
S79007	0

TRUE-N GRID-N
45°



NOTES:

1. STRETFRD UNIT TO BE PLACED IN INDICATED AREA.
2. AREA 9,856 SQ.FT. RESULTS FROM DIMENSIONS 77' x 128' AS REPORTED BY PARSONS FOR STRETFRD EQUIPMENT.
3. EXISTING WELL WILL NOT PERMIT THE AVAILABILITY OF THIS SITE FOR THE STRETFRD PROCESS.

1	2	3	4	5	6	7																																		
<table border="1"> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td colspan="2">REFERENCE DRAWINGS</td> <td>REV. <i>1/17</i></td> <td>ZONE <i>10</i></td> <td>DATE <i>6-13-79</i></td> <td>ISSUED FOR MILESTONE REPORT <i>3</i></td> <td>CO. <i>JF</i> LFW <i>100</i></td> </tr> <tr> <td colspan="2"></td> <td></td> <td></td> <td></td> <td>DR. <i>CO.</i> CHK. <i>100</i></td> <td>APPR. <i>RECD.</i> APPR. <i>100</i></td> </tr> </table>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	REFERENCE DRAWINGS		REV. <i>1/17</i>	ZONE <i>10</i>	DATE <i>6-13-79</i>	ISSUED FOR MILESTONE REPORT <i>3</i>	CO. <i>JF</i> LFW <i>100</i>						DR. <i>CO.</i> CHK. <i>100</i>	APPR. <i>RECD.</i> APPR. <i>100</i>	<p>ROGERS ENGINEERING CO., INC. ENGINEERS - ARCHITECTS 11 PINE STREET, SAN FRANCISCO, CALIFORNIA 94111</p> <p>SCALE: 1" = 20' DATE: 6-13-79</p> <p>APPROVALS</p>	<p>PG and E RETROFIT STUDY UNITS 9 & 10 SITE SITE PLAN - STRETFRD ALTERNATIVE No. 2 CONSOLIDATION OF UNITS 9,10 & 12</p> <table border="1"> <tr> <td>JOB NO. 579007</td> <td>SK-030</td> <td>0</td> </tr> </table>			JOB NO. 579007	SK-030	0
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																					
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																					
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																					
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																					
REFERENCE DRAWINGS		REV. <i>1/17</i>	ZONE <i>10</i>	DATE <i>6-13-79</i>	ISSUED FOR MILESTONE REPORT <i>3</i>	CO. <i>JF</i> LFW <i>100</i>																																		
					DR. <i>CO.</i> CHK. <i>100</i>	APPR. <i>RECD.</i> APPR. <i>100</i>																																		
JOB NO. 579007	SK-030	0																																						
GE 212	1	2	3	4	5	6	7																																	



Rogers

5.3

Combining Units 9, 10, 12 with Unit 14

A Stretford abatement facility is currently under construction at Unit 14 by R. M. Parsons Company. The possibility exists to enlarge the capacity of this facility to also accommodate the noncondensable gases from Units 9 and 10 and Unit 12. The gases would be pressurized at the power plant units with a blower and piped to the Unit 14 Stretford facility. Parsons has stated that the Unit 14 Stretford could be enlarged by adding a new oxidizer, oxidizer blower, circulation pump, and venturi scrubber. A cost estimate for this modification has been requested from Parsons and will be included in the final report.

The piping network for this system would cross very steep terrain and could not parallel existing roads or steam lines for the majority of the route. Thus, the installed cost of the stainless steel pipe would be high. Lacking the price information from Parsons, it can not be concluded at the present time that the piping and blower energy cost would be offset by a savings in the Stretford capital and operations and maintenance costs.

Another important economic consideration appears in the consolidation of Units 9, 10, 12 and 14. The current design for individual Stretford facilities tied to a single power plant unit is such that the scheduled maintenance outages of the power plant are sufficient to service the Stretford unit at the same time. Parsons has indicated that for single power plant installations, there is enough mechanical equipment redundancy built into the Stretford unit so that the Stretford equipment will never force an outage on the power plant.

By connecting the four power plant units to a single Stretford facility, the Stretford unit must operate 100% of the time, since the current size of the maintenance staff would prevent the four power plant units from having simultaneous scheduled outages. The replacement cost for the electrical energy from the four units involved is substantial.



Rogers

5.4 Conclusions - Units 9-10 and 12

The conclusions that must be evaluated in determination of a Stretford location to handle the noncondensable gas from Units 9-10 and 12 are:

Units 9-10

- Measure existing site adjacent to steam line sparger pit and insert evaluation conclusions and drawing into the final report (Milestone #4)
- Disregard Drawing SK-0029 titled Units 9-10, Alternative No. 1, because of its inability to meet PCN 30 criteria established June 19. No Stretford unit shall be located within 50 feet of a well.

Unit 12

- Removal of water purification equipment.
- Impact on construction schedule, since it forces maximum amount of man power at Unit 12 site.
- Impact on Unit 12 outage if Stretford installation lags condenser retrofit.



Rogers

5.5 Noncondensable Gas Piping Network

The remarks applicable for the noncondensable gas piping network in Section 3.5 also apply to the piping system for Units 9, 10 and 12.

The flow rate and molecular weight of the noncondensable gases from Units 9 and 10 collectively are nearly identical to those of the gases discharged from Unit 12. Thus, the piping network between Units 9 and 10 and Unit 12 is independent of the location of the Stretford facility. Regardless of whether the abatement system is located at Units 9 and 10 or at Unit 12, a 12" Φ stainless steel pipe is required to carry the noncondensable gases between power plant units to the Stretford unit.



Rogers

PRELIMINARY

6.0 STRETFORD ALTERNATIVES

It is normally desirable to use a lower unit cost of larger capacity units and thereby consolidate all the noncondensable vent gas abatement equipment into a minimum number of large processing units. There are, however, offsetting problems as follows:

- (1) The vent gas is corrosive to unprotected carbon steel. Therefore, the vent gas collection system will require expensive materials of construction.
- (2) In addition, since the gas is poisonous and the terrain is steep and subject to slides, the control and system design of the gas collection network must include expensive controls needed to shutdown the system on line failure.
- (3) The cost of having back up compression units at each gas pick up point, which must include pressure and anti-surge controls along with recycle gas cooling systems.
- (4) The large consolidated unit would need added equipment to insure redundancy to achieve a 100% operating factor (zero forced outage). While smaller units might achieve acceptable power penalties by planned maintenance during unit turnaround by taking a short forced outage of the paired operating unit.

To respond to the above problems the following alternatives were evaluated.

Alternative I

- (a) Install a complete small Stretford unit close enough to each point of vent gas origin (i.e. Unit 1 and 2, etc.) so as to eliminate the need for the gas compression equipment and piping.
- (b) Compare to a consolidated Stretford Unit with a gas collection system.

Alternative II

- (a) Install a complete Stretford gas scrubber system only close enough to each point of vent gas origin so as to eliminate the need for the gas compression equipment.



Rogers

The scrubber system circulating fluid would be pumped to and from the centrally located regeneration and sulfur recovery system. This proposed system can be constructed of carbon steel.

(b) Compare to a gas collection system.

It should be noted that Parsons has made some preliminary evaluations of Alternative II and concluded that the liquid pumping costs were too high to offset the savings obtained by deleting the expensive gas piping and compression equipment.

This re-evaluation has been prepared to update and document the estimated costs for the subject alternatives. It is directed only to the proposed consolidation of Units 1 thru 6.



Rogers

PRELIMINARY

SUMMARY OF EVALUATION

ALTERNATIVE I

1.0 INDIVIDUAL STRETFORD SYSTEM AT THREE LOCATIONS

<u>Installed Equipment</u> Cost Estimate - 10^6 \$	Level Annual	\$/yr. (a)
Units 1 and 2 - 2.66	\$ 389,690	
Units 3 and 4 - 4.50	659,250	
Units 5 and 6 - 5.5	805,750	
 <u>Operation and Maintenance</u>		
Units 1 and 2	407,778	\$/yr. (b)
Units 3 and 4	689,850	
UNits 5 and 6	843,150	
 <u>Power Penalty</u>	 296,400	\$/yr. (d)
 <u>Sum of \$/year Values</u>	 \$3,795,468	
	=====	



Rogers

PRELIMINARY

ALTERNATIVE I (Cont'd)

2.0 CONSOLIDATED STRETFORD SYSTEM NEAR UNITS 3 AND 4

Installed cost estimate (includes 20% adder for zero outage)

Units 1 thru 6 - 10^6 \$	7.8	Level Annual	\$/yr.
		\$1,142,700	(a)

Operation and Maintenance		\$1,195,740	(b)
---------------------------	--	-------------	-----

Installed Cost Estimate

Gas Collection Piping

Units 1 thru 6

1,143,096	167,464	(a)
-----------	---------	-----

Gas Compressors (Includes 100% spare - Zero Outage)

Units 1 and 2	\$465,800	\$ 68,240	(a)
Units 3 and 4	\$451,600	67,185	(a)
Units 5 and 6	\$550,700	80,678	(a)

Compressor Operation and Maintenance

Units 1 thru 6	387,656	(c)
----------------	---------	-----

Electric Power for Compression

110 kW x 8760 x 0.065	<u>62,634</u>
-----------------------	---------------

Sum of \$/yr. Values	\$3,172,297
----------------------	-------------

NOTES:

- (a) Installed Cost x 0.1465
- (b) Installed Cost x (0.05 + 0.02) x [2.19]
- (c) Installed Cost Sum x (0.10 + 0.02) x [2.19]
- (d) Power Penalty - 48 hr. forced outage/year x Unit Rated kW x \$0.065/kWh
Rated kW = one unit of pair = $12,500 + 27,500 + 55,000 = 45,000$ kW
 $48 \times 95,000 \times 0.065$

3.0 COMPARISON

<u>Item</u>	<u>Level-Annual</u>	<u>\$/yr.</u>
Individual Units	\$3,795,468	
Consolidated 1-6	<u>3,172,297</u>	
Difference	\$ 623,171	=====

Favors Consolidated



Rogers

PRELIMINARY

SUMMARY OF EVALUATION

ALTERNATIVE II

1.0 INDIVIDUAL VENT GAS SCRUBBERS

Installed Equipment Cost Estimate \$

<u>Scrubbers</u>		Level Annual	\$/yr.
Delete Consolidated Unit	(283,000)		
Units 1 and 2	57,000		
Units 3 and 4	95,000		
Units 5 and 6	155,000		
Solution Charge	30,000		(1)
 Pump and Recovery Power Units			
1 thru 6 (includes 100% spares)	372,000		
 Liquid Lines	<u>690,000</u>		
 Sub Total	\$1,116,000	\$163,494	(2)
 Maintenance & Operation			
For Scrubbers & Pumping Equip.			
189 kW x 8760 x 0.065	107,617		
Power Penalty	<u>296,400</u>		(5)
 Sum of \$/yr. Values		\$671,602	<u>=====</u>



Rogers

PRELIMINARY

ALTERNATIVE II (Cont'd)

2.0

CONSOLIDATED SYSTEM WITH GAS COLLECTION AND COMPRESSION SYSTEM

Installed Equipment	Level Annual \$/yr.
Cost Estimate	
Gas Collection Piping	
Units 1 thru 6	
1,143,096	\$167,464
Gas Compressors	
Units 1 thru 6 (includes 100% spares)	
1,475,100	216,102
Operation & Maintenance for Compressors	387,656 (4)
Electric Power for Compression	
110 kW x 8760 x 0.065	<u>62,634</u>
Sum of \$/yr. Values	\$833,856
	=====

3.0

COMPARISON

Individual Vent Gas Scrubbers	\$671,602
Consolidated With Gas Collection & Compression	<u>833,856</u>
Difference	\$162,254
Favors Individual Gas Scrubbers	

NOTES:

- (1) 55,000 gal. x \$0.55/gal.
- (2) \$ x 0.1465
- (3) Sum Equipment Specified x (0.05 + 0.02) x [2.19]
- (4) Cost Equipment Specified x (0.10 + 0.02) x [2.19]
- (5) Power Penalty - 48 hr. forced outage/year x Unit Rated kW x \$0.065/kWh
Rated kW = one unit of pair = 12,500 + 27,500 + 55,000 = 45,000 kW
48 x 95,000 x 0.065



Rogers

7.1

Blowers

The blowers used to transport the noncondensable gases from the power plant aftercondensers to the Stretford Unit have been specified for price quotations as being fabricated from stainless steel. However, several of the vendors have proposed alternative metal alloys or phenolic coated blower internals. All of the manufacturers have not responded to our quotation solicitation at this date, thus, a complete bid analysis and blower recommendation will be included in the final report.

The noncondensable gas piping networks have been designed so that one blower will be required (with a 100% standby) for each power plant location. Thus, one blower will be installed serving both Units 1 and 2. The blower will have a bypass loop with automatic controls so that the blower will continue to operate should one of the units have a forced or scheduled outage. This same design philosophy applies for the blowers located at Units 3 and 4, Units 5 and 6, Units 7 and 8, and Units 9 and 10.




Rogers

7.2 Data Sheets for Blowers

INSTRUCTIONS BIDERS - FIL IN EVERY SPACE TO MAKE BID COMPLETE

POWER VOLTS 460
 CYCLES 60
 PHASES 3
 STEAM PSIG AT THROTTLE
 EXHAUST



FAN OR BLOWER DATA SHEET

SPECIFICATION NO.
 REQ. NO.

	FLOW SHEET NO. PLANT EQUIP. NO.	Unit 718 16-012 A+B (2 Reqd.)	Unit 718 16-013 A+B (2 Reqd.)		
A. GAS CHARACTERISTICS SERVICE					
1. GAS (O ₂ , H ₂ , N ₂ , CH ₄ , H ₂ , N ₂ , Ar)					
2. S.P. GR. (AIR = 1.0)	0.97	(M.W. = 28.0)			
3. POUNDS PER HOUR	11,282	11,282			
4. STD. CFM @ 60°F & 14.7 PSIA	2545	2545			
5. FLOW TEMP. °F	120	120			
6. CFM AT FLOW TEMP. & INLET PRESS.	2981	2981			
B. PRESSURES					
1. SUCTION (psig)	14.0	14.0			
2. DIFFERENTIAL	6.3	1.3			
3. DISCHARGE	20.3	15.3			
C. OPERATION					
1. EFFICIENCY AT RATING					
2. B.H.P. AT RATING					
3. BID IMPELLER DIA.					
4. MAX. BHP FOR BID IMP. DIA.					
5. R.P.M. OF FAN OR BLOWER					
6. R.P.M. OF DRIVER					
7. TIP SPEED					
8. OUTLET VELOCITY					
9. DIRECTION OF ROTATION CCW FACING COUPLING END CW					
10. NUMBER OF STAGES					
D. CONSTRUCTION & MATERIAL					
1. CASE MATERIAL	S.S.	S.S.			
CONSTRUCTION: HORIZ. OR VERT. SPLIT					
2. IMPELLER	S.S.	S.S.			
3. SHAFT MATERIAL	S.S.	S.S.			
4. SHAFT DIAMETER					
5. FLEXIBLE COUPLING					
6. COUPLING GUARD	Yes	Conform to Cal-OSHA			
7. BASE PLATE					
8. CLASS (FANS)					
9. ARRANGEMENT (FANS)					
10. INLET SCREEN REQUIRED	S.S.	S.S.			
11. CLEAN OUT REQUIRED					
12. VARIABLE INLET VANES REQ'D.	No	No			

MANUFACTURER

MFR'S TYPE & SIZE

718-718 16-013 A+B
 718-711 16-012 A+B

REV. DATE

06/22/11 Issued for Circulation

DATE

	FLOW SHEET NO. PLANT EQUIP. NO.	Unit 718 16-012 A+B (2 Reqd.)	Unit 718 16-013 A+B (2 Reqd.)		
E. BEARINGS & LUBRICATION SERVICE					
1. THRUST (S.A.E. NO. ON FINAL DATA SHEET)					
2. RADIAL (S.A.E. NO. ON FINAL DATA SHEET)					
3. GREASE PKCD. FLOOD OILING. RING OILING.					
THRUST RADIAL	A	B	C		
	A	B	C		
4. TYPE OF CLOSURES					
5. METHOD OF SEALING					
6. VISIBLE LUBRICATORS: TYPE					
7. VISIBLE LUBRICATORS: CAPACITY					
8. BEARINGS: WATER COOLED					
9. LUBRICATING OIL PUMP					
10. LUBRICATING OIL COOLER					
F. CONNECTIONS					
1A. INLET SIZE					
1B. INLET RATING					
1C. INLET FACING					
2A. DISCHARGE SIZE					
2B. DISCHARGE RATING					
2C. DISCHARGE FACING					
2D. DISCHARGE LOCATION					
G. TESTING					
STATE EXTRA COST IF ANY FOR EACH					
1. DYNAMIC BALANCING OF IMPELLERS					
2. WITNESSED PERFORMANCE TEST					
3. INSPECTION					
4. RUNNING TEST WITH ACTUAL DRIVER					
H. MISCELLANEOUS					
1. PRICE EACH F.O.B. F.A.S.					
2. WEIGHT POUNDS NET					
2A. WEIGHT BOXED FOR SHIPMENT					
3. SHIPMENT FROM RCPT OF ORDER WEEKS					
4. DRIVER H.P.					
5. TYPE OF DRIVER: MOTOR OR TURBINE					
6. DRIVER COUPLED: V-BELT GEARED					
7. PERFORMANCE CURVE MANUFACTURERS NO.					
7A. PERFORMANCE CURVE FOREIGN PRINT NO.					
8. OUTLINE DRAWING MANUFACTURERS NO.					
8A. OUTLINE DRAWING FOREIGN PRINT NO.					
9. CROSS SECTION DWG. MANUFACTURERS NO.					
9A. CROSS SECTION DWG. FOREIGN PRINT NO.					
10. MFR'S SERIAL NO. ON FINAL DATA SHEET					
Notes: 1. Bearings must be O.G.E. Geyser Retrofit 2. This is very corrosive to H ₂ S, CO ₂ , HCl					

JOB NO. S-74007 REV. 0
 DWG. NO. DS-16-012 0

POWER VOLTS 460
CYCLES 60 PHASES 3
STEAM PSIG AT THROTTLE
EXHAUST



FAN OR BLOWER DATA SHEET

SPECIFICATION NO. _____
REQ. NO. _____

INSTRUCTIONS: BIDDERS - FILL IN EVERY SPACE TO MAKE BID COMPLETE

	FLOWSHEET NO. PLANT EQUIP. NO.	Unit 9110 16-014 A+B (2 Req'd.)	Unit 9110 16-015 A+B (2 Req'd.)		
A. GAS CHARACTERISTICS SERVICE					
1. GAS CO ₂ , H ₂ S, NH ₃ , CH ₄ , H ₂ , N ₂ , Ar, S ₂ , H ₂ O					
2. S.P. GR. (AIR = 1.0)	0.97	(MW = 28.0)			
3. POUNDS PER HOUR	11,282	11,282			
4. STD. C.F.M. @ 60°F 8.147 PSIA	2545	2545			
5. FLOW TEMP. °F	120	120			
6. CFM AT FLOW TEMP. & Inlet Press.	2981	2981			
B. PRESSURES					
1. SUCTION (PSIG)	14.0	14.0			
2. DIFFERENTIAL	4.9	1.7			
3. DISCHARGE	18.9	15.7			
C. OPERATION					
1. EFFICIENCY AT RATING					
2. B.H.P. AT RATING					
3. BID IMPELLER DIA.					
4. MAX. BHP FOR BID IMP. DIA.					
5. R.P.M. OF FAN OR BLOWER					
6. R.P.M. OF DRIVER					
7. TIP SPEED					
8. OUTLET VELOCITY					
9. DIRECTION OF ROTATION CCW FACING COUPLING END CW					
10. NUMBER OF STAGES					
D. CONSTRUCTION & MATERIAL					
1. CASE MATERIAL	S.S.	S.S.			
CONSTRUCTION: HORIZ. OR VERT. SPLIT					
2. IMPELLER	S.S.	S.S.			
3. SHAFT MATERIAL	S.S.	S.S.			
4. SHAFT DIAMETER					
5. FLEXIBLE COUPLING					
6. COUPLING GUARD	Yes - Conform to Ca. OSHA				
7. BASE PLATE					
8. CLASS (FANS)					
9. ARRANGEMENT (FANS)					
10. INLET SCREEN REQUIRED	S.S.	S.S.			
11. CLEAN OUT REQUIRED					
12. VARIABLE INLET VANES REQ'D.	No	No			
MANUFACTURER					
MFR'S TYPE & SIZE					

	FLOWSHEET NO. PLANT EQUIP. NO.	Unit 9110 16-014 A+B (2 Req'd.)	Unit 9110 16-015 A+B (2 Req'd.)		
E. BEARINGS & LUBRICATION SERVICE					
1. THRUST (S.A.E. NO. ON FINAL DATA SHEET)					
2. RADIAL (S.A.E. NO. ON FINAL DATA SHEET)					
3. GREASE PKGD. FLOOD OILING. RING OILING.					
THRUST RADIAL	A	B	C		
A	B	C			
4. TYPE OF CLOSURES					
5. METHOD OF SEALING					
6. VISIBLE LUBRICATORS: TYPE					
7. VISIBLE LUBRICATORS: CAPACITY					
8. BEARINGS WATER COOLED					
9. LUBRICATING OIL PUMP					
10. LUBRICATING OIL COOLER					
F. CONNECTIONS					
1A. INLET SIZE					
1B. INLET RATING					
1C. INLET FACING					
2A. DISCHARGE SIZE					
2B. DISCHARGE RATING					
2C. DISCHARGE FACING					
2D. DISCHARGE LOCATION					
G. TESTING					
STATE EXTRA COST IF ANY FOR EACH					
1. DYNAMIC BALANCING OF IMPELLERS					
2. WITNESSED PERFORMANCE TEST					
3. INSPECTION					
4. RUNNING TEST WITH ACTUAL DRIVER					
H. MISCELLANEOUS					
1. PRICE EACH F.O.B. F.A.S.					
2. WEIGHT POUNDS NET					
2A. WEIGHT BOXED FOR SHIPMENT					
3. SHIPMENT FROM RCPT OF ORDER WEEKS					
4. DRIVER H.P.					
5. TYPE OF DRIVER: MOTOR OR TURBINE					
6. DRIVER COUPLED, V-BELT, GEARED					
7. PERFORMANCE CURVE MANUFACTURERS NO.					
7A. PERFORMANCE CURVE FOREIGN PRINT. NO.					
8. OUTLINE DRAWING MANUFACTURERS NO.					
8A. OUTLINE DRAWING FOREIGN PRINT. NO.					
9. CROSS SECTION DWG. MANUFACTURERS NO.					
9A. CROSS SECTION DWG. FOREIGN PRINT. NO.					
10. MFR'S SERIAL NO. ON FINAL DATA SHEET					
Notes:	1) Bearing must be sealed.				
	2) Gas is very corrosive due to H ₂ S, CO ₂ , H ₂ O.				

REV.	DATE	REV.	DATE
16-010-9110	16-015	16-010-12	16-014
0	6/22/19	0	6/22/19

EQ314

JOB. NO. S-791007 REV.	
DWG. NO.	DS-16-014 0

PAGE Geysco Retrofit

EQ314

INSTRUCTIONS BIDDERS - FIL IN EVERY SPACE TO MAKE BID COMPLETE

POWER VOLTS 460
 CYCLES 60 PHASES 3
 STEAM P.S.I.G. AT THROTTLE
 EXHAUST



FAN OR BLOWER DATA SHEET

SPECIFICATION NO. _____
 REQ. NO. _____

	Unit 11	Unit 11		
PLANT EQUIP. NO.	16-016	16-017		
A. GAS CHARACTERISTICS SERVICE	A+B (2 Req'd.)	A+B (2 Req'd.)		
1. GAS CO ₂ , H ₂ S, NH ₃ , CH ₄ , H ₂ , N ₂ , Ar, H ₂ O	1.1	(m.w. = 33.1)		
2. S.P. GR. (AIR = 1.0)	18,649	18,649		
3. POUNDS PER HOUR	3558	3558		
4. STD. C.F.M. @ 60°F & 14.7 PSIA	120	120		
5. FLOW TEMP. °F	4167	4167		
6. CFM AT FLOW TEMP. & Inlet Press.				
B. PRESSURES				
1. SUCTION (psi.g)	14.0	14.0		
2. DIFFERENTIAL	6.4	1.5		
3. DISCHARGE	20.4	15.5		
C. OPERATION				
1. EFFICIENCY AT RATING				
2. B.H.P. AT RATING				
3. BID IMPELLER DIAM.				
4. MAX BHP FOR BID IMP. DIA.				
5. R.P.M. OF FAN OR BLOWER				
6. R.P.M. OF DRIVER				
7. TIP SPEED				
8. OUTLET VELOCITY				
9. DIRECTION OF ROTATION CCW FACING COUPLING END CW				
10. NUMBER OF STAGES				
D. CONSTRUCTION & MATERIAL				
1. CASE MATERIAL	S.S.	S.S.		
CONSTRUCTION: HORIZ. OR VERT. SPLIT				
2. IMPELLER	S.S.	S.S.		
3. SHAFT MATERIAL	S.S.	S.S.		
4. SHAFT DIAMETER				
5. FLEXIBLE COUPLING				
6. COUPLING GUARD	Yes - Conform	to Cal-OSHA		
7. BASE PLATE				
8. CLASS (FANS)				
9. ARRANGEMENT (FANS)				
10. INLET SCREEN REQUIRED	S.S.	S.S.		
11. CLEAN-OUT REQUIRED	No	No		
12. VARIABLE INLET VANES REQ'D.	No	No		

MANUFACTURER

MFR'S TYPE & SIZE

11-11 16-017 A+B
11-78 16-016 A+B

REV. DATE

06/23/79 Issued for Quotation

EX. DATE

EQ314

	Unit 11	Unit 11		
PLANT EQUIP. NO.	16-016	16-017		
E. BEARINGS & LUBRICATION SERVICE	A+B (2 Req'd.)	A+B (2 Req'd.)		
1. THRUST: (S.A.E. NO. ON FINAL DATA SHEET)				
2. RADIAL: (S.A.E. NO. ON FINAL DATA SHEET)				
3. GREASE PKGD, FLOOD OILING, RING OILING.	A	B	C	
THRUST RADIAL	A	B	C	
4. TYPE OF CLOSURES:				
5. METHOD OF SEALING				
6. VISIBLE LUBRICATORS: TYPE				
7. VISIBLE LUBRICATORS: CAPACITY				
8. BEARINGS WATER COOLED				
9. LUBRICATING OIL PUMP				
10. LUBRICATING OIL COOLER				
F. CONNECTIONS				
1A. INLET: SIZE				
1B. INLET: RATING				
1C. INLET: FACING				
2A. DISCHARGE: SIZE				
2B. DISCHARGE: RATING				
2C. DISCHARGE: FACING				
2D. DISCHARGE: LOCATION				
G. TESTING				
STATE EXTRA COST IF ANY FOR EACH				
1. DYNAMIC BALANCING OF IMPELLERS				
2. WITNESSED PERFORMANCE TEST				
3. INSPECTION				
4. RUNNING TEST WITH ACTUAL DRIVER				
H. MISCELLANEOUS				
1. PRICE EACH F.O.B. F.A.S.				
2. WEIGHT POUNDS NET				
2A. WEIGHT BOXED FOR SHIPMENT				
3. SHIPMENT FROM RCPT OF ORDER WEEKS				
4. DRIVER H.P.				
5. TYPE OF DRIVER: MOTOR OR TURBINE				
6. DRIVER: COUPLED, V-BELT, GEARED				
7. PERFORMANCE CURVE MANUFACTURERS NO.				
7A. PERFORMANCE CURVE FOREIGN PRINT NO.				
8. OUTLINE DRAWING MANUFACTURERS NO.				
8A. OUTLINE DRAWING FOREIGN PRINT NO.				
9. CROSS SECTION DWG. MANUFACTURERS NO.				
9A. CROSS SECTION DWG. FOREIGN PRINT NO.				
10. MFR'S SERIAL NO. ON FINAL DATA SHEET				
Notes:	1) Bearings must be sealed.			
	2) Gas is very corrosive due to H ₂ S, CO ₂ , & H ₂ O.			

PGE Geysers Retrofit

JOB. NO. S-79007 REV.
 DWG. NO. DS-16-016 0

POWER: VOLTS 460
CYCLES 60 PHASES 3
STEAM PSIG AT THROTTLE
EXHAUST



FAN OR BLOWER DATA SHEET

SPECIFICATION NO. _____
REQ. NO. _____

INSTRUCTIONS: BIDDERS: FILL IN EVERY SPACE TO MAKE BID COMPLETE

	FLOWSHEET NO. PLANT EQUIP. NO.	Unit 12	Unit 12		
A GAS CHARACTERISTICS SERVICE		16-018	16-019		
1. GAS CO ₂ , H ₂ S, NH ₃ , CH ₄ , H ₂ , N ₂ , Ar, He, O ₂		A/B (2 Rad)	A/B (2 Rad)		
2. S.P. GR. (AIR = 1.0)		1	MW = 32.8		
3. POUNDS PER HOUR		1124	1124		
4. STD. CFM. @ 60°F. & 14.7 PSIA		2141	2141		
5. FLOW TEMP. °F		120	120		
6. CFM. AT FLOW TEMP. Inlet Press.		2507	2507		
B PRESSURES					
1. SUCTION (PSIG)		14.0	14.0		
2. DIFFERENTIAL		5.2	1.4		
3. DISCHARGE		19.2	15.4		
C OPERATION					
1. EFFICIENCY AT RATING					
2. B.H.P. AT RATING					
3. BID IMPELLER DIA.					
4. MAX. BHP FOR BID IMP. DIA.					
5. R.P.M. OF FAN OR BLOWER					
6. R.P.M. OF DRIVER					
7. TIP SPEED					
8. OUTLET VELOCITY					
9. DIRECTION OF ROTATION CCW FACING COUPLING END CW					
10. NUMBER OF STAGES					
D CONSTRUCTION & MATERIAL					
1. CASE MATERIAL		S.S.	S.S.		
CONSTRUCTION: HORIZ. OR VERT. SPLIT					
2. IMPELLER		S.S.	S.S.		
3. SHAFT MATERIAL		S.S.	S.S.		
4. SHAFT DIAMETER					
5. FLEXIBLE COUPLING					
6. COUPLING GUARD	Yes	Conform to 16 CFR OSHA			
7. BASE PLATE					
8. CLASS (FANS)					
9. ARRANGEMENT (FANS)					
10. INLET SCREEN REQUIRED		S.S.	S.S.		
11. CLEAN-OUT REQUIRED					
12. VARIABLE INLET VANES REQ'D	No	No			
MANUFACTURER					
MFR'S TYPE & SIZE					

	FLOWSHEET NO. PLANT EQUIP. NO.	Unit 12	Unit 12		
E. BEARINGS & LUBRICATION SERVICE					
1. THRUST (S.A.E. NO. ON FINAL DATA SHEET)					
2. RADIAL (S.A.E. NO. ON FINAL DATA SHEET)					
3. GREASE PKGD	FLOOD OILING	RING OILING			
THRUST A	B	C			
RADIAL A	B	C			
4. TYPE OF CLOSURES					
5. METHOD OF SEALING					
6. VISIBLE LUBRICATORS: TYPE					
7. VISIBLE LUBRICATORS: CAPACITY					
8. BEARINGS: WATER COOLED					
9. LUBRICATING OIL PUMP					
10. LUBRICATING OIL COOLER					
F. CONNECTIONS					
1A. INLET SIZE					
1B. INLET: RATING					
1C. INLET: FACING					
2A. DISCHARGE SIZE					
2B. DISCHARGE: RATING					
2C. DISCHARGE: FACING					
2D. DISCHARGE: LOCATION					
G. TESTING					
STATE EXTRA COST IF ANY FOR EACH					
1. DYNAMIC BALANCING OF IMPELLERS					
2. WITNESSED PERFORMANCE TEST					
3. INSPECTION					
4. RUNNING TEST WITH ACTUAL DRIVER					
H. MISCELLANEOUS					
1. PRICE EACH F.O.B. F.A.S.					
2. WEIGHT POUNDS NET					
2A. WEIGHT BOXED FOR SHIPMENT					
3. SHIPMENT FROM RCPT OF ORDER WEEKS					
4. DRIVER H.P.					
5. TYPE OF DRIVER: MOTOR OR TURBINE					
6. DRIVER COUPLED: V-BELT, GEARED					
7. PERFORMANCE CURVE MANUFACTURERS NO.					
7A. PERFORMANCE CURVE FOREIGN PRINT NO.					
8. OUTLINE DRAWING MANUFACTURERS NO.					
8A. OUTLINE DRAWING FOREIGN PRINT NO.					
9. CROSS SECTION DWG. MANUFACTURERS NO.					
9A. CROSS SECTION DWG. FOREIGN PRINT NO.					
10. MFR'S SERIAL NO. ON FINAL DATA SHEET					
11. (Note) Bearing must be rated					
12. Gas is very corrosive. Use 15% H ₂ S, 10% H ₂ O					

JOB NO. S79007 REV.
DWG NO. DS-16-018 O

REV. DATE
12-12 16-019 A-1
2-9-10 16-018 A-1
06/27/11 Issued for Quotation 12/13/11



Rogers

8.1 Equipment Quotations

Table 8.1, entitled Equipment Summary All Units - Stretford Process, indicates the Equipment Quotations by various vendors.

Table 8.1.1 indicates the costs from vendors for the Stretford Chemicals (Inventory for the process.

Section 8.1.2 describes the Power Service and indications of associated costs related to the Stretford Units.



Rogers

TABLE 8.1
EQUIPMENT SUMMARY ALL UNITS
STRETFORD PROCESS

In one configuration under consideration three Stretford units are contemplated as follows:

<u>Stretford Unit</u>	<u>#/Hr. N. C.</u>	<u>#/Hr. H₂S</u>	<u>Long Tons Sulfur/Day</u>
Units 1 through 6 - 1	26,548	1,318	13.29
Units 7, 8, 9 - 2	25,730	1,347	13.68
Units 9, 10, 12 - 3	19,120	363	3.66

VENDOR

<u>Stretford Unit</u>	<u>Parsons</u>	<u>J. T. Pritchard</u>	<u>Peabody Engr.g</u>
1 Plot A	95' x 162'	125' x 125'	Not Stated
2 Plot A	95' x 162'	125' x 125'	Not Stated
3 Plot A	77' x 128'	100' x 100'	Not Stated
1 Installed Cost \$ (± %)	4,800,000 (-10%, + 30%)*		
Estimated \$		3,610,000	Not Stated
2 "	5,000,000	3,610,000	Not Stated
3 "	3,200,000	1,870,000	Not Stated
1 One Time Royalty \$ incl. above \$		91,160	Not Stated
2 " " "	" "	89,160	Not Stated
3 " " "	" "	57,200	Not Stated

*Based on Gulf Coast installed price



Rogers

TABLE 8.1.1
STRETFORD CHEMICALS (INVENTORY)

VENDOR

<u>Stretford Unit</u>	<u>Parsons</u>	<u>J. T. Pritchard</u>	<u>Peabody</u>
1 Sol. gals/cost \$	307,000/169,000	250,000/62,500	N. S.
2 Sol. gals/cost \$	316,000/174,000	250,000/62,500	N. S.
3 Sol. gals/cost \$	84,000/ 46,500		N. S.
Sol. Cost/gal. \$	0.55	0.25	N. S.



Rogers

8.1.2 POWER SERVICE

8.1.2.1 TABLES 8.1.2.1 and 8.1.2.2 summarize the estimated kilowatt demand for each of the three Stretford facilities, the estimated kVA demand based on an assumed 0.85 power factor and the closest standard transformer size if an independent power supply is provided.

The estimated demands were obtained from R. M. Parsons Co. and include lighting. Largest motor will not exceed 200 hp. Service is required at 480 volts.



Rogers

TABLE 8.1.2.1

<u>Stretford Facility for</u>	<u>Estimated Demand</u> kW	<u>Closest Standard Oil Insulated Transformer</u> kVA ¹
Units 1 thru 6	1065	1252 1500 OA or 1000 kVA OA/FA (1288 kVA max.)
Units 7, 8 and 11	1095	1288 1500 OA or 1000 kVA OA/FA (1288 kVA max.)
Units 9, 10 and 12	300	353 500 OA

¹OA - Self cooled rating at 55°C rise

FA - rating with fans

13% additional capacity available if 65°C temperature rise is utilized

TABLE 8.1.2.2

<u>Stretford Facility for</u>	<u>Location</u>	<u>Existing Aux. Transformer</u> Max. Capacity	<u>Load</u>	<u>Existing Retrofit</u> ²	<u>Estimated Increase with Stretford</u>	<u>Total</u>
Units 1 thru 6	Unit 3 or 4	1546 ¹	1185	1395	1252	2647 *
Units 7, 8 and 11	Unit 7 or 8	3500	2145	3113	1288	4401 *
Units 9, 10 and 12	Unit 11 12	4200	2145	2615	353	2965

¹With fans, 65°C temperature rise

²Includes noncondensable gas blower

* Exceeds existing transformer capacity



Rogers

8.1.2.2 Two alternatives have been considered for power service to the Stretford units:

- a) From the power plant 480 volt auxiliary bus, or
- b) an independent transformer connected to one of the high voltage transmission lines or the 22 kV distribution line now in use in some parts of the Geysers area.

8.1.2.3 The major problems with using the auxiliary bus are transformer capacity voltage drop and reliability. Table 8.1.2 summarizes the change in load on the auxiliary transformer. If the proposed Stretford facilities are located adjacent to the existing facilities no significant voltage drop problems are foreseen.

Reliability is a major consideration. Since one Stretford facility serves several power plants, failure of the power supply at the "host" unit is not tolerable.

8.1.2.4 For the Stretford facility proposed for Units 1 thru 6, the Alternative 1 site, with installation adjacent to the Unit 4 auxiliary transformers, does not have sufficient capacity; however, capacity can be provided with a replacement transformer. The alternative 2 site is too far away from the plant to utilize the auxiliary transformer of this particular plant.

For the Stretford facility proposed at Units 7 for Units 7 and 11, the transformers at these units have adequate capacity and voltage drop in the feeder is not a major problem.

8.1.2.5 Units 3, 4, 6 and 7 auxiliary transformers are connected between the generator circuit breaker and the main transformer and power is normally available whether or not the generator is in service. However a transmission line outage on main transformer or secondary connection failure would shutdown the Stretford facility. Reliability can be improved by providing a dual 480 volt supply, with one feeder from the auxiliary bus for each unit.

Unit 4 is unique with an auxiliary or start-up transformer connected at the main transformer circuit breaker. However failure of transmission line or the main transformer would effect the usefulness of this connection.

At Units 7 and 8, one auxiliary transformer is capable of picking up both the Stretford unit and auxiliary power load of both units; however, the 4,000 ampere bus on the secondary of the auxiliary



Rogers

transformer limits the supply to the existing 480 volt switchgear to 3,300 kVA. A circuit breaker connected to transformer terminal for a feeder to the Stretford unit will bypass this bottleneck.

Unit 11 in addition to the auxiliary transformer associated with each generator auxiliary or start-up transformer is connected to the 480V auxiliary power bus. This transformer is provided since the Stretford facility load is very small and does not present a problem regarding auxiliary transformer capacity.

8.1.2.6 The installation of a separate stepdown transformer supplied from either a transmission line or a local distribution line free of most power plant interruptions with an emergency tie to a unit auxiliary power bus appears to be the most attractive scheme.

For Unit 3, this would be from the Unit 3 auxiliary power bus and the local distribution line supplying the start-up bank for Unit 4. One auxiliary power transformer would be required.

For Unit 7, a new distribution line would be required and the alternative supply would be off either the Unit 7 or 8 auxiliary switchgear.

Unit 11 has an existing tie to an outside distribution line. A dual supply from the 480 volt switchgear is considered adequate.

8.1.2.7 Power service to noncondensable blowers will be taken from the individual unit ~~auxiliary~~ 480 volt switchgear or motor control center.



Rogers

8.2 Installation Costs

The following Section depicts the Total Cost Installed of Stretford Systems.

SUMMARY

<u>Item</u>	<u>Direct Cost</u>	<u>GM Est.</u>
Units 1 through 6	\$ 8,267,400	\$ 9,970,500
Unit 7, 8 and 11	8,353,200	10,073,900
Unit 9, 10 and 12	<u>6,271,500</u>	<u>7,563,400</u>
Totals	\$22,892,100	\$27,607,800

These costs are June 1979 costs. In the Final Report they will also be escalated to time of construction. Also the same factors have been used as in Milestone 1 and 2 reports for contingency and labor rates, etc.

The detailed breakdown of each unit Stretford System follows:



ROGERS ENGINEERING CO., INC.
111 PINE STREET
SAN FRANCISCO, CALIF. 94111
JOB NO.

PG-023

ROGERS ENGINEERING CO., INC. COST ESTIMATE
JOB NAME-STRFD 11 JOB NO.-S79007 CLIENT-P G AND E ESTIMATE DATE- 29 JUNE 79

ITEM NO.	DESCRIPTION	MATL&EQPT	INSTALL	MANHOURS	TOTAL
54-291-4	FOUNDATION BLWR 7&8	890.	4193.	180.	5084.
54-291-5	FOUNDATION BLWR 11	890.	4193.	180.	5084.
54-293-8	EQ STRETFORD 7-8-11	5173800.	0.	0.	5173800.
54-293-9	EQ BLOWER 7&8	193344.	0.	0.	193344.
54-293-10	INSTALL BLOWER 7&8	165360.	65230.	2806.	230590.
54-293-11	EQ BLOWER 11	198432.	0.	0.	198432.
54-293-12	INSTALL BLOWER 11	171720.	65230.	2806.	236950.
54-294-1	EQ UNIT 7 ELEC	65126.	0.	0.	65126.
54-294-2	INSTALL ELECT & MISC	28620.	62435.	2685.	91055.
54-296-1	GAS BLWR 7&8 ELEC	2162.	2330.	100.	4492.
54-296-2	GAS BLWR 11 ELEC	8001.	2795.	120.	10796.
54-297-3	NC GAS PIPE 7-8-11	674160.	0.	0.	674160.
54-297-4	INSTALL PIPE 7-8-11	127200.	1025046.	44088.	1152246.
54-293-19	R CRANE, TRUCKS 7-11	31800.	18637.	802.	50437.
54-299-4	CONTROLS BLWR 7&8	114480.	16308.	701.	130788.
54-299-5	CONTROLS BLOWER 11	114480.	16308.	701.	130788.
ACCOUNT TOTAL		7070466.	1282705.	55170.	8353172.

365-1	CONST FIELD	0.	0.	0.	0.
365-2	GFNRL ENG	0.	0.	0.	0.
365-3	OTHR ENGINEERING	0.	0.	0.	0.

ACCOUNT TOTAL		0.	0.	0.	0.
----------------------	--	----	----	----	----

TABLE: 8.2.2
STRETFORD SYSTEM
UNITS 7, 8, 11

DRAWING NO.	REV.



ROGERS ENGINEERING CO., INC. COST ESTIMATE
 JOB NAME-STRFD 1-6 JOB NO.-S79007 CLIENT-P G AND E ESTIMATE DATE- 29 JUNE 79

ITEM NO.	DESCRIPTION	MATL&EQPT	INSTALL	MANHOURS	TOTAL
54-293-1	EQ STRETFORD 1-6	4968850.	0.	0.	4968850.
54-293-2	EQ BLOWER 1&2	171720.	0.	0.	171720.
54-293-3	INSTALL BLOWER	139920.	55912.	2405.	195832.
54-293-4	EQ BLOWER 3&4	166632.	0.	0.	166632.
54-293-5	INSTALL BLOWER 3&4	152640.	55912.	2405.	208552.
54-293-6	EQ BLOWER 5&6	203520.	0.	0.	203520.
54-293-7	INSTALL BLOWER 5&6	184440.	65230.	2806.	249670.
54-297-1	NC GAS PIPE 1-6	534240.	0.	0.	534240.
54-297-2	INSTALL PIPE 1-6	101760.	838674.	36072.	940434.
54-291-1	FOUNDATION BLWR 1&2	890.	4193.	180.	5084.
54-291-2 F	FOUNDATION BLWR 3&4	890.	4193.	180.	5084.
54-291-3	FOUNDATION BLWR 5&6	890.	4193.	180.	5084.
54-293-18	K CRANE, TRUCKS 1-6	31800.	18637.	802.	50437.
54-294-1	EQ UNIT 3 ELEC	65126.	0.	0.	65126.
54-294-2	INSTALL & MISC MTL	26076.	63832.	2745.	89908.
54-296-1	GAS BLWR 1&2 ELEC	5724.	2982.	128.	8706.
54-296-4	GAS BLWR 3&4 ELEC	3053.	1864.	80.	4917.
54-296-3	GAS BLWR 5&6 ELEC	13992.	4659.	200.	18651.
54-299-1	CONTROLS BLOWER 1&2	101760.	13978.	601.	115738.
54-299-2	CONTROLS BLOWER 3&4	108120.	13978.	601.	122098.
54-299-3	CONTROLS BLOWER 5&6	120840.	16338.	701.	137148.
<hr/>					
ACCOUNT TOTAL		7102884.	1164545.	50088.	8267429.

365-1	CONST FIELD	0.	0.	0.	0.
365-2	GENRL ENG	0.	0.	0.	0.
365-3	OTHR ENGINEERING	0.	0.	0.	0.
<hr/>					
ACCOUNT TOTAL		0.	0.	0.	0.



ROGERS ENGINEERING CO., INC. COST ESTIMATE

JOB NAME-STRFD 12

JOB NO.-S79007

CLIENT-P G AND E

ESTIMATE DATE- 29 JUNE 79

ITEM NO.	DESCRIPTION	MATL&EQPT	INSTALL	MANHOURS	TOTAL
54-291-6	FOUNDATION BLWR 9&10	890.	4193.	180.	5084.
54-291-7	FOUNDATION BLWR 12	890.	4193.	180.	5084.
54-293-13	EQ STRETFORN 9-10-12	3246475.	0.	0.	3246475.
54-293-14	EQ BLOWER 9&10	188256.	0.	0.	188256.
54-293-15	INSTALL BLOWER 9&10	171720.	60571.	2605.	232291.
54-293-16	EQ BLOWER 12	181896.	0.	0.	181896.
54-293-17	INSTALL BLOWER 12	165360.	60571.	2605.	225931.
54-293-20	R CRANE, TRUCKS 9-12	25440.	16308.	701.	41748.
54-294-1	EQ UNIT 12 ELEC	16560.	0.	0.	10560.
54-294-2	INSTALL ELEC	50880.	52184.	2244.	103064.
54-296-1	GAS BLWR ELEC 9&10	6716.	2050.	88.	8766.
54-296-2	GAS BLWR ELEC 12	1081.	1972.	46.	2153.
54-297-4	NC GAS PIPE 9-10-12	642360.	0.	0.	642360.
54-297-5	INSTALL PIPE 9-10-12	114480.	1001750.	43086.	1116230.
54-299-6	CONTROLS BLOWER	114480.	16308.	701.	130788.
54-299-7	CONTROLS BLOWER 182	114480.	16308.	701.	130788.
<hr/>					
ACCOUNT TOTAL		5035965.	1235507.	53140.	5271472.

365-1	CONST FIELD	0.	0.	0.	0.
365-2	GENRL ENG	0.	0.	0.	0.
365-3	OTHR ENGTNEERING	0.	0.	0.	0.
<hr/>					
ACCOUNT TOTAL		0.	0.	0.	0.

TABLE: 8.2.3

STRETFORD SYSTEM

BG-023

JOB NO.

ROGERS ENGINEERING CO., INC.

111 PINE STREET

SAN FRANCISCO, CALIF. 94111

DRAWING NO.	REV.

SHEET 1 OF 1



Rogers

8.3 Operation and Maintenance Costs

These costs are indicated in Table 8.3.1 which follows in this Section.



Rogers

TABLE 8.3.1
OPERATION AND MAINTENANCE COSTS
STEAM AND OPERATING SOLUTION

REPLACEMENT COST

VENDOR

<u>Stretford Unit</u>	<u>Parsons</u>	<u>J. T. Pritchard</u>	<u>Peabody</u>
1 Operating, Sol'n replacement cost/ day/L. T./Daily Cost \$		80/1094	N. S.
2 "		80/1063	N. S.
3 "		80/393	N. S.
1 Steam requirements Press-psig#/Hr./L. T./Day		50/3694	N. S.
2 "		50/3588	N. S.
3 "		50/988	N. S.