



Rogers

ECONOMIC STUDY

(HR)

OF

GEOOTHERMAL STEAM PRODUCTION
AND POWER GENERATION

FOR

PHILLIPS PETROLEUM COMPANY

BY

ROGERS ENGINEERING CO., INC.
SAN FRANCISCO

S-77001

February 1, 1977

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.



Rogers

- 1. INTRODUCTION**
- 2. SUMMARY**
- 3. DESCRIPTION**
 - A. General**
 - B. Power Plant**
 - C. Steam Gathering System and Reinjection Facilities**
 - D. Production and Reinjection Wells**
- 4. COST ESTIMATE**
 - A. Power Plant**
 - B. Steam Gathering and Reinjection Facilities**
 - C. Production and Reinjection Wells**
- 5. ECONOMIC ANALYSIS**
 - A. General**
 - B. Power Plant**
 - C. Steam Production, Gathering and Reinjection Facilities**



Rogers

1. INTRODUCTION

This report presents the results of our study to determine the required selling price of geothermal flash steam in order for Phillips Petroleum Company to obtain a rate of return on investment of 10, 15 or 20 percent on its discovery in Nevada.

The economic evaluations are based on an order-of-magnitude type of estimate of capital costs for the flash steam production, steam gathering and brine reinjection system to supply steam to a 55 MW (Gross) geothermal power generating plant, using mixed pressure (double flash steam) turbine design.

Geothermal well costs, brine quality and well productivity data were provided by Phillips Petroleum Company and are based on the discovery wells in Nevada. Power plant costs are based on current technology and available hardware, under construction at the present time. Costs have been escalated to 1977.

2. SUMMARY

Based on resource temperatures of 400°F and well flow of 450,000 pounds of geothermal brine per hour per well, the flash steam must be priced at 10, 14 or 20 mills/kWh in order to achieve a rate of return on the investment for the production quantities of 10, 15 or 20 percent respectively.

The corresponding cost of power (electricity) at the power plant bus bar would be 24, 28, 34 mills/kWh.



Rogers

3. DESCRIPTION

A. General

The geothermal power plant, utilizes steam flashed from geothermal brine. A two stage flash system was chosen to maximize the power production for the given well flow. The design conditions used as a basis for the cost estimates are as follows:

Power Plant (Gross)	55 MW
Reservoir Bottom Hole Temperature	400°F
Wellhead Pressure	75 psig
Well Flow Each Well	450,000 lbs./hr.
Production Wells Initially Required, Including One Spare	17
Reinjection Wells Initially Required	8

B. Power Plant

The power plant consists of the powerhouse building which encloses the generating equipment and auxiliaries, the high voltage substation, and the cooling tower. The high voltage substation is located adjacent to the powerhouse. The cooling tower is located on the opposite side and downwind of the powerhouse with respect to the prevailing winds and at a sufficient distance to minimize the exhaust plume impingement on the powerhouse and the high voltage substation.



Rogers

The equipment inside the power plant building consists of the turbine generator, low level direct contact condenser, hot well pumps, electrical switchgear, generator step-up transformer and associated mechanical and electrical auxiliary equipment.

The steam entering the turbine is condensed in the direct contact condenser. The hot water is pumped to the cooling tower by the hot well pumps and the cooled water is returned to the condenser assisted by gravity and the condenser vacuum. The amount of water evaporated in the cooling tower nearly equals the steam flow to the turbine. The excess is reinjected into the ground together with the flash waste water. Therefore, once the plant is started no additional cooling water is required.

C. Steam Gathering System and Reinjection Facilities

Hot water from the wells is transported by the wellhead pressure to the high pressure flash drum. Each flash drum, approximately 10 ft. in diameter and 20 ft. high, is fed by a maximum of four wells. The high pressure steam and hot water remaining from the first stage flash are piped separately to the powerhouse. The high pressure steam is fed to the turbine and the hot water to a single low pressure flash drum.



Rogers

The low pressure flash drum, approximately 20 ft. in diameter and 30 ft. high, is located near the powerhouse.

The low pressure steam from the second flash is fed to the turbine and the remaining hot water from the flash drum is pumped directly to the reinjection wells.

A holding pond is provided at each high pressure separator for the hot water in case the low pressure flash drum is out of service. Pumps are installed at each holding pond so that the waste water can be pumped to the reinjection wells. A pump is also provided at the cooling tower for disposal of the blowdown into the reinjection system.

D. Production and Rejection Wells

The production wells are spaced at approximately 1,000 ft. intervals. Seventeen wells are drilled initially to provide the required steam for the power plant. From previous experience it has been determined that the hot water flow from each well decreases with time until in approximately ten years it levels off to about one half the original flow. Therefore, additional wells are required to meet the power plant demand throughout the life of the plant. The well drilling schedule for the power plant requirements is shown in Table IV.



Rogers

The reinjection wells are drilled approximately 9,000 ft. from the power plant at the edge of the hot water field. Eight reinjection wells are required, with two extra wells drilled as spares in the beginning of the power plant life.

4. COST ESTIMATE

A. Power Plant

The power plant cost estimate was made using actual costs from previously built plants escalated to 1977 and from current data supplied by major equipment manufacturers. A summary of the installed cost is shown in Table I.

The current (first quarter 1977) installed costs of the major equipment used in the cost estimate are shown below:

Turbine Generator 55 MW Gross	\$6,090,000
Condenser and Gas Removal Equipment	1,420,000
Hot Well Pumps	1,020,000
Cooling Tower	1,300,000

B. Steam Gathering and Rejection Facilities

The cost estimate for the steam gathering and reinjection facilities was made from cost of the individual components. A summary of the installed cost is shown in Table II.



Rogers

C. Production and Rejection Wells

The drilling cost of the wells was obtained from Paul English of Phillips Petroleum Company.

Production Well (1977)	\$488,000
Rejection Well (1977)	\$435,000

5. ECONOMIC ANALYSIS

A. General

The economic analysis was made separately for the power plant and for the steam producing, gathering and reinjection facilities.

The power plant analysis developed the cost per kilowatt-hour based on the cost of the installed power plant excluding the price of steam.

The steam producing, gathering and reinjection facilities analysis developed the selling price of steam per kilowatthour, to provide various rates of return on investment.

By adding the two kilowatthour cost elements the rate of return on investment on the steam producing, gathering and reinjection facilities can be obtained for various electric power selling prices.



Rogers

B. Power Plant

The economic analysis of the power plant is shown in Table III. The power plant cost is the cost at start of operation in early 1981. Escalation of the 1977 cost was based on figures given in the next section.

C. Steam Production, Gathering and Reinjection Facilities

The results of the economic analysis of the steam producing, gathering and reinjection facilities are shown in Figure 1 which plots the selling price of steam versus the return on investment. Sample calculation for the rate of return are shown in Table IV.

The analysis was made using the present worth method wherein the return on investment is equal to that return which balances the present worth of the investment outlay and the present worth of the positive net cash flow.

The following data supplied in a telephone conversation by Paul English were used in the development of the economic analysis.

a. Land Acquisition Cost	\$152,500
b. Annual Lease Rentals, Payable up to Time of Production	\$ 61,200



Rogers

c. Escalation	
1977-1978	10.0%
1979	9.5%
1980	9.0%
1981	8.5%
1982	8.0%
1983-1986	7.5%
No escalation beyond 1986	
d. 30% of well cost depreciable	
70% of well cost intangible drilling cost	
e. Three dry wells	
f. Federal and State Income Tax	51%
g. Royalty Rate	10%
h. Gross Production Tax and Ad Valorum Tax	3%
i. Overhead Investment Cost, Excluding Land	1.65%

The following additional assumptions were made.

- a. Wells and gathering system has 20 year life for accounting purposes.
- b. Straight line depreciation
- c. Life of field 35 years, which is the same as the power plant.

Investment tax credit was not used since it would balance the interest on the money spent before production starts.



Rogers

TABLE 1

CAPITAL COST SUMMARY
55 MW GENERATING UNIT (Note 1)
COST ESTIMATE

<u>Account No. (2)</u>	<u>Dollars (Thousands)</u>	
311	Structures and Improvements	\$ 3,500
314	Turbine Generator Unit, Condenser, Cooling Tower, Pumps, etc.	11,620
315	Power Plant Electrical Equipment	1,240
316	Miscellaneous Power Plant Equipment	580
353	Substation Equipment	<u>610</u>
	Total Direct Cost	\$17,550
	Engineering and Construction Management	<u>1,755</u>
	Sub Total	\$19,305
	Contingency 10%	<u>1,930</u>
	Sub Total	\$21,235
	(3) Financing During Construction @ 9%	<u>1,911</u>
	Total Estimated Installed Cost (4)	\$23,146

NOTES

- (1) Generating Unit is 55 Gross MW
Net Output at Bus 51.5 MW
- (2) Account Numbers include equipment in accordance with Federal Power
Commission Publication UNIFORM SYSTEMS OF ACCOUNTS PRESCRIBED FOR
PUBLIC UTILITIES AND LICENSEES FPC A-118
- (3) 24 month construction period. Financing during construction equal to
approximately total cost for one year at 9%.
- (4) Costs are for First Quarter 1977 (*Escalated to 1980?*)



Rogers

TABLE 11

CAPITAL COST SUMMARY
STEAM GATHERING AND REINJECTION SYSTEM

GATHERING SYSTEM

Piping	\$2,651,000
Valves and Controls	279,000
Separators	<u>940,000</u>
Sub Total	\$3,870,000

REINJECTION SYSTEM

Piping	\$2,800,000
Pumps and Holding Ponds	276,000
Valves and Controls	<u>92,000</u>
Sub Total	\$3,168,000

TOTAL ESTIMATED INSTALLED COST (Note 1 and 2)	\$7,038,000
--	--------------------

NOTES

- (1) Costs are for First Quarter 1977
- (2) Includes engineering and construction management, contingency and financing during construction



Rogers

TABLE III

ESTIMATED COST OF POWER EXCLUDING FUEL COSTS

Fixed Charges

1. Return and Depreciation	9.91
2. Taxes and Insurance	<u>5.43</u>
3. Sub Total (Fixed Charges)	15.34


Expenses

4. Operation	0.55
5. Maintenance	0.80
6. General Expense	<u>0.41</u>
7. Total (Percent)	17.10
8. Estimated Construction Cost (1980)	\$30,321,000
9. Net Capacity	51,500 kW
10. Capacity Factor Operation	80%
11. Net Annual Energy Production (Million kWh)	360.9
12. Cost Per Kilowatt (\$/kWh) (Line 8 x Line 7)/(100 x Line 11)	<u>0.014</u>

NOTES

- (1) Item 1 based on 35 year plant life using straight line depreciation and 9.5% return.
- (2) Items 2, 3, 4, 5, 6 based on a California utility's application to the Public Utilities Commission for construction of a geothermal power plant.

FIG. 1 RETURN ON INVESTMENT
FOR STEAM PRODUCTION, GATHERING
AND REINJECTION SYSTEM VS.
STEAM SELLING COST



FLOW PER WELL 450,000 BBL/HA.

1ST QUARTER 1977 COSTS

PRODUCTION WELLS \$438,000 ADD FOR PIPING 119,000 } FOR ADDITIONAL
 REINJECTION WELLS \$435,000 900 FOR PIPING 84,000 } WELLS AFTER
 INITIAL GATEWAY SYSTEM \$7,078,000 1980

COST OF DAY WELLS INTANGIBLE
 70% OF WELL COST INTANGIBLE
 30% OF WELL COST TANGIBLE

STRAIGHT LINE DEPRECIATION 20 yrs

TABLE IV

ROGERS ENGINEERING CO., INC.
 ENGINEERS - ARCHITECTS
 16 BEALE STREET
 SAN FRANCISCO, CALIFORNIA 94105

YEAR	ESCALATION FACTOR	PRODUCTION			REINJECTION			GATHERING SYSTEM			1.65% X ⑩ ⑩ + ⑪			FROM ⑨		
		WELLS	WELL COST	INTANGIBLE COST	TANGIBLE COST	ADD FOR PIPING	WELL COST	INTANGIBLE COST	TANGIBLE COST	ADD FOR PIPING	GATHERING SYSTEM	TANGIBLE COSTS	INTANGIBLE COSTS	1.65% OVERHEAD ON INVEST.	TOTAL TANGIBLE COSTS	
		⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭	⑮	⑯	⑰	⑱	⑲	
1976	0.81	1	395	277	118						152 ¹⁴⁰⁰	270	277	4	274	277
77	1.00	4 2	1952	1366	586		870	609	261			947	1975	11	261	1975
78	1.10	1 4 2	2684	2039	644		987	670	287			931	2709	15	946	2709
79	1.20	1 4 2	2928	2224	703		1044	731	313			1016	2955	17	1033	2955 + LEASE COST
80	1.31	1 4 2	3196	2429	767		1140	798	342		9220	10329	3227	170	10499	3227
81	1.43	2 1	1396	977	419	340	623	311	186	114		1059	1288	17	1076	= 11143 + 305
82	1.54	2 1	1503	1032	451	367	670	335	200	123		1141	1587	19	1160	= 11450
83	1.64															OPERATING
84	1.78	2	1737	1215	521	423						944	1235	15	959	LOSS CARRY OVER
85	1.91															
86	2.05															
87																
88		2	2000	1400	800	488						1088	1400	18	1106	
89																
90																
91																
92		2	2000	1400	600	418						1088	1400	18	1106	
93																
94																
95																
96		2	2000	1400	600	488						1088	1400	18	1106	
97																
98																
99																
2000		2	2000	1400	600	418						1088	1400	18	1106	
01-03																
004		1	1000	700	300	244						544	700	9	533	
05-07																
08		1	1000	700	300	244						544	700	9	533	
09-011																
012		1	1000	700	300	244						544	700	9	533	
013-015	2.05															
3	34	10														

TABLE IV CON'T

ROGERS ENGINEERING CO., INC.
ENGINEERS - ARCHITECTS
10 BEALE STREET
SAN FRANCISCO, CALIFORNIA 94105

YEAR	INTANGIBLE COSTS	DEPRECIATION	OPERATING COST	TOTAL EXP'DEP	GROSS INCOME	GROSS LOSS 10% PROFIT 3% CASHFLOW	NET INCOME	LOSS CARRY OVER	TAXABLE INCOME	AFTER TAX INCOME	NET CASH FLOW	PRES. WORTH FACTOR - 15%	P.W. NBT CASH FLOW	PRES. WORTH FACTOR 20%	P.W. NBT CASH FLOW	YEAR	PRES. WORTH FACTOR 17%	P.W. INVESTMENT
1981	1288	673	332	2293	5414	4710	2417	(2417)	0	2417	3090	0.870	2688	0.833	2571	76	1.87	513
82	1387	727		2446		2264	(2264)	0	2264	2991	0.756	2261	0.694	2075	77	1.60	1338	
83	785			1117		2593	(3593)	0	3593	4378	0.658	2881	0.579	2534	78	1.37	1296	
84	1215	785		2332		2378	(2378)	0	2378	3163	0.572	1809	0.488	1853	79	1.17	1209	
85	833			1165		3545	(796)	2749	2143	2976	0.497	1479	0.411	1223	80	1.0	10499	
86	833			1165		3545		3545	1737	2570	0.432	1110	0.335	841	81	0.855	920	
87	833			1165		3545		3545	1737	2570	0.376	966	0.279	717	82	0.731	848	
88	1400	833		2565		2145		2145	1051	1884	0.327	616	0.233	439	83			
89	888			1220		3490		3490	1710	2598	0.284	738	0.194	584	84	0.533	511	
90	888			1220		3490		3490	1710	2598	0.247	642	0.162	431	85	0.284	314	
91	888			1220		3490		3490	1710	2598	0.215	559	0.135	350	86	0.152	168	
92	1400	888		2620		2090		2090	1024	1912	0.177	357	0.112	219	86	0.081	89	
93	943			1275		3435		3435	1683	2626	0.163	424	0.094	247	2000	0.043	47	
94	943			1275		3435		3435	1683	2626	0.141	370	0.078	205	04	0.023	13	
95	943			1275		3435		3435	1683	2626	0.123	323	0.065	171	08	0.012	7	
96	1400	943		2675		2035		2035	997	1940	0.107	208	0.054	105	12	0.006	3	
97	998			1330		3380		3380	1656	2654	0.093	247	0.045	119			17,800	
98	998			1330		3380		3380	1656	2654	0.081	215	0.038	101				
99	998			1330		3380		3380	1656	2654	0.071	188	0.031	82				
2000	1400	998		2730		1980		1980	970	1968	0.061	120	0.026	51				
01	325			657		4053		4053	1986	2311	0.053	182	0.012	51	(23)	18990	0 15%	
02	325			657		4053		4053	1986	2311	0.046	106	0.018	42	(21)	17800		
03	325			657		4053		4053	1986	2311	0.040	98	0.015	35		1190		
04	700	268		1300		3410		3410	1671	1939	0.035	68	0.013	25				
05	247			579		4131		4131	2024	2271	0.030	68	0.011	25	(25)	14615	@ 20%	
06	247			579		4131		4131	2024	2271	0.026	59	0.009	20	(23)	17900		
07	247			579		4131		4131	2024	2271	0.023	52	0.007	16		3175		
08	700	247		1279		3431		3431	1681	1928	0.020	38	0.006	12				
09	219			551		4159		4159	2038	2257	0.017	38	0.005	11			RETURN ON INVESTMENT	
10	219			551		4159		4159	2038	2257	0.015	34	0.004	9				
11	219			551		4159		4159	2038	2257	0.013	29	0.003	7				
12	700	219		1251		3459		3459	1695	1914	0.011	21	0.003	6				
13	191			523		4187		4187	2052	2243	0.01	22	0.002	5				
14	191			523		4197		4197	2052	2243	0.009	20	0.002	5				
15	191	332		523	5414	4710	4187		4187	2052	2243	0.007	16	0.002	5			