

# **Systems Study for Improving Gas Turbine Performance for Coal/IGCC Application**

## **Final Report**

### **Tasks 1-6**

**January 1, 2004 to September 30, 2005**

**Submitted To: US Department of Energy  
National Energy Technology Laboratory  
Morgantown, WV 26507-0880**

**Submitted By: GE Energy  
Schenectady, NY. 12345**

**December 16, 2005**

**DOE Cooperative Agreement No. DE-FC26-03NT41889**

## **DISCLAIMER**

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

## ABSTRACT

This study identifies vital gas turbine (GT) parameters and quantifies their influence in meeting the DOE Turbine Program overall Integrated Gasification Combined Cycle (IGCC) plant goals of 50% net HHV efficiency, \$1000/kW capital cost, and low emissions. The project analytically evaluates GE advanced F class air cooled technology level gas turbine conceptual cycle designs and determines their influence on IGCC plant level performance including impact of Carbon capture. This report summarizes the work accomplished in each of the following six Tasks.

Task 1.0 – Overall IGCC Plant Level Requirements Identification: Plant level requirements were identified, and compared with DOE's IGCC Goal of achieving 50% Net HHV Efficiency and \$1000/KW by the Year 2008, through use of a Six Sigma Quality Functional Deployment (QFD) Tool. This analysis resulted in 7 GT System Level Parameters as the most significant.

Task 2.0 – Requirements Prioritization/Flow-Down to GT Subsystem Level: GT requirements were identified, analyzed and prioritized relative to achieving plant level goals, and compared with the flow down of power island goals through use of a Six Sigma QFD Tool. This analysis resulted in 11 GT Cycle Design Parameters being selected as the most significant.

Task 3.0 – IGCC Conceptual System Analysis: A Baseline IGCC Plant configuration was chosen, and an IGCC simulation analysis model was constructed, validated against published performance data and then optimized by including air extraction heat recovery and GE steam turbine model. Baseline IGCC based on GE 207FA+e gas turbine combined cycle has net HHV efficiency of 40.5% and net output nominally of 526 Megawatts at NOx emission level of 15 ppmvd@15% corrected O<sub>2</sub>. 18 advanced F technology GT cycle design options were developed to provide performance targets with increased output and/or efficiency with low NOx emissions.

Task 4.0 – Gas Turbine Cycle Options vs. Requirements Evaluation: Influence coefficients on 4 key IGCC plant level parameters (IGCC Net Efficiency, IGCC Net Output, GT Output, NOx Emissions) of 11 GT identified cycle parameters were determined. Results indicate that IGCC net efficiency HHV gains up to 2.8 pts (40.5% to 43.3%) and IGCC net output gains up to 35 % are possible due to improvements in GT technology alone with single digit NOx emission levels.

Task 5.0 – Recommendations for GT Technical Improvements: A trade off analysis was conducted utilizing the performance results of 18 gas turbine (GT) conceptual designs, and three most promising GT candidates are recommended. A roadmap for turbine technology development is proposed for future coal based IGCC power plants.

Task 6.0 – Determine Carbon Capture Impact on IGCC Plant Level Performance: A gas turbine performance model for high Hydrogen fuel gas turbine was created and integrated to an IGCC system performance model, which also included newly created models for moisturized syngas, gas shift and CO<sub>2</sub> removal subsystems. This performance model was analyzed for two gas turbine technology based subsystems each with two Carbon removal design options of 85% and 88% respectively. The results show larger IGCC performance penalty for gas turbine designs with higher firing temperature and higher Carbon removal.

## TABLE OF CONTENTS

<b>Disclaimer</b>	<b>i</b>
<b>Abstract</b>	<b>ii</b>
<b>Figures and Tables</b>	<b>iv, v</b>
<b>Introduction</b>	<b>1</b>
<b>Executive Summary</b>	<b>2</b>
<b>Experimental</b>	<b>4</b>
<b>Results and Discussion</b>	<b>6</b>
<b>Conclusions</b>	<b>35</b>
<b>References</b>	<b>38</b>
<b>List of Acronyms and Abbreviations</b>	<b>39</b>

# Figures and Tables

<u>Figures:</u>	<u>Page</u>
Figure 1 – Matrix for Plant Level QFD	7
Figure 2 – Pareto for Plant Level QFD	8
Figure 3 – Matrix for Gas Turbine QFD	10
Figure 4 – Pareto for Gas Turbine QFD	10
Figure 5 – Baseline IGCC Plant Configuration and Performance	12
Figure 6 - Integrated IGCC Simulation Analysis Model of Baseline IGCC Plant	13
Figure 7 - Gas Turbine Configuration Options	17
Figure 8 - IGCC Plant Performance of GT Design Options	25
Figure 9 – IGCC Net Efficiency vs. GT Specific Output for various GT options	26
Figure 10 - IGCC Specific Output vs. GT Specific Output for various GT Options	26
Figure 11: IGCC Net Efficiency vs. IGCC Specific Output for various GT options	27
Figure 12: Turbine Technology Roadmap for future coal-based IGCC	27
Figure 13: Simplified IGCC Cycle with CO2 Capture	29
Figure 14: Carbon Removal From O2 Blown IGCC Power Plant	30
Figure 15: Shift conversion rate vs. % Saturation of Syngas	30
Figure 16: Auxiliary Power Consumed vs. % CO2 Removal in AGR Unit	31
Figure 17: IGCC Performance model incorporating variable Carbon capture & removal	32

**Tables:**

	<b><u>Page</u></b>
Table 1 - CURC/EPRI/DOE Consensus Roadmap for IGCC Plant Requirements	6
Table 2 – Syngas Compositions Comparison of published data and Simulation Model	14
Table 3 – Comparison of Plant Performance for Baseline Model and published data	14
Table 4 – Syngas Composition of Modified Baseline Case	15
Table 5 –Modified Baseline 207 FA +e IGCC Summary Performance	15
Table 6 – Major Streams Data of Modified Baseline IGCC	16
Table 7 – Conceptual Design Option Results for Base Case and Cases 1 – 4	18
Table 8 – Conceptual Design Option Results for Cases 5 – 9	19
Table 9 – Conceptual Design Option Results for Cases 10 – 14	19
Table 10 – Conceptual Design Option Results for Cases 15– 18	20
Table 11 – Gas Turbine Cycle Influence Coefficients on IGCC Performance	21
Table 12 – IGCC Summary Performance of Gas Turbine Cycle Design Cases 1 thru 6	23
Table 13 – IGCC Summary Performance of Gas Turbine Cycle Design Cases 7 thru 12	23
Table 14 – IGCC Summary Performance of Gas Turbine Cycle Design Cases 13 thru 18	24
Table 15 – Gas Turbine Fuel Composition for 85% and 88% Carbon removal	32
Table 16 – IGCC Summary Performance of Gas Turbine Cycle Design Cases with 85 and 88% Carbon removal	34

# Introduction

## Systems Study for Improving GT Performance for Coal/IGCC Applications

### **A. Objective:**

This study identifies impact of gas turbine performance improvements on coal Integrated Gasification Combined Cycle (IGCC) plants and quantifies influence of vital gas turbine parameters in meeting the DOE Turbine Program overall IGCC plant goals of 50% net HHV efficiency, \$1000/kW capital cost, and low emissions. Focus is on air-cooled gas turbines for near-term, year 2008 operation in coal fed oxygen blown IGCC power plants with commercially demonstrated gasification, gas cleaning, & air separation technologies. Gas Turbine conceptual design recommendation plan towards achieving DOE's goals for the Turbine Program is defined, and provides a total systems-level perspective to identify the development needs and improvements that have the highest impact/ payback to the program.

### **B. Background/Relevancy**

#### Background:

In the near term as reliance on natural gas increases and prices escalate opportunities will arise to reinvest in the use of coal, our nations most abundant fossil fuel resource. Estimates suggest that more than 30 Gigawatts of new coal-based power generation will be installed over the next 15 years. The US generates approximately 50% of its power from coal. Much of this added capacity could be based on integrated gasification combined-cycle technology (IGCC). Significant improvements in overall cycle efficiency and cost per unit of power will dramatically reduce generation costs and emissions. This will help provide low-cost, environmentally acceptable power from a domestically abundant low cost fuel.

#### Relevancy:

Clean, efficient and cost effective coal based power systems depend on advanced power turbine technology to achieve higher levels of efficiency. IGCC technology has been demonstrated to show superiority in both performance and emissions compared with conventional coal power generation technology. However, additional enhancements in IGCC will be needed to gain superiority in life cycle electricity costs. One area of improvement is in the gas turbine portion of the cycle, which is the primary energy conversion device within an IGCC power plant. Increases in gas turbine conversion efficiency of coal derived syngas energy to power and higher utilization of exhaust energy will help drive lower IGCC plant level generating costs.

Meeting of DOE overall IGCC plant goals of 50% net HHV efficiency, \$1000/kW capital cost, and low emissions for a 500 MW coal plant could provide annual generating cost savings of about \$50 MM/yr compared to current F-Class IGCC systems and about \$20 MM/yr compared to conventional PC technology. Additional enhancements in the area of emitted NOx and SOx could also be realized by making IGCC the technology of choice for coal based power production. Future IGCC plant could also be designed limiting atmospheric emissions of Carbon dioxide by using conventional Carbon removal technology.

## Executive Summary

Overall DOE Turbine Program plant level goals were established from DOE Vision 21 and IGCC Power Plant CURC Roadmap Studies. Using GE's Six Sigma Methodology, key gas turbine (GT) plant level requirements were identified. These gas turbine plant level requirements were used to quantify and prioritize gas turbine cycle parameters. A Baseline Conceptual IGCC System Design was established utilizing current General Electric (GE) F-class gas turbine technology based on a Midwest US IGCC site. An overall IGCC System Performance Model was constructed utilizing GE in- house proprietary software for the gas turbine & steam turbine, and commercially available software for the balance of the systems. The model was exercised through parametric analysis to quantify gas turbine performance impact at IGCC plant system level. Various advanced F class technology gas turbine cycle design options were evaluated to determine performance impact on IGCC efficiency, cost and emissions. Results were used to identify gas turbine technology improvements for development consideration in future Turbine Program phases. The program includes the following six major tasks:

### **Task 1 - Overall IGCC Plant Level Requirements Identification:**

This task established ranking of DOE's overall IGCC plant level goals of achieving 50% net HHV efficiency and \$1000/kW in year 2008, and is used to prioritize plant level requirements. Using Six Sigma QFD tools, the key IGCC Plant Level parameters identified were: IGCC Net Efficiency, IGCC Net Output, GT Output and NO<sub>x</sub> Emissions. A subsequent QFD flow down identified the most significant GT Plant Level requirements as: Availability, Product Cost, Efficiency, Air Integration flexibility, syngas & diluent supply conditions and syngas NO<sub>x</sub> Capability.

### **Task 2 - Requirements Prioritization & Flow-Down to Gas Turbine Subsystem Level**

This task prioritizes GT cycle design parameters from an IGCC Plant Level flow down to the GT subsystem level. The most significant GT cycle design parameters were identified as Firing Temperature, Combustor Options, Turbine and Compressor Efficiency, Compressor Pressure Ratio, Cooling Flows, Air Extraction amount, Syngas Supply and Diluent Supply Temperatures, Compressor Air Flow and Diluent Flow.

### **Task 3 - IGCC Conceptual System Analysis**

A coal-based Baseline IGCC Configuration with Oxygen Blown Gasification and GE F-Class GT technology was defined and then used to validate a Baseline Case IGCC System Performance Simulation Analysis Model. The Simulation Analysis Model was reconfigured as a typical advanced IGCC powerplant by eliminating cogeneration of steam, adding heat recovery from GT air extraction, and using a GE steam turbine.

Using this revised IGCC System Performance Simulation Analysis model, eighteen new advanced F technology GT cycle options were analyzed to explore varying turbine configuration impacts that would provide performance targets with increased output and/or efficiency and low NO<sub>x</sub> emissions. These GT cycle design options were developed by varying the selected system parameters such as Air Integration Method,

ASU type, Diluent Method, and Fuel Temperature, as well as GT parameters such as Combustor Type, available Hot Gas Path Configuration including future hardware components, Firing Temperature and Target NOx Level.

#### **Task 4 - Gas Turbine Cycle Options vs. Requirements Evaluation**

In this task, IGCC performance derivatives in terms of IGCC Net Plant Efficiency, IGCC Net Plant Output, GT Output and NOx Emissions were evaluated for 11 key GT cycle parameters. The following GT parameters were found to have the greatest impact on each respective plant level derivative: GT Firing Temperature, Turbine & Compressor Efficiency, Diluent Supply Temperature, Compressor Pressure Ratio and Cooling Flows on IGCC Net Efficiency; Firing Temperature, Compressor Inlet Air Flow, Turbine & Compressor Efficiency, Compressor Pressure Ratio and Dilution Flow on IGCC Net Output; Firing Temperature, Compressor Inlet Air Flow, Turbine & Compressor Efficiency and Dilution Flow on GT Output; and Combustion Technology (Diffusion or Premix), Diluent Flow, Firing Temperature and Compressor Pressure Ratio on NOx Emissions.

Using these plant level derivative effects, GT cycle design trade-off studies utilizing the IGCC System Performance Simulation Model and Eighteen new gas turbine cycle options based on advanced F GT technology were analyzed. Results indicate that IGCC efficiency gains up to 2.8 pts (from 40.5% to 43.3%) and IGCC net output gains up to 35 % are possible while still maintaining single digit NOx emission levels with improvements in gas turbine technology alone.

#### **Task 5 - Recommendations for Gas Turbine Technical Improvements**

Various GT cycle designs results were examined to select the most promising candidate cycle concepts. The 3 most promising GT candidates are recommended on the basis of their merit on IGCC Efficiency, IGCC Net Output, GT Specific Output and NOx Emissions. For near term (2006): the recommended GT cycle design should have a 2400F class firing temperature, base class compressor pressure ratio (CPR), diffusion combustor and integrated air extraction; for midterm (2008): a 2500F class firing temperature, base class CPR, diffusion combustor, and integrated air extraction; and for long term (2010): a 2600F class firing temperature, increased CPR, and further combustion and hot gas path technology enhancements. A turbine technology development roadmap is recommended for future coal based IGCC power plants.

#### **Task 6 - Determine Carbon Capture Impact on IGCC Plant Level Performance**

Performance impact of Coal fired IGCC plants using high Hydrogen fueled current and advanced technology gas turbine was analyzed due to Carbon capture and removal. A high Hydrogen fueled gas turbine performance model was created and integrated to an overall IGCC system performance model, which also included newly created subsystem models for moisturized syngas, gas shift and CO<sub>2</sub> removal. Two gas turbine technology based IGCC systems were analyzed, each with two Carbon removal design options of 85% and 88% respectively. The results show larger IGCC performance penalty for gas turbine designs with higher firing temperature and higher Carbon removal.

# **Experimental**

**Overview:** Both commercially available software and GE in-house proprietary software packages were utilized in the analysis phases of this study. A brief description of their functionality is provided below.

## **Task 1 - Overall IGCC Plant Level Requirements Identification:**

Plant level IGCC requirements were identified, and compared with DOE's IGCC Goals of achieving 50% Net HHV Efficiency and \$1000/KW by the Year 2008, through use of a Six Sigma Quality Functional Deployment (QFD) Tool. This GE in-house, Excel-based, proprietary tool provides a ranking of the importance of IGCC requirements relative to DOE's IGCC Goals.

## **Task 2 – Requirements Prioritization & Flow-Down to Gas Turbine Subsystem Level**

Gas turbine cycle design requirements were identified, analyzed and prioritized relative to achieving plant level goals, and compared with the flow down of power island goals through use of a Six Sigma Quality Functional Deployment (QFD) Tool. This GE in-house, Excel-based, proprietary tool provides a ranking of the importance of gas turbine requirements relative to power island goals.

## **Task 3 – IGCC Conceptual System Analysis**

Overall integrated IGCC system performance model was constructed utilizing GE in-house proprietary software, GateCycle™ for the gas turbine & steam turbine, and commercially available HYSYS Process Modeling software for the balance of the systems. The model is exercised by a parametric analysis in commercial ModelCenter software to quantify gas turbine performance impact at the IGCC plant system level.

## **Task 4 – Gas Turbine Cycle Options vs. Requirements Evaluation**

This integrated IGCC system analysis model is used to determine the influence coefficients of vital Gas Turbine parameters (firing temperature, turbine and compressor efficiency, compressor pressure ratio, diluent and fuel temperature, etc.) on plant-level goals (efficiency, output, emissions, etc). This model is also used for IGCC performance evaluation of various advanced F technology gas turbine cycle design options.

## **Task 5 – Recommendations for Gas Turbine Technical Improvements**

This task did not utilize software tools over and above those used in previous tasks.

## **Task 6 – Determine Carbon Capture Impact on IGCC Plant Level Performance.**

The HYSYS model of the Low Temperature Gas Cooling (LTGC) System was modified to include two Water Saturators and two Water Gas Shift Reactors in order to provide the required shift of Syngas CO to CO<sub>2</sub> necessary for the targeted CO<sub>2</sub> removal from the Syngas. All MP and

LP Steam within the LTGC System was diverted as a source of energy for the Saturators such that only Net HP Steam is now sent from the LTGC to the HRSG for all of the Carbon Capture cases.

A modified Acid Gas Removal (AGR) System was developed in order to simulate the removal of CO<sub>2</sub> at the 90% and 95% level from the untreated Syngas. This AGR model was based on a traditional two-column Selexol System, with the addition of a CO<sub>2</sub> Removal Section consisting of an additional Low-Temperature Absorption Column, three Flash Drums for CO<sub>2</sub> separation, and refrigeration necessary for the low-temperature CO<sub>2</sub> absorption process.

# Results and Discussion

## Task 1 - Results/Discussion:

**Overview:** Gas turbine System level (Power Island) requirements were identified, and compared with DOE's IGCC Goal of achieving 50% Net HHV Efficiency and \$1000/KW by the Year 2008, through use of a Six Sigma Quality Functional Deployment (QFD) Tool.

### **Task 1 Discussion:**

IGCC Plant Requirements for this study have been based on the DOE Vision 21 Performance Goal for 2008 which outlines a coal-based power system with:

- 1) System HHV based Efficiency of 50%
- 2) Capital Cost of less than \$1000./KW
- 3) NO<sub>x</sub> Reduction to less than 2 ppm
- 4) Increase of Heat Engine Efficiency of 2 to 3%
- 5) Attainment of reliability/availability standards for pre-1999 gas turbines

These Plant Requirements are consistent with the CURC/EPRI/DOE Consensus Roadmap as shown below in table 1:

**Table 1 - CURC/EPRI/DOE Consensus Roadmap for IGCC Plant Requirements**

Item	Reference Plant	2010	2020
Plant Efficiency (HHV)	40%	45-50%	50-60%
Availability	> 80%	> 85%	> 90%
Plant Capital Cost (\$/KW)	1000 - 1300	900 - 1000	800 - 900
Cost of Electricity (cents/KWh)	3.5	3.0 - 3.2	< 3.0
Air Emissions	98% SO <sub>2</sub> Removal	99% SO <sub>2</sub> Removal	> 99% SO <sub>2</sub> Removal
	0.15 lb/10 <sup>6</sup> Btu NO <sub>x</sub>	0.05 lb/10 <sup>6</sup> Btu NO <sub>x</sub>	< 0.01 lb/10 <sup>6</sup> Btu NO <sub>x</sub>
	0.01 lb/10 <sup>6</sup> Btu Pariculate	0.005 lb/10 <sup>6</sup> Btu Pariculate	0.002 lb/10 <sup>6</sup> Btu Pariculate
	Mercury Removal	90%	95%
By-Product Utilization	30%	50%	Near 100%

An analysis of DOE and customer requirements and expectations result in the following set of Power Plant Level Expectations (with corresponding levels of Importance, 5 being the highest):

<b>Power Plant Level Expectations, (Y's )</b>	<b>Importance</b>	<b>Notes:</b>
Low Capital Cost (<\$1000/KW)	5	\$900 – 1000/KW by 2010
High Net Electrical Efficiency (50% HHV)	5	Not Co-Gen or CO <sub>2</sub> Capture Value
High Availability	5	85% by 2010 through RAM Excellence
Low COE	3	3.2 cents/KWH by 2010
Low Emissions for NO <sub>x</sub> and SO <sub>x</sub>	3	2 PPM NO <sub>x</sub> , 99% Sulfur Removal
Fuel Flexibility	3	Low to High Rank Coals, Petcoke
Co-Production Capable	3	Chemical Co-Production, Hydrogen
CO <sub>2</sub> Removal	3	85% CO <sub>2</sub> Removal
Reduced H <sub>2</sub> O Use	2	Driven by Permitting Requirements
Zero Process Discharge	2	Driven by Permitting Requirements

A corresponding set of Gas Turbine Power Island Level Requirements were established as input to the Quality Functional Deployment analysis:

**Gas Turbine Power Island Requirements, (X's)**

Product Cost (\$/KW)  
 Generator Output  
 Efficiency  
 Availability  
 Syngas NO<sub>x</sub>  
 Syngas CO  
 Syngas Fuel Flexibility  
 Syngas and Diluent Supply Conditions  
 Diluent Flexibility  
 Exhaust Gas Energy  
 Air Integration Flexibility

**Notes:**

Target of \$200/KW  
 Maximize  
 Drives Overall IGCC Efficiency  
 At Least 95%  
 9 ppm Ceiling by 2010  
 9 ppm Ceiling by 2010  
 Variable CO, H<sub>2</sub> Composition  
 Efficiency, Combustor Requirements  
 For NO<sub>x</sub> Removal  
 Effect Bottoming Cycle Efficiency  
 With Air Separation Unit


These Expectations and Plant Requirements are mapped in Figure 1 through the QFD tool, with the weighting factors for the expectations, and the Y's are analyzed against the X's through Low (L), Medium (M) and High (H) levels of connection, with the following results matrix:

**IGCC Systems Study QFD**

	Gas Turbine Power Island Requirements											Total	
	Importance	Availability	Product Cost (\$/KW)	Efficiency	Air Integration Flexibility	Syngas and Diluent Supply Conditions	Generator Output	Syngas NOx	Syngas Fuel Flexibility	Exhaust Gas Energy	Diluent Flexibility		
Expectation													
High Availability	5	H	M		M			L	M		L		
High Net Electrical Efficiency - 50% HHV	5		L	H	M	H	M	M		M	M	L	
Low Capital Cost \$1000/KW	5	M	H	L	M	M	H	L	L	M			
CO <sub>2</sub> Removal	3	L		L	M			M			L		
Coproduction Capable	3	L			M	M			M		L		
Fuel Flexibility	3				M	L			M		L		
Low COE	3	H	H	M	M	M	M	L	L	M	L		
Low Emissions Max 0.02 lb/MMBTU NOx and S	3			H	L	L	L	H	M	M	L	M	
Reduced H <sub>2</sub> O Use	2				L			M	L	L	M		
Zero Process Discharge	2				L							2	
Total			93	92	89	88	84	72	70	52	50	41	14

**Figure 1 – Matrix for Plant Level QFD**

An alternate representation of the results of the QFD process is the Pareto Chart in Figure 2:



**Figure 2 – Pareto for Plant Level QFD**

The following 7 IGCC Gas Turbine System Level Parameters were selected as the most significant for further analysis of IGCC system requirements at the power island level:

- 1) Availability
- 2) Product Cost
- 3) Efficiency
- 4) Air Integration Flexibility
- 5) Syngas and Diluent Supply Conditions
- 6) Generator Output
- 7) Syngas NO<sub>x</sub> Capability

### **Task 2 - Results/Discussion:**

**Overview:** Gas turbine cycle requirements were identified, analyzed and prioritized relative to achieving plant level goals, and compared with the flowdown of power island goals through use of a Six Sigma Quality Functional Deployment (QFD) Tool.

#### **Task 2 Discussion:**

The previous Plant Level Requirements are flowed down as part of the QFD process to yield the following set of Power Island Level Expectations (with corresponding levels of Importance):

<b>Y's</b>	
<b>Gas Turbine Power Island Requirements</b>	<b>Importance</b>
Availability	5
Gas Turbine Cost (\$/KW)	5
Efficiency	5
Air Integration Flexibility	5
Syngas and Diluent Supply Conditions	5
Exhaust NO <sub>x</sub>	4
Generator Output	4
Syngas Fuel Flexibility	3
Exhaust Gas Energy	3
Diluent Flexibility	3
Exhaust CO	2

A corresponding set of Gas Turbine Cycle Requirements were established as input to the Quality Functional Deployment analysis:

<b>X's</b>	
<b>Gas Turbine Cycle Design Options</b>	<b>Notes:</b>
Compressor Air Flow	Impacts size and cost
Compressor Pressure Ratio	Impacts GT plant efficiency, output
Firing Temperature	Maximize for HGP materials
Combustor Pressure Drop	Minimize
Cooling Flows	Minimize
Syngas Supply Temperature	Maximize
Syngas Supply Pressure	Minimize
Diluent Supply Temperature	Maximize
Diluent Supply Pressure	Minimize
Diluent Flow	Optimize
Diluent Type	Nitrogen, Steam, Pre-Moisturized
Turbine & Compressor Efficiency	Optimize for syngas fuel
Combustor Options	Diffusion, Premix Combustors
Percent Air Extraction	Air Extraction Range, Effects on Performance
Exhaust Temperature	Gas Turbine Exhaust Effects

These Gas Turbine Cycle Design options and Power Island Requirements are mapped through the Six Sigma QFD tool, with the weighting factors for the expectations, and the Y's are analyzed against the X's through Low, Medium and High levels of connection, with the following results matrix as shown in Figure 3:

### IGCC System Gas Turbine

#### Gas Turbine Tradeoff Requirements

Gas Turbine Power Island Requirements															Importance	Firing Temperature	Combustor Options - NOx Range	Turbine & Compressor Efficiency	Compressor Pressure Ratio	Cooling Flows	Percent Air Extraction	Syngas Supply Temperature	Diluent Supply Temperature	Compressor Air Flow	Diluent Flow	Diluent Type	Combustor Pressure Drop	Syngas Supply Pressure	Diluent Supply Pressure	Exhaust Temperature	Total
	L	M	M	H	L	H	L	M	M	L	M	M	M	L	L	L	L	L													
Air Integration Flexibility	5	L	M	M	H	L	H	L	M	M	L	M	M	L	L	L	L	165													
Availability	5	H	M			H	M											120													
Efficiency	5	H	M	M	H	H	M	M	M	L	M	M	M	L	L	L	L	275													
Gas Turbine Cost \$/Kw	5	H	M	H	M	L	L	M	M	M	L	L	L	L	L	L	L	205													
Syngas and Diluent Supply Conditions	5	H	M	H	M	L	L	M	M	M	M	M	M	H	H			345													
Generator Output	4	H	M	H	L	M	M	L	L	H	M	M	L				M	196													
Syngas NOx	4	H	H	H	L	M	M	M	M	M	M	L	M					188													
Diluent Flexibility	3	H	H			L		L		M	M	L	L	M				93													
Exhaust Gas Energy	3	H	M	H	H	M	L			M	L	L	M			M		126													
Syngas Fuel Flexibility	3	L	H	M			L	M		L	L	L	M					69													
Syngas CO	2	M	H	M			M	M	L	L	L	L	L					52													
Total			248	234	231	185	139	134	102	101	80	76	68	64	59	58	55														

Figure 3 – Matrix for IGCC Gas Turbine QFD

An alternate representation of the results of the QFD process is the Pareto Chart in Figure 4:




Figure 4 – Pareto for Gas Turbine QFD

The following 11 IGCC Gas Turbine Parameters were selected as the most significant for analysis of Baseline and other IGCC system configurations:

- 1) Firing Temperature
- 2) Combustor Options
- 3) Turbine Efficiency
- 4) Compressor Efficiency
- 5) Compressor Pressure Ratio
- 6) Cooling Flows
- 7) Percent Air Extraction
- 8) Syngas Supply Temperature
- 9) Diluent Supply Temperature
- 10) Compressor Air Flow
- 11) Diluent Flow

### **Task 3 - Results/Discussion:**

**Overview:** A Baseline IGCC Plant configuration and its performance design basis were chosen. An integrated simulation analysis model of IGCC was constructed to validate the Baseline IGCC Plant model against published performance data. The model was exercised by a parametric analysis to quantify the influence of key gas turbine parameters on performance impact at the IGCC plant system level. Various gas turbine cycle design options were chosen to evaluate performance effects on IGCC at plant level and select appropriate gas turbine technical improvements.

#### **Task 3 Discussion:**

##### **Task 3.1 – Establish IGCC System Design Basis**

During this task, a Baseline IGCC System was chosen as follows:


- 1) Determined the appropriate gasifier and F-Class Baseline IGCC Plant configuration.
- 2) Evaluated the Energy Flow “Sankey Diagram” for the Baseline IGCC Plant.
- 3) Evaluated overall heat and mass balances for Baseline IGCC Plant.
- 4) Developed an Integrated IGCC Simulation Analysis Model for the Baseline IGCC Plant configuration, and validated this model against published performance data.

The Reference Plant was chosen on the basis of a design which was representative of GE Frame 7FA+e current technology with sufficient public information to perform a detailed performance comparison with the results for that configuration by the Integrated IGCC Simulation Analysis Model. The chosen plant design was the Nordic Energy of Ashtabula (1) case with:

- ISO ambient conditions
- Pittsburgh No. 8 Coal
- E-Gas oxygen blown gasifier
- High pressure cryogenic Air Separation Unit

- HP steam heat recovery similar to Ashtabula study
- COS hydrolysis, wet particulate removal
- Syngas saturation, heating and low temperature heat recovery
- Amine based acid gas cleanup and sulfur recovery
- 7FA+e gas turbine with 2300 °F firing temperature
- Air extraction and N<sub>2</sub> injection
- 3 pressure HRSG
- Reheat 1450 psig/1000F/1000F/ 1.5 in. steam turbine
- Cooling tower, transformer and plant auxiliaries included

The overall configuration of the Baseline Plant is given in Figure 5:




**Figure 5 – Baseline IGCC Plant Configuration and Performance**

### Task 3.2 – Develop System Models and Analyze IGCC System Performance

An Integrated IGCC Simulation Analysis Model for the Baseline IGCC Plant configuration was developed with the following configuration and capabilities:

- E-Gas gasifier
- Air extraction integrated high pressure Air Separation Unit
- Gas turbine cycle for detailed performance evaluation
- 3 pressure, reheat steam cycle
- N<sub>2</sub> saturation and injection
- Syngas fuel saturation and heating
- Syngas heat recovery
- Sulfur removal and recovery

This Simulation Analysis Model as shown in Figure 6 utilized in-house tools including a GateCycle™ model of a gas turbine suitable for syngas fuel application. This gas turbine model was integrated with a steam turbine, HRSG combined cycle model using GateCycle™ software. This combined cycle subsystem model was integrated, through use of ModelCenter commercial Software, with a performance simulation model of gasification, ASU, syngas cooling and AGR subsystems utilizing HYSIS commercial software.



**Figure 6 - Integrated IGCC Simulation Analysis Model of Baseline IGCC Plant**

The Simulation Analysis Model of the Baseline Case yielded results in very good agreement with the published literature of Nordic Energy Ashtabula Plant. A comparison of syngas compositions for the model and simulation cases in Table 2 shows very good agreement (with Simulation results scaled up to be consistent with the 3x7FA+e Ashtabula and 2x7FA+e Baseline Case configurations).

**Table 2 –Syngas Composition Comparison of published data and Simulation Model**

<b><u>Syngas Compositions (Mole Percent)</u></b>		
<b><u>Species</u></b>	<b><u>Nordic Energy Ashtabula Case</u></b>	<b><u>Simulation Case</u></b>
H <sub>2</sub>	25.88	25.99
CO	43.71	43.94
CH <sub>4</sub>	4.40	4.42
CO <sub>2</sub>	9.77	9.67
N <sub>2</sub>	1.41	1.09
Ar	0.93	1.06
H <sub>2</sub> O	13.90	13.83

A comparison of performance data for the Ashtabula and Simulation case in Table 3 also showed very good agreement. We note that the Baseline Case simulation exhibits an appreciably better heat rate since the Baseline Case simulation does not contain the modest co-generation steam included in the Ashtabula case)

**Table 3 – Comparison of Plant Performance for Model and Simulation Cases**

<b><u>IGCC Plant Performance</u></b>		
<b><u>Parameter</u></b>	<b><u>Nordic Energy Ashtabula Case</u></b>	<b><u>Simulation Case</u></b>
Gas Turbine Output (MW)	591.0	590.7
Steam Turbine Output (MW)	350.0	343.5
Auxiliary Power (MW)	-145.5	-141.5
-----	-----	-----
Net Power Output (MW)	795.4	792.7
Net Heat Rate (HHV) (Btu/Kw-hr)	8540.	8464.

The Baseline IGCC configuration was further modified to model a 207FA+e based IGCC plant and incorporated the following additional changes:

- 1) Air extraction heat recovery
- 2) GE steam turbine with suitable LP last stage

The syngas composition, summary performance and streams data for the Modified Baseline Case are presented in Tables 4, 5 and 6 respectively.

**Table 4 – Syngas Composition for Modified Baseline Case**

<b>Syngas Comp</b>	<b>Vol %</b>
H2	25.97%
CO	43.89%
CH4	4.42%
CO2	9.66%
N2	1.09%
Ar	1.06%
H2O	13.90%
Total S	31.2 ppm

**Table 5: Modified Baseline 207 FA +e IGCC Summary Performance**


<b>Overall Performance</b>		<b>Units</b>
GT Power	393200	kW
ST Power	227600	kW
Aux Power		
ASU	71800	kW
Gasification	11400	kW
CC Plant	11100	kW
Net Power	526500	kW
Feed Q (HHV)	4429	MMbtu/hr
Net Heat Rate (HHV)	8413	Btu/kW-hr
Net Efficiency (HHV)	40.59%	
Net Heat Rate (LHV)	8126	Btu/kW-hr
Net Efficiency (LHV)	42.03%	

**Table 6: Major Streams Data of Modified Baseline IGCC**

<b>Stream</b>	<b>Description</b>	<b>Flow (lb/hr)</b>	<b>Pressure (psia)</b>	<b>Temperature (F)</b>
<b>P1</b>	Air to ASU	812700	14.7	59
<b>P2</b>	Nitrogen to GT	961700	340	533
<b>P3</b>	Air to GT	6667600	14.7	59
<b>P4</b>	Air Extraction from GT	466700	234	771
<b>P5</b>	O2 to Gasification	289100	624	240
<b>P6</b>	Coal (as received)	334000		
<b>P7</b>	Cond to ASU	372100	35	88
<b>P8</b>	Cond Return from ASU	372100	32	221
<b>P9</b>	Slag	52400		
<b>P10</b>	Sulfur	7100		
<b>P11</b>	MP steam from Gasification	16200	423	455
<b>P12</b>	Cold Reheat Steam	1076900	394	654
<b>P13</b>	MP BFW	16200	426	407
<b>P14</b>	Hot BFW	609500	1746	561
<b>P15</b>	HP Steam	609500	1746	617
<b>P16</b>	Superheated HP Steam	1099500	1682	1034
<b>P17</b>	Cold Condensate	1006700	80	88
<b>P18</b>	Cond CW Supply	84824800		71
<b>P19</b>	Cond CW Return	84824800		86
<b>P20</b>	Steam Turbine Exhaust	1270800	0.7367	92
<b>P21</b>	Hot Reheat Steam	1301100	371	1034
<b>P22</b>	Demin Makeup	220000	15	59
<b>P23</b>	LP steam Extraction	75900	70	607
<b>P24</b>	Warm Condensate	876200	159	174
<b>P25</b>	GT Exhaust	7934100	17	1079
<b>P26</b>	HRSG HP Steam	490000	1731	616
<b>P27</b>	Syngas	745500	375	533
<b>P28</b>	HRSG Stack	7934100	15	268
<b>P29</b>	Steam Injection to GT	0	388	653

### Task 3.3 – Develop Gas Turbine Conceptual Design Options

Gas turbine cycle design options illustrated in Figure 7 were developed by varying the selected system parameters such as Air Integration Method, ASU type, Diluent Method, and Fuel Temperature, as well as gas turbine parameters such as Combustor Type, Hot Gas Path Configuration, Firing Temperature and Target NO<sub>x</sub> Level.



**Figure 7 - Gas Turbine Configuration Options**

IGCC subsystem models developed in the previous task were exercised to create performance results for these cycle configurations in the integrated IGCC environment. These configuration performance results enable the determination of the performance effects of gas turbine technical improvements on IGCC plant-level performance.

Configuration details for the Base Case and 18 chosen Conceptual Design Options are presented in the following Tables 7 through 10:

**Table 7 – Conceptual Design Option Results for Base Case and Cases 1 – 4.**

<b>Gas Turbine and Systems Configurations</b>					
<b>Parameters</b>	<u>Base</u>	<u>Case 01</u>	<u>Case 02</u>	<u>Case 03</u>	<u>Case 04</u>
ASU Type	EP	EP	EP	EP	LP
Air Integration	Partial	Partial	Partial	Full	None
Diluent Type	N2 + Fuel Sat	N2 Sat + Fuel Sat	N2 Sat + Fuel Sat	N2 Sat + Fuel Sat	Steam Inj + Fuel Sat
Fuel Temperature	533	533	533	533	533
Compressor	FA+e	FB	FB	FB	Reduced FB
Combustor Type	Diffusion	Diffusion	Diffusion	Diffusion	Diffusion
Cooling Air Cooling	No	No	No	No	No
SCR	None	None	Yes	Yes	Yes
Firing Temperature (F)	2300	2400	2500	2500	2500
NOx (ppmvd @ 15%O2)	15	15	9	9	9

These Conceptual Design Options were set up to cover the gamut of turbine options within the available, as well as future, hardware components. First three cases use diffusion combustion, FB compressor and variation of turbine hot gas path geometry. Case 1 does not use SCR and limits NOx emissions to current EPA emission standards at 15 ppmvd @15% corrected O2. Case 2 and 3 use SCR to get single digit NOx. Cases 4 and 5 use no air integration, standard low pressure cryogenic ASU, fuel saturation, current Natural gas fueled FB gas turbine Hot Gas Path and scaled down FB compressor. Case 4 uses Diffusion combustor and SCR, while Case 5 uses Premix combustor to limit NOx to 15 ppmvd@15% corrected O2.

Cases 6 through 9 use Elevated Pressure ASU, Premix combustor, standard FB compressor and variation of turbine hot gas path geometry. Cases 6 and 7 use enough diluents as not to require SCR, while Case 8 requires SCR to limit NOx to single digit level. Cases 9 through 11 use FA+e compressor and turbine hot gas path geometry and no SCR to limit NOx to 15 ppmvd@15% corrected O2. Case 9 and 10 use Diffusion combustor, EP ASU and N2 and fuel saturation as diluents. Case 11 uses LP ASU and saturated fuel in a premix combustor. Cases 12 through 16 use new compressor and turbine geometry, premix combustor and higher fuel and diluent temperatures to increase thermal efficiency. Cases 12 through 14, use nitrogen and fuel saturation but no SCR, while Cases 15 and 16 use SCR to limit NOx to single digits.

**Table 8 – Conceptual Design Option Results for Cases 5 – 9**

<b>Gas Turbine and Systems Configurations</b>					
<b>Parameters</b>	<u>Case 05</u>	<u>Case 06</u>	<u>Case 07</u>	<u>Case 08</u>	<u>Case 09</u>
ASU Type	LP	EP	EP	EP	EP
Air Integration	None	Partial	None	Full	Full
Diluent Type	Fuel Sat	N2 Sat + Fuel Sat	N2 Inj + Fuel Sat	N2 Inj	N2 Sat + Fuel Sat
Fuel Temperature	533	533	533	750	533
Compressor	Reduced FB	FB	FB	FB	FA+e
Combustor Type	DLN	DLN	DLN	DLN	Diffusion
Cooling Air Cooling	No	No	No	No	No
SCR	Yes	None	None	Yes	None
Firing Temperature (F)	2500	2500	2500	2550	2400
NOx (ppmvd @ 15%O <sub>2</sub> )	9	9	9	9	15

**Table 9 – Conceptual Design Option Results for Cases 10 – 14**

<b>Gas Turbine and Systems Configurations</b>					
<b>Parameters</b>	<u>Case 10</u>	<u>Case 11</u>	<u>Case 12</u>	<u>Case 13</u>	<u>Case 14</u>
ASU Type	EP	LP	EP	EP	EP
Air Integration	None	None	Partial	Full	Partial, 50%
Diluent Type	N2 Inj + Fuel Sat	Fuel Sat	N2 Sat + Fuel Sat	N2 Sat + Fuel Sat	N2 Sat + Fuel Sat
Fuel Temperature	533	533	600	600	600
Compressor	Reduced FA+e	FA+e	New FB	New FB	New FB
Combustor Type	Diffusion	DLN	DLN	DLN	DLN
Cooling Air Cooling	No	No	No	No	No
SCR	None	None	None	None	None
Firing Temperature (F)	2400	2400	2550	2550	2600
NOx (ppmvd @ 15%O <sub>2</sub> )	15	15	9	9	9

**Table 10 – Conceptual Design Option Results for Cases 15 – 18**

Gas Turbine and Systems Configurations				
Parameters	Case 15	Case 16	Case 17	Case 18
ASU Type	EP	EP	EP	EP
Air Integration	Partial, 50%	Full	Partial	Partial
Diluent Type	N2 + Fuel Sat	N2 Sat + Fuel Sat	N2 Sat + Fuel Sat	N2 Sat + Fuel Sat
Fuel Temperature	600	600	533	533
Compressor	New FB	New FB	Reduced FA+e	Reduced FB
Combustor Type	DLN	DLN	Diffusion	Diffusion
Cooling Air Cooling	Yes	No	Yes	No
SCR	Yes	Yes	None	None
Firing Temperature (F)	2600	2650	2400	2500
NOx (ppmvd @ 15%O2)	9	9	2	2

Cases 14 through 16 use higher firing temperature than current FB and reduced cooling by utilizing new CMC materials for turbine first stage nozzles. Case 15 even explores the potential of using external turbine cooling air. Cases 17 and 18 explore Diffusion combustor and new turbine hot gas path design to reach DOE goals of 2 ppm NOx limit without SCR by increasing diluent flow to the limit by saturation of N2 and fuel.

The 18 options represent reasonable, compatible options, which explore the region of attractive turbine configurations with aim to provide improved performance, increased output, efficiency and reduced NOx emissions for IGCC systems.

#### **Task 4 - Results/Discussion:**

**Overview:** The integrated IGCC system analysis model developed in Task 3 was used to determine the influence coefficients of vital gas turbine parameters (firing temperature, turbine and compressor efficiency, compressor pressure ratio, cooling flow, fuel and diluent temperature, etc.) on key plant-level performance goals (net plant efficiency, net output, NOx emissions, etc.). The analysis model was utilized to perform IGCC performance trade-off analysis of various gas turbine cycle design options in order to determine which options best meet DOE IGCC Plant Goals.

#### Task 4 Discussion:

##### Task 4.1: - Determine Gas Turbine Vital Parameters Influence on Plant Level Performance

IGCC simulation model was exercised to determine the influence coefficients on four key IGCC plant level performance parameters namely, net efficiency, net output, gas turbine output and NOx emissions of the 11 selected gas turbine cycle parameters.

Influence coefficients, as shown in Table 11, are defined as the relative change in IGCC plant performance parameter such as IGCC net efficiency for an incremental change in gas turbine cycle parameter, such as Firing temperature or relative slope value,  $(DY/Y) / (DX/X)$ , where X and Y refer to values for Baseline IGCC system.

**Table 11: Gas Turbine Cycle Influence Coefficients on IGCC Performance**

Turbine Cycle Parameter	IGCC Net Eff	IGCC Net kW	GT Output	NOx
<b>Firing Temperature</b>	<b>0.584</b>	<b>3.113</b>	<b>2.948</b>	<b>2.604</b>
<b>Turbine Isen Efficiency %</b>	<b>0.784</b>	<b>0.784</b>	<b>2.070</b>	<b>0.000</b>
<b>Compressor Isen Efficiency %</b>	<b>0.252</b>	<b>0.669</b>	<b>0.937</b>	<b>0.130</b>
<b>Compressor Air Flow</b>	<b>-0.026</b>	<b>0.970</b>	<b>1.007</b>	<b>0.000</b>
<b>Compressor Pressure Ratio</b>	<b>-0.048</b>	<b>-0.361</b>	<b>-0.144</b>	<b>0.910</b>
<b>Turbine Cooling Flow</b>	<b>-0.045</b>	<b>-0.180</b>	<b>-0.208</b>	<b>0.525</b>
<b>Combustor DP/P</b>	<b>-0.010</b>	<b>-0.009</b>	<b>-0.026</b>	<b>0.207</b>
<b>Nitrogen Diluent Flow</b>	<b>0.020</b>	<b>0.192</b>	<b>0.294</b>	<b>-3.869</b>
<b>Diluent Supply Temperature</b>	<b>0.063</b>	<b>-0.055</b>	<b>-0.058</b>	<b>0.715</b>
<b>Syngas Supply Temperature</b>	<b>0.030</b>	<b>-0.110</b>	<b>-0.078</b>	<b>0.840</b>
<b>Air Extraction</b>	<b>-0.003</b>	<b>-0.087</b>	<b>-0.154</b>	<b>0.044</b>

Results show that gas turbine Firing Temperature, Turbine & Compressor Efficiency, Diluent Supply Temperature, Compressor Pressure Ratio and Cooling Flows have the maximum impact on IGCC net efficiency.

IGCC net output was most impacted by Firing Temperature, Compressor Inlet Air Flow, Turbine & Compressor Efficiency, Compressor Pressure Ratio and Dilution Flow respectively.

Gas Turbine Output was most impacted by Firing Temperature, Turbine & Compressor Efficiency and Compressor Inlet Air respectively.

Combustion Technology (Diffusion or Premix), Diluent flow, Firing Temperature and Compressor Pressure Ratio have the most impact on NOx Emissions.

The analysis results indicate that IGCC performance is most influenced by gas turbine internal design parameters such as Firing Temperature, Turbine and Compressor geometry, Combustion and Cooling technology. IGCC cycle integration parameters such as Fuel and Diluent Flow and supply conditions have secondary impact except for NOx emissions.

#### **Task 4.2: - Perform Design Trade-off Analysis**

Eighteen new gas turbine cycle designs were selected in Task 3.3 for conducting IGCC plant performance trade-off studies. These studies utilized IGCC System Performance Simulation Model developed in task 3.2. Tables 12 through 14 show IGCC summary performance of these cases. Results indicate that IGCC efficiency gains up to 2.8 pts, from 40.5% to 43.3% and IGCC net output gains up to 35 % are possible due to improvements in gas turbine technology alone with single digit NOx emission levels.

**Table 12: IGCC Summary Performance of Gas Turbine Cycle Design Cases 1 thru 6**

Stream	Description	Units	Case 01	Case 02	Case 03	Case 04	Case 05	Case 06
CC Power		kW	750100	759800	600500	624000	608700	760100
Aux Power								
ASU		kW	100400	81700	33700	54300	48900	81700
Gasification		kW	14500	13500	11500	11900	11300	13500
CC Plant		kW	12200	12500	11000	9700	10700	12500
Net Power		kW	623000	652100	544300	548100	537800	652400
Feed Q (HHV)		MMbtu/hr	5080	5212	4424	4587	4347	5213
Net Heat Rate (HHV)		Btu/kW-hr	8154	7993	8127	8369	8083	7990
Net Efficiency (HHV)			41.88%	42.73%	42.02%	40.81%	42.25%	42.74%
Net Heat Rate (LHV)		Btu/kW-hr	7876	7721	7850	8084	7808	7718
Net Efficiency (LHV)			43.36%	44.23%	43.51%	42.25%	43.74%	44.25%
<b>GT Parameters</b>		<b>Units</b>						
Combustor Type			Diffusion	Diffusion	Diffusion	Diffusion	Premix	Premix
Tfire		F	2400	2500	2500	2500	2500	2500
Texh		F	1100	1200	1200	1200	1200	1200
Stack NOx		ppmvd@15% O2	15	9	15	9	9	9
GT Spec Output		kW-s/lb	254.4	255.0	189.0	263.5	209.9	255.2
IGCC Spec Output		kW-s/lb	165.3	173.0	144.4	171.3	151.6	173.1
CC LHV % Eff			65.84%	65.04%	60.46%	60.70%	62.35%	65.06%
Exh Dp		in H2O	-15.0	-15.9	-15.9	-16.1	-16.1	-15.0

**Table 13: IGCC Summary Performance of Gas Turbine Cycle Design Cases 7 thru 12**

Stream	Description	Units	Case 07	Case 08	Case 09	Case 10	Case 11	Case 12
CC Power		kW	875500	605500	598600	665400	611200	752900
Aux Power								
ASU		kW	122300	30200	40900	96200	49400	79800
Gasification		kW	15000	11500	11400	11700	11400	13300
CC Plant		kW	13600	11100	11000	10900	10800	12200
Net Power		kW	724600	552700	535300	546600	539600	647600
Feed Q (HHV)		MMbtu/hr	5782	4437	4388	4501	4396	5140
Net Heat Rate (HHV)		Btu/kW-hr	7980	8027	8197	8235	8147	7936
Net Efficiency (HHV)			42.80%	42.55%	41.66%	41.47%	41.92%	43.03%
Net Heat Rate (LHV)		Btu/kW-hr	7708	7754	7918	7954	7870	7666
Net Efficiency (LHV)			44.31%	44.05%	43.13%	42.93%	43.40%	44.55%
<b>GT Parameters</b>		<b>Units</b>						
Combustor Type			Premix	Premix	Diffusion	Diffusion	Premix	Premix
Tfire		F	2500	2550	2400	2400	2400	2550
Texh		F	1200	1200	1100	1100	1100	1200
Stack NOx		ppmvd@15% O2	9	9	15	15	15	9
GT Spec Output		kW-s/lb	303.0	191.5	189.9	266.0	198.5	255.0
IGCC Spec Output		kW-s/lb	192.3	146.7	142.0	170.2	143.2	171.8
CC LHV % Eff			67.62%	60.78%	60.70%	65.90%	61.85%	65.44%
Exh Dp		in H2O	-15.0	-16.1	-15.0	-15.0	-15.0	-15.0

**Table 14: IGCC Summary Performance of Gas Turbine Cycle Design Cases 13 thru 18**

Stream	Description	Units	Case 13	Case 14	Case 15	Case 16	Case 17	Case 18
CC Power	kW		777700	784800	773500	700000	728700	691900
Aux Power	kW							
ASU	kW		55500	86100	83000	50700	78700	74700
Gasification	kW		14300	13900	13600	12800	13500	12700
CC Plant	kW		13200	12600	12700	12000	10700	10100
Net Power	kW		694700	672200	664200	624500	625800	594400
Feed Q (HHV)	MMbtu/hr		5537	5352	5239	4930	5213	4883
Net Heat Rate (HHV)	Btu/kW-hr		7970	7962	7888	7894	8329	8215
Net Efficiency (HHV)			42.85%	42.89%	43.29%	43.26%	41.00%	41.57%
Net Heat Rate (LHV)	Btu/kW-hr		7698	7691	7620	7625	8046	7935
Net Efficiency (LHV)			44.36%	44.41%	44.82%	44.79%	42.45%	43.04%
<b>GT Parameters</b>		<b>Units</b>						
Combustor Type			Premix	Premix	Premix	Premix	Diffusion	Diffusion
Tfire	F		2550	2600	2600	2650	2400	2500
Texh	F		1200	1200	1200	1200	1100	1200
Stack NOx	ppmvd@15% O <sub>2</sub>		9	9	9	9	2	2
GT Spec Output	kW-s/lb		215.0	267.8	260.9	229.4	300.3	329.1
IGCC Spec Output	kW-s/lb		155.3	178.4	176.2	165.7	186.5	203.8
CC LHV % Eff			62.70%	65.56%	65.98%	63.42%	62.38%	63.29%
Exh Dp	in H <sub>2</sub> O		-15.0	-15.0	-16.1	-16.1	-15.0	-15.0

## **Task 5 - Results/Discussion:**

**Overview:** Various GT cycle designs were examined utilizing the performance results to select the most promising candidate cycle concepts. The 3 most promising GT candidates are recommended on the basis of their merit on IGCC Efficiency, IGCC Net Output, GT Specific Output and NOx Emissions. For near term (2006): the recommended GT cycle design should have a 2400F class firing temperature, base class compressor pressure ratio (CPR), diffusion combustor and integrated air extraction; for midterm (2008): a 2500F class firing temperature, base class CPR, diffusion combustor, and integrated air extraction; and for long term (2010): a 2600F class firing temperature, increased CPR, and further combustion and hot gas path technology enhancements. A roadmap of turbine technology development leading to DOE IGCC efficiency goal of 50%, less than \$1000/kw cost and NOx emissions less than 3 ppm is presented.

### **Task 5 - Discussion:**

Results of the Trade-Off Analysis utilizing 18 Conceptual Design Options have been used to produce the most promising candidate GT Cycle Design Concepts which best meet DOE goals for this study. The GT Cycle Design Concepts were analyzed relative to Overall IGCC Efficiency, IGCC Specific Power, GT Specific Power, NOx Emissions and shown in Figure 8.






Figure 8: IGCC Plant Performance of GT Design Options

One way to select gas turbine is to analyze the IGCC Efficiency against GT Specific Output as shown in Figure 9 for various GT options. The higher the IGCC efficiency and GT Specific Output, the design option will result in higher cost effective machine.



**Figure 9: IGCC Net Efficiency vs. GT Specific Output for various GT options**


Another way to select gas turbine is to analyze the IGCC Specific Output against GT Specific Output as shown in Figure 10 for various GT options. The higher the IGCC specific output and GT Specific Output, the design option will result in higher cost effective machine.



**Figure 10: IGCC Specific Output vs. GT Specific Output for various GT options**

When IGCC Efficiency and IGCC Output have equal importance, the GT options can be selected as the option, which would give both of these higher values as shown in Figure 11.


### Optimized IGCC Cycle Selection



**Figure 11: IGCC Net Efficiency vs. IGCC Specific Output for various GT options**

As GT Cycle Firing temperature increases from 2300F to 2600F, IGCC plant efficiency increases and IGCC Specific Output also increases. An optimum GT cycle selection path is shown in Figure 11, based on increased GT technology development required.

**Turbine Technology Development Roadmap:** A roadmap of gas turbine technology and development is required to advance beyond today's state-of-the art performance, economics, and emissions for coal based IGCC power plants. Today's IGCC technology delivers 40% efficiency, low double-digit NOx, and competitive COE. Future targets and technologies have been proposed to reach 50% HHV efficiency, with lower capital cost and COE performance, while isolating CO2 and producing less than 3ppm NOx. The recommended technology roadmap is shown in Figure 12.



**Figure 12: Turbine Technology Roadmap for future coal-based IGCC**

## **Near-Term Developments**

Near-term, high efficiency can be accomplished by improving GT cycle technology through conventional means of increased firing temperature and pressure ratio, and through advanced cycle integration concepts. Increased firing temperature, CO<sub>2</sub> sequestration, and lower NO<sub>x</sub> targets all cause additional demands on combustion and turbine technologies related to high-hydrogen combustion and turbine durability. These two challenges are common to the next generations of high technology and very low emissions turbine power plants envisioned by power generation researchers and industry.

High efficiency for the 7FB IGCC will be achieved by performing a system optimization of the integrated cycle, by analyzing the impact of technologies and design choices on performance, reliability, and Cost of Electricity. Further advances in turbine cooling and materials technology will provide significant improvements toward performance and economic objectives: such as allowing increased firing temperature at a given NO<sub>x</sub>, and reducing turbine cooling flows. Advances are needed in the state-of-art combustor from a diffusion-flame to pre-mix fuel nozzle, improving NO<sub>x</sub> characteristics on syngas and carbon free high Hydrogen fuels. Current IGCC gas turbine practice involves injection of dilution gas, typically nitrogen or steam, into a diffusion-flame combustor in order to mitigate NO<sub>x</sub> emissions. As NO<sub>x</sub> limits are reduced to the 2ppm DOE goal, large amounts of steam will be required for diluent, as nitrogen will not be adequate. Without corresponding combustor improvements, the NO<sub>x</sub> is most effectively reduced by injecting steam, reducing turbine life by increasing water content and heat transfer. Other methods of improving high H<sub>2</sub> combustion performance such as Trapped vortex/ Rich Catalyst/ Exhaust gas Recirculation may also be required to achieve less than 3 ppm NO<sub>x</sub> emission goals. Ceramic Matrix Composite (CMC) components will provide additional performance advantages in this environment. Not only do CMCs require less cooling than metallic parts in current turbine environments, they will consume less incremental cooling as gas path heat capacity increases from higher moisture and higher firing temperature.

## **Long-Term Developments**

Long-term coal based IGCC cycles will optimize around improved technologies in all areas of combustion, turbine, air separation unit (ASU), CO<sub>2</sub> separation, gasifier, and process island technologies.

There is potential for additional benefit through increased cycle integration using components such as intercoolers, recuperators, and by incorporating novel ideas such as exhaust gas recirculation, reheat combustion, and variable inlet oxygen content. These concepts will present new challenges with regard to risk, costs, startup and transient performance, control and flexibility criteria.

The roadmap shows FutureGen demos in 2010 and 2015. The 2010 configuration would include diffusion-flame combustion with diluent injection and an SCR, using the 7FB optimized for near-term market needs and with the best available injector technologies. The 2015 demo would include features of the advanced combustion systems, with better performance while running on higher hydrogen content. Other aspects of the test would include advanced HGP material and

cooling strategies. The cycle efficiency of these units would demonstrate both progress along the efficiency and emissions roadmap, but also the enabling capabilities required for higher hydrogen turbines proposed for longer-range development.

## **Task 6 - Results/Discussion:**

**Overview:** High Hydrogen fueled Gas turbine performance model was created for an integrated IGCC with newly created models of variable Carbon capture and removal subsystems. IGCC Performance impact of 85% and 88% CO<sub>2</sub> removal levels were analyzed for 2300F class and 2500F class gas turbines. Performance penalty as compared to gas turbine designs without carbon capture are studied and reported.

### **Task 6 - Discussion:**

Performance analysis modeling was completed of a high Hydrogen fueled gas turbine based Oxygen blown IGCC power plant using a conventional system of carbon removal from syngas. The system modeled consists of conversion of carbon monoxide in the moisturized syngas to carbon dioxide and hydrogen by utilizing shift catalyst, and later removal of carbon dioxide by Selexol solvent in Acid Gas Removal unit, as shown in Figure 13 below:




Figure 13: Simplified IGCC Cycle with CO<sub>2</sub> Capture

The performance penalty for carbon removal in the IGCC plant model was minimized by first moisturizing and shifting in the low temperature sour gas shift reactors operated at 400F and subsequently cooling of the syngas in two stages. Carbon dioxide recovery in the model was varied by changing the number of separation columns, amount and temperature of Selexol absorbent in the Acid Gas Removal Unit. Cleaned syngas fuel to gas turbine contained mostly hydrogen together with unconverted carbon monoxide, unremoved carbon dioxide and methane. Figure 14 shows % of total input carbon removal by varying CO<sub>2</sub> removal rate and level of shift. It was determined that carbon removal rate of greater than 88% was not practical due to

significant amount of methane (about 6% of dry syngas and 7% of carbon content) in the fuel to gas turbine, which could not be removed in the gas shift or in Acid Gas removal process.




Figure 14: Carbon Removal From O2 Blown IGCC Power Plant

Figure 15 shows the relationship between % gas shift and % moisturization of syngas. It is clear that increasing moisturization above 45% provides limited improvement in gas shift. A practical upper limit of conventional gas shift appears to be 98%.




Figure 15: Shift conversion rate vs. % Saturation of Syngas

Figure 16 shows increase in auxiliary power required with increase in desired carbon dioxide removal rate for Selexol solvent. The auxiliary power consumption and the associated cost of AGR equipment increases linearly with carbon dioxide removal rate up to a level of 90%. This technology has an upper limit of 97% on carbon dioxide removal level, based on a practical limit on the number of carbon dioxide removal columns (assumed to be three). It is recommended that a different carbon dioxide removal technology such as cryogenic CO<sub>2</sub> separation or membrane be used beyond a carbon dioxide removal level of 97%.




Figure 16: Auxiliary Power Consumed vs. % CO<sub>2</sub> Removal in AGR Unit

The detailed IGCC model configuration with all major streams modified to model a 207FA+e and 207FB based IGCC plants and incorporating additional changes for variable Carbon capture and removal is shown in Figure 17.




Figure 17: IGCC Performance model incorporating variable Carbon capture and removal

The results of gas turbine fuel gas analysis for carbon capture levels of 85% and 88% for the IGCC plant are shown in Table 15 below. It should be noted that the gas turbine fuel hydrogen content has increased from about 26% by volume for no Carbon Capture case to greater than 71% for Carbon capture cases, while fuel Carbon monoxide and Carbon dioxide content by volume has reduced from roughly 44% and 10% for no Carbon Capture cases to about 2% for Carbon capture cases. However, fuel mass heating value has increased substantially from roughly 4550 Btu/lb to 12000 to 13000 Btu/lb resulting in large reduction in gas turbine fuel flow.

Syngas Component	Volume %	
	85% Carbon Conversion	88% Carbon Conversion
H <sub>2</sub>	71.34	73.16
CO	2.04	1.25
CH <sub>4</sub>	4.44	4.50
CO <sub>2</sub>	2.92	1.80
N <sub>2</sub>	1.15	1.17
Ar	1.11	1.12
H <sub>2</sub> O	17.00	17.00
Total S (ppm)	20.6	20.7
Heating Value Btu/Lb	11780	13010

Table 15: Gas Turbine Fuel Composition for 85% and 88% Carbon removal

IGCC performance summary of the four gas turbine cycle design cases with 85% and 88% Carbon removal and 2300 F and 2500F class firing temperature cases is presented in Table 16. With most of the carbon removed from the fuel, its heating value has increased by a factor of three resulting in a fuel flow decrease by the same order. This results in large reduction of specific output of both the gas turbine and net IGCC power plant. Similarly, energy losses due to saturation of syngas, resulting chemical shift of Carbon monoxide to Carbon dioxide and Hydrogen, and auxiliary power required to capture and remove carbon dioxide all result in reduced net IGCC efficiency.

The results show larger IGCC performance penalty for gas turbine designs with higher firing temperature and higher Carbon removal. A 2500 F class gas turbine with 85% CO<sub>2</sub> removal shows a net output penalty of 6.5% and a net efficiency penalty of 6% vs. 2300 F class gas turbine at net output penalty of 4.7% and a net efficiency penalty of 5.5%, while at 88% Carbon removal, 2500F class gas turbine shows a net output penalty of 8.4% and a net efficiency penalty 7% as compared to 2300F class gas turbine with net output and net efficiency penalty of 6.4%.

<u>Stream</u>	<u>Description</u>	<u>Units</u>	<u>Tfire 2300 - 85% Removal</u>	<u>Tfire 2500 - 85% Removal</u>	<u>Tfire 2300 - 88% Removal</u>	<u>Tfire 2500 - 88% Removal</u>
CC Power		kW	613900	741600	605800	727100
Aux Power						
ASU		kW	79800	94400	80400	95300
Gasification		kW	21500	24800	21700	24900
CC Plant		kW	10900	12400	10800	12100
Net Power		kW	501700	610000	492900	594800
Feed Q (HHV)		MMbtu/hr	4900	5658	4920	5674
Net Heat Rate (HHV)		Btu/kW-hr	9768	9276	9981	9539
Net Efficiency (HHV)			34.96%	36.82%	34.22%	35.80%
Net Heat Rate (LHV)		Btu/kW-hr	9435	8960	9641	9214
Net Efficiency (LHV)			36.20%	38.12%	35.42%	37.06%
<b>GT Parameters</b>		<u>Units</u>				
Combustor Type			Diffusion	Diffusion	Diffusion	Diffusion
Tfire		F	2300	2500	2300	2500
Texh		F	1069	1133	1069	1131
Stack NOx	ppmvd@15% O2		12	17	12	18
GT Spec Output	kW-s/lb		212.7	254.9	212.8	254.7
IGCC Spec Output	kW-s/lb		135.4	161.9	133.1	157.8
CC LHV % Eff			62.55%	65.64%	61.74%	64.48%
Exh Dp	in H2O		-15.0	-15.0	-15.0	-15.0

Table 16: IGCC Summary Performance of Gas Turbine Cycle Design Cases with 85 and 88% Carbon removal

# Conclusions and Recommendations

## Conclusions:

### **Task 1 - Overall IGCC Plant Level Requirements Identification:**

Plant level (power island) requirements were identified, and compared with DOE's IGCC Goal of achieving 50% Net HHV Efficiency and \$1000/KW by the Year 2008, through use of a Quality Functional Deployment (QFD) Tool. This analysis resulted in the following 7 Gas Turbine System Level Parameters being selected as the most significant for further analysis of IGCC system Requirements at the power island level:

- 1) Availability
- 2) Product Cost per kW
- 3) Efficiency
- 4) Air Integration Flexibility
- 5) Syngas Supply Conditions
- 6) Diluent Supply Conditions
- 7) Syngas NO<sub>x</sub> Capability

### **Task 2 – Requirements Prioritization & Flow-Down to Gas Turbine Subsystem Level**

Gas turbine requirements were identified, analyzed and prioritized relative to achieving plant level goals, and compared with the flowdown of power island goals through use of a Quality Functional Deployment (QFD) Tool. This analysis resulted in the following 11 Gas Turbine Cycle Design Parameters being selected as the most significant for analysis of Baseline and other IGCC system configurations:

- 1) Firing Temperature
- 2) Combustor Options
- 3) Turbine Efficiency
- 4) Compressor Efficiency
- 5) Compressor Pressure Ratio
- 6) Cooling Flows
- 7) Percent Air Extraction
- 8) Syngas Supply Temperature
- 9) Diluent Supply Temperature
- 10) Compressor Air Flow
- 11) Diluent Flow

### **Task 3 – IGCC Conceptual System Analysis**

A Baseline IGCC Plant configuration was chosen, and an integrated IGCC simulation analysis model was constructed to successfully validate the Baseline IGCC Plant Model against published

performance data. The baseline model was optimized by including air extraction heat recovery and GE steam turbine model with appropriate last stage buckets.

Baseline IGCC based on GE 207FA+e gas turbine combined cycle has net HHV efficiency of 40.5% and net output nominally of 526 Megawatts at NOx emission level of 15 ppmvd@15% corrected O2.

Eighteen Advanced F technology gas turbine cycle design options were developed to provide performance targets with increased output and/or efficiency with low NOx emissions for IGCC systems by varying the selected system parameters such as Air Integration Method, ASU type, Diluent Method, and Fuel Temperature, as well as gas turbine parameters such as Combustor Type, Hot Gas Path Configuration, Firing Temperature and Target NO<sub>x</sub> Level.

#### **Task 4 – Gas Turbine Cycle Options vs. Requirements Evaluation**

Influence coefficients on four key IGCC plant level performance parameters namely, net efficiency, net output, gas turbine output and NOx emissions of the 11 gas turbine cycle parameters were determined. IGCC net efficiency was most impacted by gas turbine Firing temperature, turbine & compressor efficiency, diluent supply temperature, compressor pressure ratio and turbine cooling flows. IGCC net output was most impacted by Firing temperature, compressor inlet airflow, turbine & compressor efficiency, compressor pressure ratio and dilution flow respectively. IGCC Plant NOx emissions were most influenced by gas turbine combustion technology (Diffusion or Premix), Diluent flow, Firing temperature and compressor pressure ratio.

A total of 18 new gas turbine cycle options based on Advanced F technology have been analyzed. Results indicate that IGCC net efficiency HHV gains up to 2.8 pts, from 40.5% to 43.3% and IGCC net output gains up to 35 % are possible due to improvements in gas turbine technology alone with single digit NOx emission levels.

#### **Task 5 – Gas Turbine Technology Improvement Recommendations**

Various GT cycle designs were examined utilizing the performance results to select the most promising candidate cycle concepts. The 3 most promising GT candidates are recommended on the basis of their merit on IGCC Efficiency, IGCC Net Output, GT Specific Output and NOx Emissions. For near term (2006): the recommended GT cycle design should have a 2400F class firing temperature, base class compressor pressure ratio (CPR), diffusion combustor and integrated air extraction; for midterm (2008): a 2500F class firing temperature, base class CPR, diffusion combustor, and integrated air extraction; and for long term (2010): a 2600F class firing temperature, increased CPR, and further combustion and hot gas path technology enhancements.

A Turbine technology roadmap is presented, which will lead to coal based IGCC goals of 50% in efficiency, less than \$1000/kW in cost and NOx emissions less than 3 ppm.

## **Task 6 - Carbon Capture Impact on IGCC Plant Level Performance**

The results show that IGCC performance penalty for gas turbine cycle designs with higher firing temperature and higher Carbon removal is larger than for current gas turbine designs. A 2500 F class gas turbine with 85% CO<sub>2</sub> removal shows a net output penalty of 6.5% and a net efficiency penalty of 6% vs. 2300 F class gas turbine at net output penalty of 4.7% and a net efficiency penalty of 5.5%, while at 88% Carbon removal, 2500F class gas turbine shows a net output penalty of 8.4% and a net efficiency penalty 7% as compared to 2300F class gas turbine with net output and net efficiency penalty of 6.4%.will be limited to show performance effects of gas turbine for carbon capture level of 85% to 88% on this particular gasification process of an IGCC plant.

## **Recommendations**

The 3 most promising GT candidates are recommended on the basis of their merit on IGCC Efficiency, IGCC Net Output, GT Specific Output and NO<sub>x</sub> Emissions. For near term (2006): the recommended GT cycle design should have a 2400F class firing temperature, base class compressor pressure ratio (CPR), diffusion combustor and integrated air extraction; for midterm (2008): a 2500F class firing temperature, base class CPR, diffusion combustor, and integrated air extraction; and for long term (2010): a 2600F class firing temperature, increased CPR, and further combustion and hot gas path technology enhancements.

High Carbon capture and removal rate (85% or higher) results in high Hydrogen content fuel in the gas turbine with significant performance penalty for a coal fired IGCC in terms of its net output and efficiency. Gas turbine cycle designs with higher firing temperatures have larger performance penalty and need further design optimization to reduce the performance loss and cost impact on IGCC power plants. Gas turbine design changes in terms of turbine hot gas path and the cycle design parameters will be required to minimize the reduction in specific output and net efficiency due to high Hydrogen content of the carbon free syngas fuel.

## **References**

1. Integrating Clean Coal Technologies and Cogeneration Opportunities with Industrial Land Reuse”, Nordic Energy of Ashtabula LLC, Department of Energy Program Solicitation No. DE-PS26-02NT41428, August 2002.

## **List of Acronyms and Abbreviations**

**AGR** - Acid Gas Removal sulfur removal sub-system

**ASU** - Air Separation Unit oxygen plant sub-system

**CPR** - Compressor Pressure Ratio

**EP** - Elevated Pressure Air Separation Unit

**FB** - GE's Advanced Air cooled Turbine

**GT** - Gas Turbine

**HHV** - Fuel Higher Heating Value

**HGP** - Hot Gas Path

**HRSG** - Heat Recovery Steam Generator

**IGCC** - Integrated Gasifier Combined Cycle power plant

**LP** - Low Pressure Air Separation Unit

**LTGC** - Low Temperature Syngas Cooling Unit

**NOx** - Gaseous mixture of Nitrogen Oxides

**SCR** - Selective Catalytic Reduction

**QFD** - Six Sigma Quality Functional Deployment analysis system

